

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1005	391	BRGPR	1102	1363	88.98
1006	767	MDTHN	1703	609	88.83
1007	2089	HSKAV	0003	1420	88.82
1008	832	CDHCR	2052	1405	88.82
1009	1997	ELGIN	1002	2621	88.71
1010	1309	TROYS	1014	1321	88.49
1011	2315	HORNE	1972	766	88.45
1012	2097	ADISN	1601	636	88.34
1013	880	MABNK	2402	979	88.26
1014	339	ATHNW	1404	1366	88.12
1015	1039	HOLDY	0911	1162	87.94
1016	2726	NLNVL	2001	420	87.93
1017	677	PCUST	2012	1813	87.85
1018	932	FLINT	3211	2289	87.54
1019	535	COLDG	4047	411	87.42
1020	441	TYLNE	1623	510	87.34
1021	1133	LRENA	2901	992	87.16
1022	1262	ALVDO	1902	928	87.09
1023	392	AMMFG	5631	1225	86.99
1024	478	BOWEN	3192	1264	86.96
1025	1028	DNIWS	1601	892	86.62
1026	438	MDFRM	2131	11	86.42
1027	1893	HMTRD	0001	967	86.27
1028	2634	ARTHR	0441	1891	86.24
1029	793	WXNTH	2303	2224	86.23
1030	684	SWDTN	1611	1488	86.23
1031	2641	SHDYG	7811	379	86.20
1032	275	TYBLR	2811	1124	86.17
1033	1101	IRVGS	1903	882	86.15
1034	266	IRVBL	2504	1585	86.07
1035	2313	PRSTN	0003	2960	86.00
1036	1991	WDGWD	1512	828	85.95
1037	806	HSKAV	0001	1077	85.78
1038	1908	OVRTN	4015	626	85.56
1039	1574	CRLJL	1503	752	85.55
1040	2268	SYCRK	4512	4161	85.40
1041	1120	SMFLD	2313	2128	85.33
1042	2036	REAST	1504	1294	85.32
1043	2954	JREST	2103	267	85.22
1044	1245	MABNK	2401	2132	85.15
1045	2720	DENDR	0006	44	85.09
1046	375	GNSVE	1602	1737	84.96

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1047	155	BNBOR	1201	752	84.94
1048	696	PCUST	2007	1393	84.88
1049	106	KEYSB	2621	16	84.88
1050	2087	SMFLD	2391	292	84.86
1051	116	CRANE	0321	23	84.68
1052	957	FINKS	1803	1345	84.65
1053	2706	SSPNE	1402	69	84.58
1054	1883	BRCKR	6533	1833	84.55
1055	2328	NMAIN	0231	318	84.54
1056	2513	HRSMD	1951	4461	84.50
1057	346	CMPST	0004	1586	84.37
1058	1095	GRDPR	0811	1216	84.34
1059	876	OKLND	0002	1261	84.29
1060	2563	RICES	0206	656	84.18
1061	379	MNHNS	1921	1848	84.14
1062	529	LGVST	8521	1761	84.00
1063	571	LNDAL	2202	1239	83.96
1064	378	IRVVV	2803	154	83.92
1065	184	TYWST	2012	2147	83.91
1066	1324	HUDSN	1604	1760	83.86
1067	1389	BONHM	1206	2111	83.80
1068	2138	PREST	1602	1413	83.76
1069	2878	MDDTN	4331	1835	83.75
1070	1116	BONHM	1202	737	83.73
1071	2510	MRLNS	4002	411	83.69
1072	1091	RWALL	1204	1064	83.62
1073	2299	WALST	0006	10	83.58
1074	1905	GRHWY	5522	1728	83.55
1075	2679	HLTOM	2472	1812	83.55
1076	2616	BRNAV	0732	798	83.54
1077	1976	RSNHT	1122	2027	83.49
1078	1822	DEALY	0002	1465	83.43
1079	1013	IRVNR	1559	2599	83.32
1080	1418	GRDPR	0871	1569	83.30
1081	32	TYLNW	1910	609	83.12
1082	930	KLNPS	1101	2291	83.10
1083	399	WDGWD	1541	1133	82.99
1084	189	WHOUS	4121	1333	82.94
1085	2181	MNWLL	1204	286	82.90
1086	2537	BKWST	0002	1667	82.89
1087	117	RVRFT	0003	908	82.66
1088	1413	CAMRN	1201	1032	82.63

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1089	1350	KIMBL	5012	1013	82.58
1090	2148	BDFRD	8831	877	82.57
1091	2210	EULSO	9131	1977	82.56
1092	1702	FSTVW	0008	1814	82.54
1093	89	TSLVL	4001	1275	82.44
1094	1347	MSLSW	0005	1023	82.43
1095	1424	DALLW	0004	1323	82.41
1096	2163	DFWSW	2209	42	82.40
1097	2037	SANSM	3922	1837	82.24
1098	1462	PFFRD	3482	1087	82.12
1099	226	TYSTH	1209	814	82.01
1100	2584	CTYVW	2221	1829	81.87
1101	2051	WEBBS	8611	2610	81.81
1102	286	WALST	0009	817	81.73
1103	861	ARMST	0002	1685	81.69
1104	2803	COVEE	3403	1356	81.45
1105	2007	MESFR	2105	1049	81.42
1106	1703	RKDLN	1401	934	81.31
1107	1002	MRDCK	0003	1267	81.29
1108	387	IRVGS	1902	1496	81.29
1109	1287	HNYGR	2402	159	81.22
1110	1027	SCYEN	0002	1282	81.14
1111	992	IRVNE	1310	1421	81.04
1112	967	DNCNV	1901	891	81.02
1113	2218	CRTLD	4723	2326	81.01
1114	2723	PROAD	0004	991	80.96
1115	1879	LIGSW	1607	1435	80.86
1116	1772	DAVST	0005	1828	80.79
1117	1190	ABRRD	0002	1372	80.77
1118	288	RECCR	0001	163	80.75
1119	197	PCOIT	1001	1233	80.59
1120	2769	BLMND	3252	1138	80.56
1121	240	CNTRY	2823	1864	80.52
1122	2013	IRVBL	2501	387	80.47
1123	2151	SALSW	3004	1377	80.36
1124	1928	KLRPR	9021	2022	80.28
1125	2229	DNCNV	1905	1328	80.22
1126	1546	GAVSW	0006	522	80.11
1127	1869	RECCR	0004	71	80.03
1128	2077	RCLNS	1405	639	80.03
1129	973	SHDYG	7842	728	79.74
1130	878	CANTN	1303	860	79.72

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1131	2652	LMBLN	0004	50	79.64
1132	1588	GORMN	0421	353	79.55
1133	1491	CNEXP	0006	1213	79.53
1134	516	CRLJL	1504	1285	79.50
1135	1818	WCOLO	1315	1585	79.50
1136	2450	CRSCN	1204	618	79.47
1137	1060	WNRTH	1417	1395	79.45
1138	27	BRGPR	1103	900	79.43
1139	631	NLNVL	2003	691	79.37
1140	855	BLTLN	0006	926	79.36
1141	1626	RCHHL	0332	1713	79.26
1142	2477	HLSBR	1202	1224	78.95
1143	660	BMTWN	1621	1432	78.92
1144	131	VANSB	1502	1666	78.78
1145	1932	WNDWD	3611	297	78.78
1146	1710	NSTAR	2011	524	78.73
1147	1914	COPEL	3056	2811	78.69
1148	960	MESQT	1308	1880	78.46
1149	2834	BLTSW	3205	1439	78.35
1150	1261	SCYEN	0003	1974	78.33
1151	2025	MCGRG	0775	527	78.31
1152	1986	EDGCF	2241	929	78.16
1153	760	OAKHL	3031	624	78.10
1154	1238	BNDRA	0007	504	78.06
1155	1167	GVODS	3062	1978	77.97
1156	122	MEANS	4411	37	77.95
1157	1695	FORSW	2051	4026	77.73
1158	2844	BAGWL	1202	48	77.72
1159	2427	CRLJL	1502	391	77.72
1160	232	CRSGL	1306	644	77.71
1161	1450	MLKF2	1201	1837	77.68
1162	1222	WRBND	2312	1443	77.65
1163	925	EDGCF	2213	3188	77.64
1164	1657	MDLNW	1541	2294	77.62
1165	1346	TMPLE	1201	1656	77.61
1166	530	MDWCK	0007	1081	77.56
1167	1761	CPLND	1101	1056	77.48
1168	2303	CRNTH	2405	3957	77.47
1169	2963	MAPLE	0004	480	77.42
1170	2099	WNDWD	3662	883	77.40
1171	2761	FSTVW	0002	146	77.32
1172	1835	TMNTH	1607	12	77.31

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1173	2420	HKBRY	1117	141	77.29
1174	1236	TYSTH	1202	1056	77.20
1175	1383	WDGWD	1592	1167	77.12
1176	620	JKSNR	4109	651	77.11
1177	1564	GLNHV	3963	1597	77.08
1178	1996	CRLTN	1401	810	77.02
1179	469	RCHHL	0342	1007	76.98
1180	519	HUTCH	1502	203	76.83
1181	2387	RRSTH	1707	609	76.76
1182	352	TYEST	1503	1077	76.75
1183	257	ARMST	0004	1282	76.66
1184	2041	SHLMT	1801	305	76.62
1185	1511	ANDNR	2211	2528	76.58
1186	787	PRKRW	3362	1099	76.53
1187	2055	FSCRK	6712	2562	76.52
1188	2595	SANSM	3913	4118	76.50
1189	2756	ABRRD	0001	1418	76.35
1190	1834	TMSTH	1408	754	76.33
1191	2471	PRKWY	1542	509	76.31
1192	1719	FSTVW	0006	1250	76.31
1193	556	CRLFR	2154	3458	76.04
1194	1478	DESHR	1201	990	75.90
1195	2173	RCHHL	0374	541	75.89
1196	942	MNWLL	1203	885	75.87
1197	1514	PTENN	2358	1440	75.86
1198	334	EZACH	0008	1534	75.82
1199	354	ODESW	5912	335	75.76
1200	2567	BSPRW	2511	760	75.75
1201	1662	BDFRD	8821	889	75.66
1202	1726	CNTRY	2824	3090	75.64
1203	598	BSPRW	2542	751	75.52
1204	2766	CRLUD	1306	26	75.35
1205	287	KFMNW	1201	1020	75.26
1206	804	PTENN	2357	1294	75.21
1207	1055	ADISN	1607	1237	75.03
1208	1977	KNEDL	6342	2123	74.93
1209	883	GRNGR	1801	908	74.90
1210	893	PRKRW	3372	1494	74.83
1211	681	MESFR	2102	676	74.78
1212	1030	KNEDL	6321	2423	74.77
1213	1777	CDHIL	1804	1221	74.68
1214	580	HHSTH	1501	3392	74.62

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1215	1848	CRNTH	2404	2380	74.37
1216	1553	KRUMS	1204	1416	74.24
1217	1751	DCVSO	1101	1478	74.14
1218	2199	RSPVY	1704	1406	74.12
1219	1224	ALLEN	2408	3213	74.10
1220	987	FROKS	0007	1497	73.83
1221	1916	CMPWI	0001	1889	73.72
1222	317	HLTOM	2442	1096	73.61
1223	173	WLWSP	1201	505	73.57
1224	2801	PCOMM	3311	28	73.55
1225	1052	PWEST	1307	945	73.54
1226	1591	CMTSW	0966	124	73.52
1227	2404	JUDCT	0001	1906	73.42
1228	383	GRDPR	0822	627	73.24
1229	1122	SPRDL	4811	1225	73.20
1230	2815	ZEPHR	2404	181	73.04
1231	979	BRCRK	6521	1428	73.03
1232	986	WELRD	0008	1125	72.94
1233	1852	WNDCR	0262	230	72.92
1234	912	THRNE	0005	1351	72.87
1235	1218	WFALS	0133	1672	72.74
1236	496	CRLUD	1305	1368	72.53
1237	1482	SGOVL	1404	2184	72.48
1238	1345	MSTLT	1054	609	72.38
1239	2348	BRCRK	6512	1784	72.34
1240	180	TYOMN	1410	1535	72.24
1241	1234	GVFTW	1801	667	72.14
1242	1737	MESQW	1808	1343	72.10
1243	604	NPKWY	0006	4874	72.07
1244	296	LKMNT	0005	680	72.07
1245	1430	FRFWS	3002	850	72.06
1246	2251	WNDCR	0232	646	72.04
1247	1526	BOWEN	3151	1944	71.85
1248	756	HDWLK	3001	970	71.84
1249	874	BLMND	3231	1227	71.73
1250	70	BKWST	0001	386	71.73
1251	901	JKSBR	1402	1427	71.58
1252	783	PLSTH	1301	722	71.58
1253	1683	DIBOL	1506	613	71.57
1254	849	RWDHV	1906	639	71.48
1255	2517	GAVSW	0012	834	71.27
1256	1837	IRVNG	1405	1163	71.20

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1257	357	CNTRY	2813	3070	71.03
1258	1495	PLKST	0008	1699	70.98
1259	2154	MRLNS	4003	938	70.90
1260	1965	BLMED	1621	2067	70.87
1261	1250	TATSP	4311	1873	70.87
1262	2166	MSTLT	1063	976	70.78
1263	1940	LIPAN	1303	268	70.73
1264	524	IRVNE	1306	1535	70.70
1265	219	WEBBS	8623	2800	70.70
1266	1328	CRLTN	1406	1202	70.68
1267	2597	DFWSW	2203	39	70.67
1268	2890	MCDMT	2553	1926	70.49
1269	472	ENTOH	0002	808	70.46
1270	1180	BRLSN	2052	3010	70.24
1271	227	MTLDA	0002	1783	70.24
1272	415	SCHRD	0001	1029	70.17
1273	281	TYSTH	1201	1132	70.05
1274	541	CDCSW	0002	2369	70.01
1275	2839	PWEST	1302	339	69.98
1276	79	CRANE	0331	1202	69.96
1277	1065	TYLER	1012	1706	69.90
1278	1778	EZACH	0004	1171	69.75
1279	249	RKCRK	6112	2322	69.67
1280	2157	GAVSW	0009	1032	69.65
1281	2473	TMPLE	1202	1362	69.54
1282	2217	CRNRD	0004	480	69.50
1283	575	MRTSP	1504	703	69.41
1284	1860	DAVIS	3711	678	69.21
1285	297	TRLWD	7712	3254	69.17
1286	1867	WHITE	3522	1813	68.95
1287	691	HKHTS	1603	1035	68.90
1288	2837	RGLRW	0008	36	68.89
1289	719	EUSTC	2402	815	68.85
1290	2187	CRTLD	4721	3062	68.78
1291	2526	MDLNW	1513	2469	68.70
1292	1793	IRVND	1201	976	68.61
1293	2796	WELRD	0004	802	68.55
1294	1878	DESHR	1203	1405	68.52
1295	841	BSPRW	2521	1121	68.47
1296	214	RWALS	1853	2350	68.46
1297	2370	HURST	1831	1366	68.44
1298	513	MRSDO	9621	1843	68.43

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1299	2343	RCHRD	1201	1436	68.34
1300	921	MSHLN	0006	1113	68.32
1301	1464	BELLS	1201	573	68.26
1302	1140	WELRD	0001	1220	68.23
1303	1666	ALPHA	0002	1260	68.20
1304	1283	PCOIT	1008	1243	68.15
1305	2931	BLMND	3272	12	68.11
1306	984	LOMAL	0011	1130	68.01
1307	2729	MKNSO	3614	2401	68.00
1308	549	BLKST	1711	1966	67.98
1309	2812	WSOTH	1019	823	67.94
1310	1589	RECCR	0002	97	67.92
1311	2422	RWALE	3326	3032	67.91
1312	554	ALLNC	6411	46	67.77
1313	724	LWSNR	2242	1374	67.76
1314	2283	SPRTN	1802	883	67.75
1315	2032	ARTHR	0452	680	67.73
1316	2810	PROAD	0003	1140	67.45
1317	1193	BLTLN	0007	780	67.45
1318	2027	MLKF2	1202	455	67.28
1319	990	IVANS	1612	1049	67.25
1320	1338	DCVSO	1102	705	67.19
1321	2424	ALLNC	6421	73	67.19
1322	1014	CRSGL	1301	146	67.17
1323	1492	AYERS	4411	1210	67.13
1324	945	KILEN	1205	1329	67.10
1325	776	WDGWD	1581	604	66.99
1326	818	WHOUS	4128	362	66.85
1327	142	REYST	4129	518	66.84
1328	1469	TATSP	4323	2495	66.81
1329	1828	SSPNG	1201	1311	66.80
1330	2421	RCHRD	1206	683	66.78
1331	1313	ALDTU	9421	1764	66.76
1332	650	ELKTN	2506	1688	66.72
1333	1360	GLNHV	3922	730	66.64
1334	400	DENAV	0662	588	66.63
1335	2373	RWDHV	1905	1215	66.49
1336	123	WEBBS	8612	3384	66.48
1337	1736	GODRD	8142	1039	66.34
1338	1974	BSPRG	1903	1700	66.23
1339	1882	BSPRG	1905	1608	66.15
1340	674	BNBRK	4121	5015	66.08

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1341	1836	FRMBR	1803	2408	66.03
1342	2895	TERSO	2503	1097	65.99
1343	1743	KNEDL	6322	3918	65.82
1344	2107	MCGHR	2003	1298	65.80
1345	2352	HRSMD	1907	2662	65.68
1346	439	GODRD	8131	1533	65.67
1347	325	SGOVL	1402	945	65.66
1348	1902	BLTSW	3203	1000	65.65
1349	2318	PALMR	2202	1051	65.63
1350	2174	GRDPR	0892	1319	65.50
1351	1419	RBNSN	2501	1968	65.16
1352	1889	RENSW	3122	1541	65.10
1353	1953	SIKES	2411	2073	65.09
1354	1387	WTAUG	4641	574	65.08
1355	380	HLSES	0553	1930	64.99
1356	2091	GNSVL	1203	1622	64.95
1357	2417	JKSNR	4111	442	64.85
1358	1862	WSTHL	3642	4162	64.73
1359	2039	TATSP	4312	2527	64.66
1360	393	MDTHS	1001	1700	64.62
1361	588	RSKMN	3053	497	64.57
1362	2224	SMFLD	2341	980	64.56
1363	1158	SHDYG	7831	97	64.53
1364	668	BLKST	1742	1729	64.51
1365	1782	CRTLD	4742	920	64.46
1366	576	NCSFA	1706	1185	64.46
1367	2287	ABRRD	0008	1438	64.45
1368	163	REAST	1509	140	64.41
1369	329	DALLW	0001	1149	64.34
1370	770	BRYAN	0004	1301	64.32
1371	710	BNDRA	0004	722	64.06
1372	1558	WNDCR	0211	1183	64.02
1373	54	BNMAG	1201	197	63.99
1374	1500	BLTON	1803	441	63.94
1375	966	IRVVV	2802	1034	63.89
1376	2308	WTHRE	2101	1215	63.81
1377	2080	DLEON	0111	836	63.79
1378	1597	MOSSW	4621	1462	63.63
1379	1247	BNDRA	0011	402	63.37
1380	1633	ROLTR	2922	2467	63.24
1381	1646	PREST	1603	1521	63.21
1382	1740	FINKS	1801	1643	63.19

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1383	2632	CNTRD	0002	1476	63.16
1384	60	CANTN	1302	1348	63.15
1385	1803	CPLSO	4312	1789	63.09
1386	429	TNPON	0001	66	63.01
1387	540	TRNTH	1502	544	62.97
1388	265	PALRD	2201	797	62.96
1389	2642	RCLNS	1401	115	62.95
1390	2276	ARLNG	1251	548	62.93
1391	2123	HLSBR	1203	1643	62.90
1392	221	NCDSW	3813	396	62.87
1393	792	CMTSW	0922	1420	62.80
1394	#N/A	MOSSW	4612	2281	62.75
1395	318	IRVNR	1557	3120	62.65
1396	2242	CPRCV	1407	2205	62.63
1397	422	BNTDR	0002	1784	62.60
1398	910	ADISN	1608	369	62.53
1399	721	SMPST	0002	1458	62.50
1400	365	WSTHL	3652	3207	62.49
1401	1799	ELKHR	1201	959	62.46
1402	1257	EULSO	9111	1843	62.45
1403	2311	CPRCV	1403	1437	62.40
1404	1688	CNSES	0370	1256	62.37
1405	1286	MDTHS	1003	1251	62.29
1406	1129	MKNNY	1254	2366	62.28
1407	701	CMPWI	0003	977	62.13
1408	2386	PRMED	4403	2640	62.06
1409	1508	BSPSW	0841	2117	61.94
1410	1279	TYLGE	1306	2323	61.83
1411	129	PRKRW	3311	1140	61.83
1412	1693	BLKST	1762	1033	61.81
1413	659	IRVNG	1407	1467	61.74
1414	1426	CMPWI	0004	1025	61.70
1415	995	WTAUG	4613	1896	61.53
1416	1438	BDFRD	8832	984	61.50
1417	209	BRLSN	2041	3811	61.28
1418	1136	PLGRV	0001	1201	61.25
1419	1142	MTLDA	0003	1550	61.20
1420	676	GPLND	1201	676	61.18
1421	1443	MESQT	1306	978	61.16
1422	502	CPLSO	4322	279	61.03
1423	1054	PSHIL	1602	1077	61.01
1424	1604	WTAUG	4611	1394	60.97

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1425	309	MDDTN	4312	1173	60.95
1426	974	WHITE	3512	1533	60.92
1427	1299	WESTS	1602	864	60.84
1428	95	LFSTH	1404	513	60.71
1429	2732	CRNSO	3911	301	60.70
1430	2353	BLMND	3221	95	60.66
1431	2496	WHITE	3532	1366	60.66
1432	1237	DALLW	0003	663	60.57
1433	1204	MESTE	1206	1288	60.53
1434	1550	DAVST	0003	1691	60.53
1435	332	MABNK	2403	1661	60.52
1436	2414	DCATR	1205	121	60.47
1437	2320	ODNTH	2053	2350	60.46
1438	1200	SMPST	0001	2088	60.38
1439	2361	WMMMR	2708	250	60.38
1440	1376	PWEST	1301	1253	60.37
1441	490	MKNSW	1601	1603	60.30
1442	738	MURPH	2751	2315	60.26
1443	1092	ATHNW	1403	2244	60.24
1444	566	LOMAL	0003	1055	60.22
1445	785	KRUMS	1201	376	60.18
1446	1506	FRMNT	0013	3105	60.08
1447	1371	DALWT	2991	1222	60.07
1448	1254	TMNTH	1605	1829	60.03
1449	2704	TMPLE	1203	126	59.70
1450	1025	IRVND	1202	1503	59.65
1451	2260	TATSP	4321	1445	59.65
1452	376	CLYVL	9322	2203	59.65
1453	82	MNWLW	1402	1531	59.64
1454	1433	PFFRD	3492	297	59.56
1455	1541	CDHIL	1802	754	59.54
1456	241	SWAN2	1803	1161	59.41
1457	2516	BLMND	3262	122	59.38
1458	1825	BDFWD	8931	1731	59.38
1459	729	MSHLN	0004	1302	59.34
1460	311	LTFRD	3021	899	59.34
1461	1966	LEMON	0006	709	59.28
1462	889	ALPHA	0003	874	59.23
1463	956	EDDYS	0712	1100	59.00
1464	2323	BRNSO	1805	798	58.96
1465	2615	PFLGV	2002	2272	58.93
1466	954	TYEST	1511	881	58.87

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1467	1404	DALWT	2962	473	58.78
1468	2019	DUVAL	0421	1303	58.75
1469	2601	DFWNW	2606	18	58.61
1470	1846	HKHTS	1607	943	58.58
1471	1260	WRBND	2311	1398	58.55
1472	150	ECTHM	3311	1539	58.54
1473	2026	SWDTN	1631	1624	58.47
1474	996	KIMBL	5021	2366	58.44
1475	1856	RECCR	0006	503	58.42
1476	1217	MESQN	1502	1089	58.40
1477	1592	FSTVW	0007	1614	58.40
1478	645	EZACH	0002	1424	58.36
1479	1742	MESQN	1501	1807	58.19
1480	2775	TMPNW	1102	680	58.10
1481	1440	OKLND	0001	1339	58.10
1482	557	CRWLY	7011	424	58.06
1483	633	BNBOR	1202	736	58.04
1484	411	MRTSP	1501	667	58.03
1485	1034	FARON	4072	1541	57.94
1486	1467	IRVNR	1506	2970	57.85
1487	1606	MSHLN	0002	1584	57.85
1488	1907	WNTHW	1120	1035	57.82
1489	2590	SHNRW	1614	954	57.82
1490	1311	RDOAK	1301	2475	57.72
1491	1357	AMLIA	0003	22	57.68
1492	1536	SSPNG	1202	1228	57.59
1493	1747	DUVAL	0473	1602	57.59
1494	2776	BANGS	1201	1498	57.53
1495	355	DCDAM	2001	799	57.52
1496	2611	BDFWD	8912	1008	57.45
1497	1016	COVEE	3405	1431	57.41
1498	777	BDFRD	8811	1703	57.30
1499	1931	MAYFD	5522	3262	57.29
1500	2538	PAYSW	1203	857	57.17
1501	1434	HNRTA	0311	1044	57.14
1502	991	TMPTV	2405	491	57.12
1503	1983	BOWEN	3132	1779	57.12
1504	788	DENDR	0005	404	57.11
1505	1175	LKMNT	0007	1553	57.09
1506	2521	BNDRA	0005	1264	57.06
1507	1178	RCHRD	1204	1141	57.00
1508	1636	TMPNW	1104	1927	56.91

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1509	1368	MEXIA	4012	1112	56.72
1510	1300	WDGWD	1522	1440	56.69
1511	1631	CMTSW	0973	1615	56.61
1512	1578	ADMDS	6521	1593	56.51
1513	969	CRLCC	2704	535	56.48
1514	2088	MRSES	4012	395	56.37
1515	1337	ENSSO	2001	227	56.34
1516	718	MESTE	1202	814	56.24
1517	1302	CNTRY	2851	1504	56.22
1518	2419	BLTSW	3201	2607	56.19
1519	37	MNWLE	1701	672	56.02
1520	1535	GRPVN	8212	4097	56.01
1521	1842	MOSSW	4611	1583	55.96
1522	1152	CRLTR	2054	105	55.93
1523	1303	MDLNW	1511	2588	55.92
1524	2432	DALWT	2982	1031	55.89
1525	1679	ROWLT	1103	1090	55.86
1526	1531	DENAV	0621	1705	55.79
1527	255	BEAST	4082	515	55.78
1528	1216	SSPNG	1205	1130	55.68
1529	1409	BBTWN	1501	1954	55.56
1530	1322	SHLMT	1802	538	55.54
1531	2716	FSCRK	6724	1397	55.36
1532	1890	KLNTF	1805	1339	55.31
1533	2069	PLKST	0003	1303	55.26
1534	366	MLFRD	2103	983	55.16
1535	164	NLNVL	2002	526	55.15
1536	2650	PCOIT	1025	2924	55.05
1537	1477	CRLTN	1407	1571	55.04
1538	302	MYPTX	2401	305	55.01
1539	2169	MRSES	3019	13	55.00
1540	1821	LVOAK	1602	936	54.97
1541	1329	WALST	0003	131	54.86
1542	1038	CDHIL	1613	2979	54.83
1543	2972	PLHWY	3703	14	54.77
1544	468	CRTLD	4724	3179	54.77
1545	870	HUDSN	1602	1707	54.72
1546	1755	EULES	8712	1071	54.68
1547	931	PRSTN	0002	1345	54.64
1548	1172	LKBRN	2402	1173	54.56
1549	1228	GRHWY	5511	1899	54.45
1550	1927	WRTHM	5004	225	54.42

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1551	2542	WHTRK	0005	727	54.42
1552	1096	ALPHA	0013	449	54.33
1553	1664	DAVIS	3721	1323	54.31
1554	989	MSLMN	4131	132	54.25
1555	1470	CLLVL	0003	679	54.14
1556	1652	GODRD	8132	2702	53.98
1557	820	GRPVN	8223	2049	53.95
1558	1929	KEENE	1503	833	53.94
1559	1021	LOMAL	0008	449	53.72
1560	192	RWALS	1852	2767	53.71
1561	369	PLSTH	1304	1310	53.70
1562	2182	KLNPS	1103	2184	53.57
1563	1830	CRLTR	2002	1495	53.54
1564	305	BBTWN	1502	1741	53.42
1565	300	FROKS	0001	1364	53.35
1566	1847	TRNTH	1504	818	53.32
1567	2073	HKHTS	1602	1019	53.29
1568	2415	BOWEN	3112	907	53.28
1569	539	EULES	8732	629	53.26
1570	834	CRLTR	2053	1742	53.24
1571	2317	IRVVV	2851	2972	53.10
1572	158	WINKS	0511	636	53.03
1573	877	ALPHA	0014	515	53.01
1574	2755	ALNTH	2842	1943	52.99
1575	1145	TRPMN	4094	573	52.98
1576	2197	DFWNW	2603	10	52.89
1577	1614	ARTHR	0472	1289	52.89
1578	1671	BDFRD	8842	1465	52.87
1579	2383	KLNTF	1806	1181	52.86
1580	764	SHRSW	6621	1816	52.86
1581	1281	RYSSW	2802	4193	52.85
1582	2506	FRMBG	1752	464	52.67
1583	2188	PALRD	2204	687	52.67
1584	715	DNCNV	1906	406	52.63
1585	1572	BRHLW	7611	1628	52.61
1586	230	MNWLW	1403	926	52.57
1587	336	LSCOL	2138	1057	52.56
1588	611	GODRD	8141	855	52.51
1589	1796	MESTE	1215	1516	52.45
1590	1805	IRVGS	1907	966	52.40
1591	2747	WELRD	0007	442	52.37
1592	1800	PRNTH	1401	1343	52.35

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1593	2059	MESTE	1209	1448	52.35
1594	958	PPARK	1804	247	52.32
1595	752	DESPR	1402	1305	52.29
1596	1035	TYOMN	1405	1662	52.23
1597	#N/A	LKBLT	2103	1915	52.15
1598	955	SMPST	0004	1991	52.15
1599	160	BRTL	1402	122	52.08
1600	2345	PCOIT	1005	1095	52.06
1601	458	MKNSO	3613	3322	52.03
1602	926	MKNNY	1205	507	52.03
1603	279	WALST	0005	249	52.01
1604	2600	WEAST	0617	1403	51.98
1605	1192	BRKRG	0232	1718	51.95
1606	2594	GNSVL	1223	1015	51.90
1607	1988	DNIWS	1602	1429	51.84
1608	1704	GRDPR	0852	1435	51.79
1609	2744	OKCLS	0008	1986	51.76
1610	264	CNTRY	2814	930	51.71
1611	1411	CHNDW	1201	1190	51.65
1612	2212	FSHSW	2121	1702	51.61
1613	1939	CLBRN	1203	1574	51.61
1614	593	PPARK	1808	598	51.57
1615	343	MAYFD	5511	4142	51.57
1616	1017	CRLJL	1508	345	51.56
1617	1547	LVBRD	0008	1761	51.49
1618	1917	MESTE	1207	952	51.41
1619	1466	RRSTH	1706	3691	51.41
1620	128	TYWST	2001	179	51.40
1621	646	EULTB	5721	1770	51.39
1622	1539	KNEDL	6311	2923	51.35
1623	1294	HMPHL	2762	1014	51.25
1624	1537	BLTLN	0003	589	51.13
1625	709	FRMNT	0014	629	51.12
1626	1081	COLNY	2406	811	51.11
1627	1103	CMBTP	1201	261	51.02
1628	694	OAKHL	3041	945	50.90
1629	2443	CLMET	0004	1174	50.90
1630	807	LSCOL	2142	13	50.86
1631	2519	RRSTH	1703	3573	50.83
1632	732	ABRRD	0005	1461	50.70
1633	1554	EULES	8723	5166	50.70
1634	254	TYEST	1507	1279	50.60

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1635	781	WEBBS	8624	2302	50.60
1636	1405	HUDSN	1601	971	50.56
1637	2938	DFWSW	2208	17	50.53
1638	2503	ENTOH	0008	10	50.50
1639	2046	ALNTH	2844	2188	50.43
1640	2772	EULES	8731	1426	50.43
1641	827	CDCSW	0008	725	50.41
1642	1390	ODESA	0251	1891	50.36
1643	1717	SGOVL	1401	1816	50.35
1644	2480	DAVIS	3752	502	50.35
1645	866	SHRSW	6622	1624	50.23
1646	1031	HKBRY	1106	1671	50.21
1647	1074	PKRVL	1052	2361	50.19
1648	864	IRVGS	1901	1388	50.11
1649	489	ODNTH	2034	2782	50.11
1650	1600	CRTLD	4711	3181	50.10
1651	2552	FLMSO	3712	865	50.07
1652	455	SPRDL	4831	1268	50.06
1653	1456	MESQW	1801	2102	50.05
1654	2031	PCOIT	1023	639	50.04
1655	1690	GRLRD	0004	1556	50.04
1656	1042	PRSTN	0008	748	50.00
1657	1625	WTAUG	4652	800	49.97
1658	1808	DNINR	1403	1198	49.95
1659	29	TEGMN	3040	798	49.79
1660	2114	CLCTY	1031	1224	49.79
1661	2717	DAVIS	3762	41	49.72
1662	816	CRNDL	2403	986	49.62
1663	2275	FORSW	2025	549	49.62
1664	1612	LIGSW	1604	720	49.61
1665	2136	WTAUG	4631	1147	49.58
1666	47	NIPAK	1001	131	49.47
1667	1435	TROYS	1013	785	49.46
1668	2754	ENNIS	1901	363	49.42
1669	888	MKNGB	5312	625	49.35
1670	1160	BMTWN	1611	1843	49.35
1671	2474	LNCST	1601	681	49.30
1672	2413	LOMAL	0006	1413	49.06
1673	617	EGFRD	0001	1813	48.96
1674	2288	RNDRK	1508	4031	48.87
1675	1195	WTAUG	4632	1313	48.85
1676	1659	ODESA	0231	2115	48.82

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1677	92	TYRSW	1703	1387	48.70
1678	1098	SHSTH	1305	488	48.65
1679	1627	MRDCK	0002	1699	48.57
1680	1397	PALRD	2205	333	48.52
1681	1003	DALRK	1301	1230	48.40
1682	1382	MKNSW	2603	2604	48.36
1683	2072	LOMAL	0010	1558	48.24
1684	1130	BONHM	1210	1178	48.22
1685	2863	WALST	0010	1083	48.18
1686	722	MSLSW	0004	411	48.17
1687	1312	WXNTH	2305	1067	48.15
1688	1515	CLBRN	1206	1038	48.12
1689	1623	ABRRD	0004	850	48.08
1690	107	LMESA	2833	22	48.01
1691	2800	ARLNG	1212	122	47.92
1692	1341	KFMSS	1301	924	47.92
1693	501	CRNTH	2406	1310	47.90
1694	228	TYOMN	1401	1558	47.90
1695	2624	FRMNT	0010	2519	47.89
1696	835	IRVNE	1303	1688	47.86
1697	1990	CHNDW	1203	844	47.80
1698	1697	ATHNW	1401	902	47.72
1699	321	SHSTH	1303	716	47.68
1700	#N/A	BLMND	3211	11	47.67
1701	1015	RTHGB	1421	1661	47.67
1702	2872	FRMBG	1750	41	47.66
1703	1058	CRNSO	3913	1541	47.65
1704	428	LIGSW	1608	386	47.60
1705	2094	HORNE	1991	1480	47.53
1706	578	DALWT	2911	347	47.49
1707	1248	MESQT	1307	593	47.45
1708	467	MDLNW	1532	1965	47.45
1709	2478	CRTLD	4732	2785	47.22
1710	2841	CGRSW	9811	58	47.20
1711	1384	MNSTR	1201	662	47.17
1712	745	DNISN	1205	1537	47.17
1713	2666	BLKST	1732	1224	47.14
1714	758	ARPMN	4147	600	47.11
1715	1566	EDGCF	2223	3179	47.07
1716	2610	IRVVV	2804	943	47.05
1717	1093	IRVRS	4411	1247	46.99
1718	2126	PPARK	1801	1318	46.93

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1719	1134	INAIR	1411	948	46.91
1720	837	DALRK	1303	1271	46.91
1721	1340	MDWCK	0001	839	46.86
1722	1534	RWALE	3324	1508	46.84
1723	2255	PLKST	0004	1310	46.83
1724	248	MCKMY	0821	1783	46.69
1725	110	CLBRN	1204	1094	46.64
1726	2223	RRNES	2403	4953	46.61
1727	1059	TMPLE	1206	720	46.61
1728	1490	LWSNR	2231	789	46.50
1729	1844	HKHTS	1601	1506	46.46
1730	1730	HORNE	1913	1685	46.42
1731	1046	FLINT	3212	3024	46.36
1732	1369	WXNTH	2301	1311	46.32
1733	1372	NYLDV	1202	139	46.30
1734	585	CDCSW	0007	990	46.24
1735	2565	EZACH	0003	1288	46.23
1736	2572	STNVL	1205	439	46.18
1737	831	GRLRD	0003	641	46.16
1738	2446	WCOLO	1316	2076	46.15
1739	2560	ABRRD	0003	345	46.15
1740	2193	MDLNW	1564	1275	46.12
1741	2900	RRSTH	1705	934	46.07
1742	1310	LAVON	1404	960	46.06
1743	235	EMPCT	0003	1355	46.06
1744	1555	ALLEN	2406	2630	46.06
1745	774	THRNE	0004	811	46.03
1746	1764	MAYFD	5521	3213	46.03
1747	1271	CRLJL	1506	1940	46.02
1748	1637	ALLEN	2404	2057	45.99
1749	2647	BRLSN	2062	3790	45.98
1750	1647	RCLNS	1404	717	45.89
1751	1189	CNSES	0750	1977	45.86
1752	2794	MSLSW	0007	385	45.85
1753	1946	PREST	1601	1159	45.73
1754	1570	WWDWY	2020	1243	45.70
1755	507	HKHTS	1606	1781	45.70
1756	1759	EDGCF	2262	1019	45.64
1757	498	TSLVL	4002	2748	45.61
1758	1952	MESQT	1303	830	45.61
1759	1849	BRNSO	1807	565	45.59
1760	613	WCOLO	1320	1439	45.50

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1761	2467	ODESA	0221	252	45.49
1762	1240	CDMIL	1201	598	45.43
1763	1243	TAYLR	1203	1331	45.33
1764	1897	PCUST	2003	1028	45.27
1765	1166	ODNTH	2014	1289	45.06
1766	2116	PROAD	0002	841	45.05
1767	101	DAVST	0008	27	44.93
1768	2002	STAUG	0003	2162	44.89
1769	1011	HLTOM	2482	1163	44.88
1770	2423	HKHTS	1605	1473	44.87
1771	2295	MTLDA	0007	1785	44.84
1772	1691	MCKMY	0811	2605	44.66
1773	1493	IRVNG	1406	1278	44.63
1774	937	LKHLD	0005	1137	44.63
1775	1474	CRKET	2401	151	44.52
1776	905	WALST	0014	893	44.51
1777	2028	ARLNG	1232	1273	44.37
1778	1308	CDHIL	1805	621	44.36
1779	105	PWEST	1309	61	44.33
1780	1403	TYSTH	1206	1265	44.32
1781	727	HMPHL	2743	907	44.26
1782	414	RWDHV	1901	914	44.26
1783	863	ODESW	5211	1262	44.20
1784	1208	GRDPR	0831	1226	44.18
1785	245	PLANO	1105	60	44.15
1786	550	GRLND	1606	965	44.13
1787	2243	WITTS	1703	1583	44.09
1788	2246	MESQT	1304	635	44.06
1789	1471	WATSN	5331	1114	44.04
1790	485	BOWEN	3122	1281	44.00
1791	748	BRNWD	1202	445	43.96
1792	567	SHMNE	1401	1205	43.91
1793	1926	PLSTH	1305	500	43.87
1794	736	PCUST	2009	2273	43.73
1795	2084	ARLNG	1213	1328	43.72
1796	1711	GRAHM	0711	1616	43.67
1797	1458	ENTOH	0006	1952	43.67
1798	2656	MRTNS	1503	359	43.62
1799	1579	CDCRK	1201	1253	43.56
1800	2548	ARTHR	0411	736	43.55
1801	673	ROWLT	1104	1121	43.54
1802	280	PLSTN	1001	1897	43.42

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1803	2127	PCOIT	1003	1511	43.38
1804	1487	HLTOM	2411	1442	43.29
1805	2132	SACRC	5521	120	43.27
1806	2707	KLNCC	1704	2556	43.22
1807	993	RSNHT	1181	1713	43.13
1808	2958	LOMAL	0015	177	43.12
1809	1437	TMSTH	1402	1656	43.05
1810	1921	PWEST	1304	1615	42.93
1811	2357	BRHLW	7621	2882	42.78
1812	2314	MESTE	1203	174	42.72
1813	2539	PWEST	1312	1361	42.63
1814	2125	ENNIS	1903	1386	42.53
1815	2980	SMFLD	2322	41	42.48
1816	1006	HMPHL	2772	299	42.45
1817	1724	ROWLT	1101	1255	42.34
1818	2130	TRLNW	1204	581	42.33
1819	1791	SHNRW	1612	827	42.29
1820	2533	ODESA	0272	1653	42.29
1821	2309	DUVAL	0462	1062	42.27
1822	1544	NHNSW	0003	527	42.26
1823	1956	TRNTY	7511	1451	42.26
1824	1000	TRLWD	7721	1620	42.22
1825	431	BRLSN	2013	1104	42.20
1826	1948	MSHLN	0005	503	42.20
1827	1184	JNKNS	0005	552	42.19
1828	2507	SORCY	0001	2557	42.19
1829	1353	DUVAL	0452	1274	42.08
1830	2670	WALNT	0005	992	42.07
1831	2655	BLTON	1802	1410	42.06
1832	1078	RSPCK	2104	1903	42.04
1833	1935	KLNSO	4501	3429	42.04
1834	2304	LKHLD	0004	1262	42.03
1835	636	JEWET	1204	1331	42.02
1836	1720	HKHTS	1604	875	42.00
1837	1595	MLFRD	2101	970	41.99
1838	1714	LEMON	0008	784	41.86
1839	713	LFSTH	1408	2116	41.75
1840	2448	WNRTH	1418	1780	41.74
1841	2042	COMSO	1405	754	41.73
1842	1901	BLTLN	0005	881	41.67
1843	#N/A	CMTSW	0957	1175	41.63
1844	2529	DAVST	0006	1150	41.60

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1845	1746	BRCRK	6523	876	41.59
1846	2105	MESWE	3611	1923	41.57
1847	976	RGLRW	0006	36	41.53
1848	168	ALVRD	1504	158	41.46
1849	1361	WSOTH	1021	2131	41.39
1850	1924	TMSTH	1401	1823	41.35
1851	1794	JKSBR	1401	742	41.30
1852	1501	KLNPS	1104	1344	41.29
1853	641	BNDRA	0006	693	41.27
1854	692	ODNTH	2044	2091	41.23
1855	875	LKBLT	2105	2003	41.21
1856	2141	PNTGO	7112	739	41.18
1857	2799	BRKRG	0221	699	41.11
1858	947	MESQT	1305	1146	41.09
1859	2745	CLBRN	1202	1002	40.94
1860	1114	PKRMX	4701	1744	40.86
1861	2356	WNRTH	1419	306	40.85
1862	2339	GVODS	3011	2282	40.84
1863	1839	MRTSP	1502	498	40.84
1864	2460	MDAIR	2922	387	40.84
1865	562	PRFTW	4211	3614	40.84
1866	657	TYEST	1509	383	40.72
1867	2346	BDFRD	8841	813	40.67
1868	2937	DFWNW	2604	12	40.51
1869	1792	HURST	1882	1900	40.40
1870	2231	BRLSN	2033	1671	40.39
1871	2296	IRVNR	1555	2202	40.39
1872	840	IRVNR	1508	2015	40.35
1873	582	BARRY	1802	300	40.34
1874	1241	MKNGB	5352	680	40.31
1875	1232	CLYVL	9321	822	40.30
1876	283	HLSBR	1204	554	40.09
1877	786	ANDNR	2242	512	40.09
1878	569	IRVND	1208	164	39.93
1879	814	ROWLT	1107	369	39.89
1880	1449	FARON	4052	1072	39.87
1881	2540	IRVND	1203	437	39.71
1882	1239	DESPR	1406	955	39.66
1883	1669	COPEL	3053	2070	39.66
1884	1998	GPLND	1202	401	39.61
1885	531	OKLND	0004	799	39.61
1886	1504	IRVGS	1904	958	39.57

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1887	1707	PFFRD	3472	1279	39.55
1888	2354	RDRSE	2604	3786	39.52
1889	2291	MESTE	1213	995	39.47
1890	1264	PLKST	0006	816	39.45
1891	2369	SORCY	0004	603	39.36
1892	1173	CRTLD	4734	792	39.35
1893	826	PFFRD	3462	1773	39.32
1894	1004	FRMNT	0001	850	39.27
1895	1645	GRDPR	0881	1882	39.27
1896	2675	HLSES	0542	766	39.25
1897	742	PRKRW	3341	542	39.21
1898	56	ECTHM	3331	22	39.16
1899	2861	RSNHT	1111	348	39.11
1900	1987	NPKWY	0014	6107	39.09
1901	149	HKBRY	1101	339	38.94
1902	2886	LSCOL	2137	774	38.79
1903	419	MSLMN	4009	237	38.68
1904	1770	LFSTH	1402	1188	38.67
1905	2822	NCSTH	1506	91	38.63
1906	1278	REAST	1506	1208	38.63
1907	1809	RGLRW	0005	51	38.63
1908	1480	ROANW	9521	1944	38.62
1909	1810	BRCRK	6511	1291	38.53
1910	803	ALLEN	2402	3343	38.51
1911	322	ROANW	9512	1928	38.48
1912	2124	BNBRK	4111	2890	38.48
1913	2936	DFWNW	2602	27	38.46
1914	1980	FROKS	0005	1423	38.39
1915	664	PLSTN	1002	1222	38.38
1916	2085	JUDCT	0006	1213	38.36
1917	1275	RGLRW	0004	79	38.32
1918	370	GMINI	5821	1422	38.29
1919	2489	HMPHL	2791	30	38.26
1920	1806	MCWHT	3512	864	38.22
1921	1884	FROKS	0002	1567	38.22
1922	2430	TMPTV	2402	3763	38.17
1923	1955	CDHCR	2050	809	38.16
1924	#N/A	CMTSW	0977	249	38.14
1925	1199	RNDRK	1507	891	38.11
1926	1984	NHNSW	0008	587	38.10
1927	1111	CRLJL	1507	926	38.09
1928	2520	BOWEN	3181	768	38.09

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1929	2494	HORNE	1942	1558	38.01
1930	1658	KEENE	1501	1611	38.00
1931	1468	MESTE	1211	1171	37.99
1932	2426	GRDPR	0862	1564	37.88
1933	1077	LNGLK	1604	448	37.83
1934	2701	RDOAK	1304	3370	37.76
1935	100	MSLSW	0008	192	37.70
1936	2331	WELRD	0003	511	37.63
1937	1789	CLBWS	8111	1682	37.60
1938	2221	DNISN	1201	1468	37.56
1939	1875	WMRLD	0005	1616	37.51
1940	#N/A	DENDR	0003	2224	37.51
1941	2442	STAUG	0007	1183	37.49
1942	1741	VENSW	2601	1425	37.40
1943	1316	MESQW	1803	1691	37.36
1944	1876	PSHIL	1603	1594	37.35
1945	1605	CRNTH	2403	2764	37.29
1946	2171	FARON	4082	1599	37.29
1947	308	LMESA	1561	1426	37.28
1948	65	WEAST	0618	854	37.28
1949	2233	KILEN	1201	1851	37.25
1950	1132	IRVHF	2302	1408	37.24
1951	250	QNLAN	1202	389	37.11
1952	1561	WXHCH	1201	1657	37.04
1953	1788	CRYVE	3011	289	36.97
1954	2280	CRNDL	2401	511	36.96
1955	584	PFLGV	2001	4552	36.94
1956	1938	WNDWD	3641	1483	36.92
1957	983	KERNS	2401	554	36.88
1958	1786	TYBLR	2801	1238	36.87
1959	2220	NCSFA	1702	1305	36.68
1960	1975	DNCNV	1903	1203	36.67
1961	2164	WNTHW	1118	1524	36.63
1962	1607	DESHR	1204	1157	36.60
1963	2515	TRNTY	7541	697	36.59
1964	1124	CRSCN	1205	766	36.57
1965	1709	LKHLD	0007	1209	36.54
1966	950	IRVNG	1402	1142	36.47
1967	1393	ALVDO	1901	1464	36.42
1968	590	TAYLR	1204	2026	36.25
1969	892	HUBRD	1401	902	36.22
1970	1291	PWEST	1311	958	36.19

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1971	2079	KLBRG	0002	1716	36.16
1972	2905	FRMBG	1753	708	36.14
1973	2153	MESQW	1807	1498	36.04
1974	2389	TMSTH	1406	1156	36.04
1975	2374	CNTRD	0004	1081	36.02
1976	2857	WNDWD	3672	265	36.01
1977	2310	BRNSO	1801	1568	35.91
1978	2735	TMSTH	1407	206	35.91
1979	2145	MYPRL	1803	599	35.74
1980	675	GMINI	5812	775	35.46
1981	88	CDHCR	2053	279	35.46
1982	1729	WNTHW	1119	1318	35.39
1983	2554	RRNES	2405	2628	35.37
1984	74	ELCTR	1221	129	35.36
1985	169	WEBBS	8622	1696	35.34
1986	2699	EDGCF	2252	401	35.32
1987	2005	RCLNS	1407	1390	35.20
1988	2301	COMSO	1402	946	35.10
1989	1641	DAVIS	3741	1288	35.02
1990	2322	LTVSB	5461	795	35.02
1991	1082	TMSTH	1403	1177	35.00
1992	1549	RWDHV	1903	1261	34.97
1993	2498	RSNHT	1142	946	34.96
1994	2475	HUTTO	2721	2702	34.96
1995	1722	WNTHW	1116	675	34.68
1996	1320	BRCRK	6524	782	34.67
1997	2305	WNTHW	1121	749	34.55
1998	1596	MRSES	4006	529	34.53
1999	2083	CLYVL	9311	2011	34.52
2000	753	ODNTH	2013	1594	34.47
2001	1050	CNSES	3054	1580	34.40
2002	1061	WHTRK	0001	2750	34.38
2003	2048	CLBRN	1201	1750	34.37
2004	1941	BLTON	1801	850	34.37
2005	1731	IRVBL	2502	181	34.29
2006	2363	NCSTH	1505	17	34.29
2007	456	CHROW	0001	136	34.27
2008	1933	DGNST	0002	456	34.25
2009	508	HORNE	1921	1348	34.18
2010	223	POWEL	2706	239	34.15
2011	2230	WALST	0011	747	34.10
2012	1146	FSTVW	0001	793	33.95

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2013	1617	KNLTR	0008	902	33.89
2014	1915	INAIR	1423	233	33.84
2015	1436	IVANS	1621	61	33.84
2016	2767	MESQN	1503	1890	33.83
2017	1068	IRVNG	1401	1604	33.83
2018	2284	KLNCC	1702	3779	33.83
2019	1918	LTVSB	5451	1231	33.82
2020	1958	SUNNY	2301	611	33.77
2021	1483	SHAMP	0005	1722	33.76
2022	2253	BRLSN	2023	1844	33.73
2023	2367	SHRSW	6612	1826	33.69
2024	1960	NCDCH	1202	1027	33.60
2025	634	CLMET	0002	1407	33.57
2026	915	BONHM	1204	840	33.55
2027	2047	WNDWD	3621	2154	33.46
2028	1297	LFEST	1901	1512	33.39
2029	1407	CRLFR	2157	2417	33.30
2030	454	PCUST	2002	821	33.28
2031	2306	HORNE	1933	1998	33.28
2032	367	ECTOR	1201	388	33.14
2033	1610	WSOTH	1017	1744	33.09
2034	1100	HMTRD	0004	1059	33.04
2035	1149	ROWLT	1105	1066	32.95
2036	1773	IRVBL	2503	1304	32.95
2037	1530	EULES	8713	2185	32.91
2038	2340	RCHRD	1202	798	32.89
2039	1343	EGFRD	0004	1864	32.86
2040	1872	KRUMS	1203	791	32.82
2041	1577	KILEN	1202	1721	32.82
2042	2004	GRLWS	1704	173	32.80
2043	2403	RCHHL	0363	579	32.79
2044	2380	TYWST	2004	984	32.78
2045	825	LMESA	1512	1814	32.77
2046	1885	COPER	1202	976	32.77
2047	2355	SHRSW	6641	1005	32.75
2048	2727	MESQN	1506	65	32.71
2049	2566	ESTLD	3611	1538	32.69
2050	1708	SHNRW	1609	1772	32.50
2051	1444	MDLNW	1594	1648	32.49
2052	500	FSCRK	6723	4515	32.47
2053	2509	BRCRK	6543	1659	32.46
2054	847	RGFTW	6813	23	32.40

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2055	434	PCOIT	1006	1040	32.40
2056	1274	CRLTR	2005	677	32.36
2057	1115	IRVNG	1403	525	32.35
2058	423	MNWLW	1401	1546	32.34
2059	663	GVODS	3031	1371	32.34
2060	1220	PROAD	0005	122	32.29
2061	728	ALNSW	2654	1973	32.28
2062	371	LFKHL	2103	1954	32.16
2063	614	TYBLR	2804	2442	32.14
2064	2237	PRKWY	1532	2134	32.13
2065	372	WDGWD	1591	1131	32.09
2066	537	MRDCK	0001	2203	32.07
2067	1784	IRVVV	2801	2407	32.07
2068	2439	MDWCK	0005	1379	32.02
2069	1668	WCOLO	1318	1647	31.94
2070	2472	MDLNE	0121	232	31.93
2071	2179	ARMST	0005	1514	31.93
2072	2118	FRMBG	1751	808	31.90
2073	2410	MESQW	1805	83	31.83
2074	2016	TRNTY	7551	1576	31.82
2075	940	HLTOM	2421	1592	31.80
2076	293	OKCLS	0004	1497	31.71
2077	597	HOLND	1901	1097	31.70
2078	2639	WATCO	2605	2709	31.67
2079	2297	WRBND	2322	847	31.64
2080	730	LWRDR	0002	994	31.56
2081	2172	TMPNW	1105	829	31.50
2082	1585	RCHHL	0384	718	31.47
2083	1716	HURST	1841	1001	31.41
2084	1185	BRCKR	6514	572	31.38
2085	2911	WFALS	0124	126	31.36
2086	563	IRVVV	2853	2601	31.25
2087	390	MRSDO	9611	1762	31.24
2088	1385	PPARK	1802	606	31.23
2089	639	CRLFR	2152	3480	31.13
2090	1768	MDWPK	9231	2416	31.01
2091	750	CDCSW	0003	716	31.00
2092	1968	ACRLY	1711	174	30.97
2093	2396	FRMBR	1808	684	30.91
2094	1951	CRNRD	0006	353	30.75
2095	1833	BLMED	1619	1036	30.61
2096	1401	DCATR	1203	929	30.58

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2097	1451	WELRD	0002	744	30.51
2098	1694	DAVIS	3731	767	30.48
2099	655	KFMNW	1202	874	30.44
2100	2751	CRLTR	2051	3938	30.43
2101	2674	HRSMD	1953	405	30.41
2102	2211	GSTHW	1623	2529	30.33
2103	1624	CLBSN	8821	10	30.32
2104	1513	WMMMR	2707	1547	30.21
2105	815	TRLNW	1202	59	30.14
2106	1151	SPRDL	4821	1363	30.10
2107	640	BRCRK	6522	2213	30.10
2108	532	GRLND	1603	313	30.09
2109	2881	WMMMR	2706	19	30.05
2110	2750	SHNRW	1607	554	30.04
2111	2068	CRSWS	1403	1801	30.03
2112	2065	VGCRK	8011	1531	30.02
2113	1354	MNWLL	1205	448	29.99
2114	1981	LWSNR	2241	1085	29.94
2115	2382	CDHCR	2055	1321	29.93
2116	2395	GRLRD	0001	1773	29.90
2117	1355	WEAST	0616	777	29.87
2118	1252	GRMES	0511	1201	29.82
2119	1295	THRNE	0003	1252	29.82
2120	1900	HUTTO	2742	4671	29.81
2121	1284	GAVSW	0004	830	29.81
2122	2062	BRNAV	0784	1896	29.81
2123	2531	MCDMT	2552	876	29.80
2124	918	CRTLD	4712	1172	29.76
2125	1930	LUFKN	1205	1335	29.76
2126	1775	LKHLD	0003	1347	29.59
2127	1273	PPARK	1806	840	29.58
2128	2829	RWALL	1201	1301	29.41
2129	1815	THRNE	0008	2222	29.39
2130	2204	SHSTH	1301	2221	29.37
2131	1339	MURPH	2755	3282	29.35
2132	1086	RDRSE	2601	1952	29.35
2133	1153	CRLTN	1451	474	29.28
2134	2390	MDLNE	0172	372	29.25
2135	2146	COPEL	3052	1309	29.19
2136	2623	CLLVL	0002	12	29.17
2137	2010	ATHNW	1405	882	29.14
2138	1442	RCHRD	1207	1544	29.12

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2139	2842	WATSN	5382	664	29.08
2140	1978	BLKST	1721	1029	29.06
2141	203	LVBRD	0002	509	29.03
2142	2274	BDFWD	8941	1223	28.97
2143	1075	CDCSW	0006	1369	28.95
2144	2316	THSES	2402	1407	28.92
2145	909	SMPST	0006	844	28.91
2146	1619	MCDMT	2554	1779	28.90
2147	1127	CLYVL	9313	2010	28.88
2148	1453	OAKHL	3062	2282	28.83
2149	2606	KLNSO	4502	3190	28.81
2150	1533	ESTLD	3621	1494	28.79
2151	706	MESQT	1301	1454	28.76
2152	1112	PFFRD	3452	871	28.72
2153	1608	JUDCT	0002	1409	28.67
2154	1843	DESPR	1408	1998	28.52
2155	96	CRLSP	1703	263	28.52
2156	1811	WHITE	3542	1671	28.48
2157	2587	LOMAL	0009	1007	28.48
2158	1117	CPRCV	1402	2034	28.47
2159	934	LFSTH	1405	216	28.43
2160	2558	HNYGR	2401	468	28.41
2161	848	TYOMN	1408	1333	28.37
2162	1097	LSCOL	2116	59	28.35
2163	999	ODNTH	2073	671	28.34
2164	2487	ARLNG	1282	839	28.32
2165	2117	DNINR	1402	389	28.30
2166	548	FHLSW	1361	983	28.23
2167	1732	PREST	1604	1343	28.22
2168	2397	DENAV	0642	912	28.22
2169	2144	MEXIA	4024	345	28.22
2170	2686	HMPHL	2721	518	28.20
2171	2206	CRLTN	1402	798	28.19
2172	#N/A	MDESA	4541	310	28.15
2173	2592	GRMES	0512	1195	28.12
2174	2240	RNDRK	1505	1321	28.11
2175	2612	SPRDL	4812	1205	28.03
2176	1102	RRNES	2407	3365	27.99
2177	1816	BLMED	1617	320	27.98
2178	1315	EZACH	0006	1103	27.95
2179	1850	CMNCH	1402	1156	27.89
2180	2508	WEBBS	8621	2832	27.88

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2181	1366	IRVNG	1408	1067	27.88
2182	1356	GRSMN	4028	710	27.74
2183	1599	FRNKF	0002	943	27.71
2184	2033	WKATY	1718	2215	27.69
2185	1386	STNVL	1207	971	27.69
2186	2665	MSTLT	1084	800	27.66
2187	2668	WSOTH	1022	1797	27.62
2188	2378	KILEN	1203	759	27.61
2189	2196	COPER	0402	169	27.61
2190	1653	ELKTN	2502	1564	27.59
2191	720	KLBRG	0004	1171	27.57
2192	1593	LKWOD	7432	1609	27.56
2193	1135	SHNRW	1608	1431	27.55
2194	2927	ABBOT	1901	111	27.47
2195	2277	FSTVW	0005	1762	27.36
2196	850	PLSTH	1302	1012	27.31
2197	396	KRGRV	2401	15	27.29
2198	2388	TATSP	4313	1612	27.26
2199	2364	PRKWY	1561	1737	27.25
2200	2511	KNLTR	0006	947	27.22
2201	1205	RRNES	2404	4452	27.20
2202	1489	CHROW	0008	88	27.16
2203	2651	MAPLE	0001	1066	27.06
2204	735	GMINI	5811	3285	27.01
2205	546	CDCSW	0005	1705	26.96
2206	1760	BSPRG	1902	2408	26.93
2207	2680	BOWEN	3142	1193	26.92
2208	1611	RCHHL	0311	978	26.89
2209	1206	BSPRG	1904	1665	26.89
2210	2808	SHDYG	7841	340	26.88
2211	2020	LOMAL	0005	395	26.78
2212	1023	PKRVL	1054	2567	26.74
2213	2293	RDOAK	1303	2389	26.73
2214	2249	IRVNR	1551	1367	26.70
2215	1568	SMFLD	2343	719	26.67
2216	587	DALRK	1326	2807	26.65
2217	2711	BKWST	0005	918	26.61
2218	2202	GAVSW	0007	1541	26.52
2219	2208	KLNTF	1802	866	26.50
2220	754	PTENN	2354	524	26.45
2221	2050	WATSN	5361	2524	26.36
2222	1804	CRLTR	2003	1355	26.32

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2223	2436	HORNE	1952	1275	26.30
2224	1663	CDHIL	1803	1903	26.29
2225	2385	MCKMY	0812	133	26.26
2226	1817	PCUST	2001	579	26.22
2227	406	ELGIN	1001	539	26.21
2228	470	FHLSW	1372	1314	26.14
2229	1559	LOMAL	0013	1056	26.13
2230	528	MKNNY	1253	156	26.09
2231	1314	CAMRN	1202	1471	26.09
2232	2307	HSKAV	0008	791	26.05
2233	1538	MKNGB	5342	1257	26.04
2234	2853	WMRNR	0001	184	26.03
2235	1744	MDLNW	1521	1788	26.00
2236	904	CKRHL	0005	1226	26.00
2237	1823	PRKRW	3352	1532	25.98
2238	1979	OKCLS	0005	197	25.98
2239	2667	FARON	4021	285	25.97
2240	2434	ALLEN	2403	1366	25.96
2241	970	ITSCA	1701	747	25.93
2242	1267	DALLW	0007	442	25.93
2243	1244	TMPLE	1204	1034	25.90
2244	1520	RSNHT	1171	2317	25.81
2245	982	JSHUA	1302	1331	25.80
2246	2847	FSCRK	6721	1665	25.68
2247	2104	RSPVY	1706	1342	25.64
2248	2096	ODESA	0261	1455	25.57
2249	2405	WALST	0001	509	25.55
2250	2514	HKBRY	1115	15	25.48
2251	1107	BLTON	1804	464	25.44
2252	644	RNDRK	1503	3919	25.39
2253	2147	EULSO	9122	1296	25.37
2254	859	WHITE	3511	1341	25.32
2255	1298	CLMET	0001	1592	25.30
2256	2207	EDGCF	2211	2105	25.25
2257	2712	WEAST	0619	2449	25.21
2258	1517	CLYVL	9312	1295	25.18
2259	2631	WEAST	0621	15	25.15
2260	2831	EULTB	5711	2295	25.02
2261	1769	BRNSO	1806	1782	25.02
2262	1521	BRNWD	1204	1779	24.97
2263	601	MESTE	1205	1640	24.91
2264	1012	BRTRD	7311	1191	24.78

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2265	2209	KLNTF	1801	1114	24.76
2266	1972	RSPCK	2142	930	24.74
2267	2876	WALST	0012	516	24.74
2268	55	IRVBL	2505	499	24.73
2269	1543	KNLTR	0005	2858	24.67
2270	1891	RCHHL	0321	1739	24.66
2271	2659	MRSES	4014	18	24.56
2272	1048	IRVGS	1906	719	24.53
2273	381	ALPHA	0005	128	24.51
2274	2452	SHMNE	1403	995	24.48
2275	2347	RGLRW	0003	91	24.44
2276	1540	PSHIL	1604	1163	24.39
2277	1913	GRHWY	5512	3134	24.38
2278	104	PERIN	1511	653	24.35
2279	1673	SANSM	3923	3786	24.27
2280	2635	BLKST	1771	1214	24.19
2281	1851	SWTWR	1321	140	24.18
2282	1749	TYSTH	1208	250	24.17
2283	581	EDDYS	0710	648	24.13
2284	2103	MESFR	2101	2018	24.12
2285	1342	ROWLT	1106	1312	24.11
2286	1527	GSTHW	1641	81	24.09
2287	2749	FRMBG	1708	45	24.07
2288	2889	WMMMR	2705	1062	24.07
2289	2278	GNSVL	1204	505	24.01
2290	1524	PFLGV	2005	3802	24.00
2291	2622	HURST	1852	1508	23.93
2292	259	BLSRA	1602	158	23.90
2293	242	RRNES	2401	4972	23.87
2294	2300	ELMGV	3651	2238	23.85
2295	773	MEXIA	4040	861	23.76
2296	2605	ADISN	1604	1152	23.67
2297	2459	WATCO	2603	2950	23.63
2298	2455	RRSTH	1702	3289	23.56
2299	2575	WFALS	0193	2233	23.54
2300	860	WHTRK	0002	1428	23.46
2301	2342	KNEDL	6332	2191	23.40
2302	2263	THRNE	0001	1771	23.31
2303	948	ENNIS	1905	44	23.30
2304	928	RCHRD	1203	837	23.27
2305	2349	HUTTO	2711	3776	23.26
2306	1886	LKBLT	2107	1100	23.24

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2307	1944	IRVNR	1505	1319	23.21
2308	1715	CRLTR	2052	1568	23.12
2309	1613	MKNSW	1603	1379	23.11
2310	2227	TLRWT	2203	815	23.08
2311	1214	CRLTN	1405	1251	22.97
2312	2044	PWEST	1310	685	22.95
2313	491	IRVNR	1507	1490	22.93
2314	1841	ARTHR	0431	471	22.88
2315	2213	ELKTN	2501	735	22.86
2316	1049	MESTE	1204	1828	22.76
2317	2555	MSTLT	1011	63	22.69
2318	2337	WSTHL	3631	3801	22.67
2319	1084	LKHLD	0002	1528	22.67
2320	946	PRSTN	0001	907	22.63
2321	2731	SHDYG	7821	97	22.58
2322	1484	ROWLT	1102	807	22.49
2323	2024	TYLER	1002	861	22.45
2324	1277	KILEN	1204	1520	22.41
2325	2035	CRSGL	1302	1462	22.39
2326	2586	WGROB	8411	3435	22.38
2327	2092	RSPCK	2141	19	22.24
2328	1010	PARIS	1202	1264	22.23
2329	427	VLRYN	2951	2209	22.03
2330	2873	STNVL	1202	73	22.00
2331	678	DESHR	1206	2238	21.94
2332	2225	CRSWS	1401	1380	21.88
2333	1812	CRLUD	1304	1498	21.87
2334	1615	CMNCH	1401	1200	21.87
2335	2133	ALNTH	2851	2093	21.84
2336	845	CRLTR	2007	1449	21.81
2337	2109	EDGCF	2231	868	21.78
2338	1171	BAKKE	6912	1842	21.78
2339	1231	PCUST	2010	2259	21.76
2340	2070	WSTHL	3613	3363	21.70
2341	2113	PSHIL	1601	1416	21.68
2342	1863	ELGIN	1003	2107	21.66
2343	#N/A	DFWSE	2712	24	21.65
2344	1121	MKNNY	1202	1911	21.50
2345	2360	OKCLS	0007	635	21.47
2346	726	PRCTR	1601	207	21.45
2347	1920	PCUST	2005	1716	21.43
2348	1639	TLRWT	2201	1821	21.42

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2349	523	BRYAN	0006	928	21.35
2350	2739	FRMBG	1701	100	21.27
2351	1045	CKRHL	0006	258	21.25
2352	505	BRCRK	6513	1198	21.24
2353	2577	WMMMR	2702	1544	21.23
2354	2470	WFALS	0114	419	21.22
2355	2095	WDGWD	1513	865	21.21
2356	447	BKWST	0007	1839	21.21
2357	2654	RDRSE	2602	3262	21.11
2358	2064	HHSTH	1504	2390	21.10
2359	1029	DALWT	2921	288	21.08
2360	2490	MDTHN	1701	1524	21.00
2361	1306	ITSCA	1702	203	21.00
2362	1529	WXNTH	2302	1308	20.95
2363	1727	MRTNS	1501	493	20.95
2364	1087	PPARK	1807	889	20.89
2365	670	TYBLR	2805	2231	20.87
2366	1246	RNDRK	1506	1687	20.79
2367	1692	BLMED	1620	2019	20.73
2368	2100	FHLSW	1311	1469	20.71
2369	2697	GRPVN	8231	398	20.62
2370	2598	LEMON	0001	2161	20.60
2371	902	LKBRN	2401	705	20.60
2372	2078	MSTLT	1021	1288	20.53
2373	1721	FRMBR	1801	1245	20.51
2374	2238	RANGR	4311	925	20.50
2375	2778	SHMNE	1405	795	20.46
2376	51	LIGSW	1621	49	20.44
2377	2757	WEBBS	8631	3599	20.38
2378	2625	PKRVL	1053	1069	20.36
2379	1635	CRLTN	1404	104	20.36
2380	1269	CRTLD	4731	2977	20.32
2381	865	TAYLR	1201	1774	20.31
2382	778	GVODS	3072	2256	20.21
2383	2330	IRLBJ	3211	2614	20.21
2384	2108	ENNIS	1904	1264	20.14
2385	2698	RDRSE	2607	5011	20.10
2386	1961	LOMAL	0014	588	20.06
2387	908	PRCRK	0004	1497	20.03
2388	2813	IRVNR	1510	430	19.98
2389	653	ADMDS	6511	1050	19.96
2390	638	EULSO	9112	735	19.94

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2391	965	GRPVN	8211	135	19.91
2392	1826	ALLEN	2410	2338	19.83
2393	450	STNVL	1203	2267	19.83
2394	1959	GRPVN	8222	2043	19.80
2395	2609	LIGSW	1603	2517	19.79
2396	2626	MSLSW	0006	94	19.70
2397	2830	VENSW	2603	32	19.66
2398	605	WNRTH	1420	1165	19.64
2399	2789	KNLTR	0001	2124	19.53
2400	2254	PLSTH	1303	573	19.38
2401	1183	HMPHL	2711	524	19.31
2402	1452	CRLFR	2155	1330	19.30
2403	2677	WTAUG	4612	1230	19.27
2404	1155	WHTRK	0004	1165	19.22
2405	495	DENDR	0008	90	19.21
2406	2777	DNISN	1206	920	19.21
2407	2708	SCHRD	0003	360	19.17
2408	1853	MDTHS	1002	1265	19.15
2409	1910	PFLGV	2003	2858	19.11
2410	711	MTLDA	0004	834	19.03
2411	2688	MRSES	3015	582	18.99
2412	2741	LKBLT	2101	571	18.94
2413	2875	LOMAL	0007	151	18.86
2414	1292	GRFRD	1002	382	18.85
2415	1677	ARMST	0001	282	18.81
2416	1289	WVST	1216	250	18.80
2417	1249	DCVSO	1107	1102	18.79
2418	2428	BRYAN	0005	3880	18.77
2419	2603	LVBRD	0005	1364	18.77
2420	175	VLYRN	2954	2748	18.67
2421	217	VLYRN	2952	3425	18.65
2422	1181	RCLNS	1402	725	18.64
2423	2449	KLNCC	1701	2312	18.61
2424	1157	DENAV	0673	61	18.58
2425	2737	PALRD	2208	1076	18.57
2426	1398	RCLNS	1408	107	18.56
2427	125	WMRLD	0002	1566	18.49
2428	2190	CKRHL	0003	472	18.47
2429	608	IRVGS	1908	957	18.46
2430	1085	CPRCV	1401	1850	18.45
2431	1459	SYCRK	4511	1991	18.41
2432	1131	BNTDR	0001	1314	18.40

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2433	2709	DGNST	0004	942	18.33
2434	361	HUBRD	1402	1013	18.33
2435	1211	DAVIS	3713	869	18.29
2436	2461	RSPCK	2106	348	18.29
2437	1270	DUBLN	2214	689	18.23
2438	2327	ARTHR	0422	1054	18.14
2439	824	FRMNT	0009	945	18.13
2440	2066	MTLDA	0005	1559	18.12
2441	1106	CRTLD	4722	3303	18.03
2442	1213	ELZCK	4922	19	18.02
2443	2568	ALPHA	0008	1256	18.01
2444	2683	SHAMP	0003	1775	17.89
2445	2556	PARIS	1204	1161	17.89
2446	2468	KLNCC	1703	4088	17.87
2447	52	HUDSN	1605	146	17.85
2448	1895	STAUG	0004	2075	17.83
2449	2362	FRNKF	0003	497	17.82
2450	2469	BLMED	1618	35	17.77
2451	2183	SMFLD	2311	1417	17.75
2452	417	SYCRK	4521	3155	17.60
2453	1682	RWDHV	1907	894	17.58
2454	868	ENTOH	0003	13	17.56
2455	90	MDLNE	0151	308	17.56
2456	148	BRHLW	7651	1149	17.52
2457	1903	DUVAL	0483	2254	17.51
2458	672	SORCY	0003	843	17.50
2459	2038	BLTLN	0004	640	17.45
2460	2914	JNKNS	0006	525	17.44
2461	2760	WMRLD	0009	32	17.44
2462	1790	PCOIT	1002	674	17.36
2463	2402	BRKNR	1221	1154	17.34
2464	1949	WMRNR	0002	431	17.34
2465	1485	MDDTN	4311	192	17.25
2466	2399	CDCSW	0004	1373	17.24
2467	2846	EDGCF	2221	862	17.22
2468	1080	MURPH	2752	2147	17.22
2469	1191	EMPCT	0005	71	17.09
2470	2781	CMTSW	0987	396	17.07
2471	896	PCOIT	1004	735	16.97
2472	1296	LNCST	1603	1593	16.88
2473	547	SMFLD	2323	620	16.85
2474	2840	CMPST	0003	212	16.85

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2475	473	TYWST	2002	87	16.83
2476	2259	LKHLD	0008	1464	16.79
2477	1989	ATNRN	3421	1962	16.75
2478	1499	TYBLR	2802	998	16.71
2479	2804	RRSTH	1704	3261	16.67
2480	2579	PCOIT	1022	2125	16.61
2481	2898	WEAST	0620	578	16.59
2482	1923	NPKWY	0008	882	16.54
2483	2547	WTAUG	4621	445	16.45
2484	1725	GODRD	8112	1421	16.40
2485	716	CRSWS	1402	925	16.40
2486	2000	WWDWY	2024	1440	16.33
2487	2714	RRSTH	1708	4237	16.29
2488	185	MDDTN	4321	918	16.25
2489	2527	MTLDA	0006	2011	16.20
2490	2269	CLYVL	9323	1423	16.18
2491	1374	PNTGO	7122	1097	16.17
2492	1873	PJPTR	3212	30	16.12
2493	1887	DEALY	0004	2383	16.12
2494	78	SFTLK	4011	46	16.06
2495	2266	MKNGB	5331	1451	16.05
2496	2785	SHNRW	1601	106	16.03
2497	2444	NMAIN	0282	1345	16.02
2498	1640	WTAUG	4642	1270	16.02
2499	2101	CRSCN	1201	833	16.01
2500	405	WITTS	1701	2021	16.00
2501	#N/A	HUTTO	2723	3621	15.99
2502	1687	DUVAL	0434	2491	15.95
2503	211	JKSES	3028	376	15.92
2504	1126	CRSCN	1203	1992	15.92
2505	1552	MURPH	2753	1063	15.83
2506	609	RDLML	2512	1208	15.82
2507	2571	LKHLD	0001	1662	15.64
2508	1141	BRNWD	1206	1397	15.55
2509	2143	DCDAM	2002	907	15.55
2510	2137	JNKNS	0003	1064	15.54
2511	2063	ROLTR	2913	1727	15.47
2512	2488	ROBNW	1503	1670	15.42
2513	1367	SWDTN	1621	714	15.35
2514	2247	PALRD	2207	1126	15.33
2515	213	CRNRD	0007	754	15.30
2516	740	LWRDR	0004	804	15.30

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2517	1053	MESQN	1508	1788	15.29
2518	1551	ARLNG	1292	1563	15.23
2519	1290	GRSMN	4029	955	15.23
2520	1698	ROLTR	2911	1809	15.18
2521	851	GSTHW	1611	817	15.09
2522	2536	DGNST	0007	241	15.05
2523	2384	WTAUG	4623	730	15.04
2524	2662	HMPHL	2713	130	14.96
2525	1881	SHRSW	6631	1287	14.96
2526	2203	RNDRK	1504	988	14.95
2527	903	CNEXP	0007	398	14.94
2528	2657	HHSTH	1503	1620	14.91
2529	1255	CURIE	7221	805	14.89
2530	2326	GRPTT	9921	582	14.88
2531	2453	BRHLW	7642	935	14.87
2532	#N/A	DFWSE	2715	11	14.86
2533	1548	SMFLD	2392	1030	14.86
2534	1696	LIPAN	1301	510	14.82
2535	2696	AMLIA	0008	106	14.80
2536	1429	PEGAS	2321	136	14.75
2537	2628	PLANO	1103	1877	14.61
2538	2232	EULTB	5731	494	14.58
2539	282	TYWST	2013	916	14.57
2540	737	PWEST	1308	921	14.53
2541	1431	PRKRW	3392	1676	14.52
2542	2241	BRNWD	1201	1583	14.49
2543	2006	EDGCF	2282	1054	14.47
2544	2541	ARLNG	1271	2077	14.41
2545	2653	TMPSE	1501	543	14.40
2546	2528	STNVL	1201	2533	14.32
2547	2925	WTAUG	4651	541	14.30
2548	647	WTHRF	2001	645	14.17
2549	1154	CNTRD	0003	1385	14.16
2550	167	GSTHW	1622	20	14.11
2551	1985	BEAST	4088	116	14.02
2552	2746	EMPCT	0002	98	13.92
2553	2753	RWDHV	1904	516	13.91
2554	2859	IRLBJ	3221	842	13.91
2555	1699	RWALS	1851	1554	13.91
2556	2464	SPRDL	4822	1197	13.85
2557	2664	JNKNS	0001	25	13.83
2558	2916	CNEXP	0001	213	13.81

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2559	2681	RRSTH	1701	3176	13.66
2560	1128	WSANG	2801	1340	13.63
2561	2076	LKBLT	2102	1369	13.62
2562	2335	MURPH	2756	3603	13.56
2563	2512	GAVSW	0010	486	13.53
2564	2636	GAVSW	0001	1712	13.53
2565	2504	STAUG	0005	1230	13.51
2566	2602	WMMMR	2703	1120	13.42
2567	1765	CLBNR	1404	1330	13.33
2568	71	SCSES	1201	281	13.28
2569	708	SNYDR	1813	324	13.27
2570	335	ECTHM	3321	1012	13.25
2571	2581	RBNSN	2504	1646	13.22
2572	2545	BKBNT	1811	679	13.09
2573	2447	WGROB	8422	2694	13.02
2574	1783	WCOLO	1317	1268	13.00
2575	1203	DESHR	1202	1598	12.96
2576	962	WHTRK	0007	1242	12.88
2577	2973	PRNTH	1403	20	12.87
2578	1840	LEMON	0009	1778	12.87
2579	2562	CMHBL	8121	62	12.83
2580	2017	GODRD	8122	1053	12.82
2581	2637	SSPNG	1203	1373	12.72
2582	574	BDFWD	8922	2170	12.66
2583	741	FROKS	0006	992	12.62
2584	2820	GRHWY	5521	895	12.59
2585	2620	WRTHM	5017	159	12.55
2586	402	PFFRD	3431	580	12.54
2587	2758	IRVHF	2303	86	12.54
2588	2189	RCHHL	0353	1731	12.51
2589	680	FRNKS	1202	94	12.47
2590	652	WSOTH	1018	562	12.44
2591	1402	RSNHT	1131	2718	12.28
2592	1824	CHROW	0002	110	12.25
2593	2721	DCATR	1204	654	12.23
2594	2381	FRNKF	0004	1608	12.22
2595	2774	GLNHV	3953	1631	12.21
2596	1745	SMFLD	2372	634	12.17
2597	1005	NMAIN	0262	416	12.14
2598	1326	COPEL	3054	828	12.14
2599	2412	MCDMT	2551	2214	12.13
2600	2435	GNSVN	1401	28	12.10

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2601	2920	VGCRK	8031	1812	11.92
2602	2262	CMTSW	0927	565	11.92
2603	2700	CRLFR	2153	245	11.81
2604	2302	ABBOT	1902	120	11.78
2605	1090	CTYVW	2211	1462	11.76
2606	2795	WALST	0013	386	11.64
2607	1838	CLLVL	0004	53	11.63
2608	1265	WALNT	0004	1475	11.62
2609	517	CRLFR	2159	1449	11.62
2610	2902	SCHRD	0006	488	11.56
2611	994	IRVNG	1404	1448	11.52
2612	1655	PALMR	2201	54	11.49
2613	665	NPKWY	0011	4165	11.47
2614	2763	WNRTH	1416	728	11.46
2615	2783	LAVON	1402	155	11.43
2616	2661	PFFRD	3421	858	11.43
2617	1832	FRSTN	1604	334	11.35
2618	2910	PLHWY	3701	495	11.34
2619	2903	FRMBR	1807	849	11.26
2620	802	HUTCH	1505	26	11.26
2621	2067	CLBWS	8121	268	11.24
2622	693	CRSSN	7911	834	11.21
2623	1971	LFKHL	2101	128	11.19
2624	749	LKHLD	0006	737	11.14
2625	2790	HMPHL	2792	456	11.09
2626	2797	DALWT	2952	656	11.04
2627	2690	EULSO	9121	118	11.03
2628	1063	PLANO	1102	143	11.01
2629	1123	MSTLT	1073	194	10.99
2630	2192	CRLTN	1408	127	10.97
2631	1377	STNVL	1206	2519	10.90
2632	2292	RDLML	2532	1788	10.89
2633	2836	HLTOM	2461	849	10.86
2634	606	FRNKF	0005	1086	10.82
2635	2351	BRNWD	1205	1151	10.76
2636	2135	DAVST	0001	576	10.76
2637	2168	WSANG	2802	635	10.73
2638	2843	CRSCN	1202	626	10.66
2639	2433	BLMGR	1901	269	10.65
2640	2214	LOMAL	0002	518	10.65
2641	2860	GRAHM	0713	401	10.63
2642	2286	BLMGR	1902	180	10.61

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2643	2617	GAVSW	0002	930	10.61
2644	1993	WEBBS	8633	2469	10.55
2645	714	RCHHL	0344	1247	10.55
2646	1221	ENTOH	0007	907	10.54
2647	1880	ENSSO	2003	503	10.53
2648	2456	BLTON	1805	1537	10.46
2649	577	MKNNY	1204	36	10.44
2650	2825	FRMBR	1806	147	10.42
2651	2142	WEAST	0615	2153	10.35
2652	1969	DLEON	0131	737	10.31
2653	1567	DUBLN	1360	1101	10.30
2654	2074	RWDHV	1908	2306	10.26
2655	1301	PLKST	0005	1134	10.20
2656	2482	WDGWD	1561	1498	10.17
2657	521	ENTOH	0005	1083	10.13
2658	2570	RKCRK	6111	2708	10.12
2659	2244	MESTE	1208	995	10.10
2660	2725	EMPCT	0004	340	10.07
2661	2802	VANAL	1201	603	10.05
2662	2644	BRNSO	1804	11	10.04
2663	1422	LKMNT	0001	203	10.01
2664	2359	WTAUG	4622	1005	9.98
2665	2788	SHAMP	0006	1145	9.95
2666	1162	DALRK	1309	876	9.89
2667	2871	HNTNG	1302	41	9.82
2668	755	RSPVY	1702	539	9.78
2669	1763	FRMBG	1705	281	9.75
2670	757	RGLRW	0002	215	9.67
2671	1866	GRDPR	0891	891	9.66
2672	2838	BRHLW	7631	633	9.59
2673	1198	MAYFD	5531	1185	9.54
2674	1665	KLBRG	0001	410	9.52
2675	1044	WALST	0004	45	9.48
2676	2945	FRNKF	0008	1342	9.48
2677	2034	HORNE	1992	254	9.47
2678	1421	FRMNT	0008	1052	9.47
2679	2407	TRLNW	1201	1167	9.45
2680	2924	LEMON	0002	979	9.38
2681	573	MNWLL	1202	693	9.31
2682	2285	WTAUG	4633	1049	9.30
2683	2845	JUDCT	0008	140	9.29
2684	2649	NCRST	2202	30	9.23

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2685	2849	GDNVL	1201	64	9.18
2686	1922	CNTRD	0001	2132	9.13
2687	769	IRLBJ	3212	3299	9.12
2688	2466	PFFRD	3411	317	9.11
2689	1686	BDFWD	8932	1709	9.07
2690	2630	HORNE	1981	1573	8.98
2691	2678	ROANW	9511	1459	8.96
2692	2671	WRTHM	5012	315	8.93
2693	1321	IRVRS	4413	1353	8.85
2694	2457	FRMNT	0012	475	8.83
2695	1632	CMTSW	0983	1080	8.77
2696	897	ALPHA	0011	1173	8.67
2697	553	REAST	1501	304	8.44
2698	2406	BNDRA	0001	845	8.34
2699	2879	GAVSW	0011	109	8.29
2700	1787	ALPHA	0007	1465	8.20
2701	2015	CKRHL	0008	1666	8.19
2702	2852	KLELM	2202	2378	8.18
2703	1754	RRNES	2402	3859	8.04
2704	#N/A	MLDR2	1603	505	8.04
2705	1227	LWRDR	0003	1783	8.00
2706	2862	TMNTH	1601	30	8.00
2707	506	NCRST	2203	987	7.92
2708	1351	WTHRF	2002	1718	7.91
2709	1575	BRNWD	1203	829	7.90
2710	2782	RCHHL	0394	237	7.86
2711	2201	TYOMN	1411	307	7.80
2712	2892	KLNTF	1803	1054	7.65
2713	2798	TMPNW	1106	1001	7.64
2714	1047	JNKNS	0004	129	7.61
2715	533	FARON	4031	1142	7.60
2716	2128	TMPNW	1101	2633	7.59
2717	2884	DNINR	1401	81	7.59
2718	2658	KLELM	2204	3070	7.54
2719	2713	NPKWY	0009	1290	7.48
2720	483	KERNS	2402	378	7.46
2721	2375	RNDRK	1501	803	7.44
2722	2971	PLANO	1108	491	7.40
2723	594	ATNRN	3411	3007	7.33
2724	1197	IRVND	1206	107	7.32
2725	159	WMRLD	0001	222	7.21
2726	53	POYNR	1201	334	7.20

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2727	1099	BKWST	0006	804	7.16
2728	2532	TYLER	1010	55	7.15
2729	780	VLYRN	2955	4545	7.07
2730	2522	REGST	0003	968	6.96
2731	1667	DALWT	2972	240	6.95
2732	1684	ALPHA	0001	428	6.93
2733	2437	NPKWY	0012	2231	6.91
2734	2134	BLTLN	0001	681	6.89
2735	2111	THRNE	0002	1705	6.81
2736	480	CNEXP	0003	1396	6.81
2737	2155	MKNNY	1201	1311	6.81
2738	2484	DGNST	0008	117	6.74
2739	2576	LWSNR	2211	1421	6.74
2740	2856	CRNRD	0002	360	6.72
2741	2986	WXOCF	1402	13	6.71
2742	2614	SANSM	3921	1381	6.70
2743	1957	CLLVL	0001	503	6.69
2744	2929	ARLNG	1291	87	6.67
2745	2479	CMPST	0001	454	6.64
2746	1143	PFLGV	2007	3994	6.60
2747	2689	HKBRY	1103	244	6.60
2748	2762	WGROB	8412	3894	6.60
2749	2823	MNSTR	1202	268	6.56
2750	2982	STERT	2702	19	6.49
2751	2719	PCOIT	1007	849	6.46
2752	2883	ALPHA	0006	294	6.41
2753	2608	BNMNW	1102	411	6.37
2754	2814	ALPHA	0010	517	6.36
2755	2897	MDWPK	9221	769	6.29
2756	1685	CLBNR	1401	22	6.20
2757	2289	WALNT	0002	1227	6.17
2758	1219	WHTRK	0003	1276	6.07
2759	1512	MDWCK	0006	887	6.04
2760	512	BARRY	1801	84	5.93
2761	475	IRLBJ	3231	2504	5.90
2762	224	GVODS	3052	1324	5.79
2763	2983	WALST	0007	27	5.76
2764	2691	BLNKT	0701	280	5.61
2765	2643	DENAV	0652	31	5.57
2766	2222	PSHIL	1607	458	5.52
2767	2907	HMPHL	2752	295	5.37
2768	35	CHROW	0004	200	5.33

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2769	2705	PLANO	1106	492	5.32
2770	916	PRSTN	0005	1191	5.32
2771	1752	WHTRK	0008	1514	5.30
2772	356	CHROW	0005	179	5.28
2773	1943	FRMBR	1802	1117	5.23
2774	2848	WWEST	1220	198	5.22
2775	2333	BRNSO	1808	792	5.15
2776	2805	MDWPK	9211	1274	5.15
2777	2491	HKBRY	1102	1682	5.12
2778	821	WDGWD	1552	314	5.11
2779	623	WATSN	5352	1900	5.05
2780	2358	ARLNG	1222	97	5.03
2781	2770	LMBLN	0001	2042	5.02
2782	#N/A	MLDR2	1601	364	5.01
2783	2589	HKBRY	1111	27	5.01
2784	1161	RNDRK	1509	1439	5.00
2785	1757	GODRD	8151	801	4.94
2786	2525	DESPR	1404	642	4.93
2787	1601	FRNKF	0001	964	4.87
2788	2021	CRNRD	0005	361	4.86
2789	503	CURIE	7231	1080	4.80
2790	654	MKNSW	2604	2101	4.79
2791	2896	COTRD	0004	105	4.70
2792	2593	ROANW	9522	42	4.69
2793	2974	PSHIL	1605	135	4.65
2794	2530	GORMN	0411	545	4.55
2795	2940	EULSO	9141	59	4.51
2796	1586	DAVIS	3723	350	4.42
2797	1583	CRLUD	1302	152	4.42
2798	#N/A	CMTSW	0946	865	4.35
2799	362	DAVIS	3743	200	4.31
2800	2191	BRKRG	0211	310	4.30
2801	2176	LOMAL	0012	714	4.18
2802	2465	TMNTH	1604	55	4.18
2803	2258	FROKS	0008	1514	4.14
2804	#N/A	PRMED	4404	1154	4.14
2805	2618	SHNRW	1610	434	4.08
2806	2740	HKBRY	1104	121	4.02
2807	2787	MSTLT	1032	27	3.98
2808	2082	HKHTS	1608	1312	3.82
2809	2979	SMBMG	1701	29	3.77
2810	351	WEAST	0626	291	3.66

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2811	637	BRTRD	7322	640	3.56
2812	682	WALNT	0001	1468	3.56
2813	2960	LSCOL	2135	608	3.52
2814	2056	WWEST	1218	1015	3.52
2815	208	WEBBS	8634	1194	3.52
2816	2817	HORNE	1923	1572	3.42
2817	2245	PSHIL	1606	1392	3.41
2818	497	WFALS	0163	361	3.39
2819	2129	WWEST	1221	37	3.34
2820	2645	BNMNW	1101	204	3.33
2821	2864	COPER	0401	116	3.33
2822	1425	PROAD	0001	126	3.31
2823	1733	RNKSW	5412	28	3.29
2824	2234	ARMST	0011	900	3.27
2825	629	PLGRV	0004	384	3.09
2826	2544	DESPR	1401	1700	3.00
2827	2832	PROAD	0009	124	2.96
2828	1379	LAVON	1453	949	2.95
2829	2497	ARMST	0007	125	2.94
2830	1348	FRMNT	0005	483	2.89
2831	313	RSNHT	1152	1039	2.88
2832	2248	MESFR	2104	156	2.81
2833	30	KYSTN	1011	89	2.79
2834	2418	MCGHR	2004	27	2.79
2835	2926	JNKNS	0008	27	2.74
2836	2561	DALWT	2992	332	2.71
2837	2463	COMRC	1204	587	2.69
2838	1118	MAPLE	0007	143	2.62
2839	2951	GSTHW	1672	40	2.60
2840	1182	MRSES	3016	41	2.57
2841	2891	TMSTH	1405	519	2.55
2842	1569	MSLSW	0003	193	2.53
2843	2200	BRKRG	0213	411	2.51
2844	2733	DALWT	2941	309	2.46
2845	2935	CRLTR	2006	54	2.44
2846	2673	WALST	0002	31	2.33
2847	2619	CKRHL	0007	73	2.32
2848	2899	CNEXP	0005	463	2.31
2849	2869	SHDYG	7812	126	2.31
2850	1325	PRKRW	3331	134	2.29
2851	2273	DGNST	0003	1161	2.20
2852	2557	ADISN	1603	192	2.18

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2853	2827	ADISN	1602	226	2.17
2854	2139	COMRC	1201	1018	2.16
2855	2981	STERT	2701	34	2.13
2856	1359	CRSGL	1303	91	2.13
2857	1718	TYOMN	1402	1615	2.11
2858	247	RSKMN	3078	135	2.09
2859	2865	PJPTR	3221	46	2.08
2860	1395	ALPHA	0016	1817	2.07
2861	879	CDCSW	0001	273	1.97
2862	917	ELKTN	2503	839	1.97
2863	2854	SHAMP	0002	1746	1.95
2864	1242	PROAD	0008	1206	1.95
2865	2588	FRNKF	0006	1726	1.91
2866	2919	FRMBR	1853	55	1.91
2867	2692	ALPHA	0015	838	1.87
2868	#N/A	MDLNE	0132	35	1.85
2869	2534	DESHR	1208	439	1.82
2870	2953	JNKNS	0002	197	1.80
2871	2966	PARIS	1205	29	1.74
2872	#N/A	TIODE	9622	974	1.70
2873	1420	HMPHL	2742	466	1.65
2874	2948	GSTHW	1613	93	1.64
2875	906	WEAST	0628	241	1.58
2876	2198	DGNST	0005	154	1.53
2877	2918	SMFLD	2362	63	1.52
2878	1934	WHTRK	0006	1311	1.42
2879	2867	FLMSO	3711	1661	1.41
2880	268	HKBRY	1109	129	1.31
2881	1476	VLYRN	2957	499	1.30
2882	42	BAYLC	1201	116	1.28
2883	2850	SORCY	0002	66	1.28
2884	2001	AMLIA	0006	80	1.18
2885	2908	COTRD	0005	228	1.10
2886	2806	GAVSW	0008	107	1.09
2887	2901	DGNST	0001	270	1.05
2888	2629	BRYAN	0007	244	0.98
2889	276	LMBLN	0008	119	0.94
2890	2270	HMPHL	2723	48	0.94
2891	2282	STNVL	1204	828	0.93
2892	2495	TMPNW	1103	682	0.91
2893	2582	SHDYG	7832	1854	0.91
2894	731	WFALS	0143	171	0.87

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2895	2546	NHNSW	0001	469	0.78
2896	2882	HKBRY	1113	427	0.75
2897	2913	ROBNW	1501	849	0.73
2898	2710	CRLUD	1301	24	0.65
2899	2978	RSPCK	2105	313	0.64
2900	2703	COMSO	1403	463	0.64
2901	2894	MSTLT	1042	500	0.62
2902	#N/A	DNINR	1404	177	0.60
2903	596	CNEXP	0002	880	0.59
2904	2962	LSCOL	2148	1572	0.59
2905	1947	FRMBG	1706	62	0.58
2906	2821	HMPHL	2733	116	0.55
2907	1233	LOMAL	0004	145	0.53
2908	284	WALNT	0008	873	0.52
2909	2759	VGCRK	8021	211	0.50
2910	1628	ENTOH	0004	2003	0.47
2911	2922	WMRNR	0003	799	0.44
2912	1381	JUDCT	0003	1775	0.44
2913	2793	TYBLR	2806	214	0.43
2914	2866	BRYAN	0002	213	0.42
2915	2877	FHLSW	1382	108	0.42
2916	2736	COTRD	0008	1352	0.36
2917	2786	CNEXP	0008	414	0.36
2918	2682	WEAST	0627	205	0.35
2919	1022	CURIE	7241	713	0.34
2920	2738	JUDCT	0004	216	0.34
2921	2792	EULES	8714	811	0.33
2922	2779	RGFTW	6822	23	0.31
2923	2372	LWSNR	2212	1410	0.27
2924	2807	MDWCK	0008	888	0.27
2925	2029	TYLGE	1314	946	0.26
2926	2957	KNLTR	0009	861	0.24
2927	2771	INAIR	1414	766	0.24
2928	2175	BDFWD	8911	937	0.23
2929	2578	IRLBJ	3222	1033	0.22
2930	2858	CURIE	7222	970	0.20
2931	1446	MAPLE	0002	910	0.12
2932	2481	CKRHL	0004	424	0.11
2933	2909	FRMNT	0007	703	0.10
2934	2811	ARMST	0003	366	0.09
2935	2235	SCHRD	0004	1924	0.07
2936	2893	WEBBS	8613	634	0.06

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2937	2921	PWEST	1306	286	0.06
2938	2917	RECCR	0005	157	0.05
2939	2824	BKWST	0004	1053	0.03
2940	31	ANARN	1911	19	0.00
2941	119	FRMBG	1702	62	0.00
2942	186	DFWSW	2202	57	0.00
2943	389	AMLIA	0005	10	0.00
2944	453	ALPHA	0004	22	0.00
2945	924	DALLW	0002	62	0.00
2946	935	SCHRD	0008	74	0.00
2947	1177	LUFKN	1204	33	0.00
2948	1293	PROAD	0006	133	0.00
2949	1412	ARPCM	4169	11	0.00
2950	2819	FRMBG	1704	37	0.00
2951	2161	DFWSW	2204	24	0.00
2952	2215	RRWES	1603	11	0.00
2953	2252	CHROW	0006	82	0.00
2954	2294	COTRD	0003	109	0.00
2955	2324	SHSTH	1302	20	0.00
2956	2764	STERT	2704	10	0.00
2957	2376	RNKSW	5413	37	0.00
2958	2411	EXPKY	8141	23	0.00
2959	2964	MDDTN	4322	26	0.00
2960	2906	STERT	2703	333	0.00
2961	2574	WWEST	1217	102	0.00
2962	2596	LKWOD	7421	43	0.00
2963	2638	RVRFT	0001	28	0.00
2964	2669	RSPCK	2133	778	0.00
2965	2695	CPLSO	4311	95	0.00
2966	2734	MAPLE	0008	214	0.00
2967	2773	INAIR	1442	114	0.00
2968	2784	CURIE	7212	20	0.00
2969	2833	AMLIA	0007	93	0.00
2970	2870	BRNAV	0774	205	0.00
2971	2888	NPKWY	0007	180	0.00
2972	2928	ALLEN	2405	27	0.00
2973	2930	ARMST	0008	246	0.00
2974	2932	COLDG	4048	10	0.00
2975	2933	COMRC	1202	49	0.00
2976	2934	COTRD	0001	11	0.00
2977	2941	EXPKY	8112	11	0.00
2978	2942	FRMBG	1703	31	0.00

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2979	2943	FRMNT	0006	12	0.00
2980	2949	GSTHW	1651	13	0.00
2981	2950	GSTHW	1662	13	0.00
2982	2952	INAIR	1421	18	0.00
2983	2956	KNLTR	0007	12	0.00
2984	2968	PJPTR	3231	25	0.00
2985	2970	PJPTR	3242	76	0.00
2986	2975	PTENN	2356	14	0.00
2987	2976	REGST	0007	10	0.00
2988	2985	WMMMR	2704	18	0.00
2989	#N/A	ALPHA	0012	14	0.00
2990	#N/A	BLMND	3223	230	0.00
2991	#N/A	DFWSE	2710	72	0.00
2992	#N/A	DFWSE	2713	17	0.00
2993	#N/A	FBRIW	1901	305	0.00
2994	#N/A	GLSCN	6221	20	0.00
2995	#N/A	PAULN	2503	115	0.00
2996	#N/A	PWEST	1305	15	0.00
2997	#N/A	RRWES	1623	716	0.00
2998	#N/A	SCHRD	0002	297	0.00

NOTES:

EMMAS4021 was transferred to EMMAS4022 (new substation transformer and breaker)
MDLNE0163 was transferred to MDLNE0161 (new substation transformer and breaker)
MDLNE0133 was transferred to MDLNE0131 (new substation transformer and breaker)
MDLNE0141 was transferred to MDLNE0142 (new substation transformer and breaker)
MDLNE0122 was transferred to MDLNE0121 (new substation transformer and breaker)

Oncor Electric Delivery

INTERRUPTION CAUSES

Provide the percentage of interruptions attributable to each cause.

2016 Reporting Year

Causes of Forced Interruptions	Percentage
Weather (Including Lightning)	13%
Vegetation	16%
Animals and Birds	6%
People (Including cars and farm equip	14%
Utility-owned Equipment	45%
Other	1%
Unknown	5%