



Control Number: 46717



Item Number: 5

Addendum StartPage: 0

RECEIVED

2017 FEB 14 PM 12:02

**PUBLIC UTILITY COMMISSION
FILING CLERK**

Service Quality Report
To The
Public Utility Commission of Texas
In Accordance With
Substantive Rule §25.81
2016 Reporting Year

Oncor Electric Delivery

Project 46717

4

5

6

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

System SAIFI	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced 2016	0.97	0.07	0.06	0.07	0.04	0.08	0.09	0.10	0.12	0.11	0.09	0.08	0.06
Scheduled 2016	0.07	0.00	0.00	0.00	0.01	0.00	0.01	0.01	0.01	0.01	0.01	0.00	0.01
Outside Causes 2016	0.08	0.01	0.00	0.01	0.00	0.01	0.01	0.00	0.01	0.01	0.00	0.01	0.01
Major Events 2016	0.69	0.00	0.00	0.07	0.13	0.18	0.09	0.13	0.05	0.00	0.00	0.01	0.03

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

System SAIDI	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced 2016	89.58	5.36	5.00	6.34	4.90	8.17	8.06	9.49	11.30	11.11	7.53	6.99	5.33
Scheduled 2016	4.46	0.30	0.32	0.30	0.31	0.31	0.45	0.37	0.33	0.56	0.45	0.33	0.43
Outside Causes 2016	3.72	0.48	0.12	0.34	0.03	0.47	0.46	0.32	0.18	0.57	0.13	0.49	0.13
Major Events 2016	107.32	0.00	0.00	8.44	18.89	28.03	13.61	26.31	7.47	0.00	0.00	0.65	3.92

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

Total Number of Feeders

With 10 or more Customers

2998

Add or Delete Rows as Necessary

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1	288	SBEAN	6011	182	18.86
2	53	ELMAR	3211	134	10.94
3	122	SNDHL	3821	61	9.07
4	2900	BRKTN	1202	120	8.53
5	88	CWIND	6311	27	8.00
6	316	CNANG	1806	2458	7.70
7	961	MASON	3421	53	7.62
8	302	NHNSW	0006	946	7.47
9	1924	LOVNG	2521	44	7.14
10	38	MSTNG	2621	72	7.06
11	35	RYLTY	1411	126	6.85
12	1178	MNFLD	2672	2275	6.59
13	591	KNOTT	5221	60	6.58
14	12	PLDAV	4231	73	6.00
15	210	BRIRV	6922	3406	5.97
16	478	MDLNW	1582	2061	5.96
17	147	COYAN	6321	311	5.94
18	344	BRNSY	1211	135	5.93
19	41	CRNES	2711	143	5.86
20	231	MEXIA	4008	690	5.82
21	79	MASON	3431	142	5.79
22	5	LOVNG	2511	51	5.78
23	1170	BKWWF	0521	463	5.69
24	99	NCDCH	1201	781	5.68
25	27	MDLNW	1531	1754	5.54
26	220	BLKRV	8311	48	5.48
27	31	ELMAR	3212	38	5.29
28	286	WINKS	0531	48	5.25
29	355	MIDWY	0612	474	5.24
30	238	TXHRV	1611	169	5.21
31	1349	ELMAR	3222	87	5.16
32	85	MSTNG	2611	145	5.14
33	47	TIODE	9632	413	5.11
34	1264	FRNKS	4168	968	5.03
35	664	ANDRD	0921	91	5.02
36	1616	MEXIA	3016	279	5.01
37	1882	CRLUD	1303	616	5.00
38	391	MDFRM	2131	11	5.00
39	445	UPTON	0721	121	4.97
40	1487	RYSSW	2804	2188	4.95
41	162	MIDWY	0621	141	4.93
42	2589	MCGRG	0776	222	4.88
43	2469	WMRLD	0006	593	4.82

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
44	816	FARON	4011	642	4.81
45	468	GLSCK	2411	240	4.78
46	1026	OKCLS	0006	687	4.76
47	579	ADMDS	6532	466	4.75
48	270	LMBLN	0005	686	4.74
49	133	AMMFG	5611	813	4.69
50	57	CLCTY	1011	1056	4.64
51	1162	NCDCH	1205	1084	4.61
52	257	LUFKN	1203	741	4.58
53	N/A	GASLD	4211	101	4.57
54	247	EMMAS	4022	60	4.53
55	722	WSTHL	3621	4999	4.52
56	343	MAPLE	0006	2373	4.51
57	1274	GNSVE	1603	1687	4.50
58	3	BARNW	4511	72	4.50
59	2610	BRIRV	6921	2448	4.43
60	452	PRNTH	1405	986	4.39
61	2323	NCDCH	1203	1825	4.39
62	996	TMNTH	1606	232	4.35
63	146	WDGWD	1531	1516	4.35
64	1717	DAVST	0004	1721	4.31
65	1603	IRVNE	1304	630	4.22
66	179	MDFRM	2111	63	4.17
67	2638	DEALY	0003	1773	4.17
68	349	CHRNO	1203	419	4.16
69	15	BARNW	4521	101	4.15
70	104	LKMNT	0002	987	4.12
71	1596	CHALK	0951	73	4.11
72	2124	BKBNT	1842	555	4.10
73	853	EMPCT	0008	37	4.08
74	1363	PLKST	0007	1784	4.07
75	878	CKRHL	0002	425	4.05
76	2153	WRTHM	5004	225	4.03
77	144	RYLTY	1421	453	4.02
78	653	RYLTY	1431	76	4.01
79	2606	WALST	0006	10	4.00
80	1190	MCGRG	1902	491	3.99
81	2623	PLKST	0001	786	3.99
82	2472	FORSW	2053	3210	3.96
83	139	DGLAS	2401	754	3.95
84	N/A	LKBLT	2103	1915	3.94
85	241	FRFWS	3004	822	3.93
86	1328	FRNKS	1201	385	3.89
87	2106	ELCTR	1211	279	3.83
88	96	WXHNW	2901	179	3.82
89	1046	PRFTW	4222	3314	3.82
90	52	TYLGE	1311	809	3.78
91	148	CRSCN	1206	1518	3.78

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
92	132	MEXIA	4023	616	3.76
93	7	DHIDE	2811	105	3.74
94	1476	EMMAS	4012	86	3.73
95	673	ODESA	0242	640	3.72
96	1525	BLMND	3241	231	3.71
97	611	AYERS	4421	1481	3.69
98	390	PMBRK	1821	73	3.68
99	2257	RSPCK	2131	58	3.67
100	2829	PAYSW	1223	115	3.66
101	716	FSTVW	0003	1929	3.66
102	1806	KMASB	1711	304	3.62
103	312	MDLNE	0161	992	3.61
104	1661	NHNSW	0007	581	3.61
105	159	HOWRD	3921	74	3.58
106	1847	LMESA	1522	1334	3.57
107	1957	NWARD	3511	63	3.52
108	102	STHRL	0004	1278	3.52
109	847	BNBRK	4122	2743	3.52
110	641	CLMET	0003	909	3.51
111	1223	WOVER	6111	1329	3.50
112	4	MASON	3411	30	3.50
113	2419	ABRRD	0008	1438	3.49
114	350	BRNAV	0753	1267	3.49
115	219	MKNSW	2601	3198	3.48
116	2837	BNDRA	0013	146	3.48
117	1677	WWDWY	2015	1200	3.48
118	1186	MRSES	4005	751	3.48
119	1446	ENNIS	1902	1260	3.47
120	1634	HRSMO	1905	2787	3.47
121	1504	PAYSW	1205	724	3.46
122	801	BLMED	1622	955	3.45
123	2911	ARMST	0006	613	3.44
124	22	GRLND	1604	1996	3.43
125	2054	MYPRL	1801	158	3.42
126	392	CNSES	3056	2646	3.42
127	483	BRLSN	2051	2689	3.42
128	252	PGSTH	7021	135	3.41
129	1081	MKNNY	1251	1517	3.41
130	915	DFWNW	2603	10	3.40
131	2451	INAIR	1413	2418	3.39
132	1671	ALNTH	2854	690	3.35
133	1041	PRKRW	3321	163	3.34
134	1495	GRPVN	8213	264	3.34
135	78	SSPNE	1403	1109	3.34
136	361	SCYEN	0004	1234	3.33
137	2674	WHITE	3521	1122	3.32
138	1038	GRSMN	3071	333	3.31
139	2665	BRKRG	0242	24	3.29

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
140	706	CLKVL	1202	1265	3.27
141	2984	WALST	0008	11	3.27
142	870	WXHCH	1205	972	3.26
143	228	HNTNG	1307	1499	3.26
144	237	LTFRD	3011	945	3.26
145	2429	KLNPS	1105	1556	3.25
146	2809	HMTRD	0003	428	3.21
147	603	PEGAS	2311	121	3.21
148	1823	BNBRK	4112	2229	3.20
149	1559	KNLTR	0011	1852	3.20
150	245	NCNTH	1806	868	3.19
151	1843	COMRC	1203	682	3.19
152	1540	MNWLE	1702	1287	3.19
153	1536	LAVON	1401	1714	3.18
154	934	SHAMP	0004	1142	3.17
155	510	TRIRA	6222	998	3.17
156	16	JDKNS	0821	38	3.16
157	945	MRLNS	4002	411	3.13
158	1101	OTTOJ	3060	17	3.12
159	1149	WHITE	3531	1922	3.12
160	2627	BRLSN	2062	3790	3.12
161	2682	HRSMD	1951	4461	3.11
162	2754	NHNSW	0002	404	3.09
163	1964	NMAIN	0211	1928	3.08
164	1719	BRHLW	7622	1130	3.07
165	232	NCWDN	1121	59	3.07
166	2602	BANGS	1201	1498	3.04
167	1624	IRVND	1204	1353	3.03
168	18	BAKKE	6922	1458	3.03
169	1076	GAVSW	0006	522	3.02
170	927	MSLSW	0001	846	3.02
171	71	BLSRA	1601	1404	3.02
172	532	TYLNE	1613	464	3.02
173	1885	FROKS	0004	118	3.01
174	2938	COLDG	4048	10	3.00
175	1524	TNSCL	1104	198	2.99
176	1632	BRKRG	0223	286	2.99
177	70	CRLTN	1454	347	2.98
178	310	WLSPT	1001	1956	2.98
179	2879	DENDR	0009	63	2.95
180	2	DHIDE	2821	116	2.95
181	1925	EZACH	0005	541	2.95
182	2365	CPLSO	4321	158	2.94
183	2550	PRSTN	0004	674	2.93
184	2594	MDWCK	0004	1750	2.93
185	2426	IRVNR	1553	1336	2.91
186	1057	RGLRW	0001	34	2.88
187	776	JNKNS	0005	552	2.86

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
188	453	JDKNS	0822	57	2.86
189	330	ESKSW	2711	107	2.85
190	N/A	DENDR	0003	2224	2.85
191	1835	AZLES	2121	2882	2.84
192	470	MDLNE	0112	363	2.84
193	176	PLDAV	4221	219	2.84
194	253	JEWET	1202	759	2.83
195	1767	KMASB	1721	105	2.82
196	400	HRSMD	1955	2091	2.81
197	1931	PLGRV	0003	594	2.79
198	879	DENAV	0683	884	2.78
199	441	SPRTN	1801	1843	2.77
200	351	PRNTH	1406	1021	2.76
201	867	DCATR	1201	1258	2.76
202	480	FORSN	5632	237	2.76
203	2621	NMAIN	0241	712	2.75
204	1397	CNANG	1804	192	2.73
205	1034	CRNTH	2401	2531	2.73
206	2254	LKMNT	0003	603	2.72
207	2958	JNKNS	0002	197	2.72
208	2952	GSMTH	1731	49	2.71
209	1327	GRPTT	9911	697	2.71
210	901	GRSMN	3027	362	2.70
211	1045	BSPSW	0832	406	2.68
212	1114	CRISP	1501	916	2.68
213	734	FKLCY	5121	105	2.67
214	23	ANDRD	0931	191	2.66
215	271	RSPCK	2102	1562	2.66
216	1746	SPRDL	4841	953	2.65
217	135	AZLES	2112	1718	2.65
218	287	TYEST	1501	1757	2.65
219	368	TYLNE	1624	259	2.63
220	562	GLSCN	6211	119	2.62
221	894	MSLSW	0005	1023	2.62
222	2016	EULES	8711	2049	2.61
223	1547	WFALS	0184	1263	2.61
224	503	MCWHT	3511	3132	2.60
225	2170	RANGR	4321	869	2.59
226	276	WMRLD	0007	1696	2.59
227	1578	CLKVL	1203	633	2.58
228	929	COHMA	1132	63	2.57
229	1069	FRMNT	0014	629	2.57
230	1115	CUMBY	1201	750	2.57
231	2227	MOSSW	4621	1462	2.56
232	891	NCRST	2204	443	2.56
233	650	MESQW	1808	1343	2.55
234	552	JKSES	3029	1183	2.55
235	2238	GLNHV	3911	1360	2.55

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
236	921	BRNAV	0762	2393	2.55
237	1283	KMP SO	2400	931	2.54
238	34	COYAN	6311	105	2.53
239	2018	HLSBR	1202	1224	2.52
240	1276	NPKWY	0010	3016	2.52
241	1312	ATHNW	1402	487	2.52
242	105	CRNAT	4121	64	2.52
243	1366	PCUST	2011	1639	2.51
244	1473	MNFLD	2621	2282	2.51
245	536	SMFLD	2313	2128	2.51
246	1269	LGVST	8511	754	2.51
247	1876	TYRSW	1701	2410	2.51
248	2603	ATNRN	3412	5640	2.49
249	1910	BLMED	1621	2067	2.49
250	1124	FSCRK	6713	3068	2.49
251	404	DALLW	0005	128	2.48
252	1860	MABNK	2404	2541	2.47
253	2151	RWDHV	1902	967	2.46
254	1531	TYSTH	1203	430	2.46
255	1393	MABNK	2401	2132	2.45
256	780	SHNRW	1611	975	2.45
257	1350	HLSBR	1201	1128	2.45
258	2608	FLMSO	3714	1231	2.45
259	2193	NCRST	2201	1934	2.44
260	926	BSPSW	0812	1076	2.44
261	2284	RKDLE	1302	1186	2.44
262	2246	HSKAV	0002	1737	2.44
263	161	SCHRD	0007	1405	2.44
264	208	NOLNW	2111	23	2.43
265	48	EMPCT	0001	35	2.43
266	151	GYVLM	8611	14	2.43
267	2158	PARIS	1203	953	2.42
268	2295	PGSTH	7011	43	2.42
269	2357	ARTHR	0462	209	2.42
270	583	PALRD	2201	797	2.41
271	558	LNCST	1605	816	2.41
272	1361	RTHGB	1411	680	2.41
273	1645	WCITY	2402	684	2.40
274	1116	LFEST	1902	1044	2.39
275	1355	RDLML	2581	1238	2.39
276	1172	SLAKE	8321	4376	2.38
277	1891	NHNSW	0003	527	2.38
278	1958	RDLML	2552	281	2.38
279	2804	WGROB	8421	2174	2.38
280	660	AYERS	4431	1667	2.37
281	2537	CHROW	0007	84	2.37
282	1798	FSCRK	6732	4208	2.37
283	1251	NCSFA	1706	1185	2.36

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
284	2730	PJPTR	3211	118	2.36
285	2929	JNKNS	0006	525	2.36
286	1756	WOVER	6131	2113	2.36
287	337	REYST	4051	1076	2.35
288	571	RDLML	2571	365	2.35
289	810	PPARK	1803	1063	2.35
290	225	QNLAN	1201	850	2.34
291	1278	SWAN2	1801	543	2.34
292	2697	CTYVW	2221	1829	2.34
293	1879	FORSN	5611	12	2.33
294	2199	EULSO	9132	1987	2.33
295	1286	DALRK	1307	1161	2.32
296	1382	SYCRK	4532	4150	2.32
297	1400	DESPR	1407	944	2.32
298	1612	WWDWY	2022	1028	2.31
299	45	RYSSW	2803	2278	2.31
300	87	HNTNG	1301	1390	2.29
301	1801	BNDRA	0002	540	2.29
302	1191	INDIA	2501	376	2.29
303	1731	PLKST	0002	837	2.29
304	2009	SYCRK	4512	4161	2.29
305	656	BRKTN	1201	493	2.29
306	1584	PTENN	2353	936	2.28
307	371	OAKHL	3011	2252	2.28
308	570	MDLNE	0131	2564	2.28
309	1695	CNEXP	0004	912	2.28
310	1888	STAUG	0002	1402	2.28
311	459	GSMTH	1732	45	2.27
312	1783	VLYRN	2953	2837	2.26
313	2428	GAVSW	0009	1032	2.26
314	1752	IRVNE	1305	236	2.26
315	21	PRCRK	0001	202	2.26
316	1462	DALRK	1354	1461	2.26
317	127	GSMTH	1721	47	2.26
318	2651	MSHLN	0008	680	2.25
319	1529	HNTNG	1306	1085	2.25
320	72	ENTOH	0001	846	2.25
321	235	LUFKN	1208	1786	2.25
322	1937	SSPSW	1604	1212	2.25
323	2715	PTENN	2352	2488	2.24
324	2251	MOSSW	4611	1583	2.24
325	857	WRBND	2321	1545	2.23
326	965	PRMED	4401	2042	2.23
327	2573	HORNE	1911	1017	2.23
328	1267	WHITE	3541	955	2.22
329	1365	IRVNE	1306	1535	2.22
330	863	PROAD	0007	422	2.22
331	111	WEBBS	8612	3384	2.22

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
332	328	LFEST	1905	1791	2.21
333	862	EULES	8724	2400	2.20
334	451	CHYNE	9111	30	2.20
335	449	FLRTN	3721	75	2.20
336	2363	MESQN	1507	696	2.20
337	50	BAKKE	6912	1842	2.20
338	848	MDLNW	1522	1180	2.19
339	1648	RENSW	3122	1541	2.19
340	698	RCHLD	2101	613	2.19
341	2875	PRHLL	2402	59	2.19
342	2702	RVRFT	0002	330	2.18
343	2210	FRMBR	1803	2408	2.18
344	1775	CHSPG	2401	3722	2.17
345	659	CRLUD	1307	290	2.17
346	1348	SYCRK	4522	2835	2.17
347	690	CMTSW	0922	1420	2.17
348	1203	FORSN	5642	42	2.17
349	761	REAST	1502	1323	2.16
350	2042	KNLTR	0003	624	2.16
351	2871	GAVSW	0008	107	2.16
352	2463	GAVSW	0012	834	2.16
353	113	ENTOH	0002	808	2.15
354	1086	CKRHL	0001	415	2.15
355	2098	CRNRD	0001	740	2.15
356	2617	GAVSW	0010	486	2.15
357	2869	WATSN	5372	1339	2.14
358	81	RHOME	2402	1324	2.14
359	1492	MEXIA	3015	123	2.14
360	1851	REGST	0004	980	2.14
361	668	PLSTN	1003	1454	2.13
362	953	ALDTU	9411	2505	2.13
363	1930	HSKAV	0004	1315	2.13
364	92	KNAPP	4021	31	2.13
365	2559	PCOMM	3313	473	2.13
366	223	ABRRD	0005	1461	2.13
367	1619	ANDNR	2231	1086	2.13
368	39	GVODS	3041	1477	2.12
369	399	BLMND	3213	3272	2.12
370	1177	NCNTH	1802	1289	2.12
371	166	GRLND	1605	1533	2.12
372	341	ACRLY	1721	60	2.12
373	1466	FHLSW	1332	309	2.12
374	1108	CRLTR	2004	235	2.11
375	2684	WRTHM	5012	315	2.11
376	2182	ABRRD	0006	456	2.11
377	60	COLNY	2405	2388	2.11
378	6	VANSB	1501	797	2.11
379	825	MCWHT	3522	2963	2.11

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
380	112	BNDRA	0009	718	2.11
381	2517	WFALS	0153	1135	2.10
382	1613	GRDNC	1211	49	2.10
383	2925	RDRSE	2605	736	2.10
384	2483	BRGPR	1101	627	2.10
385	444	JKWST	4035	81	2.10
386	631	MKNNY	1252	2649	2.10
387	374	WBOSE	1103	906	2.10
388	1720	WNDWD	3641	1483	2.09
389	2593	ARMST	0010	880	2.09
390	320	SMPST	0003	1020	2.08
391	163	BARRY	1802	300	2.08
392	2410	DNCNV	1903	1203	2.07
393	804	PRSTN	0006	758	2.07
394	995	NCSFA	1704	1402	2.07
395	2277	FLMSO	3716	2141	2.07
396	422	IRVNR	1501	1103	2.07
397	585	ENSSO	2004	1202	2.07
398	1129	EULES	8723	5166	2.07
399	25	PRNTH	1404	1474	2.06
400	17	ODESA	0212	885	2.06
401	201	CSHNG	1202	66	2.06
402	375	WMRLD	0001	222	2.05
403	2888	TERSO	2503	1097	2.05
404	1757	NHNSW	0005	422	2.05
405	2329	WBOSE	1102	347	2.05
406	2979	RGFTW	6841	20	2.05
407	2723	CLCRK	1011	204	2.04
408	1330	ABRRD	0004	850	2.04
409	318	MKNGB	5321	590	2.03
410	2544	HRSMD	1907	2662	2.03
411	2055	WOVER	6122	833	2.03
412	649	RSPCK	2103	167	2.03
413	817	WOVER	6142	1505	2.03
414	543	RENSW	3124	1708	2.03
415	2634	TYBLR	2808	981	2.03
416	244	HUTCH	1501	974	2.02
417	1188	UPTON	0711	170	2.02
418	835	HKBRY	1105	185	2.02
419	1277	ELZCK	4921	1733	2.02
420	408	CRLCC	2703	635	2.02
421	2250	PKRVL	1051	4720	2.02
422	2468	ARMST	0012	1161	2.02
423	1468	SWTWR	1341	246	2.00
424	1577	WNDWD	3611	297	2.00
425	960	ALLNC	6422	15	2.00
426	2916	COTRD	0005	228	2.00
427	993	DAVIS	3762	41	2.00

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
428	2795	TRLNW	2401	22	2.00
429	2487	ROLTR	2921	2599	2.00
430	1013	FRMNT	0001	850	2.00
431	942	SSPNE	1401	1276	1.99
432	632	MESQW	1802	827	1.99
433	1813	TRLWD	7722	4056	1.99
434	149	FRMNT	0004	2377	1.98
435	474	BRIRV	6912	805	1.98
436	1371	RDOAK	1302	1252	1.98
437	684	TRNTY	7521	1165	1.98
438	819	SCURY	1911	172	1.98
439	2139	CNTRY	2833	2366	1.98
440	1765	FARON	4041	1032	1.98
441	704	MDAIR	2921	71	1.97
442	1356	FERIS	1103	988	1.97
443	1048	CHICW	1302	202	1.97
444	77	MDAIR	2911	412	1.97
445	1721	THRDN	1901	1710	1.97
446	1075	NCDSW	3811	1469	1.97
447	83	TYLNE	1605	1181	1.97
448	1164	WATCO	2602	2273	1.96
449	1805	GNSVL	1203	1622	1.96
450	1833	PWEST	1303	1008	1.96
451	489	ARMST	0002	1685	1.96
452	2179	TYLGE	1316	2841	1.95
453	432	WELCH	4911	22	1.95
454	1227	MKNGB	5311	487	1.95
455	1144	TYOMN	1409	1600	1.95
456	1483	SBEND	0611	171	1.95
457	2409	GLNHV	3992	1158	1.95
458	2637	GODRD	8161	2216	1.94
459	525	ATHNS	1203	1044	1.94
460	1730	GRDNE	9211	439	1.94
461	439	ALPHA	0005	128	1.94
462	597	CANTN	1301	2169	1.94
463	242	RWALL	1202	2503	1.93
464	1369	WALST	0004	45	1.93
465	2437	HORNE	1961	1774	1.93
466	511	BAKKE	6911	287	1.92
467	1594	LWSNR	2232	2269	1.92
468	1842	WMRLD	0004	1584	1.92
469	366	SCURY	1921	101	1.91
470	121	WINKS	0521	51	1.90
471	2513	BLMND	3282	91	1.90
472	1012	JNKNS	0004	129	1.90
473	715	NECSP	2401	564	1.90
474	775	OAKHL	3021	1988	1.90
475	1429	AMMFG	5621	553	1.90

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
476	1072	BKBNT	1832	196	1.89
477	634	WESTS	1601	1047	1.89
478	818	EZACH	0007	1591	1.88
479	2750	NCSTH	1505	17	1.88
480	876	COLDG	4047	411	1.88
481	164	STANT	1311	1525	1.87
482	216	NCSTH	1503	916	1.86
483	1125	DIBOL	1505	1446	1.86
484	600	CMEXP	1601	249	1.85
485	674	REAST	1505	999	1.85
486	963	CLNSE	4201	933	1.84
487	291	IOWPK	0821	756	1.84
488	529	RSNHT	1162	1514	1.83
489	303	SMOUR	0721	18	1.83
490	236	HURST	1872	2104	1.83
491	1008	HORNE	1933	1998	1.83
492	1510	CRLTN	1453	297	1.83
493	212	PLSTN	1004	1576	1.83
494	1913	PLANO	1101	404	1.83
495	1085	PTENN	2355	179	1.82
496	1404	RWALL	1203	3587	1.82
497	2453	BLTLN	0002	880	1.82
498	1769	DALWT	2931	1563	1.82
499	647	BSPSW	0851	1426	1.81
500	672	MTLDA	0001	2603	1.81
501	697	MRDCK	0004	824	1.80
502	633	ALVRD	1501	1172	1.80
503	676	SWDTN	1611	1488	1.80
504	1807	KLRPR	9021	2022	1.80
505	1736	NCNTH	1808	757	1.80
506	1886	SNYDR	1852	1347	1.80
507	2574	FRMNT	0010	2519	1.79
508	1154	LKBLT	2105	2003	1.78
509	463	NCDCH	1204	1268	1.78
510	2278	FROKS	0003	639	1.77
511	1668	HLSBR	1203	1643	1.76
512	1187	CRLUD	1305	1368	1.76
513	502	PLDAV	4211	57	1.75
514	1539	CRLTN	1403	211	1.75
515	1421	MNWLL	1207	2096	1.75
516	1424	ODNTH	2033	676	1.75
517	2584	TYLNW	1912	2100	1.74
518	2758	PCOIT	1024	2312	1.74
519	1772	KLNPS	1102	1883	1.74
520	759	GLNHV	3922	730	1.74
521	2699	MCHSN	1201	244	1.73
522	1066	CLBNR	1407	268	1.73
523	354	CRKET	2402	1672	1.73

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
524	1137	DGNST	0006	1283	1.73
525	2963	LSCOL	2114	91	1.73
526	2446	PTENN	2358	1440	1.72
527	481	TSLVL	4008	2029	1.72
528	1201	CRSCN	1205	766	1.72
529	1345	HNRTA	0321	850	1.71
530	1799	SNYDR	1823	1472	1.71
531	1700	LAVON	1406	1476	1.70
532	540	WBROK	3011	199	1.70
533	737	OAKHL	3052	765	1.70
534	1377	NCNTH	1801	2532	1.70
535	2918	WALST	0012	516	1.70
536	1250	DNCNV	1902	1078	1.70
537	1534	BLVUE	1111	358	1.69
538	224	KFMNW	1201	1020	1.69
539	594	CMPST	0004	1586	1.69
540	1694	PRKWY	1521	2322	1.69
541	689	RSPCK	2108	960	1.69
542	1489	TRSES	1201	500	1.69
543	1905	CMPWI	0002	1660	1.69
544	1197	MEXIA	4012	1112	1.68
545	944	WNRTH	1417	1395	1.68
546	93	GLNHV	3973	1525	1.68
547	477	HURST	1822	1588	1.67
548	1453	BDFRD	8821	889	1.67
549	1213	FHLSW	1321	414	1.67
550	1083	DNCNV	1901	891	1.67
551	1808	HRSMD	1957	2457	1.67
552	592	EGFRD	0005	738	1.67
553	491	MNWLL	1206	1105	1.67
554	2066	BLTSW	3201	2607	1.66
555	N/A	STANT	1313	162	1.66
556	2034	WNRTH	1421	1484	1.66
557	1908	WXNTH	2308	869	1.66
558	492	RCLNS	1406	527	1.66
559	191	ELKTN	2508	1419	1.65
560	513	LUFKN	1206	1615	1.65
561	488	BOWEN	3171	1717	1.65
562	966	LKMNT	0004	2183	1.65
563	137	KRGRV	2403	3720	1.64
564	2209	LAVON	1454	2979	1.64
565	2826	SIKES	2422	1066	1.64
566	1776	PFFRD	3441	1211	1.64
567	1465	CPRCV	1404	1616	1.64
568	95	BNDRA	0006	693	1.63
569	1705	TRLNW	1203	682	1.63
570	1364	LUFKN	1201	1341	1.63
571	2505	JNKNS	0003	1064	1.63

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
572	1401	TEGMN	3038	1664	1.63
573	64	CNTRY	2831	1592	1.63
574	1224	RRSTH	1706	3691	1.63
575	1997	DNISN	1202	819	1.62
576	2389	GVGLF	9601	50	1.62
577	1464	TRLWD	7711	2341	1.62
578	962	BLTON	1803	441	1.62
579	2234	CRANE	0311	791	1.61
580	1527	ROLTR	2912	3609	1.60
581	211	RDLML	2561	897	1.60
582	1545	ALLNC	6412	3266	1.60
583	556	FRSTN	1602	1248	1.60
584	450	EDGWD	1101	629	1.60
585	348	LSCOL	2138	1057	1.60
586	975	ADISN	1605	1106	1.60
587	323	COHMA	1111	730	1.59
588	1479	LORAN	9711	391	1.59
589	1832	DENAV	0611	852	1.59
590	2913	MDAIR	2912	851	1.59
591	1520	TYBLR	2803	787	1.59
592	841	DESPR	1403	1796	1.59
593	1921	BRNAV	0741	2076	1.59
594	760	SCYEN	0001	2012	1.58
595	37	WEBBS	8623	2800	1.58
596	791	MESQT	1302	654	1.58
597	1517	HMTRD	0002	2178	1.58
598	1091	FRMNT	0003	877	1.58
599	581	ODESA	0251	1891	1.58
600	1293	WXHCH	1204	1782	1.56
601	2152	CMPWI	0004	1025	1.56
602	1047	BRKNR	1211	116	1.56
603	290	WALST	0014	893	1.56
604	983	BLTON	1806	847	1.56
605	1335	WMRLD	0003	489	1.56
606	2670	RWALE	3326	3032	1.55
607	1138	JREST	2102	1051	1.55
608	1597	DALWT	2991	1222	1.55
609	24	ECTHP	4911	1195	1.55
610	1687	LUFKN	1202	1070	1.55
611	2325	LEMON	0004	579	1.55
612	2007	SCYEN	0002	1282	1.55
613	136	MSLMN	4007	134	1.54
614	473	IRVND	1205	218	1.54
615	1338	OVRTN	4019	660	1.54
616	2225	TMPLE	1205	2488	1.54
617	1505	CRLUD	1304	1498	1.54
618	1890	BLMED	1619	1036	1.53
619	1729	ARTHR	0452	680	1.53

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
620	1830	BRNSO	1805	798	1.53
621	1199	DNCNV	1904	1471	1.53
622	1033	GNSVL	1213	737	1.53
623	123	MKNSO	3611	1944	1.53
624	1171	RHOME	2401	1183	1.53
625	364	MNHNS	1912	1899	1.52
626	1155	MSHLN	0001	1043	1.52
627	2716	HSKAV	0006	756	1.52
628	2000	RDLML	2591	1626	1.52
629	1152	LFSTH	1407	1730	1.52
630	645	SHMNE	1409	900	1.52
631	2729	GLNHV	3931	1338	1.51
632	1779	ROLTR	2922	2467	1.51
633	781	MRLNS	4003	938	1.50
634	654	DWSON	3121	28	1.50
635	1841	LVOAK	1601	863	1.50
636	1722	PCUST	2004	1204	1.50
637	2746	HRSMD	1953	405	1.49
638	1555	BSPRW	2532	1604	1.49
639	448	IRVHF	2305	1455	1.49
640	1073	MDDTN	4331	1835	1.49
641	1391	BRHLW	7612	710	1.48
642	2019	SALSW	3001	1484	1.48
643	63	ATHNS	1202	775	1.48
644	1676	CPRCV	1406	1640	1.48
645	2228	PKRMX	4703	3034	1.48
646	1494	NAVCO	0001	23	1.48
647	2511	RDOAK	1303	2389	1.48
648	1165	CRLJL	1505	925	1.48
649	2083	REAST	1504	1294	1.47
650	1809	ALLEN	2408	3213	1.47
651	190	EZACH	0008	1534	1.47
652	2943	DFWSW	2208	17	1.47
653	782	MKNNY	1203	1083	1.47
654	1157	LAVON	1451	1020	1.47
655	2126	AIRPK	8411	782	1.47
656	249	WICKT	0411	250	1.47
657	2924	MCDMT	2553	1926	1.47
658	80	EDWDS	5931	1087	1.47
659	150	TRPMN	4001	784	1.46
660	1773	MESQT	1307	593	1.46
661	1094	LNLK	1602	637	1.46
662	607	BOWIE	0621	11	1.45
663	518	PPARK	1805	996	1.45
664	1728	RDOAK	1301	2475	1.45
665	1209	CDCSW	0008	725	1.45
666	807	CRLJL	1504	1285	1.45
667	1639	HLSES	0561	1825	1.45

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
668	1900	NCDCH	1206	1098	1.45
669	2643	CLMET	0004	1174	1.44
670	2618	MRSES	4014	18	1.44
671	1861	BLKST	1781	1928	1.44
672	2136	ARCTY	1321	890	1.44
673	1426	CDHCR	2051	2128	1.44
674	545	MAYFD	5524	2594	1.44
675	1001	TMPLE	1206	720	1.44
676	707	ATHNS	1201	971	1.44
677	175	PRKRW	3311	1140	1.44
678	731	CDCSW	0007	990	1.44
679	2661	BLMND	3252	1138	1.44
680	1304	BRKRG	0232	1718	1.44
681	1214	GSTHW	1631	2205	1.44
682	843	RECCR	0001	163	1.44
683	1947	MDLNW	1552	1365	1.43
684	1912	HNRTA	0311	1044	1.43
685	376	ODESA	0272	1653	1.43
686	1683	BNDRA	0003	820	1.43
687	1333	KLELM	2205	3200	1.42
688	794	BLTLN	0006	926	1.42
689	718	HOWRD	3911	38	1.42
690	2823	TMPNW	1102	680	1.42
691	2099	DAVST	0005	1828	1.42
692	2739	JKSNR	4107	330	1.42
693	1184	SMFLD	2352	602	1.42
694	2224	SALSW	3004	1377	1.42
695	33	EDWDS	5921	24	1.42
696	2845	WALST	0010	1083	1.42
697	373	KLBRG	0003	1404	1.42
698	918	DAVIS	3733	294	1.41
699	2782	TMNTH	1603	138	1.41
700	2023	WNTHW	1120	1035	1.41
701	614	WDGWD	1523	308	1.41
702	2022	MESQW	1804	1344	1.41
703	2131	IRVNE	1302	282	1.41
704	1290	STNVL	1207	971	1.41
705	28	LMESA	2833	22	1.41
706	2156	BRHLW	7632	1487	1.41
707	2959	JNKNS	0008	27	1.41
708	1519	CPRCV	1405	1530	1.41
709	2366	HUTTO	2721	2702	1.40
710	515	PLSTN	1005	1901	1.40
711	2264	CLYVL	9311	2011	1.40
712	2267	MESTE	1209	1448	1.40
713	773	WNDWD	3652	979	1.40
714	187	STHRL	0001	602	1.40
715	2861	ALNSW	2651	2054	1.39

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
716	2353	RDLML	2532	1788	1.39
717	1755	LAVON	1452	1816	1.39
718	1387	TYLNE	1623	510	1.39
719	505	COLNY	2403	2631	1.39
720	1292	WNTHW	1116	675	1.39
721	264	WEBBS	8614	2507	1.39
722	1874	EZACH	0004	1171	1.39
723	141	CDCSW	0002	2369	1.39
724	1642	RDLML	2521	1025	1.39
725	2008	TRLNW	1204	581	1.39
726	259	TIODE	9611	359	1.39
727	1712	KIMBL	5032	1741	1.39
728	549	RWALS	1852	2767	1.38
729	1123	HUTCH	1503	551	1.38
730	637	EULES	8722	2131	1.38
731	2609	PROAD	0004	991	1.38
732	1853	SYCRK	4511	1991	1.38
733	1486	FARON	4062	1149	1.38
734	2749	BRYAN	0001	16	1.38
735	218	GODLY	1601	662	1.37
736	1743	KFMNSO	1301	924	1.37
737	14	BRNAV	0723	1330	1.37
738	1118	ALNTH	2832	974	1.37
739	1987	CRSCN	1204	618	1.37
740	903	PCUST	2006	1611	1.37
741	1015	RYSSW	2802	4193	1.37
742	855	CMPST	0002	1060	1.37
743	2714	BLMND	3262	122	1.37
744	1440	HUDSN	1601	971	1.37
745	508	PCUST	2007	1393	1.37
746	1052	GAVSW	0005	1500	1.37
747	1907	HSKAV	0005	1373	1.37
748	2466	RRSTH	1703	3573	1.37
749	2039	DEALY	0002	1465	1.37
750	N/A	PGSTH	7012	173	1.36
751	1419	RKDLE	1301	1226	1.36
752	499	TYEST	1508	631	1.36
753	272	MKNSO	3613	3322	1.36
754	1996	JKSBR	1401	742	1.36
755	671	SMFLD	2381	849	1.36
756	2004	CPLSO	4312	1789	1.36
757	1368	GDPRW	9611	1261	1.35
758	1340	BNTDR	0003	460	1.35
759	2078	HSKAV	0003	1420	1.35
760	1408	RENSW	3121	1942	1.35
761	1163	DNISN	1204	1213	1.35
762	363	THRNE	0008	2222	1.35
763	447	JKWST	4033	748	1.35

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
764	281	GVODS	3031	1371	1.35
765	1218	CNTRY	2811	2659	1.35
766	2375	DENAV	0642	912	1.35
767	2371	WCOLO	1319	2072	1.34
768	871	WMRLD	0008	1595	1.34
769	565	WDGWD	1581	604	1.34
770	2200	WNRTH	1419	306	1.34
771	2109	GPLND	1202	401	1.34
772	1062	PRFTW	4221	1383	1.34
773	1650	BRHLW	7611	1628	1.34
774	240	EUSTC	2401	1705	1.34
775	109	CSHNG	1201	918	1.33
776	661	LKTMS	2412	12	1.33
777	1245	SSPNE	1402	69	1.33
778	1234	PAYSW	1202	1652	1.33
779	1411	SMPST	0001	2088	1.33
780	1018	DCDAM	2003	1322	1.33
781	2931	FRMNT	0002	575	1.33
782	339	BLMND	3231	1227	1.33
783	2245	SMFLD	2333	1063	1.33
784	739	ITALY	2101	568	1.33
785	2507	TMPLE	1202	1362	1.33
786	1990	NCDCH	1202	1027	1.33
787	1989	GNSVN	1403	299	1.32
788	643	LNCST	1602	1870	1.32
789	1544	BLTON	1804	464	1.32
790	155	ECTHM	3341	2415	1.32
791	2949	FRMNT	0011	993	1.32
792	255	MSLMN	4131	132	1.32
793	1297	OKLND	0002	1261	1.32
794	283	BRNSY	1221	79	1.32
795	2260	RDRSE	2603	3880	1.32
796	2280	RDRSE	2604	3786	1.32
797	2142	WNTHW	1118	1524	1.31
798	1665	GORMN	0421	353	1.31
799	799	NPKWY	0006	4874	1.31
800	582	CHYNE	9121	91	1.31
801	1673	CRLUD	1306	26	1.31
802	494	GODRD	8131	1533	1.31
803	357	ALPHA	0013	449	1.31
804	683	ALVDO	1902	928	1.30
805	89	CDHIL	1623	2153	1.30
806	326	PARIS	1201	1137	1.30
807	262	IRVNR	1557	3120	1.30
808	1626	MESQN	1505	1429	1.30
809	833	ARPMN	4149	313	1.30
810	784	BKWST	0007	1839	1.30
811	114	MNWLW	1402	1531	1.30

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
812	1120	SGOVL	1403	2376	1.30
813	2554	TYWST	2004	984	1.30
814	313	ALPHA	0003	874	1.30
815	1985	CHROW	0003	155	1.30
816	949	PRCRK	0003	1836	1.29
817	2349	CMPWI	0005	1645	1.29
818	790	FARON	4072	1541	1.29
819	777	FINKS	1804	2306	1.29
820	440	WCITY	2401	917	1.29
821	622	CNTRY	2842	1148	1.29
822	183	CHICC	1701	55	1.29
823	1200	ARLNG	1241	657	1.29
824	2751	WALST	0002	31	1.29
825	989	WALST	0003	131	1.29
826	986	FROKS	0007	1497	1.29
827	1103	MCDMT	2552	876	1.29
828	380	DENDR	0005	404	1.29
829	314	PRCRK	0002	2234	1.29
830	1944	WXHCH	1203	1288	1.29
831	883	ALNSW	2652	2600	1.29
832	768	DAVIS	3782	983	1.28
833	2052	WNDWD	3662	883	1.28
834	2069	WNDWD	3682	782	1.28
835	670	WND CR	0252	912	1.28
836	1039	TYLNE	1607	782	1.28
837	1723	FORSW	2015	2404	1.28
838	902	DNISN	1203	1686	1.28
839	884	LFEST	1904	1335	1.28
840	1715	ODESW	5922	2399	1.28
841	2324	LMBLN	0003	181	1.28
842	2539	RDOAK	1304	3370	1.28
843	1970	WNRTH	1418	1780	1.27
844	640	SHRSW	6611	1243	1.27
845	1862	TRNTH	1503	1841	1.27
846	895	FSCRK	6712	2562	1.27
847	2585	BOWEN	3112	907	1.27
848	531	WNRTH	1420	1165	1.27
849	1838	BNDRA	0007	504	1.27
850	568	FERIS	1101	1179	1.27
851	2247	PLANO	1104	991	1.27
852	2221	MCDMT	2532	1978	1.27
853	2297	LVBRD	0008	1761	1.27
854	2456	CLOTY	1031	1224	1.27
855	1507	MESQT	1305	1146	1.27
856	1375	LAVON	1404	960	1.27
857	2050	PRKRW	3362	1099	1.27
858	170	OAKCK	2211	45	1.27
859	246	HSKAV	0007	1888	1.27

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
860	2728	AIRPK	8432	948	1.27
861	1458	CAMRN	1203	1220	1.26
862	1877	OKCLS	0001	1396	1.26
863	628	GRDPR	0842	1378	1.26
864	2404	OAKHL	3082	1449	1.26
865	1739	ALLNC	6411	46	1.26
866	2263	SNYDR	1822	1616	1.26
867	922	MCDMT	2531	2439	1.26
868	2542	MRTNS	1502	508	1.26
869	62	ECTHP	4921	311	1.26
870	2560	BLTON	1802	1410	1.25
871	2286	PLANO	1102	143	1.25
872	379	MESFR	2102	676	1.25
873	1402	COPEL	3051	1588	1.25
874	1043	NLNVL	2001	420	1.25
875	2887	PRKRW	3382	309	1.25
876	1406	CLCTY	1021	680	1.25
877	2694	PWEST	1312	1361	1.25
878	2601	PLKST	0003	1303	1.25
879	2339	SSPNG	1204	972	1.25
880	2482	LKHLD	0004	1262	1.24
881	2249	BNBRK	4111	2890	1.24
882	747	BBTWN	1504	2105	1.24
883	800	LKBRN	2402	1173	1.24
884	1298	CDCSW	0003	716	1.24
885	838	CDMIL	1201	598	1.24
886	2044	ARLNG	1223	1838	1.24
887	937	THRNE	0004	811	1.24
888	369	CNI45	2401	608	1.24
889	382	IRVNR	1559	2599	1.24
890	644	OTTOJ	3059	1092	1.23
891	1309	DESPR	1405	931	1.23
892	1496	CDCSW	0006	1369	1.23
893	2633	HLTOM	2472	1812	1.23
894	2095	LKBLT	2107	1100	1.23
895	2369	WATSN	5342	2032	1.23
896	274	MSLMN	4009	237	1.23
897	797	ALLEN	2402	3343	1.23
898	455	GNSVE	1602	1737	1.23
899	730	PARIS	1206	1024	1.22
900	1894	ROGRS	1301	768	1.22
901	196	LNDAL	2201	1907	1.22
902	2092	EXPKY	8142	27	1.22
903	601	WICKT	0431	18	1.22
904	696	LWRDR	0001	1166	1.22
905	906	IRVVV	2851	2972	1.22
906	2293	GSTHW	1692	999	1.22
907	1140	WEBBS	8631	3599	1.22

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
908	2822	RCLNS	1401	115	1.22
909	692	CDCSW	0005	1705	1.22
910	1802	WELRD	0008	1125	1.22
911	1403	TYEST	1506	479	1.22
912	1407	ODESW	5912	335	1.21
913	1255	HLSBR	1204	554	1.21
914	913	COPEL	3056	2811	1.21
915	798	MSHLN	0007	724	1.21
916	1762	ALPHA	0009	62	1.21
917	2351	CMPWI	0001	1889	1.21
918	1583	CNTRY	2862	401	1.21
919	578	ELCTR	1221	129	1.21
920	2551	BRNAV	0732	798	1.21
921	2030	DCATR	1205	121	1.21
922	174	FSCRK	6711	3788	1.21
923	2811	MSLSW	0006	94	1.20
924	2114	ELMGV	3653	1988	1.20
925	572	BDFWD	8921	688	1.20
926	2736	JNKNS	0001	25	1.20
927	852	SHAMP	0007	690	1.20
928	534	FROKS	0001	1364	1.20
929	932	KLRPR	9011	2738	1.20
930	457	MESQT	1301	1454	1.20
931	523	DUVAL	0441	1034	1.20
932	1606	CNI45	2402	811	1.20
933	638	FHLSW	1372	1314	1.19
934	1770	NCSFA	1702	1305	1.19
935	1622	WNDRC	0221	572	1.19
936	295	GAVSW	0004	830	1.19
937	438	SYCRK	4531	2434	1.19
938	1110	MRVLY	2311	368	1.19
939	1551	TYLER	1004	184	1.19
940	840	LKMNT	0008	1004	1.19
941	2077	CMTSW	0966	124	1.19
942	103	REAST	1503	570	1.18
943	2527	PRSTN	0003	2960	1.18
944	2525	PFLGV	2002	2272	1.18
945	1766	FORSW	2051	4026	1.18
946	1334	LOMAL	0003	1055	1.18
947	2598	SHMNE	1407	807	1.18
948	383	MESQW	1806	1665	1.18
949	1831	BLMED	1620	2019	1.18
950	2454	RCLNS	1407	1390	1.18
951	437	MKNNY	1254	2366	1.18
952	169	ANDNR	2242	512	1.18
953	2400	STAUG	0008	2057	1.18
954	178	DENAV	0662	588	1.17
955	2312	TATSP	4322	2534	1.17

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
956	2766	RRSTH	1707	609	1.17
957	772	PRFTW	4211	3614	1.17
958	1291	KNEDL	6312	3080	1.17
959	309	LTLRV	1701	1085	1.17
960	2393	MDLNW	1513	2469	1.17
961	1928	GLNHV	3963	1597	1.17
962	1816	HLSES	0511	1809	1.17
963	793	WEAST	0617	1403	1.17
964	1211	PKRVL	1052	2361	1.17
965	2519	CDCSW	0004	1373	1.17
966	824	WEAST	0629	1802	1.17
967	117	ITSCA	1702	203	1.17
968	2135	PTENN	2351	1553	1.17
969	19	RBNSN	2502	1224	1.17
970	1385	SHAMP	0001	1230	1.17
971	248	JKWST	4178	421	1.17
972	97	ITSCA	1701	747	1.17
973	1993	GODRD	8171	839	1.17
974	1541	HORNE	1932	1159	1.16
975	61	MKNSW	2602	1272	1.16
976	2425	EDGCF	2272	1079	1.16
977	2026	TYSTH	1202	1056	1.16
978	815	WSANG	2801	1340	1.16
979	1865	WELRD	0006	732	1.16
980	435	RSKMN	3046	1085	1.16
981	1413	FSHSW	2111	315	1.16
982	2002	PAYSW	1213	1427	1.16
983	1846	BKBNT	1821	1148	1.16
984	254	ARMST	0004	1282	1.16
985	359	WALST	0009	817	1.16
986	596	NCRST	2203	987	1.16
987	265	BEAST	4090	937	1.15
988	1740	MCGHR	2003	1298	1.15
989	763	ODESA	0261	1455	1.15
990	988	CLBNR	1406	106	1.15
991	2745	KLELM	2201	2428	1.15
992	971	HLSES	0522	1753	1.15
993	898	CLLVL	0006	1183	1.15
994	1226	ANDNR	2252	241	1.15
995	2657	NSTAR	2011	524	1.15
996	1295	CNSES	0750	1977	1.15
997	724	MSLSW	0002	1038	1.15
998	2683	IRVNR	1552	68	1.15
999	948	BRIRV	6911	3239	1.15
1000	182	JKSNR	4109	651	1.15
1001	2282	TYLGE	1308	1559	1.15
1002	493	BBTWN	1502	1741	1.15
1003	2624	PCOIT	1005	1095	1.15

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1004	2533	BKWST	0005	918	1.14
1005	695	PLGRV	0001	1201	1.14
1006	2343	PRMED	4403	2640	1.14
1007	2562	BLMED	1618	35	1.14
1008	1339	ELZCK	4911	35	1.14
1009	2452	OVRTN	4037	119	1.14
1010	2752	SANSM	3911	1479	1.14
1011	1607	LFSTH	1402	1188	1.14
1012	1135	REYST	4040	545	1.14
1013	119	RICES	0208	715	1.14
1014	2299	TMPNW	1105	829	1.14
1015	2450	NHNSW	0008	587	1.14
1016	1641	BOWEN	3161	1544	1.14
1017	2961	KIMBL	5011	162	1.14
1018	1351	MNFLD	2611	1894	1.14
1019	2390	JKREA	1201	30	1.13
1020	1600	NHNSW	0004	567	1.13
1021	1956	LVBRD	0001	38	1.13
1022	1797	WFALS	0174	1226	1.13
1023	2673	DAVST	0006	1150	1.13
1024	1856	WSANG	2802	635	1.13
1025	814	CNI45	1202	820	1.13
1026	2812	MSLSW	0007	385	1.13
1027	2381	TMSTH	1404	1313	1.13
1028	2374	GAVSW	0007	1541	1.13
1029	2652	OKLND	0003	1352	1.13
1030	2336	WEBBS	8611	2610	1.13
1031	2395	BLKST	1721	1029	1.13
1032	2421	WMRLD	0009	32	1.13
1033	280	TRIRA	6221	634	1.12
1034	1501	SHLMT	1802	538	1.12
1035	1450	MABNK	2402	979	1.12
1036	1998	BLMED	1617	320	1.12
1037	1753	ALLEN	2406	2630	1.12
1038	2384	IRVRS	4411	1247	1.12
1039	2595	BLKST	1732	1224	1.12
1040	2298	FRMBG	1707	443	1.12
1041	1963	ALNTH	2853	2993	1.12
1042	990	BRTD	7311	1191	1.12
1043	168	WINKS	0511	636	1.12
1044	1871	GRLRD	0004	1556	1.12
1045	851	STAUG	0001	707	1.12
1046	1707	CNTRY	2824	3090	1.12
1047	1911	FRNKF	0002	943	1.11
1048	924	PRSTN	0002	1345	1.11
1049	2292	SNYDR	1833	1425	1.11
1050	774	BSPRG	1904	1665	1.11
1051	2774	RDRSE	2602	3262	1.11

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1052	294	COPEL	3055	2178	1.11
1053	1028	MSHLN	0004	1302	1.11
1054	792	TMNTH	1602	474	1.11
1055	785	DEALY	0001	730	1.11
1056	2162	RECCR	0006	503	1.11
1057	2639	ABRRD	0001	1418	1.11
1058	548	LENSW	0321	46	1.11
1059	2033	PRFTW	4212	2009	1.11
1060	925	HHSTH	1501	3392	1.11
1061	524	PLSTH	1304	1310	1.11
1062	1884	ALPHA	0014	515	1.11
1063	1845	BLTON	1805	1537	1.11
1064	795	HKBRY	1107	969	1.11
1065	1055	CRLTR	2054	105	1.10
1066	769	MSHLN	0002	1584	1.10
1067	2269	LOMAL	0010	1558	1.10
1068	2615	BNDRA	0005	1264	1.10
1069	1820	CNEXP	0006	1213	1.10
1070	907	FRMBR	1804	300	1.10
1071	936	EGFRD	0001	1813	1.10
1072	2038	MDLNW	1564	1275	1.09
1073	2477	MESFR	2105	1049	1.09
1074	584	MURPH	2754	2115	1.09
1075	881	FSTVW	0004	2269	1.09
1076	1412	HUDSN	1603	1799	1.09
1077	2289	BSPRG	1901	586	1.09
1078	2898	GAVSW	0011	109	1.09
1079	1601	BNTDR	0001	1314	1.09
1080	2327	OKCLS	0007	635	1.09
1081	2121	PEGAS	2321	136	1.09
1082	2532	WMMMR	2708	250	1.09
1083	2578	CRLJL	1502	391	1.08
1084	2198	LEMON	0011	1870	1.08
1085	1217	DFWNW	2604	12	1.08
1086	1968	BNTDR	0004	1844	1.08
1087	2625	WRTHM	5017	159	1.08
1088	2548	GAVSW	0002	930	1.08
1089	486	CRLJL	1508	345	1.08
1090	2081	ALPHA	0007	1465	1.08
1091	2302	TRNTY	7541	697	1.08
1092	2212	OKLND	0001	1339	1.08
1093	2942	DFWNW	2602	27	1.07
1094	2442	HKBRY	1111	27	1.07
1095	1430	MLDR2	1605	216	1.07
1096	1557	WXNTH	2304	855	1.07
1097	1621	LIGSW	1604	720	1.07
1098	728	FRMNT	0013	3105	1.07
1099	2024	TYBLR	2801	1238	1.07

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1100	994	CMTSW	0936	522	1.07
1101	2775	PCOIT	1025	2924	1.07
1102	2726	WNRTH	1416	728	1.07
1103	138	MKNGB	5322	1587	1.07
1104	427	SYCRK	4521	3155	1.07
1105	2733	DENAV	0652	31	1.06
1106	94	CRSGL	1306	644	1.06
1107	1315	HURST	1811	1242	1.06
1108	2195	NMAIN	0231	318	1.06
1109	230	PRNTH	1401	1343	1.06
1110	2796	MESQW	1805	83	1.06
1111	192	CTYVW	2222	1385	1.06
1112	2755	BRTRD	7312	3712	1.06
1113	2065	LEMON	0008	784	1.06
1114	2150	LOMAL	0015	177	1.06
1115	1049	GRLRD	0002	994	1.06
1116	1236	CRLTN	1408	127	1.06
1117	1563	KNLTR	0004	1945	1.06
1118	2231	ELZCK	4922	19	1.05
1119	2355	FRMBG	1753	708	1.05
1120	1256	MCKMY	0811	2605	1.05
1121	1552	PRKRW	3372	1494	1.05
1122	1181	TAYLR	1202	1565	1.05
1123	890	NCSTH	1501	808	1.05
1124	1503	GNSVL	1205	880	1.05
1125	1732	MSTLT	1073	194	1.05
1126	1787	BRKRG	0213	411	1.05
1127	2641	JUDCT	0001	1906	1.05
1128	2344	IRVNR	1555	2202	1.04
1129	2872	SHAMP	0006	1145	1.04
1130	1194	FRNKS	1202	94	1.04
1131	1307	HNTNG	1305	1176	1.04
1132	1994	IRVGS	1905	770	1.04
1133	2853	ALPHA	0015	838	1.04
1134	1839	DCVSO	1106	1210	1.04
1135	2865	LMBLN	0004	50	1.04
1136	2547	LEMON	0006	709	1.04
1137	167	CKRHL	0008	1666	1.04
1138	2417	ARTHR	0411	736	1.04
1139	2503	MESFR	2103	375	1.03
1140	425	GMINI	5821	1422	1.03
1141	2629	FSTVW	0002	146	1.03
1142	1995	CHROW	0008	88	1.03
1143	2338	THRNE	0002	1705	1.03
1144	1920	NCRST	2202	30	1.03
1145	469	CRLUD	1302	152	1.03
1146	977	ODESA	0221	252	1.03
1147	1383	EZACH	0001	985	1.03

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1148	1229	INAIR	1423	233	1.03
1149	2565	BNDRA	0001	845	1.03
1150	336	RGLRW	0006	36	1.03
1151	688	TRSES	1202	507	1.03
1152	307	TRNTH	1501	1765	1.02
1153	2304	ABRRD	0002	1372	1.02
1154	931	WWEST	1222	178	1.02
1155	N/A	PRMED	4402	867	1.02
1156	1392	HLTOM	2442	1096	1.02
1157	181	MNRVA	1301	743	1.02
1158	2440	HORNE	1942	1558	1.02
1159	475	MSTLT	1054	609	1.02
1160	1939	DALLW	0007	442	1.02
1161	566	RWALL	1204	1064	1.02
1162	2817	EMPCT	0004	340	1.02
1163	2612	MDWCK	0003	1873	1.02
1164	258	EDDYS	0712	1100	1.02
1165	2524	PROAD	0003	1140	1.02
1166	992	PRKRW	3331	134	1.01
1167	1977	FSTVW	0008	1814	1.01
1168	665	MESQT	1306	978	1.01
1169	940	SHAMP	0005	1722	1.01
1170	563	RECCR	0002	97	1.01
1171	2806	FSCRK	6724	1397	1.01
1172	484	WHOUS	4128	362	1.01
1173	1090	ALPHA	0011	1173	1.01
1174	2398	FSTVW	0006	1250	1.01
1175	1299	CLBWS	8112	1626	1.01
1176	189	JUDCT	0007	895	1.00
1177	619	ENTOH	0004	2003	1.00
1178	1398	ALPHA	0001	428	1.00
1179	2873	ALPHA	0006	294	1.00
1180	2800	CRLUD	1301	24	1.00
1181	2734	DENDR	0006	44	1.00
1182	458	DFWNW	2606	18	1.00
1183	2967	MAPLE	0004	480	1.00
1184	2743	RSNHT	1111	348	1.00
1185	412	STHRL	0007	134	1.00
1186	2230	WND CR	0241	708	1.00
1187	401	FRMBG	1752	464	1.00
1188	1141	CDCSW	0001	273	1.00
1189	2579	SANSM	3913	4118	1.00
1190	1417	WWEST	1219	941	1.00
1191	550	NCWDN	1111	801	1.00
1192	8	BKWST	0001	386	0.99
1193	829	CDHIL	1801	1050	0.99
1194	126	MTLDA	0004	834	0.99
1195	1237	CHRNO	1201	517	0.99

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1196	2671	NHNSW	0001	469	0.99
1197	2067	ELKTN	2502	1564	0.99
1198	153	PTENN	2357	1294	0.99
1199	415	HORNE	1921	1348	0.99
1200	1537	KIMBL	5022	890	0.98
1201	509	FINKS	1802	727	0.98
1202	1528	SWTWR	1382	438	0.98
1203	1035	GSMTH	1742	37	0.97
1204	916	OAKHL	3072	2489	0.97
1205	723	EUSTC	2402	815	0.97
1206	2890	WMMMR	2705	1062	0.97
1207	957	WMRLD	0005	1616	0.97
1208	199	TYSTH	1201	1132	0.97
1209	498	TXHRV	1621	89	0.97
1210	2678	EULES	8714	811	0.96
1211	1133	MEANS	4421	52	0.96
1212	1893	HLTOM	2452	1810	0.96
1213	1332	SSPNG	1201	1311	0.96
1214	1370	PALRD	2206	1511	0.96
1215	358	INAIR	1432	3279	0.96
1216	269	BNBOR	1203	310	0.95
1217	1084	FRMBG	1750	41	0.95
1218	370	KILEN	1205	1329	0.95
1219	1016	CRLFR	2154	3458	0.95
1220	460	WHOUS	4122	2062	0.95
1221	2866	BLTSW	3205	1439	0.94
1222	745	BEAST	4084	875	0.94
1223	1206	RCHRD	1208	1036	0.94
1224	770	HSKAV	0001	1077	0.94
1225	2317	SWDTN	1641	1572	0.93
1226	900	RECCR	0003	210	0.93
1227	2256	IRASB	3211	277	0.93
1228	2350	GLNHV	3983	1677	0.93
1229	1321	ARCTY	1311	431	0.93
1230	1588	COLNY	2401	734	0.93
1231	849	BRYAN	0006	928	0.92
1232	1121	CLKVL	1201	431	0.92
1233	546	FRFWS	3001	1810	0.92
1234	2784	ZEPHR	2404	181	0.92
1235	2937	BLMND	3272	12	0.92
1236	646	BSPRW	2542	751	0.92
1237	1854	OKCLS	0005	197	0.91
1238	2514	DGNST	0002	456	0.91
1239	593	WSOTH	1020	1140	0.91
1240	1623	CMPWI	0003	977	0.91
1241	2756	OKCLS	0008	1986	0.91
1242	2965	LSCOL	2140	624	0.91
1243	506	MNFLD	2682	2388	0.90

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1244	397	FRNKF	0007	1172	0.90
1245	559	CNTRY	2822	2847	0.90
1246	2178	CRLTN	1401	810	0.90
1247	1513	MNWLL	1204	286	0.89
1248	106	WLSPT	1002	604	0.89
1249	261	DNISN	1205	1537	0.88
1250	353	RVRFT	0003	908	0.88
1251	2600	TMPLE	1203	126	0.88
1252	54	LNDAL	2203	2424	0.88
1253	1682	MCDMT	2554	1779	0.88
1254	1793	KNLTR	0006	947	0.88
1255	2512	PAYSW	1203	857	0.88
1256	1347	DALLW	0004	1323	0.88
1257	1359	MNWLW	1401	1546	0.88
1258	569	GMINI	5812	775	0.87
1259	1143	PFLGV	2004	3937	0.87
1260	1378	DCVSO	1105	1660	0.87
1261	419	MRTSP	1504	703	0.87
1262	687	LKTMS	2411	95	0.86
1263	2028	ELGIN	1002	2621	0.86
1264	389	EZACH	0002	1424	0.86
1265	666	LRENA	2901	992	0.86
1266	1530	MEXIA	4011	1015	0.86
1267	517	FINKS	1801	1643	0.86
1268	1196	LWSNR	2221	1451	0.86
1269	1233	RCHRD	1204	1141	0.86
1270	1248	MDLNW	1511	2588	0.86
1271	1317	KLNTF	1804	1007	0.86
1272	821	SHSTH	1305	488	0.85
1273	923	MDTHN	1703	609	0.85
1274	418	ENTOH	0006	1952	0.85
1275	636	TYLNW	1910	609	0.84
1276	1435	HHSTH	1502	3740	0.84
1277	2084	ARMST	0009	1140	0.84
1278	1252	PKRVL	1054	2567	0.84
1279	424	POWEL	2706	239	0.84
1280	284	VALVW	1802	431	0.84
1281	709	BONHM	1202	737	0.84
1282	2415	MCKMY	0822	1386	0.84
1283	1219	HUDSN	1602	1707	0.84
1284	522	MRKLY	0811	121	0.83
1285	1	VESTS	3111	54	0.83
1286	1546	GVFTW	1802	903	0.83
1287	1313	SSPNG	1205	1130	0.83
1288	267	TSLVL	4001	1275	0.83
1289	2196	STNVL	1205	439	0.83
1290	1325	CDMIL	2401	902	0.83
1291	2048	BRCKR	6523	876	0.83

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1292	1254	NLNVL	2003	691	0.82
1293	1063	CRLTR	2053	1742	0.82
1294	1095	CGDEL	5411	28	0.82
1295	864	ENSSO	2002	1109	0.82
1296	300	MAREA	1201	151	0.81
1297	2166	LSCOL	2116	59	0.81
1298	2005	IRVNR	1506	2970	0.81
1299	1447	HLTOM	2411	1442	0.81
1300	118	MEANS	4411	37	0.81
1301	1587	RKDLN	1401	934	0.81
1302	875	JREST	2101	1354	0.81
1303	742	RWALE	3322	1946	0.81
1304	1810	ENNIS	1906	2033	0.81
1305	1734	DLEON	0111	836	0.81
1306	335	KYSTN	1031	26	0.81
1307	2073	WXNTH	2306	2356	0.81
1308	130	TYEST	1511	881	0.81
1309	1372	WXHCH	1202	1710	0.80
1310	227	ELKTN	2506	1688	0.80
1311	1288	WRBND	2312	1443	0.80
1312	65	MDLNE	0142	884	0.80
1313	2604	ENTOH	0008	10	0.80
1314	1023	HNYGR	2402	159	0.80
1315	1576	PNTGO	7112	739	0.80
1316	1470	DNCNV	1906	406	0.80
1317	1006	WHTRK	0007	1242	0.80
1318	2492	WNDWD	3631	309	0.80
1319	1883	HURST	1861	1849	0.80
1320	735	TMPSE	1503	621	0.80
1321	667	DNIWS	1602	1429	0.79
1322	1230	CRTLD	4732	2785	0.79
1323	1553	SHLMT	1801	305	0.79
1324	1738	MNWLL	1203	885	0.79
1325	464	MNHNS	1911	1515	0.78
1326	297	PREST	1602	1413	0.78
1327	1077	EULES	8732	629	0.78
1328	1352	HUDSN	1604	1760	0.78
1329	229	VANAL	2412	2997	0.78
1330	1265	DCATR	1202	1720	0.78
1331	1050	BONHM	1210	1178	0.78
1332	2764	WHITE	3532	1366	0.77
1333	1815	BDFRD	8831	877	0.77
1334	1469	BONHM	1206	2111	0.77
1335	1824	TROYS	1013	785	0.77
1336	90	FKLCY	5111	72	0.76
1337	609	IOWPK	0831	1073	0.76
1338	1415	AIRPK	8421	1035	0.76
1339	2204	GSTHW	1633	955	0.76

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1340	1869	SMPST	0002	1458	0.76
1341	120	HDWLK	3003	971	0.76
1342	1643	MESWE	3621	807	0.75
1343	485	BDFRD	8822	1054	0.75
1344	1168	LNCST	1604	637	0.75
1345	1653	IRVBL	2501	387	0.75
1346	1145	NYLDV	1201	652	0.74
1347	2164	DALLW	0006	1950	0.74
1348	1243	ATHNW	1403	2244	0.74
1349	2006	IRVNE	1309	1130	0.74
1350	1147	OAKHL	3031	624	0.74
1351	783	ROSCO	2911	616	0.74
1352	1852	MRSES	4012	395	0.74
1353	1595	RCHRD	1205	1039	0.74
1354	215	GLNHV	3942	1363	0.73
1355	538	ATHNW	1404	1366	0.73
1356	889	GODRD	8141	855	0.73
1357	205	AMMFG	5631	1225	0.73
1358	1636	RBNSN	2501	1968	0.73
1359	1384	PCUST	2008	694	0.73
1360	N/A	DFWSE	2715	11	0.73
1361	1399	JSHUA	1301	1003	0.73
1362	2192	PRCTR	1602	230	0.73
1363	771	MEXIA	4007	453	0.72
1364	1193	LFSTH	1406	2091	0.72
1365	2169	ALNTH	2844	2188	0.72
1366	1056	ROSCO	2921	239	0.72
1367	2359	WALST	0011	747	0.71
1368	1567	MKNGB	5352	680	0.71
1369	553	RWALE	3324	1508	0.71
1370	662	DCVSO	1104	1352	0.71
1371	1261	LGVST	8521	1761	0.71
1372	346	FINKS	1803	1345	0.71
1373	1379	EDDYS	0425	411	0.71
1374	2394	NMAIN	0272	414	0.71
1375	1790	FHLSW	1342	1955	0.71
1376	2296	WDGWD	1512	828	0.71
1377	198	WMRLD	0002	1566	0.71
1378	652	WRBND	2311	1398	0.71
1379	2184	DNCNV	1905	1328	0.70
1380	1195	FHLSW	1351	1443	0.70
1381	128	PREST	1603	1521	0.70
1382	750	LIGSW	1608	386	0.70
1383	732	BRNAV	0711	1642	0.70
1384	547	GVODS	3021	262	0.69
1385	2732	BRHLW	7641	36	0.69
1386	1714	PLSTH	1305	500	0.69
1387	1176	TYLER	1005	2004	0.69

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1388	142	HKBRY	1101	339	0.69
1389	2783	EULES	8731	1426	0.69
1390	200	DALLW	0001	1149	0.69
1391	2431	PLGRV	0002	2338	0.69
1392	2265	DUVAL	0414	653	0.69
1393	329	WXNTH	2303	2224	0.69
1394	973	ORANS	1501	850	0.69
1395	2388	DALWT	2982	1031	0.68
1396	720	CRKET	2403	2796	0.68
1397	1933	GRHWY	5522	1728	0.68
1398	256	TYBLR	2811	1124	0.68
1399	2308	EULSO	9131	1977	0.68
1400	519	CHICG	1402	508	0.68
1401	1827	IRVND	1201	976	0.68
1402	129	LFSTH	1404	513	0.67
1403	1628	WITTS	1705	1353	0.67
1404	2731	CTYVW	2212	145	0.67
1405	1220	TMNTH	1605	1829	0.67
1406	2172	CAMRN	1201	1032	0.67
1407	751	PMBRK	1811	24	0.67
1408	541	WBROK	3021	51	0.67
1409	2211	CMTSW	0973	1615	0.67
1410	758	KILEN	1201	1851	0.66
1411	2075	RSNHT	1122	2027	0.66
1412	91	NLNVL	2002	526	0.66
1413	928	MDLNW	1573	1050	0.66
1414	66	FLRTN	3711	-100	0.66
1415	2183	TMPTV	2404	1427	0.66
1416	2191	BDFRD	8812	770	0.66
1417	82	NIPAK	1001	131	0.66
1418	2799	RSPVY	1708	980	0.66
1419	1969	CMTSW	0916	555	0.66
1420	1523	FRFWS	3002	850	0.66
1421	395	GRAHM	0721	1241	0.65
1422	1689	HMPHL	2762	1014	0.65
1423	1644	FRMNT	0012	475	0.65
1424	616	SCYEN	0003	1974	0.65
1425	1117	HDWLK	3001	970	0.65
1426	717	DNIWS	1603	1363	0.65
1427	2141	CRYVE	3021	1285	0.65
1428	372	MKNSW	1602	550	0.65
1429	2029	NPKWY	0014	6107	0.64
1430	305	PREST	1601	1159	0.64
1431	743	BRNWD	1202	445	0.64
1432	1240	CDHCR	2054	1435	0.64
1433	472	COLNY	2404	1947	0.64
1434	1848	TYSTH	1208	250	0.64
1435	1362	CRTLD	4711	3181	0.64

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1436	1811	GRMES	0521	549	0.64
1437	744	WTAUG	4613	1896	0.64
1438	157	THRNE	0005	1351	0.64
1439	40	WHOUS	4121	1333	0.64
1440	2765	CRLTR	2051	3938	0.64
1441	1159	IRVGS	1902	1496	0.63
1442	2791	PWEST	1302	339	0.63
1443	298	NCDSW	3813	396	0.63
1444	140	HDWLK	3005	1020	0.63
1445	1457	TYLER	1012	1706	0.63
1446	608	STERT	2706	171	0.63
1447	378	GRDPR	0822	627	0.63
1448	1266	TYOMN	1408	1333	0.63
1449	980	DAVIS	3772	1720	0.63
1450	812	LIGSW	1602	1109	0.63
1451	2215	CRTLD	4723	2326	0.62
1452	2333	GNSVL	1223	1015	0.62
1453	406	KRUMS	1202	701	0.62
1454	1582	CRTLD	4742	920	0.62
1455	1518	MLKF2	1201	1837	0.62
1456	1572	LVOAK	1602	936	0.62
1457	2576	WALNT	0005	992	0.62
1458	535	PWEST	1307	945	0.62
1459	679	BDFRD	8832	984	0.62
1460	1065	PRKWY	1552	556	0.62
1461	1535	CRNDL	2401	511	0.61
1462	285	WLWSP	1201	505	0.61
1463	107	VANSB	1502	1666	0.61
1464	1565	TMPLE	1201	1656	0.61
1465	1367	IRVVV	2802	1034	0.61
1466	2545	PRKWY	1542	509	0.61
1467	2244	PFFRD	3482	1087	0.61
1468	567	MKNSW	1601	1603	0.61
1469	2968	MESTE	1201	23	0.61
1470	778	WDGWD	1572	1475	0.61
1471	1436	GRAHM	0711	1616	0.61
1472	551	GVODS	3062	1978	0.61
1473	998	RICES	0206	656	0.61
1474	1354	PRKWY	1511	1301	0.60
1475	2567	WALST	0001	509	0.60
1476	544	SMPST	0004	1991	0.60
1477	202	BMTWN	1621	1432	0.60
1478	1360	GRDPR	0811	1216	0.60
1479	682	GRPVN	8223	2049	0.60
1480	1509	LUFKN	1207	47	0.60
1481	1951	COLNY	2402	2426	0.60
1482	1311	DFWSW	2209	42	0.60
1483	564	MNWLW	1403	926	0.60

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1484	2385	CDHIL	1804	1221	0.59
1485	1967	RECCR	0004	71	0.59
1486	1306	TROYS	1014	1321	0.59
1487	1302	BNMAG	1202	405	0.59
1488	655	MABNK	2403	1661	0.59
1489	1726	LGVST	8522	354	0.59
1490	325	DALRK	1326	2807	0.59
1491	467	DNIWS	1601	892	0.59
1492	195	IRVBL	2504	1585	0.59
1493	1268	BOWEN	3192	1264	0.59
1494	787	EULTB	5721	1770	0.59
1495	2358	WTHRE	2101	1215	0.59
1496	36	TRPMN	4023	426	0.58
1497	635	MRSDO	9621	1843	0.58
1498	1499	TATSP	4323	2495	0.58
1499	352	IRVNG	1407	1467	0.58
1500	561	TAYLR	1201	1774	0.58
1501	1289	COVEE	3405	1431	0.58
1502	279	RKCRK	6112	2322	0.58
1503	2190	DALRK	1358	2088	0.58
1504	726	BRYAN	0004	1301	0.58
1505	749	AZLES	2111	3043	0.58
1506	131	TIODE	9621	310	0.58
1507	1768	MESQN	1501	1807	0.58
1508	1246	CDHIL	1613	2979	0.58
1509	557	RWALE	3321	1533	0.57
1510	2568	BKWST	0004	1053	0.57
1511	299	MESQT	1308	1880	0.57
1512	2330	ODNTH	2024	2618	0.57
1513	1982	WTAUG	4643	1001	0.57
1514	624	CLBRN	1204	1094	0.57
1515	831	DIALV	3911	1081	0.57
1516	1585	WCOLO	1315	1585	0.57
1517	490	RSKMN	3053	497	0.57
1518	49	BNBOR	1201	752	0.57
1519	765	BEAST	4082	515	0.57
1520	2430	BDFWD	8912	1008	0.57
1521	1858	RWDHV	1905	1215	0.57
1522	479	CURIE	7211	752	0.57
1523	1657	KIMBL	5012	1013	0.57
1524	1461	HKHTS	1604	875	0.57
1525	1941	KLNPS	1103	2184	0.57
1526	1105	CADDO	0911	448	0.56
1527	1432	DCVSO	1103	1828	0.56
1528	1748	IRVNG	1405	1163	0.56
1529	197	MRTSP	1501	667	0.56
1530	1198	IRVGS	1901	1388	0.56
1531	2163	GRDPR	0892	1319	0.56

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1532	2460	WATCO	2603	2950	0.56
1533	837	CRLTR	2001	2501	0.56
1534	755	DENAV	0621	1705	0.56
1535	2444	MLKF2	1202	455	0.56
1536	1127	WESTS	1602	864	0.56
1537	1358	MESQN	1504	1331	0.56
1538	213	RWALS	1853	2350	0.56
1539	1897	HKHTS	1602	1019	0.56
1540	1167	GRNGR	1801	908	0.56
1541	1044	CRNDL	2403	986	0.56
1542	1573	BRCRK	6521	1428	0.56
1543	317	NPKWY	0005	856	0.55
1544	2051	LKHLD	0003	1347	0.55
1545	712	MKNGB	5312	625	0.55
1546	260	CRTLD	4724	3179	0.55
1547	1112	ARTHR	0492	49	0.55
1548	658	CRNTH	2402	1461	0.55
1549	362	PFLGV	2001	4552	0.55
1550	1474	TMPTV	2405	491	0.55
1551	1857	PFFRD	3472	1279	0.55
1552	1570	CPLND	1101	1056	0.55
1553	2599	LIGSW	1607	1435	0.55
1554	1002	HORNE	1972	766	0.55
1555	1892	BLTSW	3203	1000	0.55
1556	1916	BMTWN	1611	1843	0.55
1557	1950	SUNNY	2303	590	0.55
1558	2222	TNPON	0001	66	0.55
1559	1433	HKHTS	1603	1035	0.54
1560	1821	EULES	8712	1071	0.54
1561	2130	OVRTN	4015	626	0.54
1562	100	WSTHL	3652	3207	0.54
1563	160	CRLTN	1452	1158	0.54
1564	917	CDHIL	1802	754	0.54
1565	2740	ALNTH	2842	1943	0.54
1566	914	SSPNG	1202	1228	0.54
1567	1386	AYERS	4411	1210	0.54
1568	786	ALVRD	1504	158	0.54
1569	554	SPRDL	4811	1225	0.54
1570	1875	MCGRG	0775	527	0.54
1571	1655	ALDTU	9421	1764	0.54
1572	1625	MDTHN	1702	1899	0.54
1573	2712	IRVVV	2804	943	0.54
1574	2663	TYLER	1001	153	0.54
1575	1111	IRVBL	2502	181	0.54
1576	1025	KNEDL	6321	2423	0.53
1577	1232	WDGWD	1541	1133	0.53
1578	2563	WELRD	0007	442	0.53
1579	1271	KLNPS	1101	2291	0.53

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1580	2465	ARTHR	0441	1891	0.53
1581	533	ANDNR	2222	126	0.53
1582	84	RSKMN	3057	1173	0.53
1583	1376	REYST	4118	737	0.53
1584	501	TYRSW	1703	1387	0.53
1585	861	JKSBR	1402	1427	0.53
1586	1986	WITTS	1703	1583	0.53
1587	1442	PNTGO	7121	1506	0.53
1588	2399	RSPVY	1704	1406	0.52
1589	1455	NCSTH	1504	63	0.52
1590	575	TYOMN	1405	1662	0.52
1591	1975	MDWPK	9241	1566	0.52
1592	414	BAGWL	1202	48	0.52
1593	1598	BOWEN	3151	1944	0.52
1594	1737	ARTHR	0472	1289	0.52
1595	2102	ADISN	1601	636	0.52
1596	1818	BLKST	1762	1033	0.52
1597	576	RWDHV	1901	914	0.52
1598	1896	CRLJL	1501	1463	0.52
1599	1459	GVFTW	1801	667	0.52
1600	2122	ARLNG	1251	548	0.51
1601	2219	SPRTN	1802	883	0.51
1602	1599	SGOVL	1404	2184	0.51
1603	1522	ESTLD	3621	1494	0.51
1604	2137	PWEST	1301	1253	0.51
1605	1817	LMESA	1531	640	0.51
1606	2541	SHDYG	7822	529	0.51
1607	806	LNDAL	2202	1239	0.51
1608	186	MLFRD	2103	983	0.51
1609	1706	TMSTH	1408	754	0.51
1610	2680	CLBRN	1202	1002	0.51
1611	1166	CRTLD	4734	792	0.51
1612	1926	HURST	1831	1366	0.51
1613	573	ALPHA	0002	1260	0.51
1614	1631	VGCRK	8041	1041	0.50
1615	2188	DUVAL	0421	1303	0.50
1616	685	CDHCR	2052	1405	0.50
1617	2113	CPRCV	1407	2205	0.50
1618	610	TYWST	2012	2147	0.50
1619	1649	EDGWD	1102	947	0.50
1620	1331	SHDYG	7842	728	0.50
1621	939	MSHLN	0003	531	0.50
1622	1955	BSPRG	1905	1608	0.50
1623	1652	MESTE	1202	814	0.50
1624	2057	TMSTH	1406	1156	0.50
1625	154	SGOVL	1402	945	0.50
1626	1253	MNSTR	1201	662	0.50
1627	1593	BOWEN	3122	1281	0.50

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1628	2241	BSPRG	1903	1700	0.50
1629	1880	OKCLS	0003	1513	0.50
1630	482	BLKST	1711	1966	0.50
1631	1078	ECTHM	3311	1539	0.50
1632	909	JKSNR	4111	442	0.50
1633	1500	HKHTS	1601	1506	0.49
1634	292	TYOMN	1410	1535	0.49
1635	1796	RCLNS	1405	639	0.49
1636	820	CHNDW	1203	844	0.49
1637	2203	WHITE	3522	1813	0.49
1638	577	DNINR	1403	1198	0.49
1639	327	STAUG	0006	1800	0.49
1640	2687	REAST	1507	114	0.49
1641	2279	WSTHL	3642	4162	0.49
1642	789	ODESW	5221	1484	0.49
1643	2552	BLKST	1752	1176	0.49
1644	1548	DALRK	1305	1153	0.49
1645	2063	CRLJL	1503	752	0.49
1646	152	MDDTN	4312	1173	0.49
1647	1497	IRVHF	2302	1408	0.49
1648	1477	PPARK	1804	247	0.49
1649	207	REAST	1509	140	0.49
1650	1516	RBNSN	2503	1126	0.48
1651	1866	ENSSO	2001	227	0.48
1652	1983	TRNTH	1504	818	0.48
1653	1836	KRUMS	1204	1416	0.48
1654	951	WDGWD	1592	1167	0.48
1655	1867	LKWOD	7411	630	0.48
1656	304	SWAN2	1803	1161	0.48
1657	935	FRMBG	1751	808	0.48
1658	969	MDLNW	1532	1965	0.48
1659	266	CPLSO	4322	279	0.48
1660	2197	WNDWD	3621	2154	0.48
1661	1205	CANTN	1303	860	0.48
1662	2818	HNYGR	2403	594	0.48
1663	1781	BSPRW	2521	1121	0.48
1664	44	MTLDA	0002	1783	0.48
1665	1257	KIMBL	5021	2366	0.48
1666	268	SHSTH	1303	716	0.47
1667	1974	SMFLD	2341	980	0.47
1668	2148	DAVIS	3711	678	0.47
1669	2094	WTAUG	4631	1147	0.47
1670	1917	SALSW	3003	733	0.47
1671	766	IRVNE	1310	1421	0.47
1672	1484	MDLNW	1541	2294	0.47
1673	1696	GRDPR	0871	1569	0.47
1674	1323	SIKES	2421	1843	0.47
1675	1427	HLTOM	2431	1306	0.47

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1676	2535	GSTHW	1682	179	0.47
1677	1542	EULSO	9111	1843	0.47
1678	2208	WXHCH	1201	1657	0.47
1679	333	REYST	4129	518	0.47
1680	421	PARIS	1202	1264	0.47
1681	1609	SWDTN	1621	714	0.46
1682	845	HOLDY	0911	1162	0.46
1683	893	IRVGS	1904	958	0.46
1684	2145	KNEDL	6322	3918	0.46
1685	1629	MNWLL	1205	448	0.46
1686	1192	COPER	1201	321	0.46
1687	1560	CRLTN	1406	1202	0.46
1688	456	BNBRK	4121	5015	0.46
1689	2816	COVEE	3403	1356	0.46
1690	1498	CMBTP	1201	261	0.46
1691	1691	DESHR	1204	1157	0.46
1692	850	SHMNE	1401	1205	0.45
1693	1543	CRLTN	1407	1571	0.45
1694	331	LWSNR	2242	1374	0.45
1695	277	MNWLE	1701	672	0.45
1696	1575	PLKST	0008	1699	0.45
1697	1887	HMPHL	2781	331	0.45
1698	1511	GODRD	8142	1039	0.45
1699	2648	MRTNS	1503	359	0.45
1700	2032	TYSTH	1206	1265	0.45
1701	1666	RCHHL	0311	978	0.45
1702	1441	IRVGS	1903	882	0.45
1703	2214	TATSP	4321	1445	0.45
1704	2447	RCHHL	0374	541	0.45
1705	1480	DESPR	1406	955	0.45
1706	1647	PSHIL	1608	1941	0.44
1707	2575	CNTRD	0002	1476	0.44
1708	2847	RGLRW	0008	36	0.44
1709	2144	SGOVL	1401	1816	0.44
1710	639	KYSTN	1021	43	0.44
1711	1532	PPARK	1808	598	0.44
1712	967	PFFRD	3462	1773	0.44
1713	446	CNTRY	2823	1864	0.44
1714	1948	DCVSO	1101	1478	0.44
1715	1346	NYLDV	1202	139	0.44
1716	984	ANDNR	2211	2528	0.44
1717	1592	WWDWY	2020	1243	0.44
1718	2223	SANSM	3922	1837	0.44
1719	1451	FRMBR	1805	760	0.44
1720	1319	CRANE	0321	23	0.43
1721	1906	DESHR	1201	990	0.43
1722	2155	HOLDY	0921	615	0.43
1723	1571	MDTHS	1003	1251	0.43

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1724	29	LMESA	2813	118	0.43
1725	896	PPARK	1801	1318	0.43
1726	2489	PLKST	0004	1310	0.43
1727	2177	PALMR	2202	1051	0.43
1728	1437	FLINT	3211	2289	0.43
1729	2068	ELKHR	1201	959	0.43
1730	520	HKHTS	1606	1781	0.43
1731	1235	JSHUA	1302	1331	0.43
1732	507	SHNRW	1608	1431	0.43
1733	1390	BRCRK	6514	572	0.43
1734	1388	WMMMR	2707	1547	0.43
1735	2523	ENNIS	1901	363	0.43
1736	555	COMSO	1401	655	0.43
1737	324	TRLWD	7712	3254	0.43
1738	1586	PSHIL	1602	1077	0.43
1739	1179	CNSES	0370	1256	0.43
1740	630	SHNRW	1609	1772	0.43
1741	1940	TMSTH	1401	1823	0.42
1742	2518	CRTLD	4721	3062	0.42
1743	1341	MURPH	2751	2315	0.42
1744	1156	IOWPK	0811	789	0.42
1745	1902	CRNTH	2404	2380	0.42
1746	1099	MDLNE	0121	232	0.42
1747	1422	HLTOM	2482	1163	0.42
1748	2237	WELRD	0001	1220	0.42
1749	1675	FARON	4052	1072	0.42
1750	604	CRANE	0331	1202	0.42
1751	1945	ALLEN	2404	2057	0.42
1752	1488	WWDWY	2024	1440	0.42
1753	2462	CLBNR	1402	2453	0.42
1754	20	SCHRD	0001	1029	0.42
1755	2368	TATSP	4312	2527	0.42
1756	2434	BRCRK	6512	1784	0.42
1757	1589	MESQW	1801	2102	0.42
1758	888	HLSES	0553	1930	0.42
1759	1316	ODNTH	2014	1289	0.42
1760	703	PWEST	1308	921	0.42
1761	1285	LOMAL	0001	676	0.42
1762	2117	RRNES	2403	4953	0.42
1763	1794	COLNY	2406	811	0.41
1764	2441	SHDYG	7811	379	0.41
1765	1698	MSHLN	0006	1113	0.41
1766	2721	LIPAN	1303	268	0.41
1767	2107	ARLNG	1232	1273	0.41
1768	1669	MRDCK	0003	1267	0.41
1769	828	MESQT	1304	635	0.41
1770	1604	MCWHT	3512	864	0.41
1771	2316	MAYFD	5522	3262	0.41

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1772	748	KERNS	2401	554	0.41
1773	188	OKCLS	0004	1497	0.41
1774	2288	BDFWD	8941	1223	0.41
1775	708	BDFRD	8811	1703	0.41
1776	2347	ALLNC	6421	73	0.41
1777	826	CHNDW	1201	1190	0.41
1778	648	RDRSE	2601	1952	0.41
1779	2012	RCHHL	0332	1713	0.41
1780	2311	SFTLK	4021	39	0.41
1781	2725	WSOTH	1019	823	0.41
1782	764	BRGPR	1102	1363	0.41
1783	1425	DALWT	2911	347	0.41
1784	1558	GRPVN	8212	4097	0.41
1785	2662	SMPST	0005	152	0.41
1786	N/A	MOSSW	4612	2281	0.41
1787	365	BSPSW	0822	395	0.41
1788	239	CLYVL	9322	2203	0.40
1789	1747	GRDPR	0852	1435	0.40
1790	947	CRNTH	2405	3957	0.40
1791	2549	STAUG	0007	1183	0.40
1792	1685	DAVST	0002	552	0.40
1793	1929	COMSO	1402	946	0.40
1794	1988	LKWOD	7442	717	0.40
1795	651	TAYLR	1203	1331	0.40
1796	1161	EZACH	0006	1103	0.40
1797	340	MDTHS	1001	1700	0.40
1798	2877	CRNRD	0002	360	0.40
1799	2337	ROWLT	1103	1090	0.40
1800	2053	WXNTH	2301	1311	0.40
1801	56	PERIN	1511	653	0.40
1802	1485	BNDRA	0011	402	0.40
1803	311	TYEST	1507	1279	0.40
1804	2118	FSTVW	0007	1614	0.40
1805	321	MNHNS	1921	1848	0.40
1806	1175	BRNWD	1204	1779	0.39
1807	N/A	CMTSW	0957	1175	0.39
1808	827	SHNRW	1614	954	0.39
1809	2461	BKWST	0002	1667	0.39
1810	2185	DESHR	1203	1405	0.39
1811	2590	RCHRD	1201	1436	0.39
1812	410	RCHHL	0342	1007	0.39
1813	2259	BDFRD	8841	813	0.39
1814	2397	DNISN	1201	1468	0.39
1815	987	WXNTH	2305	1067	0.39
1816	67	ALNSW	2653	3516	0.39
1817	729	IRVVV	2803	154	0.39
1818	869	HUTCH	1502	203	0.39
1819	1778	MRDCK	0002	1699	0.39

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1820	315	SLBLF	1201	139	0.39
1821	2168	BRCRK	6533	1833	0.39
1822	2120	GODRD	8132	2702	0.39
1823	738	LKMNT	0007	1553	0.39
1824	1207	IRVND	1202	1503	0.38
1825	1405	MESQW	1803	1691	0.38
1826	854	EDGCF	2262	1019	0.38
1827	2570	RCHRD	1206	683	0.38
1828	952	CLYVL	9313	2010	0.38
1829	1889	LKHLD	0007	1209	0.38
1830	1633	TATSP	4311	1873	0.38
1831	1279	DALLW	0003	663	0.38
1832	2202	WCOLO	1316	2076	0.38
1833	409	RGLRW	0004	79	0.38
1834	466	TAYLR	1204	2026	0.38
1835	204	DCDAM	2001	799	0.38
1836	1010	KLNSO	4502	3190	0.38
1837	1620	KILEN	1204	1520	0.38
1838	1241	DGNST	0007	241	0.38
1839	1208	WHTRK	0001	2750	0.38
1840	2917	LSCOL	2137	774	0.38
1841	1326	KLNTF	1805	1339	0.38
1842	1617	WNDRCR	0211	1183	0.38
1843	2058	CPRCV	1403	1437	0.38
1844	721	KEYSB	2621	16	0.38
1845	512	PCOIT	1001	1233	0.37
1846	2960	JREST	2103	267	0.37
1847	1022	GRLRD	0003	641	0.37
1848	877	LOMAL	0011	1130	0.37
1849	1475	BRNSO	1806	1782	0.37
1850	946	SPRDL	4831	1268	0.37
1851	746	MESQT	1303	830	0.37
1852	2309	CRLTR	2002	1495	0.37
1853	2373	TATSP	4313	1612	0.37
1854	714	PCUST	2012	1813	0.37
1855	2105	RRNES	2405	2628	0.37
1856	2707	TMSTH	1407	206	0.37
1857	882	BLKST	1742	1729	0.37
1858	273	ODNTH	2044	2091	0.37
1859	55	WDGWD	1591	1131	0.37
1860	1782	SANSM	3912	5168	0.37
1861	2722	DAVST	0007	608	0.37
1862	599	LTFRD	3021	899	0.36
1863	2432	CRNRD	0004	480	0.36
1864	580	CNTRY	2813	3070	0.36
1865	754	LNGLK	1604	448	0.36
1866	2493	RSNHT	1142	946	0.36
1867	1357	AZLES	2122	2255	0.36

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1868	1515	EDGCF	2213	3188	0.36
1869	1242	MDWCK	0007	1081	0.36
1870	950	DNINR	1402	389	0.36
1871	1702	BSPSW	0841	2117	0.36
1872	1380	BRCRK	6524	782	0.36
1873	613	KILEN	1202	1721	0.36
1874	1148	PLSTH	1301	722	0.36
1875	1949	BRCRK	6511	1291	0.36
1876	2705	MKNSO	3614	2401	0.36
1877	1909	SWDTN	1631	1624	0.36
1878	1812	HURST	1882	1900	0.36
1879	1750	RRNES	2404	4452	0.36
1880	1936	KNEDL	6311	2923	0.36
1881	2087	CLBRN	1203	1574	0.36
1882	701	EULSO	9112	735	0.36
1883	1672	PCOIT	1008	1243	0.36
1884	2490	WFALS	0193	2233	0.36
1885	184	CRNTH	2406	1310	0.36
1886	367	WTAUG	4632	1313	0.36
1887	1239	TYEST	1503	1077	0.36
1888	621	IVANS	1612	1049	0.36
1889	1130	CLMET	0002	1407	0.36
1890	2174	BLTLN	0007	780	0.35
1891	2133	ESTLD	3611	1538	0.35
1892	2253	MEXIA	4024	345	0.35
1893	2378	MSTLT	1063	976	0.35
1894	221	WALST	0005	249	0.35
1895	194	TEGMN	3040	798	0.35
1896	620	SHNRW	1612	827	0.35
1897	514	HUBRD	1401	902	0.35
1898	1275	BONHM	1204	840	0.35
1899	2010	ARLNG	1213	1328	0.35
1900	263	CNTRY	2814	930	0.35
1901	1569	ATHNW	1401	902	0.35
1902	2275	ARLNG	1261	1366	0.35
1903	2402	HKHTS	1605	1473	0.35
1904	2439	BSPRW	2511	760	0.35
1905	1699	PNTGO	7111	723	0.35
1906	1526	DUVAL	0452	1274	0.35
1907	9	CANTN	1302	1348	0.35
1908	1663	SHRSW	6621	1816	0.35
1909	2852	FLMSO	3712	865	0.35
1910	1174	ALVDO	1901	1464	0.35
1911	887	PALRD	2205	333	0.35
1912	1282	CPRCV	1402	2034	0.35
1913	2528	PALRD	2203	1088	0.34
1914	1680	WSOTH	1017	1744	0.34
1915	2342	FSHSW	2121	1702	0.34

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1916	2970	PJPTR	3222	183	0.34
1917	1759	HKBRY	1106	1671	0.34
1918	1107	RWDHV	1906	639	0.34
1919	2719	WELRD	0004	802	0.34
1920	985	CNTRD	0004	1081	0.34
1921	1244	CRSWS	1402	925	0.34
1922	2340	KNEDL	6342	2123	0.34
1923	1976	PLKST	0006	816	0.34
1924	250	PRKRW	3341	542	0.34
1925	1445	SUNNY	2301	611	0.34
1926	832	ODESA	0231	2115	0.34
1927	2149	JUDCT	0002	1409	0.34
1928	403	LKHLD	0005	1137	0.34
1929	2096	CRSWS	1403	1801	0.34
1930	805	TYWST	2001	179	0.34
1931	1849	BRNSO	1801	1568	0.33
1932	1512	WDGWD	1522	1440	0.33
1933	2157	BBTWN	1501	1954	0.33
1934	2935	ARLNG	1291	87	0.33
1935	858	OAKHL	3041	945	0.33
1936	1727	TMNTH	1607	12	0.33
1937	1713	WFALS	0133	1672	0.33
1938	629	WCOLO	1320	1439	0.33
1939	69	LVBRD	0002	509	0.33
1940	1554	ROANW	9521	1944	0.33
1941	2825	CRKET	1201	323	0.33
1942	2101	KLNTF	1806	1181	0.33
1943	1789	DUVAL	0473	1602	0.33
1944	234	BRTLTL	1402	122	0.33
1945	2181	DCVSO	1102	705	0.33
1946	733	WTAUG	4652	800	0.33
1947	803	KRUMS	1201	376	0.33
1948	1878	MESQW	1807	1498	0.33
1949	1324	CNSES	3054	1580	0.33
1950	1640	WXNTH	2302	1308	0.33
1951	1868	MSTLT	1021	1288	0.33
1952	1301	MRTSP	1502	498	0.33
1953	1864	IRVGS	1907	966	0.33
1954	762	CRLTR	2005	677	0.32
1955	342	BRLSN	2041	3811	0.32
1956	2271	SIKES	2411	2073	0.32
1957	1259	KLNPS	1104	1344	0.32
1958	752	CRLFR	2152	3480	0.32
1959	1113	BNTDR	0002	1784	0.32
1960	1701	RTHGB	1421	1661	0.32
1961	2255	PFFRD	3492	297	0.32
1962	381	CNTRY	2851	1504	0.32
1963	1521	BELLS	1201	573	0.32

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1964	417	TRLSW	1202	59	0.32
1965	1092	SHNRW	1607	554	0.32
1966	233	KLNCC	1702	3779	0.32
1967	1658	DALRK	1301	1230	0.32
1968	892	TMPLE	1204	1034	0.32
1969	1260	DESPR	1402	1305	0.32
1970	143	IRVBL	2507	904	0.32
1971	116	ECTHM	3331	22	0.32
1972	1490	RCHHL	0384	718	0.32
1973	1580	FLINT	3212	3024	0.32
1974	1185	CRTLD	4712	1172	0.32
1975	1249	GRHWY	5511	1899	0.32
1976	1791	MKNKY	1205	507	0.32
1977	2229	ENNIS	1903	1386	0.32
1978	2319	RRSTH	1702	3289	0.32
1979	2471	MDAIR	2922	387	0.32
1980	1710	THRNE	0003	1252	0.31
1981	1414	TMSTH	1402	1656	0.31
1982	2306	MESWE	3611	1923	0.31
1983	1454	IRVNR	1507	1490	0.31
1984	1662	CDCRK	1201	1253	0.31
1985	1777	MESQN	1502	1089	0.31
1986	2377	MESTE	1203	174	0.31
1987	1322	IRVGS	1906	719	0.31
1988	1158	CSHNG	1204	326	0.31
1989	496	RNDRK	1503	3919	0.31
1990	1711	CLYVL	9321	822	0.31
1991	1764	MESTE	1206	1288	0.31
1992	1788	BRLSN	2052	3010	0.31
1993	2291	WNTHW	1121	749	0.31
1994	2020	CLBRN	1206	1038	0.31
1995	1389	GRSMN	4028	710	0.31
1996	1030	RSPCK	2132	72	0.31
1997	N/A	CMTSW	0977	249	0.31
1998	1443	CLBRN	1201	1750	0.31
1999	2611	SHRSW	6612	1826	0.31
2000	537	IRVNR	1508	2015	0.30
2001	1395	TYWST	2003	1412	0.30
2002	1786	BDFRD	8842	1465	0.30
2003	2405	HORNE	1991	1480	0.30
2004	1703	ODESW	5211	1262	0.30
2005	1374	TYSTH	1209	814	0.30
2006	669	IRVNE	1303	1688	0.30
2007	710	JEWET	1204	1331	0.30
2008	86	PLSTN	1001	1897	0.30
2009	1814	DAVST	0003	1691	0.30
2010	1822	ARTHR	0481	1251	0.30
2011	2564	GRLRD	0001	1773	0.30

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2012	741	MKNSW	1603	1379	0.30
2013	2226	LOMAL	0016	664	0.30
2014	943	WDGWD	1513	865	0.30
2015	822	RRNES	2407	3365	0.30
2016	2236	BOWEN	3132	1779	0.30
2017	602	TSLVL	4002	2748	0.30
2018	1212	ODNTH	2013	1594	0.30
2019	1654	TMPNW	1104	1927	0.30
2020	1150	ELGIN	1001	539	0.29
2021	2110	ODNTH	2053	2350	0.29
2022	387	HOLND	1901	1097	0.29
2023	1102	RGLRW	0005	51	0.29
2024	1122	KFMNW	1202	874	0.29
2025	1966	BRLSN	2033	1671	0.29
2026	413	IRVGS	1908	957	0.29
2027	2143	HSKAV	0008	791	0.29
2028	1938	DESPR	1408	1998	0.29
2029	1556	WTAUG	4611	1394	0.29
2030	1146	CKRHL	0003	472	0.29
2031	2232	PCUST	2003	1028	0.29
2032	461	ECTOR	1201	388	0.29
2033	2478	WEAST	0619	2449	0.29
2034	1508	CRLJL	1506	1940	0.29
2035	2538	BRCRK	6543	1659	0.29
2036	26	EMPCT	0003	1355	0.29
2037	206	MKNYY	1253	156	0.29
2038	2011	MESTE	1215	1516	0.29
2039	2414	LOMAL	0006	1413	0.29
2040	2820	EULTB	5711	2295	0.29
2041	1215	RSNHT	1181	1713	0.29
2042	2186	PALRD	2204	687	0.29
2043	214	PREST	1604	1343	0.29
2044	1538	PRCTR	1601	207	0.29
2045	2656	EZACH	0003	1288	0.28
2046	2013	IRVNG	1406	1278	0.28
2047	1761	CRKET	2401	151	0.28
2048	686	TRPMN	4094	573	0.28
2049	1478	CRLJL	1507	926	0.28
2050	2475	GRDPR	0862	1564	0.28
2051	2123	MDWCK	0001	839	0.28
2052	823	SPRDL	4821	1363	0.28
2053	1568	DAVIS	3721	1323	0.28
2054	1097	DFWSW	2203	39	0.28
2055	1919	WSTHL	3631	3801	0.28
2056	2112	CRLTR	2052	1568	0.28
2057	2041	WATSN	5331	1114	0.28
2058	590	ROANW	9512	1928	0.28
2059	959	TRNTH	1502	544	0.28

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2060	1438	HMPHL	2743	907	0.28
2061	2613	SPRDL	4812	1205	0.28
2062	1881	WCOLO	1318	1647	0.28
2063	2546	PCUST	2001	579	0.28
2064	2082	RNDRK	1505	1321	0.28
2065	2933	ABBOT	1901	111	0.28
2066	2830	CRNSO	3911	301	0.28
2067	301	MTLDA	0003	1550	0.28
2068	859	PWEST	1309	61	0.28
2069	1637	CDHIL	1805	621	0.28
2070	2115	MSHLN	0005	503	0.28
2071	1180	LFSTH	1408	2116	0.28
2072	1071	MCKMY	0821	1783	0.28
2073	1863	SMFLD	2343	719	0.28
2074	677	LKBRN	2401	705	0.28
2075	1506	LOMAL	0008	449	0.28
2076	1396	CMNCH	1401	1200	0.28
2077	912	MYPTX	2401	305	0.28
2078	1270	CRNSO	3913	1541	0.28
2079	1688	PWEST	1304	1615	0.27
2080	1481	MRSES	4006	529	0.27
2081	289	FSCRK	6723	4515	0.27
2082	727	PKRMX	4701	1744	0.27
2083	N/A	BLMND	3211	11	0.27
2084	2433	TYLER	1010	55	0.27
2085	1296	IRVNG	1402	1142	0.27
2086	193	ODNTH	2034	2782	0.27
2087	2127	GSTHW	1623	2529	0.27
2088	1898	WHITE	3542	1671	0.27
2089	2049	TMPTV	2402	3763	0.27
2090	1460	LFEST	1901	1512	0.27
2091	411	PROAD	0005	122	0.27
2092	2710	MESQN	1503	1890	0.27
2093	500	PLSTN	1002	1222	0.27
2094	753	VENSW	2601	1425	0.27
2095	1472	CRLTN	1405	1251	0.27
2096	981	GSTHW	1611	817	0.27
2097	675	BRLSN	2013	1104	0.27
2098	2175	MESTE	1207	952	0.27
2099	1514	SMPST	0006	844	0.27
2100	1708	RSPCK	2104	1903	0.27
2101	1667	CRLFR	2157	2417	0.27
2102	1751	PFLGV	2005	3802	0.27
2103	2021	MURPH	2755	3282	0.27
2104	740	CRSGL	1301	146	0.27
2105	2779	ABRRD	0003	345	0.27
2106	1088	CLLVL	0003	679	0.27
2107	615	IRVBL	2505	499	0.27

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2108	958	GRLWS	1704	173	0.27
2109	2620	WATCO	2605	2709	0.27
2110	2201	KLBRG	0002	1716	0.27
2111	2703	BOWEN	3181	768	0.27
2112	1394	BRNSO	1807	565	0.27
2113	1067	BDFWD	8931	1731	0.27
2114	1136	ADISN	1607	1237	0.27
2115	2040	KRUMS	1203	791	0.26
2116	1999	ARMST	0007	125	0.26
2117	933	FRMNT	0009	945	0.26
2118	2207	MDLNE	0172	372	0.26
2119	1216	GPLND	1201	676	0.26
2120	2778	WMMMR	2706	19	0.26
2121	1337	IRVNG	1403	525	0.26
2122	2458	MAPLE	0001	1066	0.26
2123	2473	EDGCF	2211	2105	0.26
2124	1679	HKHTS	1607	943	0.26
2125	930	TMSTH	1403	1177	0.26
2126	2268	TRNTY	7551	1576	0.26
2127	1895	PCOIT	1023	639	0.26
2128	2423	MSTLT	1084	800	0.26
2129	165	WEAST	0618	854	0.26
2130	1449	CRLCC	2704	535	0.26
2131	2138	CDHCR	2050	809	0.26
2132	2074	CRYVE	3011	289	0.26
2133	2108	EULSO	9122	1296	0.26
2134	2789	WALST	0013	386	0.26
2135	504	CRSCN	1203	1992	0.26
2136	185	ALNSW	2654	1973	0.26
2137	1627	BEAST	4088	116	0.26
2138	2534	RRSTH	1708	4237	0.26
2139	2035	PARIS	1204	1161	0.26
2140	1952	FARON	4082	1599	0.26
2141	1471	PSHIL	1604	1163	0.26
2142	2326	BRLSN	2023	1844	0.26
2143	2486	STAUG	0005	1230	0.26
2144	2387	RNDRK	1508	4031	0.26
2145	1238	CPRCV	1401	1850	0.26
2146	2427	EDGCF	2241	929	0.26
2147	1019	GRLWS	1706	289	0.26
2148	844	KLNSO	4501	3429	0.26
2149	2859	WMRNR	0001	184	0.26
2150	2356	WMMMR	2702	1544	0.26
2151	1079	ARPMN	4147	600	0.26
2152	1615	PRSTN	0001	907	0.25
2153	2418	GVODS	3011	2282	0.25
2154	680	WTAUG	4641	574	0.25
2155	2085	LTVSB	5451	1231	0.25

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2156	1428	CAMRN	1202	1471	0.25
2157	938	MDLNW	1594	1648	0.25
2158	1128	TERSO	2501	185	0.25
2159	1733	RCHHL	0363	579	0.25
2160	2521	WNDRC	0232	646	0.25
2161	1151	TYOMN	1401	1558	0.25
2162	2502	LKHL	0001	1662	0.25
2163	1202	MSLSW	0004	411	0.25
2164	2205	CRLTR	2003	1355	0.25
2165	2173	PCOIT	1003	1511	0.25
2166	2607	WGROB	8411	3435	0.25
2167	2889	CLLVL	0002	12	0.25
2168	115	JKSNR	4105	84	0.25
2169	1605	EDGCF	2223	3179	0.25
2170	2506	IRVND	1203	437	0.25
2171	860	ROWLT	1107	369	0.25
2172	588	TYBLR	2805	2231	0.25
2173	1273	EDDYS	0710	648	0.25
2174	1660	WHITE	3511	1341	0.25
2175	1828	WNDRC	0262	230	0.25
2176	625	MESTE	1205	1640	0.25
2177	2717	CMTSW	0987	396	0.25
2178	1678	ADMDS	6521	1593	0.25
2179	2003	ATHNW	1405	882	0.25
2180	1602	FSTVW	0001	793	0.25
2181	1991	TYLGE	1306	2323	0.25
2182	2242	BRNWD	1201	1583	0.25
2183	1840	HORNE	1913	1685	0.25
2184	2111	CLBWS	8111	1682	0.25
2185	2529	CRSCN	1201	833	0.25
2186	1294	WEBBS	8624	2302	0.25
2187	2128	COMSO	1405	754	0.25
2188	2708	HMPHL	2721	518	0.25
2189	2258	WKATY	1718	2215	0.25
2190	1923	HMTRD	0001	967	0.25
2191	2147	EULES	8713	2185	0.24
2192	2379	SMFLD	2311	1417	0.24
2193	58	ECTHM	3321	1012	0.24
2194	2982	SMFLD	2322	41	0.24
2195	779	LNCST	1601	681	0.24
2196	2583	DNISN	1206	920	0.24
2197	705	LWRDR	0002	994	0.24
2198	1590	REAST	1506	1208	0.24
2199	713	GRDPR	0831	1226	0.24
2200	1418	ROWLT	1104	1121	0.24
2201	2348	STAUG	0003	2162	0.24
2202	1932	MDWPK	9231	2416	0.24
2203	2015	KEENE	1503	833	0.24

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2204	2047	PRKWY	1561	1737	0.24
2205	2167	KLNTF	1802	866	0.24
2206	1284	RCHRD	1203	837	0.24
2207	700	MESQN	1508	1788	0.24
2208	1971	RCHHL	0321	1739	0.24
2209	2376	HORNE	1952	1275	0.24
2210	251	LMESA	1561	1426	0.24
2211	2785	LKBLT	2101	571	0.24
2212	73	LFKHL	2103	1954	0.24
2213	43	BRGPR	1103	900	0.24
2214	384	KLNCC	1704	2556	0.24
2215	1914	TRLWD	7721	1620	0.24
2216	1850	LOMAL	0014	588	0.24
2217	1651	BLTLN	0003	589	0.24
2218	1718	COPER	1202	976	0.24
2219	2367	PROAD	0002	841	0.24
2220	808	PCUST	2002	821	0.24
2221	2281	IRVBL	2503	1304	0.23
2222	1754	WELRD	0002	744	0.23
2223	1344	PLANO	1105	60	0.23
2224	1608	DIBOL	1506	613	0.23
2225	813	SHRSW	6622	1624	0.23
2226	1100	MESQN	1506	65	0.23
2227	2892	NCSTH	1506	91	0.23
2228	2346	DUVAL	0462	1062	0.23
2229	2217	BLTON	1801	850	0.23
2230	626	HUTTO	2742	4671	0.23
2231	1704	OAKHL	3062	2282	0.23
2232	2842	SHDYG	7841	340	0.23
2233	1844	BRNAV	0784	1896	0.23
2234	334	BNBOR	1202	736	0.23
2235	834	MRDCK	0001	2203	0.23
2236	1763	AMLIA	0003	22	0.23
2237	1681	ENNIS	1905	44	0.23
2238	2160	MLFRD	2101	970	0.23
2239	574	WICKT	0421	137	0.23
2240	2801	BRKRG	0221	699	0.23
2241	2416	THSES	2402	1407	0.23
2242	1581	RCHRD	1207	1544	0.22
2243	1709	EULTB	5731	494	0.22
2244	2597	DGNST	0004	942	0.22
2245	2300	LUFKN	1205	1335	0.22
2246	2235	MTLDA	0007	1785	0.22
2247	788	GRMES	0511	1201	0.22
2248	1656	CDHIL	1803	1903	0.22
2249	2843	WNDWD	3672	265	0.22
2250	2797	MSTLT	1011	63	0.22
2251	75	VLYRN	2954	2748	0.22

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2252	2060	ROBNW	1503	1670	0.22
2253	618	MRSDO	9611	1762	0.22
2254	1463	HMPHL	2772	299	0.22
2255	402	HLSES	0542	766	0.22
2256	2474	MAYFD	5521	3213	0.22
2257	605	TYBLR	2804	2442	0.22
2258	1272	GRLND	1606	965	0.22
2259	2037	LKWOD	7432	1609	0.22
2260	1690	WHITE	3512	1533	0.22
2261	1859	ROWLT	1101	1255	0.22
2262	874	CKRHL	0005	1226	0.22
2263	2628	ALLEN	2403	1366	0.22
2264	1803	ROWLT	1102	807	0.22
2265	2480	SHRSW	6641	1005	0.22
2266	2090	MDLNW	1521	1788	0.22
2267	2119	MESFR	2101	2018	0.22
2268	1005	CRLTN	1451	474	0.22
2269	1954	KNLTR	0008	902	0.22
2270	1189	IRVNG	1401	1604	0.22
2271	725	TYEST	1509	383	0.22
2272	2445	KNEDL	6332	2191	0.22
2273	955	LVBRD	0004	1059	0.22
2274	872	CRLTR	2007	1449	0.22
2275	2322	SMFLD	2391	292	0.22
2276	1007	DAVIS	3752	502	0.22
2277	2313	DAVIS	3741	1288	0.21
2278	1744	PWEST	1311	958	0.21
2279	1934	CLMET	0001	1592	0.21
2280	839	IRVND	1208	164	0.21
2281	2571	GRPTT	9921	582	0.21
2282	2129	TRNTY	7511	1451	0.21
2283	2287	SMFLD	2372	634	0.21
2284	46	OKLND	0004	799	0.21
2285	2062	IRVVV	2801	2407	0.21
2286	2125	FROKS	0002	1567	0.21
2287	1972	IRVNR	1505	1319	0.21
2288	1444	CMNCH	1402	1156	0.21
2289	1027	BLMND	3221	95	0.21
2290	796	PLSTH	1302	1012	0.21
2291	1310	PFFRD	3431	580	0.21
2292	293	PCUST	2009	2273	0.21
2293	1745	DALRK	1303	1271	0.21
2294	2159	TLRWT	2201	1821	0.21
2295	2582	WELRD	0003	511	0.21
2296	2025	MESTE	1211	1171	0.21
2297	51	LKMNT	0005	680	0.21
2298	2276	MYPRL	1803	599	0.21
2299	1771	VGCRK	8011	1531	0.21

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2300	2392	ADISN	1604	1152	0.21
2301	2303	CRLTN	1402	798	0.21
2302	970	GNSVL	1204	505	0.21
2303	394	MAYFD	5511	4142	0.21
2304	2882	WFALS	0124	126	0.21
2305	2080	SHDYG	7831	97	0.21
2306	2630	THRNE	0001	1771	0.21
2307	2294	MESTE	1213	995	0.21
2308	897	PRSTN	0008	748	0.21
2309	2239	ARLNG	1282	839	0.20
2310	2659	WHTRK	0005	727	0.20
2311	2341	ALLEN	2401	744	0.20
2312	180	RRNES	2401	4972	0.20
2313	1784	DCATR	1203	929	0.20
2314	2858	IRLBJ	3221	842	0.20
2315	1287	RWDHV	1903	1261	0.20
2316	1031	CRNTH	2403	2764	0.20
2317	1774	ELGIN	1003	2107	0.20
2318	2735	HKBRY	1115	15	0.20
2319	2655	HMPHL	2791	30	0.20
2320	2443	WEAST	0621	15	0.20
2321	1735	ROWLT	1105	1066	0.20
2322	1961	RNDRK	1504	988	0.20
2323	999	GRDPR	0881	1882	0.20
2324	2070	ENNIS	1904	1264	0.20
2325	2334	GRMES	0512	1195	0.20
2326	2318	SHSTH	1301	2221	0.20
2327	2252	GRHWY	5512	3134	0.20
2328	982	RNDRK	1507	891	0.20
2329	1780	TYLER	1002	861	0.20
2330	1320	HLTOM	2421	1592	0.20
2331	899	WMPNR	0002	431	0.20
2332	1872	ODNTH	2073	671	0.20
2333	2408	WMMMR	2703	1120	0.20
2334	2516	RBNSN	2504	1646	0.20
2335	1000	LOMAL	0009	1007	0.20
2336	1741	KEENE	1501	1611	0.20
2337	1550	LKBLT	2102	1369	0.20
2338	1716	IRVNG	1408	1067	0.19
2339	2103	BSPRG	1902	2408	0.19
2340	1758	DALWT	2962	473	0.19
2341	2455	HNYGR	2401	468	0.19
2342	1959	HUTTO	2711	3776	0.19
2343	2272	RCHRD	1202	798	0.19
2344	1183	MEXIA	4040	861	0.19
2345	434	CKPHL	0006	258	0.19
2346	1305	FHLSW	1361	983	0.19
2347	2760	BNMNW	1102	411	0.19

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2348	2283	FROKS	0005	1423	0.19
2349	2543	HKBRY	1117	141	0.19
2350	2383	LWSNR	2241	1085	0.19
2351	1225	PCOIT	1006	1040	0.19
2352	1927	RSNHT	1171	2317	0.19
2353	222	CRLSP	1703	263	0.19
2354	2588	CDHCR	2055	1321	0.19
2355	2262	MTLDA	0005	1559	0.19
2356	2906	KLNTF	1803	1054	0.19
2357	1431	WCOLO	1317	1268	0.19
2358	2014	FSTVW	0005	1762	0.19
2359	1922	WNTHW	1119	1318	0.19
2360	910	BRNWD	1206	1397	0.19
2361	2501	EDGCF	2252	401	0.19
2362	2171	STAUG	0004	2075	0.19
2363	2097	COPEL	3053	2070	0.19
2364	756	CRWLY	7011	424	0.19
2365	1591	KNLTR	0005	2858	0.19
2366	2187	PPARK	1806	840	0.19
2367	2558	JUDCT	0006	1213	0.19
2368	560	DAVST	0008	27	0.19
2369	1981	GSTHW	1641	81	0.19
2370	2093	LWSNR	2231	789	0.19
2371	2406	MDTHN	1701	1524	0.18
2372	868	WEAST	0616	777	0.18
2373	74	WEBBS	8622	1696	0.18
2374	2273	SACRC	5521	120	0.18
2375	388	HMTRD	0004	1059	0.18
2376	767	BRCRK	6522	2213	0.18
2377	347	DAVIS	3713	869	0.18
2378	2742	LEMON	0001	2161	0.18
2379	2420	BRHLW	7621	2882	0.18
2380	2819	GRAHM	0713	401	0.18
2381	1659	SANSM	3923	3786	0.18
2382	1899	WATSN	5361	2524	0.18
2383	1960	TLRWT	2203	815	0.18
2384	308	WTAUG	4642	1270	0.18
2385	428	STNVL	1203	2267	0.18
2386	2494	BLKST	1771	1214	0.18
2387	2132	RCHHL	0353	1731	0.18
2388	2581	PCUST	2005	1716	0.18
2389	2438	LEMON	0009	1778	0.18
2390	2531	MDWCK	0005	1379	0.18
2391	2556	RSPCK	2142	930	0.18
2392	1870	INAIR	1411	948	0.18
2393	2154	SHNRW	1601	106	0.18
2394	2382	KILEN	1203	759	0.18
2395	2435	MCDMT	2551	2214	0.18

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2396	2616	TMPSE	1501	543	0.18
2397	1561	SWTWR	1321	140	0.18
2398	177	HUDSN	1605	146	0.18
2399	681	STNVL	1206	2519	0.18
2400	2667	CMHBL	8121	62	0.18
2401	2706	HORNE	1992	254	0.18
2402	2206	MKNGB	5342	1257	0.18
2403	1829	PSHIL	1603	1594	0.18
2404	2497	SSPNG	1203	1373	0.18
2405	2165	WTAUG	4621	445	0.18
2406	1061	BRYAN	0005	3880	0.18
2407	2596	ARLNG	1271	2077	0.17
2408	997	WTAUG	4612	1230	0.17
2409	1210	RGFTW	6813	23	0.17
2410	2676	WATSN	5382	664	0.17
2411	2689	BLTLN	0005	881	0.17
2412	1903	HHSTH	1504	2390	0.17
2413	885	PRCRK	0004	1497	0.17
2414	1173	WSOTH	1021	2131	0.17
2415	2086	CRSWS	1401	1380	0.17
2416	2104	FRMBR	1801	1245	0.17
2417	1343	WHTRK	0002	1428	0.17
2418	2422	PNTGO	7122	1097	0.17
2419	1962	PLSTH	1303	573	0.17
2420	1381	DUBLN	2214	689	0.17
2421	830	ARTHR	0431	471	0.17
2422	1011	BNMAG	1201	197	0.17
2423	2555	HHSTH	1503	1620	0.17
2424	2116	DUVAL	0483	2254	0.17
2425	1574	DCVSO	1107	1102	0.17
2426	N/A	DFWSE	2712	24	0.17
2427	2266	PPARK	1802	606	0.17
2428	2653	RRSTH	1701	3176	0.17
2429	1943	MRTNS	1501	493	0.17
2430	2220	ROWLT	1106	1312	0.17
2431	1978	COPER	0402	169	0.17
2432	2100	BRKNR	1221	1154	0.17
2433	2140	IRVNR	1551	1367	0.17
2434	2510	ARTHR	0422	1054	0.17
2435	2540	RSPVY	1706	1342	0.16
2436	1638	KLBRG	0004	1171	0.16
2437	1329	DENAV	0673	61	0.16
2438	1336	IVANS	1621	61	0.16
2439	542	CNEXP	0007	398	0.16
2440	2354	RWDHV	1907	894	0.16
2441	2457	CLYVL	9323	1423	0.16
2442	976	RCHHL	0344	1247	0.16
2443	2930	WTAUG	4651	541	0.16

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2444	1684	CRSGL	1302	1462	0.16
2445	2802	CRSCN	1202	626	0.16
2446	1119	BRCRK	6513	1198	0.16
2447	1904	PCUST	2010	2259	0.16
2448	1502	PWEST	1310	685	0.16
2449	968	CRTLD	4731	2977	0.16
2450	1837	GRPVN	8222	2043	0.16
2451	2669	KNLTR	0001	2124	0.16
2452	612	PTENN	2354	524	0.16
2453	1697	CLBNR	1404	1330	0.16
2454	2310	WSTHL	3613	3363	0.16
2455	2757	ARMST	0005	1514	0.16
2456	110	GMINI	5811	3285	0.16
2457	2017	STNVL	1201	2533	0.16
2458	586	DESHR	1206	2238	0.16
2459	332	IRVVV	2853	2601	0.16
2460	2500	PRKWY	1532	2134	0.16
2461	2773	MCKMY	0812	133	0.16
2462	2413	RSPCK	2141	19	0.16
2463	1221	RSPVY	1702	539	0.16
2464	2361	PRKRW	3352	1532	0.16
2465	1416	ADISN	1608	369	0.16
2466	2088	GRFRD	1002	382	0.16
2467	2737	DAVST	0001	576	0.16
2468	2315	DEALY	0004	2383	0.16
2469	1670	GRSMN	4029	955	0.16
2470	42	VLYRN	2952	3425	0.16
2471	1009	RCLNS	1402	725	0.16
2472	1533	CMTSW	0983	1080	0.16
2473	811	LOMAL	0013	1056	0.16
2474	1979	ELKTN	2501	735	0.16
2475	2331	FORSW	2025	549	0.15
2476	2401	ALNTH	2851	2093	0.15
2477	282	RDLML	2512	1208	0.15
2478	2424	MRSES	3019	13	0.15
2479	134	MDDTN	4321	918	0.15
2480	2928	PLHWY	3701	495	0.15
2481	377	FRMNT	0005	483	0.15
2482	1946	PFFRD	3452	871	0.15
2483	2572	SORCY	0001	2557	0.15
2484	1439	RANGR	4311	925	0.15
2485	691	BNDRA	0004	722	0.15
2486	1204	WTAUG	4623	730	0.15
2487	2189	BRKRG	0211	310	0.15
2488	2632	MRSES	3015	582	0.15
2489	2849	STNVL	1202	73	0.15
2490	2522	FRMBG	1701	100	0.15
2491	2675	RWDHV	1904	516	0.15

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2492	2261	LTVSB	5461	795	0.15
2493	2815	FSCRK	6721	1665	0.15
2494	1749	DCDAM	2002	907	0.15
2495	1819	MURPH	2752	2147	0.15
2496	663	CHROW	0001	136	0.15
2497	2484	WSOTH	1022	1797	0.15
2498	1674	LMESA	1512	1814	0.15
2499	2321	SHMNE	1403	995	0.15
2500	2240	MDTHS	1002	1265	0.14
2501	2839	SHDYG	7821	97	0.14
2502	1281	LKHLD	0002	1528	0.14
2503	1855	DAVIS	3731	767	0.14
2504	1134	MKNKY	1202	1911	0.14
2505	2975	PLHWY	3703	14	0.14
2506	2061	WRBND	2322	847	0.14
2507	1353	EDGCF	2282	1054	0.14
2508	2640	WEBBS	8621	2832	0.14
2509	2886	LAVON	1402	155	0.14
2510	1036	MTLDA	0006	2011	0.14
2511	846	MESTE	1204	1828	0.14
2512	1686	CRNRD	0006	353	0.14
2513	627	QNLAN	1202	389	0.14
2514	1792	BRNWD	1205	1151	0.14
2515	2844	GRPVN	8231	398	0.14
2516	2046	ATNRN	3421	1962	0.14
2517	2903	WEAST	0620	578	0.14
2518	2713	PALRD	2208	1076	0.14
2519	657	BLSRA	1602	158	0.14
2520	1834	LOMAL	0005	395	0.14
2521	1308	MKNSW	2603	2604	0.14
2522	2950	FRNKF	0008	1342	0.14
2523	471	JKSES	3028	376	0.14
2524	1610	TYBLR	2802	998	0.14
2525	1314	RCLNS	1404	717	0.14
2526	2436	ACRLY	1711	174	0.14
2527	678	CGRSW	9811	58	0.14
2528	2932	LEMON	0002	979	0.14
2529	2586	PLANO	1103	1877	0.14
2530	2646	GAVSW	0001	1712	0.14
2531	476	KLNCC	1701	2312	0.14
2532	59	MDLNE	0151	308	0.14
2533	2079	GODRD	8122	1053	0.14
2534	2045	DUVAL	0434	2491	0.14
2535	2709	SHMNE	1405	795	0.13
2536	156	HUBRD	1402	1013	0.13
2537	2194	LIPAN	1301	510	0.13
2538	2831	TMNTH	1601	30	0.13
2539	423	COPEL	3054	828	0.13

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2540	275	PPARK	1807	889	0.13
2541	1231	DUBLN	1360	1101	0.13
2542	719	DLEON	0131	737	0.13
2543	1373	RNDRK	1506	1687	0.13
2544	2076	ROLTR	2911	1809	0.13
2545	642	GVODS	3072	2256	0.13
2546	693	HMPHL	2711	524	0.13
2547	2335	BLTLN	0004	640	0.13
2548	1493	WHTRK	0004	1165	0.13
2549	2301	SPRDL	4822	1197	0.13
2550	2536	IRLBJ	3211	2614	0.13
2551	2767	HORNE	1981	1573	0.13
2552	1420	GRLND	1603	313	0.13
2553	2364	BLMGR	1902	180	0.13
2554	1646	EMPCT	0005	71	0.13
2555	920	BDFWD	8922	2170	0.13
2556	2216	COPEL	3052	1309	0.13
2557	699	ENTOH	0007	907	0.13
2558	1020	CNTRD	0001	2132	0.13
2559	2553	SHAMP	0003	1775	0.13
2560	1074	DALWT	2921	288	0.13
2561	32	MSLSW	0008	192	0.13
2562	2580	FRNKF	0003	497	0.12
2563	2285	FRMBG	1705	281	0.12
2564	N/A	HUTTO	2723	3621	0.12
2565	1142	BRNWD	1203	829	0.12
2566	2790	HLTOM	2461	849	0.12
2567	2832	BOWEN	3142	1193	0.12
2568	319	KLNCC	1703	4088	0.12
2569	1915	BDFWD	8932	1709	0.12
2570	2134	CTYVW	2211	1462	0.12
2571	2320	ALLEN	2410	2338	0.12
2572	2846	HNTNG	1302	41	0.12
2573	2696	PCOIT	1022	2125	0.12
2574	2064	ARLNG	1292	1563	0.12
2575	2396	EGFRD	0004	1864	0.12
2576	587	NMAIN	0262	416	0.12
2577	2488	MKNGB	5331	1451	0.12
2578	2636	PFFRD	3411	317	0.12
2579	2498	EDGCF	2231	868	0.12
2580	217	POYNR	1201	334	0.12
2581	396	LNCST	1603	1593	0.12
2582	1409	CLYVL	9312	1295	0.12
2583	2499	DGNST	0003	1161	0.12
2584	2043	CHROW	0002	110	0.12
2585	1482	NPKWY	0011	4165	0.12
2586	1089	WTHRF	2001	645	0.12
2587	2515	FHLSW	1311	1469	0.12

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2588	2868	RRSTH	1704	3261	0.12
2589	2808	PKRVL	1053	1069	0.12
2590	N/A	MDESA	4541	310	0.12
2591	2644	HKBRY	1102	1682	0.12
2592	1549	SHRSW	6631	1287	0.11
2593	1160	TYWST	2002	87	0.11
2594	2059	BLTLN	0001	681	0.11
2595	711	SMFLD	2323	620	0.11
2596	125	ENTOH	0005	1083	0.11
2597	1040	KERNS	2402	378	0.11
2598	2927	VGCRK	8031	1812	0.11
2599	442	ADMDS	6511	1050	0.11
2600	1611	MNWLL	1202	693	0.11
2601	1942	PFLGV	2003	2858	0.11
2602	1029	ALPHA	0008	1256	0.11
2603	2693	PCOIT	1007	849	0.11
2604	2805	VANAL	1201	603	0.11
2605	1724	PLKST	0005	1134	0.11
2606	1635	CRSSN	7911	834	0.11
2607	521	SFTLK	4011	46	0.11
2608	956	WEAST	0615	2153	0.11
2609	2146	ABBOT	1902	120	0.11
2610	2695	SCHRD	0003	360	0.11
2611	11	WEBBS	8634	1194	0.11
2612	243	CDHCR	2053	279	0.11
2613	2403	WFALS	0114	419	0.11
2614	2827	GNSVN	1401	28	0.11
2615	2681	PCOMM	3311	28	0.11
2616	2772	IRVNR	1510	430	0.11
2617	1984	GRDPR	0891	891	0.11
2618	2036	CMTSW	0927	565	0.11
2619	443	BRHLW	7651	1149	0.11
2620	1935	WTAUG	4633	1049	0.11
2621	623	MDDTN	4311	192	0.10
2622	1182	CRLFR	2155	1330	0.10
2623	2690	PFFRD	3421	858	0.10
2624	98	CRLFR	2159	1449	0.10
2625	2213	KLNTF	1801	1114	0.10
2626	1153	WGROB	8422	2694	0.10
2627	2056	GODRD	8112	1421	0.10
2628	2914	FRMBR	1807	849	0.10
2629	278	WITTS	1701	2021	0.10
2630	1053	CRLFR	2153	245	0.10
2631	124	LIGSW	1621	49	0.10
2632	2664	FRNKF	0004	1608	0.10
2633	1467	LFSTH	1405	216	0.10
2634	1126	SNYDR	1813	324	0.10
2635	2741	NMAIN	0282	1345	0.10

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2636	1491	LWRDR	0003	1783	0.10
2637	2660	LIGSW	1603	2517	0.10
2638	2759	RDRSE	2607	5011	0.10
2639	2530	BLMGR	1901	269	0.10
2640	2631	TRLNW	1201	1167	0.10
2641	2470	BKBNT	1811	679	0.10
2642	2587	ELMGV	3651	2238	0.10
2643	2027	CLBSN	8821	10	0.10
2644	606	PRNTH	1403	20	0.10
2645	454	TYWST	2013	916	0.10
2646	598	IRVRS	4413	1353	0.10
2647	991	RGLRW	0003	91	0.10
2648	2813	EDGCF	2221	862	0.10
2649	1087	CNEXP	0001	213	0.10
2650	972	WTAUG	4622	1005	0.10
2651	2905	RRSTH	1705	934	0.10
2652	2841	RWALL	1201	1301	0.10
2653	2352	RNDRK	1501	803	0.10
2654	1825	SMFLD	2392	1030	0.10
2655	2412	TYOMN	1411	307	0.10
2656	2780	MNSTR	1202	268	0.10
2657	1456	CRTLD	4722	3303	0.10
2658	1247	GRPVN	8211	135	0.10
2659	964	CRLTN	1404	104	0.10
2660	595	BARRY	1801	84	0.10
2661	1630	PRKRW	3392	1676	0.09
2662	1693	MDWCK	0006	887	0.09
2663	886	CNTRD	0003	1385	0.09
2664	2592	AMLIA	0008	106	0.09
2665	2495	LKHLD	0008	1464	0.09
2666	2448	PSHIL	1601	1416	0.09
2667	426	LFKHL	2101	128	0.09
2668	2838	VENSW	2603	32	0.09
2669	1003	IRLBJ	3212	3299	0.09
2670	1965	ENSSO	2003	503	0.09
2671	1051	KLBRG	0001	410	0.09
2672	1423	LWRDR	0004	804	0.09
2673	1059	MAYFD	5531	1185	0.09
2674	2666	BRNSO	1804	11	0.09
2675	2679	FRMBR	1808	684	0.09
2676	N/A	MLDR2	1603	505	0.09
2677	2233	LKMNT	0001	203	0.09
2678	2814	FRMBR	1806	147	0.09
2679	2485	SORCY	0004	603	0.09
2680	757	FROKS	0006	992	0.09
2681	1725	RSNHT	1131	2718	0.09
2682	2718	RSPCK	2106	348	0.09
2683	2788	DCATR	1204	654	0.09

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2684	1742	RWALS	1851	1554	0.09
2685	2761	CMPST	0003	212	0.08
2686	1973	WALNT	0004	1475	0.08
2687	2781	FARON	4021	285	0.08
2688	2692	MDWPK	9211	1274	0.08
2689	2821	BRHLW	7631	633	0.08
2690	1258	WSOTH	1018	562	0.08
2691	2738	BRHLW	7642	935	0.08
2692	2803	NPKWY	0009	1290	0.08
2693	2976	PSHIL	1605	135	0.08
2694	2771	WWEST	1221	37	0.08
2695	978	IRVNG	1404	1448	0.08
2696	1564	WDGWD	1552	314	0.08
2697	68	VLRYN	2951	2209	0.08
2698	2243	PCOIT	1002	674	0.08
2699	2834	GDNVL	1201	64	0.08
2700	2476	WDGWD	1561	1498	0.08
2701	1901	WALNT	0002	1227	0.08
2702	589	CURIE	7221	805	0.08
2703	2768	DGNST	0008	117	0.08
2704	836	ENTOH	0003	13	0.08
2705	2668	LSCOL	2142	13	0.08
2706	2986	WXOCF	1402	13	0.08
2707	528	WEAST	0626	291	0.08
2708	1032	RWDHV	1908	2306	0.08
2709	2569	GORMN	0411	545	0.08
2710	1873	DESHR	1202	1598	0.08
2711	1980	IRVND	1206	107	0.07
2712	2635	HKHTS	1608	1312	0.07
2713	338	LKHLN	0006	737	0.07
2714	2072	BRNSO	1808	792	0.07
2715	1992	ARMST	0001	282	0.07
2716	2776	ARLNG	1212	122	0.07
2717	2770	ALPHA	0010	517	0.07
2718	2591	MESTE	1208	995	0.07
2719	1093	WTHRF	2002	1718	0.07
2720	385	FARON	4031	1142	0.07
2721	2314	MURPH	2753	1063	0.07
2722	2884	KLELM	2202	2378	0.07
2723	465	WWEST	1216	250	0.07
2724	1139	ROLTR	2913	1727	0.07
2725	856	CRNRD	0007	754	0.07
2726	2509	LOMAL	0002	518	0.07
2727	2810	RKCRK	6111	2708	0.07
2728	2672	LVBRD	0005	1364	0.07
2729	873	ATNRN	3411	3007	0.07
2730	2907	SCHRD	0006	488	0.07
2731	386	FRNKF	0005	1086	0.07

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2732	842	SORCY	0003	843	0.07
2733	2792	GLNHV	3953	1631	0.07
2734	1042	HURST	1841	1001	0.07
2735	2698	EULSO	9121	118	0.07
2736	1804	TMPNW	1101	2633	0.07
2737	1826	CLBWS	8121	268	0.07
2738	1132	SHNRW	1610	434	0.07
2739	296	DENDR	0008	90	0.07
2740	495	KRGRV	2401	15	0.07
2741	2691	PJPTR	3212	30	0.07
2742	2835	HMPHL	2792	456	0.07
2743	1692	DALRK	1309	876	0.07
2744	108	SCSES	1201	281	0.06
2745	360	VLRYN	2955	4545	0.06
2746	2504	REGST	0003	968	0.06
2747	866	FRSTN	1604	334	0.06
2748	802	DAVIS	3723	350	0.06
2749	2479	MKNNY	1201	1311	0.06
2750	2793	DESPR	1404	642	0.06
2751	2345	PRSTN	0005	1191	0.06
2752	2919	MDWPK	9221	769	0.06
2753	2824	TMPNW	1106	1001	0.06
2754	2642	BLNKT	0701	280	0.06
2755	N/A	MLDR2	1601	364	0.06
2756	1785	WHTRK	0008	1514	0.06
2757	2622	PALRD	2207	1126	0.06
2758	2895	HMPHL	2752	295	0.06
2759	2619	SANSM	3921	1381	0.06
2760	974	RCLNS	1408	107	0.06
2761	1918	RRNES	2402	3859	0.06
2762	2860	GRHWY	5521	895	0.06
2763	2941	CRLTR	2006	54	0.06
2764	407	CURIE	7231	1080	0.06
2765	13	CHROW	0004	200	0.06
2766	2248	LOMAL	0012	714	0.05
2767	2769	TMNTH	1604	55	0.05
2768	2762	WGROB	8412	3894	0.05
2769	1169	STERT	2702	19	0.05
2770	322	WATSN	5352	1900	0.05
2771	2561	MURPH	2756	3603	0.05
2772	2380	ARLNG	1222	97	0.05
2773	101	IRLBJ	3231	2504	0.05
2774	2270	FRMNT	0008	1052	0.05
2775	2449	KLELM	2204	3070	0.05
2776	2700	PLANO	1106	492	0.05
2777	904	GSTHW	1622	20	0.05
2778	2956	GSTHW	1672	40	0.05
2779	1064	DNINR	1401	81	0.05

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2780	941	REAST	1501	304	0.05
2781	1262	PFLGV	2007	3994	0.05
2782	1410	MRSES	3016	41	0.05
2783	2763	IRVHF	2303	86	0.05
2784	2481	HMPHL	2713	130	0.05
2785	2332	PSHIL	1607	458	0.05
2786	527	CLLVL	0001	503	0.05
2787	1318	CLBNR	1401	22	0.05
2788	539	PCOIT	1004	735	0.04
2789	2863	FRMBG	1708	45	0.04
2790	2649	BNMNW	1101	204	0.04
2791	2807	RGFTW	6822	23	0.04
2792	2685	ROANW	9511	1459	0.04
2793	356	MKNSW	2604	2101	0.04
2794	10	GVODS	3052	1324	0.04
2795	158	WFALS	0163	361	0.04
2796	1614	ARMST	0011	900	0.04
2797	2508	LOMAL	0007	151	0.04
2798	2407	FRNKF	0001	964	0.04
2799	2496	COMRC	1204	587	0.04
2800	2677	NPKWY	0012	2231	0.04
2801	516	HUTCH	1505	26	0.04
2802	2686	MESFR	2104	156	0.04
2803	2851	RCHHL	0394	237	0.04
2804	462	CLLVL	0004	53	0.04
2805	1037	AMLIA	0006	80	0.04
2806	2577	DALWT	2972	240	0.04
2807	171	RGLRW	0002	215	0.04
2808	2305	MCGHR	2004	27	0.04
2809	2176	MSTLT	1032	27	0.04
2810	1131	PALMR	2201	54	0.04
2811	2983	WALST	0007	27	0.04
2812	2711	HKBRY	1103	244	0.04
2813	N/A	PRMED	4404	1154	0.04
2814	2386	HURST	1852	1508	0.04
2815	2328	RNKSW	5412	28	0.04
2816	2883	WWEST	1220	198	0.04
2817	N/A	CMTSW	0946	865	0.03
2818	2878	COPER	0401	116	0.03
2819	2969	PARIS	1205	29	0.03
2820	2981	SMBMG	1701	29	0.03
2821	2945	EULSO	9141	59	0.03
2822	2688	LWSNR	2211	1421	0.03
2823	1664	GODRD	8151	801	0.03
2824	173	CNEXP	0003	1396	0.03
2825	2854	HKBRY	1104	121	0.03
2826	1222	CRSGL	1303	91	0.03
2827	1263	NPKWY	0008	882	0.03

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2828	2089	WWEST	1218	1015	0.03
2829	416	WEBBS	8633	2469	0.03
2830	2876	PROAD	0009	124	0.03
2831	2881	SMFLD	2362	63	0.03
2832	2464	FROKS	0008	1514	0.03
2833	2180	ALPHA	0016	1817	0.03
2834	2867	EMPCT	0002	98	0.03
2835	1021	BRTRD	7322	640	0.03
2836	1054	STERT	2701	34	0.03
2837	911	BKWST	0006	804	0.03
2838	2897	COTRD	0004	105	0.03
2839	2840	JUDCT	0008	140	0.03
2840	N/A	MDLNE	0132	35	0.03
2841	203	CHROW	0005	179	0.03
2842	405	MKNNY	1204	36	0.03
2843	1448	CRNRD	0005	361	0.03
2844	2360	CKRHL	0007	73	0.03
2845	905	WHTRK	0003	1276	0.03
2846	2855	CMPST	0001	454	0.03
2847	2964	LSCOL	2135	608	0.03
2848	2874	DALWT	2952	656	0.03
2849	2557	FRNKF	0006	1726	0.03
2850	1280	RNDRK	1509	1439	0.03
2851	2701	ROANW	9522	42	0.02
2852	2880	SHDYG	7812	126	0.02
2853	76	KYSTN	1011	89	0.02
2854	954	FRMBR	1802	1117	0.02
2855	1562	RSKMN	3078	135	0.02
2856	2864	PJPTR	3221	46	0.02
2857	2894	HORNE	1923	1572	0.02
2858	2953	GSTHW	1613	93	0.02
2859	2902	TMSTH	1405	519	0.02
2860	2370	HMPHL	2723	48	0.02
2861	2850	SHAMP	0002	1746	0.02
2862	530	DAVIS	3743	200	0.02
2863	2031	COMRC	1201	1018	0.02
2864	2885	LMBLN	0001	2042	0.02
2865	2362	LAVON	1453	949	0.02
2866	2974	PLANO	1108	491	0.02
2867	2647	DESHR	1208	439	0.02
2868	2926	FRMBR	1853	55	0.02
2869	2645	HMPHL	2733	116	0.02
2870	2274	PSHIL	1606	1392	0.02
2871	2862	DALWT	2941	309	0.02
2872	2071	FRMBG	1706	62	0.02
2873	1566	PROAD	0001	126	0.02
2874	2459	ADISN	1603	192	0.02
2875	1004	PLGRV	0004	384	0.02

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2876	2372	MSLSW	0003	193	0.02
2877	145	HKBRY	1109	129	0.02
2878	1017	RSNHT	1152	1039	0.02
2879	2798	SORCY	0002	66	0.02
2880	1953	HMPHL	2742	466	0.02
2881	2920	MSTLT	1042	500	0.01
2882	1434	WHTRK	0006	1311	0.01
2883	2307	STNVL	1204	828	0.01
2884	2650	DGNST	0005	154	0.01
2885	908	WALNT	0001	1468	0.01
2886	2748	DESPR	1401	1700	0.01
2887	1760	TYOMN	1402	1615	0.01
2888	2836	BRYAN	0007	244	0.01
2889	2901	ROBNW	1501	849	0.01
2890	1070	WFALS	0143	171	0.01
2891	809	PROAD	0008	1206	0.01
2892	N/A	DNINR	1404	177	0.01
2893	2218	VLYRN	2957	499	0.01
2894	2980	RSPCK	2105	313	0.01
2895	2899	FHLSW	1382	108	0.01
2896	2857	DALWT	2992	332	0.01
2897	2467	ADISN	1602	226	0.01
2898	2654	COMSO	1403	463	0.01
2899	172	BAYLC	1201	116	0.01
2900	1452	LMBLN	0008	119	0.01
2901	979	WEAST	0628	241	0.01
2902	N/A	TIODE	9622	974	0.01
2903	2915	DGNST	0001	270	0.01
2904	1068	ELKTN	2503	839	0.01
2905	431	MAPLE	0007	143	0.01
2906	1014	LOMAL	0004	145	0.01
2907	2908	RECCR	0005	157	0.01
2908	436	WALNT	0008	873	0.01
2909	2966	LSCOL	2148	1572	0.01
2910	487	WEAST	0627	205	0.00
2911	2747	SHDYG	7832	1854	0.00
2912	2856	CNEXP	0008	414	0.00
2913	2910	FLMSO	3711	1661	0.00
2914	2777	VGCRK	8021	211	0.00
2915	2870	BRYAN	0002	213	0.00
2916	2904	HKBRY	1113	427	0.00
2917	2626	TYBLR	2806	214	0.00
2918	2614	JUDCT	0004	216	0.00
2919	1342	CNEXP	0005	463	0.00
2920	2921	WMRNR	0003	799	0.00
2921	2566	LWSNR	2212	1410	0.00
2922	2922	PWEST	1306	286	0.00
2923	2411	KNLTR	0009	861	0.00

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2924	526	CNEXP	0002	880	0.00
2925	2605	TYLGE	1314	946	0.00
2926	2828	CURIE	7222	970	0.00
2927	1104	COTRD	0008	1352	0.00
2928	2091	TMPNW	1103	682	0.00
2929	1024	JUDCT	0003	1775	0.00
2930	2893	ARMST	0003	366	0.00
2931	2753	INAIR	1414	766	0.00
2932	420	CKRHL	0004	424	0.00
2933	2290	MDWCK	0008	888	0.00
2934	1058	BDFWD	8911	937	0.00
2935	1300	SCHRD	0004	1924	0.00
2936	2912	WEBBS	8613	634	0.00
2937	2923	FRMNT	0007	703	0.00
2938	1080	CURIE	7241	713	0.00
2939	393	MAPLE	0002	910	0.00
2940	2787	IRLBJ	3222	1033	0.00
2941	2934	ALLEN	2405	27	0.00
2942	497	ALPHA	0004	22	0.00
2943	N/A	ALPHA	0012	14	0.00
2944	429	AMLIA	0005	10	0.00
2945	2833	AMLIA	0007	93	0.00
2946	865	ANARN	1911	19	0.00
2947	2936	ARMST	0008	246	0.00
2948	1618	ARPCM	4169	11	0.00
2949	N/A	BLMND	3223	230	0.00
2950	2896	BRNAV	0774	205	0.00
2951	2520	CHROW	0006	82	0.00
2952	2939	COMRC	1202	49	0.00
2953	2940	COTRD	0001	11	0.00
2954	2001	COTRD	0003	109	0.00
2955	2891	CPLSO	4311	95	0.00
2956	1303	CURIE	7212	20	0.00
2957	398	DALLW	0002	62	0.00
2958	N/A	DFWSE	2710	72	0.00
2959	N/A	DFWSE	2713	17	0.00
2960	209	DFWSW	2202	57	0.00
2961	430	DFWSW	2204	24	0.00
2962	2946	EXPKY	8112	11	0.00
2963	2794	EXPKY	8141	23	0.00
2964	N/A	FBRIW	1901	305	0.00
2965	617	FRMBG	1702	62	0.00
2966	2947	FRMBG	1703	31	0.00
2967	1060	FRMBG	1704	37	0.00
2968	2948	FRMNT	0006	12	0.00
2969	N/A	GLSCN	6221	20	0.00
2970	2954	GSTHW	1651	13	0.00
2971	2955	GSTHW	1662	13	0.00

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2972	2957	INAIR	1421	18	0.00
2973	2848	INAIR	1442	114	0.00
2974	2962	KNLTR	0007	12	0.00
2975	2724	LKWOD	7421	43	0.00
2976	2391	LUFKN	1204	33	0.00
2977	2491	MAPLE	0008	214	0.00
2978	1098	MDDTN	4322	26	0.00
2979	2909	NPKWY	0007	180	0.00
2980	N/A	PAULN	2503	115	0.00
2981	2971	PJPTR	3231	25	0.00
2982	2973	PJPTR	3242	76	0.00
2983	1109	PROAD	0006	133	0.00
2984	2977	PTENN	2356	14	0.00
2985	N/A	PWEST	1305	15	0.00
2986	2978	REGST	0007	10	0.00
2987	2744	RNKSW	5413	37	0.00
2988	1800	RRWES	1603	11	0.00
2989	N/A	RRWES	1623	716	0.00
2990	2526	RSPCK	2133	778	0.00
2991	2727	RVRFT	0001	28	0.00
2992	N/A	SCHRD	0002	297	0.00
2993	1795	SCHRD	0008	74	0.00
2994	2786	SHSTH	1302	20	0.00
2995	1106	STERT	2703	333	0.00
2996	880	STERT	2704	10	0.00
2997	2985	WMMMR	2704	18	0.00
2998	2720	WWEST	1217	102	0.00

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

Total Number of Feeders

With 10 or more Customers

2998

Add or Delete Rows as Necessary

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1	76	SBEAN	6011	182	2898.06
2	498	KNOTT	5221	60	2451.96
3	1	CWIND	6311	27	2451.05
4	56	BRNSY	1211	135	2000.81
5	1078	NWARD	3511	63	1844.04
6	73	COYAN	6321	311	1772.45
7	20	DHIDE	2821	116	1553.11
8	6	DHIDE	2811	105	1537.57
9	98	RYLTY	1431	76	1496.86
10	575	LOVNG	2521	44	1475.27
11	129	MASON	3421	53	1475.13
12	27	CRNES	2711	143	1470.98
13	131	WINKS	0531	48	1467.70
14	45	MIDWY	0621	141	1396.44
15	16	ELMAR	3211	134	1361.49
16	8	BLKRV	8311	48	1348.20
17	46	EMMAS	4022	60	1344.71
18	25	MSTNG	2611	145	1235.99
19	411	WICKT	0431	18	1220.75
20	7	RYLTY	1411	126	1212.16
21	15	SNDHL	3821	61	1131.23
22	11	MDFRM	2111	63	1099.21
23	104	SMOUR	0721	18	1018.49
24	209	EMMAS	4012	86	1004.88
25	53	CRNAT	4121	64	978.08
26	2952	GSMTH	1731	49	974.85
27	57	GLSCK	2411	240	944.72
28	48	NCWDN	1121	59	904.60
29	1120	CHALK	0951	73	858.25
30	2	BARNW	4511	72	838.93
31	38	MSTNG	2621	72	810.01
32	69	UPTON	0721	121	803.18
33	132	WINKS	0521	51	800.41
34	466	MNFLD	2672	2275	789.04
35	216	GLSCN	6211	119	785.41
36	103	CHYNE	9111	30	769.92
37	578	MIDWY	0612	474	761.18
38	1334	HNTNG	1306	1085	743.73
39	26	MASON	3431	142	742.33
40	207	SCURY	1921	101	736.62
41	358	CNANG	1806	2458	734.11
42	334	COHMA	1111	730	722.25
43	594	WXHCH	1205	972	711.31

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
44	164	ESKSW	2711	107	711.04
45	766	ANDRD	0921	91	708.73
46	9	PLDAV	4231	73	703.17
47	N/A	STANT	1313	162	700.11
48	1212	FRNKS	1201	385	699.91
49	49	HOWRD	3921	74	693.02
50	2174	PGSTH	7011	43	684.18
51	149	ELMAR	3222	87	683.71
52	1041	SWTWR	1341	246	678.01
53	434	BKWWF	0521	463	676.30
54	2004	NCDCH	1203	1825	672.03
55	548	MKNSW	2601	3198	665.31
56	125	LMESA	2833	22	665.17
57	283	PMBRK	1821	73	642.45
58	72	CLCTY	1011	1056	638.54
59	17	JDKNS	0821	38	634.35
60	1715	FSCRK	6732	4208	632.54
61	894	RSPCK	2131	58	624.65
62	N/A	GASLD	4211	101	623.44
63	2130	PLKST	0001	786	610.59
64	172	PLDAV	4211	57	603.61
65	81	TYLGE	1311	809	593.44
66	402	UPTON	0711	170	586.58
67	344	MDLNE	0161	992	581.87
68	224	DWSON	3121	28	571.64
69	2923	RDRSE	2605	736	567.29
70	4	BARNW	4521	101	544.40
71	203	PLDAV	4221	219	542.12
72	728	PEGAS	2311	121	538.45
73	463	HNRTA	0321	850	537.77
74	1928	WHITE	3521	1122	535.99
75	151	WELCH	4911	22	530.80
76	508	FARON	4011	642	520.47
77	287	GYVLM	8611	14	514.53
78	2844	PRHLL	2402	59	509.64
79	1434	NCRST	2204	443	506.60
80	1127	GRDNC	1211	49	504.53
81	10	PGSTH	7021	135	504.20
82	1236	ELCTR	1211	279	500.42
83	266	BOWIE	0621	11	497.69
84	2207	OKCLS	0006	687	496.62
85	19	RYLTY	1421	453	494.84
86	378	SCURY	1911	172	491.17
87	1269	BSPRW	2532	1604	481.20
88	1013	TMNTH	1606	232	480.96
89	24	GSMTH	1721	47	480.81
90	589	GRSMN	3027	362	476.08
91	913	MCGRG	1902	491	473.77

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
92	139	ACRLY	1721	60	472.21
93	1502	HNRTA	0311	1044	471.30
94	77	MEXIA	4008	690	470.51
95	152	BRNSY	1221	79	469.49
96	1270	WCITY	2402	684	468.68
97	157	ALVRD	1501	1172	460.29
98	661	GRSMN	3071	333	458.75
99	294	STHRL	0004	1278	455.40
100	627	LAVON	1401	1714	450.62
101	1439	FRNKS	4168	968	449.85
102	50	FORSN	5632	237	447.59
103	497	GSMTH	1742	37	447.33
104	108	DGLAS	2401	754	447.19
105	1754	CLKVL	1203	633	446.21
106	1863	DENAV	0683	884	445.92
107	14	CHICC	1701	55	444.84
108	558	TYEST	1506	479	441.92
109	36	BLSRA	1601	1404	440.86
110	911	FROKS	0004	118	439.47
111	171	AMMFG	5611	813	433.85
112	2664	BRIRV	6921	2448	431.05
113	95	ARPMN	4149	313	427.47
114	162	MDLNE	0112	363	426.82
115	65	KNAPP	4021	31	422.94
116	819	FORSN	5642	42	421.79
117	18	VANSB	1501	797	416.84
118	1178	KMASB	1721	105	412.98
119	1817	FORSN	5611	12	412.92
120	941	RTHGB	1411	680	411.19
121	23	ELMAR	3212	38	410.34
122	3	MASON	3411	30	404.31
123	379	BRIRV	6922	3406	403.34
124	217	FRFWS	3004	822	394.99
125	40	TYLNE	1605	1181	392.41
126	2533	MCGRG	0776	222	387.96
127	454	NHNSW	0006	946	384.42
128	2639	MCHSN	1201	244	382.85
129	1590	CRANE	0311	791	382.77
130	631	LKTMS	2412	12	381.42
131	243	CRLCC	2703	635	380.43
132	873	SPRTN	1801	1843	379.23
133	1132	MRDCK	0004	824	378.78
134	929	FRNKF	0007	1172	378.14
135	1206	FKLCY	5121	105	377.99
136	1293	TYLNE	1607	782	377.55
137	2216	SHAMP	0004	1142	376.81
138	88	GSMTH	1732	45	374.74
139	2455	SNYDR	1823	1472	370.33

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
140	1500	BRHLW	7622	1130	367.63
141	1450	MEXIA	3016	279	364.58
142	359	NCDSW	3811	1469	363.61
143	1894	MKNGB	5311	487	362.31
144	1174	BLMND	3241	231	357.56
145	599	CNANG	1804	192	357.34
146	468	MDFRM	2131	11	356.63
147	236	CHICW	1302	202	356.22
148	99	TXHRV	1611	169	355.57
149	5	LOVNG	2511	51	354.92
150	1243	GRDNE	9211	439	354.23
151	665	ADMDS	6532	466	350.40
152	293	TIODE	9632	413	349.23
153	826	NCDCH	1205	1084	348.13
154	2984	WALST	0008	11	348.12
155	234	NCNTH	1806	868	345.73
156	553	MDLNE	0131	2564	344.23
157	21	NOLNW	2111	23	340.13
158	2156	RGLRW	0001	34	337.64
159	1807	BNBRK	4122	2743	334.53
160	320	FHLSW	1321	414	329.34
161	2286	MDWCK	0004	1750	326.14
162	2012	MSHLN	0007	724	324.55
163	289	CRLUD	1307	290	324.23
164	141	MDLNW	1531	1754	322.97
165	2893	BRKTN	1202	120	321.30
166	1327	PRKRW	3321	163	317.65
167	86	LKTMS	2411	95	314.25
168	510	NECSP	2401	564	313.45
169	331	CGDEL	5411	28	311.34
170	390	IRVNE	1305	236	310.22
171	492	CRISP	1501	916	309.55
172	495	LAVON	1451	1020	308.79
173	134	BAKKE	6922	1458	308.54
174	467	TRIRA	6222	998	307.64
175	729	TNSCL	1104	198	307.07
176	740	WOVER	6142	1505	306.80
177	279	MEXIA	4023	616	306.72
178	1023	PRNTH	1405	986	306.13
179	194	TYLNE	1624	259	304.60
180	188	NCDCH	1201	781	304.40
181	1001	BSPSW	0812	1076	304.23
182	2540	SNYDR	1822	1616	302.76
183	329	NCSTH	1503	916	302.67
184	2938	COLDG	4048	10	300.35
185	2785	WATSN	5372	1339	297.64
186	1563	BRNAV	0762	2393	297.21
187	837	PRNTH	1406	1021	297.12

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
188	864	MNWLL	1206	1105	296.46
189	453	CNI45	1202	820	296.27
190	1125	FERIS	1103	988	295.52
191	704	DCATR	1201	1258	294.35
192	2209	DNISN	1202	819	293.99
193	2440	WNDRCR	0221	572	293.82
194	2203	PKRVL	1051	4720	293.26
195	709	ENNIS	1902	1260	292.95
196	569	AYERS	4421	1481	292.64
197	28	ANDRD	0931	191	291.86
198	645	PLKST	0007	1784	291.69
199	1743	PAYSW	1205	724	291.26
200	621	ENSSO	2004	1202	291.00
201	730	CHRNO	1201	517	290.84
202	214	RYSSW	2803	2278	290.26
203	1191	AMMFG	5621	553	290.24
204	472	RSNHT	1162	1514	290.02
205	954	IRVND	1205	218	288.12
206	280	BLVUE	1111	358	287.64
207	526	MNWLE	1702	1287	286.34
208	1352	ROGRS	1301	768	285.69
209	1158	SMFLD	2381	849	285.68
210	364	JKSES	3029	1183	285.11
211	2310	SNYDR	1852	1347	284.39
212	2678	HMTRD	0003	428	284.27
213	1278	OTTOJ	3060	17	282.98
214	2227	WOVER	6122	833	282.63
215	791	CLKVL	1201	431	282.25
216	219	ODESA	0212	885	280.61
217	400	WLSPT	1001	1956	279.82
218	105	WBROK	3011	199	279.67
219	2810	TRLSW	2401	22	279.67
220	1921	RDLML	2552	281	277.63
221	155	WXHNV	2901	179	277.30
222	2116	CKRHL	0001	415	276.33
223	389	WDGWD	1531	1516	275.77
224	185	CNI45	2401	608	274.99
225	902	COPEL	3055	2178	274.57
226	447	CNSES	3056	2646	274.16
227	1314	MABNK	2401	2132	273.71
228	2159	KLNPS	1105	1556	273.24
229	2120	CRLUD	1303	616	271.88
230	1418	MSLSW	0005	1023	271.78
231	1275	MNWLL	1207	2096	271.74
232	2556	NMAIN	0241	712	271.07
233	2786	CRLUD	1306	26	269.96
234	1004	RYSSW	2804	2188	269.35
235	52	NCWDN	1111	801	269.03

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
236	2211	MYPRL	1801	158	267.43
237	2112	HSKAV	0004	1315	267.21
238	2378	GLNHV	3992	1158	266.54
239	1491	ATHNS	1201	971	266.51
240	637	KLRPR	9011	2738	265.62
241	1865	BRKRG	0223	286	264.87
242	1882	ODNTH	2033	676	264.10
243	388	BRKNR	1211	116	263.25
244	1533	GRPTT	9911	697	262.73
245	1932	SBEND	0611	171	262.67
246	127	ECTHP	4911	1195	260.49
247	N/A	PRMED	4402	867	259.40
248	2376	ARCTY	1321	890	258.84
249	2151	CRLTN	1403	211	258.36
250	938	TEGMN	3038	1664	258.35
251	2218	AIRPK	8411	782	257.56
252	241	TRIRA	6221	634	257.09
253	597	CLMET	0003	909	256.65
254	1168	WBOSE	1102	347	255.69
255	1496	DALWT	2931	1563	254.98
256	789	CLKVL	1202	1265	254.82
257	2422	NCRST	2201	1934	253.61
258	536	HKBRY	1105	185	252.87
259	2425	WND CR	0241	708	252.45
260	1453	KNLTR	0011	1852	252.17
261	718	PARIS	1206	1024	252.00
262	2712	KLELM	2201	2428	251.66
263	94	TSLVL	4008	2029	251.66
264	31	COYAN	6311	105	251.14
265	109	WICKT	0411	250	250.27
266	962	CLCTY	1021	680	249.26
267	324	RDLML	2571	365	248.27
268	1306	EGFRD	0005	738	247.91
269	370	PLSTN	1004	1576	247.49
270	422	LTFRD	3011	945	246.10
271	982	INDIA	2501	376	246.06
272	2117	OAKHL	3082	1449	245.00
273	153	CRSCN	1206	1518	244.78
274	2194	RWDHV	1902	967	244.46
275	2069	STAUG	0008	2057	244.42
276	1781	LVOAK	1601	863	243.82
277	1109	WOVER	6111	1329	243.77
278	215	CHRNO	1203	419	243.59
279	1375	PLKST	0002	837	243.22
280	218	LFEST	1905	1791	242.40
281	1252	JNKNS	0005	552	239.94
282	1230	BRHLW	7612	710	239.09
283	1827	BLKST	1781	1928	239.00

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
284	846	MRSES	4005	751	238.10
285	1037	SUNNY	2303	590	237.47
286	855	KMASB	1711	304	237.24
287	1056	PLGRV	0003	594	237.22
288	2366	WMRLD	0006	593	237.15
289	1059	CNEXP	0004	912	236.89
290	2750	CLCRK	1011	204	236.85
291	1153	LNCST	1602	1870	235.56
292	2382	BRKRG	0242	24	235.34
293	2001	BKBNT	1821	1148	235.25
294	2920	ARMST	0006	613	235.17
295	319	HNTNG	1307	1499	234.95
296	2504	BRGPR	1101	627	234.78
297	2483	MRTNS	1502	508	233.08
298	1566	LORAN	9711	391	233.01
299	226	TYEST	1501	1757	232.78
300	2721	PAYSW	1223	115	232.52
301	591	LMBLN	0005	686	232.19
302	291	RCLNS	1406	527	232.17
303	2032	ALDTU	9411	2505	231.99
304	2514	BSPSW	0832	406	231.75
305	1228	ODESA	0242	640	231.39
306	2088	ADISN	1605	1106	229.85
307	895	GVFTW	1802	903	229.40
308	598	HURST	1872	2104	228.97
309	44	TRPMN	4001	784	228.94
310	2541	BLMND	3282	91	228.76
311	2889	BNDRA	0013	146	228.61
312	1776	ANDNR	2231	1086	228.02
313	1213	PTENN	2353	936	228.01
314	473	FLRTN	3721	75	227.71
315	51	HOWRD	3911	38	226.69
316	1296	EDDYS	0425	411	226.11
317	2373	DEALY	0003	1773	225.89
318	971	MDLNW	1522	1180	224.96
319	67	OAKCK	2211	45	224.78
320	198	LUFKN	1208	1786	224.41
321	253	LKMNT	0002	987	222.94
322	2022	NCSTH	1504	63	222.58
323	1568	LAVON	1406	1476	222.05
324	54	KYSTN	1031	26	221.42
325	2233	LMBLN	0003	181	221.21
326	165	MSLMN	4007	134	220.92
327	1955	WOVER	6131	2113	220.66
328	1009	CAMRN	1203	1220	220.49
329	739	ANDNR	2252	241	219.58
330	58	TYLNE	1613	464	218.71
331	229	REYST	4051	1076	218.10

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
332	1964	COMRC	1203	682	217.84
333	1747	ALNTH	2854	690	217.65
334	2657	SANSM	3911	1479	217.26
335	142	RICES	0208	715	217.18
336	2524	FORSW	2053	3210	215.67
337	1485	HLSES	0561	1825	214.42
338	341	JKWST	4033	748	212.98
339	2544	ATNRN	3412	5640	212.61
340	441	CRLTN	1454	347	212.44
341	1088	IRVNE	1304	630	212.03
342	96	PRNTH	1404	1474	211.45
343	439	TRNTY	7521	1165	211.38
344	918	WHITE	3531	1922	211.01
345	500	WSTHL	3621	4999	210.39
346	328	VALVW	1802	431	209.99
347	1043	OAKHL	3052	765	209.57
348	1014	KNEDL	6312	3080	208.20
349	1186	REAST	1502	1323	208.05
350	173	BNBOR	1203	310	205.83
351	1420	BSPSW	0851	1426	205.81
352	347	CRLTN	1453	297	205.41
353	1720	LMESA	1522	1334	204.64
354	251	WMRLD	0007	1696	204.21
355	841	MKNSW	1602	550	203.04
356	848	RHOME	2401	1183	202.64
357	2800	ALNSW	2651	2054	202.40
358	213	EDGWD	1101	629	201.28
359	2319	ROLTR	2921	2599	201.27
360	534	MDLNW	1582	2061	201.23
361	273	TYEST	1508	631	200.19
362	455	LFEST	1902	1044	199.92
363	374	LWRDR	0001	1166	199.69
364	2914	MDAIR	2912	851	199.28
365	2958	JNKNS	0002	197	199.14
366	355	ARCTY	1311	431	199.04
367	256	BNDRA	0009	718	198.82
368	576	CRLJL	1505	925	198.66
369	354	WNDCH	0252	912	198.49
370	1531	LUFKN	1207	47	198.48
371	725	EMPCT	0008	37	198.30
372	1949	MESQN	1505	1429	198.18
373	871	HMTRD	0002	2178	197.93
374	179	PMBRK	1811	24	197.72
375	680	EZACH	0001	985	197.54
376	1066	OAKHL	3011	2252	197.37
377	92	QNLAN	1201	850	197.16
378	559	CUMBY	1201	750	196.36
379	2163	CHSPG	2401	3722	196.33

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
380	610	DNCNV	1902	1078	195.95
381	2021	SCYEN	0004	1234	195.33
382	1130	FSTVW	0003	1929	195.26
383	2148	PLANO	1104	991	194.96
384	654	SGOVL	1403	2376	194.90
385	2278	IRASB	3211	277	194.82
386	1423	HNTNG	1305	1176	194.78
387	78	STANT	1311	1525	194.58
388	115	TXHRV	1621	89	194.39
389	872	DAVIS	3782	983	194.32
390	257	TYSTH	1203	430	193.45
391	1535	AZLES	2121	2882	192.29
392	281	MNHNS	1912	1899	191.43
393	822	PLSTN	1003	1454	191.07
394	2228	INAIR	1413	2418	190.62
395	2853	SIKES	2422	1066	190.60
396	383	JEWET	1202	759	190.54
397	649	KYSTN	1021	43	190.47
398	2898	DENDR	0009	63	190.32
399	1299	GRDPR	0842	1378	190.03
400	123	JDKNS	0822	57	189.81
401	1518	LGVST	8522	354	189.53
402	780	LGVST	8511	754	188.62
403	1655	TRLST	1203	682	188.56
404	274	AZLES	2112	1718	188.40
405	363	HUTCH	1501	974	188.25
406	70	CSHNG	1201	918	187.82
407	211	GODLY	1601	662	187.55
408	298	CRKET	2402	1672	186.82
409	205	FLRTN	3711	100	186.78
410	889	FRSTN	1602	1248	186.58
411	1604	REAST	1505	999	186.40
412	1668	TYLER	1004	184	186.36
413	174	WINKS	0511	636	186.01
414	193	CRLTN	1452	1158	185.74
415	1115	RWALL	1203	3587	185.37
416	272	ELKTN	2508	1419	185.26
417	910	DESPR	1405	931	184.65
418	1154	GSTHW	1631	2205	184.63
419	394	LUFKN	1203	741	184.52
420	2345	WALST	0006	10	184.35
421	143	MDAIR	2911	412	184.01
422	2835	CRKET	1201	323	183.67
423	282	GLNHV	3942	1363	183.06
424	2922	JNKNS	0006	525	182.95
425	865	SLAKE	8321	4376	182.85
426	2586	FLMSO	3714	1231	181.97
427	1030	WMRLD	0004	1584	181.20

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
428	2336	ALNTH	2853	2993	180.85
429	2431	PARIS	1203	953	180.38
430	1011	KMPSO	2400	931	180.00
431	528	FARON	4062	1149	180.00
432	735	PRFTW	4222	3314	179.28
433	1969	PRSTN	0004	674	179.17
434	1674	NAVCO	0001	23	178.98
435	1971	GVGLF	9601	50	178.95
436	1104	JNKNS	0004	129	178.78
437	1495	WRBND	2321	1545	178.27
438	2070	MSLSW	0001	846	178.16
439	588	FRMNT	0004	2377	178.04
440	1241	FHLSW	1332	309	177.89
441	816	MDLNW	1573	1050	177.79
442	1853	BNTDR	0004	1844	177.60
443	1791	CPRCV	1404	1616	177.20
444	2763	REAST	1507	114	176.47
445	350	CHYNE	9121	91	176.38
446	884	ALNTH	2832	974	175.77
447	1517	CNTRY	2833	2366	175.62
448	2748	TMNTH	1603	138	175.56
449	715	ENTOH	0001	846	175.37
450	930	MESQT	1302	654	175.01
451	847	LNGLK	1602	637	174.60
452	137	MRKLY	0811	121	174.11
453	1690	HLSES	0511	1809	173.98
454	2702	OKLND	0003	1352	173.20
455	204	BSPSW	0822	395	173.12
456	113	FKLCY	5111	72	172.93
457	862	JREST	2102	1051	172.66
458	1959	FARON	4041	1032	172.34
459	436	FRFWS	3001	1810	171.65
460	481	RCHLD	2101	613	171.40
461	541	NCRST	2203	987	171.22
462	2244	WATSN	5342	2032	170.72
463	1433	HURST	1811	1242	170.25
464	794	PFLGV	2004	3937	170.09
465	1802	KNLTR	0003	624	169.91
466	813	WMRLD	0008	1595	169.83
467	852	RDLML	2581	1238	169.58
468	1387	TYRSW	1701	2410	169.41
469	2176	FSHSW	2111	315	169.18
470	1552	IRVND	1204	1353	168.24
471	703	NCNTH	1801	2532	168.10
472	1021	IRVHF	2305	1455	167.55
473	814	EULES	8724	2400	167.33
474	1555	COHMA	1132	63	167.15
475	13	VESTS	3111	54	167.02

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
476	1726	PRKWY	1521	2322	166.95
477	981	JREST	2101	1354	166.81
478	2204	SALSW	3004	1377	166.63
479	210	MNRVA	1301	743	166.49
480	595	OTTOJ	3059	1092	166.36
481	851	LKMNT	0004	2183	166.34
482	112	SSPNE	1403	1109	166.13
483	2562	CTYVW	2212	145	166.11
484	1645	GNSVE	1603	1687	165.68
485	199	HDWLK	3003	971	165.50
486	2139	BKBNT	1842	555	165.49
487	448	ROSCO	2921	239	165.13
488	786	REYST	4118	737	164.83
489	1400	OKCLS	0001	1396	164.66
490	254	GRLND	1604	1996	164.57
491	97	ECTHP	4921	311	164.16
492	624	BKBNT	1832	196	163.99
493	1950	CLLVL	0006	1183	163.97
494	2762	PCOMM	3313	473	163.09
495	1140	WXHCH	1202	1710	163.01
496	2744	SHMNE	1407	807	162.56
497	953	MESQW	1802	827	162.55
498	750	JKWST	4035	81	162.48
499	1263	HKBRY	1107	969	162.42
500	741	FRMBR	1804	300	161.66
501	707	WBOSE	1103	906	161.45
502	1574	RCHRD	1205	1039	161.41
503	574	MAYFD	5524	2594	161.35
504	1515	ALLNC	6422	15	161.30
505	2030	WNDWD	3682	782	161.11
506	1765	WEAST	0629	1802	160.24
507	843	PRCRK	0003	1836	160.11
508	146	HNTNG	1301	1390	159.94
509	681	CRNTH	2401	2531	159.27
510	2234	CHROW	0007	84	158.95
511	2269	JKREA	1201	30	158.82
512	1599	SYCRK	4532	4150	158.50
513	237	MEANS	4421	52	158.33
514	2937	BLMND	3272	12	158.26
515	2738	FRMNT	0003	877	158.24
516	1150	PLSTN	1005	1901	158.07
517	1843	CRNRD	0001	740	158.05
518	1957	IRVNR	1553	1336	157.72
519	1697	MABNK	2404	2541	157.09
520	1480	MNFLD	2621	2282	157.08
521	2461	IRVNE	1302	282	156.90
522	1077	DESPR	1407	944	156.70
523	914	MLDR2	1605	216	156.22

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
524	2385	MESQN	1507	696	155.96
525	689	MKNNY	1203	1083	154.31
526	738	DNCNV	1904	1471	154.01
527	944	GRLND	1605	1533	153.40
528	1172	CLBWS	8112	1626	153.02
529	747	CDHCR	2051	2128	152.99
530	1581	CNI45	2402	811	152.93
531	2041	PLGRV	0002	2338	152.89
532	513	MAPLE	0006	2373	152.55
533	2434	RRSTH	1707	609	152.51
534	1204	EXPKY	8142	27	152.29
535	969	IOWPK	0831	1073	152.13
536	736	TIODE	9611	359	152.12
537	1544	ALLNC	6412	3266	152.10
538	949	LFSTH	1407	1730	151.53
539	1028	CLNSE	4201	933	151.39
540	2060	BRHLW	7632	1487	151.38
541	1038	HRSMD	1905	2787	151.02
542	145	PRKRW	3311	1140	150.96
543	2445	OVRTN	4037	119	150.67
544	623	CDCSW	0007	990	150.40
545	1152	BLMED	1622	955	150.31
546	1428	RKDLE	1301	1226	149.88
547	719	COLNY	2401	734	149.81
548	2103	SALSW	3001	1484	149.66
549	1092	WSOTH	1020	1140	149.31
550	470	MNFLD	2682	2388	149.25
551	348	SSPNE	1401	1276	149.15
552	376	RSPCK	2108	960	149.09
553	2328	SSPNG	1204	972	149.04
554	2101	TMPLE	1205	2488	148.40
555	1401	FHLSW	1342	1955	148.38
556	1717	WXHCH	1203	1288	148.12
557	246	HRSMD	1955	2091	147.81
558	1264	AIRPK	8421	1035	147.43
559	1803	HURST	1861	1849	147.21
560	1224	CMEXP	1601	249	146.94
561	442	TIODE	9621	310	146.92
562	2554	BLMND	3262	122	146.81
563	2081	EZACH	0005	541	146.76
564	1849	CHROW	0003	155	146.65
565	1577	HSKAV	0005	1373	146.57
566	1731	FINKS	1804	2306	146.56
567	1322	LKWOD	7442	717	146.44
568	1527	NCNTH	1808	757	146.34
569	59	JKWST	4178	421	146.26
570	1688	ARMST	0009	1140	146.18
571	1662	WWDWY	2015	1200	146.14

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
572	484	TYLER	1005	2004	146.04
573	121	BAKKE	6911	287	145.63
574	1903	MOSSW	4611	1583	145.41
575	900	PCUST	2011	1639	145.36
576	150	WCITY	2401	917	145.34
577	1550	RENSW	3121	1942	145.20
578	1097	RENSW	3124	1708	144.91
579	N/A	PGSTH	7012	173	144.78
580	1918	SFTLK	4021	39	144.75
581	1510	NHNSW	0005	422	144.69
582	277	KRUMS	1202	701	144.68
583	1891	TMPTV	2404	1427	144.19
584	857	FINKS	1802	727	144.18
585	114	LNDAL	2203	2424	144.02
586	372	WHITE	3541	955	143.97
587	883	CDCSW	0008	725	143.96
588	1405	HORNE	1932	1159	143.88
589	1543	CPLSO	4321	158	143.82
590	2447	HSKAV	0006	756	143.37
591	2949	FRMNT	0011	993	143.35
592	1988	KLRPR	9021	2022	143.31
593	2167	CPRCV	1406	1640	143.30
594	521	DIBOL	1505	1446	143.13
595	1464	BOWEN	3161	1544	143.12
596	428	RWALL	1202	2503	143.05
597	43	RSPCK	2103	167	143.02
598	249	IOWPK	0821	756	142.50
599	1403	PLANO	1101	404	142.26
600	2605	ARTHR	0462	209	141.92
601	189	SMPST	0003	1020	141.82
602	655	NCSTH	1501	808	141.80
603	377	CNTRY	2842	1148	141.67
604	2076	ABRRD	0006	456	141.63
605	406	MSHLN	0001	1043	141.62
606	663	CNTRY	2811	2659	141.53
607	945	NPKWY	0010	3016	141.51
608	349	ENSSO	2002	1109	141.39
609	1631	CRLTR	2004	235	141.34
610	1148	DAVIS	3733	294	141.20
611	1558	SALSW	3003	733	140.98
612	369	PRCRK	0001	202	140.81
613	107	ECTHM	3341	2415	140.47
614	177	LUFKN	1206	1615	140.31
615	1414	MNFLD	2611	1894	140.19
616	340	ALNSW	2653	3516	140.08
617	2177	CLBNR	1407	268	140.04
618	1256	TRSES	1201	500	139.84
619	2056	BSPRG	1901	586	139.80

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
620	517	NCNTH	1802	1289	139.79
621	551	SCYEN	0001	2012	139.77
622	2186	CRYVE	3021	1285	139.75
623	810	MKNNY	1251	1517	139.73
624	1124	MCWHT	3511	3132	139.49
625	2305	EDGCF	2272	1079	139.42
626	2009	PRFTW	4212	2009	139.23
627	687	BRNAV	0753	1267	139.20
628	288	CDCSW	0002	2369	139.20
629	192	LENSW	0321	46	138.95
630	410	BRLSN	2051	2689	138.90
631	878	DNISN	1203	1686	138.79
632	360	CNTRY	2822	2847	138.48
633	302	MNHNS	1911	1515	138.36
634	1650	WNRTH	1421	1484	138.19
635	33	RBNSN	2502	1224	137.92
636	879	PCUST	2008	694	137.84
637	830	LNCST	1605	816	137.70
638	2023	FSTVW	0004	2269	137.52
639	1966	SMFLD	2352	602	137.44
640	130	CNTRY	2831	1592	137.44
641	545	OVRTN	4019	660	137.17
642	1876	CRLUD	1304	1498	136.93
643	1742	PKRMX	4703	3034	136.56
644	477	HUTCH	1503	551	136.18
645	1835	KIMBL	5032	1741	135.93
646	195	INAIR	1432	3279	135.69
647	2066	EULSO	9132	1987	135.67
648	1484	BNBRK	4112	2229	135.36
649	1569	SPRDL	4841	953	135.30
650	2555	GAVSW	0012	834	135.05
651	1445	TMPSE	1503	621	135.01
652	449	FERIS	1101	1179	134.33
653	1698	FLMSO	3716	2141	134.21
654	438	TYOMN	1409	1600	134.07
655	743	WESTS	1601	1047	133.92
656	2344	PROAD	0007	422	133.77
657	1027	DNCNV	1901	891	133.73
658	2979	RGFTW	6841	20	133.64
659	885	RWALE	3321	1533	133.40
660	1136	CDCSW	0006	1369	133.32
661	264	COLNY	2404	1947	133.27
662	1702	LWSNR	2232	2269	133.11
663	1716	LKMNT	0003	603	132.97
664	1825	STAUG	0002	1402	132.82
665	630	LNDAL	2201	1907	132.72
666	1175	MESQW	1806	1665	132.49
667	1840	OAKHL	3021	1988	132.49

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
668	800	CDCSW	0003	716	132.37
669	1034	HRSMD	1957	2457	132.31
670	1007	MESQT	1305	1146	132.07
671	2298	RSPCK	2132	72	131.98
672	746	PRKWY	1552	556	131.83
673	796	CDMIL	2401	902	131.82
674	2551	HRSMD	1951	4461	131.76
675	727	LFSTH	1406	2091	131.71
676	1579	PFFRD	3441	1211	131.67
677	335	MKNNY	1252	2649	131.65
678	749	DAVST	0004	1721	131.59
679	2393	HORNE	1961	1774	131.56
680	1317	MESQT	1307	593	131.36
681	947	MDAIR	2921	71	131.33
682	1653	SYCRK	4522	2835	131.03
683	2788	PTENN	2355	179	130.83
684	1868	WXNTH	2306	2356	130.74
685	928	LFEST	1904	1335	130.56
686	2256	TYLGE	1316	2841	130.51
687	1996	KLNPS	1102	1883	130.47
688	760	TYBLR	2803	787	130.32
689	979	MEXIA	4007	453	130.32
690	1024	NCDCH	1204	1268	130.31
691	2690	WGROB	8421	2174	130.20
692	437	BEAST	4090	937	130.14
693	317	STHRL	0001	602	129.97
694	754	GNSVL	1213	737	129.85
695	1725	VLYRN	2953	2837	129.70
696	474	NCSFA	1704	1402	129.35
697	2474	WCOLO	1319	2072	129.33
698	1131	VGCRK	8041	1041	129.22
699	397	PRCRK	0002	2234	129.19
700	1461	RDLML	2521	1025	129.10
701	514	PPARK	1805	996	128.88
702	2968	MESTE	1201	23	128.82
703	530	CRLUD	1305	1368	128.77
704	196	STHRL	0007	134	128.74
705	660	BRIRV	6911	3239	128.61
706	1917	CNTRY	2862	401	128.56
707	2288	PTENN	2351	1553	128.48
708	2469	SHDYG	7822	529	128.00
709	1924	IRVNE	1309	1130	127.78
710	1707	SWTWR	1382	438	127.68
711	2587	PCOIT	1024	2312	127.36
712	2588	GODRD	8161	2216	126.84
713	899	NHNSW	0007	581	126.75
714	1442	BLMND	3213	3272	126.57
715	462	BRKTN	1201	493	126.44

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
716	634	LKMNT	0008	1004	126.38
717	1979	MDWPK	9241	1566	126.32
718	1000	WWEST	1219	941	126.28
719	2444	DENAV	0642	912	126.05
720	1758	MCDMT	2532	1978	125.96
721	154	WLSPT	1002	604	125.93
722	295	MKNSO	3611	1944	125.78
723	2883	PRKRW	3382	309	125.73
724	2439	BRNAV	0741	2076	125.44
725	1067	PALRD	2206	1511	125.41
726	1357	CMPWI	0002	1660	125.12
727	445	CADD0	0911	448	124.84
728	1658	WWDWY	2022	1028	124.82
729	506	TYWST	2003	1412	124.71
730	805	PPARK	1803	1063	124.56
731	1740	PWEST	1303	1008	124.52
732	1459	LUFKN	1202	1070	124.49
733	748	MESQT	1301	1454	124.48
734	1169	DUVAL	0441	1034	124.46
735	1046	WATCO	2602	2273	124.37
736	2959	JNKNS	0008	27	124.36
737	1279	DALLW	0005	128	124.34
738	2067	LEMON	0004	579	124.31
739	1536	RRSTH	1706	3691	124.25
740	1686	FROKS	0003	639	124.23
741	2104	HLSES	0522	1753	124.19
742	1360	LVBRD	0004	1059	124.04
743	1745	HMPHL	2781	331	123.79
744	1122	AYERS	4431	1667	123.75
745	519	CRKET	2403	2796	123.69
746	2633	WFALS	0153	1135	123.65
747	844	CMTSW	0922	1420	123.41
748	515	IRVNR	1501	1103	123.37
749	2049	HSKAV	0002	1737	123.15
750	2500	PAYSW	1213	1427	123.02
751	190	ANDNR	2222	126	122.99
752	1711	WXNTH	2308	869	122.77
753	2590	BRYAN	0001	16	122.60
754	2789	BLMND	3252	1138	122.54
755	30	HDWLK	3005	1020	122.46
756	2192	JNKNS	0003	1064	121.60
757	170	GVODS	3041	1477	121.49
758	2446	CDCSW	0004	1373	121.30
759	87	BRNAV	0723	1330	121.29
760	1771	HHSTH	1502	3740	121.23
761	1229	ATHNW	1402	487	121.12
762	1722	THRDN	1901	1710	121.09
763	2065	SHNRW	1611	975	120.95

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
764	863	FHLSW	1351	1443	120.82
765	1340	JSHUA	1301	1003	120.81
766	2396	HRSMD	1907	2662	120.78
767	2651	WNDWD	3631	309	120.56
768	1648	MEXIA	4011	1015	120.51
769	2486	CLMET	0004	1174	120.37
770	767	DALRK	1305	1153	120.37
771	1173	DESPR	1403	1796	120.29
772	2144	TYLGE	1308	1559	120.24
773	1806	TYLNW	1912	2100	120.11
774	2636	MESFR	2103	375	119.99
775	2316	SYCRK	4512	4161	119.74
776	1128	TERSO	2501	185	119.70
777	2438	ODNTH	2024	2618	119.63
778	1710	STAUG	0001	707	119.44
779	2963	LSCOL	2114	91	119.25
780	357	CANTN	1301	2169	119.24
781	1649	MDLNW	1552	1365	119.18
782	966	LOMAL	0001	676	119.15
783	1634	KIMBL	5022	890	119.00
784	223	WICKT	0421	137	118.78
785	688	DCDAM	2003	1322	118.54
786	222	ATHNS	1202	775	118.51
787	835	BRNAV	0711	1642	118.35
788	2625	GLNHV	3931	1338	118.30
789	2970	PJPTR	3222	183	118.13
790	554	PRSTN	0006	758	118.05
791	1691	TRNTH	1503	1841	117.85
792	1831	WXNTH	2304	855	117.83
793	42	MDLNE	0142	884	117.78
794	1570	RBNSN	2503	1126	117.71
795	343	REAST	1503	570	117.65
796	672	ORANS	1501	850	117.55
797	698	EUSTC	2401	1705	117.43
798	2846	NHNSW	0002	404	117.34
799	1738	MRVLY	2311	368	117.27
800	527	BEAST	4084	875	117.24
801	658	CRNTH	2402	1461	117.18
802	2098	TYLER	1001	153	117.02
803	2416	REGST	0004	980	116.92
804	2111	GSTHW	1633	955	116.45
805	888	SWAN2	1801	543	116.31
806	100	RDLML	2561	897	116.30
807	648	RHOME	2402	1324	116.29
808	875	MTLDA	0001	2603	116.22
809	998	RECCR	0003	210	115.81
810	2108	TMSTH	1404	1313	115.79
811	1640	OAKHL	3072	2489	115.67

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
812	487	IRVBL	2507	904	115.65
813	2027	ARMST	0012	1161	115.53
814	82	MEANS	4411	37	115.48
815	755	LTLRV	1701	1085	115.48
816	430	MCDMT	2531	2439	115.45
817	1995	CMTSW	0916	555	115.44
818	1277	ENNIS	1906	2033	115.35
819	1593	TAYLR	1202	1565	115.26
820	1530	PCUST	2004	1204	115.22
821	312	COLNY	2405	2388	115.19
822	314	KFMNW	1201	1020	115.17
823	2526	GRMES	0521	549	115.15
824	1920	DGNST	0006	1283	114.94
825	2532	BRHLW	7641	36	114.69
826	2493	IRVNR	1552	68	114.64
827	2304	GLNHV	3983	1677	114.60
828	1388	HLSBR	1201	1128	114.51
829	976	ROLTR	2912	3609	114.28
830	1972	WWEST	1222	178	114.28
831	2313	ARLNG	1261	1366	114.23
832	1003	GDPRW	9611	1261	114.04
833	2205	SWDTN	1641	1572	114.01
834	2072	HOLDY	0921	615	113.95
835	393	STAUG	0006	1800	113.90
836	459	SCHRD	0007	1405	113.88
837	461	WHOUS	4122	2062	113.67
838	608	HSKAV	0007	1888	113.17
839	567	RSKMN	3046	1085	113.10
840	823	COLNY	2403	2631	113.04
841	556	IRVNE	1306	1535	113.04
842	2671	PTENN	2352	2488	112.89
843	633	WXHCH	1204	1782	112.82
844	571	CURIE	7211	752	112.72
845	770	KLBRG	0003	1404	112.66
846	258	DIALV	3911	1081	112.51
847	1846	RDOAK	1302	1252	112.50
848	186	CSHNG	1202	66	112.25
849	817	GODRD	8171	839	112.25
850	1594	DENAV	0611	852	112.19
851	332	WDGWD	1572	1475	112.08
852	371	WEBBS	8614	2507	111.95
853	584	PRKWY	1511	1301	111.85
854	859	PAYSW	1202	1652	111.60
855	1329	CMPST	0002	1060	111.47
856	1514	ITALY	2101	568	111.25
857	496	WMRLD	0003	489	111.23
858	2357	MCKMY	0822	1386	111.22
859	1377	STERT	2706	171	111.10

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
860	1093	RSPCK	2102	1562	111.10
861	326	TRSES	1202	507	111.03
862	2674	DENAV	0652	31	110.95
863	1613	DCVSO	1106	1210	110.91
864	323	CDHIL	1623	2153	110.88
865	1344	RWALE	3322	1946	110.84
866	2596	CMPWI	0005	1645	110.84
867	1748	FRMBG	1707	443	110.82
868	161	GLNHV	3973	1525	110.55
869	126	KRGRV	2403	3720	110.38
870	1736	MCWHT	3522	2963	110.10
871	2965	LSCOL	2140	624	109.89
872	955	PCUST	2006	1611	109.77
873	384	ODESW	5912	335	109.70
874	781	NPKWY	0005	856	109.65
875	2825	GAVSW	0008	107	109.40
876	1524	REYST	4040	545	109.20
877	2326	SNYDR	1833	1425	108.79
878	2119	EULES	8711	2049	108.58
879	2175	GNSVL	1205	880	108.52
880	2221	BDFRD	8812	770	108.19
881	299	SHRSW	6611	1243	108.10
882	2828	LVBRD	0001	38	108.03
883	1255	RCHRD	1208	1036	107.87
884	2770	AIRPK	8432	948	107.54
885	403	BDFRD	8822	1054	107.44
886	1084	SCYEN	0002	1282	107.39
887	651	ARLNG	1241	657	107.28
888	1582	LUFKN	1201	1341	107.18
889	1618	GAVSW	0006	522	107.14
890	2315	WFALS	0174	1226	107.05
891	147	EDWDS	5931	1087	106.89
892	1805	DNIWS	1603	1363	106.84
893	1099	MRLNS	4002	411	106.75
894	239	ATHNS	1203	1044	106.73
895	2235	NMAIN	0211	1928	106.64
896	602	BNTDR	0003	460	106.62
897	997	LWSNR	2221	1451	106.59
898	866	PRFTW	4221	1383	106.55
899	867	CKRHL	0002	425	106.48
900	1632	ALPHA	0009	62	106.42
901	2245	GLNHV	3911	1360	106.40
902	22	EDWDS	5921	24	106.25
903	2307	RANGR	4321	869	106.17
904	2720	BLKST	1752	1176	106.08
905	2516	SMPST	0005	152	106.06
906	1101	WALST	0004	45	105.77
907	2212	PRCTR	1602	230	105.69

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
908	2128	PLKST	0003	1303	105.59
909	431	SYCRK	4531	2434	105.50
910	1254	DNISN	1204	1213	105.25
911	1378	BLTON	1806	847	105.10
912	898	DCATR	1202	1720	105.01
913	833	SHAMP	0007	690	104.99
914	2694	JNKNS	0001	25	104.95
915	2364	NMAIN	0272	414	104.84
916	950	BOWEN	3171	1717	104.83
917	892	COPEL	3051	1588	104.65
918	1560	GRLRD	0002	994	104.51
919	1819	OKCLS	0003	1513	104.28
920	1070	BNDRA	0003	820	104.08
921	557	EULES	8722	2131	103.88
922	1020	HURST	1822	1588	103.87
923	2380	RDRSE	2603	3880	103.83
924	2412	DAVST	0007	608	103.58
925	316	MSLSW	0002	1038	103.54
926	924	WNDWD	3652	979	103.19
927	225	MKNSW	2602	1272	103.08
928	1300	WFALS	0184	1263	102.94
929	1588	NCDCH	1206	1098	102.80
930	206	ROSCO	2911	616	102.57
931	568	COLDG	4047	411	102.18
932	2055	GPLND	1202	401	101.99
933	1470	GRPVN	8213	264	101.83
934	414	DALRK	1307	1161	101.76
935	362	MKNGB	5322	1587	101.52
936	2052	ALLEN	2401	744	101.51
937	1100	FSCRK	6713	3068	101.25
938	1616	ARLNG	1223	1838	101.22
939	2426	TYWST	2004	984	101.13
940	1476	HLTOM	2452	1810	100.97
941	1338	ODESW	5922	2399	100.94
942	485	SLBLF	1201	139	100.94
943	853	ALNSW	2652	2600	100.92
944	2714	RSPVY	1708	980	100.85
945	2496	MDWCK	0003	1873	100.33
946	1184	BNDRA	0002	540	100.23
947	2172	SSPSW	1604	1212	100.10
948	160	RSKMN	3057	1173	100.00
949	1712	PSHIL	1608	1941	99.80
950	1393	DALLW	0006	1950	99.71
951	2169	GSTHW	1692	999	99.71
952	2867	HNYGR	2403	594	99.65
953	1448	KLELM	2205	3200	99.55
954	1822	EZACH	0007	1591	99.54
955	2113	LKWOD	7411	630	99.34

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
956	1483	ELZCK	4911	35	99.33
957	986	BNMAG	1202	405	99.23
958	1282	SANSM	3912	5168	99.22
959	2740	PJPTR	3211	118	99.17
960	641	COMSO	1401	655	98.93
961	2572	TYBLR	2808	981	98.87
962	1089	ARTHR	0481	1251	98.86
963	292	WDGWD	1523	308	98.76
964	1348	CPRCV	1405	1530	98.66
965	1210	HLTOM	2431	1306	98.44
966	1933	WTAUG	4643	1001	98.34
967	849	MEXIA	3015	123	98.29
968	577	CDCSW	0005	1705	98.19
969	1406	FRMBR	1805	760	98.08
970	696	ODESW	5221	1484	97.97
971	338	JKSNR	4105	84	97.88
972	1642	PRMED	4401	2042	97.85
973	511	FSCRK	6711	3788	97.81
974	1508	LMESA	1531	640	97.62
975	1196	MESQW	1808	1343	97.43
976	544	CDHIL	1801	1050	97.29
977	1466	GVODS	3021	262	97.09
978	1049	TMNTH	1602	474	96.88
979	1596	MESWE	3621	807	96.88
980	1462	TRLWD	7711	2341	96.88
981	2539	HORNE	1911	1017	96.80
982	119	MKNGB	5321	590	96.70
983	169	VANAL	2412	2997	96.68
984	1205	BBTWN	1504	2105	96.65
985	657	KNLTR	0004	1945	96.51
986	667	PNTGO	7121	1506	96.50
987	923	DCVSO	1105	1660	96.49
988	926	NHNSW	0004	567	96.46
989	2888	JKSNR	4107	330	96.46
990	1797	TATSP	4322	2534	96.42
991	1221	AZLES	2111	3043	96.29
992	1232	KLNTF	1804	1007	96.17
993	1469	IRVGS	1905	770	96.08
994	726	MURPH	2754	2115	96.00
995	2409	MSHLN	0008	680	95.99
996	479	BDFWD	8921	688	95.95
997	2276	FORSW	2015	2404	95.84
998	2727	RVRFT	0002	330	95.74
999	2251	BRKRG	0213	411	95.73
1000	1478	EDGWD	1102	947	95.69
1001	2202	GNSVN	1403	299	95.60
1002	83	MAREA	1201	151	95.59
1003	156	IOWPK	0811	789	95.55

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1004	1397	ARTHR	0492	49	95.48
1005	604	TRNTH	1501	1765	95.45
1006	1237	TRLWD	7722	4056	95.38
1007	2080	LAVON	1454	2979	95.32
1008	585	JUDCT	0007	895	95.31
1009	423	CHICG	1402	508	95.20
1010	1310	MKNGB	5352	680	95.11
1011	2338	RDLML	2532	1788	95.09
1012	1834	RDLML	2591	1626	94.97
1013	2482	GRLWS	1706	289	94.91
1014	972	CRLTR	2001	2501	94.81
1015	1031	CTYVW	2222	1385	94.71
1016	952	DCVSO	1104	1352	94.69
1017	1235	LNCST	1604	637	94.62
1018	1848	SIKES	2421	1843	94.50
1019	904	MSLMN	4131	132	94.47
1020	2620	CLBNR	1402	2453	94.45
1021	1953	MESQW	1804	1344	94.42
1022	659	LAVON	1452	1816	94.27
1023	842	SHMNE	1409	900	94.16
1024	2051	DUVAL	0414	653	94.02
1025	413	CSHNG	1204	326	93.84
1026	1114	CLBNR	1406	106	93.75
1027	2410	RKDLE	1302	1186	93.70
1028	2705	ARMST	0010	880	93.62
1029	1295	COLNY	2402	2426	93.60
1030	1985	WELRD	0006	732	93.49
1031	699	DALRK	1354	1461	93.46
1032	994	ELMGV	3653	1988	93.33
1033	2210	GAVSW	0009	1032	93.29
1034	1057	NYLDV	1201	652	93.28
1035	520	COPER	1201	321	93.27
1036	2961	KIMBL	5011	162	93.25
1037	1867	DALRK	1358	2088	93.20
1038	639	AZLES	2122	2255	93.00
1039	2517	HLSBR	1202	1224	92.86
1040	2601	PALRD	2203	1088	92.67
1041	854	MSHLN	0003	531	92.67
1042	940	CDHCR	2054	1435	92.56
1043	1137	SHAMP	0001	1230	92.46
1044	12	LMESA	2813	118	92.37
1045	118	TRPMN	4023	426	92.36
1046	744	GRAHM	0721	1241	92.22
1047	483	WBROK	3021	51	91.94
1048	1215	DCVSO	1103	1828	91.87
1049	1320	HUDSN	1603	1799	91.39
1050	2561	GSTHW	1682	179	91.38
1051	2930	FRMNT	0002	575	91.26

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1052	936	CDCSW	0001	273	91.12
1053	917	ARMST	0002	1685	91.08
1054	1096	DEALY	0001	730	91.03
1055	2580	BRTRD	7312	3712	90.83
1056	980	PARIS	1201	1137	90.83
1057	342	BAKKE	6912	1842	90.79
1058	877	DAVIS	3772	1720	90.74
1059	1938	ELZCK	4921	1733	90.67
1060	706	CMTSW	0936	522	90.66
1061	812	DAVST	0002	552	90.54
1062	792	BRIRV	6912	805	90.54
1063	2034	DNCNV	1903	1203	90.18
1064	375	CMPST	0004	1586	90.12
1065	1144	PNTGO	7111	723	90.09
1066	1770	MDTHN	1702	1899	89.95
1067	1628	CRLJL	1501	1463	89.83
1068	752	FRMNT	0014	629	89.81
1069	1906	SMFLD	2333	1063	89.80
1070	1525	BLTLN	0002	880	89.79
1071	2701	WRTHM	5012	315	89.77
1072	1922	LOMAL	0016	664	89.76
1073	1889	WITTS	1705	1353	89.59
1074	2693	LEMON	0011	1870	89.34
1075	669	EMPCT	0001	35	89.32
1076	686	MESQN	1504	1331	89.18
1077	1354	GAVSW	0005	1500	89.17
1078	1546	LIGSW	1602	1109	88.98
1079	419	BRGPR	1102	1363	88.98
1080	818	MDTHN	1703	609	88.93
1081	2147	HSKAV	0003	1420	88.82
1082	887	CDHCR	2052	1405	88.82
1083	2054	ELGIN	1002	2621	88.71
1084	2680	NCRST	2202	30	88.67
1085	977	MRLNS	4003	938	88.50
1086	1381	TROYS	1014	1321	88.49
1087	1626	EULES	8723	5166	88.46
1088	2360	HORNE	1972	766	88.45
1089	2155	ADISN	1601	636	88.34
1090	937	MABNK	2402	979	88.26
1091	368	ATHNW	1404	1366	88.12
1092	933	OKLND	0002	1261	88.04
1093	1095	HOLDY	0911	1162	87.94
1094	2704	HRSMD	1953	405	87.94
1095	1501	NLNVL	2001	420	87.93
1096	716	PCUST	2012	1813	87.85
1097	2349	LKHLD	0004	1262	87.76
1098	991	FLINT	3211	2289	87.54
1099	471	TYLNE	1623	510	87.34

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1100	1200	LRENA	2901	992	87.16
1101	1333	ALVDO	1902	928	87.09
1102	420	AMMFG	5631	1225	86.99
1103	512	BOWEN	3192	1264	86.96
1104	1039	DNIWS	1601	892	86.62
1105	1954	HMTRD	0001	967	86.27
1106	2665	ARTHR	0441	1891	86.24
1107	845	WXNTH	2303	2224	86.23
1108	724	SWDTN	1611	1488	86.23
1109	2672	SHDYG	7811	379	86.20
1110	296	TYBLR	2811	1124	86.17
1111	1165	IRVGS	1903	882	86.15
1112	286	IRVBL	2504	1585	86.07
1113	2358	PRSTN	0003	2960	86.00
1114	2048	WDGWD	1512	828	85.95
1115	2550	GAVSW	0010	486	85.92
1116	860	HSKAV	0001	1077	85.78
1117	N/A	LKBLT	2103	1915	85.74
1118	1968	OVRTN	4015	626	85.56
1119	1643	CRLJL	1503	752	85.55
1120	1185	SMFLD	2313	2128	85.33
1121	2094	REAST	1504	1294	85.32
1122	2960	JREST	2103	267	85.22
1123	2742	DENDR	0006	44	85.09
1124	404	GNSVE	1602	1737	84.96
1125	163	BNBOR	1201	752	84.94
1126	737	PCUST	2007	1393	84.88
1127	124	KEYSB	2621	16	84.88
1128	2145	SMFLD	2391	292	84.86
1129	133	CRANE	0321	23	84.68
1130	963	FINKS	1803	1345	84.65
1131	1523	SSPNE	1402	69	84.58
1132	1944	BRCKR	6533	1833	84.55
1133	2372	NMAIN	0231	318	84.54
1134	1117	WNRTH	1417	1395	84.43
1135	1159	GRDPR	0811	1216	84.34
1136	1665	RICES	0206	656	84.18
1137	380	MNHNS	1921	1848	84.14
1138	561	LGVST	8521	1761	84.01
1139	609	LNDAL	2202	1239	83.96
1140	407	IRVVV	2803	154	83.92
1141	200	TYWST	2012	2147	83.91
1142	1394	HUDSN	1604	1760	83.86
1143	1460	BONHM	1206	2111	83.80
1144	721	PREST	1602	1413	83.76
1145	2485	MDDTN	4331	1835	83.75
1146	1181	BONHM	1202	737	83.73
1147	1035	RWALL	1204	1064	83.62

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1148	1965	GRHWY	5522	1728	83.55
1149	2707	HLTOM	2472	1812	83.55
1150	2647	BRNAV	0732	798	83.54
1151	2035	RSNHT	1122	2027	83.49
1152	1884	DEALY	0002	1465	83.43
1153	1072	IRVNR	1559	2599	83.32
1154	1486	GRDPR	0871	1569	83.30
1155	37	TYLNW	1910	609	83.12
1156	988	KLNPS	1101	2291	83.10
1157	425	WDGWD	1541	1133	82.99
1158	201	WHOUS	4121	1333	82.94
1159	2230	MNWLL	1204	286	82.90
1160	2574	BKWST	0002	1667	82.89
1161	1160	ALPHA	0013	449	82.68
1162	135	RVRFT	0003	908	82.66
1163	1482	CAMRN	1201	1032	82.63
1164	1421	KIMBL	5012	1013	82.58
1165	2201	BDFRD	8831	877	82.57
1166	2261	EULSO	9131	1977	82.56
1167	1772	FSTVW	0008	1814	82.54
1168	102	TSLVL	4001	1275	82.44
1169	220	ITSCA	1701	747	82.41
1170	1492	DALLW	0004	1323	82.41
1171	2214	DFWSW	2209	42	82.40
1172	2095	SANSM	3922	1837	82.24
1173	1532	PFFRD	3482	1087	82.12
1174	247	TYSTH	1209	814	82.01
1175	2619	CTYVW	2221	1829	81.87
1176	549	CRLJL	1504	1285	81.86
1177	2110	WEBBS	8611	2610	81.81
1178	313	WALST	0009	817	81.73
1179	175	WMRLD	0001	222	81.61
1180	2822	COVEE	3403	1356	81.45
1181	2064	MESFR	2105	1049	81.42
1182	1773	RKDLN	1401	934	81.31
1183	1061	MRDCK	0003	1267	81.29
1184	415	IRVGS	1902	1496	81.29
1185	1359	HNYGR	2402	159	81.22
1186	1051	IRVNE	1310	1421	81.04
1187	2268	CRTLD	4723	2326	81.01
1188	2745	PROAD	0004	991	80.96
1189	1940	LIGSW	1607	1435	80.86
1190	1841	DAVST	0005	1828	80.79
1191	1259	ABRRD	0002	1372	80.77
1192	2656	MSLSW	0006	94	80.76
1193	315	RECCR	0001	163	80.75
1194	212	PCOIT	1001	1233	80.59
1195	260	CNTRY	2823	1864	80.52

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1196	2071	IRVBL	2501	387	80.47
1197	2279	DNCNV	1905	1328	80.22
1198	1931	RECCR	0004	71	80.03
1199	2135	RCLNS	1405	639	80.03
1200	2892	GAVSW	0011	109	79.81
1201	1032	SHDYG	7842	728	79.74
1202	935	CANTN	1303	860	79.72
1203	2682	LMBLN	0004	50	79.64
1204	1656	GORMN	0421	353	79.55
1205	1557	CNEXP	0006	1213	79.53
1206	1880	WCOLO	1315	1585	79.50
1207	2492	CRSCN	1204	618	79.47
1208	32	BRGPR	1103	900	79.43
1209	668	NLNVL	2003	691	79.37
1210	912	BLTLN	0006	926	79.36
1211	1694	RCHHL	0332	1713	79.26
1212	697	BMTWN	1621	1432	78.92
1213	148	VANSB	1502	1666	78.78
1214	1992	WNDWD	3611	297	78.78
1215	1779	NSTAR	2011	524	78.73
1216	1974	COPEL	3056	2811	78.69
1217	478	MESQT	1308	1880	78.46
1218	2852	BLTSW	3205	1439	78.35
1219	1332	SCYEN	0003	1974	78.33
1220	2083	MCGRG	0775	527	78.31
1221	2045	EDGCF	2241	929	78.16
1222	811	OAKHL	3031	624	78.10
1223	1290	BNDRA	0007	504	78.06
1224	1234	GVODS	3062	1978	77.97
1225	615	NCSFA	1706	1185	77.92
1226	1764	FORSW	2051	4026	77.73
1227	475	BAGWL	1202	48	77.72
1228	2471	CRLJL	1502	391	77.72
1229	252	CRSGL	1306	644	77.71
1230	1520	MLKF2	1201	1837	77.68
1231	1292	WRBND	2312	1443	77.65
1232	984	EDGCF	2213	3188	77.64
1233	1723	MDLNW	1541	2294	77.62
1234	1417	TMPLE	1201	1656	77.61
1235	208	RWALS	1852	2767	77.56
1236	563	MDWCK	0007	1081	77.56
1237	1830	CPLND	1101	1056	77.48
1238	2078	CRNTH	2405	3957	77.47
1239	2967	MAPLE	0004	480	77.42
1240	2152	WNDWD	3662	883	77.40
1241	2782	FSTVW	0002	146	77.32
1242	1897	TMNTH	1607	12	77.31
1243	2464	HKBRY	1117	141	77.29

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1244	1307	TYSTH	1202	1056	77.20
1245	1454	WDGWD	1592	1167	77.12
1246	603	JKSNR	4109	651	77.11
1247	1633	GLNHV	3963	1597	77.08
1248	2053	CRLTN	1401	810	77.02
1249	504	RCHHL	0342	1007	76.98
1250	552	HUTCH	1502	203	76.83
1251	268	ITSCA	1702	203	76.83
1252	2025	BLMED	1621	2067	76.81
1253	382	TYEST	1503	1077	76.75
1254	278	ARMST	0004	1282	76.66
1255	2099	SHLMT	1801	305	76.62
1256	1583	ANDNR	2211	2528	76.62
1257	839	PRKRW	3362	1099	76.53
1258	2114	FSCRK	6712	2562	76.52
1259	2629	SANSM	3913	4118	76.50
1260	2777	ABRRD	0001	1418	76.35
1261	1896	TMSTH	1408	754	76.33
1262	2511	PRKWY	1542	509	76.31
1263	1787	FSTVW	0006	1250	76.31
1264	1395	PRKRW	3331	134	76.07
1265	592	CRLFR	2154	3458	76.04
1266	1549	DESHR	1201	990	75.90
1267	2224	RCHHL	0374	541	75.89
1268	1002	MNWLL	1203	885	75.87
1269	1586	PTENN	2358	1440	75.86
1270	392	MSLMN	4009	237	75.85
1271	365	EZACH	0008	1534	75.82
1272	2603	BSPRW	2511	760	75.75
1273	1727	BDFRD	8821	889	75.66
1274	1792	CNTRY	2824	3090	75.64
1275	636	BSPRW	2542	751	75.52
1276	858	PTENN	2357	1294	75.21
1277	1113	ADISN	1607	1237	75.03
1278	2036	KNEDL	6342	2123	74.93
1279	939	GRNGR	1801	908	74.90
1280	948	PRKRW	3372	1494	74.83
1281	722	MESFR	2102	676	74.78
1282	1086	KNEDL	6321	2423	74.77
1283	1845	CDHIL	1804	1221	74.68
1284	618	HHSTH	1501	3392	74.62
1285	1910	CRNTH	2404	2380	74.37
1286	1625	KRUMS	1204	1416	74.24
1287	1820	DCVSO	1101	1478	74.14
1288	2250	RSPVY	1704	1406	74.12
1289	1294	ALLEN	2408	3213	74.10
1290	1048	FROKS	0007	1497	73.83
1291	1121	PLANO	1102	143	73.78

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1292	1976	CMPWI	0001	1889	73.72
1293	345	HLTOM	2442	1096	73.61
1294	187	WLWSP	1201	505	73.57
1295	2820	PCOMM	3311	28	73.55
1296	1110	PWEST	1307	945	73.54
1297	1659	CMTSW	0966	124	73.52
1298	2450	JUDCT	0001	1906	73.42
1299	1666	MOSSW	4621	1462	73.26
1300	412	GRDPR	0822	627	73.24
1301	1188	SPRDL	4811	1225	73.20
1302	2834	ZEPHR	2404	181	73.04
1303	1040	BRCRK	6521	1428	73.03
1304	970	THRNE	0005	1351	73.02
1305	1047	WELRD	0008	1125	72.94
1306	1914	WNDRC	0262	230	72.92
1307	1285	WFALS	0133	1672	72.74
1308	921	TAYLR	1201	1774	72.74
1309	1553	SGOVL	1404	2184	72.48
1310	1415	MSTLT	1054	609	72.38
1311	2391	BRCRK	6512	1784	72.34
1312	197	TYOMN	1410	1535	72.24
1313	2178	HLSBR	1203	1643	72.23
1314	1305	GVFTW	1801	667	72.14
1315	642	NPKWY	0006	4874	72.07
1316	321	LKMNT	0005	680	72.07
1317	1498	FRFWS	3002	850	72.06
1318	2299	WNDRC	0232	646	72.04
1319	1597	BOWEN	3151	1944	71.85
1320	807	HDWLK	3001	970	71.84
1321	931	BLMND	3231	1227	71.73
1322	79	BKWST	0001	386	71.73
1323	956	JKSBR	1402	1427	71.58
1324	834	PLSTH	1301	722	71.58
1325	1750	DIBOL	1506	613	71.57
1326	907	RWDHV	1906	639	71.48
1327	1899	IRVNG	1405	1163	71.20
1328	387	CNTRY	2813	3070	71.03
1329	1567	PLKST	0008	1699	70.98
1330	1319	TATSP	4311	1873	70.87
1331	2217	MSTLT	1063	976	70.78
1332	1999	LIPAN	1303	268	70.73
1333	240	WEBBS	8623	2800	70.70
1334	1398	CRLTN	1406	1202	70.68
1335	2631	DFWSW	2203	39	70.67
1336	2901	MCDMT	2553	1926	70.49
1337	503	ENTOH	0002	808	70.46
1338	1494	CMPWI	0004	1025	70.34
1339	1247	BRLSN	2052	3010	70.24

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1340	233	MTLDA	0002	1783	70.24
1341	943	ALPHA	0003	874	70.20
1342	444	SCHRD	0001	1029	70.17
1343	304	TYSTH	1201	1132	70.05
1344	2857	PWEST	1302	339	69.98
1345	90	CRANE	0331	1202	69.96
1346	1123	TYLER	1012	1706	69.90
1347	1847	EZACH	0004	1171	69.75
1348	270	RKCRK	6112	2322	69.67
1349	2513	TMPLE	1202	1362	69.54
1350	2267	CRNRD	0004	480	69.50
1351	1572	BLTON	1803	441	69.43
1352	1987	WRTHM	5004	225	69.42
1353	490	MRTSP	1504	703	69.41
1354	1923	DAVIS	3711	678	69.21
1355	322	TRLWD	7712	3254	69.17
1356	1930	WHITE	3522	1813	68.95
1357	731	HKHTS	1603	1035	68.90
1358	2855	RGLRW	0008	36	68.89
1359	762	EUSTC	2402	815	68.85
1360	2236	CRTLD	4721	3062	68.78
1361	2564	MDLNW	1513	2469	68.70
1362	1861	IRVND	1201	976	68.61
1363	2815	WELRD	0004	802	68.55
1364	1939	DESHR	1203	1405	68.52
1365	897	BSPRW	2521	1121	68.47
1366	232	RWALS	1853	2350	68.46
1367	2414	HURST	1831	1366	68.44
1368	547	MRSDO	9621	1843	68.43
1369	2387	RCHRD	1201	1436	68.34
1370	978	MSHLN	0006	1113	68.32
1371	1534	BELLS	1201	573	68.26
1372	1207	WELRD	0001	1220	68.23
1373	1732	ALPHA	0002	1260	68.20
1374	1355	PCOIT	1008	1243	68.15
1375	159	LOMAL	0011	1130	68.01
1376	2749	MKNSO	3614	2401	68.00
1377	581	BLKST	1711	1966	67.98
1378	2831	WSOTH	1019	823	67.94
1379	1657	RECCR	0002	97	67.92
1380	2466	RWALE	3326	3032	67.91
1381	590	ALLNC	6411	46	67.77
1382	769	LWSNR	2242	1374	67.76
1383	2331	SPRTN	1802	883	67.75
1384	2090	ARTHR	0452	680	67.73
1385	1497	PEGAS	2321	136	67.51
1386	2829	PROAD	0003	1140	67.45
1387	1262	BLTLN	0007	780	67.45

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1388	2624	HKBRY	1111	27	67.34
1389	2085	MLKF2	1202	455	67.28
1390	772	IVANS	1612	1049	67.25
1391	1408	DCVSO	1102	705	67.19
1392	2468	ALLNC	6421	73	67.19
1393	1073	CRSGL	1301	146	67.17
1394	1564	AYERS	4411	1210	67.13
1395	522	KILEN	1205	1329	67.10
1396	827	WDGWD	1581	604	66.99
1397	803	WHOUS	4128	362	66.85
1398	158	REYST	4129	518	66.84
1399	1539	TATSP	4323	2495	66.81
1400	1890	SSPNG	1201	1311	66.80
1401	2465	RCHRD	1206	683	66.78
1402	1384	ALDTU	9421	1764	66.76
1403	435	ELKTN	2506	1688	66.72
1404	1431	GLNHV	3922	730	66.64
1405	426	DENAV	0662	588	66.63
1406	2418	RWDHV	1905	1215	66.49
1407	138	WEBBS	8612	3384	66.48
1408	2253	GAVSW	0007	1541	66.43
1409	1804	GODRD	8142	1039	66.34
1410	1116	TMPLE	1206	720	66.23
1411	2033	BSPRG	1903	1700	66.23
1412	1943	BSPRG	1905	1608	66.15
1413	712	BNBRK	4121	5015	66.08
1414	1898	FRMBR	1803	2408	66.03
1415	2906	TERSO	2503	1097	65.99
1416	1811	KNEDL	6322	3918	65.82
1417	2164	MCGHR	2003	1298	65.80
1418	1602	DENAV	0621	1705	65.77
1419	469	GODRD	8131	1533	65.67
1420	356	SGOVL	1402	945	65.66
1421	1962	BLTSW	3203	1000	65.65
1422	2363	PALMR	2202	1051	65.63
1423	2842	BKWST	0004	1053	65.54
1424	2225	GRDPR	0892	1319	65.50
1425	1487	RBNSN	2501	1968	65.16
1426	1774	RENSW	3122	1541	65.10
1427	2011	SIKES	2411	2073	65.09
1428	1458	WTAUG	4641	574	65.08
1429	408	HLSES	0553	1930	64.99
1430	2149	GNSVL	1203	1622	64.95
1431	300	WALST	0005	249	64.94
1432	2283	JKSNR	4111	442	64.85
1433	1926	WSTHL	3642	4162	64.73
1434	2679	BRLSN	2062	3790	64.67
1435	2097	TATSP	4312	2527	64.66

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1436	421	MDTHS	1001	1700	64.63
1437	626	RSKMN	3053	497	64.57
1438	2274	SMFLD	2341	980	64.56
1439	1223	SHDYG	7831	97	64.53
1440	705	BLKST	1742	1729	64.51
1441	1850	CRTLD	4742	920	64.46
1442	2333	ABRRD	0008	1438	64.45
1443	180	REAST	1509	140	64.41
1444	261	DALLW	0001	1149	64.34
1445	821	BRYAN	0004	1301	64.32
1446	753	BNDRA	0004	722	64.06
1447	1629	WNDRC	0211	1183	64.02
1448	64	BNMAG	1201	197	63.99
1449	1026	IRVVV	2802	1034	63.89
1450	2353	WTHRE	2101	1215	63.81
1451	2138	DLEON	0111	836	63.79
1452	1379	RDOAK	1301	2475	63.70
1453	1316	BNDRA	0011	402	63.37
1454	1701	ROLTR	2922	2467	63.24
1455	587	PREST	1603	1521	63.21
1456	1703	FINKS	1801	1643	63.19
1457	2663	CNTRD	0002	1476	63.16
1458	71	CANTN	1302	1348	63.15
1459	1869	CPLSO	4312	1789	63.09
1460	458	TNPON	0001	66	63.01
1461	573	TRNTH	1502	544	62.97
1462	285	PALRD	2201	797	62.96
1463	2673	RCLNS	1401	115	62.95
1464	2323	ARLNG	1251	548	62.93
1465	242	NCDSW	3813	396	62.87
1466	1967	WNTHW	1120	1035	62.79
1467	N/A	MOSSW	4612	2281	62.75
1468	346	IRVNR	1557	3120	62.65
1469	2291	CPRCV	1407	2205	62.63
1470	450	BNTDR	0002	1784	62.60
1471	968	ADISN	1608	369	62.53
1472	764	SMPST	0002	1458	62.50
1473	318	WSTHL	3652	3207	62.49
1474	1866	ELKHR	1201	959	62.46
1475	1328	EULSO	9111	1843	62.45
1476	2356	CPRCV	1403	1437	62.40
1477	1756	CNSES	0370	1256	62.37
1478	1358	MDTHS	1003	1251	62.34
1479	1195	MKNNY	1254	2366	62.28
1480	742	CMPWI	0003	977	62.13
1481	2433	PRMED	4403	2640	62.06
1482	1580	BSPSW	0841	2117	61.94
1483	1351	TYLGE	1306	2323	61.83

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1484	1762	BLKST	1762	1033	61.81
1485	562	IRVNG	1407	1467	61.74
1486	1054	WTAUG	4613	1896	61.53
1487	1507	BDFRD	8832	984	61.50
1488	228	BRLSN	2041	3811	61.28
1489	714	GPLND	1201	676	61.26
1490	1202	PLGRV	0001	1201	61.25
1491	850	MTLDA	0003	1550	61.20
1492	990	MESQT	1306	978	61.16
1493	537	CPLSO	4322	279	61.03
1494	1112	PSHIL	1602	1077	61.01
1495	1671	WTAUG	4611	1394	60.97
1496	140	WMRLD	0002	1566	60.97
1497	305	MDDTN	4312	1173	60.95
1498	1033	WHITE	3512	1533	60.92
1499	1371	WESTS	1602	864	60.84
1500	110	LFSTH	1404	513	60.71
1501	2752	CRNSO	3911	301	60.70
1502	2397	BLMND	3221	95	60.66
1503	2536	WHITE	3532	1366	60.66
1504	1308	DALLW	0003	663	60.57
1505	1272	MESTE	1206	1288	60.53
1506	1622	DAVST	0003	1691	60.53
1507	361	MABNK	2403	1661	60.52
1508	2459	DCATR	1205	121	60.47
1509	2365	ODNTH	2053	2350	60.46
1510	1268	SMPST	0001	2088	60.38
1511	2405	WMMMR	2708	250	60.38
1512	1446	PWEST	1301	1253	60.37
1513	524	MKNSW	1601	1603	60.30
1514	785	MURPH	2751	2315	60.26
1515	1156	ATHNW	1403	2244	60.24
1516	583	LOMAL	0003	1055	60.22
1517	836	KRUMS	1201	376	60.18
1518	1578	FRMNT	0013	3105	60.08
1519	1440	DALWT	2991	1222	60.07
1520	1325	TMNTH	1605	1829	60.03
1521	2729	TMPLE	1203	126	59.70
1522	1083	IRVND	1202	1503	59.65
1523	2309	TATSP	4321	1445	59.65
1524	405	CLYVL	9322	2203	59.65
1525	93	MNWLW	1402	1531	59.64
1526	1503	PFFRD	3492	297	59.56
1527	1612	CDHIL	1802	754	59.54
1528	235	SWAN2	1803	1161	59.41
1529	1887	BDFWD	8931	1731	59.38
1530	775	MSHLN	0004	1302	59.34
1531	336	LTFRD	3021	899	59.34