

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1532	2026	LEMON	0006	709	59.28
1533	2368	BRNSO	1805	798	59.11
1534	1018	EDDYS	0712	1100	59.00
1535	2646	PFLGV	2002	2272	58.93
1536	1016	TYEST	1511	881	58.87
1537	1474	DALWT	2962	473	58.78
1538	2077	DUVAL	0421	1303	58.75
1539	1667	DFWNW	2606	18	58.61
1540	1907	HKHTS	1607	943	58.58
1541	1331	WRBND	2311	1398	58.55
1542	168	ECTHM	3311	1539	58.54
1543	2084	SWDTN	1631	1624	58.47
1544	1055	KIMBL	5021	2366	58.44
1545	1919	RECCR	0006	503	58.42
1546	1284	MESQN	1502	1089	58.40
1547	1660	FSTVW	0007	1614	58.40
1548	683	EZACH	0002	1424	58.36
1549	1810	MESQN	1501	1807	58.19
1550	2795	TMPNW	1102	680	58.10
1551	1509	OKLND	0001	1339	58.10
1552	593	CRWLY	7011	424	58.06
1553	638	BNBOR	1202	736	58.04
1554	352	MRTSP	1501	667	58.03
1555	1090	FARON	4072	1541	57.94
1556	1537	IRVNR	1506	2970	57.85
1557	1677	MSHLN	0002	1584	57.85
1558	2488	SHNRW	1614	954	57.82
1559	1427	AMLIA	0003	22	57.68
1560	1607	SSPNG	1202	1228	57.59
1561	1816	DUVAL	0473	1602	57.59
1562	2796	BANGS	1201	1498	57.53
1563	385	DCDAM	2001	799	57.52
1564	2643	BDFWD	8912	1008	57.45
1565	1075	COVEE	3405	1431	57.41
1566	828	BDFRD	8811	1703	57.30
1567	1991	MAYFD	5522	3262	57.29
1568	1133	PKRVL	1052	2361	57.27
1569	2575	PAYSW	1203	857	57.17
1570	1050	TMPTV	2405	491	57.12
1571	2042	BOWEN	3132	1779	57.12
1572	840	DENDR	0005	404	57.11
1573	1242	LKMNT	0007	1553	57.09
1574	2559	BNDRA	0005	1264	57.06
1575	1245	RCHRD	1204	1141	57.00
1576	1705	TMPNW	1104	1927	56.91
1577	1437	MEXIA	4012	1112	56.72
1578	1372	WDGWD	1522	1440	56.69
1579	1699	CMTSW	0973	1615	56.61

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1580	1646	ADMDS	6521	1593	56.51
1581	1029	CRLCC	2704	535	56.48
1582	1356	GAVSW	0004	830	56.46
1583	2146	MRSES	4012	395	56.37
1584	1407	ENSSO	2001	227	56.34
1585	2654	FRMNT	0010	2519	56.28
1586	761	MESTE	1202	814	56.24
1587	1231	CNTRY	2851	1504	56.22
1588	2463	BLTSW	3201	2607	56.19
1589	41	MNWLE	1701	672	56.02
1590	1606	GRPVN	8212	4097	56.01
1591	932	LKBLT	2105	2003	55.95
1592	1217	CRLTR	2054	105	55.93
1593	1374	MDLNW	1511	2588	55.92
1594	2475	DALWT	2982	1031	55.89
1595	1746	ROWLT	1103	1090	55.86
1596	276	BEAST	4082	515	55.78
1597	1283	SSPNG	1205	1130	55.68
1598	1479	BBTWN	1501	1954	55.56
1599	1391	SHLMT	1802	538	55.54
1600	2739	FSCRK	6724	1397	55.36
1601	1893	CRLTR	2002	1495	55.36
1602	1951	KLNTF	1805	1339	55.31
1603	395	MLFRD	2103	983	55.16
1604	181	NLNVL	2002	526	55.15
1605	2681	PCOIT	1025	2924	55.05
1606	1548	CRLTN	1407	1571	55.04
1607	327	MYPTX	2401	305	55.01
1608	2220	MRSES	3019	13	55.00
1609	1883	LVOAK	1602	936	54.97
1610	1399	WALST	0003	131	54.86
1611	1094	CDHIL	1613	2979	54.83
1612	2975	PLHWY	3703	14	54.77
1613	502	CRTLD	4724	3179	54.77
1614	927	HUDSN	1602	1707	54.72
1615	1824	EULES	8712	1071	54.68
1616	989	PRSTN	0002	1345	54.64
1617	1239	LKBRN	2402	1173	54.56
1618	1298	GRHWY	5511	1899	54.45
1619	2579	WHTRK	0005	727	54.42
1620	1540	CLLVL	0003	679	54.32
1621	1729	DAVIS	3721	1323	54.31
1622	308	HLSBR	1204	554	54.21
1623	1718	GODRD	8132	2702	53.98
1624	874	GRPVN	8223	2049	53.95
1625	1989	KEENE	1503	833	53.94
1626	1411	KFMSSO	1301	924	53.79
1627	1079	LOMAL	0008	449	53.72

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1628	398	PLSTH	1304	1310	53.70
1629	2231	KLNPS	1103	2184	53.57
1630	330	BBTWN	1502	1741	53.42
1631	325	FROKS	0001	1364	53.35
1632	1908	TRNTH	1504	818	53.32
1633	2916	COTRD	0005	228	53.30
1634	2132	HKHTS	1602	1019	53.29
1635	2460	BOWEN	3112	907	53.28
1636	572	EULES	8732	629	53.26
1637	890	CRLTR	2053	1742	53.24
1638	2362	IRVVV	2851	2972	53.10
1639	934	ALPHA	0014	515	53.01
1640	2776	ALNTH	2842	1943	52.99
1641	1118	TRPMN	4094	573	52.98
1642	2247	DFWNW	2603	10	52.89
1643	1684	ARTHR	0472	1289	52.89
1644	1737	BDFRD	8842	1465	52.87
1645	2429	KLNTF	1806	1181	52.86
1646	815	SHRSW	6621	1816	52.86
1647	1353	RYSSW	2802	4193	52.85
1648	1042	FRMBG	1752	464	52.67
1649	2237	PALRD	2204	687	52.67
1650	758	DNCNV	1906	406	52.63
1651	1641	BRHLW	7611	1628	52.61
1652	2878	WALST	0010	1083	52.59
1653	250	MNWLW	1403	926	52.57
1654	367	LSCOL	2138	1057	52.56
1655	1203	ODESA	0272	1653	52.52
1656	650	GODRD	8141	855	52.51
1657	1864	MESTE	1215	1516	52.45
1658	1871	IRVGS	1907	966	52.40
1659	2769	WELRD	0007	442	52.37
1660	614	PRNTH	1401	1343	52.35
1661	2118	MESTE	1209	1448	52.35
1662	1019	PPARK	1804	247	52.32
1663	801	DESPR	1402	1305	52.29
1664	1091	TYOMN	1405	1662	52.23
1665	1017	SMPST	0004	1991	52.15
1666	176	BRTL	1402	122	52.08
1667	2388	PCOIT	1005	1095	52.06
1668	494	MKNSO	3613	3322	52.03
1669	985	MKNKY	1205	507	52.03
1670	2442	WEAST	0617	1403	51.98
1671	1261	BRKRG	0232	1718	51.95
1672	2628	GNSVL	1223	1015	51.90
1673	1925	DNIWS	1602	1429	51.84
1674	1775	GRDPR	0852	1435	51.79
1675	2764	OKCLS	0008	1986	51.76

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1676	284	CNTRY	2814	930	51.71
1677	1376	CHNDW	1201	1190	51.65
1678	2263	FSHSW	2121	1702	51.61
1679	1998	CLBRN	1203	1574	51.61
1680	629	PPARK	1808	598	51.57
1681	373	MAYFD	5511	4142	51.57
1682	1076	CRLJL	1508	345	51.56
1683	1619	LVBRD	0008	1761	51.49
1684	961	WALST	0014	893	51.47
1685	825	THRNE	0004	811	51.44
1686	1977	MESTE	1207	952	51.41
1687	144	TYWST	2001	179	51.40
1688	684	EULTB	5721	1770	51.39
1689	1610	KNEDL	6311	2923	51.35
1690	1366	HMPHL	2762	1014	51.25
1691	1608	BLTLN	0003	589	51.13
1692	1142	COLNY	2406	811	51.11
1693	1167	CMBTP	1201	261	51.02
1694	734	OAKHL	3041	945	50.90
1695	861	LSCOL	2142	13	50.86
1696	2557	RRSTH	1703	3573	50.83
1697	1343	CRLJL	1506	1940	50.71
1698	779	ABRRD	0005	1461	50.70
1699	275	TYEST	1507	1279	50.60
1700	832	WEBBS	8624	2302	50.60
1701	1475	HUDSN	1601	971	50.56
1702	2943	DFWSW	2208	17	50.53
1703	2542	ENTOH	0008	10	50.50
1704	2105	ALNTH	2844	2188	50.43
1705	2792	EULES	8731	1426	50.43
1706	1304	ODESA	0251	1891	50.36
1707	1785	SGOVL	1401	1816	50.35
1708	1151	DAVIS	3752	502	50.35
1709	922	SHRSW	6622	1624	50.34
1710	1087	HKBRY	1106	1671	50.21
1711	920	IRVGS	1901	1388	50.11
1712	523	ODNTH	2034	2782	50.11
1713	1670	CRTLD	4711	3181	50.10
1714	2589	FLMSO	3712	865	50.07
1715	489	SPRDL	4831	1268	50.06
1716	1526	MESQW	1801	2102	50.05
1717	2089	PCOIT	1023	639	50.04
1718	1759	GRLRD	0004	1556	50.04
1719	1615	NHNSW	0003	527	50.01
1720	1098	PRSTN	0008	748	50.00
1721	745	WTAUG	4652	800	49.97
1722	1757	DNINR	1403	1198	49.95
1723	2270	NCSFA	1702	1305	49.92

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1724	34	TEGMN	3040	798	49.79
1725	2171	CLCTY	1031	1224	49.79
1726	1249	DAVIS	3762	41	49.72
1727	870	CRNDL	2403	986	49.62
1728	2322	FORSW	2025	549	49.62
1729	1682	LIGSW	1604	720	49.61
1730	2191	WTAUG	4631	1147	49.58
1731	55	NIPAK	1001	131	49.47
1732	1504	TROYS	1013	785	49.46
1733	2775	ENNIS	1901	363	49.42
1734	942	MKNGB	5312	625	49.35
1735	1225	BMTWN	1611	1843	49.35
1736	2005	LNCST	1601	681	49.30
1737	2424	LOMAL	0006	1413	49.06
1738	656	EGFRD	0001	1813	48.96
1739	2566	DAVST	0006	1150	48.88
1740	2334	RNDRK	1508	4031	48.87
1741	670	WTAUG	4632	1313	48.85
1742	1541	ODESA	0231	2115	48.82
1743	765	MSLSW	0004	411	48.76
1744	106	TYRSW	1703	1387	48.70
1745	1162	SHSTH	1305	488	48.65
1746	1695	MRDCK	0002	1699	48.57
1747	1467	PALRD	2205	333	48.52
1748	1062	DALRK	1301	1230	48.40
1749	1452	MKNSW	2603	2604	48.36
1750	2131	LOMAL	0010	1558	48.24
1751	1197	BONHM	1210	1178	48.22
1752	1383	WXNTH	2305	1067	48.15
1753	1587	CLBRN	1206	1038	48.12
1754	1692	ABRRD	0004	850	48.08
1755	2819	ARLNG	1212	122	47.92
1756	465	CRNTH	2406	1310	47.90
1757	248	TYOMN	1401	1558	47.90
1758	891	IRVNE	1303	1688	47.86
1759	1892	CHNDW	1203	844	47.80
1760	1767	ATHNW	1401	902	47.72
1761	351	SHSTH	1303	716	47.68
1762	N/A	BLMND	3211	11	47.67
1763	1074	RTHGB	1421	1661	47.67
1764	793	FRMBG	1750	41	47.66
1765	1107	CRNSO	3913	1541	47.65
1766	457	LIGSW	1608	386	47.60
1767	2153	HORNE	1991	1480	47.53
1768	2685	BLTON	1802	1410	47.53
1769	617	DALWT	2911	347	47.49
1770	501	MDLNW	1532	1965	47.45
1771	2518	CRTLD	4732	2785	47.22

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1772	1149	CGRSW	9811	58	47.20
1773	2019	NCDCH	1202	1027	47.19
1774	1455	MNSTR	1201	662	47.17
1775	795	DNISN	1205	1537	47.17
1776	2696	BLKST	1732	1224	47.14
1777	809	ARPMN	4147	600	47.11
1778	1635	EDGCF	2223	3179	47.07
1779	2642	IRVVV	2804	943	47.05
1780	1157	IRVRS	4411	1247	46.99
1781	1012	PPARK	1801	1318	46.93
1782	1201	INAIR	1411	948	46.91
1783	893	DALRK	1303	1271	46.91
1784	1410	MDWCK	0001	839	46.86
1785	1605	RWALE	3324	1508	46.84
1786	2303	PLKST	0004	1310	46.83
1787	269	MCKMY	0821	1783	46.69
1788	2491	WNRTH	1418	1780	46.66
1789	128	CLBRN	1204	1094	46.64
1790	2273	RRNES	2403	4953	46.61
1791	1562	LWSNR	2231	789	46.50
1792	1905	HKHTS	1601	1506	46.46
1793	1799	HORNE	1913	1685	46.42
1794	1103	FLINT	3212	3024	46.36
1795	1438	WXNTH	2301	1311	46.32
1796	1441	NYLDV	1202	139	46.30
1797	2602	EZACH	0003	1288	46.23
1798	2609	STNVL	1205	439	46.18
1799	886	GRLRD	0003	641	46.16
1800	2489	WCOLO	1316	2076	46.15
1801	2597	ABRRD	0003	345	46.15
1802	2243	MDLNW	1564	1275	46.12
1803	2910	RRSTH	1705	934	46.07
1804	1382	LAVON	1404	960	46.06
1805	255	EMPCT	0003	1355	46.06
1806	1627	ALLEN	2406	2630	46.06
1807	1832	MAYFD	5521	3213	46.03
1808	1706	ALLEN	2404	2057	45.99
1809	1714	RCLNS	1404	717	45.89
1810	1258	CNSES	0750	1977	45.86
1811	2813	MSLSW	0007	385	45.85
1812	2400	WNRTH	1419	306	45.84
1813	664	PREST	1601	1159	45.73
1814	1639	WWDWY	2020	1243	45.70
1815	542	HKHTS	1606	1781	45.70
1816	1828	EDGCF	2262	1019	45.64
1817	532	TSLVL	4002	2748	45.61
1818	1402	MESQT	1303	830	45.61
1819	1911	BRNSO	1807	565	45.59

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1820	652	WCOLO	1320	1439	45.50
1821	2249	ODESA	0221	252	45.49
1822	838	ANDNR	2242	512	45.43
1823	1080	CDMIL	1201	598	45.43
1824	1312	TAYLR	1203	1331	45.33
1825	1958	PCUST	2003	1028	45.27
1826	1233	ODNTH	2014	1289	45.06
1827	2173	PROAD	0002	841	45.05
1828	117	DAVST	0008	27	44.93
1829	2059	STAUG	0003	2162	44.89
1830	1069	HLTOM	2482	1163	44.88
1831	2467	HKHTS	1605	1473	44.87
1832	2341	MTLDA	0007	1785	44.84
1833	1760	MCKMY	0811	2605	44.66
1834	1565	IRVNG	1406	1278	44.63
1835	995	LKHLD	0005	1137	44.63
1836	1545	CRKET	2401	151	44.52
1837	2086	ARLNG	1232	1273	44.37
1838	1380	CDHIL	1805	621	44.36
1839	122	PWEST	1309	61	44.33
1840	1473	TYSTH	1206	1265	44.32
1841	773	HMPHL	2743	907	44.26
1842	443	RWDHV	1901	914	44.26
1843	919	ODESW	5211	1262	44.20
1844	1276	GRDPR	0831	1226	44.18
1845	265	PLANO	1105	60	44.15
1846	582	GRLND	1606	965	44.13
1847	2292	WITTS	1703	1583	44.09
1848	1443	MESQT	1304	635	44.06
1849	1542	WATSN	5331	1114	44.04
1850	518	BOWEN	3122	1281	44.00
1851	798	BRNWD	1202	445	43.96
1852	606	SHMNE	1401	1205	43.91
1853	1986	PLSTH	1305	500	43.87
1854	783	PCUST	2009	2273	43.73
1855	2142	ARLNG	1213	1328	43.72
1856	1780	GRAHM	0711	1616	43.67
1857	1528	ENTOH	0006	1952	43.67
1858	2686	MRTNS	1503	359	43.62
1859	1647	CDCRK	1201	1253	43.56
1860	2585	ARTHR	0411	736	43.55
1861	711	ROWLT	1104	1121	43.54
1862	301	PLSTN	1001	1897	43.42
1863	2182	PCOIT	1003	1511	43.38
1864	1559	HLTOM	2411	1442	43.29
1865	2187	SACRC	5521	120	43.27
1866	1392	KLNCC	1704	2556	43.22
1867	1052	RSNHT	1181	1713	43.13

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1868	1512	LOMAL	0015	177	43.12
1869	1529	SYCRK	4511	1991	43.06
1870	1506	TMSTH	1402	1656	43.05
1871	1981	PWEST	1304	1615	42.93
1872	1936	WMRLD	0005	1616	42.85
1873	2402	BRHLW	7621	2882	42.78
1874	2710	RDOAK	1304	3370	42.76
1875	2359	MESTE	1203	174	42.72
1876	2576	PWEST	1312	1361	42.63
1877	2181	ENNIS	1903	1386	42.53
1878	2982	SMFLD	2322	41	42.48
1879	1065	HMPHL	2772	299	42.45
1880	1793	ROWLT	1101	1255	42.34
1881	2185	TRLNW	1204	581	42.33
1882	1741	SHNRW	1612	827	42.29
1883	2354	DUVAL	0462	1062	42.27
1884	2014	TRNTY	7511	1451	42.26
1885	1060	TRLWD	7721	1620	42.22
1886	460	BRLSN	2013	1104	42.20
1887	2007	MSHLN	0005	503	42.20
1888	2546	SORCY	0001	2557	42.19
1889	1424	DUVAL	0452	1274	42.08
1890	2700	WALNT	0005	992	42.07
1891	1139	RSPCK	2104	1903	42.04
1892	1323	KLNSO	4501	3429	42.04
1893	673	JEWET	1204	1331	42.02
1894	1788	HKHTS	1604	875	42.00
1895	1663	MLFRD	2101	970	41.99
1896	1782	LEMON	0008	784	41.86
1897	756	LFSTH	1408	2116	41.75
1898	2100	COMSO	1405	754	41.73
1899	1961	BLTLN	0005	881	41.67
1900	N/A	CMTSW	0957	1175	41.63
1901	2215	WNTHW	1118	1524	41.62
1902	1814	BRCKR	6523	876	41.59
1903	2162	MESWE	3611	1923	41.57
1904	1036	RGLRW	0006	36	41.53
1905	183	ALVRD	1504	158	41.46
1906	1432	WSOTH	1021	2131	41.39
1907	1984	TMSTH	1401	1823	41.35
1908	1862	JKSBR	1401	742	41.30
1909	1573	KLNPS	1104	1344	41.29
1910	679	BNDRA	0006	693	41.27
1911	732	ODNTH	2044	2091	41.23
1912	2195	PNTGO	7112	739	41.18
1913	2818	BRKRG	0221	699	41.11
1914	2766	CLBRN	1202	1002	40.94
1915	1179	PKRMX	4701	1744	40.86

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1916	2383	GVODS	3011	2282	40.84
1917	1416	MRTSP	1502	498	40.84
1918	2502	MDAIR	2922	387	40.84
1919	600	PRFTW	4211	3614	40.84
1920	694	TYEST	1509	383	40.72
1921	2389	BDFRD	8841	813	40.67
1922	2046	NPKWY	0014	6107	40.61
1923	1617	DFWNW	2604	12	40.51
1924	1860	HURST	1882	1900	40.40
1925	2281	BRLSN	2033	1671	40.39
1926	2342	IRVNR	1555	2202	40.39
1927	896	IRVNR	1508	2015	40.35
1928	620	BARRY	1802	300	40.34
1929	1302	CLYVL	9321	822	40.30
1930	84	ELCTR	1221	129	40.28
1931	700	GVODS	3031	1371	39.99
1932	607	IRVND	1208	164	39.93
1933	868	ROWLT	1107	369	39.89
1934	1519	FARON	4052	1072	39.87
1935	2577	IRVND	1203	437	39.71
1936	1309	DESPR	1406	955	39.66
1937	1735	COPEL	3053	2070	39.66
1938	1790	WNTHW	1116	675	39.61
1939	564	OKLND	0004	799	39.61
1940	1576	IRVGS	1904	958	39.57
1941	1777	PFFRD	3472	1279	39.55
1942	1176	CRLJL	1507	926	39.53
1943	2398	RDRSE	2604	3786	39.52
1944	2337	MESTE	1213	995	39.47
1945	1335	PLKST	0006	816	39.45
1946	2413	SORCY	0004	603	39.36
1947	1240	CRTLD	4734	792	39.35
1948	882	PFFRD	3462	1773	39.32
1949	1063	FRMNT	0001	850	39.27
1950	1713	GRDPR	0881	1882	39.27
1951	2395	HLSES	0542	766	39.25
1952	790	PRKRW	3341	542	39.21
1953	68	ECTHM	3331	22	39.16
1954	2876	RSNHT	1111	348	39.11
1955	167	HKBRY	1101	339	38.94
1956	2897	LSCOL	2137	774	38.79
1957	1839	LFSTH	1402	1188	38.67
1958	2840	NCSTH	1506	91	38.63
1959	1350	REAST	1506	1208	38.63
1960	1873	RGLRW	0005	51	38.63
1961	1551	ROANW	9521	1944	38.62
1962	1874	BRCKR	6511	1291	38.53
1963	856	ALLEN	2402	3343	38.51

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1964	353	ROANW	9512	1928	38.48
1965	2179	BNBRK	4111	2890	38.48
1966	2942	DFWNW	2602	27	38.46
1967	2039	FROKS	0005	1423	38.39
1968	701	PLSTN	1002	1222	38.38
1969	2143	JUDCT	0006	1213	38.36
1970	1347	RGLRW	0004	79	38.32
1971	399	GMINI	5821	1422	38.29
1972	2529	HMPHL	2791	30	38.26
1973	1872	MCWHT	3512	864	38.22
1974	1945	FROKS	0002	1567	38.22
1975	1337	MESQW	1803	1691	38.21
1976	2473	TMPTV	2402	3763	38.17
1977	2013	CDHCR	2050	809	38.16
1978	N/A	CMTSW	0977	249	38.14
1979	1267	RNDRK	1507	891	38.11
1980	2043	NHNSW	0008	587	38.10
1981	2558	BOWEN	3181	768	38.09
1982	2534	HORNE	1942	1558	38.01
1983	1724	KEENE	1501	1611	38.00
1984	1538	MESTE	1211	1171	37.99
1985	1947	LKBLT	2107	1100	37.93
1986	2470	GRDPR	0862	1564	37.88
1987	1346	CRLTR	2005	677	37.87
1988	1138	LNGLK	1604	448	37.83
1989	116	MSLSW	0008	192	37.70
1990	2242	CRLTN	1408	127	37.69
1991	2375	WELRD	0003	511	37.63
1992	1858	CLBWS	8111	1682	37.60
1993	2271	DNISN	1201	1468	37.56
1994	N/A	DENDR	0003	2224	37.51
1995	2484	STAUG	0007	1183	37.49
1996	1809	VENSW	2601	1425	37.40
1997	1937	PSHIL	1603	1594	37.35
1998	1675	CRNTH	2403	2764	37.29
1999	2222	FARON	4082	1599	37.29
2000	333	LMESA	1561	1426	37.28
2001	75	WEAST	0618	854	37.28
2002	1006	KILEN	1201	1851	37.25
2003	1199	IRVHF	2302	1408	37.24
2004	446	SYCRK	4521	3155	37.15
2005	271	QNLAN	1202	389	37.11
2006	1630	WXHCH	1201	1657	37.04
2007	1857	CRYVE	3011	289	36.97
2008	2327	CRNDL	2401	511	36.96
2009	622	PFLGV	2001	4552	36.94
2010	1997	WWDWD	3641	1483	36.92
2011	1045	KERNS	2401	554	36.88

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2012	1855	TYBLR	2801	1238	36.87
2013	2811	EULES	8714	811	36.87
2014	1877	THRNE	0008	2222	36.70
2015	2648	GAVSW	0002	930	36.64
2016	1678	DESHR	1204	1157	36.60
2017	2553	TRNTY	7541	697	36.59
2018	1190	CRSCN	1205	766	36.57
2019	1895	BLMED	1619	1036	36.54
2020	1778	LKHLD	0007	1209	36.54
2021	1010	IRVNG	1402	1142	36.47
2022	1463	ALVDO	1901	1464	36.42
2023	1082	PKRVL	1054	2567	36.38
2024	628	TAYLR	1204	2026	36.25
2025	946	HUBRD	1401	902	36.22
2026	1363	PWEST	1311	958	36.19
2027	2137	KLBRG	0002	1716	36.16
2028	2598	FRMBG	1753	708	36.14
2029	2206	MESQW	1807	1498	36.04
2030	2436	TMSTH	1406	1156	36.04
2031	2419	CNTRD	0004	1081	36.02
2032	2872	WNDWD	3672	265	36.01
2033	2355	BRNSO	1801	1568	35.91
2034	2755	TMSTH	1407	206	35.91
2035	2198	MYPRL	1803	599	35.74
2036	713	GMINI	5812	775	35.46
2037	101	CDHCR	2053	279	35.46
2038	1798	WNTHW	1119	1318	35.39
2039	2592	RRNES	2405	2628	35.37
2040	184	WEBBS	8622	1696	35.34
2041	2726	EDGCF	2252	401	35.32
2042	2062	RCLNS	1407	1390	35.20
2043	2347	COMSO	1402	946	35.10
2044	1709	DAVIS	3741	1288	35.02
2045	2367	LTVSB	5461	795	35.02
2046	1143	TMSTH	1403	1177	35.00
2047	1621	RWDHV	1903	1261	34.97
2048	2538	RSNHT	1142	946	34.96
2049	2515	HUTTO	2721	2702	34.96
2050	1389	BRCRK	6524	782	34.67
2051	2350	WNTHW	1121	749	34.55
2052	1664	MRSES	4006	529	34.53
2053	2141	CLYVL	9311	2011	34.52
2054	802	ODNTH	2013	1594	34.47
2055	1652	CRLUD	1302	152	34.43
2056	1108	CNSES	3054	1580	34.40
2057	1119	WHTRK	0001	2750	34.38
2058	2107	CLBRN	1201	1750	34.37
2059	2000	BLTON	1801	850	34.37

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2060	2280	WALST	0011	747	34.36
2061	1800	IRVBL	2502	181	34.29
2062	2407	NCSTH	1505	17	34.29
2063	491	CHROW	0001	136	34.27
2064	1993	DGNST	0002	456	34.25
2065	543	HORNE	1921	1348	34.18
2066	244	POWEL	2706	239	34.15
2067	1211	FSTVW	0001	793	33.95
2068	1878	BLMED	1617	320	33.90
2069	1687	KNLTR	0008	902	33.89
2070	1975	INAIR	1423	233	33.84
2071	1505	IVANS	1621	61	33.84
2072	2787	MESQN	1503	1890	33.83
2073	1126	IRVNG	1401	1604	33.83
2074	1015	KLNCC	1702	3779	33.83
2075	1978	LTVSB	5451	1231	33.82
2076	2017	SUNNY	2301	611	33.77
2077	1554	SHAMP	0005	1722	33.76
2078	2301	BRLSN	2023	1844	33.73
2079	2411	SHRSW	6612	1826	33.70
2080	671	CLMET	0002	1407	33.57
2081	973	BONHM	1204	840	33.55
2082	2106	WNDWD	3621	2154	33.46
2083	1369	LFEST	1901	1512	33.39
2084	1477	CRLFR	2157	2417	33.30
2085	488	PCUST	2002	821	33.28
2086	2351	HORNE	1933	1998	33.28
2087	396	ECTOR	1201	388	33.14
2088	1680	WSOTH	1017	1744	33.09
2089	1164	HMTRD	0004	1059	33.04
2090	1601	EULES	8713	2185	33.01
2091	1214	ROWLT	1105	1066	32.95
2092	1842	IRVBL	2503	1304	32.95
2093	2384	RCHRD	1202	798	32.89
2094	1413	EGFRD	0004	1864	32.86
2095	1934	KRUMS	1203	791	32.82
2096	768	KILEN	1202	1721	32.82
2097	2061	GRLWS	1704	173	32.80
2098	2449	RCHHL	0363	579	32.79
2099	881	LMESA	1512	1814	32.77
2100	1946	COPER	1202	976	32.77
2101	2733	CRLUD	1301	24	32.77
2102	2399	SHRSW	6641	1005	32.75
2103	2747	MESQN	1506	65	32.71
2104	2591	ESTLD	3611	1538	32.69
2105	1673	SHNRW	1609	1772	32.50
2106	1513	MDLNW	1594	1648	32.49
2107	417	FSCRK	6723	4515	32.47

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2108	2548	BRCRK	6543	1659	32.46
2109	905	RGFTW	6813	23	32.40
2110	464	PCOIT	1006	1040	32.40
2111	1180	IRVNG	1403	525	32.35
2112	451	MNWLW	1401	1546	32.34
2113	1289	PROAD	0005	122	32.29
2114	774	ALNSW	2654	1973	32.28
2115	310	LFKHL	2103	1954	32.16
2116	653	TYBLR	2804	2442	32.14
2117	2339	RDOAK	1303	2389	32.13
2118	2287	PRKWY	1532	2134	32.13
2119	401	WDGWD	1591	1131	32.09
2120	570	MRDCK	0001	2203	32.07
2121	1852	IRVVV	2801	2407	32.07
2122	2481	MDWCK	0005	1379	32.02
2123	1734	WCOLO	1318	1647	31.94
2124	2512	MDLNE	0121	232	31.93
2125	2229	ARMST	0005	1514	31.93
2126	797	FRMBG	1751	808	31.90
2127	2456	MESQW	1805	83	31.83
2128	2074	TRNTY	7551	1576	31.82
2129	999	HLTOM	2421	1592	31.80
2130	307	OKCLS	0004	1497	31.71
2131	596	HOLND	1901	1097	31.70
2132	2670	WATCO	2605	2709	31.67
2133	2343	WRBND	2322	847	31.64
2134	776	LWRDR	0002	994	31.56
2135	2890	WALST	0012	516	31.52
2136	2223	TMPNW	1105	829	31.50
2137	1654	RCHHL	0384	718	31.47
2138	1784	HURST	1841	1001	31.41
2139	1253	BRCRK	6514	572	31.38
2140	2919	WFALS	0124	126	31.36
2141	601	IRVVV	2853	2601	31.25
2142	418	MRSDO	9611	1762	31.24
2143	1456	PPARK	1802	606	31.23
2144	1870	CRLTR	2003	1355	31.22
2145	676	CRLFR	2152	3480	31.13
2146	1836	MDWPK	9231	2416	31.01
2147	2028	ACRLY	1711	174	30.97
2148	1171	BLTON	1804	464	30.96
2149	2443	FRMBR	1808	684	30.91
2150	2010	CRNRD	0006	353	30.75
2151	1471	DCATR	1203	929	30.58
2152	2772	CRLTR	2051	3938	30.54
2153	1521	WELRD	0002	744	30.51
2154	1763	DAVIS	3731	767	30.48
2155	693	KFMNW	1202	874	30.44

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2156	1696	ENTOH	0004	2003	30.42
2157	2262	GSTHW	1623	2529	30.33
2158	1693	CLBSN	8821	10	30.32
2159	1585	WMMMR	2707	1547	30.21
2160	2703	WALST	0002	31	30.17
2161	869	TRLNW	1202	59	30.14
2162	1216	SPRDL	4821	1363	30.10
2163	678	BRCRK	6522	2213	30.10
2164	565	GRLND	1603	313	30.09
2165	2894	WMMMR	2706	19	30.05
2166	2637	SHNRW	1607	554	30.04
2167	2127	CRSWS	1403	1801	30.03
2168	2124	VGCRK	8011	1531	30.02
2169	1425	MNWLL	1205	448	29.99
2170	1367	THRNE	0003	1252	29.98
2171	2040	LWSNR	2241	1085	29.94
2172	2428	CDHCR	2055	1321	29.93
2173	2441	GRLRD	0001	1773	29.90
2174	1324	WEAST	0616	777	29.87
2175	1321	GRMES	0511	1201	29.82
2176	1960	HUTTO	2742	4671	29.81
2177	2121	BRNAV	0784	1896	29.81
2178	2568	MCDMT	2552	876	29.80
2179	965	CRTLD	4712	1172	29.76
2180	1990	LUFKN	1205	1335	29.76
2181	1844	LKHLN	0003	1347	29.59
2182	1345	PPARK	1806	840	29.58
2183	2847	RWALL	1201	1301	29.41
2184	2255	SHSTH	1301	2221	29.37
2185	1409	MURPH	2755	3282	29.35
2186	1147	RDRSE	2601	1952	29.35
2187	1218	CRLTN	1451	474	29.28
2188	2437	MDLNE	0172	372	29.25
2189	2199	COPEL	3052	1309	29.19
2190	2653	CLLVL	0002	12	29.17
2191	2068	ATHNW	1405	882	29.14
2192	1511	RCHRD	1207	1544	29.12
2193	2859	WATSN	5382	664	29.08
2194	2037	BLKST	1721	1029	29.06
2195	221	LVBRD	0002	509	29.03
2196	2321	BDFWD	8941	1223	28.97
2197	2361	THSES	2402	1407	28.92
2198	967	SMPST	0006	844	28.91
2199	1689	MCDMT	2554	1779	28.90
2200	1193	CLYVL	9313	2010	28.88
2201	1522	OAKHL	3062	2282	28.83
2202	1796	KLNSO	4502	3190	28.81
2203	1603	ESTLD	3621	1494	28.79

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2204	1177	PFFRD	3452	871	28.72
2205	1679	JUDCT	0002	1409	28.67
2206	1904	DESPR	1408	1998	28.52
2207	111	CRLSP	1703	263	28.52
2208	1875	WHITE	3542	1671	28.48
2209	259	LOMAL	0009	1007	28.48
2210	1182	CPRCV	1402	2034	28.47
2211	992	LFSTH	1405	216	28.43
2212	2595	HNYGR	2401	468	28.41
2213	906	TYOMN	1408	1333	28.37
2214	1161	LSCOL	2116	59	28.35
2215	1058	ODNTH	2073	671	28.34
2216	2527	ARLNG	1282	839	28.32
2217	2024	DNINR	1402	389	28.30
2218	580	FHLSW	1361	983	28.23
2219	611	PREST	1604	1343	28.22
2220	2197	MEXIA	4024	345	28.22
2221	2713	HMPHL	2721	518	28.20
2222	2257	CRLTN	1402	798	28.19
2223	N/A	MDESA	4541	310	28.15
2224	2626	GRMES	0512	1195	28.12
2225	2289	RNDRK	1505	1321	28.11
2226	2644	SPRDL	4812	1205	28.03
2227	2479	HORNE	1952	1275	28.02
2228	1166	RRNES	2407	3365	27.99
2229	1386	EZACH	0006	1103	27.95
2230	1912	CMNCH	1402	1156	27.89
2231	2547	WEBBS	8621	2832	27.88
2232	1435	IRVNG	1408	1067	27.88
2233	1426	GRSMN	4028	710	27.74
2234	1669	FRNKF	0002	943	27.71
2235	2091	WKATY	1718	2215	27.69
2236	1457	STNVL	1207	971	27.69
2237	2695	MSTLT	1084	800	27.66
2238	2698	WSOTH	1022	1797	27.62
2239	2423	KILEN	1203	759	27.61
2240	2246	COPER	0402	169	27.61
2241	1719	ELKTN	2502	1564	27.59
2242	763	KLBRG	0004	1171	27.57
2243	1661	LKWOD	7432	1609	27.56
2244	1134	SHNRW	1608	1431	27.55
2245	2933	ABBOT	1901	111	27.47
2246	2650	WRTHM	5017	159	27.44
2247	2324	FSTVW	0005	1762	27.36
2248	2781	WMRLD	0009	32	27.32
2249	908	PLSTH	1302	1012	27.31
2250	424	KRGRV	2401	15	27.29
2251	2435	TATSP	4313	1612	27.26

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2252	2408	PRKWY	1561	1737	27.25
2253	2549	KNLTR	0006	947	27.22
2254	1273	RRNES	2404	4452	27.20
2255	1561	CHROW	0008	88	27.16
2256	2677	MAPLE	0001	1066	27.06
2257	782	GMINI	5811	3285	27.01
2258	1829	BSPRG	1902	2408	26.93
2259	2708	BOWEN	3142	1193	26.92
2260	1681	RCHHL	0311	978	26.89
2261	1274	BSPRG	1904	1665	26.89
2262	2827	SHDYG	7841	340	26.88
2263	1808	LOMAL	0005	395	26.78
2264	2297	IRVNR	1551	1367	26.70
2265	1637	SMFLD	2343	719	26.67
2266	1761	BLMED	1620	2019	26.65
2267	625	DALRK	1326	2807	26.65
2268	2734	BKWST	0005	918	26.61
2269	2259	KLNTF	1802	866	26.50
2270	804	PTENN	2354	524	26.45
2271	2109	WATSN	5361	2524	26.36
2272	1728	CDHIL	1803	1903	26.29
2273	2432	MCKMY	0812	133	26.26
2274	1879	PCUST	2001	579	26.22
2275	433	ELGIN	1001	539	26.21
2276	2352	HSKAV	0008	791	26.19
2277	505	FHLSW	1372	1314	26.14
2278	1257	LOMAL	0013	1056	26.13
2279	560	MKNNY	1253	156	26.09
2280	1385	CAMRN	1202	1471	26.09
2281	1609	MKNGB	5342	1257	26.04
2282	2869	WMRNR	0001	184	26.03
2283	1812	MDLNW	1521	1788	26.00
2284	958	CKRHL	0005	1226	26.00
2285	901	CRLTR	2007	1449	25.98
2286	1885	PRKRW	3352	1532	25.98
2287	2038	OKCLS	0005	197	25.98
2288	2697	FARON	4021	285	25.97
2289	2477	ALLEN	2403	1366	25.96
2290	1339	DALLW	0007	442	25.93
2291	1313	TMPLE	1204	1034	25.90
2292	1591	RSNHT	1171	2317	25.81
2293	1044	JSHUA	1302	1331	25.80
2294	2863	FSCRK	6721	1665	25.68
2295	2161	RSPVY	1706	1342	25.64
2296	1909	ODESA	0261	1455	25.57
2297	2451	WALST	0001	509	25.55
2298	2552	HKBRY	1115	15	25.48
2299	682	RNDRK	1503	3919	25.39

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2300	2200	EULSO	9122	1296	25.37
2301	915	WHITE	3511	1341	25.32
2302	1370	CLMET	0001	1592	25.30
2303	2258	EDGCF	2211	2105	25.25
2304	2735	WEAST	0619	2449	25.21
2305	1589	CLYVL	9312	1295	25.18
2306	2662	WEAST	0621	15	25.15
2307	1198	BNTDR	0001	1314	25.06
2308	2849	EULTB	5711	2295	25.02
2309	1837	BRNSO	1806	1782	25.02
2310	1592	BRNWD	1204	1779	24.97
2311	640	MESTE	1205	1640	24.91
2312	1071	BRTRD	7311	1191	24.78
2313	2260	KLNTF	1801	1114	24.76
2314	2031	RSPCK	2142	930	24.74
2315	66	IRVBL	2505	499	24.73
2316	1783	CRLTR	2052	1568	24.70
2317	1614	KNLTR	0005	2858	24.67
2318	1952	RCHHL	0321	1739	24.66
2319	643	WNRTH	1420	1165	24.60
2320	2689	MRSES	4014	18	24.56
2321	1105	IRVGS	1906	719	24.53
2322	409	ALPHA	0005	128	24.51
2323	2494	SHMNE	1403	995	24.48
2324	2390	RGLRW	0003	91	24.44
2325	1611	PSHIL	1604	1163	24.39
2326	1973	GRHWY	5512	3134	24.38
2327	120	PERIN	1511	653	24.35
2328	1739	SANSM	3923	3786	24.27
2329	2666	BLKST	1771	1214	24.19
2330	1913	SWTWR	1321	140	24.18
2331	1818	TYSTH	1208	250	24.17
2332	619	EDDYS	0710	648	24.13
2333	2160	MESFR	2101	2018	24.12
2334	1412	ROWLT	1106	1312	24.11
2335	1598	GSTHW	1641	81	24.09
2336	2771	FRMBG	1708	45	24.07
2337	2900	WMMMR	2705	1062	24.07
2338	2325	GNSVL	1204	505	24.01
2339	1595	PFLGV	2005	3802	24.00
2340	2652	HURST	1852	1508	23.93
2341	62	BLSRA	1602	158	23.90
2342	262	RRNES	2401	4972	23.87
2343	2346	ELMGV	3651	2238	23.85
2344	2509	BLMED	1618	35	23.77
2345	824	MEXIA	4040	861	23.76
2346	2638	ADISN	1604	1152	23.67
2347	2501	WATCO	2603	2950	23.63

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2348	2497	RRSTH	1702	3289	23.56
2349	2611	WFALS	0193	2233	23.54
2350	916	WHTRK	0002	1428	23.46
2351	2386	KNEDL	6332	2191	23.40
2352	2312	THRNE	0001	1771	23.31
2353	1008	ENNIS	1905	44	23.30
2354	987	RCHRD	1203	837	23.27
2355	2392	HUTTO	2711	3776	23.26
2356	2003	IRVNR	1505	1319	23.21
2357	1683	MKNSW	1603	1379	23.11
2358	2277	TLRWT	2203	815	23.08
2359	1281	CRLTN	1405	1251	22.97
2360	2102	PWEST	1310	685	22.95
2361	525	IRVNR	1507	1490	22.93
2362	1902	ARTHR	0431	471	22.88
2363	2264	ELKTN	2501	735	22.86
2364	1106	MESTE	1204	1828	22.76
2365	2593	MSTLT	1011	63	22.69
2366	2381	WSTHL	3631	3801	22.67
2367	1145	LKHLD	0002	1528	22.67
2368	1005	PRSTN	0001	907	22.63
2369	2751	SHDYG	7821	97	22.58
2370	1556	ROWLT	1102	807	22.49
2371	2082	TYLER	1002	861	22.45
2372	1349	KILEN	1204	1520	22.41
2373	2093	CRSGL	1302	1462	22.39
2374	2621	WGROB	8411	3435	22.38
2375	2073	CKRHL	0008	1666	22.28
2376	2150	RSPCK	2141	19	22.24
2377	1068	PARIS	1202	1264	22.23
2378	456	VLYRN	2951	2209	22.03
2379	2887	STNVL	1202	73	22.00
2380	717	DESHR	1206	2238	21.94
2381	2275	CRSWS	1401	1380	21.88
2382	1685	CMNCH	1401	1200	21.87
2383	2188	ALNTH	2851	2093	21.84
2384	2166	EDGCF	2231	868	21.78
2385	1301	PCUST	2010	2259	21.76
2386	2129	WSTHL	3613	3363	21.70
2387	2170	PSHIL	1601	1416	21.68
2388	1927	ELGIN	1003	2107	21.66
2389	N/A	DFWSE	2712	24	21.65
2390	1187	MKNNY	1202	1911	21.50
2391	2404	OKCLS	0007	635	21.47
2392	771	PRCTR	1601	207	21.45
2393	1980	PCUST	2005	1716	21.43
2394	1708	TLRWT	2201	1821	21.42
2395	555	BRYAN	0006	928	21.35

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2396	2759	FRMBG	1701	100	21.27
2397	1102	CKRHL	0006	258	21.25
2398	540	BRCRK	6513	1198	21.24
2399	2613	WMMMR	2702	1544	21.23
2400	2510	WFALS	0114	419	21.22
2401	2154	WDGWD	1513	865	21.21
2402	480	BKWST	0007	1839	21.21
2403	2530	MDTHN	1701	1524	21.18
2404	2684	RDRSE	2602	3262	21.11
2405	2123	HHSTH	1504	2390	21.10
2406	1085	DALWT	2921	288	21.08
2407	1600	WXNTH	2302	1308	20.95
2408	1795	MRTNS	1501	493	20.95
2409	452	PPARK	1807	889	20.89
2410	708	TYBLR	2805	2231	20.87
2411	1315	RNDRK	1506	1687	20.79
2412	2157	FHLSW	1311	1469	20.71
2413	2724	GRPVN	8231	398	20.62
2414	2632	LEMON	0001	2161	20.60
2415	957	LKBRN	2401	705	20.60
2416	2136	MSTLT	1021	1288	20.53
2417	1789	FRMBR	1801	1245	20.51
2418	2241	RANGR	4311	925	20.50
2419	2798	SHMNE	1405	795	20.46
2420	60	LIGSW	1621	49	20.44
2421	2778	WEBBS	8631	3599	20.38
2422	2655	PKRVL	1053	1069	20.36
2423	1704	CRLTN	1404	104	20.36
2424	1341	CRTLD	4731	2977	20.32
2425	829	GVODS	3072	2256	20.21
2426	2374	IRLBJ	3211	2614	20.21
2427	2165	ENNIS	1904	1264	20.14
2428	2725	RDRSE	2607	5011	20.10
2429	2020	LOMAL	0014	588	20.06
2430	964	PRCRK	0004	1497	20.03
2431	2832	IRVNR	1510	430	19.98
2432	691	ADMDS	6511	1050	19.96
2433	675	EULSO	9112	735	19.94
2434	1025	GRPVN	8211	135	19.91
2435	1888	ALLEN	2410	2338	19.83
2436	482	STNVL	1203	2267	19.83
2437	2018	GRPVN	8222	2043	19.80
2438	2641	LIGSW	1603	2517	19.79
2439	2848	VENSW	2603	32	19.66
2440	2808	KNLTR	0001	2124	19.53
2441	2302	PLSTH	1303	573	19.38
2442	1251	HMPHL	2711	524	19.31
2443	1135	CRLFR	2155	1330	19.30

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2444	1651	WTAUG	4612	1230	19.27
2445	1220	WHTRK	0004	1165	19.22
2446	529	DENDR	0008	90	19.21
2447	2797	DNISN	1206	920	19.21
2448	2731	SCHRD	0003	360	19.17
2449	1916	MDTHS	1002	1265	19.15
2450	1970	PFLGV	2003	2858	19.11
2451	1856	ALPHA	0007	1465	19.08
2452	695	MTLDA	0004	834	19.03
2453	2715	MRSES	3015	582	18.99
2454	2761	LKBLT	2101	571	18.94
2455	2180	LOMAL	0007	151	18.86
2456	1364	GRFRD	1002	382	18.85
2457	1744	ARMST	0001	282	18.81
2458	1361	WWEST	1216	250	18.80
2459	1318	DCVSO	1107	1102	18.79
2460	2472	BRYAN	0005	3880	18.77
2461	2635	LVBRD	0005	1364	18.77
2462	191	VLYRN	2954	2748	18.67
2463	238	VLYRN	2952	3425	18.65
2464	1248	RCLNS	1402	725	18.64
2465	1194	WSANG	2801	1340	18.62
2466	1575	KLNCC	1701	2312	18.61
2467	1222	DENAV	0673	61	18.58
2468	2757	PALRD	2208	1076	18.57
2469	1468	RCLNS	1408	107	18.56
2470	2239	CKRHL	0003	472	18.47
2471	646	IRVGS	1908	957	18.46
2472	1146	CPRCV	1401	1850	18.45
2473	2452	BNDRA	0001	845	18.37
2474	2732	DGNST	0004	942	18.33
2475	391	HUBRD	1402	1013	18.33
2476	476	DAVIS	3713	869	18.29
2477	2503	RSPCK	2106	348	18.29
2478	1342	DUBLN	2214	689	18.23
2479	2371	ARTHR	0422	1054	18.14
2480	880	FRMNT	0009	945	18.13
2481	2125	MTLDA	0005	1559	18.12
2482	1170	CRTLD	4722	3303	18.03
2483	1280	ELZCK	4922	19	18.02
2484	2604	ALPHA	0008	1256	18.01
2485	2711	SHAMP	0003	1775	17.89
2486	2570	PARIS	1204	1161	17.89
2487	1238	KLNCC	1703	4088	17.87
2488	61	HUDSN	1605	146	17.85
2489	1956	STAUG	0004	2075	17.83
2490	2406	FRNKF	0003	497	17.82
2491	2232	SMFLD	2311	1417	17.75

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2492	1749	RWDHV	1907	894	17.58
2493	925	ENTOH	0003	13	17.56
2494	74	MDLNE	0151	308	17.56
2495	166	BRHLW	7651	1149	17.52
2496	1963	DUVAL	0483	2254	17.51
2497	710	SORCY	0003	843	17.50
2498	2096	BLTLN	0004	640	17.45
2499	1859	PCOIT	1002	674	17.36
2500	2448	BRKNR	1221	1154	17.34
2501	2008	WMRNR	0002	431	17.34
2502	1291	MDDTN	4311	192	17.25
2503	2862	EDGCF	2221	862	17.22
2504	1141	MURPH	2752	2147	17.22
2505	1260	EMPCT	0005	71	17.09
2506	2801	CMTSW	0987	396	17.07
2507	440	PCOIT	1004	735	16.97
2508	1368	LNCST	1603	1593	16.88
2509	579	SMFLD	2323	620	16.85
2510	2858	CMPST	0003	212	16.85
2511	507	TYWST	2002	87	16.83
2512	2308	LKHLN	0008	1464	16.79
2513	2047	ATNRN	3421	1962	16.75
2514	1571	TYBLR	2802	998	16.71
2515	2823	RRSTH	1704	3261	16.67
2516	2615	PCOIT	1022	2125	16.61
2517	2909	WEAST	0620	578	16.59
2518	1983	NPKWY	0008	882	16.54
2519	2584	WTAUG	4621	445	16.45
2520	2784	WNRTH	1416	728	16.43
2521	1794	GODRD	8112	1421	16.40
2522	759	CRSWS	1402	925	16.40
2523	2057	WWDWY	2024	1440	16.33
2524	2737	RRSTH	1708	4237	16.29
2525	178	MDDTN	4321	918	16.25
2526	1915	MTLDA	0006	2011	16.20
2527	2317	CLYVL	9323	1423	16.18
2528	1444	PNTGO	7122	1097	16.17
2529	1935	PJPTR	3212	30	16.12
2530	1948	DEALY	0004	2383	16.12
2531	89	SFTLK	4011	46	16.06
2532	2314	MKNGB	5331	1451	16.05
2533	2774	SHNRW	1601	106	16.03
2534	2487	NMAIN	0282	1345	16.02
2535	903	WTAUG	4642	1270	16.02
2536	2158	CRSCN	1201	833	16.01
2537	432	WITTS	1701	2021	16.00
2538	N/A	HUTTO	2723	3621	15.99
2539	2498	BLTON	1805	1537	15.99

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2540	1755	DUVAL	0434	2491	15.95
2541	230	JKSES	3028	376	15.92
2542	1192	CRSCN	1203	1992	15.92
2543	1624	MURPH	2753	1063	15.83
2544	647	RDLML	2512	1208	15.82
2545	2219	WSANG	2802	635	15.75
2546	2608	LKHL	0001	1662	15.64
2547	1208	BRNWD	1206	1397	15.55
2548	2196	DCDAM	2002	907	15.55
2549	2122	ROLTR	2913	1727	15.47
2550	2528	ROBNW	1503	1670	15.42
2551	1436	SWDTN	1621	714	15.35
2552	2295	PALRD	2207	1126	15.33
2553	231	CRNRD	0007	754	15.30
2554	787	LWRDR	0004	804	15.30
2555	1111	MESQN	1508	1788	15.29
2556	1362	GRSMN	4029	955	15.25
2557	1623	ARLNG	1292	1563	15.23
2558	1768	ROLTR	2911	1809	15.18
2559	909	GSTHW	1611	817	15.09
2560	2573	DGNST	0007	241	15.05
2561	2430	WTAUG	4623	730	15.04
2562	2692	HMPHL	2713	130	14.96
2563	1942	SHRSW	6631	1287	14.96
2564	2254	RNDRK	1504	988	14.95
2565	677	CNEXP	0007	398	14.94
2566	2687	HHSTH	1503	1620	14.91
2567	1326	CURIE	7221	805	14.89
2568	2370	GRPTT	9921	582	14.88
2569	2495	BRHLW	7642	935	14.87
2570	N/A	DFWSE	2715	11	14.86
2571	1620	SMFLD	2392	1030	14.86
2572	1766	LIPAN	1301	510	14.82
2573	2723	AMLIA	0008	106	14.80
2574	2659	PLANO	1103	1877	14.61
2575	2282	EULTB	5731	494	14.58
2576	306	TYWST	2013	916	14.57
2577	784	PWEST	1308	921	14.53
2578	1499	PRKRW	3392	1676	14.52
2579	2290	BRNWD	1201	1583	14.49
2580	2063	EDGCF	2282	1054	14.47
2581	2578	ARLNG	1271	2077	14.41
2582	2683	TMPSE	1501	543	14.40
2583	2565	STNVL	1201	2533	14.32
2584	2932	WTAUG	4651	541	14.30
2585	685	WTHRF	2001	645	14.17
2586	1219	CNTRD	0003	1385	14.16
2587	182	GSTHW	1622	20	14.11

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2588	2044	BEAST	4088	116	14.02
2589	2767	EMPCT	0002	98	13.92
2590	2765	RWDHV	1904	516	13.91
2591	2874	IRLBJ	3221	842	13.91
2592	1769	RWALS	1851	1554	13.91
2593	2506	SPRDL	4822	1197	13.85
2594	960	CNEXP	0001	213	13.81
2595	2709	RRSTH	1701	3176	13.66
2596	2134	LKBLT	2102	1369	13.62
2597	2379	MURPH	2756	3603	13.56
2598	2667	GAVSW	0001	1712	13.53
2599	2543	STAUG	0005	1230	13.51
2600	2634	WMMMR	2703	1120	13.42
2601	1833	CLBNR	1404	1330	13.33
2602	80	SCSES	1201	281	13.28
2603	751	SNYDR	1813	324	13.27
2604	366	ECTHM	3321	1012	13.25
2605	2617	RBNSN	2504	1646	13.22
2606	2582	BKBNT	1811	679	13.09
2607	2490	WGROB	8422	2694	13.02
2608	1851	WCOLO	1317	1268	13.00
2609	2499	FRMNT	0012	475	12.97
2610	1271	DESHR	1202	1598	12.96
2611	1022	WHTRK	0007	1242	12.88
2612	1430	PRNTH	1403	20	12.87
2613	1901	LEMON	0009	1778	12.87
2614	2600	CMHBL	8121	62	12.83
2615	2719	ALPHA	0015	838	12.82
2616	2075	GODRD	8122	1053	12.82
2617	2668	SSPNG	1203	1373	12.72
2618	613	BDFWD	8922	2170	12.66
2619	788	FROKS	0006	992	12.62
2620	2838	GRHWY	5521	895	12.59
2621	429	PFFRD	3431	580	12.54
2622	2779	IRVHF	2303	86	12.54
2623	2238	RCHHL	0353	1731	12.51
2624	720	FRNKS	1202	94	12.47
2625	690	WSOTH	1018	562	12.44
2626	1472	RSNHT	1131	2718	12.28
2627	1886	CHROW	0002	110	12.25
2628	2743	DCATR	1204	654	12.23
2629	2427	FRNKF	0004	1608	12.22
2630	2794	GLNHV	3953	1631	12.21
2631	1813	SMFLD	2372	634	12.17
2632	2168	THRNE	0002	1705	12.14
2633	1064	NMAIN	0262	416	12.14
2634	1396	COPEL	3054	828	12.14
2635	2458	MCDMT	2551	2214	12.13

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2636	2478	GNSVN	1401	28	12.10
2637	2927	VGCRK	8031	1812	11.92
2638	2311	CMTSW	0927	565	11.92
2639	535	CRLFR	2153	245	11.81
2640	2348	ABBOT	1902	120	11.78
2641	1155	CTYVW	2211	1462	11.76
2642	2814	WALST	0013	386	11.64
2643	1900	CLLVL	0004	53	11.63
2644	1336	WALNT	0004	1475	11.62
2645	550	CRLFR	2159	1449	11.62
2646	2912	SCHRD	0006	488	11.56
2647	1053	IRVNG	1404	1448	11.52
2648	1721	PALMR	2201	54	11.49
2649	702	NPKWY	0011	4165	11.47
2650	2803	LAVON	1402	155	11.43
2651	2691	PFFRD	3421	858	11.43
2652	1676	FRSTN	1604	334	11.35
2653	2918	PLHWY	3701	495	11.34
2654	2913	FRMBR	1807	849	11.26
2655	605	HUTCH	1505	26	11.26
2656	2126	CLBWS	8121	268	11.24
2657	733	CRSSN	7911	834	11.21
2658	1287	LFKHL	2101	128	11.19
2659	799	LKHLD	0006	737	11.14
2660	2809	HMPHL	2792	456	11.09
2661	2816	DALWT	2952	656	11.04
2662	2717	EULSO	9121	118	11.03
2663	1189	MSTLT	1073	194	10.99
2664	1447	STNVL	1206	2519	10.90
2665	2854	HLTOM	2461	849	10.86
2666	644	FRNKF	0005	1086	10.82
2667	2394	BRNWD	1205	1151	10.76
2668	2190	DAVST	0001	576	10.76
2669	2860	CRSCN	1202	626	10.66
2670	2476	BLMGR	1901	269	10.65
2671	2265	LOMAL	0002	518	10.65
2672	2875	GRAHM	0713	401	10.63
2673	2332	BLMGR	1902	180	10.61
2674	2050	WEBBS	8633	2469	10.55
2675	757	RCHHL	0344	1247	10.55
2676	1129	ENTOH	0007	907	10.54
2677	1941	ENSSO	2003	503	10.53
2678	616	MKNKY	1204	36	10.44
2679	2843	FRMBR	1806	147	10.42
2680	2015	WEAST	0615	2153	10.35
2681	2029	DLEON	0131	737	10.31
2682	1636	DUBLN	1360	1101	10.30
2683	2133	RWDHV	1908	2306	10.26

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2684	1373	PLKST	0005	1134	10.20
2685	2522	WDGWD	1561	1498	10.17
2686	493	ENTOH	0005	1083	10.13
2687	2606	RKCRK	6111	2708	10.12
2688	2293	MESTE	1208	995	10.10
2689	2746	EMPCT	0004	340	10.07
2690	2821	VANAL	1201	603	10.05
2691	2675	BRNSO	1804	11	10.04
2692	1490	LKMNT	0001	203	10.01
2693	1286	WTAUG	4622	1005	9.98
2694	2807	SHAMP	0006	1145	9.95
2695	1227	DALRK	1309	876	9.89
2696	2886	HNTNG	1302	41	9.82
2697	806	RSPVY	1702	539	9.78
2698	1815	FRMBG	1705	281	9.75
2699	808	RGLRW	0002	215	9.67
2700	1929	GRDPR	0891	891	9.66
2701	2856	BRHLW	7631	633	9.59
2702	1266	MAYFD	5531	1185	9.54
2703	1730	KLBRG	0001	410	9.52
2704	2950	FRNKF	0008	1342	9.48
2705	2092	HORNE	1992	254	9.47
2706	1489	FRMNT	0008	1052	9.47
2707	2454	TRLNW	1201	1167	9.45
2708	2931	LEMON	0002	979	9.38
2709	612	MNWLL	1202	693	9.31
2710	2329	WTAUG	4633	1049	9.30
2711	2861	JUDCT	0008	140	9.29
2712	2865	GDNVL	1201	64	9.18
2713	1982	CNTRD	0001	2132	9.13
2714	820	IRLBJ	3212	3299	9.12
2715	2508	PFFRD	3411	317	9.11
2716	1753	BDFWD	8932	1709	9.07
2717	2661	HORNE	1981	1573	8.98
2718	2706	ROANW	9511	1459	8.96
2719	1390	IRVRS	4413	1353	8.85
2720	1700	CMTSW	0983	1080	8.77
2721	951	ALPHA	0011	1173	8.67
2722	586	REAST	1501	304	8.44
2723	2583	NHNSW	0001	469	8.41
2724	2868	KLELM	2202	2378	8.18
2725	1823	RRNES	2402	3859	8.04
2726	N/A	MLDR2	1603	505	8.04
2727	1297	LWRDR	0003	1783	8.00
2728	2877	TMNTH	1601	30	8.00
2729	1422	WTHRF	2002	1718	7.91
2730	1644	BRNWD	1203	829	7.90
2731	2802	RCHHL	0394	237	7.86

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2732	2252	TYOMN	1411	307	7.80
2733	2903	KLNTF	1803	1054	7.65
2734	2817	TMPNW	1106	1001	7.64
2735	566	FARON	4031	1142	7.60
2736	2183	TMPNW	1101	2633	7.59
2737	2768	DNINR	1401	81	7.59
2738	2688	KLELM	2204	3070	7.54
2739	2736	NPKWY	0009	1290	7.48
2740	516	KERNS	2402	378	7.46
2741	2420	RNDRK	1501	803	7.44
2742	2974	PLANO	1108	491	7.40
2743	632	ATNRN	3411	3007	7.33
2744	1265	IRVND	1206	107	7.32
2745	63	POYNR	1201	334	7.20
2746	1163	BKWST	0006	804	7.16
2747	2569	TYLER	1010	55	7.15
2748	831	VLYRN	2955	4545	7.07
2749	2560	REGST	0003	968	6.96
2750	1733	DALWT	2972	240	6.95
2751	1751	ALPHA	0001	428	6.93
2752	2480	NPKWY	0012	2231	6.91
2753	2189	BLTLN	0001	681	6.89
2754	303	CNEXP	0003	1396	6.81
2755	2208	MKNNY	1201	1311	6.81
2756	2525	DGNST	0008	117	6.74
2757	2612	LWSNR	2211	1421	6.74
2758	2871	CRNRD	0002	360	6.72
2759	2986	WXOCF	1402	13	6.71
2760	2645	SANSM	3921	1381	6.70
2761	2016	CLLVL	0001	503	6.69
2762	2935	ARLNG	1291	87	6.67
2763	2520	CMPST	0001	454	6.64
2764	1209	PFLGV	2007	3994	6.60
2765	2716	HKBRY	1103	244	6.60
2766	2783	WGROB	8412	3894	6.60
2767	2841	MNSTR	1202	268	6.56
2768	2658	STERT	2702	19	6.49
2769	2741	PCOIT	1007	849	6.46
2770	2896	ALPHA	0006	294	6.41
2771	2640	BNMNW	1102	411	6.37
2772	2833	ALPHA	0010	517	6.36
2773	2908	MDWPK	9221	769	6.29
2774	1752	CLBNR	1401	22	6.20
2775	2335	WALNT	0002	1227	6.17
2776	1288	WHTRK	0003	1276	6.07
2777	1584	MDWCK	0006	887	6.04
2778	546	BARRY	1801	84	5.93
2779	509	IRLBJ	3231	2504	5.90

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2780	245	GVOVS	3052	1324	5.79
2781	2983	WALST	0007	27	5.76
2782	2718	BLNKT	0701	280	5.61
2783	2272	PSHIL	1607	458	5.52
2784	2915	HMPHL	2752	295	5.37
2785	39	CHROW	0004	200	5.33
2786	2730	PLANO	1106	492	5.32
2787	974	PRSTN	0005	1191	5.32
2788	1821	WHTRK	0008	1514	5.30
2789	386	CHROW	0005	179	5.28
2790	2002	FRMBR	1802	1117	5.23
2791	2864	WWEST	1220	198	5.22
2792	2377	BRNSO	1808	792	5.15
2793	2824	MDWPK	9211	1274	5.15
2794	2531	HKBRY	1102	1682	5.12
2795	876	WDGWD	1552	314	5.11
2796	662	WATSN	5352	1900	5.05
2797	2403	ARLNG	1222	97	5.03
2798	2790	LMBLN	0001	2042	5.02
2799	N/A	MLDR2	1601	364	5.01
2800	1226	RNDRK	1509	1439	5.00
2801	1826	GODRD	8151	801	4.94
2802	2563	DESPR	1404	642	4.93
2803	1672	FRNKF	0001	964	4.87
2804	2079	CRNRD	0005	361	4.86
2805	538	CURIE	7231	1080	4.80
2806	692	MKNSW	2604	2101	4.79
2807	2941	CRLTR	2006	54	4.78
2808	2907	COTRD	0004	105	4.70
2809	2627	ROANW	9522	42	4.69
2810	2976	PSHIL	1605	135	4.65
2811	2567	GORMN	0411	545	4.55
2812	2945	EULSO	9141	59	4.51
2813	778	DAVIS	3723	350	4.42
2814	N/A	CMTSW	0946	865	4.35
2815	311	DAVIS	3743	200	4.31
2816	2240	BRKRG	0211	310	4.30
2817	1854	LOMAL	0012	714	4.18
2818	2507	TMNTH	1604	55	4.18
2819	2306	FROKS	0008	1514	4.14
2820	N/A	PRMED	4404	1154	4.14
2821	2523	SHNRW	1610	434	4.08
2822	2760	HKBRY	1104	121	4.02
2823	2806	MSTLT	1032	27	3.98
2824	2140	HKHTS	1608	1312	3.82
2825	2981	SMBMG	1701	29	3.77
2826	381	WEAST	0626	291	3.66
2827	674	BRTRD	7322	640	3.56

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2828	723	WALNT	0001	1468	3.56
2829	2964	LSCOL	2135	608	3.52
2830	2115	WWEST	1218	1015	3.52
2831	227	WEBBS	8634	1194	3.52
2832	2836	HORNE	1923	1572	3.42
2833	2294	PSHIL	1606	1392	3.41
2834	531	WFALS	0163	361	3.39
2835	2184	WWEST	1221	37	3.34
2836	2676	BNMNW	1101	204	3.33
2837	2879	COPER	0401	116	3.33
2838	1493	PROAD	0001	126	3.31
2839	1801	RNKSW	5412	28	3.29
2840	2284	ARMST	0011	900	3.27
2841	666	PLGRV	0004	384	3.09
2842	2581	DESPR	1401	1700	3.00
2843	2850	PROAD	0009	124	2.96
2844	1449	LAVON	1453	949	2.95
2845	2537	ARMST	0007	125	2.94
2846	1419	FRMNT	0005	483	2.89
2847	339	RSNHT	1152	1039	2.88
2848	2296	MESFR	2104	156	2.81
2849	29	KYSTN	1011	89	2.79
2850	2462	MCGHR	2004	27	2.79
2851	2599	DALWT	2992	332	2.71
2852	2505	COMRC	1204	587	2.69
2853	1183	MAPLE	0007	143	2.62
2854	2956	GSTHW	1672	40	2.60
2855	1250	MRSES	3016	41	2.57
2856	2902	TMSTH	1405	519	2.55
2857	1638	MSLSW	0003	193	2.53
2858	2753	DALWT	2941	309	2.46
2859	2649	CKRHL	0007	73	2.32
2860	2415	CNEXP	0005	463	2.31
2861	2884	SHDYG	7812	126	2.31
2862	2320	DGNST	0003	1161	2.20
2863	2594	ADISN	1603	192	2.18
2864	2845	ADISN	1602	226	2.17
2865	2193	COMRC	1201	1018	2.16
2866	2622	STERT	2701	34	2.13
2867	1429	CRSGL	1303	91	2.13
2868	1786	TYOMN	1402	1615	2.11
2869	267	RSKMN	3078	135	2.09
2870	2880	PJPTR	3221	46	2.08
2871	1465	ALPHA	0016	1817	2.07
2872	975	ELKTN	2503	839	1.97
2873	2870	SHAMP	0002	1746	1.95
2874	1311	PROAD	0008	1206	1.95
2875	2623	FRNKF	0006	1726	1.91

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2876	2926	FRMBR	1853	55	1.91
2877	N/A	MDLNE	0132	35	1.85
2878	2571	DESHR	1208	439	1.82
2879	2969	PARIS	1205	29	1.74
2880	N/A	TIODE	9622	974	1.70
2881	1488	HMPHL	2742	466	1.65
2882	2953	GSTHW	1613	93	1.64
2883	959	WEAST	0628	241	1.58
2884	2248	DGNST	0005	154	1.53
2885	2925	SMFLD	2362	63	1.52
2886	1994	WHTRK	0006	1311	1.42
2887	2882	FLMSO	3711	1661	1.41
2888	290	HKBRY	1109	129	1.31
2889	1547	VLRYN	2957	499	1.30
2890	47	BAYLC	1201	116	1.28
2891	2866	SORCY	0002	66	1.28
2892	2058	AMLIA	0006	80	1.18
2893	2911	DGNST	0001	270	1.05
2894	2660	BRYAN	0007	244	0.98
2895	297	LMBLN	0008	119	0.94
2896	2318	HMPHL	2723	48	0.94
2897	2330	STNVL	1204	828	0.93
2898	2535	TMPNW	1103	682	0.91
2899	2618	SHDYG	7832	1854	0.91
2900	777	WFALS	0143	171	0.87
2901	2895	HKBRY	1113	427	0.75
2902	2921	ROBNW	1501	849	0.73
2903	2980	RSPCK	2105	313	0.64
2904	2728	COMSO	1403	463	0.64
2905	2905	MSTLT	1042	500	0.62
2906	N/A	DNINR	1404	177	0.60
2907	635	CNEXP	0002	880	0.59
2908	2966	LSCOL	2148	1572	0.59
2909	2006	FRMBG	1706	62	0.58
2910	2839	HMPHL	2733	116	0.55
2911	1303	LOMAL	0004	145	0.53
2912	309	WALNT	0008	873	0.52
2913	2780	VGCRK	8021	211	0.50
2914	2929	WMRNR	0003	799	0.44
2915	1451	JUDCT	0003	1775	0.44
2916	2812	TYBLR	2806	214	0.43
2917	2881	BRYAN	0002	213	0.42
2918	2891	FHLSW	1382	108	0.42
2919	2756	COTRD	0008	1352	0.36
2920	2805	CNEXP	0008	414	0.36
2921	2519	WEAST	0627	205	0.35
2922	1081	CURIE	7241	713	0.34
2923	2758	JUDCT	0004	216	0.34

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2924	2799	RGFTW	6822	23	0.31
2925	2417	LWSNR	2212	1410	0.27
2926	2826	MDWCK	0008	888	0.27
2927	2087	TYLGE	1314	946	0.26
2928	2453	KNLTR	0009	861	0.24
2929	2791	INAIR	1414	766	0.24
2930	2226	BDFWD	8911	937	0.23
2931	2614	IRLBJ	3222	1033	0.22
2932	2873	CURIE	7222	970	0.20
2933	1516	MAPLE	0002	910	0.12
2934	2521	CKRHL	0004	424	0.11
2935	2917	FRMNT	0007	703	0.10
2936	2830	ARMST	0003	366	0.09
2937	2285	SCHRD	0004	1924	0.07
2938	2904	WEBBS	8613	634	0.06
2939	2928	PWEST	1306	286	0.06
2940	2924	RECCR	0005	157	0.05
2941	2934	ALLEN	2405	27	0.00
2942	486	ALPHA	0004	22	0.00
2943	N/A	ALPHA	0012	14	0.00
2944	416	AMLIA	0005	10	0.00
2945	2851	AMLIA	0007	93	0.00
2946	35	ANARN	1911	19	0.00
2947	2936	ARMST	0008	246	0.00
2948	1481	ARPCM	4169	11	0.00
2949	N/A	BLMND	3223	230	0.00
2950	2885	BRNAV	0774	205	0.00
2951	2300	CHROW	0006	82	0.00
2952	2939	COMRC	1202	49	0.00
2953	2940	COTRD	0001	11	0.00
2954	2340	COTRD	0003	109	0.00
2955	2722	CPLSO	4311	95	0.00
2956	2804	CURIE	7212	20	0.00
2957	983	DALLW	0002	62	0.00
2958	N/A	DFWSE	2710	72	0.00
2959	N/A	DFWSE	2713	17	0.00
2960	202	DFWSW	2202	57	0.00
2961	2213	DFWSW	2204	24	0.00
2962	2946	EXPKY	8112	11	0.00
2963	2457	EXPKY	8141	23	0.00
2964	N/A	FBRIW	1901	305	0.00
2965	136	FRMBG	1702	62	0.00
2966	2947	FRMBG	1703	31	0.00
2967	1838	FRMBG	1704	37	0.00
2968	2948	FRMNT	0006	12	0.00
2969	N/A	GLSCN	6221	20	0.00
2970	2954	GSTHW	1651	13	0.00
2971	2955	GSTHW	1662	13	0.00

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
2972	2957	INAIR	1421	18	0.00
2973	2793	INAIR	1442	114	0.00
2974	2962	KNLTR	0007	12	0.00
2975	2630	LKWOD	7421	43	0.00
2976	1244	LUFKN	1204	33	0.00
2977	2754	MAPLE	0008	214	0.00
2978	2545	MDDTN	4322	26	0.00
2979	2899	NPKWY	0007	180	0.00
2980	N/A	PAULN	2503	115	0.00
2981	2971	PJPTR	3231	25	0.00
2982	2973	PJPTR	3242	76	0.00
2983	1365	PROAD	0006	133	0.00
2984	2977	PTENN	2356	14	0.00
2985	N/A	PWEST	1305	15	0.00
2986	2978	REGST	0007	10	0.00
2987	2421	RNKSW	5413	37	0.00
2988	2266	RRWES	1603	11	0.00
2989	N/A	RRWES	1623	716	0.00
2990	2699	RSPCK	2133	778	0.00
2991	2669	RVRFT	0001	28	0.00
2992	N/A	SCHRD	0002	297	0.00
2993	993	SCHRD	0008	74	0.00
2994	2369	SHSTH	1302	20	0.00
2995	2607	STERT	2703	333	0.00
2996	2401	STERT	2704	10	0.00
2997	2985	WMMMR	2704	18	0.00
2998	2610	WWEST	1217	102	0.00

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

INTERRUPTION CAUSES

Provide the percentage of interruptions attributable to each cause.

2016 Reporting Year

Causes of Forced Interruptions	Percentage
Weather (Including Lightning)	14%
Vegetation	15%
Animals and Birds	15%
People (Including cars and farm equip)	5%
Utility-owned Equipment	42%
Other	3%
Unknown	6%