



Control Number: 46717



Item Number: 9

Addendum StartPage: 0

FILED

RECEIVED

2017 FEB 14 PM 2:58

PUBLIC UTILITY COMMISSION  
FILING CLERK

**Service Quality Report**  
To The  
**Public Utility Commission of Texas**  
In Accordance With  
**Substantive Rule §25.81**  
**2016 Reporting Year**

**AEP Texas - (central division)**  
(f.k.a. AEP Texas Central Company)

**Project 46717**

Service Quality Report to the Public Utility Commission of Texas

**AEP Texas - (central division)**

<b>System SAIDI</b>	<b>Jan</b>	<b>Feb</b>	<b>March</b>	<b>April</b>	<b>May</b>	<b>June</b>	<b>July</b>	<b>Aug</b>	<b>Sept</b>	<b>Oct</b>	<b>Nov</b>	<b>Dec</b>	
<b>Forced</b>													
<b>2016</b>	150.94	10.56	6.01	12.99	13.12	26.73	14.66	7.61	12.85	10.23	6.31	14.75	15.15
<b>Scheduled</b>													
<b>2016</b>	7.47	0.47	0.67	- 0.34	0.54	0.62	1.48	0.40	0.53	1.02	0.50	0.48	0.42
<b>Outside Causes</b>													
<b>2016</b>	17.27	0.08	1.12	0.97	5.72	1.51	0.50	0.97	1.15	0.63	0.52	1.64	2.46
<b>Major Events</b>													
<b>2016</b>	106.77		13.22	59.91	24.33	7.29						2.02	

Service Quality Report to the Public Utility Commission of Texas

**AEP Texas - (central division)**

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value	Comments
58	177	RANDADO	94LA8350	137	3.657	
59	176	MORRIS STREET	94CS8830	1,539	3.643	
60	137	WEST HARLINGEN	94SB3720	2,032	3.620	
61	631	FULTON	94CS440	2,114	3.596	
62	267	CARRIZO SPRINGS	94LA910	869	3.562	
63	608	LEARY LANE	94CN6175	2,546	3.542	
64	123	SUNCHASE	94SB1150	1,326	3.494	
65	311	PLACEDO	94CN7980	414	3.486	
66	287	ODEM	94CS375	1,045	3.475	
67	547	COTULLA	94LA610	1,520	3.455	
68	21	BIG WELLS	94LA2630	26	3.423	
69	261	GOVERNMENT WELLS	94LA6800	226	3.416	
70	609	MCCOLL ROAD	94SB4400	1,311	3.400	
71	204	RANGERVILLE	94SB3420	762	3.390	
72	74	HIGHWAY 9	94CS6780	815	3.373	
73	543	GOODWIN	94SB4390	420	3.360	
74	673	HOLLY	94CS1220	3,473	3.354	
75	677	SANTO NINO	94LA75	1,507	3.301	
76	152	PHARAOH	94CS5175	1,131	3.294	
77	457	NORTH MCALLEN	94SB5055	3,220	3.286	
78	8	GANADO	94CN5795	466	3.268	
79	64	TAFT	94CS1260	210	3.262	
80	33	ARANSAS PASS	94CS660	803	3.250	
81	241	PLEASANTON	94LA9505	1,704	3.232	
82	266	REFUGIO	94CN1040	172	3.209	
83	633	KENEDY	94CN6270	559	3.186	
84	648	EAGLE PASS CITY	94LA450	1,024	3.178	
85	399	CABANISS	94CS80	1,265	3.169	
86	174	ARANSAS PASS	94CS1250	426	3.117	
87	24	LULING - LCRA	94CN10	399	3.105	
88	518	WASHINGTON STREET	94LA6355	999	3.098	
89	440	SANTO NINO	94LA695	1,607	3.097	
90	418	SANTO NINO	94LA645	1,399	3.095	
91	621	WESMER	94SB9705	1,031	3.081	
92	101	GILA	94CS7840	755	3.069	
93	2	CONTINENTAL	94SB4880	64	3.063	
94	297	MOCKINGBIRD	94CN370	34	3.029	
95	737	RODD FIELD	94CS3010	1,976	3.019	
96	476	THREE RIVERS	94CN8430	188	3.016	
97	233	LYTLE	94LA2850	661	2.988	
98	11	BONNIEVIEW	94CS8020	535	2.981	
99	314	ARCADIA	94CS5030	1,587	2.934	
100	116	ASPHALT MINES	94LA500	42	2.929	
101	289	CAMPWOOD	94LA2610	942	2.929	
102	148	VILLA CAVAZOS	94SB7615	1,031	2.876	
103	279	EAST HARRISON	94SB3950	587	2.853	
104	358	WEIL TRACT (138/12KV)	94CS2520	74	2.824	
105	277	ZAPATA	94LA2710	45	2.822	
106	378	BUENA VISTA	94LA8965	923	2.793	
107	312	BEEVILLE	94CN2200	741	2.781	
108	216	PARKER	94CN9260	112	2.741	
109	104	DARST	94CN790	247	2.725	
110	53	HEARN ROAD	94CS8990	1,246	2.722	
111	347	GOLIAD	94CN8220	1,029	2.721	
112	419	EDNA	94CN5775	506	2.719	
113	178	PLACEDO	94CN7970	480	2.696	
114	6	MAVERICK	94LA9680	752	2.677	
115	247	MORRIS STREET	94CS5655	851	2.653	
116	604	GOVERNMENT WELLS	94LA7250	541	2.647	
117	124	PREMONT	94LA6570	744	2.637	
118	173	MAGRUDER	94CN7870	1,283	2.623	
119	102	KINGSVILLE	94CS1350	392	2.617	

Service Quality Report to the Public Utility Commission of Texas

**AEP Texas - (central division)**

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value	Comments
182	421	SOUTH MCALLEN	94SB3640	318	2.176	
183	354	VICTORIA POWER PLANT	94CN8170	797	2.174	
184	536	ANNA STREET	94LA2250	1,554	2.172	
185	577	EDROY	94CS6980	188	2.170	
186	166	MAGRUDER	94CN245	1,224	2.170	
187	117	FALFURRIAS	94LA2830	1,429	2.167	
188	244	GOODWIN	94SB4380	1,509	2.165	
189	430	SOUTH MCALLEN	94SB3935	969	2.162	
190	235	YORKTOWN	94CN3130	463	2.158	
191	395	PHARAOH	94CS1185	1,611	2.157	
192	372	SANTO NINO	94LA515	2,032	2.155	
193	269	WESMER	94SB4050	1,959	2.119	
194	222	EAST HARRISON	94SB3000	521	2.117	
195	82	NORTH ALAMO	94SB3610	1,843	2.103	
196	300	CRYSTAL CITY	94LA1425	1,124	2.096	was 94LA190
197	126	WOODSBORO	94CS8330	1,103	2.080	
198	349	SOUTH SANTA ROSA	94SB1235	647	2.080	
199	162	WEST OSO	94CS9090	1,671	2.079	
200	672	STADIUM	94LA7810	1,603	2.077	
201	556	SABINAL	94LA485	487	2.076	
202	370	EL GATO	94SB780	1,660	2.066	
203	294	KLEBERG	94CS280	1,276	2.061	
204	729	SOUTH MISSION	94SB3940	836	2.059	
205	588	SHARYLAND	94SB2150	1,475	2.053	
206	581	HIGHWAY 9	94CS9830	144	2.049	
207	140	AIRLINE	94CS7390	1,978	2.043	
208	492	MILO	94LA6940	356	2.037	
209	286	NORTH MERCEDES	94SB4860	1,506	2.029	
210	636	KLEBERG	94CS8140	656	2.029	
211	79	BAY CITY	94CN6670	1,605	2.024	
212	465	WEST HARLINGEN	94SB3800	1,377	2.020	
213	628	BAY CITY	94CN5960	2,066	2.015	
214	54	CATARINA	94LA2380	195	2.010	
215	326	HOLLY	94CS9675	1,773	2.003	
216	95	GILA	94CS345	55	2.000	
217	463	HOLLY	94CS1480	1,733	1.997	
218	359	PREMONT	94LA6610	821	1.988	
219	682	WEIL TRACT (138/12KV)	94CS5405	172	1.983	
220	107	ARANSAS PASS	94CS9130	409	1.980	
221	583	ELSA	94SB3500	1,202	1.979	
222	429	UNIVERSITY	94LA950	2,335	1.954	
223	155	DEL RIO CITY	94LA420	2,233	1.943	
224	611	KINGSVILLE	94CS1670	433	1.924	
225	84	HARLINGEN S.S.	94SB4230	1,332	1.904	
226	616	DIMMIT	94LA4120	1,297	1.897	
227	528	RIO GRANDE CITY	94SB3210	1,831	1.882	
228	42	BRACKETTVILLE	94LA8460	1,172	1.875	
229	473	GOODWIN	94SB3530	348	1.856	
230	293	BROWNSVILLE	94SB3050	1,952	1.842	
231	642	CASA BLANCA	94CS55	847	1.841	
232	356	MAYBERRY	94SB3160	560	1.832	
233	486	CHARLOTTE	94LA2790	195	1.810	
234	26	CABANISS	94CS75	2,192	1.803	
235	255	SINTON	94CS180	952	1.800	
236	212	MATHIS	94CS340	1,492	1.786	
237	290	NORTH VICTORIA	94CN1580	1,024	1.785	
238	231	POLK AVENUE	94SB4170	1,770	1.784	
239	285	BLACK BAYOU	94CN1120	331	1.776	
240	389	HOLLY	94CS7740	2,032	1.768	
241	164	LA PRYOR	94LA580	230	1.761	
242	17	DEL RIO CITY	94LA1930	1,030	1.750	
243	169	FALFURRIAS	94LA5210	1,137	1.723	

Service Quality Report to the Public Utility Commission of Texas

**AEP Texas - (central division)**

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value	Comments
306	27	GREGORY	94CS5900	125	1.416	
307	329	KINGSVILLE	94CS1130	2,254	1.415	
308	439	ARCADIA	94CS1400	434	1.415	
309	387	DEVINE	94LA8100	1,566	1.413	
310	562	GEORGE WEST	94CN730	937	1.400	
311	115	BIG WELLS	94LA1570	438	1.397	
312	655	MCCOLL ROAD	94SB1655	1,332	1.395	
313	41	SABINAL	94LA200	444	1.394	
314	240	CAMPWOOD	94LA3430	93	1.387	
315	318	LA PRYOR	94LA2440	700	1.386	
316	62	PALACIOS	94CN8550	42	1.381	
317	144	HARLINGEN	94SB380	2,418	1.380	
318	342	PETTUS	94CN1020	453	1.377	
319	238	ARCADIA	94CS6930	1,486	1.373	
320	446	OLMITO	94SB4275	778	1.370	
321	172	SOUTH MISSION	94SB5215	1,268	1.365	
322	282	INGLESIDE CITY	94CS8050	1,272	1.361	
323	250	JOURDANTON	94LA5695	685	1.359	
324	257	BEEVILLE	94CN490	944	1.349	
325	464	NORTH PADRE ISLAND	94CS1010	2,073	1.343	
326	670	SOUTHSIDE	94CS8035	1,085	1.333	
327	190	PHARAOH	94CS1285	1,773	1.330	
328	258	ARANSAS PASS	94CS8270	667	1.328	
329	226	SOUTHSIDE	94CS7905	1,821	1.328	
330	295	UVALDE	94LA9770	1,498	1.325	
331	532	SOUTHSIDE	94CS8055	856	1.325	
332	60	BRUNI	94LA1100	624	1.324	
333	88	OLMITO	94SB715	589	1.323	
334	705	STADIUM	94LA7800	679	1.321	
335	353	RODD FIELD	94CS225	2,333	1.320	
336	196	DEL RIO CITY	94LA440	1,110	1.310	
337	194	FREER	94LA2900	166	1.307	
338	514	WEAVER ROAD	94CN1910	23	1.304	
339	112	CRESTONIO	94LA260	1,764	1.304	
340	59	LAREDO HEIGHTS	94LA9400	1,421	1.297	
341	695	PORT ARANSAS	94CS3030	863	1.294	
342	606	BISHOP	94CS2690	569	1.292	
343	488	KNIPPA	94LA6365	319	1.288	
344	425	NORTH VICTORIA	94CN6390	1,505	1.285	
345	554	ASHERTON	94LA2660	612	1.283	
346	47	BRUNI	94LA1120	288	1.281	
347	256	CASA BLANCA	94CS1300	279	1.280	
348	589	RODD FIELD	94CS2190	2,735	1.279	
349	198	NORTH MCALLEN	94SB3830	1,350	1.267	
350	91	WOOLRIDGE	94CS1170	1,688	1.263	
351	192	HOLLY	94CS1370	1,903	1.262	
352	620	VICTORIA POWER PLANT	94CN8070	605	1.255	
353	308	ARCADIA	94CS8570	1,459	1.243	
354	727	KITTIE WEST	94CN3760	177	1.243	
355	381	WEST MCALLEN	94SB4505	1,817	1.241	
356	726	KARNES CITY	94CN2315	1,042	1.240	
357	87	PALMHURST	94SB1300	2,028	1.239	
358	524	PUEBLO	94LA130	2,375	1.235	
359	423	HARLINGEN S.S.	94SB4110	844	1.235	
360	408	PHARR	94SB1625	1,447	1.234	
361	1	CARRIZO SPRINGS	94LA860	30	1.233	
362	427	RAYMONDVILLE #1	94SB620	631	1.233	
363	479	CITRUS CITY	94SB9775	1,512	1.220	
364	601	COTULLA	94LA90	232	1.211	
365	98	NORDHEIM	94CN3380	176	1.210	
366	615	SHARYLAND	94SB2020	2,385	1.203	
367	697	LAREDO HEIGHTS	94LA2100	2,114	1.200	

Service Quality Report to the Public Utility Commission of Texas

**AEP Texas - (central division)**

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value *	Comments
430	575	THREE RIVERS	94CN2010	310	0.977	
431	371	ALAZAN	94CS2740	33	0.970	
432	753	MCCOLL ROAD	94SB4910	344	0.968	
433	334	WESLACO UNIT	94SB5970	2,350	0.952	
434	694	ROCKPORT	94CS5940	69	0.942	
435	538	RIO BRAVO	94LA5	719	0.933	
436	404	EL CAMPO	94CN6370	742	0.925	
437	505	LEARY LANE	94CN7530	2,950	0.921	
438	96	SOUTHSIDE	94CS5335	1,295	0.919	
439	634	PREMONT	94LA2720	757	0.919	
440	618	WEST MCALLEN	94SB4555	1,665	0.909	
441	135	RIO RICO	94SB5050	1,767	0.899	
442	503	FREER	94LA6320	158	0.892	
443	263	CONOCO-CHITTAM RANCH	94LA8580	27	0.889	
444	470	VILLA CAVAZOS	94SB1980	1,611	0.888	
445	659	EL CAMPO	94CN2860	1,473	0.886	
446	67	EDNA	94CN5765	1,133	0.883	
447	714	GOODWIN	94SB4625	1,824	0.868	
448	317	CITRUS CITY	94SB3470	1,544	0.864	
449	195	UVALDE	94LA5060	1,333	0.854	
450	264	GREENLAKE	94CN2740	34	0.853	
451	142	NORTH VICTORIA	94CN7440	1,594	0.851	
452	93	MORRIS STREET	94CS2515	1,084	0.849	
453	251	SAN BENITO	94SB3910	1,791	0.849	
454	284	NORTH EDINBURG	94SB560	1,020	0.839	
455	622	LEARY LANE	94CN6005	1,405	0.830	
456	322	FULTON	94CS6070	3,395	0.824	
457	56	NORTH MCALLEN	94SB2750	3,475	0.824	
458	637	POLK AVENUE	94SB4610	1,193	0.821	
459	573	COLUMBUS	94CN930	918	0.819	
460	544	RACHAL	94LA8145	347	0.813	
461	252	LOS FRESNOS	94SB2160	1,307	0.810	
462	748	ANNA STREET	94LA5780	693	0.799	
463	428	GOLIAD	94CN6540	1,200	0.793	
464	136	KLEBERG	94CS1560	1,368	0.792	
465	159	MORRIS STREET	94CS8715	1,600	0.789	
466	568	GEORGE WEST	94CN1320	715	0.783	
467	497	LOS FRESNOS	94SB7270	2,161	0.782	
468	183	MUSTANG ISLAND	94CS8510	457	0.777	
469	741	NORDHEIM	94CN4275	76	0.776	
470	245	SAN DIEGO	94LA2890	1,037	0.774	
471	348	BAY CITY	94CN6450	965	0.765	
472	130	CLARKWOOD	94CS7610	114	0.754	
473	747	SANTO NINO	94LA70	2,585	0.753	
474	218	VICTORIA POWER PLANT	94CN7600	166	0.753	
475	260	NORTH EDINBURG	94SB3570	2,038	0.735	
476	229	GREGORY	94CS5920	648	0.735	
477	411	WADSWORTH	94CN8630	677	0.730	
478	715	RACHAL	94LA6595	322	0.720	
479	466	RIO GRANDE CITY	94SB3220	1,801	0.715	
480	417	JOURDANTON	94LA880	317	0.710	
481	392	CHARLOTTE	94LA8120	203	0.709	
482	338	PORT ISABEL S.S.	94SB9295	2,188	0.708	
483	483	POINT COMFORT	94CN2460	332	0.708	
484	362	NORTH MCALLEN	94SB9660	1,997	0.700	
485	515	EL CAMPO	94CN7710	1,060	0.695	
486	292	HALL ACRES ROAD	94SB3460	3,260	0.689	
487	632	WESMER	94SB4480	2,684	0.688	
488	9	CAUSEWAY	94SB4795	1,225	0.683	
489	587	PLEASANTON	94LA120	1,231	0.677	
490	272	TAFT	94CS5230	853	0.675	
491	603	BAY CITY	94CN1110	1,279	0.669	

Service Quality Report to the Public Utility Commission of Texas

**AEP Texas - (central division)**

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value	Comments
554	723	LEARY LANE	94CN1540	797	0.425	
555	158	NORTH MCALLEN	94SB2980	1,767	0.425	
556	529	EAGLE PASS CITY	94LA2745	935	0.422	
557	280	MAGRUDER	94CN6680	696	0.421	
558	468	BIG OAK	94CN420	140	0.421	
559	352	LAREDO HEIGHTS	94LA2450	2,540	0.420	
560	276	YORKTOWN	94CN8420	653	0.418	
561	391	NORTH VICTORIA	94CN1470	484	0.417	
562	298	STADIUM	94LA7490	1,285	0.416	
563	119	EAST HARRISON	94SB4360	1,721	0.413	
564	585	DILLEY	94LA6400	175	0.411	
565	559	SOUTHSIDE	94CS7955	1,063	0.409	
566	584	ALICE	94LA2530	1,432	0.409	
567	502	SEAWALL	94CS9325	1,510	0.407	
568	472	AIRLINE	94CS9605	712	0.406	
569	313	SOUTH SANTA ROSA	94SB1240	1,601	0.403	
570	560	TYNAN	94CS1855	132	0.402	
571	303	ALICE	94LA1770	1,628	0.399	
572	593	HARLINGEN	94SB360	2,450	0.396	
573	147	VICTORIA POWER PLANT	94CN1390	1,142	0.396	
574	307	LEARY LANE	94CN1430	1,740	0.394	
575	234	HAIN DRIVE	94SB9700	1,062	0.392	
576	548	NORTH WESLACO	94SB4830	501	0.391	
577	475	WESLACO UNIT	94SB2195	1,093	0.390	
578	138	HAMILTON ROAD	94LA9665	961	0.390	
579	108	SAN BENITO	94SB4135	1,251	0.388	
580	540	PALMVIEW	94SB7595	2,691	0.387	
581	627	BEEVILLE	94CN8090	1,362	0.383	
582	344	SOUTHSIDE	94CS8045	1,012	0.380	
583	319	GREGORY	94CS420	458	0.380	
584	73	RANGERVILLE	94SB3410	840	0.379	
585	684	SHARYLAND	94SB6745	2,082	0.378	
586	61	BEEVILLE	94CN8510	838	0.376	
587	541	SOUTHSIDE	94CS7995	1,566	0.375	
588	614	FREER	94LA5200	1,010	0.374	
589	68	SINTON	94CS1750	506	0.374	
590	496	MATHIS	94CS1420	916	0.372	
591	448	BROOKHOLLOW	94CN7190	282	0.369	
592	109	LAREDO PLANT	94LA8505	766	0.369	
593	651	RAYMONDVILLE #1	94SB800	728	0.367	
594	199	LOLITA	94CN6330	30	0.367	
595	566	STADIUM	94LA8540	1,562	0.364	
596	288	SOUTH PADRE ISLAND	94SB5850	1,314	0.363	
597	40	ARCADIA	94CS1460	2,133	0.362	
598	193	JOURDANTON	94LA5685	1,170	0.362	
599	332	HAIN DRIVE	94SB9240	36	0.361	
600	97	UVALDE	94LA540	1,213	0.360	
601	167	BISHOP	94CS7180	930	0.355	
602	594	HAIN DRIVE	94SB8065	1,339	0.353	
603	15	CONTINENTAL	94SB3650	17	0.353	
604	650	FULTON	94CS3070	1,651	0.352	
605	384	CITRUS CITY	94SB6000	2,124	0.349	
606	146	WEST MCALLEN	94SB4815	212	0.349	
607	120	SAN DIEGO	94LA2930	571	0.347	
608	161	CAUSEWAY	94SB4765	967	0.345	
609	460	SOUTH SANTA ROSA	94SB7485	1,064	0.343	
610	315	SOUTH MISSION	94SB3620	1,958	0.343	
611	393	HALL ACRES ROAD	94SB8870	2,320	0.341	
612	243	EL GATO	94SB910	2,413	0.340	
613	531	HAIN DRIVE	94SB9690	569	0.336	
614	693	POLK AVENUE	94SB4190	1,696	0.335	
615	565	AIRLINE	94CS9030	449	0.332	



Service Quality Report to the Public Utility Commission of Texas

**AEP Texas - (central division)**

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value	Comments
678	689	ESCONDIDO	94LA1510	736	0.209	
679	625	WESLACO UNIT	94SB8610	1,190	0.207	
680	403	HEARN ROAD	94CS9665	623	0.207	
681	44	JOURDANTON	94LA250	787	0.206	
682	734	MORRIS STREET	94CS8850	493	0.203	
683	666	KINGSVILLE	94CS1660	1,846	0.200	
684	248	SOUTH MISSION	94SB3980	730	0.200	
685	323	NORTH VICTORIA	94CN2240	766	0.197	
686	653	KLEBERG	94CS6410	274	0.197	
687	676	WEST MCALLEN	94SB4595	1,163	0.195	
688	new	HOLCOMB	94LA3025	325	0.194	
689	105	FALFURRIAS	94LA1070	1,021	0.194	
690	206	COMSTOCK	94LA230	185	0.189	
691	667	MCCOLL ROAD	94SB4780	1,933	0.186	
692	375	WEST MCALLEN	94SB4965	1,049	0.186	
693	new	CRYSTAL CITY	94LA7425	431	0.186	
694	623	EAGLE PASS CITY	94LA7060	867	0.186	
695	386	GATEWAY	94LA3595	1,523	0.185	
696	80	LAREDO HEIGHTS	94LA6820	2,080	0.184	
697	434	POINT COMFORT	94CN6060	55	0.182	
698	635	CHARLOTTE	94LA1960	502	0.177	
699	742	COTULLA	94LA110	34	0.176	
700	762	MAYBERRY	94SB5770	808	0.175	
701	398	MORRIS STREET	94CS8840	596	0.169	
702	733	UNIVERSITY	94LA305	2,107	0.169	
703	413	MAYBERRY	94SB3010	91	0.165	
704	new	CASA BLANCA	94CS4170	1,010	0.163	
705	700	ARCADIA	94CS1360	1,541	0.157	
706	713	LAREDO HEIGHTS	94LA6810	2,050	0.155	
707	569	ODEM	94CS5575	65	0.154	
708	304	POLK AVENUE	94SB4520	917	0.149	
709	582	ROCKSPRINGS	94LA2600	379	0.148	
710	447	RAYMONDVILLE #1	94SB630	798	0.148	
711	720	EL CAMPO	94CN7260	527	0.148	
712	580	HEARN ROAD	94CS2220	1,534	0.146	
713	685	MCKENZIE ROAD	94CS330	2,319	0.143	
714	735	UNIVERSITY	94LA920	373	0.142	
715	656	RODD FIELD	94CS1730	2,184	0.141	
716	595	WESLACO UNIT	94SB9805	1,883	0.141	
717	749	UNIVERSITY	94LA465	825	0.139	
718	709	PHARR	94SB1640	1,279	0.136	
719	207	CLARKWOOD	94CS7220	463	0.136	
720	600	PORTLAND	94CS9270	1,509	0.135	
721	504	MINES ROAD	94LA4275	37	0.135	
722	437	BEEVILLE	94CN2380	195	0.133	
723	663	EAGLE PASS CITY	94LA2510	599	0.132	
724	732	POLK AVENUE	94SB4740	2,128	0.132	
725	230	AIRLINE	94CS8890	555	0.130	
726	605	RODD FIELD	94CS205	1,916	0.129	
727	698	WEST MCALLEN	94SB4515	1,317	0.128	
728	new	PAWNEE	94CN22202	194	0.124	
729	185	AIRLINE	94CS6970	1,254	0.117	
730	394	AIRLINE	94CS9390	2,357	0.115	
731	445	WASHINGTON STREET	94LA2470	199	0.111	
732	new	LANTANA	94CS4095	200	0.110	
733	707	POLK AVENUE	94SB4180	1,275	0.108	
734	443	DEL MAR	94LA220	2,481	0.100	
735	561	ROMA	94SB3070	1,275	0.100	
736	758	MAGNOLIA	94CN315	10	0.100	
737	458	AIRLINE	94CS8370	279	0.097	
738	572	PALMHURST	94SB3890	2,558	0.096	
739	14	NORTH PADRE ISLAND	94CS720	1,243	0.093	

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

With 10 or more Customers

Total Number of Feeders

**776**

Add or Delete Rows as Necessary

**AEP Texas - (central division)**

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value	Comment
1	322	THREE RIVERS	94CN8430	188	1,743.4	
2	26	FOSTER FIELD	94CN2550	69	1,631.9	
3	8	LA PRYOR	94LA570	142	1,622.9	
4	50	RANDADO	94LA8350	137	1,421.7	
5	182	ENCINAL	94LA2160	226	1,251.6	
6	10	RAYMONDVILLE #2	94SB3250	30	1,225.8	
7	360	NAVAL BASE	94CS9720	2,453	1,184.3	was 94CS1380
8	19	BIG WELLS	94LA2630	26	1,176.7	
9	2	GOVERNMENT WELLS	94LA7240	214	1,124.7	
10	42	CHARLOTTE	94LA2780	52	870.9	
11	34	PREMONT	94LA2730	156	861.5	
12	16	LOS FRESNOS	94SB4315	1,038	858.3	
13	560	THREE RIVERS	94CN5100	53	845.8	
14	14	PRAIRIE PUMP	94CN1940	77	818.1	
15	101	NAVAL BASE	94CS8540	1,650	806.5	was 94CS8440
16	33	GOVERNMENT WELLS	94LA6800	226	774.0	
17	173	MOORE FIELD	94SB3120	162	763.3	
18	196	PUEBLO	94LA95	1,388	745.4	
19	78	PORT ISABEL S.S.	94SB3820	213	739.4	
20	54	ZAPATA	94LA2710	45	725.9	
21	13	MAVERICK	94LA9680	752	715.1	
22	287	STAFFORD HILL	94CN1550	227	705.0	
23	429	BLESSING	94CN1030	276	691.7	
24	551	LA GRULLA	94SB4120	1,473	676.9	
25	98	SIERRA VISTA	94LA9900	2,769	669.4	
26	47	CATARINA	94LA2380	195	661.0	
27	243	ASHERTON	94LA2670	88	658.2	
28	123	CRYSTAL CITY	94LA8380	1,322	646.2	was 94LA330
29	1	RANDADO	94LA8360	167	634.6	
30	398	GARWOOD CITY	94CN2560	194	632.3	
31	119	CARANCAHUA	94CN5870	480	630.2	
32	210	MCKENZIE ROAD	94CS140	272	615.5	
33	32	ASPHALT MINES	94LA500	42	613.2	
34	567	LIVE OAK	94CS1070	2,946	611.4	
35	463	GARWOOD CITY	94CN2570	140	606.6	
36	12	GILA	94CS350	148	597.5	
37	40	MARKHAM	94CN5550	116	596.4	
38	100	RIO RICO	94SB8330	423	595.8	
39	241	FASHING	94CN360	35	595.2	
40	88	BLESSING	94CN8790	753	593.0	
41	402	WEIL TRACT (138/12KV)	94CS2520	74	572.1	
42	133	RUNGE	94CN4465	383	545.2	
43	36	MALONE	94CN7550	184	539.6	
44	550	MATTHEWS	94CN1740	168	531.4	
45	230	NORTH MERCEDES	94SB4860	1,506	510.7	
46	744	WOOLRIDGE	94CS1110	1,706	502.2	
47	455	ZAPATA	94LA8290	2,071	491.6	
48	81	PREMONT	94LA6570	744	491.4	
49	125	REFUGIO	94CN1040	172	487.9	
50	308	GANADO	94CN5815	601	487.7	
51	156	ALICE	94LA2540	979	487.5	
52	588	SOUTH MCALLEN	94SB3850	604	487.2	
53	542	NORTH EDINBURG	94SB4240	2,407	485.9	
54	30	RAYMONDVILLE #2	94SB3170	717	481.3	
55	62	BEEVILLE	94CN1760	1,796	480.1	
56	502	SANTO NINO	94LA645	1,399	471.3	
57	72	FREER	94LA1500	220	469.6	
58	661	SANTO NINO	94LA75	1,507	469.5	
59	89	TATTON	94CN8490	134	464.2	
60	134	RANGERVILLE	94SB3420	762	464.1	
61	5	CONTINENTAL	94SB4880	64	459.2	
62	177	CAMPWOOD	94LA3430	93	454.5	
63	249	SUNCHASE	94SB1150	1,326	450.0	
64	710	MCCOLL ROAD	94SB4400	1,311	445.1	
65	413	ROCKPORT	94CS5930	1,262	442.8	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas - (central division)

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value	Comment
136	275	CLARKWOOD	94CS9570	1,147	287.4	
137	556	CLARKWOOD	94CS7230	610	284.3	
138	48	BRUNI	94LA1100	624	282.5	
139	452	ROBSTOWN	94CS1650	366	280.9	
140	303	HOLLY	94CS1370	1,903	280.5	
141	683	KENEDY	94CN6270	559	280.3	
142	65	ARANSAS PASS	94CS1250	426	280.2	
143	624	SANTO NINO	94LA80	1,873	280.0	
144	39	LULING - LCRA	94CN10	399	279.5	
145	618	NORTH MCALLEN	94SB5060	2,428	279.4	
146	155	BLACK BAYOU	94CN1120	331	278.9	
147	20	GILA	94CS345	55	278.8	
148	38	DEL RIO CITY	94LA1930	1,030	277.7	
149	357	PREMONT	94LA6610	821	277.5	
150	467	HOLLY	94CS7740	2,032	276.2	
151	242	CAMPWOOD	94LA2610	942	273.8	
152	37	RIO RICO	94SB8290	392	273.4	
153	314	BUENA VISTA	94LA8965	923	271.5	
154	111	UVALDE	94LA6620	2,746	271.2	
155	665	FULTON	94CS440	2,114	270.0	
156	171	YORKTOWN	94CN3130	463	269.6	
157	215	ARCADIA	94CS5030	1,587	269.0	
158	3	CONTINENTAL	94SB4080	65	268.4	
159	310	GOODWIN	94SB4380	1,509	267.7	
160	120	BAY CITY	94CN6670	1,605	267.4	
161	185	CRYSTAL CITY	94LA2170	724	263.3	was 94LA140
162	168	PEARSALL	94LA3675	1,391	262.9	
163	620	EDROY	94CS6980	188	262.8	
164	239	PORT LAVACA	94CN8310	345	262.7	
165	479	BLESSING	94CN8780	64	262.7	
166	157	GRETA	94CN7890	277	261.5	
167	519	GOVERNMENT WELLS	94LA7250	541	261.0	
168	698	EAGLE LAKE	94CN310	736	256.8	
169	652	HOLLY	94CS7620	2,720	255.5	
170	158	HEARN ROAD	94CS8990	1,246	254.8	
171	174	SOUTHSIDE	94CS7925	1,279	254.6	
172	607	PEARSALL	94LA5580	1,572	253.0	
173	282	HOLLY	94CS1950	838	252.9	
174	292	ARCADIA	94CS1440	1,687	252.5	
175	574	KINGSVILLE	94CS1670	433	252.0	
176	354	SANTO NINO	94LA515	2,032	251.9	
177	430	ESCONDIDO	94LA2035	2,768	249.0	
178	682	TYNAN	94CS4010	42	244.2	
179	377	RIO BRAVO	94LA5	719	241.6	
180	410	BISHOP	94CS2690	569	238.2	
181	713	KLEBERG	94CS8140	656	238.0	
182	596	SHARYLAND	94SB2150	1,475	236.5	
183	313	EL GATO	94SB780	1,660	236.3	
184	301	MCCOLL ROAD	94SB2810	2,290	235.9	
185	638	PHARAOH	94CS1365	681	234.2	
186	245	NIXON	94CN3300	571	233.2	
187	409	KINGSVILLE	94CS1130	2,254	233.1	
188	161	SOUTH MCALLEN	94SB5065	122	231.2	
189	561	SABINAL	94LA485	487	231.0	
190	43	FREER	94LA2900	166	230.9	
191	135	MAGRUDER	94CN245	1,224	230.8	
192	477	SINTON	94CS6860	1,642	230.5	
193	112	TAFT	94CS1180	1,022	230.5	
194	565	RACHAL	94LA6595	322	230.0	
195	415	ROCKPORT	94CS5950	592	229.9	
196	593	ZAPATA	94LA8300	1,693	229.7	
197	614	DIMMIT	94LA4120	1,297	229.5	
198	678	WEIL TRACT (138/12KV)	94CS5405	172	227.7	
199	446	GOODWIN	94SB4390	420	226.8	
200	190	WESMER	94SB6900	1,636	226.4	
201	449	CRYSTAL CITY	94LA1425	1,124	226.3	was 94LA190
202	298	LAGUNA	94CS9065	2,180	225.8	
203	369	EAGLE LAKE	94CN9455	601	225.3	
204	107	ARANSAS PASS	94CS660	803	224.5	
205	73	GILA	94CS7840	755	222.9	

Service Quality Report to the Public Utility Commission of Texas

**AEP Texas - (central division)**

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value	Comment
276	192	SOUTHSIDE	94CS8025	1,058	166.5	
277	276	JOURDANTON	94LA5695	685	166.5	
278	46	HIGHWAY 9	94CS6730	539	165.8	
279	539	LEARY LANE	94CN1890	1,601	165.2	
280	176	WOODSBORO	94CS8330	1,103	164.5	
281	629	NORTH VICTORIA	94CN7770	817	163.5	
282	419	GATEWAY	94LA390	1,992	161.4	
283	144	ALAZAN	94CS2740	33	161.3	
284	371	HEARN ROAD	94CS870	1,172	160.6	
285	17	NIXON	94CN6630	655	160.3	
286	465	GOLIAD	94CN8220	1,029	160.2	
287	457	SOUTH MCALLEN	94SB3640	318	159.8	
288	302	WESMER	94SB4050	1,959	159.1	
289	63	SOUTH EAST EDINBURG	94SB5045	2,075	157.8	
290	187	BANQUETTE	94CS130	232	157.4	
291	294	EL GATO	94SB720	2,403	156.0	
292	348	MAGRUDER	94CN6680	696	155.9	
293	139	ZAPATA	94LA7330	1,349	155.7	
294	422	NORTH VICTORIA	94CN1580	1,024	155.5	
295	401	MORRIS STREET	94CS7625	558	154.8	
296	44	SABINAL	94LA200	444	154.5	
297	149	INGLESIDE CITY	94CS2495	281	153.2	
298	579	SOUTH SANTA ROSA	94SB1235	647	153.0	
299	280	POLK AVENUE	94SB4600	2,770	153.0	
300	295	DEVINE	94LA8100	1,566	152.7	
301	140	NORTH MERCEDES	94SB3770	1,631	152.6	
302	617	SHARYLAND	94SB2020	2,385	152.2	
303	370	ELSA	94SB3500	1,202	150.2	
304	137	GOODWIN	94SB7380	2,197	150.1	
305	28	BRACKETTVILLE	94LA8460	1,172	150.1	
306	469	WASHINGTON STREET	94LA6525	2,109	149.0	
307	127	NORTH ALAMO	94SB3610	1,843	148.8	
308	589	KLEBERG	94CS9395	1,295	147.7	
309	424	WASHINGTON STREET	94LA7015	1,545	147.6	
310	669	EAST HARRISON	94SB4620	743	147.3	
311	431	WEAVER ROAD	94CN1910	23	147.1	
312	534	NORTH MCALLEN	94SB5055	3,220	145.8	
313	503	HALL ACRES ROAD	94SB4895	857	144.1	
314	666	COTULLA	94LA90	232	143.8	
315	428	WEST HARLINGEN	94SB3800	1,377	143.7	
316	25	EDROY	94CS6990	278	143.6	
317	677	BAY CITY	94CN5960	2,066	142.5	
318	658	SHARYLAND	94SB2010	1,158	142.0	
319	368	RACHAL	94LA8145	347	141.9	
320	235	PORT LAVACA	94CN2490	1,061	141.8	
321	212	ALAZAN	94CS620	166	141.6	
322	335	HARLINGEN S.S.	94SB320	1,523	140.8	
323	254	THREE RIVERS	94CN5190	492	139.2	
324	251	NORTH PADRE ISLAND	94CS7900	2,083	138.7	
325	264	HARLINGEN S.S.	94SB4230	1,332	138.3	
326	709	PHARR	94SB1645	2,324	137.5	
327	221	SINTON	94CS360	316	137.2	
328	375	PORT LAVACA	94CN2480	1,511	136.0	
329	755	DIMMIT	94LA5545	568	135.9	
330	680	STADIUM	94LA7800	679	135.1	
331	325	SINTON	94CS180	952	134.4	
332	52	MARKHAM	94CN6440	462	133.5	
333	405	INGLESIDE CITY	94CS8050	1,272	133.5	
334	460	AIRLINE	94CS7390	1,978	133.2	
335	651	MCCOLL ROAD	94SB1655	1,332	132.2	
336	611	WESLACO UNIT	94SB7630	2,529	132.2	
337	124	DEL RIO CITY	94LA440	1,110	131.8	
338	485	ANNA STREET	94LA2250	1,554	131.5	
339	267	PHARAOH	94CS1285	1,773	131.4	
340	549	BAY CITY	94CN2050	525	131.2	
341	527	NORTH EDINBURG	94SB3570	2,038	131.0	
342	548	MAGRUDER	94CN6700	1,346	130.8	
343	136	HARLINGEN S.S.	94SB4090	2,261	130.1	
344	559	MILO	94LA6940	356	129.5	
345	70	MOORE FIELD	94SB3960	2,056	128.7	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas - (central division)

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value	Comment
416	656	BAY CITY	94CN1110	1,279	94.2	
417	141	LOS FRESNOS	94SB2160	1,307	94.1	
418	464	GEORGE WEST	94CN1320	715	93.5	
419	166	VICTORIA POWER PLANT	94CN7600	166	93.5	
420	356	EAST HARRISON	94SB3000	521	93.3	
421	708	ANNA STREET	94LA780	473	92.7	
422	696	EL CAMPO	94CN2860	1,473	92.5	
423	436	WADSWORTH	94CN8630	677	92.4	
424	253	PORT ISABEL S S.	94SB9295	2,188	92.2	
425	113	PORT ARANSAS	94CS1000	1,867	91.9	
426	160	UVALDE	94LA9770	1,498	91.2	
427	388	EAST HARRISON	94SB3030	679	90.9	
428	724	ARCADIA	94CS1400	434	90.0	
429	612	RAYMONDVILLE #2	94SB3240	941	89.5	
430	521	ANNA STREET	94LA900	2,857	89.1	
431	79	WOOLRIDGE	94CS1170	1,688	88.9	
432	442	DILLEY	94LA510	574	88.8	
433	321	CITRUS CITY	94SB3470	1,544	88.3	
434	509	PEARSALL	94LA7050	939	88.0	
435	346	TATTON	94CS950	580	87.2	
436	456	RODD FIELD	94CS2190	2,735	87.0	
437	703	GOODWIN	94SB4625	1,824	87.0	
438	746	NORDHEIM	94CN4275	76	86.8	
439	319	SAN BENITO	94SB4135	1,251	86.4	
440	181	AIRLINE	94CS9605	712	85.9	
441	411	POINT COMFORT	94CN2460	332	85.5	
442	421	WASHINGTON STREET	94LA2350	2,958	85.4	
443	491	PUEBLO	94LA130	2,375	85.4	
444	692	LAREDO HEIGHTS	94LA2390	1,702	85.2	
445	383	PALMHURST	94SB2535	1,382	85.1	
446	159	SOUTHSIDE	94CS5335	1,295	84.5	
447	510	RAYMONDVILLE #2	94SB4160	342	84.4	
448	433	SOUTH SANTA ROSA	94SB1215	1,638	82.6	
449	458	NORTH WESLACO	94SB4810	1,456	82.5	
450	630	PLEASANTON	94LA120	1,231	82.2	
451	727	KARNES CITY	94CN2315	1,042	82.2	
452	512	DILLEY	94LA3795	804	81.4	
453	162	WESMER	94SB1850	1,337	81.1	
454	523	EL GATO	94SB890	2,805	80.9	
455	394	EL CAMPO	94CN5745	914	80.1	
456	427	RIO GRANDE CITY	94SB3220	1,801	80.1	
457	358	HAIN DRIVE	94SB3490	1,102	80.0	
458	531	MUSTANG ISLAND	94CS9470	696	79.8	
459	637	PALMVIEW	94SB3930	1,115	79.8	
460	374	BAY CITY	94CN6450	965	79.7	
461	664	PORT ARANSAS	94CS990	1,554	79.1	
462	399	HALL ACRES ROAD	94SB5585	758	78.8	
463	417	BANDERA ELECTRIC (LEAKEY)	94LAL30	258	78.4	
464	653	HIDALGO	94SB3680	338	77.5	
465	450	EL CAMPO	94CN6370	742	77.3	
466	668	SHARYLAND	94SB6745	2,082	77.2	
467	490	NORTH WESLACO	94SB4830	501	76.2	
468	742	ANNA STREET	94LA5780	693	75.3	
469	261	WESLACO UNIT	94SB5970	2,350	75.2	
470	118	MOORE FIELD	94SB3110	661	75.1	
471	64	RANGERVILLE	94SB4060	887	74.9	
472	448	UNIVERSITY	94LA950	2,335	74.3	
473	659	DEL MAR	94LA10	1,964	74.1	
474	257	NORTH PADRE ISLAND	94CS1010	2,073	73.7	
475	505	RAYMONDVILLE #1	94SB800	728	73.7	
476	440	SOUTHSIDE	94CS7955	1,063	73.3	
477	517	PHARR	94SB1625	1,447	72.9	
478	639	VICTORIA POWER PLANT	94CN8070	605	72.8	
479	529	HOMEPORT	94CS4665	477	72.6	
480	489	PREMONT	94LA2720	757	72.3	
481	90	CAUSEWAY	94SB4795	1,225	72.3	
482	147	KLEBERG	94CS1560	1,368	72.1	
483	265	TAFT	94CS5230	853	72.0	
484	628	POLK AVENUE	94SB4610	1,193	71.9	
485	278	HOLLY	94CS5820	956	71.6	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas - (central division)

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value	Comment
556	418	DEL MAR	94LA3440	1,431	51.2	
557	578	HARLINGEN	94SB360	2,450	51.2	
558	577	RIO GRANDE CITY	94SB3740	2,286	50.5	
559	496	RIO GRANDE CITY	94SB3230	2,577	50.1	
560	189	LAREDO HEIGHTS	94LA9400	1,421	49.8	
561	722	LEARY LANE	94CN1540	797	49.7	
562	674	NORTH VICTORIA	94CN7860	1,489	49.3	
563	555	REFUGIO	94CN1210	187	49.3	
564	391	EL CAMPO	94CN2800	797	48.6	
565	148	THREE RIVERS	94CN2580	125	48.1	
566	423	SOUTH EAST EDINBURG	94SB4550	2,118	48.1	
567	272	CARRIZO SPRINGS	94LA370	540	47.3	
568	341	EAST HARRISON	94SB3080	417	47.3	
569	641	DILLEY	94LA6400	175	46.7	
570	97	BISHOP	94CS7180	930	46.6	
571	362	CAUSEWAY	94SB4765	967	46.3	
572	626	MCCOLL ROAD	94SB4780	1,933	46.2	
573	566	HAINES DRIVE	94SB8065	1,339	45.9	
574	594	FULTON	94CS3070	1,651	45.6	
575	new	HOLCOMB	94LA3025	325	45.6	
576	444	WESLACO UNIT	94SB2195	1,093	45.4	
577	66	DEVINE	94LA7090	972	45.4	
578	688	SKIDMORE	94CS600	368	45.3	
579	644	KINGSVILLE	94CS1660	1,846	45.1	
580	715	LAREDO HEIGHTS	94LA2100	2,114	45.0	
581	27	SAN DIEGO	94LA2930	571	44.9	
582	384	TATTON	94CS8200	1,076	44.8	
583	673	WEST MCALLEN	94SB4555	1,665	44.7	
584	571	HIDALGO	94SB4845	1,179	44.4	
585	595	EAST HARRISON	94SB3190	1,479	44.2	
586	416	KENEDY S.S.	94CN8340	346	43.9	
587	472	SEAWALL	94CS9325	1,510	43.9	
588	78	RANGERVILLE	94SB3410	840	43.9	
589	513	NORTH VICTORIA	94CN7430	1,716	43.7	
590	569	FREER	94LA5200	1,010	43.0	
591	461	COLUMBUS	94CN6180	469	43.0	
592	227	ELSA	94SB690	2,335	42.7	
593	49	ARCADIA	94CS1460	2,133	42.6	
594	573	EAGLE PASS CITY	94LA2770	2,948	42.3	
595	693	LAREDO PLANT	94LA8565	1,511	42.0	
596	318	NORTH MCALLEN	94SB2980	1,767	42.0	
597	470	ANNA STREET	94LA850	1,578	41.6	
598	395	VICTORIA POWER PLANT	94CN1390	1,142	41.3	
599	201	NORTH MCALLEN	94SB4995	2,446	41.3	
600	582	PUEBLO	94LA275	2,618	41.2	
601	537	EL CAMPO	94CN7710	1,060	40.5	
602	248	SINTON	94CS1750	506	40.5	
603	572	PORT ISABEL S.S.	94SB4070	287	40.5	
604	385	MORRIS STREET	94CS8840	596	40.0	
605	316	JOURDANTON	94LA5685	1,170	40.0	
606	110	BEEVILLE	94CN8510	838	39.9	
607	87	CHOKE CANYON	94CN5390	426	39.8	
608	462	STADIUM	94LA8540	1,562	39.7	
609	new	KARNES CITY	94CN2340	814	39.6	
610	608	HAMILTON ROAD	94LA9645	301	39.6	
611	344	TYNAN	94CS4000	25	39.4	
612	121	HAMILTON ROAD	94LA9665	961	39.2	
613	207	FREER	94LA6320	158	38.9	
614	84	JOURDANTON	94LA250	787	38.6	
615	645	MORRIS STREET	94CS8850	493	38.5	
616	492	SEAWALL	94CS9420	825	38.4	
617	387	WEST HARLINGEN	94SB4870	1,057	37.9	
618	670	BROOKHOLLOW	94CN7190	282	37.7	
619	260	SOUTH SANTA ROSA	94SB1225	854	37.7	
620	706	SHARYLAND	94SB5635	2,197	37.1	
621	543	NORTH VICTORIA	94CN2240	766	36.4	
622	412	PALMHURST	94SB2525	2,016	36.0	
623	627	PALMVIEW	94SB9680	1,000	35.9	
624	615	BAY CITY	94CN7480	2,084	35.5	
625	7	CONTINENTAL	94SB3650	17	35.4	

Service Quality Report to the Public Utility Commission of Texas

**AEP Texas - (central division)**

**INTERRUPTION CAUSES**

Provide the percentage of interruptions attributable to each cause.

2016 Reporting Year

<b>Causes of Forced Interruptions</b>	<b>Percentage</b>
Weather (Including Lightning)	17.25%
Vegetation	18.06%
Animals and Birds	6.07%
People (Including cars and farm equip)	2.63%
Utility-owned Equipment	46.14%
Other	0.06%
Unknown	9.79%