



Control Number: 47200



Item Number: 8

Addendum StartPage: 0



HAYES ENGINEERING, INC.

Texas Registered Engineering Firm F-1465 www.hayesengineering.net
2126 ALPINE ST. LONGVIEW, TX 75601-3401
V 903.758.2010 F 903.758.2099

RECEIVED
2017 JUL 25 AM 9:37
PUBLIC UTILITY COMMISSION
FILING CLERK

July 21, 2017

Public Utility Commission of Texas
Attention: Filing Clerk
1701 N. Congress Avenue
P.O. Box 13326
Austin, TX 78711-3326

RE: Union Grove W.S.C.
Application to Amend Water CCN (10514)
PWS ID# 2300008
Upshur County, Texas
Docket #47200

Dear Sirs:

We received email from Jolie Mathis regarding the TCEQ requirements for specification and development plans for provision of water service in the requested area. Union Grove will be extending their existing distribution system in order to serve the requested area and the extension will serve less than 10% of their existing connections per 30 TAC 290.39(j)(1)(D). As such, TCEQ reviewed and approved plans and specifications will not be required for the future work. Should you require additional information, please do not hesitate to call.

Sincerely,
HAYES ENGINEERING, INC.



Kyle A. Stephens, PE
Project Manager

