

Control Number: 47229



Item Number: 10

Addendum StartPage: 0



AUSTIN WATER
Utility Development Services Division
625 East 10th Street, Suite 715
Austin, Texas 78701



September 22, 2017

Public Utility Commission
1701 Congress Ave., Suite 8-100
Austin, TX 78701

RE: Docket No. 47229 CCN Transfer Response to Comments
To Whom It May Concern:

This response is provided for comments received from Patricia Garcia. Attached is the latest TCEQ inspection report. Austin Water does not have any letters approving construction of facilities to serve the requested area. The area is currently undeveloped and no customers are in the requested area.

If additional information is required or should you have any questions, please notify me by email at alberto.ramirez@austintexas.gov or by phone at 512-972-0211.

Sincerely,

A handwritten signature in black ink, appearing to be "AR" or similar initials.


Alberto Ramirez
Engineering Associate
Austin Water
City of Austin

RECEIVED
2017 SEP 22 AM 11:02
PUBLIC UTILITY COMMISSION
ALBERTO RAMIREZ

10

COPY

Bryan W. Shaw, Ph.D., P.E., *Chairman*
Toby Baker, *Commissioner*
Jon Niermann, *Commissioner*
Richard A. Hyde, P.E., *Executive Director*



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Protecting Texas by Reducing and Preventing Pollution

July 7, 2017

Mr. Greg Meszaros, Director
Austin Water
City of Austin
Post Office Box 1088
Austin, Texas 78767

Re: Comprehensive Compliance Investigation at:
City of Austin Water System
625 East 10th Street, Austin, Travis County
TCEQ Public Water Supply 2270001, RN101220085

Dear Mr. Meszaros:

On May 16 and 18, 2017, Lawrence King and Lauren Parrish of the Texas Commission on Environmental Quality (TCEQ) Austin Region Office conducted an investigation of the above-referenced facilities to evaluate compliance with applicable requirements for public water systems. No violations are being alleged as a result of the investigation. However, please review the attached additional issue. Austin Water continues to merit recognition as a "Superior" water system.

The TCEQ appreciates your assistance in this matter and your continued efforts to ensure the protection of the public health. Should you have a question, please feel free to contact Mr. King in the Austin Region Office at (512) 339-2929.

Sincerely,

A handwritten signature in black ink, appearing to read "Shawn Stewart", is located below the "Sincerely," text.

Shawn Stewart
Water Section Manager
Austin Region Office

SS/lok

cc: Mr. Charlie Maddox, Water Regulatory Manager, Austin Water

Summary of Investigation Findings

CITY OF AUSTIN WATER & WASTEWATER	Investigation # 1414241
, TRAVIS COUNTY,	Investigation Date: 05/16/2017
Additional ID(s): 2270001	

No Violations Associated to this Investigation

ADDITIONAL ISSUES

Description

Item 1

Additional Comments

During the inspection of the water system facilities at the Albert R. Davis Plant, it was observed that the surface coating on the high-service discharge pipes had deteriorated allowing corrosion to form in a number of places.