



Control Number: 47924



Item Number: 11

Addendum StartPage: 0

Service Quality Report
To The
Public Utility Commission of Texas
In Accordance With
Substantive Rule §25.81
2017 Reporting Year

AEP Texas Inc.

Project 47924

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

System SAIFI	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced													
2017	1.27	0.12	0.09	0.09	0.12	0.15	0.14	0.12	0.09	0.08	0.11	0.07	0.10
Scheduled													
2017	0.09	0.01	0.01	0.00	0.02	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.00
Outside Causes													
2017	0.24	0.05	0.02	0.02	0.02	0.01	0.05	0.02	0.01	0.01	0.00	0.00	0.01
Major Events													
2017	0.50					0.07	0.03	0.00	0.29	0.06			0.05

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

System SAIDI	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced													
2017	133.19	11.10	10.71	9.18	14.22	19.68	14.61	12.71	8.45	8.42	9.62	4.80	9.70
Scheduled													
2017	9.89	0.48	0.54	0.60	1.39	0.85	0.59	0.60	0.78	0.65	1.33	1.54	0.54
Outside Causes													
2017	18.19	4.21	2.60	1.40	0.87	0.32	4.80	0.81	0.67	1.15	0.30	0.32	0.75
Major Events													
2017	1541.60					25.21	10.38	0.27	1462.13	32.62			10.99

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

Total Number of Feeders

With 10 or more Customers

1190

Add or Delete Rows as Necessary

AEP Texas Inc.

2017 SAIFI Ranking	2016 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIFI Value
1	328	ARANSAS PASS	94CS8270	352	10.741
2	283	ELSA	94SB710	2039	8.119
3	232	MAYBERRY	94SB3160	557	7.754
4	247	PORT LAVACA	94CN8310	350	7.591
5	313	SABINAL	94LA200	435	6.536
6	31	RAYMONDVILLE #2	94SB3170	729	6.472
7	40	GILA	94CS350	142	6.204
8	238	POLK AVENUE	94SB4170	1865	5.845
9	64	SUNCHASE	94SB1150	1292	5.776
10	241	LA PRYOR	94LA580	225	5.707
11	272	LAGUNA	94CS9590	2244	5.703
12	227	RIO GRANDE CITY	94SB3210	1930	5.529
13	504	SOUTH PADRE ISLAND	94SB6440	2665	5.465
14	664	ARANSAS PASS	94CS590	377	5.358
15	1	LA PRYOR	94LA570	145	5.297
16	408	NIXON	94CN2025	513	4.984
17	581	BEEVILLE	94CN8090	1358	4.982
18	197	WOODSBORO	94CS8330	277	4.877
19	688	HOLCOMB	94LA3025	323	4.854
20	29	FULTON	94CS2020	1623	4.807
21	421	MAYO	94CS625	218	4.794
22	61	FULTON	94CS440	1827	4.724
23	103	EAST HARRISON	94SB3950	609	4.701
24	243	FALFURRIAS	94LA5210	1120	4.662
25	667	DEL RIO CITY	94LA9850	1017	4.648
26	8	AB RAINEY CREEK	97AB4550	985	4.634
27	167	WOOLRIDGE	94CS1120	2646	4.624
28	129	ELSA	94SB700	1438	4.607
29	98	BONNIEVIEW	94CS8020	451	4.588
30	441	RIO RICO	94SB5050	1793	4.558
31	363	RANKIN	97SA6405	12	4.417
32	27	LA GRULLA	94SB5110	998	4.403
33	548	BROWNSVILLE	94SB4290	502	4.213
34	113	PLACEDO	94CN7970	474	4.203
35	24	BLESSING	94CN8790	759	4.198
36	552	ALAZAN	94CS620	173	4.197
37	291	MALONE	94CN7560	111	4.081
38	158	GARCENO	94SB2135	2127	4.067
39	302	BROWNSVILLE	94SB4280	318	4.047
40	74	INDIAN MESA	97SA2695	168	4.030
41	89	VERHALEN	97SA4465	84	3.964
42	219	WEIL TRACT (138/12KV)	94CS5405	168	3.952
43	64	NORTH MCCAMEY	97SA6555	486	3.928

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIFI Ranking	2016 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIFI Value
44	456	FULTON	94CS6070	3152	3.866
45	8	FOSTER FIELD	94CN2550	65	3.831
46	751	HALL ACRES ROAD	94SB3670	1028	3.791
47	617	SEAWALL	94CS9420	690	3.788
48	379	ODEM	94CS385	418	3.782
49	254	FREER	94LA1500	210	3.771
50	222	PUTNAM	97AB2129	211	3.768
51	394	GRETA	94CN7890	256	3.758
52	109	DARST	94CN790	248	3.746
53	181	ROBSTOWN	94CS1650	366	3.724
54	306	GREGORY	94CS5900	95	3.716
55	631	PORT ISABEL S.S.	94SB4070	284	3.708
56	77	MCELROY	97SA5165	122	3.705
57	56	ASPR CONTINENTAL	97AB4800	30	3.700
58	163	SINTON	94CS360	310	3.626
59	582	SOUTHSIDE	94CS8045	1012	3.613
60	2	WOODSON OIL FIELD	97AB30	32	3.594
61	443	CONOCO-CHITTAM RANCH	94LA8580	38	3.579
62	337	FREER	94LA2900	166	3.512
63	402	PHARAOH	94CS1365	683	3.511
64	628	HAMILTON ROAD	94LA9645	291	3.509
65	187	FALFURRIAS	94LA2830	1454	3.497
66	28	BEEVILLE	94CN300	1666	3.487
67	343	KNIPPA	94LA6365	323	3.486
68	58	RISING STAR	97AB5080	575	3.463
69	18	NAVAL BASE	94CS8540	1582	3.444
70	87	LULING - LCRA	94CN10	396	3.432
71	55	MASTERSON FIELD	97SA800	197	3.406
72	428	PORT ARANSAS	94CS1000	1933	3.405
73	633	DEL RIO CITY	94LA9790	2336	3.393
74	387	EDROY	94CS6990	279	3.348
75	676	PHARR	94SB1620	2676	3.318
76	92	GILA	94CS7840	767	3.308
77	17	RAYMONDVILLE #2	94SB3250	29	3.276
78	80	BOBCAT HILLS	97SA6655	22	3.273
79	457	NORTH MCALLEN	94SB2750	2773	3.269
80	161	CRESTONIO	94LA270	626	3.243
81	185	EDROY	94CS6980	196	3.240
82	57	NIXON	94CN3300	572	3.222
83	42	ALBANY	97AB3640	322	3.202
84	251	RIO RICO	94SB8290	419	3.198
85	652	WEST OSO	94CS9095	1599	3.184
86	426	CHOKO CANYON	94CN9255	358	3.179
87	352	VICTORIA POWER PLANT	94CN8070	620	3.148
88	60	WEST HARLINGEN	94SB3720	2096	3.146
89	30	GOVERNMENT WELLS	94LA7240	208	3.130
90	186	SUN VALLEY	97SA4300	62	3.129
91	110	SANTA RITA	97SA1105	75	3.120

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIFI Ranking	2016 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIFI Value
92	191	PHARAOH	94CS1185	1596	3.118
93	173	CROSS PLAINS	97AB2920	565	3.115
94	37	LULING - LCRA	94CN20	279	3.115
95	6	AB CANYON ROCK	97AB5035	944	3.066
96	165	PORTLAND	94CS9290	1755	3.053
97	41	ZAPATA	94LA8290	2127	3.040
98	21	IRAAN	97SA2055	540	3.004
99	71	STAMFORD	97AB2815	698	2.991
100	58	RANDADO	94LA8350	132	2.955
101	26	PECOS VALLEY	97SA4075	21	2.952
102	479	RIO GRANDE CITY	94SB3220	1335	2.938
103	135	SONORA 138 SUB	97SA4810	909	2.937
104	81	PLEASANTON	94LA9505	1735	2.908
105	83	CROSS PLAINS	97AB2915	749	2.865
106	330	UVALDE	94LA9770	1497	2.836
107	281	CHASE FIELD	94CN460	12	2.833
108	642	BANQUETTE	94CS9000	452	2.821
109	420	PEARSALL	94LA7050	939	2.818
110	474	VICTORIA POWER PLANT	94CN7600	155	2.813
111	182	SOUTH MCALLEN	94SB3640	301	2.804
112	133	TAFT	94CS1180	999	2.804
113	332	BRUNI	94LA1100	604	2.801
114	280	PARKER	94CN9010	19	2.789
115	100	CLIMAX/BRADSHAW	97AB11301	61	2.787
116	20	MORAN	97AB2107	229	2.786
117	425	TATTON	94CS950	394	2.774
118	14	QUANAH	97AB1830	609	2.745
119	204	CHILLICOTHE	97AB4530	497	2.726
120	438	SOUTHSIDE	94CS5335	1297	2.722
121	346	BRUNI	94LA1120	282	2.716
122	121	HOLLY	94CS7620	2701	2.710
123	186	MAGRUDER	94CN245	1235	2.707
124	67	SA CONCHO	97SA1700	501	2.697
125	48	CRYSTAL CITY	94LA8380	1326	2.686
126	149	FULTON	94CS9050	1311	2.683
127	46	MCKENZIE ROAD	94CS140	283	2.682
128	518	DEL RIO CITY	94LA430	2540	2.674
129	728	PAWNEE (STEC OWNED)	94CN22202	197	2.665
130	640	REFUGIO	94CN1170	824	2.648
131	86	ARANSAS PASS	94CS1250	589	2.637
132	134	EDNA	94CN5785	1247	2.630
133	157	GREENLAKE	94CN2760	1131	2.630
134	276	LA GRULLA	94SB6150	1509	2.616
135	350	WOOLRIDGE	94CS1170	1846	2.598
136	573	VICTORIA POWER PLANT	94CN1390	1099	2.595
137	168	VALENTINE	97SA5590	208	2.591
138	52	PHARAOH	94CS5185	2366	2.588
139	544	TATTON	94CS8200	1014	2.586

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIFI Ranking	2016 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIFI Value
140	114	MAVERICK	94LA9680	746	2.579
141	584	RANGERVILLE	94SB3410	856	2.567
142	21	NAVAL BASE	94CS9720	2443	2.563
143	154	BEN FICKLIN	97SA6175	693	2.561
144	636	POLK AVENUE	94SB4900	2516	2.550
145	476	GREGORY	94CS5920	700	2.529
146	144	MCCOLL ROAD	94SB2810	2321	2.526
147	578	HAMILTON ROAD	94LA9665	967	2.517
148	376	VALERA HUMBLE	97SA7015	79	2.506
149	150	BAY CITY	94CN2700	1075	2.473
150	384	BRUNI	94LA5440	127	2.465
151	4	MCCAMEY	97SA2415	158	2.462
152	132	PORTLAND	94CS6505	1862	2.452
153	386	ESCONDIDO	94LA3350	494	2.439
154	17	ALBANY	97AB2029	249	2.438
155	New	MEDIO CREEK	94CN1380	759	2.427
156	692	WEST MCALLEN	94SB4965	917	2.425
157	611	HALL ACRES ROAD	94SB8870	2347	2.425
158	5	LOS FRESNOS	94SB4315	1062	2.414
159	135	MARKHAM	94CN5550	22	2.409
160	320	OLMITO	94SB4275	789	2.408
161	37	QUANAH	97AB3100	543	2.405
162	353	ARCADIA	94CS8570	1455	2.392
163	369	CABANISS	94CS240	1541	2.391
164	183	VICTORIA POWER PLANT	94CN8170	791	2.368
165	536	PALACIOS	94CN6830	815	2.364
166	340	HEIGHTS	94LA9400	1371	2.363
167	217	HOLLY	94CS1480	1713	2.344
168	601	BISHOP	94CS7180	937	2.342
169	139	WESMER	94SB7760	2451	2.339
170	279	WESLACO UNIT	94SB7630	2562	2.334
171	315	LA PRYOR	94LA2440	709	2.333
172	300	MOORE FIELD	94SB3960	2073	2.329
173	New	SHROPSHIRE	94CN1240	65	2.323
174	225	HARLINGEN SWITCH	94SB4230	1338	2.286
175	689	FALFURRIAS	94LA1070	1015	2.286
176	333	AB MCMURRY	97AB3240	753	2.274
177	75	BAIRD	97AB5125	594	2.271
178	451	NORTH VICTORIA	94CN7440	1591	2.267
179	433	WESLACO UNIT	94SB5970	2393	2.259
180	293	AB MCMURRY	97AB3235	797	2.258
181	174	CHERRY CREEK TAP	97SA5245	43	2.256
182	223	DEL RIO CITY	94LA420	2232	2.251
183	162	CITRUS CITY	94SB7985	1118	2.240
184	241	AB MCMURRY	97AB3245	797	2.236
185	655	SOUTH PADRE ISLAND	94SB4695	1315	2.233
186	411	NIXON	94CN6630	672	2.226
187	586	BEEVILLE	94CN8510	816	2.217

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIFI Ranking	2016 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIFI Value
188	524	HAMILTON ROAD	94LA9655	1247	2.213
189	511	UVALDE	94LA550	702	2.202
190	713	MCKENZIE ROAD	94CS330	2366	2.200
191	183	AB MAPLE ST	97AB5755	1561	2.197
192	373	THOMASTON	94CN9580	47	2.191
193	485	EL CAMPO	94CN7710	1079	2.187
194	182	ALBANY	97AB3540	609	2.187
195	72	MESA VIEW	97SA7045	98	2.184
196	396	HOMEPORT	94CS4665	428	2.182
197	85	CABANISS	94CS80	1296	2.174
198	501	ELSA	94SB3520	449	2.171
199	202	EL GATO	94SB780	1668	2.170
200	165	AB RAINEY CREEK	97AB4225	113	2.168
201	100	ASPHALT MINES	94LA500	42	2.167
202	54	COFFEE PORT	94SB1095	991	2.154
203	356	SA SOUTH	97SA2595	946	2.151
204	62	ELDORADO	97SA1845	764	2.147
205	34	OZONA	97SA4185	1249	2.145
206	230	BROWNSVILLE	94SB3050	1979	2.144
207	227	ROARING SPRINGS	97AB6155	30	2.133
208	547	MCKENZIE ROAD	94CS150	23	2.130
209	471	BAY CITY	94CN6450	973	2.121
210	407	AIRLINE	94CS7280	642	2.120
211	335	RODD FIELD	94CS225	2503	2.119
212	152	ROBERT LEE	97SA4120	563	2.115
213	258	ASPERMONT	97AB1070	322	2.106
214	262	AB SHELTON ST	97AB3045	555	2.105
215	228	BRACKETTVILLE	94LA8460	1177	2.104
216	301	SOUTH EAST EDINBURG	94SB6580	1521	2.101
217	11	AB DYESS 2	97AB6335	360	2.100
218	253	SOUTHSIDE	94CS7925	1266	2.098
219	131	ASPR CONTINENTAL	97AB3830	23	2.087
220	362	RAYMONDVILLE #1	94SB620	637	2.078
221	331	JUNCTION	97SA4340	794	2.074
222	569	SOUTH SANTA ROSA	94SB1240	1584	2.071
223	725	AIRLINE	94CS8890	540	2.067
224	539	ELSA	94SB690	2370	2.067
225	327	SA WALNUT ST	97SA3920	891	2.059
226	169	SOUTHSIDE	94CS8025	1065	2.059
227	722	BEEVILLE	94CN2380	206	2.058
228	119	KINGSVILLE	94CS1350	396	2.058
229	665	GATEWAY	94LA350	1836	2.052
230	517	REFUGIO	94CN1210	181	2.039
231	141	ELDORADO	97SA2880	339	2.038
232	128	NORTH ALAMO	94SB3580	838	2.036
233	318	PETTUS	94CN1020	453	2.033
234	19	QUANAH	97AB100	91	2.033
235	368	KENEDY S.S.	94CN8340	333	2.027

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIFI Ranking	2016 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIFI Value
236	622	LAREDO PLANT	94LA8565	1554	2.020
237	398	IRAAN	97SA4305	74	2.014
238	609	SOUTH SANTA ROSA	94SB7485	1055	2.009
239	84	EAGLE PASS CITY	94LA450	969	2.007
240	639	NORTH MCALLEN	94SB4995	2442	2.007
241	263	KARNES CITY	94CN2325	663	1.998
242	215	TURKEY	97AB3825	391	1.997
243	704	CASA BLANCA	94CS4170	1022	1.996
244	391	VERNON CITY PLANT	97AB5770	99	1.990
245	38	MATTHEWS	94CN1740	164	1.982
246	240	HOLLY	94CS7740	2186	1.970
247	680	HEARN ROAD	94CS9665	673	1.969
248	285	PHARR	94SB1645	2347	1.949
249	290	VERHALEN	97SA4460	19	1.947
250	167	BARNHART	97SA3725	149	1.946
251	242	DEL RIO CITY	94LA1930	1025	1.942
252	624	AIRLINE	94CS8260	1453	1.939
253	691	MCCOLL ROAD	94SB4780	1933	1.932
254	327	PHARAOH	94CS1285	1781	1.926
255	641	PALMHURST	94SB2820	1777	1.921
256	54	CEDAR GAP (TEC)	97AB4115	491	1.919
257	268	SAN BENITO	94SB3920	2551	1.914
258	431	ALAZAN	94CS2740	33	1.909
259	117	SPUDDER FLAT	97SA4175	52	1.904
260	68	BIG WELLS	94LA2630	27	1.889
261	488	CAUSEWAY	94SB4795	1215	1.883
262	12	HAROLD	97AB1495	24	1.875
263	32	MOORE FIELD	94SB3120	157	1.866
264	347	CASA BLANCA	94CS1300	276	1.862
265	130	HARLINGEN SWITCH	94SB320	1528	1.860
266	463	GOLIAD	94CN6540	1193	1.855
267	103	TWILIGHT TRAIL	97AB5855	1439	1.855
268	23	TWILIGHT TRAIL	97AB4290	928	1.853
269	277	THREE RIVERS	94CN5190	477	1.851
270	117	PREMONT	94LA6570	751	1.838
271	3	BRYANTS RANCH	97SA205	18	1.833
272	608	CAUSEWAY	94SB4765	961	1.825
273	16	PORT ISABEL S.S.	94SB3820	182	1.819
274	140	BARNHART	97SA590	22	1.818
275	New	SHROPSHIRE	94CN3575	30	1.800
276	437	LEARY LANE	94CN7530	3010	1.794
277	482	PORT ISABEL S.S.	94SB9295	2242	1.792
278	339	CRESTONIO	94LA260	1744	1.791
279	88	TUSCOLA	97AB3730	1334	1.790
280	225	RISING STAR	97AB5075	654	1.787
281	739	NORTH PADRE ISLAND	94CS720	1287	1.774
282	206	HIGHWAY 9	94CS9830	151	1.768
283	670	WEST MCALLEN	94SB4535	2855	1.767

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIFI Ranking	2016 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIFI Value
284	543	EAGLE PASS CITY	94LA2770	2948	1.754
285	406	WADSWORTH	94CN7660	1391	1.753
286	292	MORRIS STREET	94CS8820	1241	1.749
287	752	PHARR	94SB1650	825	1.738
288	154	COFFEE PORT	94SB1090	1197	1.738
289	199	ASPERMONT	97AB3380	400	1.738
290	388	HOLLY	94CS5820	941	1.734
291	216	GILA	94CS345	60	1.733
292	564	DILLEY	94LA6400	170	1.712
293	66	ODEM	94CS375	1069	1.711
294	297	HARLINGEN	94SB660	1937	1.709
295	27	SARAGOSA	97SA1590	74	1.703
296	141	GARCENO	94SB2130	2623	1.689
297	124	PUTNAM	97AB2131	127	1.685
298	218	PREMONT	94LA6610	818	1.683
299	460	RACHAL	94LA8145	337	1.680
300	151	CLARKWOOD	94CS9570	1141	1.678
301	565	SOUTHSIDE	94CS7955	1066	1.674
302	171	LAGUNA	94CS9065	2333	1.673
303	24	AB RAINEY CREEK	97AB4220	190	1.668
304	221	ELSA	94SB3500	1232	1.666
305	80	ARANSAS PASS	94CS660	691	1.654
306	110	HEARN ROAD	94CS8990	1255	1.653
307	491	BAY CITY	94CN1110	1246	1.638
308	705	ARCADIA	94CS1360	1494	1.637
309	New	FRIO	94LA2270	677	1.626
310	25	SOUTH MCALLEN	94SB3850	603	1.619
311	690	COMSTOCK	94LA230	182	1.615
312	489	PLEASANTON	94LA120	1246	1.614
313	226	CHRISTOVAL	97SA6620	567	1.603
314	526	PORT ARANSAS	94CS6940	1352	1.599
315	50	FASHING	94CN360	37	1.595
316	587	SOUTHSIDE	94CS7995	1561	1.573
317	465	MORRIS STREET	94CS8715	1604	1.571
318	12	BEEVILLE	94CN1760	1831	1.571
319	63	LEARY LANE	94CN6175	2565	1.568
320	166	WESLACO UNIT	94SB7455	1219	1.560
321	645	TYNAN	94CS4000	27	1.556
322	177	LAREDO PLANT	94LA8745	767	1.549
323	358	GRAYBACK	97AB3315	46	1.543
324	668	ROMA	94SB3060	1549	1.540
325	97	LYTLE	94LA2850	681	1.536
326	399	MILO	94LA5020	1873	1.534
327	594	LOLITA	94CN6330	30	1.533
328	577	WESLACO UNIT	94SB2195	1104	1.530
329	131	BERCLAIR	94CN990	203	1.522
330	392	SOUTHSIDE	94CS8005	746	1.521
331	259	HIGHWAY 9	94CS6730	536	1.519

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIFI Ranking	2016 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIFI Value
332	74	HOLLY	94CS1220	3314	1.518
333	762	SUNCHASE	94SB1155	1458	1.516
334	76	TUSCOLA	97AB3305	1030	1.515
335	122	PEARSALL	94LA5580	1583	1.514
336	319	ARCADIA	94CS6930	1498	1.513
337	170	SOUTH EAST EDINBURG	94SB5045	2197	1.513
338	562	STADIUM	94LA7490	1287	1.511
339	96	SA MATHIS FIELD	97SA4790	171	1.509
340	336	DEL RIO CITY	94LA440	1104	1.507
341	115	MORRIS STREET	94CS5655	420	1.505
342	51	LIVE OAK	94CS1090	279	1.502
343	616	RIO GRANDE CITY	94SB3230	2571	1.501
344	22	BUSH KNOB	97AB5200	286	1.497
345	494	HOLCOMB	94LA2240	447	1.494
346	342	BISHOP	94CS2690	561	1.494
347	231	CASA BLANCA	94CS55	848	1.488
348	480	JOURDANTON	94LA880	314	1.484
349	188	FT DAVIS	97SA4515	966	1.482
350	383	PORT LAVACA	94CN2480	1524	1.481
351	470	SAN DIEGO	94LA2890	1027	1.479
352	111	GOLIAD	94CN8220	1043	1.477
353	295	KLEBERG	94CS6000	1467	1.473
354	265	PALACIOS	94CN6840	1546	1.465
355	235	SINTON	94CS180	972	1.463
356	372	EL GATO	94SB720	2430	1.456
357	New	GARCENO	94SB5490	496	1.454
358	145	LIVE OAK	94CS1080	1221	1.450
359	663	CARRIZO SPRINGS	94LA370	535	1.445
360	248	DILLEY	94LA510	564	1.443
361	334	STADIUM	94LA7800	677	1.443
362	79	TAFT	94CS1260	190	1.442
363	435	RIO BRAVO	94LA5	717	1.441
364	322	INGLESIDE CITY	94CS8050	1269	1.438
365	56	ESCONDIDO	94LA2035	2608	1.436
366	107	MCCAMEY	97SA2855	76	1.434
367	492	RAYMONDVILLE #2	94SB3240	949	1.429
368	311	BIG WELLS	94LA1570	439	1.417
369	123	AMISTAD DAM	94LA5450	1192	1.416
370	385	PALMVIEW	94SB3930	1126	1.414
371	76	PHARAOH	94CS5175	1289	1.414
372	486	HALL ACRES ROAD	94SB3460	3281	1.412
373	168	WASHINGTON STREET	94LA7015	1539	1.411
374	224	KINGSVILLE	94CS1670	427	1.410
375	108	PARKER	94CN9260	109	1.404
376	550	ANNA STREET	94LA850	1572	1.403
377	239	BLACK BAYOU	94CN1120	306	1.402
378	324	BEEVILLE	94CN490	949	1.398
379	734	DEL MAR	94LA220	2590	1.396

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIFI Ranking	2016 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIFI Value
380	233	PECAN BAYOU	97AB6810	390	1.395
381	648	SKIDMORE	94CS600	364	1.393
382	712	HEARN ROAD	94CS2220	1538	1.390
383	16	SPUDDER FLAT	97SA4180	44	1.386
384	78	GANADO	94CN5795	482	1.386
385	614	POLK AVENUE	94SB4190	1698	1.385
386	326	SOUTHSIDE	94CS8035	1097	1.383
387	175	INGLESIDE CITY	94CS2495	260	1.369
388	262	KENEDY	94CN1970	562	1.367
389	9	KITTIE WEST	94CN3765	317	1.363
390	192	AB VOGEL ST	97AB4405	567	1.362
391	604	FULTON	94CS3070	1412	1.360
392	195	HAMLIN SHELL	97AB6330	25	1.360
393	47	ALPINE 12KV	97SA6825	1913	1.354
394	361	CARRIZO SPRINGS	94LA860	32	1.344
395	36	HIGHWAY 9	94CS6770	1141	1.340
396	198	SOUTH SANTA ROSA	94SB1235	639	1.338
397	314	CAMPWOOD	94LA3430	104	1.337
398	92	WINTERS	97SA3765	781	1.334
399	176	BRONTE AMBASSADOR	97SA6650	15	1.333
400	95	PADUCAH CITY	97AB1935	283	1.332
401	309	DEVINE	94LA8100	1574	1.327
402	209	NORTH MERCEDES	94SB4860	1503	1.326
403	344	WEINERT	97AB6490	124	1.323
404	567	SEAWALL	94CS9325	1488	1.322
405	343	SHAFTER	97SA5110	53	1.321
406	308	ARCADIA	94CS1400	438	1.317
407	287	EAGLE LAKE	94CN310	735	1.317
408	337	PECAN BAYOU	97AB530	19	1.316
409	237	NORTH VICTORIA	94CN1580	1021	1.314
410	662	SOUTH MCALLEN	94SB3790	2165	1.309
411	759	SKIDMORE	94CS380	155	1.303
412	650	UVALDE	94LA480	1293	1.302
413	507	WEST HARLINGEN	94SB4870	1042	1.300
414	710	RAYMONDVILLE #1	94SB630	792	1.298
415	462	ANNA STREET	94LA5780	684	1.295
416	143	ARANSAS PASS	94CS8280	568	1.294
417	740	MCCOLL ROAD	94SB4790	2017	1.293
418	15	PECAN BAYOU	97AB6815	1502	1.291
419	612	EL GATO	94SB910	2443	1.289
420	137	TYNAN	94CS4010	42	1.286
421	304	CLARKWOOD	94CS7230	614	1.285
422	295	STAMFORD	97AB4565	797	1.285
423	657	ALICE	94LA1780	239	1.285
424	467	LOS FRESNOS	94SB7270	2180	1.282
425	528	RIO GRANDE CITY	94SB3740	2287	1.281
426	310	GEORGE WEST	94CN730	921	1.280
427	416	ARMSTRONG	94CS6050	72	1.278

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIFI Ranking	2016 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIFI Value
428	3	ENCINAL	94LA2160	228	1.276
429	634	LAREDO PLANT	94LA9305	1041	1.275
430	559	HEIGHTS	94LA2450	2566	1.274
431	35	CARANCAHUA	94CN5870	495	1.273
432	355	WEST MCALLEN	94SB4505	1861	1.269
433	600	UVALDE	94LA540	1207	1.267
434	274	ROBERT LEE	97SA4125	267	1.266
435	176	BROOKHOLLOW	94CN7580	487	1.265
436	724	POLK AVENUE	94SB4740	1433	1.261
437	134	MUNDAY	97AB3365	391	1.261
438	107	BEEVILLE	94CN2200	752	1.258
439	31	QUANAH	97AB3975	202	1.257
440	59	MORRIS STREET	94CS8830	1540	1.256
441	588	FREER	94LA5200	1017	1.256
442	202	TANKERSLY (CVEC)	97SA5260	438	1.251
443	490	TAFT	94CS5230	847	1.250
444	311	MELVIN	97SA940	44	1.250
445	397	TALPA ATLANTIC	97SA5180	60	1.250
446	44	SOUTH EAST EDINBURG	94SB4570	1369	1.244
447	331	SOUTHSIDE	94CS8055	861	1.244
448	49	FREISS RANCH	97SA4870	96	1.240
449	275	ROUNDTOP	97AB4490	46	1.239
450	249	AB WALNUT ST	97AB3785	483	1.236
451	248	AB VOGEL ST	97AB4560	1459	1.235
452	172	HASKELL 12KV	97AB3770	443	1.235
453	116	AB SHELTON ST	97AB4640	649	1.231
454	148	WESMER	94SB1850	1383	1.224
455	18	SONORA 138 SUB	97SA4805	447	1.224
456	405	WOOLRIDGE	94CS1110	1697	1.223
457	249	INGLESIDE CITY	94CS8060	2071	1.222
458	389	HEIGHTS	94LA2390	1702	1.214
459	159	AILEEN	97AB4600	253	1.213
460	171	SARAGOSA	97SA1552	721	1.212
461	397	HOLLY	94CS1950	826	1.211
462	318	CROSS PLAINS	97AB1795	419	1.210
463	598	JOURDANTON	94LA5685	1191	1.207
464	105	ZAPATA	94LA2710	44	1.205
465	170	MORAN	97AB2108	329	1.204
466	52	PECOS VALLEY	97SA4080	118	1.203
467	70	MCCOLL ROAD	94SB4400	1382	1.203
468	51	SAND ROAD	97AB5295	529	1.202
469	45	WYLIE	97AB2675	782	1.201
470	162	SANTA RITA	97SA1135	10	1.200
471	409	RAYMONDVILLE #2	94SB4160	346	1.197
472	29	TRENT	97AB4245	182	1.192
473	185	SA NORTH	97SA3130	235	1.187
474	229	ALBANY	97AB3655	616	1.187
475	673	COLUMBUS	94CN9060	370	1.186

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIFI Ranking	2016 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIFI Value
476	150	MIDWAY LANE	97SA3440	60	1.183
477	736	MAGNOLIA	94CN315	11	1.182
478	497	FOSTER FIELD	94CN8880	286	1.182
479	316	PALACIOS	94CN8550	45	1.178
480	7	STAFFORD HILL	94CN1550	225	1.178
481	71	RANGERVILLE	94SB3420	763	1.176
482	310	AB EAST 12KV	97AB5760	200	1.175
483	370	SEAWALL	94CS9450	303	1.175
484	458	POLK AVENUE	94SB4610	1179	1.174
485	328	WYLIE	97AB6340	702	1.172
486	382	EAGLE LAKE	94CN320	644	1.172
487	298	STERLING CITY	97SA1445	888	1.172
488	681	JOURDANTON	94LA250	778	1.172
489	114	ROTAN	97AB1860	721	1.168
490	746	YORKTOWN	94CN8380	775	1.165
491	367	HEIGHTS	94LA2100	2122	1.164
492	149	RUSSEK STREET	97SA7705	1339	1.163
493	47	NORTH EDINBURG	94SB4240	2502	1.158
494	637	SHARYLAND	94SB5635	2168	1.158
495	580	PALMVIEW	94SB7595	3105	1.155
496	620	HIGHWAY 9	94CS7200	658	1.154
497	73	MUNDAY	97AB2080	473	1.152
498	542	PUEBLO	94LA275	2759	1.152
499	558	BIG OAK	94CN420	145	1.152
500	596	SOUTH PADRE ISLAND	94SB5850	1310	1.150
501	85	AB COUNTRY CLUB	97AB4855	772	1.148
502	726	RODD FIELD	94CS205	1979	1.145
503	682	MORRIS STREET	94CS8850	497	1.145
504	98	HAMLIN	97AB3270	882	1.143
505	60	MERKEL	97AB1895	711	1.136
506	376	MOCKINGBIRD	94CN305	302	1.136
507	304	SA EMERSON ST	97SA4630	1189	1.135
508	649	PALMHURST	94SB2525	2068	1.134
509	708	POLK AVENUE	94SB4520	935	1.134
510	370	TRUSCOTT	97AB3845	30	1.133
511	266	ANSON 12KV	97AB6630	686	1.133
512	520	WESLACO UNIT	94SB8195	1629	1.132
513	493	CLARKWOOD	94CS5525	1166	1.130
514	322	VERNON	97AB3340	525	1.128
515	203	KLEBERG	94CS280	1275	1.127
516	651	BANDERA ELECTRIC (LEAKEY)	94LAL30	268	1.127
517	378	PORT LAVACA	94CN6850	669	1.121
518	317	HARLINGEN	94SB380	2650	1.120
519	653	LAREDO PLANT	94LA8695	1325	1.118
520	572	HARLINGEN	94SB360	2460	1.117
521	234	TURKEY	97AB2980	316	1.117
522	42	UVALDE	94LA6620	2779	1.116
523	1	ALPINE 12KV	97SA3875	536	1.116

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIFI Ranking	2016 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIFI Value
524	138	WINTERS	97SA2113	810	1.115
525	77	NORTH MCALLEN	94SB5055	3214	1.115
526	48	ANSON 12KV	97AB6635	412	1.114
527	545	HIDALGO	94SB3680	317	1.114
528	160	PLEASANTON	94LA9475	1340	1.113
529	316	SONORA	97SA2045	606	1.112
530	207	AIRLINE	94CS7390	2123	1.110
531	83	KENEDY	94CN6270	551	1.107
532	413	BANQUETTE	94CS130	235	1.106
533	472	CLARKWOOD	94CS7610	113	1.106
534	94	MOCKINGBIRD	94CN370	39	1.103
535	147	MATHIS	94CS2870	871	1.102
536	575	HAINE DRIVE	94SB9700	1104	1.101
537	201	ABILENE PLANT	97AB1565	280	1.100
538	123	EOLA	97SA4950	241	1.100
539	358	PUEBLO	94LA130	2410	1.100
540	280	CLYDE	97AB1755	132	1.098
541	360	PHARR	94SB1625	1714	1.097
542	125	ROCKPORT	94CS5950	522	1.096
543	683	KINGSVILLE	94CS1660	1935	1.094
544	436	EL CAMPO	94CN6370	747	1.092
545	219	BEN FICKLIN	97SA6180	1027	1.092
546	41	PERKINS PROTHO	97SA3180	22	1.091
547	195	NORTH ALAMO	94SB3610	1856	1.088
548	669	CHOKE CANYON	94CN5390	430	1.086
549	422	SOUTHSIDE	94CS5345	403	1.084
550	156	SANTA ANNA	97SA3420	361	1.083
551	288	BUENA VISTA	94LA9385	1275	1.082
552	514	SOUTH SANTA ROSA	94SB1215	1641	1.077
553	243	AB OVER STREET 12KV	97AB1635	514	1.072
554	336	COLLEGE HILLS	97SA6145	718	1.065
555	200	SAND ROAD	97AB5290	807	1.062
556	675	MAYBERRY	94SB1790	743	1.062
557	308	MELVIN	97SA4955	89	1.056
558	603	CONTINENTAL	94SB3650	18	1.056
559	666	HIGHWAY 9	94CS7210	360	1.056
560	427	MILO	94LA8365	1578	1.055
561	82	STAMFORD	97AB2835	131	1.053
562	242	STAMFORD	97AB6255	397	1.053
563	661	RODD FIELD	94CS245	2810	1.052
564	364	BEN FICKLIN	97SA6185	551	1.051
565	233	CHARLOTTE	94LA2790	199	1.050
566	40	MCCAMEY	97SA3670	359	1.050
567	753	AIRLINE	94CS7270	994	1.048
568	105	THROCKMORTON	97AB2090	66	1.045
569	220	SA MATHIS FIELD	97SA5100	223	1.045
570	301	JUNCTION	97SA4335	790	1.044
571	410	RIO BRAVO	94LA1130	994	1.044

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIFI Ranking	2016 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIFI Value
572	393	PALMHURST	94SB2535	2315	1.042
573	684	SOUTH MISSION	94SB3980	2113	1.040
574	375	GATEWAY	94LA390	2070	1.038
575	625	PETTUS	94CN8210	332	1.036
576	537	KENEDY S.S.	94CN6750	57	1.035
577	33	SIERRA VISTA	94LA9900	2848	1.034
578	87	IRAAN	97SA2050	193	1.031
579	758	SIERRA VISTA	94LA7360	2941	1.028
580	461	LOS FRESNOS	94SB2160	1429	1.027
581	341	AB COUNTRY CLUB	97AB4730	538	1.024
582	133	AILEEN	97AB6435	806	1.022
583	314	AFTON	97AB2355	46	1.022
584	756	CAUSEWAY	94SB4775	1052	1.021
585	383	AB SHELTON ST	97AB3040	178	1.017
586	359	AB SHELTON ST	97AB3435	319	1.016
587	695	GATEWAY	94LA3595	1520	1.012
588	357	PALMHURST	94SB1300	2124	1.012
589	130	BRADY	97SA5015	195	1.010
590	361	AB REBECCA LANE	97AB5555	1265	1.009
591	276	MUNDAY	97AB6715	251	1.008
592	324	COLLEGE HILLS	97SA5515	350	1.006
593	731	WASHINGTON STREET	94LA2470	453	1.002
594	403	AB WALNUT ST	97AB3250	11	1.000
595	109	KEMPER EXXON HUMBLE	97SA1490	27	1.000
596	424	ANNA STREET	94LA780	474	0.994
597	333	OLMITO	94SB715	618	0.989
598	234	CABANISS	94CS75	2208	0.984
599	155	SA JACKSON ST	97SA4250	298	0.980
600	302	PEACOCK	97AB1375	47	0.979
601	222	UNIVERSITY	94LA950	2627	0.977
602	619	SOUTH SANTA ROSA	94SB1225	860	0.974
603	146	SA SOUTH	97SA4795	1246	0.974
604	613	HAIN DRIVE	94SB9690	532	0.974
605	770	KENEDY	94CN1960	64	0.969
606	505	MINES ROAD	94LA3680	1112	0.967
607	719	CLARKWOOD	94CS7220	825	0.965
608	258	BUENA VISTA	94LA9035	2549	0.965
609	96	THREE RIVERS	94CN8430	192	0.964
610	535	GREGORY	94CS2420	818	0.962
611	615	AIRLINE	94CS9030	428	0.958
612	15	THREE RIVERS	94CN5100	65	0.954
613	39	BLESSING	94CN1030	278	0.946
614	146	PLEASANTON	94LA2080	1621	0.943
615	250	ARCADIA	94CS1440	1677	0.943
616	65	PLACEDO	94CN7980	408	0.941
617	166	RUSSEK STREET	97SA11370	177	0.932
618	129	SA GRAPE CREEK	97SA5365	784	0.930
619	549	EAST HARRISON	94SB3190	1483	0.929

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIFI Ranking	2016 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIFI Value
620	63	AILEEN	97AB4605	723	0.920
621	203	RANKIN	97SA7425	165	0.915
622	67	COTULLA	94LA610	1503	0.915
623	659	PALMVIEW	94SB6790	1817	0.914
624	190	YORKTOWN	94CN3130	469	0.908
625	10	PORTLAND	94CS9370	1832	0.907
626	605	CITRUS CITY	94SB6000	2164	0.902
627	646	CITRUS CITY	94SB5070	913	0.901
628	385	BLUFFS	97SA3005	231	0.896
629	220	ARANSAS PASS	94CS9130	360	0.881
630	69	GOVERNMENT WELLS	94LA6800	225	0.871
631	196	CRYSTAL CITY	94LA1425	1140	0.871
632	525	NORTH VICTORIA	94CN7430	1687	0.867
633	404	WYLIE	97AB6495	268	0.862
634	563	EAST HARRISON	94SB4360	1739	0.859
635	626	INGLESIDE CITY	94CS6040	390	0.856
636	660	MILO	94LA3070	2778	0.845
637	334	ROBY	97AB2276	305	0.823
638	532	EL CAMPO	94CN2800	821	0.821
639	239	VALENTINE	97SA6325	574	0.814
640	700	MAYBERRY	94SB5770	808	0.813
641	104	WEIL TRACT (138/12KV)	94CS2520	155	0.806
642	188	GOODWIN	94SB4380	1508	0.806
643	91	WESMER	94SB9705	1037	0.806
644	199	WEST OSO	94CS9090	1683	0.803
645	452	MORRIS STREET	94CS2515	1071	0.799
646	477	WADSWORTH	94CN8630	683	0.796
647	369	ABILENE PLANT	97AB1735	87	0.793
648	New	ESCONDIDO	94LA5730	1188	0.780
649	298	MAGRUDER	94CN6700	1355	0.780
650	743	ZACATE CREEK	94LA2665	1704	0.778
651	102	VILLA CAVAZOS	94SB7615	1048	0.776
652	503	NAVAL BASE	94CS7950	329	0.775
653	715	RODD FIELD	94CS1730	2177	0.774
654	155	MALONE	94CN7550	187	0.770
655	22	PREMONT	94LA2730	198	0.768
656	246	PALMHURST	94SB2530	1813	0.767
657	534	FALFURRIAS	94LA1080	455	0.767
658	674	PORT ISABEL S.S.	94SB3760	707	0.754
659	43	NORTH MCALLEN	94SB5060	2457	0.751
660	181	POWELL FIELD	97SA2528	24	0.750
661	New	GARCENO	94SB2165	692	0.741
662	4	RUNGE	94CN4465	373	0.740
663	359	HARLINGEN SWITCH	94SB4110	849	0.740
664	506	HIDALGO	94SB4845	1210	0.739
665	264	CRESTONIO	94LA6660	765	0.731
666	11	PUEBLO	94LA95	1475	0.729
667	13	PEARSALL	94LA3675	722	0.729

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIFI Ranking	2016 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIFI Value
668	82	REFUGIO	94CN1040	168	0.726
669	28	DUNE FIELD (N CRANE)	97SA3885	73	0.726
670	450	GREENLAKE	94CN2740	349	0.725
671	647	REFUGIO	94CN5120	673	0.721
672	481	CHARLOTTE	94LA8120	208	0.716
673	84	VERNON	97AB4275	590	0.715
674	519	MOORE FIELD	94SB3110	650	0.714
675	303	GREGORY	94CS8560	255	0.714
676	26	RIO RICO	94SB8330	435	0.701
677	271	RANDADO	94LA8360	163	0.699
678	2	LA GRULLA	94SB4120	1412	0.692
679	607	SAN DIEGO	94LA2930	576	0.684
680	618	SAN BENITO	94SB3860	234	0.684
681	101	CAMPWOOD	94LA2610	951	0.681
682	329	SOUTHSIDE	94CS7905	1811	0.678
683	53	NORTH MERCEDES	94SB3840	651	0.674
684	55	LIVE OAK	94CS1070	2294	0.664
685	602	HAIN DRIVE	94SB8065	1342	0.657
686	282	ZACATE CREEK	94LA2635	311	0.656
687	25	SANTA RITA	97SA1100	113	0.655
688	235	CHRISTOVAL	97SA6615	423	0.650
689	621	ARCADIA	94CS1450	1972	0.650
690	90	AB MCMURRY	97AB4510	827	0.649
691	294	ZAPATA	94LA8300	1663	0.645
692	330	PAULANN	97SA6280	421	0.637
693	126	NORTH ALAMO	94SB4370	1548	0.634
694	217	SAND ROAD	97AB5655	614	0.630
695	487	WESMER	94SB4480	1128	0.629
696	260	DILLEY	94LA3795	812	0.624
697	377	WEST OSO	94CS9085	890	0.622
698	464	KLEBERG	94CS1560	1416	0.619
699	214	AB SHELTON ST	97AB3050	646	0.618
700	193	WESMER	94SB4050	1945	0.616
701	159	SAN DIEGO	94LA1980	594	0.613
702	732	LANTANA	94CS4095	200	0.610
703	510	LANTANA	94CS7150	273	0.608
704	515	SOUTH EAST EDINBURG	94SB4550	2125	0.600
705	632	SHARYLAND	94SB5105	1617	0.599
706	585	SHARYLAND	94SB6745	2139	0.597
707	272	ABILENE PLANT	97AB1570	679	0.591
708	502	HALL ACRES ROAD	94SB5465	1378	0.589
709	157	ALPINE 12KV	97SA6820	780	0.587
710	540	RANGERVILLE	94SB4060	888	0.581
711	400	NORTH PADRE ISLAND	94CS7900	2156	0.571
712	627	O CONNER	94CN390	193	0.570
713	245	SINTON	94CS6860	1644	0.569
714	442	FREER	94LA6320	157	0.567
715	153	CRYSTAL CITY	94LA2170	738	0.566

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIFI Ranking	2016 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIFI Value
716	523	ALICE	94LA1790	470	0.566
717	269	SOUTH EAST EDINBURG	94SB4015	449	0.561
718	629	BROOKHOLLOW	94CN8960	586	0.560
719	285	COLLEGE HILLS	97SA4835	441	0.558
720	444	VILLA CAVAZOS	94SB1980	1643	0.558
721	685	NORTH VICTORIA	94CN2240	757	0.557
722	750	RAYMONDVILLE #1	94SB3130	277	0.556
723	693	CRYSTAL CITY	94LA7425	436	0.555
724	10	RIO PECOS	97SA3835	128	0.555
725	213	BAY CITY	94CN5960	2103	0.553
726	184	PLASTERCO (MWEC)	97AB2720	107	0.551
727	478	RACHAL	94LA6595	329	0.550
728	706	HEIGHTS	94LA6810	2067	0.549
729	211	BAY CITY	94CN6670	1603	0.541
730	571	ALICE	94LA1770	1641	0.534
731	138	GOODWIN	94SB7380	1799	0.533
732	206	RULE	97AB3396	431	0.529
733	New	FLOMOT	97AB1852	72	0.528
734	13	CHILDRESS 69	97AB4865	773	0.527
735	198	MERTZON (CVEC)	97SA2905	584	0.526
736	766	SOUTH PADRE ISLAND	94SB4675	156	0.526
737	34	GARWOOD CITY	94CN2570	145	0.524
738	236	MATHIS	94CS340	1363	0.522
739	371	HALL ACRES ROAD	94SB5585	1445	0.518
740	716	WESLACO UNIT	94SB9805	1948	0.518
741	375	HIGHLAND	97SA6380	413	0.511
742	136	LOS FRESNOS	94SB5335	2452	0.510
743	299	BLESSING	94CN8780	63	0.508
744	73	GOODWIN	94SB4390	412	0.507
745	727	WEST MCALLEN	94SB4515	875	0.503
746	527	BROOKHOLLOW	94CN8950	889	0.501
747	508	HAIN DRIVE	94SB270	1077	0.500
748	401	SONORA ATLANTIC (SWTEC)	97SA4415	24	0.500
749	447	GOODWIN	94SB4625	1867	0.499
750	445	EL CAMPO	94CN2860	1476	0.499
751	275	HEARN ROAD	94CS870	1183	0.497
752	338	AB OVER STREET 12KV	97AB1645	790	0.494
753	270	VERNON CITY PLANT	97AB5775	824	0.492
754	332	RUSSEK STREET	97SA250	149	0.490
755	294	SA NORTH	97SA3115	558	0.489
756	118	MAGRUDER	94CN7870	1248	0.488
757	228	AB SHELTON ST	97AB3060	1578	0.488
758	201	SABINAL	94LA485	492	0.488
759	560	YORKTOWN	94CN8420	666	0.486
760	300	RIO PECOS	97SA513	33	0.485
761	348	KNOX CITY	97AB3390	369	0.482
762	742	RUNGE	94CN3250	264	0.481
763	531	SAN DIEGO	94LA2880	1312	0.480

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIFI Ranking	2016 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIFI Value
764	570	TYNAN	94CS1855	137	0.474
765	748	DEL MAR	94LA7930	1441	0.473
766	127	ASHERTON	94LA2670	89	0.472
767	19	CHARLOTTE	94LA2780	53	0.472
768	115	ANSON REA (SEC)	97AB5215	246	0.472
769	172	OLMITO	94SB905	1559	0.467
770	597	ARCADIA	94CS1460	2151	0.465
771	210	SA NORTH	97SA3125	1240	0.462
772	192	SANTO NINO	94LA515	1529	0.460
773	364	COTULLA	94LA90	330	0.458
774	286	WEAVER ROAD	94CN1900	57	0.456
775	466	GEORGE WEST	94CN1320	707	0.451
776	160	SA GRAPE CREEK	97SA4700	715	0.450
777	495	SAN YGNACIO	94LA16060	494	0.449
778	554	LEARY LANE	94CN1540	795	0.448
779	99	ARCADIA	94CS5030	1575	0.442
780	354	KITTIE WEST	94CN3760	241	0.440
781	430	THREE RIVERS	94CN2010	305	0.433
782	187	RULE	97AB3378	105	0.429
783	576	NORTH WESLACO	94SB4830	516	0.428
784	116	GOVERNMENT WELLS	94LA7250	540	0.428
785	449	UVALDE	94LA5060	1350	0.427
786	423	VILLA CAVAZOS	94SB5680	1773	0.426
787	345	ASHERTON	94LA2660	616	0.425
788	179	SA GRAPE CREEK	97SA5220	664	0.425
789	45	ROCKPORT	94CS5930	1238	0.423
790	296	NORTH PADRE ISLAND	94CS5170	1257	0.423
791	553	SAN BENITO	94SB4030	2625	0.422
792	348	RODD FIELD	94CS2190	2750	0.422
793	208	SA LAKE DR	97SA5865	1027	0.422
794	78	ROCHESTER	97AB3290	76	0.421
795	381	POLK AVENUE	94SB4600	3095	0.420
796	194	TANKERSLY (CVEC)	97SA5265	367	0.420
797	86	AB ELM CREEK	97AB5045	373	0.418
798	509	ARCADIA	94CS5020	1477	0.410
799	161	ESPY WELLS	97SA50207	27	0.407
800	765	DEL MAR	94LA490	770	0.404
801	121	MERKEL	97AB1890	587	0.404
802	212	WEST HARLINGEN	94SB3800	1382	0.402
803	153	CROWELL	97AB3490	177	0.401
804	498	THREE RIVERS	94CN2580	128	0.398
805	546	MAGRUDER	94CN6690	743	0.398
806	124	HIDALGO	94SB3400	880	0.398
807	459	COLUMBUS	94CN930	924	0.396
808	253	OZONA	97SA3555	162	0.395
809	101	FT CHADBOURNE	97SA6520	535	0.387
810	454	NORTH EDINBURG	94SB560	1021	0.386
811	635	STADIUM	94LA6950	532	0.383

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIFI Ranking	2016 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIFI Value
812	128	SPUR	97AB260	154	0.383
813	557	MAGRUDER	94CN6680	698	0.383
814	270	NORTH MERCEDES	94SB3770	1657	0.380
815	68	THROCKMORTON	97AB3190	608	0.378
816	404	WASHINGTON STREET	94LA2350	2971	0.376
817	556	EAGLE PASS CITY	94LA2745	922	0.375
818	500	SAN BENITO	94SB4945	1746	0.375
819	293	EAGLE LAKE	94CN9455	599	0.371
820	352	SA JACKSON ST	97SA4260	664	0.370
821	136	HASKELL 12KV	97AB5240	643	0.369
822	49	LA GRULLA	94SB5005	1142	0.367
823	566	ALICE	94LA2530	1460	0.366
824	191	AB ELMDALE	97AB4520	247	0.364
825	512	PALMVIEW	94SB9685	2841	0.364
826	184	ANNA STREET	94LA2250	1525	0.363
827	69	CHILDRESS 69	97AB1800	541	0.362
828	760	ROCKSPRINGS	94LA8040	324	0.361
829	323	JOURDANTON	94LA5695	713	0.360
830	254	SA SOUTH	97SA3995	1373	0.360
831	312	MCCOLL ROAD	94SB1655	1336	0.359
832	764	NORTH EDINBURG	94SB3810	1244	0.357
833	555	NORTH MCALLEN	94SB2980	1756	0.356
834	403	ARANSAS PASS	94CS650	790	0.354
835	38	MCCAMEY	97SA2830	460	0.354
836	267	BLUFFS	97SA7280	1448	0.354
837	305	PORT LAVACA	94CN2490	1046	0.354
838	212	BLUFFS	97SA9110	604	0.353
839	164	EL CAMPO	94CN5745	902	0.350
840	698	CHARLOTTE	94LA1960	499	0.349
841	256	YELLOW JACKET	97SA5505	525	0.347
842	335	AFTON	97AB2225	52	0.346
843	62	CARRIZO SPRINGS	94LA910	877	0.340
844	541	WEST HARLINGEN	94SB3700	1779	0.340
845	256	MOCKINGBIRD	94CN400	389	0.339
846	126	EDITH HUMBLE	97SA6170	83	0.337
847	499	HIGHWAY 9	94CS6720	1319	0.334
848	679	WESLACO UNIT	94SB8610	1139	0.334
849	356	KARNES CITY	94CN2315	1052	0.333
850	231	AB HARTFORD ST	97AB3815	1114	0.331
851	174	TATTON	94CN8490	340	0.329
852	529	MAGRUDER	94CN7690	553	0.329
853	273	HARLINGEN	94SB370	1194	0.328
854	214	CATARINA	94LA2380	190	0.326
855	455	LEARY LANE	94CN6005	1380	0.325
856	344	NORTH VICTORIA	94CN6390	1493	0.323
857	595	STADIUM	94LA8540	1578	0.323
858	351	HOLLY	94CS1370	1893	0.319
859	551	RAYMONDVILLE #2	94SB1280	1004	0.315

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIFI Ranking	2016 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIFI Value
860	341	PORT ARANSAS	94CS3030	709	0.315
861	707	ODEM	94CS5575	67	0.313
862	309	MARFA	97SA1900	753	0.313
863	630	SOUTH MISSION	94SB3590	561	0.312
864	200	STADIUM	94LA7810	1575	0.312
865	419	NORTH VICTORIA	94CN7770	828	0.312
866	218	MERTZON (CVEC)	97SA1530	325	0.311
867	267	BAY CITY	94CN2050	530	0.309
868	226	DIMITT	94LA4120	1310	0.308
869	321	SOUTH MISSION	94SB5215	1246	0.306
870	606	WEST MCALLEN	94SB4815	677	0.306
871	197	AB MAPLE ST	97AB5750	390	0.305
872	623	PALMVIEW	94SB9680	1005	0.300
873	193	CHILLICOTHE	97AB4525	117	0.299
874	106	BUENA VISTA	94LA8965	926	0.299
875	365	NORDHEIM	94CN3380	171	0.298
876	93	ROBY	97AB3795	71	0.296
877	319	SA COKE ST	97SA3905	661	0.295
878	140	WESMER	94SB6900	1635	0.294
879	57	GONZALES	97SA15390	1319	0.293
880	289	HALL ACRES ROAD	94SB4895	870	0.293
881	179	HIGHWAY 9	94CS6760	1042	0.292
882	363	CITRUS CITY	94SB9775	1507	0.291
883	654	WASHINGTON STREET	94LA2360	210	0.290
884	475	NORTH EDINBURG	94SB3570	2107	0.289
885	291	AB VOGEL ST	97AB4410	767	0.288
886	513	KLEBERG	94CS9395	1287	0.287
887	672	WEIL TRACT (138/12KV)	94CS1990	1382	0.287
888	434	ROCKPORT	94CS5940	35	0.286
889	305	MUNDAY REA (BKEC)	97AB2015	21	0.286
890	94	CHILDRESS 69	97AB1480	288	0.285
891	137	AB ONYX REA	97AB3260	141	0.284
892	50	CISCO	97AB6530	529	0.284
893	711	EL CAMPO	94CN7260	531	0.282
894	521	PORT ARANSAS	94CS990	1437	0.281
895	173	LEARY LANE	94CN1890	1627	0.278
896	396	PONDER KENNEDY	97SA50208	11	0.273
897	592	LAREDO PLANT	94LA8505	771	0.272
898	266	ALICE	94LA2540	955	0.272
899	390	HARLINGEN SWITCH	94SB4090	2289	0.272
900	209	AB WALNUT ST	97AB3445	70	0.271
901	522	EAGLE PASS CITY	94LA2650	1284	0.270
902	88	WASHINGTON STREET	94LA6355	986	0.269
903	346	SA AVENUE N	97SA1730	799	0.267
904	236	AB COUNTRY CLUB	97AB4735	124	0.266
905	44	CISCO	97AB9715	977	0.260
906	33	MCCAMEY	97SA2420	116	0.259
907	610	SOUTH MISSION	94SB3620	1951	0.258

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIFI Ranking	2016 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIFI Value
908	New	ESCONDIDO	94LA3775	144	0.257
909	671	NORTH MCALLEN	94SB9640	1513	0.256
910	326	STAMFORD PUMP	97AB3930	43	0.256
911	261	BENJAMIN (BEPC)	97AB5680	157	0.255
912	590	MATHIS	94CS1420	908	0.254
913	418	MARKHAM	94CN6440	470	0.253
914	211	YELLOW JACKET	97SA7935	791	0.250
915	156	WASHINGTON STREET	94LA6525	2720	0.247
916	284	DIMITT	94LA5545	570	0.246
917	278	ANNA STREET	94LA900	2846	0.242
918	35	FT CHADBOURNE	97SA6515	91	0.242
919	320	SA WALNUT ST	97SA3925	879	0.241
920	568	AIRLINE	94CS9605	705	0.241
921	533	COLUMBUS	94CN6180	461	0.241
922	112	EDNA	94CN5775	505	0.240
923	283	CLYDE	97AB3630	570	0.237
924	574	LEARY LANE	94CN1430	1666	0.236
925	72	HIGHWAY 9	94CS6780	814	0.235
926	677	KINGSVILLE	94CS1140	1039	0.233
927	368	AB MCMURRY	97AB4355	985	0.232
928	99	QUANAH	97AB3530	332	0.232
929	36	SAND ROAD	97AB5195	239	0.230
930	307	KINGSVILLE	94CS1130	2305	0.230
931	237	AB OIL MILL	97AB3900	680	0.229
932	264	HASKELL 12KV	97AB3495	803	0.229
933	122	CISCO	97AB1020	419	0.229
934	380	NORTH WESLACO	94SB4810	1459	0.227
935	204	SOUTH MISSION	94SB3940	843	0.227
936	656	DEL MAR	94LA3440	1413	0.225
937	240	AB OIL MILL	97AB2785	247	0.223
938	190	CLYDE	97AB1760	437	0.222
939	469	NORDHEIM	94CN4275	77	0.221
940	440	WEST MCALLEN	94SB4555	1654	0.221
941	152	MORRIS STREET	94CS7625	562	0.215
942	245	SA JACKSON ST	97SA4690	1115	0.213
943	738	PALMHURST	94SB3890	2605	0.213
944	210	KLEBERG	94CS8140	634	0.213
945	638	SOUTH MISSION	94SB4650	1014	0.212
946	384	PAULANN	97SA6285	62	0.210
947	561	NORTH VICTORIA	94CN1470	459	0.209
948	643	BAY CITY	94CN7480	2079	0.209
949	194	EAST HARRISON	94SB3000	524	0.208
950	448	CITRUS CITY	94SB3470	1566	0.208
951	142	MINES ROAD	94LA3745	2013	0.207
952	232	PADUCAH CITY	97AB1930	582	0.206
953	395	SOUTH MCALLEN	94SB5065	127	0.205
954	213	CROWELL	97AB3980	490	0.204
955	108	BRONTE	97SA3590	177	0.203

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIFI Ranking	2016 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIFI Value
956	290	DEVINE	94LA7100	979	0.203
957	261	MATHIS	94CS1410	473	0.203
958	718	PHARR	94SB1640	1303	0.203
959	709	ROCKSPRINGS	94LA2600	375	0.200
960	New	CLARKWOOD	94CS2170	10	0.200
961	325	NORTH PADRE ISLAND	94CS1010	2114	0.200
962	274	EL GATO	94SB890	2846	0.199
963	417	KARNES CITY	94CN2340	809	0.199
964	729	AIRLINE	94CS6970	1370	0.195
965	81	ALPINE 12KV	97SA3160	1075	0.194
966	39	PAISANO	97SAPAISAN	139	0.194
967	189	SPUR	97AB5170	371	0.194
968	299	AB ELM CREEK	97AB4780	485	0.194
969	132	ROCHESTER	97AB3295	228	0.193
970	593	RAYMONDVILLE #1	94SB800	722	0.193
971	366	SHARYLAND	94SB2020	2392	0.192
972	23	COTULLA	94LA460	507	0.191
973	106	ALPINE 12KV	97SA3155	1119	0.191
974	180	AB MCMURRY	97AB4350	701	0.191
975	282	SA COKE ST	97SA4910	1726	0.190
976	702	UNIVERSITY	94LA305	2125	0.190
977	439	PREMONT	94LA2720	763	0.189
978	538	DEVINE	94LA7090	994	0.188
979	496	NORTH VICTORIA	94CN7860	1500	0.187
980	315	SA WALNUT ST	97SA4635	1526	0.185
981	484	NORTH MCALLEN	94SB9660	2009	0.183
982	255	CONTINENTAL	94SB4080	66	0.182
983	142	SWENSON	97AB136	33	0.182
984	323	PAINT ROCK	97SA5235	124	0.177
985	686	KLEBERG	94CS6410	273	0.176
986	583	GREGORY	94CS420	452	0.175
987	473	SANTO NINO	94LA70	1163	0.175
988	288	GONZALES	97SA14685	1076	0.174
989	292	ABILENE PLANT	97AB1575	606	0.172
990	699	COTULLA	94LA110	35	0.171
991	412	EAST HARRISON	94SB3080	414	0.167
992	589	SINTON	94CS1750	505	0.166
993	453	SAN BENITO	94SB3910	1780	0.164
994	644	HARLINGEN SWITCH	94SB5350	893	0.163
995	66	ROARING SPRINGS	97AB2065	217	0.161
996	268	BALLINGER	97SA4395	526	0.160
997	180	HEARN ROAD	94CS8980	1253	0.160
998	252	EAST HARRISON	94SB4620	743	0.159
999	395	SA SOUTH	97SA4255	866	0.158
1000	284	HIGHLAND	97SA6370	508	0.157
1001	735	ROMA	94SB3070	1237	0.155
1002	307	SA JACKSON ST	97SA4265	796	0.155
1003	61	VERNON	97AB5000	248	0.153

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIFI Ranking	2016 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIFI Value
1004	429	MUSTANG ISLAND	94CS9470	686	0.153
1005	20	GARWOOD CITY	94CN2560	197	0.152
1006	446	EDNA	94CN5765	1123	0.152
1007	112	CISCO	97AB7400	815	0.152
1008	394	SA EMERSON ST	97SA4625	410	0.151
1009	386	PAINT ROCK	97SA1110	68	0.147
1010	530	HAIN DRIVE	94SB3490	1136	0.147
1011	269	AB WALNUT ST	97AB3110	943	0.146
1012	579	SAN BENITO	94SB4135	1263	0.146
1013	338	WEAVER ROAD	94CN1910	21	0.143
1014	143	MILES	97SA4670	525	0.143
1015	317	AB ELM CREEK	97AB1820	91	0.143
1016	97	RANKIN	97SA5735	407	0.143
1017	516	EAST HARRISON	94SB4310	1188	0.141
1018	104	MARFA	97SA1905	1108	0.139
1019	694	EAGLE PASS CITY	94LA7060	853	0.138
1020	244	SANTO NINO	94LA80	1888	0.137
1021	53	BAIRD	97AB5120	439	0.134
1022	14	GANADO	94CN5815	597	0.134
1023	120	AB ELM CREEK	97AB4775	876	0.132
1024	761	SIERRA VISTA	94LA3540	360	0.131
1025	111	BALLINGER	97SA4375	1038	0.130
1026	701	MORRIS STREET	94CS8840	587	0.129
1027	351	AB HARTFORD ST	97AB3690	170	0.129
1028	678	ESCONDIDO	94LA1510	726	0.127
1029	32	HAWLEY	97AB4455	592	0.127
1030	New	CARRIZO SPRINGS	94LA750	596	0.126
1031	265	AB RAINEY CREEK	97AB4270	1377	0.125
1032	658	GATEWAY	94LA5055	2555	0.125
1033	251	AB ELM CREEK	97AB1810	836	0.124
1034	687	WEST MCALLEN	94SB4595	1187	0.123
1035	250	CLYDE	97AB3635	725	0.123
1036	59	SA AVENUE N	97SA1695	1439	0.121
1037	127	VERNON	97AB1750	251	0.120
1038	357	SA SOUTHLAND HILLS	97SA5055	831	0.119
1039	93	CONTINENTAL	94SB4880	68	0.118
1040	95	RODD FIELD	94CS3010	1962	0.117
1041	263	WYLIE	97AB2665	1039	0.116
1042	768	LAREDO PLANT	94LA8705	235	0.115
1043	75	SANTO NINO	94LA75	1518	0.115
1044	287	AB CANYON ROCK	97AB5030	865	0.114
1045	277	HIGHLAND	97SA6385	1307	0.114
1046	353	AB HARTFORD ST	97AB3820	918	0.113
1047	591	BROOKHOLLOW	94CN7190	278	0.112
1048	119	SANTA ANNA	97SA3415	324	0.111
1049	350	AB ELM CREEK	97AB4745	959	0.108
1050	289	MATADOR	97AB3090	316	0.108
1051	70	HAROLD	97AB3055	28	0.107

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIFI Ranking	2016 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIFI Value
1052	374	HALL ACRES ROAD	94SB9595	1161	0.107
1053	755	MILO	94LA3065	209	0.105
1054	321	BALLINGER	97SA4370	816	0.103
1055	90	SANTO NINO	94LA645	1691	0.102
1056	215	HOLLY	94CS9675	1775	0.101
1057	252	CEDAR GAP (TEC)	97AB5445	289	0.100
1058	273	KNOX CITY	97AB3985	20	0.100
1059	281	AFTON	97AB2310	240	0.100
1060	306	AB SHELTON ST	97AB3145	1054	0.095
1061	9	RANKIN	97SA6400	170	0.094
1062	757	WEST MCALLEN	94SB6385	240	0.092
1063	255	KNOX CITY	97AB3300	471	0.091
1064	271	ABILENE PLANT	97AB1915	66	0.091
1065	147	AB REBECCA LANE	97AB5550	714	0.090
1066	89	SANTO NINO	94LA695	1610	0.089
1067	223	SA EMERSON ST	97SA4620	435	0.087
1068	745	KEPLER	94CS1700	23	0.087
1069	286	SA JACKSON ST	97SA4685	1416	0.086
1070	763	MAYBERRY	94SB5340	35	0.086
1071	151	AB OVER STREET 12KV	97AB3140	661	0.085
1072	749	RIO BRAVO	94LA300	808	0.084
1073	401	DEL MAR	94LA10	1998	0.084
1074	696	HEIGHTS	94LA6820	1859	0.083
1075	257	AB OVER STREET 12KV	97AB1840	883	0.082
1076	329	SA SOUTH	97SA3990	737	0.081
1077	599	HAIN DRIVE	94SB9240	37	0.081
1078	118	CHILDRESS 69	97AB2800	334	0.081
1079	340	AB OIL MILL	97AB2780	735	0.080
1080	714	UNIVERSITY	94LA920	598	0.080
1081	189	SOUTH MCALLEN	94SB3935	986	0.080
1082	312	BRONTE	97SA3560	254	0.079
1083	145	WAGGONER	97AB5900	26	0.077
1084	221	AB SHELTON ST	97AB3660	647	0.074
1085	721	MINES ROAD	94LA4275	27	0.074
1086	178	EAST HARRISON	94SB3030	681	0.073
1087	325	EDEN	97SA1780	237	0.072
1088	388	HIGHLAND	97SA6375	266	0.071
1089	730	AIRLINE	94CS9390	2801	0.071
1090	144	CROCKETT HEIGHTS	97SA73703	73	0.068
1091	345	AB MAPLE ST	97AB4070	15	0.067
1092	398	SHARYLAND	94SB2010	1146	0.066
1093	259	MATADOR	97AB3030	214	0.065
1094	360	SA SOUTHLAND HILLS	97SA5455	1389	0.064
1095	260	AB DYESS 1	97AB1775	688	0.064
1096	349	SA LAKE DR	97SA6030	665	0.063
1097	158	AB MCMURRY	97AB4360	1081	0.063
1098	46	OZONA	97SA3810	612	0.062
1099	415	SHARYLAND	94SB2035	725	0.062

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIFI Ranking	2016 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIFI Value
1100	303	ABILENE PLANT	97AB1910	258	0.062
1101	390	EDEN	97SA3195	501	0.062
1102	177	CHILDRESS 20TH ST	97AB5725	662	0.060
1103	354	TWILIGHT TRAIL	97AB4285	1131	0.060
1104	205	SHARYLAND	94SB2150	1454	0.060
1105	769	HEIGHTS	94LA9080	690	0.059
1106	New	JOSLIN POWER PLANT	94CN8720	17	0.059
1107	400	SA COKE ST	97SA4915	17	0.059
1108	380	RUSSEK STREET	97SA12295	312	0.058
1109	207	FT DAVIS	97SA3345	436	0.057
1110	230	VERNON	97AB1520	743	0.055
1111	279	SA AVENUE N	97SA1975	327	0.055
1112	6	PRAIRIE PUMP	94CN1940	77	0.052
1113	374	SA WALNUT ST	97SA3915	780	0.051
1114	733	POLK AVENUE	94SB4180	1291	0.051
1115	196	CHILDRESS 20TH ST	97AB5720	180	0.050
1116	741	MORRIS STREET	94CS7465	801	0.049
1117	296	SA SOUTHLAND HILLS	97SA5050	884	0.049
1118	379	GIRARD	97AB6260	42	0.048
1119	247	AB ELMDALE	97AB4085	43	0.047
1120	125	SA NORTH	97SA3120	1104	0.045
1121	278	INDIAN MESA	97SA2690	67	0.045
1122	720	PORTLAND	94CS9270	1523	0.045
1123	381	ABILENE PLANT	97AB3175	112	0.045
1124	703	MAYBERRY	94SB3010	90	0.044
1125	349	NORTH MCALLEN	94SB3830	1362	0.043
1126	744	AIRLINE	94CS5870	948	0.042
1127	148	AB HARTFORD ST	97AB3685	363	0.041
1128	365	AB REBECCA LANE	97AB6915	992	0.040
1129	392	SA SOUTHLAND HILLS	97SA5860	1176	0.039
1130	362	SA LAKE DR	97SA5880	774	0.039
1131	414	ZAPATA	94LA7330	1350	0.039
1132	776	MAYBERRY	94SB6450	26	0.038
1133	367	COLLEGE HILLS	97SA4840	209	0.038
1134	342	AB OIL MILL	97AB3895	138	0.036
1135	366	TWILIGHT TRAIL	97AB3150	718	0.036
1136	737	AIRLINE	94CS8370	279	0.036
1137	717	UNIVERSITY	94LA465	858	0.035
1138	229	GOODWIN	94SB3530	346	0.035
1139	178	KIRKLAND	97AB3545	29	0.034
1140	387	SA WALNUT ST	97SA3910	146	0.034
1141	7	ACME BESTWALL	97AB4150	64	0.031
1142	468	MUSTANG ISLAND	94CS8510	457	0.031
1143	747	MILO	94LA3060	136	0.029
1144	347	BRONTE	97SA4160	209	0.029
1145	238	SHEFFIELD	97SA6430	249	0.028
1146	297	SA AVENUE N	97SA1655	502	0.028
1147	30	HAMLIN	97AB3775	254	0.028

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIFI Ranking	2016 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIFI Value
1148	79	ROWENA	97SA4480	221	0.027
1149	216	AB ELM CREEK	97AB1815	370	0.027
1150	372	AB REBECCA LANE	97AB2710	263	0.027
1151	772	KEPLER	94CS2665	41	0.024
1152	723	EAGLE PASS CITY	94LA2510	588	0.024
1153	339	AB EAST 12KV	97AB4820	1148	0.024
1154	371	SPUR	97AB300	216	0.023
1155	169	AB VOGEL ST	97AB4650	810	0.021
1156	399	AB CANYON ROCK	97AB5025	51	0.020
1157	389	SA JACKSON ST	97SA4695	562	0.020
1158	208	MILO	94LA6940	422	0.019
1159	313	JAYTON	97AB6125	350	0.017
1160	65	SA CONCHO	97SA1705	898	0.014
1161	697	POINT COMFORT	94CN6060	369	0.014
1162	378	AB COUNTRY CLUB	97AB4725	226	0.013
1163	102	ROTAN	97AB1865	190	0.011
1164	175	COLLEGE HILLS	97SA5520	434	0.009
1165	246	SA EMERSON ST	97SA4860	243	0.008
1166	382	AB EAST 12KV	97AB4825	421	0.007
1167	164	SA SOUTH	97SA3500	282	0.007
1168	139	SA CONCHO	97SA1715	287	0.007
1169	373	AB EAST 12KV	97AB4830	612	0.007
1170	377	COLLEGE HILLS	97SA4845	230	0.004
1171	754	ZACATE CREEK	94LA2675	1180	0.003
1172	393	PAULANN	97SA6310	980	0.000
1173	205	SILVER	97SA4295	14	0.000
1174	43	SA CONCHO	97SA3325	49	0.000
1175	163	SA CONCHO	97SA1725	24	0.000
1176	113	FLOMONT	97AB81335	34	0.000
1177	402	ONYX REA	97AB3255	30	0.000
1178	224	TRENT	97AB2850	26	0.000
1179	355	AB ELM CREEK	97AB1825	222	0.000
1180	244	ABILENE PLANT	97AB1740	18	0.000
1181	432	MCCOLL ROAD	94SB4910	339	0.000
1182	New	LA GRULLA	94SB3045	1116	0.000
1183	775	WASHINGTON STREET	94LANETLAR	163	0.000
1184	774	UNIVERSITY	94LA930	94	0.000
1185	391	KNIPPA	94LA6535	23	0.000
1186	773	MORRIS STREET	94CSNET CC	319	0.000
1187	New	CASA BLANCA	94CS5440	133	0.000
1188	771	VICTORIA POWER PLANT	94CNNETVIC	88	0.000
1189	767	KENEDY S.S.	94CN8320	154	0.000
1190	New	JOSLIN POWER PLANT	94CN7915	10	0.000

Feeders from last year that are not in this year's list

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIFI Ranking	2016 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIFI Value
	2016 Ranking	Substation Identification	Feeder ID	Reason not in 2017	
	483	POINT COMFORT	94CN2460	now <10 customers	
	120	GREENLAKE	94CN2750	now <10 customers	
	91	CORINTH	97AB2590	now <10 customers	
	257	CARRIZO SPRINGS	94LA4405	Retired	
	5	FLOMONT	97AB81330	Retired	

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

Total Number of Feeders

With 10 or more Customers

1190

Add or Delete Rows as Necessary

AEP Texas Inc.

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
1	33	ASPHALT MINES	94LA500	42	5,750.3
2	214	CONOCO-CHITTAM RANCH	94LA8580	38	1,412.1
3	72	VERHALEN	97SA4465	84	1,151.2
4	574	FULTON	94CS3070	1,412	1,037.1
5	48	BOBCAT HILLS	97SA6655	22	994.6
6	137	SUN VALLEY	97SA4300	62	981.1
7	67	LA PRYOR	94LA580	225	941.4
8	239	ARANSAS PASS	94CS8270	352	939.9
9	92	EAST HARRISON	94SB3950	609	931.3
10	217	ELSA	94SB710	2,039	911.1
11	575	HOLCOMB	94LA3025	323	895.4
12	67	INDIAN MESA	97SA2695	168	880.6
13	84	FALFURRIAS	94LA5210	1,120	864.5
14	70	PLACEDO	94CN7970	474	837.8
15	209	TURKEY	97AB2980	316	830.0
16	51	CROSS PLAINS	97AB2920	565	827.4
17	93	DARST	94CN790	248	809.9
18	164	PORT LAVACA	94CN8310	350	807.3
19	241	WOOLRIDGE	94CS1120	2,646	781.1
20	139	ROBSTOWN	94CS1650	366	766.6
21	283	ALAZAN	94CS2740	33	761.1
22	166	GRETA	94CN7890	256	760.4
23	275	MAYBERRY	94SB3160	557	744.6
24	101	CRESTONIO	94LA270	626	707.7
25	391	MAYO	94CS625	218	697.1
26	3	LA PRYOR	94LA570	145	692.4
27	131	SANTA RITA	97SA1105	75	687.3
28	130	LIVE OAK	94CS1090	279	666.7
29	327	SINTON	94CS360	310	665.5
30	68	LA GRULLA	94SB5110	998	662.3
31	21	MAVERICK	94LA9680	746	655.3
32	16	MASTERSON FIELD	97SA800	197	651.9
33	8	BIG WELLS	94LA2630	27	643.2
34	374	RANKIN	97SA6405	12	634.9
35	223	BROWNSVILLE	94SB4280	318	633.6
36	83	STAMFORD	97AB2815	698	633.1
37	321	ALAZAN	94CS620	173	623.0
38	75	BONNIEVIEW	94CS8020	451	614.3
39	6	BRYANTS RANCH	97SA205	18	601.8
40	1	PECOS VALLEY	97SA4075	21	600.1
41	260	LAGUNA	94CS9590	2,244	588.9
42	63	SUNCHASE	94SB1150	1,292	585.7
43	316	EDROY	94CS6990	279	579.6
44	296	SABINAL	94LA200	435	570.4
45	378	CHASE FIELD	94CN460	12	565.7

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
46	9	GOVERNMENT WELLS	94LA7240	208	562.9
47	379	VALERA HUMBLE	97SA7015	79	558.8
48	6	RAYMONDVILLE #2	94SB3250	29	550.0
49	123	MALONE	94CN7560	111	545.5
50	9	SPUDDER FLAT	97SA4180	44	545.3
51	280	WOODSBORO	94CS8330	277	539.2
52	435	TATTON	94CS950	394	538.1
53	85	MORAN	97AB2108	329	538.1
54	121	CLIMAX/BRADSHAW	97AB11301	61	525.3
55	87	BRUNI	94LA5440	127	525.2
56	2	FOSTER FIELD	94CN2550	65	523.6
57	4	RANDADO	94LA8350	132	519.6
58	588	RANGERVILLE	94SB3410	856	517.0
59	395	LAREDO PLANT	94LA8745	767	503.2
60	209	FULTON	94CS9050	1,311	501.3
61	226	POLK AVENUE	94SB4170	1,865	500.1
62	144	LULING - LCRA	94CN10	396	499.5
63	255	GREGORY	94CS5900	95	493.7
64	404	NIXON	94CN2025	513	490.5
65	7	WOODSON OIL FIELD	97AB30	32	483.0
66	155	FULTON	94CS440	1,827	476.8
67	697	RODD FIELD	94CS245	2,810	463.8
68	495	SOUTHSIDE	94CS8045	1,012	459.1
69	155	CHERRY CREEK TAP	97SA5245	43	455.1
70	5	ALPINE 12KV	97SA3875	536	454.3
71	New	SHROPSHIRE	94CN1240	65	452.4
72	205	GILA	94CS7840	767	451.3
73	190	FREER	94LA2900	166	451.3
74	21	BUSH KNOB	97AB5200	286	451.2
75	502	SOUTH PADRE ISLAND	94SB6440	2,665	451.0
76	54	RAYMONDVILLE #2	94SB3170	729	450.6
77	18	ASPR CONTINENTAL	97AB3830	23	446.9
78	100	ASPR CONTINENTAL	97AB4800	30	445.5
79	198	WEIL TRACT (138/12KV)	94CS5405	168	440.0
80	118	SANTA RITA	97SA1135	10	432.8
81	36	GILA	94CS350	142	431.5
82	678	ARANSAS PASS	94CS590	377	427.0
83	232	ELSA	94SB700	1,438	425.0
84	231	PARKER	94CN9010	19	424.6
85	19	MCELROY	97SA5165	122	420.8
86	111	BRUNI	94LA1120	282	419.1
87	37	MARKHAM	94CN5550	22	417.9
88	595	LAREDO PLANT	94LA8565	1,554	416.4
89	384	RIO RICO	94SB5050	1,793	416.4
90	611	TYNAN	94CS4000	27	413.1
91	130	BARNHART	97SA3725	149	411.9
92	363	GREGORY	94CS5920	700	410.5
93	122	BRONTE AMBASSADOR	97SA6650	15	408.4
94	179	RIO BRAVO	94LA5	717	406.8
95	222	LA GRULLA	94SB6150	1,509	394.6

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
96	224	BARNHART	97SA590	22	390.9
97	570	BISHOP	94CS7180	937	389.9
98	52	RISING STAR	97AB5080	575	386.7
99	114	BIG WELLS	94LA1570	439	386.5
100	610	HAMILTON ROAD	94LA9645	291	383.7
101	42	ELDORADO	97SA2880	339	382.5
102	347	WADSWORTH	94CN7660	1,391	376.8
103	253	CHOKE CANYON	94CN9255	358	376.7
104	202	LAGUNA	94CS9065	2,333	375.5
105	498	ODEM	94CS385	418	374.1
106	40	BLESSING	94CN8790	759	373.4
107	319	RACHAL	94LA8145	337	372.5
108	49	REFUGIO	94CN1040	168	372.3
109	672	FALFURRIAS	94LA1070	1,015	370.8
110	185	PHARAOH	94CS1365	683	365.6
111	20	ZAPATA	94LA2710	44	364.3
112	758	MAGNOLIA	94CN315	11	361.6
113	113	FULTON	94CS2020	1,623	360.2
114	196	CHRISTOVAL	97SA6620	567	359.8
115	336	WESLACO UNIT	94SB7630	2,562	358.4
116	11	ALBANY	97AB2029	249	357.9
117	46	WOOLRIDGE	94CS1110	1,697	355.8
118	603	PORT ISABEL S.S.	94SB4070	284	354.3
119	245	CABANISS	94CS80	1,296	350.8
120	57	FREER	94LA1500	210	345.0
121	425	PORT ARANSAS	94CS1000	1,933	344.7
122	640	AIRLINE	94CS8260	1,453	344.4
123	305	BRACKETTVILLE	94LA8460	1,177	343.9
124	326	PHARR	94SB1645	2,347	340.1
125	431	WOOLRIDGE	94CS1170	1,846	338.1
126	630	BANQUETTE	94CS9000	452	337.3
127	314	VERHALEN	97SA4460	19	337.1
128	99	EDNA	94CN5785	1,247	336.0
129	25	SPUDDER FLAT	97SA4175	52	334.4
130	142	ARANSAS PASS	94CS1250	589	334.2
131	34	AB RAINEY CREEK	97AB4225	113	332.4
132	129	FALFURRIAS	94LA2830	1,454	331.9
133	138	BRUNI	94LA1100	604	331.0
134	193	TAFT	94CS1180	999	326.8
135	28	CRYSTAL CITY	94LA8380	1,326	325.8
136	736	PAWNEE (STEC OWNED)	94CN22202	197	323.0
137	3	MCCAMEY	97SA2415	158	321.3
138	290	BANQUETTE	94CS130	235	319.6
139	48	PREMONT	94LA6570	751	318.8
140	664	PETTUS	94CN8210	332	317.6
141	74	LULING - LCRA	94CN20	279	317.5
142	71	GREENLAKE	94CN2760	1,131	317.5
143	307	HAMLIN SHELL	97AB6330	25	317.0
144	30	DUNE FIELD (N CRANE)	97SA3885	73	316.9
145	748	HALL ACRES ROAD	94SB3670	1,028	315.9

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
146	236	SAN BENITO	94SB3920	2,551	311.9
147	490	PALACIOS	94CN6830	815	311.6
148	633	COMSTOCK	94LA230	182	310.1
149	339	PHARAOH	94CS1285	1,781	308.6
150	267	THOMASTON	94CN9580	47	307.1
151	419	VICTORIA POWER PLANT	94CN7600	155	304.7
152	714	DEL RIO CITY	94LA9850	1,017	304.4
153	12	LOS FRESNOS	94SB4315	1,062	304.3
154	382	FULTON	94CS6070	3,152	300.3
155	303	ELSA	94SB3500	1,232	298.9
156	401	RIO GRANDE CITY	94SB3210	1,930	296.8
157	186	NIXON	94CN3300	572	294.1
158	125	PHARAOH	94CS5185	2,366	293.8
159	333	INGLESIDE CITY	94CS8050	1,269	293.7
160	15	MORAN	97AB2107	229	293.2
161	272	LEARY LANE	94CN6175	2,565	292.5
162	740	ALICE	94LA1780	239	290.6
163	152	RIO RICO	94SB8290	419	289.7
164	601	EL CAMPO	94CN7710	1,079	289.3
165	528	NORTH MCALEEN	94SB2750	2,773	288.4
166	355	NORTH ALAMO	94SB3580	838	287.6
167	478	VICTORIA POWER PLANT	94CN8070	620	287.2
168	598	VICTORIA POWER PLANT	94CN1390	1,099	287.1
169	104	ODEM	94CS375	1,069	286.1
170	73	PHARAOH	94CS5175	1,289	284.3
171	173	TURKEY	97AB3825	391	282.8
172	412	PETTUS	94CN1020	453	280.2
173	345	MOORE FIELD	94SB3960	2,073	279.3
174	360	DEL RIO CITY	94LA420	2,232	278.8
175	New	MEDIO CREEK	94CN1380	759	278.4
176	533	BROWNSVILLE	94SB4290	502	274.7
177	329	AFTON	97AB2355	46	270.7
178	507	BIG OAK	94CN420	145	270.5
179	639	LOLITA	94CN6330	30	269.9
180	New	GARCENO	94SB5490	496	268.8
181	285	NIXON	94CN6630	672	268.1
182	479	HOMEPORT	94CS4665	428	265.0
183	117	KNIPPA	94LA6365	323	264.1
184	393	ELSA	94SB3520	449	263.6
185	358	WEINERT	97AB6490	124	263.1
186	331	STAMFORD	97AB4565	797	261.4
187	201	SARAGOSA	97SA1552	721	260.9
188	554	SOUTHSIDE	94CS8005	746	260.5
189	242	CABANISS	94CS240	1,541	260.4
190	39	FASHING	94CN360	37	260.1
191	519	BEEVILLE	94CN8090	1,358	259.8
192	563	REFUGIO	94CN1210	181	259.3
193	44	MATTHEWS	94CN1740	164	258.9
194	94	LA PRYOR	94LA2440	709	258.0
195	55	NORTH MCCAMEY	97SA6555	486	257.7

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
196	582	TATTON	94CS8200	1,014	257.6
197	80	MORRIS STREET	94CS5655	420	256.5
198	89	KINGSVILLE	94CS1350	396	254.2
199	36	QUANAH	97AB100	91	251.0
200	237	CHILLICOTHE	97AB4530	497	250.8
201	180	BISHOP	94CS2690	561	249.5
202	569	DILLEY	94LA6400	170	248.2
203	7	NAVAL BASE	94CS9720	2,443	248.1
204	399	NAVAL BASE	94CS7950	329	247.5
205	113	SA MATHIS FIELD	97SA4790	171	247.3
206	217	PUTNAM	97AB2129	211	247.2
207	76	VICTORIA POWER PLANT	94CN8170	791	246.5
208	197	MELVIN	97SA940	44	245.9
209	685	NORTH PADRE ISLAND	94CS720	1,287	245.7
210	642	ARCADIA	94CS1360	1,494	245.3
211	456	RIO GRANDE CITY	94SB3220	1,335	245.1
212	674	PHARR	94SB1620	2,676	244.9
213	47	SONORA 138 SUB	97SA4805	447	244.8
214	496	SOUTH SANTA ROSA	94SB1240	1,584	244.4
215	278	STAMFORD	97AB6255	397	244.3
216	136	STAMFORD	97AB2835	131	241.9
217	343	MELVIN	97SA4955	89	241.2
218	360	SA SOUTH	97SA2595	946	240.7
219	91	PLEASANTON	94LA9505	1,735	240.3
220	270	PORTLAND	94CS6505	1,862	240.2
221	132	VALENTINE	97SA5590	208	240.2
222	273	PORTLAND	94CS9290	1,755	239.2
223	298	SOUTH SANTA ROSA	94SB1235	639	238.8
224	362	NORTH VICTORIA	94CN7440	1,591	238.6
225	543	MCKENZIE ROAD	94CS150	23	236.9
226	389	MORRIS STREET	94CS8715	1,604	236.5
227	653	POLK AVENUE	94SB4900	2,516	236.2
228	766	SKIDMORE	94CS380	155	235.7
229	667	HEARN ROAD	94CS2220	1,538	235.4
230	5	ENCINAL	94LA2160	228	235.2
231	62	CAMPWOOD	94LA3430	104	235.0
232	558	RIO GRANDE CITY	94SB3740	2,287	233.7
233	616	SEAWALL	94CS9420	690	232.3
234	133	FREISS RANCH	97SA4870	96	232.1
235	369	GRAYBACK	97AB3315	46	232.1
236	32	MCKENZIE ROAD	94CS140	283	231.5
237	177	ESCONDIDO	94LA2035	2,608	230.9
238	15	NAVAL BASE	94CS8540	1,582	230.2
239	764	SUNCHASE	94SB1155	1,458	229.7
240	59	ALBANY	97AB3640	322	229.2
241	New	SHROPSHIRE	94CN3575	30	229.1
242	103	EAGLE PASS CITY	94LA450	969	228.9
243	149	PREMONT	94LA6610	818	228.6
244	17	MOORE FIELD	94SB3120	157	228.6
245	590	FREER	94LA5200	1,017	225.8

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
246	476	SOUTHSIDE	94CS7955	1,066	225.4
247	464	HIDALGO	94SB3680	317	225.2
248	720	WEST MCALLEN	94SB4965	917	225.2
249	213	ARCADIA	94CS8570	1,455	225.0
250	304	AB MCMURRY	97AB3235	797	224.5
251	387	MORRIS STREET	94CS8820	1,241	224.4
252	537	DEL RIO CITY	94LA9790	2,336	223.2
253	716	HEARN ROAD	94CS9665	673	223.1
254	645	FOSTER FIELD	94CN8880	286	222.9
255	559	RIO GRANDE CITY	94SB3230	2,571	221.7
256	29	RANDADO	94LA8360	163	221.1
257	237	ARMSTRONG	94CS6050	72	220.3
258	469	WESLACO UNIT	94SB5970	2,393	219.2
259	374	RIO BRAVO	94LA1130	994	218.7
260	392	GOLIAD	94CN6540	1,193	218.3
261	1	THREE RIVERS	94CN8430	192	217.8
262	470	MOORE FIELD	94SB3110	650	217.2
263	19	PORT ISABEL S.S.	94SB3820	182	216.4
264	163	EDROY	94CS6980	196	216.3
265	732	AIRLINE	94CS8890	540	216.0
266	534	SOUTH SANTA ROSA	94SB7485	1,055	214.9
267	82	HOLLY	94CS1480	1,713	214.1
268	386	ESCONDIDO	94LA3350	494	213.5
269	268	ARCADIA	94CS6930	1,498	213.1
270	614	JOURDANTON	94LA250	778	210.4
271	485	HOLLY	94CS5820	941	208.4
272	334	AIRLINE	94CS7390	2,123	208.1
273	136	CLARKWOOD	94CS9570	1,141	207.1
274	408	SEAWALL	94CS9450	303	206.8
275	90	AB RAINEY CREEK	97AB4550	985	204.9
276	254	ROARING SPRINGS	97AB6155	30	204.8
277	460	BAY CITY	94CN6450	973	204.6
278	326	ROUNDTOP	97AB4490	46	204.6
279	400	RAYMONDVILLE #1	94SB620	637	204.6
280	129	RUSSEK STREET	97SA11370	177	203.9
281	388	HOLCOMB	94LA2240	447	203.6
282	572	MCCOLL ROAD	94SB4780	1,933	202.8
283	251	LEARY LANE	94CN7530	3,010	201.8
284	481	CAUSEWAY	94SB4795	1,215	199.6
285	16	GOVERNMENT WELLS	94LA6800	225	198.6
286	229	LIVE OAK	94CS1080	1,221	198.5
287	357	PALACIOS	94CN8550	45	198.4
288	145	NORTH MCALLEN	94SB5060	2,457	198.4
289	426	UVALDE	94LA9770	1,497	198.2
290	17	MESA VIEW	97SA7045	98	197.8
291	689	ROMA	94SB3060	1,549	197.2
292	171	SOUTHSIDE	94CS7925	1,266	196.8
293	139	THROCKMORTON	97AB2090	66	196.4
294	415	MILO	94LA8365	1,578	195.6
295	11	PREMONT	94LA2730	198	195.4

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
296	665	LAREDO PLANT	94LA9305	1,041	195.0
297	704	CASA BLANCA	94CS4170	1,022	194.6
298	580	HEIGHTS	94LA2100	2,122	194.4
299	373	HIGHWAY 9	94CS9830	151	194.3
300	86	MOCKINGBIRD	94CN370	39	194.0
301	131	AMISTAD DAM	94LA5450	1,192	193.3
302	227	CITRUS CITY	94SB7985	1,118	191.4
303	715	CLARKWOOD	94CS7220	825	191.2
304	468	ANNA STREET	94LA5780	684	191.1
305	312	NORTH MCALLEN	94SB5055	3,214	189.6
306	372	TRUSCOTT	97AB3845	30	189.1
307	191	MAGRUDER	94CN245	1,235	188.5
308	402	FALFURRIAS	94LA1080	455	188.2
309	320	CROSS PLAINS	97AB1795	419	188.2
310	189	BEN FICKLIN	97SA6180	1,027	186.4
311	122	HIGHWAY 9	94CS6770	1,141	184.2
312	625	CONTINENTAL	94SB3650	18	184.1
313	183	EL GATO	94SB780	1,668	183.8
314	581	SAN DIEGO	94LA2930	576	180.4
315	256	MATHIS	94CS1410	473	178.9
316	53	NORTH EDINBURG	94SB4240	2,502	178.5
317	594	EAGLE PASS CITY	94LA2770	2,948	178.3
318	424	PORT ISABEL S.S.	94SB9295	2,242	178.2
319	269	SA WALNUT ST	97SA3920	891	178.0
320	235	PHARAOH	94CS1185	1,596	177.9
321	725	MCKENZIE ROAD	94CS330	2,366	177.9
322	73	EOLA	97SA4950	241	177.2
323	658	REFUGIO	94CN1170	824	176.5
324	322	HARLINGEN SWITCH	94SB320	1,528	176.0
325	167	ALBANY	97AB3540	609	175.3
326	205	FT DAVIS	97SA4515	966	175.2
327	66	LYTLE	94LA2850	681	175.0
328	346	GREENLAKE	94CN2740	349	174.7
329	204	ARANSAS PASS	94CS660	691	174.4
330	592	ELSA	94SB690	2,370	173.5
331	88	OZONA	97SA4185	1,249	173.4
332	148	DEL RIO CITY	94LA1930	1,025	171.8
333	184	MCCOLL ROAD	94SB2810	2,321	171.5
334	New	FRIO	94LA2270	677	170.6
335	578	SKIDMORE	94CS600	364	170.6
336	494	PORT ARANSAS	94CS6940	1,352	170.6
337	218	WESMER	94SB7760	2,451	169.9
338	13	HAROLD	97AB1495	24	169.8
339	597	ANNA STREET	94LA850	1,572	169.7
340	354	SHAFTER	97SA5110	53	168.6
341	628	SOUTH PADRE ISLAND	94SB4695	1,315	168.5
342	301	JUNCTION	97SA4340	794	168.1
343	134	MCCAMEY	97SA2855	76	167.5
344	133	MORRIS STREET	94CS8830	1,540	166.3
345	137	CLARKWOOD	94CS7230	614	166.0

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
346	79	AB RAINEY CREEK	97AB4220	190	166.0
347	264	KLEBERG	94CS6000	1,467	165.6
348	170	HEARN ROAD	94CS8990	1,255	165.6
349	144	CEDAR GAP (TEC)	97AB4115	491	164.9
350	542	SOUTHSIDE	94CS7995	1,561	164.7
351	702	GATEWAY	94LA350	1,836	163.6
352	276	SOUTHSIDE	94CS8025	1,065	163.6
353	521	BUENA VISTA	94LA9385	1,275	163.6
354	638	POLK AVENUE	94SB4190	1,698	162.6
355	381	HALL ACRES ROAD	94SB3460	3,281	162.6
356	722	RAYMONDVILLE #1	94SB630	792	161.8
357	282	GATEWAY	94LA390	2,070	161.8
358	453	WESMER	94SB1850	1,383	161.7
359	487	MOCKINGBIRD	94CN305	302	161.2
360	147	GILA	94CS345	60	161.0
361	195	ROCKPORT	94CS5950	522	160.4
362	571	CAUSEWAY	94SB4765	961	159.7
363	637	PALMVIEW	94SB7595	3,105	158.2
364	403	PALACIOS	94CN6840	1,546	157.5
365	434	PEARSALL	94LA7050	939	157.4
366	309	WASHINGTON STREET	94LA7015	1,539	157.1
367	703	POLK AVENUE	94SB4520	935	156.9
368	615	MORRIS STREET	94CS8850	497	156.6
369	164	TANKERSLY (CVEC)	97SA5260	438	156.1
370	219	KENEDY	94CN1970	562	156.0
371	169	HOLLY	94CS7620	2,701	155.9
372	397	TALPA ATLANTIC	97SA5180	60	155.8
373	396	MORRIS STREET	94CS2515	1,071	155.7
374	68	CROSS PLAINS	97AB2915	749	155.6
375	116	PLACEDO	94CN7980	408	155.0
376	446	SOUTHSIDE	94CS5335	1,297	154.9
377	126	BAIRD	97AB5125	594	153.8
378	146	BLACK BAYOU	94CN1120	306	153.5
379	546	HEIGHTS	94LA2450	2,566	153.4
380	40	QUANAH	97AB3975	202	153.2
381	174	ARCADIA	94CS1440	1,677	152.9
382	586	KENEDY S.S.	94CN8340	333	152.8
383	10	SARAGOSA	97SA1590	74	152.4
384	201	CRYSTAL CITY	94LA1425	1,140	152.0
385	234	COFFEE PORT	94SB1090	1,197	151.9
386	599	NORTH MCALLEN	94SB4995	2,442	150.8
387	385	VERNON CITY PLANT	97AB5770	99	150.8
388	398	COFFEE PORT	94SB1095	991	150.6
389	356	CASA BLANCA	94CS1300	276	150.3
390	560	HEIGHTS	94LA9400	1,371	150.3
391	450	PLEASANTON	94LA120	1,246	150.1
392	428	ARCADIA	94CS1400	438	149.7
393	330	STADIUM	94LA7800	677	149.1
394	20	MIDWAY LANE	97SA3440	60	148.9
395	300	DEVINE	94LA8100	1,574	148.4

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
396	401	SONORA ATLANTIC (SWTEC)	97SA4415	24	148.3
397	278	HIGHWAY 9	94CS6730	536	148.2
398	622	PALMHURST	94SB2525	2,068	146.6
399	291	EL GATO	94SB720	2,430	146.6
400	22	STAFFORD HILL	94CN1550	225	146.5
401	28	SA CONCHO	97SA1700	501	145.5
402	688	RODD FIELD	94CS1730	2,177	145.5
403	244	KARNES CITY	94CN2325	663	145.5
404	186	RANKIN	97SA7425	165	145.2
405	531	SOUTH PADRE ISLAND	94SB5850	1,310	144.9
406	261	BAY CITY	94CN2700	1,075	144.1
407	472	UNIVERSITY	94LA950	2,627	143.5
408	383	SAN DIEGO	94LA2890	1,027	143.3
409	272	AB MCMURRY	97AB3245	797	143.2
410	63	TWILIGHT TRAIL	97AB4290	928	142.7
411	124	PECOS VALLEY	97SA4080	118	141.6
412	274	OLMITO	94SB4275	789	141.4
413	613	FREER	94LA6320	157	141.2
414	567	CARRIZO SPRINGS	94LA370	535	140.4
415	409	MINES ROAD	94LA3680	1,112	140.1
416	297	INGLESIDE CITY	94CS2495	260	139.9
417	192	SA MATHIS FIELD	97SA5100	223	139.0
418	57	TRENT	97AB4245	182	138.2
419	492	DEL RIO CITY	94LA430	2,540	138.0
420	463	BANDERA ELECTRIC (LEAKEY)	94LAL30	268	136.8
421	106	GANADO	94CN5795	482	136.8
422	173	HOLLY	94CS1950	826	136.7
423	151	CAMPWOOD	94LA2610	951	136.4
424	404	WYLIE	97AB6495	268	136.2
425	145	TWILIGHT TRAIL	97AB5855	1,439	135.7
426	287	SOUTH MCALLEN	94SB3640	301	135.0
427	477	PHARR	94SB1625	1,714	133.7
428	564	EL CAMPO	94CN2800	821	132.9
429	331	SINTON	94CS180	972	132.5
430	259	SOUTHSIDE	94CS7905	1,811	132.4
431	323	AB MCMURRY	97AB3240	753	131.8
432	138	WINTERS	97SA3765	781	131.4
433	635	MILO	94LA3070	2,778	131.3
434	377	CHARLOTTE	94LA8120	208	131.0
435	348	CRESTONIO	94LA260	1,744	130.3
436	41	WEIL TRACT (138/12KV)	94CS2520	155	129.4
437	605	JOURDANTON	94LA5685	1,191	129.0
438	535	ZACATE CREEK	94LA2635	311	128.8
439	27	ASHERTON	94LA2670	89	128.8
440	323	THREE RIVERS	94CN5190	477	128.4
441	43	MALONE	94CN7550	187	128.1
442	112	KITTIE WEST	94CN3765	317	125.6
443	77	BEN FICKLIN	97SA6175	693	125.5
444	169	ASPERMONT	97AB3380	400	125.4
445	416	BAY CITY	94CN1110	1,246	124.8

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
446	607	CHOKE CANYON	94CN5390	430	124.6
447	587	SEAWALL	94CS9325	1,488	124.6
448	421	ANNA STREET	94LA780	474	124.6
449	459	PALMVIEW	94SB3930	1,126	123.8
450	350	ROBY	97AB2276	305	123.2
451	134	BERCLAIR	94CN990	203	122.7
452	178	TYNAN	94CS4010	42	122.6
453	733	HIGHWAY 9	94CS7210	360	122.4
454	121	CABANISS	94CS75	2,208	122.3
455	240	ASPERMONT	97AB1070	322	122.0
456	417	LOS FRESNOS	94SB2160	1,429	121.9
457	93	SONORA 138 SUB	97SA4810	909	121.9
458	150	HOLLY	94CS7740	2,186	121.9
459	443	PUEBLO	94LA130	2,410	121.7
460	294	NORTH VICTORIA	94CN1580	1,021	120.3
461	423	WADSWORTH	94CN8630	683	120.1
462	465	EL CAMPO	94CN6370	747	119.7
463	261	ALBANY	97AB3655	616	119.2
464	79	BROWNSVILLE	94SB3050	1,979	118.0
465	220	CHRISTOVAL	97SA6615	423	117.9
466	765	SOUTH PADRE ISLAND	94SB4675	156	117.5
467	539	AIRLINE	94CS7280	642	117.5
468	701	POLK AVENUE	94SB4740	1,433	117.4
469	194	RACHAL	94LA6595	329	116.6
470	677	WEST MCALLEN	94SB4535	2,855	115.9
471	328	PORT LAVACA	94CN2480	1,524	115.8
472	432	DILLEY	94LA510	564	115.2
473	669	LAREDO PLANT	94LA8695	1,325	114.8
474	135	WEST HARLINGEN	94SB3720	2,096	114.4
475	651	ARCADIA	94CS1450	1,972	114.2
476	175	KINGSVILLE	94CS1670	427	114.2
477	284	ROBERT LEE	97SA4125	267	112.8
478	98	RODD FIELD	94CS225	2,503	112.3
479	655	HAINE DRIVE	94SB9700	1,104	112.2
480	747	PHARR	94SB1650	825	112.0
481	726	GATEWAY	94LA3595	1,520	111.8
482	754	BEEVILLE	94CN2380	206	111.3
483	58	PECAN BAYOU	97AB6815	1,502	110.7
484	634	PALMHURST	94SB2820	1,777	110.3
485	146	ROBERT LEE	97SA4120	563	110.1
486	553	CLARKWOOD	94CS5525	1,166	110.1
487	97	WEST OSO	94CS9090	1,683	110.1
488	488	JOURDANTON	94LA880	314	110.1
489	547	UVALDE	94LA550	702	109.4
490	156	YORKTOWN	94CN3130	469	109.2
491	211	RISING STAR	97AB5075	654	109.1
492	654	PALMVIEW	94SB6790	1,817	108.9
493	544	HAMILTON ROAD	94LA9655	1,247	108.9
494	248	HOLLY	94CS1220	3,314	108.8
495	753	DEL MAR	94LA7930	1,441	108.6

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
496	508	HIGHWAY 9	94CS7200	658	108.6
497	471	RANGERVILLE	94SB4060	888	108.0
498	325	HARLINGEN SWITCH	94SB4230	1,338	107.9
499	297	STERLING CITY	97SA1445	888	107.7
500	New	FLOMOT	97AB1852	72	107.4
501	555	STADIUM	94LA7490	1,287	107.4
502	New	GARCENO	94SB2165	692	107.1
503	350	WEST MCALLEN	94SB4505	1,861	106.9
504	324	NORTH PADRE ISLAND	94CS7900	2,156	105.8
505	24	LA GRULLA	94SB4120	1,412	105.7
506	120	TAFT	94CS1260	190	105.0
507	168	EAGLE LAKE	94CN310	735	104.2
508	119	NORTH MERCEDES	94SB3840	651	103.4
509	22	SANTA RITA	97SA1100	113	103.3
510	208	SAND ROAD	97AB5290	807	103.2
511	670	CITRUS CITY	94SB5070	913	103.0
512	234	VALENTINE	97SA6325	574	102.6
513	77	PARKER	94CN9260	109	101.9
514	659	GREGORY	94CS2420	818	101.6
515	750	YORKTOWN	94CN8380	775	101.6
516	127	SANTA ANNA	97SA3420	361	101.5
517	576	WESLACO UNIT	94SB2195	1,104	101.3
518	119	POWELL FIELD	97SA2528	24	101.1
519	584	HIDALGO	94SB4845	1,210	101.1
520	39	ANSON 12KV	97AB6635	412	101.0
521	666	UVALDE	94LA540	1,207	100.8
522	253	CLYDE	97AB1755	132	100.7
523	690	PORT ISABEL S.S.	94SB3760	707	100.4
524	288	ANSON 12KV	97AB6630	686	100.4
525	221	WESLACO UNIT	94SB7455	1,219	100.3
526	379	WEST OSO	94CS9085	890	100.1
527	520	HAIN DRIVE	94SB9690	532	100.1
528	306	JUNCTION	97SA4335	790	99.8
529	407	BUENA VISTA	94LA9035	2,549	99.7
530	721	CRYSTAL CITY	94LA7425	436	99.7
531	484	POLK AVENUE	94SB4610	1,179	99.6
532	154	WINTERS	97SA2113	810	99.5
533	211	CHARLOTTE	94LA2790	199	99.2
534	New	ESCONDIDO	94LA5730	1,188	99.1
535	687	HEIGHTS	94LA6810	2,067	98.9
536	240	PLEASANTON	94LA2080	1,621	98.7
537	341	COLLEGE HILLS	97SA6145	718	98.5
538	501	PALMHURST	94SB1300	2,124	98.3
539	35	ELDORADO	97SA1845	764	97.9
540	361	BEN FICKLIN	97SA6185	551	97.6
541	192	SINTON	94CS6860	1,644	97.5
542	160	BAY CITY	94CN6670	1,603	97.4
543	339	VERNON	97AB3340	525	97.1
544	96	BROOKHOLLOW	94CN7580	487	97.0
545	157	ARCADIA	94CS5030	1,575	97.0

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
546	220	SOUTHSIDE	94CS8035	1,097	96.8
547	352	MILO	94LA5020	1,873	96.7
548	668	AIRLINE	94CS9030	428	96.6
549	510	WESLACO UNIT	94SB8195	1,629	96.5
550	225	ARANSAS PASS	94CS9130	360	96.5
551	445	PALMHURST	94SB2535	2,315	95.6
552	13	THREE RIVERS	94CN5100	65	95.6
553	23	BLESSING	94CN1030	278	95.5
554	650	HALL ACRES ROAD	94SB8870	2,347	95.4
555	160	RULE	97AB3396	431	95.1
556	23	AB CANYON ROCK	97AB5035	944	94.3
557	90	BEEVILLE	94CN300	1,666	93.4
558	45	NORTH MERCEDES	94SB4860	1,503	93.2
559	86	TUSCOLA	97AB3305	1,030	93.2
560	243	GARCENO	94SB2135	2,127	93.1
561	370	GEORGE WEST	94CN730	921	93.1
562	621	NORTH VICTORIA	94CN2240	757	92.8
563	238	PLEASANTON	94LA9475	1,340	92.7
564	92	IRAAN	97SA2055	540	92.4
565	552	INGLESIDE CITY	94CS6040	390	91.9
566	96	TUSCOLA	97AB3730	1,334	90.5
567	172	PEARSALL	94LA5580	1,583	90.3
568	140	HOLLY	94CS1370	1,893	89.9
569	405	HARLINGEN	94SB660	1,937	89.5
570	34	LIVE OAK	94CS1070	2,294	89.3
571	18	PUEBLO	94LA95	1,475	89.0
572	317	BAY CITY	94CN5960	2,103	88.7
573	247	BEEVILLE	94CN2200	752	88.7
574	724	MCCOLL ROAD	94SB4790	2,017	88.5
575	55	BEEVILLE	94CN1760	1,831	88.5
576	515	HARLINGEN	94SB380	2,650	88.0
577	585	EAST HARRISON	94SB3190	1,483	87.6
578	47	ZAPATA	94LA8290	2,127	87.3
579	712	WASHINGTON STREET	94LA2470	453	86.7
580	8	RIO PECOS	97SA3835	128	86.6
581	532	EAST HARRISON	94SB4360	1,739	86.5
582	53	ESPY WELLS	97SA50207	27	86.4
583	244	AB SHELTON ST	97AB3045	555	86.0
584	64	MCCOLL ROAD	94SB4400	1,382	85.8
585	43	AB DYESS 2	97AB6335	360	85.7
586	52	SOUTH MCALLEN	94SB3850	603	85.7
587	154	UVALDE	94LA6620	2,779	85.3
588	100	CRESTONIO	94LA6660	765	85.2
589	38	RIO RICO	94SB8330	435	85.2
590	123	VERNON	97AB4275	590	85.2
591	749	AIRLINE	94CS7270	994	84.6
592	626	EL GATO	94SB910	2,443	84.6
593	104	SAND ROAD	97AB5295	529	84.2
594	107	KLEBERG	94CS280	1,275	83.4
595	132	WESMER	94SB9705	1,037	83.1

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
596	271	SAN DIEGO	94LA1980	594	83.1
597	222	SA NORTH	97SA3115	558	82.9
598	619	SOUTH SANTA ROSA	94SB1225	860	82.9
599	448	SOUTH SANTA ROSA	94SB1215	1,641	82.8
600	606	BEEVILLE	94CN8510	816	82.6
601	418	GEORGE WEST	94CN1320	707	82.3
602	620	SHARYLAND	94SB5635	2,168	82.1
603	286	GOLIAD	94CN8220	1,043	81.9
604	632	WEST OSO	94CS9095	1,599	81.4
605	59	TATTON	94CN8490	340	81.2
606	573	HAIN DRIVE	94SB8065	1,342	81.1
607	259	PECAN BAYOU	97AB6810	390	81.1
608	682	BROOKHOLLOW	94CN8960	586	81.1
609	390	PALMHURST	94SB2530	1,813	80.8
610	676	UVALDE	94LA480	1,293	80.6
611	196	ZAPATA	94LA8300	1,663	80.2
612	612	HAMILTON ROAD	94LA9665	967	80.1
613	557	HARLINGEN	94SB360	2,460	80.1
614	378	BLUFFS	97SA3005	231	80.0
615	325	PEACOCK	97AB1375	47	79.9
616	359	LOS FRESNOS	94SB7270	2,180	79.6
617	429	RAYMONDVILLE #2	94SB3240	949	79.4
618	215	AB VOGEL ST	97AB4405	567	79.3
619	85	VILLA CAVAZOS	94SB7615	1,048	78.5
620	271	SA EMERSON ST	97SA4630	1,189	78.5
621	174	AILEEN	97AB4600	253	78.5
622	708	RODD FIELD	94CS205	1,979	77.1
623	550	SAN BENITO	94SB4030	2,625	76.1
624	29	ROTAN	97AB1860	721	75.9
625	755	RAYMONDVILLE #1	94SB3130	277	74.9
626	540	REFUGIO	94CN5120	673	74.8
627	25	SIERRA VISTA	94LA9900	2,848	74.7
628	656	YORKTOWN	94CN8420	666	74.6
629	141	KENEDY	94CN6270	551	74.6
630	118	THREE RIVERS	94CN2010	305	74.4
631	695	DEL MAR	94LA220	2,590	74.4
632	142	MERTZON (CVEC)	97SA2905	584	74.3
633	257	EDITH HUMBLE	97SA6170	83	74.3
634	4	PERKINS PROTHO	97SA3180	22	73.7
635	31	CARANCAHUA	94CN5870	495	73.4
636	351	NORTH PADRE ISLAND	94CS5170	1,257	73.3
637	284	HEARN ROAD	94CS870	1,183	72.9
638	474	NORTH PADRE ISLAND	94CS1010	2,114	72.6
639	461	PORT ARANSAS	94CS990	1,437	72.4
640	467	NORTH WESLACO	94SB4830	516	72.1
641	257	EAGLE LAKE	94CN320	644	71.9
642	643	COLUMBUS	94CN9060	370	71.8
643	182	AB MCMURRY	97AB4510	827	71.4
644	288	WESMER	94SB4050	1,945	71.3
645	252	CLARKWOOD	94CS7610	113	71.0

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
646	518	ALICE	94LA1770	1,641	70.7
647	551	OLMITO	94SB715	618	70.7
648	353	LANTANA	94CS7150	273	70.6
649	549	O CONNER	94CN390	193	70.6
650	644	EAGLE PASS CITY	94LA2745	922	70.6
651	265	VILLA CAVAZOS	94SB1980	1,643	70.5
652	140	SA GRAPE CREEK	97SA5365	784	70.4
653	556	DEL MAR	94LA3440	1,413	70.4
654	744	ZACATE CREEK	94LA2665	1,704	70.1
655	593	ARCADIA	94CS1460	2,151	70.1
656	306	WASHINGTON STREET	94LA6525	2,720	70.0
657	202	RUSSEK STREET	97SA7705	1,339	70.0
658	366	WEAVER ROAD	94CN1900	57	69.9
659	629	LAREDO PLANT	94LA8505	771	69.9
660	359	COLLEGE HILLS	97SA5515	350	69.9
661	88	ASHERTON	94LA2660	616	69.5
662	516	MAYBERRY	94SB1790	743	69.5
663	548	CITRUS CITY	94SB6000	2,164	69.1
664	207	GARCENO	94SB2130	2,623	69.0
665	35	GARWOOD CITY	94CN2570	145	68.9
666	250	BEEVILLE	94CN490	949	68.5
667	238	AB VOGEL ST	97AB4560	1,459	68.2
668	403	AB WALNUT ST	97AB3250	11	68.0
669	368	CASA BLANCA	94CS55	848	67.9
670	706	MAYBERRY	94SB5770	808	67.8
671	751	SIERRA VISTA	94LA7360	2,941	67.8
672	321	SA COKE ST	97SA3905	661	67.8
673	385	VILLA CAVAZOS	94SB5680	1,773	67.3
674	512	HAIN DRIVE	94SB270	1,077	67.3
675	165	AILEEN	97AB6435	806	67.3
676	128	COTULLA	94LA610	1,503	66.2
677	623	PALMVIEW	94SB9680	1,005	66.0
678	763	NORTH EDINBURG	94SB3810	1,244	65.5
679	341	NORTH EDINBURG	94SB3570	2,107	65.4
680	175	SA NORTH	97SA3125	1,240	64.8
681	263	CARRIZO SPRINGS	94LA860	32	64.3
682	437	GOODWIN	94SB4625	1,867	64.3
683	224	HIGHWAY 9	94CS6720	1,319	64.2
684	657	SOUTH MCALLEN	94SB3790	2,165	63.6
685	436	RODD FIELD	94CS2190	2,750	63.3
686	50	QUANAH	97AB1830	609	62.9
687	338	KNOX CITY	97AB3390	369	62.9
688	81	SOUTH EAST EDINBURG	94SB4570	1,369	62.8
689	371	INGLESIDE CITY	94CS8060	2,071	62.5
690	536	WESMER	94SB4480	1,128	61.8
691	589	NORTH VICTORIA	94CN7430	1,687	61.8
692	102	LA GRULLA	94SB5005	1,142	61.4
693	262	MOCKINGBIRD	94CN400	389	61.3
694	511	SAN DIEGO	94LA2880	1,312	61.2
695	617	WEST HARLINGEN	94SB4870	1,042	61.2

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
696	32	QUANAHA	97AB3100	543	61.2
697	289	SOUTH EAST EDINBURG	94SB5045	2,197	61.1
698	158	CONTINENTAL	94SB4080	66	61.1
699	482	KLEBERG	94CS1560	1,416	60.9
700	26	CATARINA	94LA2380	190	60.7
701	372	NORTH EDINBURG	94SB560	1,021	60.7
702	207	PECAN BAYOU	97AB530	19	60.4
703	486	HALL ACRES ROAD	94SB5465	1,378	60.1
704	124	HIGHWAY 9	94CS6760	1,042	60.1
705	233	SOUTH EAST EDINBURG	94SB6580	1,521	59.6
706	499	ARCADIA	94CS5020	1,477	59.5
707	365	SAN YGNACIO	94LA16060	494	59.4
708	87	PLASTERCO (MVEC)	97AB2720	107	59.3
709	185	AB SHELTON ST	97AB4640	649	59.2
710	447	RAYMONDVILLE #2	94SB4160	346	59.1
711	506	EAGLE PASS CITY	94LA2650	1,284	58.8
712	181	SA LAKE DR	97SA5865	1,027	58.8
713	566	SOUTH EAST EDINBURG	94SB4550	2,125	58.8
714	342	MAGRUDER	94CN6700	1,355	58.7
715	422	EL CAMPO	94CN2860	1,476	58.6
716	203	EAGLE LAKE	94CN9455	599	57.6
717	770	KENEDY	94CN1960	64	57.4
718	264	SONORA	97SA2045	606	57.2
719	128	SA GRAPE CREEK	97SA4700	715	57.2
720	109	AB COUNTRY CLUB	97AB4855	772	57.1
721	483	TAFT	94CS5230	847	57.1
722	340	BAY CITY	94CN2050	530	56.8
723	170	TANKERSLY (CVEC)	97SA5265	367	56.8
724	94	HASKELL 12KV	97AB3770	443	56.6
725	10	CHARLOTTE	94LA2780	53	56.6
726	248	ABILENE PLANT	97AB1565	280	56.5
727	270	ALPINE 12KV	97SA6820	780	56.4
728	103	SA SOUTH	97SA4795	1,246	56.0
729	258	MAGRUDER	94CN7870	1,248	56.0
730	545	SOUTHSIDE	94CS8055	861	55.9
731	161	CRYSTAL CITY	94LA2170	738	55.9
732	691	SAN BENITO	94SB3860	234	55.7
733	199	GOODWIN	94SB4390	412	55.4
734	493	MAGRUDER	94CN6690	743	55.0
735	561	LEARY LANE	94CN1540	795	54.3
736	734	RUNGE	94CN3250	264	54.0
737	316	WYLIE	97AB6340	702	54.0
738	673	SOUTH MISSION	94SB3980	2,113	53.6
739	509	BROOKHOLLOW	94CN8950	889	53.4
740	277	YELLOW JACKET	97SA5505	525	53.2
741	60	RANGERVILLE	94SB3420	763	53.1
742	64	BRADY	97SA5015	195	53.1
743	301	NORTH MERCEDES	94SB3770	1,657	52.7
744	153	BUENA VISTA	94LA8965	926	52.6
745	65	ROCKPORT	94CS5930	1,238	52.4

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
746	206	LOS FRESNOS	94SB5335	2,452	52.3
747	332	RUSSEK STREET	97SA250	149	52.3
748	452	DILLEY	94LA3795	812	52.3
749	440	AIRLINE	94CS9605	705	52.1
750	266	COLUMBUS	94CN930	924	51.8
751	414	PORT LAVACA	94CN6850	669	51.6
752	231	BLUFFS	97SA7280	1,448	51.3
753	444	HEIGHTS	94LA2390	1,702	51.2
754	367	MATHIS	94CS340	1,363	51.0
755	191	MERTZON (CVEC)	97SA1530	325	50.9
756	300	AB WALNUT ST	97AB3785	483	50.7
757	99	THROCKMORTON	97AB3190	608	50.7
758	246	NORTH ALAMO	94SB4370	1,548	50.6
759	600	PUEBLO	94LA275	2,759	50.5
760	247	AB SHELTON ST	97AB3050	646	50.2
761	276	COLLEGE HILLS	97SA4835	441	50.1
762	227	AB OIL MILL	97AB3900	680	49.8
763	115	ARANSAS PASS	94CS8280	568	49.7
764	334	STAMFORD PUMP	97AB3930	43	49.4
765	42	RUNGE	94CN4465	373	49.0
766	45	KEMPER EXXON HUMBLE	97SA1490	27	49.0
767	646	LANTANA	94CS4095	200	48.8
768	361	GREGORY	94CS8560	255	48.1
769	743	COTULLA	94LA110	35	47.7
770	83	CARRIZO SPRINGS	94LA910	877	47.7
771	184	AB ELMDALE	97AB4520	247	47.1
772	78	PORTLAND	94CS9370	1,832	47.0
773	312	AB EAST 12KV	97AB5760	200	46.8
774	167	GOVERNMENT WELLS	94LA7250	540	46.7
775	299	PADUCAH CITY	97AB1930	582	46.7
776	60	MCCAMEY	97SA2420	116	46.6
777	304	GOODWIN	94SB7380	1,799	46.6
778	162	PEARSALL	94LA3675	722	46.5
779	302	PAULANN	97SA6280	421	46.5
780	335	MCCOLL ROAD	94SB1655	1,336	46.2
781	497	MAGRUDER	94CN7690	553	46.0
782	526	ALICE	94LA2530	1,460	45.9
783	107	MCCAMEY	97SA3670	359	45.8
784	527	ALICE	94LA1790	470	45.2
785	152	ANSON REA (SEC)	97AB5215	246	45.1
786	74	PUTNAM	97AB2131	127	45.1
787	171	AB MAPLE ST	97AB5755	1,561	45.0
788	165	BLESSING	94CN8780	63	45.0
789	101	MERKEL	97AB1895	711	44.9
790	24	SAND ROAD	97AB5195	239	44.7
791	337	DEL RIO CITY	94LA440	1,104	44.5
792	762	DEL MAR	94LA490	770	44.3
793	406	SAN BENITO	94SB4945	1,746	44.2
794	126	HIDALGO	94SB3400	880	44.0
795	433	CITRUS CITY	94SB3470	1,566	43.6

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
796	731	WEST MCALLEN	94SB4515	875	43.6
797	320	PORT LAVACA	94CN2490	1,046	43.6
798	541	HARLINGEN SWITCH	94SB4110	849	43.4
799	410	ARANSAS PASS	94CS650	790	43.2
800	157	PADUCAH CITY	97AB1935	283	43.1
801	189	SABINAL	94LA485	492	43.0
802	114	RANKIN	97SA5735	407	42.9
803	503	PALMVIEW	94SB9685	2,841	42.9
804	159	GOODWIN	94SB4380	1,508	42.9
805	353	ABILENE PLANT	97AB1735	87	42.9
806	292	ABILENE PLANT	97AB1570	679	42.8
807	279	CLYDE	97AB3630	570	42.8
808	661	WEIL TRACT (138/12KV)	94CS1990	1,382	42.7
809	190	SA GRAPE CREEK	97SA5220	664	42.7
810	292	MAGRUDER	94CN6680	698	42.4
811	679	CHARLOTTE	94LA1960	499	42.2
812	307	NORTH ALAMO	94SB3610	1,856	41.9
813	338	ANNA STREET	94LA2250	1,525	41.8
814	525	RAYMONDVILLE #2	94SB1280	1,004	41.6
815	680	UNIVERSITY	94LA305	2,125	41.3
816	357	AB SHELTON ST	97AB3040	178	41.2
817	505	UVALDE	94LA5060	1,350	41.2
818	365	HIGHLAND	97SA6380	413	41.2
819	596	NORTH MCALLEN	94SB2980	1,756	41.0
820	466	SHARYLAND	94SB6745	2,139	40.9
821	61	CISCO	97AB6530	529	40.8
822	102	CROWELL	97AB3490	177	40.3
823	309	SA JACKSON ST	97SA4260	664	40.2
824	565	THREE RIVERS	94CN2580	128	40.1
825	117	AB ELM CREEK	97AB5045	373	40.0
826	442	WASHINGTON STREET	94LA2350	2,971	39.9
827	698	ROCKSPRINGS	94LA2600	375	39.9
828	46	FT CHADBOURNE	97SA6520	535	39.4
829	166	SA NORTH	97SA3130	235	39.1
830	692	WESLACO UNIT	94SB9805	1,948	39.1
831	367	AB SHELTON ST	97AB3435	319	38.9
832	579	KINGSVILLE	94CS1660	1,935	38.9
833	346	AB REBECCA LANE	97AB5555	1,265	38.8
834	314	COTULLA	94LA90	330	38.3
835	318	AB COUNTRY CLUB	97AB4730	538	38.2
836	82	CHILDRESS 69	97AB1480	288	38.2
837	176	SANTO NINO	94LA515	1,529	37.9
838	80	CROCKETT HEIGHTS	97SA73703	73	37.9
839	368	AB MCMURRY	97AB4355	985	37.9
840	745	CAUSEWAY	94SB4775	1,052	37.7
841	524	KITTIE WEST	94CN3760	241	37.7
842	281	NORTH VICTORIA	94CN7770	828	37.5
843	269	WASHINGTON STREET	94LA6355	986	37.3
844	New	CLARKWOOD	94CS2170	10	37.2
845	97	SPUR	97AB260	154	36.7

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
846	369	MATHIS	94CS2870	871	36.6
847	627	TYNAN	94CS1855	137	36.3
848	228	STADIUM	94LA7810	1,575	36.0
849	396	PONDER KENNEDY	97SA50208	11	35.8
850	197	DIMMIT	94LA4120	1,310	35.7
851	299	POLK AVENUE	94SB4600	3,095	35.6
852	148	ALPINE 12KV	97SA6825	1,913	35.5
853	663	GATEWAY	94LA5055	2,555	35.2
854	179	AB MAPLE ST	97AB5750	390	35.1
855	591	COLUMBUS	94CN6180	461	35.0
856	305	SAND ROAD	97AB5655	614	35.0
857	135	WYLIE	97AB2675	782	34.8
858	262	MUNDAY	97AB6715	251	34.8
859	329	DIMMIT	94LA5545	570	34.7
860	71	CISCO	97AB9715	977	34.6
861	458	MUSTANG ISLAND	94CS9470	686	34.6
862	69	HIGHWAY 9	94CS6780	814	34.6
863	513	ROCKPORT	94CS5940	35	34.3
864	266	OZONA	97SA3555	162	34.1
865	70	HASKELL 12KV	97AB5240	643	34.0
866	514	NORDHEIM	94CN3380	171	33.9
867	742	ROMA	94SB3070	1,237	33.8
868	760	ROCKSPRINGS	94LA8040	324	33.7
869	364	CITRUS CITY	94SB9775	1,507	33.7
870	636	SOUTH MISSION	94SB3620	1,951	33.6
871	183	MERKEL	97AB1890	587	33.5
872	141	MUNDAY	97AB3365	391	33.5
873	500	LEARY LANE	94CN1430	1,666	33.4
874	449	NORTH WESLACO	94SB4810	1,459	33.2
875	125	CHILLICOTHE	97AB4525	117	32.9
876	728	AIRLINE	94CS6970	1,370	32.8
877	358	LEARY LANE	94CN6005	1,380	32.4
878	295	MORRIS STREET	94CS7625	562	32.1
879	200	RULE	97AB3378	105	31.8
880	313	HALL ACRES ROAD	94SB4895	870	31.6
881	61	CONTINENTAL	94SB4880	68	31.6
882	277	JOURDANTON	94LA5695	713	31.5
883	683	WASHINGTON STREET	94LA2360	210	31.2
884	315	AFTON	97AB2225	52	31.2
885	608	STADIUM	94LA8540	1,578	31.2
886	397	SAN BENITO	94SB3910	1,780	31.2
887	648	STADIUM	94LA6950	532	31.0
888	279	LEARY LANE	94CN1890	1,627	30.8
889	568	EAST HARRISON	94SB3080	414	30.8
890	376	PORT ARANSAS	94CS3030	709	30.5
891	523	HARLINGEN	94SB370	1,194	30.5
892	462	HALL ACRES ROAD	94SB5585	1,445	30.3
893	194	CISCO	97AB1020	419	30.2
894	91	ROBY	97AB3795	71	30.1
895	398	IRAAN	97SA4305	74	30.1

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
896	51	ALICE	94LA2540	955	30.1
897	108	HAMLIN	97AB3270	882	29.7
898	95	EDNA	94CN5775	505	29.3
899	641	WEST HARLINGEN	94SB3700	1,779	29.2
900	178	CHILDRESS 69	97AB1800	541	29.1
901	332	MARKHAM	94CN6440	470	29.0
902	232	AB OVER STREET 12KV	97AB1635	514	29.0
903	391	HIGHLAND	97SA6375	266	28.6
904	250	BENJAMIN (BEPC)	97AB5680	157	28.1
905	713	ODEM	94CS5575	67	28.0
906	699	SHARYLAND	94SB5105	1,617	27.8
907	44	CHILDRESS 69	97AB4865	773	27.8
908	315	WEST HARLINGEN	94SB3800	1,382	27.8
909	228	CLYDE	97AB1760	437	27.7
910	239	AB COUNTRY CLUB	97AB4735	124	27.6
911	693	PHARR	94SB1640	1,303	27.6
912	631	SOUTH MISSION	94SB3590	561	27.5
913	354	NORTH VICTORIA	94CN6390	1,493	27.5
914	335	AB OVER STREET 12KV	97AB1645	790	27.4
915	577	DEVINE	94LA7090	994	27.4
916	475	RAYMONDVILLE #1	94SB800	722	27.2
917	287	VERNON CITY PLANT	97AB5775	824	27.2
918	388	PAULANN	97SA6285	62	26.9
919	480	PREMONT	94LA2720	763	26.8
920	280	AB OIL MILL	97AB2785	247	26.8
921	56	SANTO NINO	94LA645	1,691	26.6
922	72	COTULLA	94LA460	507	26.4
923	562	NORTH VICTORIA	94CN7860	1,500	26.4
924	230	MINES ROAD	94LA3745	2,013	26.3
925	116	IRAAN	97SA2050	193	26.1
926	709	UNIVERSITY	94LA920	598	26.1
927	530	NORTH MCALLEN	94SB9660	2,009	26.0
928	717	KENEDY S.S.	94CN6750	57	25.9
929	684	KINGSVILLE	94CS1140	1,039	25.9
930	212	AB HARTFORD ST	97AB3815	1,114	25.9
931	200	WESMER	94SB6900	1,635	25.7
932	308	KLEBERG	94CS9395	1,287	25.5
933	517	SOUTHSIDE	94CS5345	403	25.4
934	193	RIO PECOS	97SA513	33	25.3
935	30	GARWOOD CITY	94CN2560	197	24.9
936	260	AB SHELTON ST	97AB3060	1,578	24.6
937	187	KINGSVILLE	94CS1130	2,305	24.4
938	647	GREGORY	94CS420	452	24.0
939	454	EL GATO	94SB890	2,846	24.0
940	54	ROCHESTER	97AB3290	76	23.9
941	660	WESLACO UNIT	94SB8610	1,139	23.6
942	411	SOUTH MISSION	94SB5215	1,246	23.5
943	216	OLMITO	94SB905	1,559	23.4
944	696	NORTH MCALLEN	94SB9640	1,513	23.4
945	455	EL CAMPO	94CN5745	902	23.1

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
946	210	SOUTH EAST EDINBURG	94SB4015	449	23.1
947	438	NORDHEIM	94CN4275	77	22.9
948	310	EAST HARRISON	94SB4620	743	22.8
949	343	HARLINGEN SWITCH	94SB4090	2,289	22.7
950	115	ALPINE 12KV	97SA3160	1,075	22.5
951	349	DEVINE	94LA7100	979	22.3
952	311	WEAVER ROAD	94CN1910	21	22.2
953	529	NORTH VICTORIA	94CN1470	459	22.2
954	156	SA SOUTH	97SA3995	1,373	21.9
955	430	ANNA STREET	94LA900	2,846	21.4
956	199	MUNDAY REA (BKEC)	97AB2015	21	21.2
957	741	PALMHURST	94SB3890	2,605	21.2
958	181	KLEBERG	94CS8140	634	21.0
959	457	HAIN DRIVE	94SB3490	1,136	20.9
960	41	AB ONYX REA	97AB3260	141	20.8
961	439	SAN BENITO	94SB4135	1,263	20.7
962	241	SPUR	97AB5170	371	20.2
963	76	QUANAH	97AB3530	332	20.0
964	108	RODD FIELD	94CS3010	1,962	20.0
965	81	MCCAMEY	97SA2830	460	19.9
966	New	ESCONDIDO	94LA3775	144	19.8
967	110	HEARN ROAD	94CS8980	1,253	19.7
968	229	SA JACKSON ST	97SA4690	1,115	19.6
969	473	DEL MAR	94LA10	1,998	19.4
970	188	SOUTH MCALLEN	94SB5065	127	19.4
971	242	BRONTE	97SA3590	177	19.1
972	624	BAY CITY	94CN7480	2,079	19.1
973	302	SHARYLAND	94SB2020	2,392	19.1
974	75	GONZALES	97SA15390	1,319	19.0
975	245	CEDAR GAP (TEC)	97AB5445	289	18.8
976	583	WEST MCALLEN	94SB4555	1,654	18.6
977	213	YELLOW JACKET	97SA7935	791	18.5
978	109	HOLLY	94CS9675	1,775	18.4
979	375	SANTO NINO	94LA70	1,163	18.3
980	149	BLUFFS	97SA9110	604	18.3
981	215	SOUTH MISSION	94SB3940	843	18.3
982	49	RANKIN	97SA6400	170	18.2
983	177	AB WALNUT ST	97AB3445	70	18.1
984	328	HIGHLAND	97SA6370	508	17.7
985	344	SA AVENUE N	97SA1730	799	17.7
986	322	AB SHELTON ST	97AB3145	1,054	17.7
987	290	AB VOGEL ST	97AB4410	767	17.4
988	162	MILES	97SA4670	525	17.2
989	392	SA SOUTH	97SA4255	866	17.1
990	317	AB OIL MILL	97AB2780	735	17.1
991	686	SOUTH MISSION	94SB4650	1,014	16.9
992	263	HASKELL 12KV	97AB3495	803	16.8
993	451	KARNES CITY	94CN2315	1,052	16.7
994	746	EL CAMPO	94CN7260	531	16.7
995	38	PAISANO	97SAPAISAN	139	16.7

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
996	681	WEST MCALLEN	94SB4815	677	16.0
997	50	GANADO	94CN5815	597	15.8
998	58	SANTO NINO	94LA75	1,518	15.8
999	219	KNOX CITY	97AB3985	20	15.7
1000	319	AB ELM CREEK	97AB4780	485	15.7
1001	56	MUNDAY	97AB2080	473	15.6
1002	256	SA WALNUT ST	97SA4635	1,526	15.6
1003	233	ALPINE 12KV	97SA3155	1,119	15.6
1004	767	LAREDO PLANT	94LA8705	235	15.5
1005	727	EAGLE PASS CITY	94LA7060	853	15.3
1006	268	WYLIE	97AB2665	1,039	15.3
1007	206	AB WALNUT ST	97AB3110	943	15.3
1008	420	EAST HARRISON	94SB3000	524	15.2
1009	355	AB MAPLE ST	97AB4070	15	14.9
1010	413	EDNA	94CN5765	1,123	14.8
1011	273	AB ELM CREEK	97AB1820	91	14.8
1012	723	RIO BRAVO	94LA300	808	14.6
1013	652	ESCONDIDO	94LA1510	726	14.6
1014	694	KLEBERG	94CS6410	273	14.6
1015	759	MILO	94LA3065	209	14.5
1016	New	CARRIZO SPRINGS	94LA750	596	14.5
1017	330	SA WALNUT ST	97SA3925	879	14.4
1018	265	AB CANYON ROCK	97AB5030	865	14.2
1019	390	SA EMERSON ST	97SA4625	410	14.2
1020	218	CROWELL	97AB3980	490	14.1
1021	662	MATHIS	94CS1420	908	13.8
1022	105	SANTO NINO	94LA695	1,610	13.7
1023	345	PAINT ROCK	97SA5235	124	13.6
1024	604	MORRIS STREET	94CS8840	587	13.6
1025	356	MARFA	97SA1900	753	13.6
1026	246	AB OVER STREET 12KV	97AB3140	661	13.5
1027	347	SA SOUTHLAND HILLS	97SA5055	831	13.4
1028	267	SA COKE ST	97SA4910	1,726	12.9
1029	182	SHARYLAND	94SB2150	1,454	12.9
1030	235	AB REBECCA LANE	97AB5550	714	12.8
1031	333	ABILENE PLANT	97AB1575	606	12.7
1032	538	HAIN DRIVE	94SB9240	37	12.6
1033	282	ABILENE PLANT	97AB1915	66	12.6
1034	336	GONZALES	97SA14685	1,076	12.1
1035	110	AB ELM CREEK	97AB4775	876	12.0
1036	89	VERNON	97AB5000	248	11.9
1037	251	MARFA	97SA1905	1,108	11.8
1038	719	WEST MCALLEN	94SB4595	1,187	11.8
1039	522	EAST HARRISON	94SB4310	1,188	11.8
1040	150	CISCO	97AB7400	815	11.8
1041	214	AB ELM CREEK	97AB1810	836	11.6
1042	New	JOSLIN POWER PLANT	94CN8720	17	11.5
1043	65	BAIRD	97AB5120	439	11.4
1044	2	HAROLD	97AB3055	28	11.4
1045	98	ROCHESTER	97AB3295	228	11.0

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
1046	176	AB HARTFORD ST	97AB3685	363	11.0
1047	236	CLYDE	97AB3635	725	10.8
1048	198	SA JACKSON ST	97SA4250	298	10.8
1049	143	SANTO NINO	94LA80	1,888	10.7
1050	69	HAWLEY	97AB4455	592	10.7
1051	308	HIGHLAND	97SA6385	1,307	10.5
1052	352	AB ELM CREEK	97AB4745	959	10.5
1053	163	AB MCMURRY	97AB4360	1,081	10.3
1054	158	EDEN	97SA1780	237	10.3
1055	609	KARNES CITY	94CN2340	809	10.3
1056	675	HARLINGEN SWITCH	94SB5350	893	10.2
1057	204	BALLINGER	97SA4375	1,038	10.2
1058	143	SA AVENUE N	97SA1695	1,439	10.1
1059	618	BROOKHOLLOW	94CN7190	278	10.1
1060	33	WAGGONER	97AB5900	26	10.1
1061	286	AB OVER STREET 12KV	97AB1840	883	10.1
1062	394	SA SOUTHLAND HILLS	97SA5860	1,176	10.1
1063	362	AB HARTFORD ST	97AB3690	170	10.0
1064	95	OZONA	97SA3810	612	9.9
1065	718	AIRLINE	94CS9390	2,801	9.9
1066	291	BALLINGER	97SA4395	526	9.8
1067	384	PAINT ROCK	97SA1110	68	9.6
1068	602	SINTON	94CS1750	505	9.6
1069	671	HEIGHTS	94LA6820	1,859	9.6
1070	489	HALL ACRES ROAD	94SB9595	1,161	9.5
1071	729	SIERRA VISTA	94LA3540	360	9.1
1072	761	MAYBERRY	94SB5340	35	9.1
1073	730	AIRLINE	94CS8370	279	8.9
1074	752	WEST MCALLEN	94SB6385	240	8.6
1075	711	PORTLAND	94CS9270	1,523	8.5
1076	258	AFTON	97AB2310	240	8.5
1077	349	AB HARTFORD ST	97AB3820	918	8.4
1078	313	TWILIGHT TRAIL	97AB3150	718	8.2
1079	364	SA SOUTHLAND HILLS	97SA5455	1,389	8.1
1080	504	SHARYLAND	94SB2035	725	8.1
1081	768	HEIGHTS	94LA9080	690	8.0
1082	255	SA JACKSON ST	97SA4265	796	8.0
1083	210	AB MCMURRY	97AB4350	701	7.9
1084	147	VERNON	97AB1750	251	7.8
1085	208	SOUTH MCALLEN	94SB3935	986	7.6
1086	427	EAST HARRISON	94SB3030	681	7.6
1087	294	MATADOR	97AB3090	316	7.4
1088	649	UNIVERSITY	94LA465	858	7.3
1089	289	AB RAINEY CREEK	97AB4270	1,377	7.2
1090	348	TWILIGHT TRAIL	97AB4285	1,131	7.1
1091	14	PRAIRIE PUMP	94CN1940	77	7.0
1092	187	SA NORTH	97SA3120	1,104	7.0
1093	226	KNOX CITY	97AB3300	471	6.9
1094	37	SWENSON	97AB136	33	6.7
1095	491	NORTH MCALLEN	94SB3830	1,362	6.7

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
1096	120	AILEEN	97AB4605	723	6.6
1097	351	BALLINGER	97SA4370	816	6.5
1098	203	FT DAVIS	97SA3345	436	6.5
1099	296	ABILENE PLANT	97AB1910	258	6.5
1100	737	MINES ROAD	94LA4275	27	6.3
1101	243	SA JACKSON ST	97SA4685	1,416	6.2
1102	318	SHARYLAND	94SB2010	1,146	6.2
1103	776	MAYBERRY	94SB6450	26	6.0
1104	293	ZAPATA	94LA7330	1,350	6.0
1105	311	SA AVENUE N	97SA1655	502	6.0
1106	387	GIRARD	97AB6260	42	5.9
1107	274	AB DYESS 1	97AB1775	688	5.4
1108	112	SANTA ANNA	97SA3415	324	5.3
1109	371	AB REBECCA LANE	97AB2710	263	5.3
1110	281	SA SOUTHLAND HILLS	97SA5050	884	5.0
1111	283	INDIAN MESA	97SA2690	67	4.9
1112	380	EDEN	97SA3195	501	4.9
1113	105	CHILDRESS 69	97AB2800	334	4.8
1114	212	MUSTANG ISLAND	94CS8510	457	4.8
1115	757	AIRLINE	94CS5870	948	4.6
1116	106	ROARING SPRINGS	97AB2065	217	4.4
1117	293	SA SOUTH	97SA3990	737	4.3
1118	735	MORRIS STREET	94CS7465	801	4.2
1119	366	SA WALNUT ST	97SA3915	780	4.0
1120	705	POLK AVENUE	94SB4180	1,291	4.0
1121	381	ABILENE PLANT	97AB3175	112	4.0
1122	195	CHILDRESS 20TH ST	97AB5725	662	4.0
1123	159	SA EMERSON ST	97SA4620	435	4.0
1124	84	FT CHADBOURNE	97SA6515	91	3.9
1125	153	AB ELMDALE	97AB4085	43	3.8
1126	324	SA LAKE DR	97SA6030	665	3.7
1127	383	RUSSEK STREET	97SA12295	312	3.7
1128	340	AB REBECCA LANE	97AB6915	992	3.6
1129	180	CHILDRESS 20TH ST	97AB5720	180	3.4
1130	188	SA AVENUE N	97SA1975	327	3.4
1131	225	AB SHELTON ST	97AB3660	647	3.3
1132	395	SA WALNUT ST	97SA3910	146	3.2
1133	310	MATADOR	97AB3030	214	3.1
1134	739	MILO	94LA3060	136	3.1
1135	295	VERNON	97AB1520	743	3.1
1136	386	SPUR	97AB300	216	3.0
1137	700	EAGLE PASS CITY	94LA2510	588	3.0
1138	151	AB ELM CREEK	97AB1815	370	2.9
1139	221	AB VOGEL ST	97AB4650	810	2.8
1140	344	MILO	94LA6940	422	2.8
1141	710	MAYBERRY	94SB3010	90	2.8
1142	400	SA COKE ST	97SA4915	17	2.6
1143	707	POINT COMFORT	94CN6060	369	2.6
1144	62	SA CONCHO	97SA1705	898	2.6
1145	298	BRONTE	97SA3560	254	2.5

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
1146	27	ROTAN	97AB1865	190	2.4
1147	738	KEPLER	94CS1700	23	2.3
1148	375	COLLEGE HILLS	97SA4840	209	2.3
1149	772	KEPLER	94CS2665	41	2.1
1150	337	SA LAKE DR	97SA5880	774	2.1
1151	327	AB OIL MILL	97AB3895	138	2.0
1152	168	KIRKLAND	97AB3545	29	2.0
1153	252	SHEFFIELD	97SA6430	249	2.0
1154	342	AB EAST 12KV	97AB4820	1,148	1.7
1155	249	GOODWIN	94SB3530	346	1.7
1156	26	HAMLIN	97AB3775	254	1.4
1157	370	BRONTE	97SA4160	209	1.4
1158	275	JAYTON	97AB6125	350	1.3
1159	389	SA JACKSON ST	97SA4695	562	1.3
1160	377	AB COUNTRY CLUB	97AB4725	226	1.2
1161	161	SA CONCHO	97SA1715	287	1.1
1162	111	ROWENA	97SA4480	221	1.1
1163	399	AB CANYON ROCK	97AB5025	51	0.9
1164	223	COLLEGE HILLS	97SA5520	434	0.7
1165	373	AB EAST 12KV	97AB4825	421	0.7
1166	249	SA SOUTH	97SA3500	282	0.6
1167	303	SA EMERSON ST	97SA4860	243	0.6
1168	756	ZACATE CREEK	94LA2675	1,180	0.5
1169	363	AB EAST 12KV	97AB4830	612	0.4
1170	382	COLLEGE HILLS	97SA4845	230	0.2
1171	14	ACME BESTWALL	97AB4150	64	0.2
1172	393	PAULANN	97SA6310	980	0.0
1173	230	SILVER	97SA4295	14	0.0
1174	31	SA CONCHO	97SA3325	49	0.0
1175	172	SA CONCHO	97SA1725	24	0.0
1176	66	FLOMONT	97AB81335	34	0.0
1177	402	ONYX REA	97AB3255	30	0.0
1178	216	TRENT	97AB2850	26	0.0
1179	376	AB ELM CREEK	97AB1825	222	0.0
1180	285	ABILENE PLANT	97AB1740	18	0.0
1181	394	MCCOLL ROAD	94SB4910	339	0.0
1182	#N/A	LA GRULLA	94SB3045	1,116	0.0
1183	New	WASHINGTON STREET	94LANETLAR	163	0.0
1184	774	UNIVERSITY	94LA930	94	0.0
1185	127	KNIPPA	94LA6535	23	0.0
1186	773	MORRIS STREET	94CSNET CC	319	0.0
1187	New	CASA BLANCA	94CS5440	133	0.0
1188	771	VICTORIA POWER PLANT	94CNNETVIC	88	0.0
1189	769	KENEDY S.S.	94CN8320	154	0.0
1190	New	JOSLIN POWER PLANT	94CN7915	10	0.0

Feeders from last year that are not in this year's list

2016 Ranking	Substation Identification	Feeder ID	Reason not in 2017
--------------	---------------------------	-----------	--------------------

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
	441	POINT COMFORT	94CN2460	now <10 customers	
	254	GREENLAKE	94CN2750	now <10 customers	
	78	CORINTH	97AB2590	now <10 customers	
	380	CARRIZO SPRINGS	94LA4405	Retired	
	12	FLOMONT	97AB81330	Retired	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

INTERRUPTION CAUSES

Provide the percentage of interruptions attributable to each cause.

2017 Reporting Year

Causes of Forced Interruptions	Percentage
Weather (Including Lightning)	29.00%
Vegetation	16.23%
Animals and Birds	5.55%
People (Including cars and farm equip)	2.32%
Utility-owned Equipment	43.58%
Other	0.01%
Unknown	3.31%