

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
963	269	BKBNT	1821	1136	86.41
964	1726	RRNES	2403	5015	86.35
965	1123	SALSW	3004	1434	86.33
966	1208	KNEDL	6342	2125	86.33
967	697	WXNTH	2308	965	86.17
968	1327	REYST	4129	531	86.15
969	562	PRCRK	0001	206	86.10
970	770	IRVNR	1552	66	85.95
971	1495	DCDAM	2001	805	85.76
972	1823	TRNTY	7511	1410	85.64
973	2549	CNTRD	0003	1383	85.64
974	2056	CRLTR	2005	675	85.62
975	#N/A	CMINO	1203	1816	85.61
976	2339	PCUST	2010	2258	85.58
977	2358	HHSTH	1504	2510	85.51
978	1535	NLNVL	2002	536	85.42
979	1725	CLBRN	1204	1188	85.41
980	1150	SCYEN	0003	1980	85.37
981	795	ITALY	2101	571	85.35
982	1552	ALPHA	0013	453	85.21
983	2374	RANGR	4311	887	85.19
984	1632	ABRRD	0005	1549	85.19
985	2555	RWALS	1851	1558	85.06
986	2432	BNTDR	0001	1342	85.06
987	418	LNGLK	1602	648	85.01
988	1333	GLNHV	3922	731	84.98
989	1106	RKDLN	1401	937	84.94
990	495	IOWPK	0831	1064	84.84
991	2578	LEMON	0009	2152	84.72
992	297	LAVON	1406	1504	84.62
993	314	BRNAV	0762	2381	84.60
994	2676	FRNKF	0008	1348	84.50
995	2382	GVODS	3072	2302	84.41
996	1004	LIGSW	1602	1114	84.36
997	503	COLNY	2401	741	84.28
998	382	DESPR	1405	936	84.21
999	447	CTYVW	2212	140	84.21
1000	196	CLKVL	1201	427	84.09
1001	2161	TYOMN	1408	1327	84.08
1002	1882	DESPR	1406	957	84.03
1003	2188	KILEN	1203	745	83.97
1004	1142	HLSBR	1202	1230	83.88

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
1005	1927	CRLJL	1507	919	83.81
1006	1031	SHDYG	7811	387	83.77
1007	55	BKWWF	0521	450	83.65
1008	432	RDLML	2581	1223	83.65
1009	573	MCWHT	3511	3195	83.62
1010	453	GRLND	1604	1999	83.59
1011	658	HNRTA	0321	895	83.37
1012	#N/A	WITTS	1707	762	83.28
1013	1602	MKNNY	1205	507	83.28
1014	2421	VLARN	2952	3435	83.25
1015	1517	CNTRY	2851	1508	83.21
1016	840	DENAV	0611	853	83.03
1017	1825	BRLSN	2013	1076	83.00
1018	2381	TAYLR	1201	1793	82.89
1019	1793	PLSTH	1305	500	82.88
1020	2924	MDWCK	0008	896	82.81
1021	268	BRKRG	0242	24	82.75
1022	768	BKBNT	1832	183	82.71
1023	30	MNFLD	2672	2308	82.68
1024	1153	OAKHL	3031	633	82.61
1025	1298	MRSDO	9621	1889	82.60
1026	2649	MKNNY	1204	36	82.60
1027	938	TRNTH	1501	1680	82.55
1028	1055	NMAIN	0231	297	82.34
1029	2276	PSHIL	1604	1156	82.30
1030	1493	DUVAL	0473	1673	82.21
1031	2891	STNVL	1204	820	82.20
1032	1820	ODESA	0272	1332	82.15
1033	1015	HOLDY	0911	1142	82.01
1034	2453	RWDHV	1907	882	81.86
1035	94	CLKVL	1203	605	81.84
1036	1281	TMPLE	1202	1368	81.76
1037	720	MDLNW	1552	691	81.74
1038	713	TYLNW	1912	2091	81.68
1039	688	AYERS	4431	1677	81.56
1040	1488	WNTHW	1120	1032	81.53
1041	1413	IRVNG	1407	1460	81.52
1042	879	BLTON	1806	900	81.45
1043	1023	AMMFG	5631	1464	81.44
1044	709	MEXIA	4011	1027	81.43
1045	2119	THRNE	0003	1242	81.41
1046	1939	WMRLD	0005	1612	81.22

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
1047	2565	STAUG	0005	1223	81.17
1048	278	RCLNS	1406	528	81.11
1049	2252	RNDRK	1503	3917	81.03
1050	216	RYSSW	2804	2297	80.88
1051	2742	SANSM	3921	1479	80.85
1052	870	ALNSW	2652	3624	80.64
1053	1383	CNTRD	0002	1473	80.63
1054	2701	CKRHL	0008	1666	80.29
1055	1622	KNEDL	6311	3046	80.28
1056	1828	SORCY	0001	2569	80.05
1057	1591	WELRD	0007	442	80.01
1058	184	CHRNO	1201	514	79.99
1059	1429	CRNSO	3911	455	79.85
1060	2018	KLNCC	1702	3825	79.85
1061	1716	IRVVV	2804	936	79.80
1062	1721	MDWCK	0001	810	79.80
1063	#N/A	MCTYE	1721	507	79.76
1064	180	AYERS	4421	1475	79.72
1065	1753	PREST	1601	1181	79.53
1066	2619	FRMBR	1807	844	79.51
1067	354	STANT	1311	1518	79.15
1068	136	TXHRV	1611	78	79.15
1069	853	MSLSW	0002	1042	79.01
1070	2396	MSLSW	0006	88	78.97
1071	1718	PPARK	1801	1337	78.88
1072	1284	DAVIS	3711	677	78.87
1073	2303	ENNIS	1905	42	78.85
1074	2994	GLSCN	6221	19	78.78
1075	1094	MSLSW	0005	1012	78.72
1076	1196	MNWLL	1203	851	78.63
1077	628	HRSMD	1957	2457	78.63
1078	807	MCWHT	3522	2974	78.51
1079	1998	MRSES	4006	526	78.49
1080	1858	MESQT	1305	1148	78.43
1081	997	WITTS	1705	1347	78.35
1082	2320	PRSTN	0001	898	78.23
1083	299	LMBLN	0003	179	78.16
1084	191	ROGRS	1301	776	78.15
1085	251	OAKHL	3082	1458	77.93
1086	1352	RENSW	3122	1422	77.90
1087	310	HLSES	0561	1821	77.86
1088	604	PROAD	0007	408	77.82

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
1089	2231	CAMRN	1202	1468	77.59
1090	2326	WGROB	8411	3602	77.55
1091	1500	PAYSW	1203	880	77.46
1092	1391	HLSBR	1203	1646	77.20
1093	1502	TMPTV	2405	500	77.15
1094	1296	RWALS	1853	2401	77.14
1095	2716	TMPNW	1101	2662	77.14
1096	1376	WTHRE	2101	1207	77.12
1097	2636	DAVST	0001	562	77.12
1098	1212	KNEDL	6321	2422	77.07
1099	2125	LUFKN	1205	1335	76.92
1100	589	PKRMX	4703	3075	76.71
1101	1950	IRVHF	2302	1404	76.61
1102	912	MESWE	3621	816	76.60
1103	1474	KIMBL	5021	2378	76.60
1104	825	DNIWS	1603	1367	76.55
1105	1389	RCLNS	1401	104	76.49
1106	823	LUFKN	1201	1341	76.45
1107	818	RCHRD	1208	1037	76.44
1108	283	HURST	1872	2114	76.43
1109	2284	MESFR	2101	2029	76.33
1110	2196	PLSTH	1302	1007	76.27
1111	2704	MLDR2	1603	514	76.22
1112	898	WTAUG	4643	999	76.21
1113	940	TRLWD	7722	4053	76.16
1114	206	WDGWD	1531	1506	76.14
1115	#N/A	WRIDG	3055	1363	76.04
1116	1626	COLNY	2406	818	76.04
1117	2418	BRYAN	0005	3338	75.86
1118	1247	BOWEN	3151	1931	75.83
1119	2146	MCDMT	2554	2270	75.76
1120	1905	NCSTH	1506	92	75.73
1121	2372	MSTLT	1021	986	75.66
1122	217	NCWDN	1111	792	75.58
1123	1657	WTAUG	4652	802	75.54
1124	1420	GPLND	1201	670	75.36
1125	#N/A	HORNE	1914	1021	75.35
1126	1392	NCDSW	3813	402	75.35
1127	1955	PFLGV	2001	4913	75.28
1128	2659	MESTE	1208	994	75.24
1129	2542	BRNWD	1201	1578	75.22
1130	1335	RWDHV	1905	1214	75.19

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
1131	1409	BSPSW	0841	2121	75.02
1132	477	CRNRD	0001	699	74.90
1133	2735	THRNE	0002	1711	74.87
1134	2541	PRKRW	3392	1666	74.82
1135	2129	THRNE	0008	2227	74.63
1136	1177	GLNHV	3963	1596	74.58
1137	527	TYLER	1005	1966	74.42
1138	1781	HMPHL	2743	908	74.37
1139	952	MESQW	1804	1334	74.33
1140	1204	CRLUD	1306	26	74.02
1141	1911	ROANW	9512	1986	74.01
1142	642	VLYRN	2953	2847	73.99
1143	513	WXHCH	1203	1280	73.82
1144	304	REYST	4051	1081	73.81
1145	2546	STNVL	1201	2548	73.77
1146	1621	EULTB	5721	1775	73.69
1147	1359	TATSP	4312	2523	73.68
1148	1518	BLTSW	3201	2578	73.66
1149	212	MNWLL	1207	2098	73.64
1150	1347	SGOVL	1402	968	73.58
1151	2842	MSLSW	0003	191	73.45
1152	932	EDGWD	1102	951	73.26
1153	1058	GRDPR	0811	1226	73.22
1154	1944	PSHIL	1603	1671	73.04
1155	301	ANDNR	2252	247	72.81
1156	2131	MURPH	2755	3281	72.72
1157	844	BOWEN	3171	1713	72.65
1158	207	HMTRD	0003	409	72.63
1159	921	NHNSW	0004	568	72.60
1160	1233	WDCR	0262	225	72.58
1161	338	BNDRA	0009	665	72.48
1162	517	TIODE	9621	315	72.43
1163	1102	WALST	0009	827	72.18
1164	1076	BRNAV	0732	790	72.11
1165	465	RCHRD	1205	1032	72.04
1166	1397	BNTDR	0002	1799	72.02
1167	1656	PRSTN	0008	761	71.96
1168	1396	CPRCV	1407	2211	71.94
1169	2707	NCRST	2203	959	71.91
1170	1510	WDGWD	1522	1442	71.67
1171	2833	KYSTN	1011	83	71.65
1172	2042	GRLWS	1704	179	71.49

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
1173	916	VANAL	2412	3013	71.48
1174	1403	CPRCV	1403	1438	71.44
1175	1744	ALLEN	2406	2629	71.42
1176	1678	SHSTH	1305	487	71.41
1177	740	NHNSW	0002	399	71.23
1178	2182	GRSMN	4028	691	71.22
1179	2268	IRVBL	2505	497	71.21
1180	2465	MDDTN	4311	189	71.16
1181	2108	GRLND	1603	313	70.99
1182	2143	CDCSW	0006	1380	70.94
1183	1112	DNCNV	1901	903	70.74
1184	2053	BRCRK	6543	1665	70.73
1185	1799	CDCRK	1201	1256	70.70
1186	970	AZLES	2122	2281	70.69
1187	1444	LOMAL	0003	1053	70.62
1188	1280	GAVSW	0009	1032	70.44
1189	787	KLBRG	0003	1549	70.35
1190	1009	ELGIN	1002	2673	70.18
1191	1780	TYSTH	1206	1266	70.18
1192	2403	WTAUG	4612	1239	70.13
1193	1782	RWDHV	1901	924	70.11
1194	2560	WSANG	2801	1338	70.11
1195	1692	KFMSO	1301	934	70.08
1196	603	WESTS	1601	1069	69.97
1197	576	LENSW	0321	46	69.93
1198	#N/A	CRISP	1502	664	69.83
1199	2376	LIGSW	1621	50	69.82
1200	1852	KLNPS	1104	1350	69.82
1201	2445	PARIS	1204	1156	69.74
1202	2170	HMPHL	2721	580	69.72
1203	2093	FRMBR	1808	686	69.68
1204	607	RWALE	3321	1532	69.66
1205	804	FRMBG	1707	434	69.58
1206	1022	ALVDO	1902	949	69.51
1207	1148	MESQT	1308	1875	69.47
1208	1328	TATSP	4323	2491	69.43
1209	400	PRSTN	0004	672	69.28
1210	950	HLSBR	1201	1137	69.21
1211	500	BRHLW	7632	1486	69.04
1212	2810	WEAST	0626	291	69.03
1213	544	CPRCV	1406	1656	69.01
1214	927	MURPH	2754	2176	68.94

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
1215	836	CMPST	0002	1103	68.92
1216	346	EZACH	0001	982	68.88
1217	169	PRNTH	1406	1020	68.59
1218	120	CRLCC	2703	635	68.46
1219	677	PWEST	1303	1278	68.44
1220	934	MAREA	1201	152	68.37
1221	2380	CRTLD	4731	2979	68.33
1222	195	OTTOJ	3060	16	68.11
1223	1160	CRSGL	1306	641	68.04
1224	1528	SSPNG	1205	1132	67.98
1225	1795	ARLNG	1213	1325	67.93
1226	1788	MESQT	1304	644	67.91
1227	1865	PRFTW	4211	3663	67.88
1228	1776	WALST	0014	909	67.75
1229	2356	BKWST	0007	1828	67.68
1230	1693	CRNTH	2406	1344	67.34
1231	659	LORAN	9711	379	67.27
1232	2028	LFEST	1901	1500	67.18
1233	1564	BBTWN	1502	1962	67.17
1234	2717	DNINR	1401	84	67.09
1235	264	WMRLD	0006	601	67.08
1236	369	LGVST	8511	757	67.06
1237	1461	LEMON	0006	703	67.06
1238	1498	BDFRD	8811	1683	66.84
1239	445	LKMNT	0004	2172	66.78
1240	2208	RCHHL	0311	983	66.67
1241	1133	CNEXP	0006	1401	66.54
1242	1274	CDCSW	0002	2334	66.41
1243	2499	CRSCN	1201	835	66.31
1244	1605	BRKRG	0232	1722	66.20
1245	2763	WALST	0007	30	66.15
1246	2097	WELRD	0002	743	66.13
1247	1659	TEGMN	3040	784	66.08
1248	1562	KLNPS	1103	2138	66.04
1249	896	CPRCV	1405	1548	65.96
1250	622	LFSTH	1406	2101	65.84
1251	815	BDFRD	8812	769	65.82
1252	200	WLSPT	1001	1973	65.62
1253	1973	MESQW	1807	1493	65.51
1254	1377	DLEON	0111	830	65.49
1255	387	CRKET	1201	323	65.38
1256	2000	ODNTH	2013	1611	65.32

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
1257	2080	LWRDR	0002	989	65.27
1258	2198	TATSP	4313	1612	65.24
1259	501	OVRTN	4037	113	65.12
1260	266	CLCRK	1011	199	65.07
1261	1067	BONHM	1206	2117	65.06
1262	700	GVODS	3041	1494	65.05
1263	2310	TLRWT	2203	811	65.00
1264	1371	BNDRA	0004	722	64.95
1265	1471	WRBND	2311	1409	64.92
1266	2377	WEBBS	8631	3747	64.88
1267	730	PRSTN	0006	757	64.87
1268	1357	JKSNR	4111	444	64.83
1269	61	MDLNE	0161	576	64.59
1270	2272	IRVGS	1906	723	64.49
1271	2787	FRNKF	0001	960	64.35
1272	678	LUFKN	1202	1063	64.26
1273	1681	DALRK	1301	1261	64.21
1274	1246	WND CR	0232	639	64.20
1275	1802	PLSTN	1001	1886	64.00
1276	357	DAVIS	3782	1399	63.98
1277	1450	IRVND	1202	1496	63.96
1278	525	ARMST	0009	1133	63.93
1279	273	MRTNS	1502	511	63.90
1280	1090	BDFRD	8831	877	63.90
1281	762	ENNIS	1906	2076	63.82
1282	221	ATHNS	1201	966	63.75
1283	1451	TATSP	4321	1452	63.73
1284	1553	DAVIS	3721	1321	63.61
1285	1679	MRDCK	0002	1701	63.50
1286	1251	JKSBR	1402	1398	63.41
1287	655	SWTWR	1382	439	63.39
1288	2227	ELGIN	1001	552	63.34
1289	282	GVFTW	1802	920	63.33
1290	2509	DCDAM	2002	934	63.32
1291	1324	KILEN	1205	1344	63.25
1292	443	WMRLD	0004	1581	63.11
1293	1448	TMNTH	1605	1854	63.06
1294	772	ROLTR	2912	3680	62.87
1295	1088	CAMRN	1201	1021	62.78
1296	1786	GRLND	1606	965	62.76
1297	581	RBNSN	2502	1228	62.76
1298	77	BSPRW	2532	1593	62.73

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
1299	1185	ANDNR	2211	1010	62.62
1300	864	WMRLD	0003	490	62.58
1301	571	CRYVE	3021	1282	62.51
1302	2247	RSPVY	1706	1343	62.49
1303	436	IRVND	1204	1343	62.48
1304	175	DNISN	1202	820	62.43
1305	1236	CRLUD	1305	1370	62.42
1306	1034	IRVBL	2504	1590	62.27
1307	1584	DNCNV	1906	413	62.26
1308	1407	CMPWI	0003	653	62.18
1309	567	CLBNR	1407	267	62.13
1310	1053	SSPNE	1402	71	62.02
1311	1188	SANSM	3913	4342	62.00
1312	2472	LNCST	1603	1666	61.95
1313	2600	GNSVN	1401	29	61.78
1314	1933	LNGLK	1604	448	61.73
1315	1415	WTAUG	4613	1907	61.61
1316	672	PALRD	2206	1521	61.53
1317	692	RDLML	2521	1025	61.52
1318	1549	GRHWY	5511	1937	61.39
1319	1035	PRSTN	0003	2958	61.37
1320	784	PTENN	2352	2478	61.35
1321	731	TRNTH	1503	1865	61.24
1322	2228	FHLSW	1372	1315	60.92
1323	1615	MAYFD	5511	4148	60.92
1324	884	EZACH	0007	1583	60.85
1325	2067	IRVVV	2801	2415	60.82
1326	694	HSKAV	0002	1735	60.76
1327	1349	PALMR	2202	1079	60.67
1328	1783	ODESW	5211	1520	60.59
1329	2653	DUBLN	1360	1104	60.57
1330	1294	DESHR	1203	1389	60.47
1331	1369	DALLW	0001	1151	60.41
1332	1355	HLSES	0553	1940	60.30
1333	1596	TYOMN	1405	1659	60.30
1334	1079	IRVNR	1559	2606	60.17
1335	662	NCNTH	1802	1292	60.10
1336	526	WWDWY	2015	1210	60.09
1337	2647	ENSSO	2003	494	60.07
1338	1119	PCOIT	1001	1230	59.98
1339	943	CHICG	1402	484	59.97
1340	2083	HURST	1841	990	59.95

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
1341	88	ALVRD	1501	1175	59.91
1342	2003	CLBRN	1201	1763	59.89
1343	890	SANSM	3912	5182	59.88
1344	2740	CRNRD	0002	368	59.73
1345	321	OAKHL	3052	783	59.73
1346	222	KLRPR	9011	2750	59.65
1347	2853	ADISN	1602	225	59.63
1348	887	ELZCK	4911	29	59.62
1349	1475	RECCR	0006	491	59.59
1350	2429	IRVGS	1908	934	59.54
1351	479	MABNK	2404	2564	59.53
1352	1521	MOSSW	4611	1016	59.47
1353	2745	CMPST	0001	406	59.47
1354	2281	SWTWR	1321	133	59.43
1355	1604	WEAST	0617	1399	59.39
1356	1640	EULES	8731	1424	59.38
1357	1503	BOWEN	3132	1782	59.28
1358	2235	MDLNW	1521	1806	59.26
1359	676	PPARK	1803	1056	59.23
1360	1832	RSPCK	2104	2074	59.12
1361	1829	DUVAL	0452	1424	59.11
1362	888	HRSMD	1905	2803	59.08
1363	2670	RGLRW	0002	213	58.98
1364	1052	FINKS	1803	1366	58.93
1365	1014	ATHNW	1404	1362	58.85
1366	723	KIMBL	5022	902	58.57
1367	309	FORSW	2053	2126	58.53
1368	1968	TAYLR	1204	2019	58.53
1369	1077	RSNHT	1122	2037	58.42
1370	1505	LKMNT	0007	1546	58.34
1371	1398	ADISN	1608	369	58.26
1372	2990	BLMND	3223	446	58.24
1373	1137	WNRTH	1417	1390	58.17
1374	1161	MLKF2	1201	774	58.16
1375	1603	WALST	0005	238	57.91
1376	91	FORSN	5632	239	57.78
1377	1116	DAVST	0005	1845	57.73
1378	1757	TSLVL	4002	2798	57.70
1379	1394	MOSSW	4612	2334	57.65
1380	383	GSTHW	1631	2193	57.61
1381	1218	RSPVY	1704	1403	57.47
1382	2157	LOMAL	0009	1011	57.45

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
1383	976	TRPMN	4023	427	57.39
1384	213	NMAIN	0241	698	57.26
1385	121	SPRTN	1801	1837	57.25
1386	1466	TYEST	1511	869	57.24
1387	2964	RSPCK	2133	1624	57.21
1388	974	SHAMP	0001	1004	57.20
1389	862	DALRK	1307	1196	57.16
1390	1433	MESTE	1206	1284	57.13
1391	918	KNLTR	0004	1052	56.87
1392	929	BDFWD	8921	682	56.76
1393	1297	HURST	1831	1370	56.75
1394	2347	PCUST	2005	1711	56.75
1395	171	MNWLL	1206	1100	56.68
1396	1777	ARLNG	1232	1274	56.65
1397	1532	KLNTF	1805	1340	56.64
1398	467	ALLNC	6422	15	56.57
1399	2350	FRMBG	1701	98	56.55
1400	2077	HOLND	1901	1115	56.49
1401	2747	HKBRY	1103	297	56.41
1402	2753	BNMNW	1102	420	56.26
1403	671	BRNAV	0741	2073	56.24
1404	444	OTTOJ	3059	1096	56.19
1405	561	SALSW	3003	746	56.18
1406	2169	MEXIA	4024	339	56.07
1407	926	IRVGS	1905	765	55.97
1408	2705	LWRDR	0003	1788	55.94
1409	2200	KNLTR	0006	1076	55.91
1410	1885	OKLND	0004	803	55.90
1411	468	WEAST	0629	1757	55.88
1412	635	MEXIA	4007	446	55.85
1413	1538	MYPTX	2401	314	55.84
1414	2902	DNINR	1404	179	55.77
1415	2724	IRVND	1206	109	55.69
1416	226	SBEND	0611	165	55.68
1417	2237	PRKRW	3352	1536	55.63
1418	1038	OVRTN	4015	627	55.60
1419	1557	GRPVN	8223	2079	55.58
1420	846	GRLRD	0002	972	55.57
1421	653	SHDYG	7822	526	55.54
1422	1312	ALLNC	6411	44	55.53
1423	1986	EDGCF	2252	397	55.48
1424	514	AIRPK	8421	1029	55.38

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
1425	2543	EDGCF	2282	1056	55.33
1426	1672	LOMAL	0006	1324	55.30
1427	1511	CMTSW	0973	1607	55.21
1428	1405	MDTHS	1003	1359	55.18
1429	1509	MEXIA	4012	1130	55.10
1430	#N/A	MDESA	4521	997	55.08
1431	753	NCSFA	1704	1398	55.01
1432	939	BLMED	1622	984	54.95
1433	746	REGST	0004	914	54.94
1434	2573	WGROB	8422	2751	54.91
1435	2563	GAVSW	0010	486	54.89
1436	531	RENSW	3121	1936	54.85
1437	1558	KEENE	1503	846	54.82
1438	2393	STNVL	1203	2301	54.73
1439	2084	BRCRK	6514	575	54.70
1440	1434	DAVST	0003	1665	54.68
1441	2923	LWSNR	2212	1410	54.65
1442	433	SCYEN	0004	1247	54.60
1443	2340	WSTHL	3613	3379	54.42
1444	409	MDLNW	1573	1054	54.33
1445	392	FLMSO	3714	1528	54.33
1446	2655	PLKST	0005	1125	54.30
1447	2861	CDCSW	0001	271	54.29
1448	993	CRLJL	1501	1467	54.25
1449	2917	CNEXP	0008	342	54.24
1450	1711	MNSTR	1201	675	54.17
1451	849	EULES	8722	2140	54.13
1452	638	STHRL	0001	597	54.10
1453	873	BNDRA	0002	534	54.08
1454	2099	KFMNW	1202	872	54.05
1455	422	OKLND	0003	1363	53.90
1456	1669	MKNGB	5312	637	53.88
1457	1866	TYEST	1509	372	53.84
1458	644	VGCRK	8041	1043	53.79
1459	1583	PALRD	2204	691	53.65
1460	1478	EZACH	0002	1422	53.57
1461	89	STHRL	0004	1315	53.56
1462	1059	OKLND	0002	1283	53.52
1463	1747	CRLJL	1506	1960	53.45
1464	2846	WALST	0002	32	53.41
1465	534	KRUMS	1202	707	53.35
1466	1308	BLKST	1711	1943	53.31

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
1467	1764	PCUST	2003	1026	53.30
1468	654	IRVNE	1309	1123	53.25
1469	2679	TRLNW	1201	1161	53.24
1470	1507	RCHRD	1204	1140	53.16
1471	1653	MESQW	1801	2110	53.12
1472	1734	CDCSW	0007	1003	52.97
1473	1439	WMMMR	2708	251	52.93
1474	2106	SPRDL	4821	1365	52.92
1475	1412	BLKST	1762	1024	52.78
1476	856	MESQT	1302	662	52.74
1477	2245	JSHUA	1302	1340	52.73
1478	#N/A	GRLTC	3805	943	52.72
1479	1568	BOWEN	3112	895	52.54
1480	482	DESPR	1407	947	52.51
1481	2731	DALWT	2972	239	52.46
1482	2523	WTAUG	4623	732	52.40
1483	1881	IRVND	1203	432	52.36
1484	16	WINKS	0531	43	52.32
1485	1592	PRNTH	1401	1323	52.24
1486	2176	RRNES	2407	3665	52.20
1487	588	OVRTN	4019	665	52.15
1488	1351	RBNSN	2501	1977	52.01
1489	755	TMSTH	1404	1332	52.01
1490	1146	NSTAR	2011	532	51.99
1491	2206	BSPRG	1902	2395	51.93
1492	977	GRAHM	0721	1248	51.91
1493	1981	CDHCR	2053	278	51.91
1494	599	BAKKE	6911	296	51.85
1495	1209	GRNGR	1801	912	51.84
1496	684	HLSES	0522	1744	51.82
1497	2493	DEALY	0004	1184	51.75
1498	1176	JKSNR	4109	637	51.66
1499	2036	IRVBL	2503	1246	51.58
1500	1731	FLINT	3212	3522	51.48
1501	1473	SWDTN	1631	1591	51.47
1502	2260	EULTB	5711	1881	51.46
1503	2266	RSPCK	2142	927	51.30
1504	2241	ITSCA	1701	746	51.18
1505	1810	PWEST	1304	1618	51.06
1506	2590	WSOTH	1018	879	51.05
1507	1164	MDLNW	1541	2297	51.02
1508	1999	CLYVL	9311	2083	50.97

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
1509	186	AMMFG	5621	564	50.97
1510	#N/A	BRNCH	1421	82	50.96
1511	630	WXNTH	2306	2533	50.92
1512	1715	EDGCF	2223	4051	50.76
1513	2033	WSOTH	1017	1721	50.73
1514	2092	ACRLY	1711	172	50.62
1515	947	DCVSO	1104	1352	50.59
1516	1919	HMPHL	2791	27	50.59
1517	2539	TYWST	2013	913	50.53
1518	1884	GPLND	1202	390	50.51
1519	2309	MKNSW	1603	1395	50.49
1520	487	MKNNY	1203	1094	50.49
1521	1440	PWEST	1301	1267	50.47
1522	923	TATSP	4322	2531	50.36
1523	71	GRDNC	1211	42	50.31
1524	2313	IRVNR	1507	1497	50.28
1525	1906	REAST	1506	1203	50.18
1526	1189	ABRRD	0001	1899	50.14
1527	1770	HKHTS	1605	1469	50.00
1528	984	DEALY	0001	1272	49.96
1529	1400	WSTHL	3652	3166	49.89
1530	1080	GRDPR	0871	1566	49.76
1531	2145	SMPST	0006	833	49.72
1532	1578	BDFRD	8842	1335	49.66
1533	157	CGDEL	5411	25	49.64
1534	851	RDRSE	2603	4224	49.61
1535	1547	PRSTN	0002	1337	49.61
1536	954	LAVON	1452	1928	49.55
1537	1216	KRUMS	1204	1415	49.42
1538	1567	HKHTS	1602	1026	49.40
1539	1241	GVFTW	1801	689	49.30
1540	2751	PCOIT	1007	844	49.29
1541	1193	CRLFR	2154	3458	49.23
1542	376	FRSTN	1602	1263	49.23
1543	2123	MCDMT	2552	487	49.22
1544	903	JKSNR	4105	82	49.20
1545	988	ELZCK	4921	1884	49.16
1546	843	NMAIN	0272	400	49.16
1547	1736	STNVL	1205	437	49.10
1548	595	EULSO	9132	2015	49.05
1549	1452	CLYVL	9322	2201	49.03
1550	1257	CNTRY	2813	3070	49.03

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
1551	965	ELMGV	3653	2069	48.97
1552	2971	NPKWY	0007	180	48.96
1553	1923	CDHCR	2050	808	48.88
1554	2229	LOMAL	0013	1069	48.81
1555	2575	DESHR	1202	1571	48.81
1556	1872	IRVNR	1508	2029	48.78
1557	2980	GSTHW	1651	14	48.73
1558	1021	LRENA	2901	997	48.65
1559	471	CRNTH	2401	2541	48.54
1560	722	NHNSW	0007	586	48.53
1561	2017	IRVNG	1401	1599	48.41
1562	2433	DGNST	0004	927	48.36
1563	1570	CRLTR	2053	1726	48.29
1564	1997	WNTHW	1121	747	48.24
1565	2854	COMRC	1201	989	48.21
1566	1924	CMTSW	0977	250	48.19
1567	2304	RCHRD	1203	836	48.18
1568	2918	WEAST	0627	223	48.14
1569	2269	KNLTR	0005	2924	48.12
1570	1965	LKHLD	0007	1223	48.11
1571	505	WSOTH	1020	1131	48.09
1572	568	TRSES	1201	500	48.09
1573	1426	WHITE	3512	1540	47.99
1574	367	GRDPR	0842	1381	47.98
1575	355	WOVER	6122	856	47.96
1576	2074	TRNTY	7551	1591	47.92
1577	2895	NHNSW	0001	468	47.90
1578	1836	HKHTS	1604	889	47.76
1579	2682	WTAUG	4633	1045	47.72
1580	1266	CRLTN	1406	1200	47.71
1581	323	REAST	1502	1315	47.71
1582	2043	RCHHL	0363	576	47.68
1583	311	JKWST	4033	764	47.62
1584	2470	CMTSW	0987	392	47.46
1585	2338	BAKKE	6912	1475	47.44
1586	124	FKLCY	5121	39	47.31
1587	2009	HORNE	1921	1348	47.31
1588	1895	GRDPR	0881	1892	47.24
1589	420	HLSES	0511	1816	47.20
1590	2406	DNISN	1206	926	47.20
1591	1735	EZACH	0003	1289	47.15
1592	1278	EZACH	0004	1170	47.11

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
1593	1860	PKRMX	4701	1742	47.04
1594	1468	DUVAL	0421	1316	46.96
1595	1100	CTYVW	2221	1844	46.93
1596	2209	BSPRG	1904	1663	46.88
1597	1769	HLTOM	2482	1156	46.80
1598	441	JREST	2101	1425	46.77
1599	1427	WESTS	1602	870	46.68
1600	832	GLNHV	3911	1352	46.62
1601	1487	MSHLN	0002	1586	46.61
1602	1914	FROKS	0005	1421	46.56
1603	339	CRLJL	1505	942	46.43
1604	2487	RRSTH	1708	4210	46.35
1605	1629	CLMET	0004	1191	46.31
1606	1103	ARMST	0002	1685	46.29
1607	515	HURST	1861	1851	46.27
1608	225	GRPTT	9911	704	46.26
1609	1287	HKHTS	1603	994	46.21
1610	1636	HUDSN	1601	981	46.08
1611	2517	MESQN	1508	1773	46.04
1612	2104	WMMMR	2707	1548	46.03
1613	1597	LKBLT	2103	1999	45.98
1614	521	HSKAV	0005	1349	45.88
1615	396	PARIS	1203	956	45.85
1616	1728	LWSNR	2231	793	45.82
1617	1163	EDGCF	2213	3170	45.71
1618	2194	ABBOT	1901	113	45.68
1619	1253	DIBOL	1506	599	45.65
1620	1818	TRLNW	1204	578	45.54
1621	1140	BLTLN	0006	923	45.51
1622	617	OAKHL	3021	1998	45.39
1623	1758	MESQT	1303	827	45.39
1624	764	PCUST	2004	1194	45.37
1625	880	DALLW	0006	1960	45.26
1626	2564	GAVSW	0001	2360	45.17
1627	2244	RSNHT	1171	2315	45.10
1628	1689	ABRRD	0004	862	45.08
1629	1958	TYBLR	2801	1236	45.03
1630	2285	ROWLT	1106	1319	45.03
1631	1170	WNDWD	3662	893	44.99
1632	2010	POWEL	2706	243	44.94
1633	2506	RDLML	2512	1223	44.92
1634	1595	DESPR	1402	1307	44.70

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
1635	317	WHITE	3531	1893	44.70
1636	2263	MESTE	1205	1634	44.55
1637	538	WHITE	3541	954	44.50
1638	729	PJPTR	3222	186	44.48
1639	87	WCITY	2402	674	44.44
1640	814	GNSVL	1205	893	44.39
1641	1579	KLNTF	1806	1168	44.37
1642	1254	RWDHV	1906	640	44.29
1643	1171	FSTVW	0002	146	44.27
1644	2288	WMMMR	2705	1245	44.15
1645	1887	PFFRD	3472	1286	44.13
1646	2834	MCGHR	2004	28	44.12
1647	1774	LKHLD	0005	1297	44.08
1648	1671	LNCST	1601	687	44.02
1649	294	LUFKN	1208	1783	44.00
1650	1370	BRYAN	0004	1767	43.96
1651	255	PLKST	0002	833	43.92
1652	1666	NIPAK	1001	132	43.91
1653	1542	CDHIL	1613	2997	43.87
1654	2698	BNDRA	0001	883	43.86
1655	512	FHLSW	1342	2199	43.80
1656	1612	FSHSW	2121	1689	43.74
1657	1194	DESHR	1201	987	43.71
1658	580	MESQW	1802	823	43.70
1659	1588	GODRD	8141	855	43.60
1660	2796	DAVIS	3723	344	43.59
1661	1686	MSLSW	0004	408	43.57
1662	532	RENSW	3124	2180	43.56
1663	2121	GAVSW	0004	832	43.47
1664	469	PRCRK	0003	1874	43.46
1665	1467	DALWT	2962	473	43.46
1666	816	SHRSW	6611	1234	43.46
1667	2451	SMFLD	2311	1465	43.41
1668	956	DUVAL	0414	662	43.27
1669	1941	STAUG	0007	1193	43.22
1670	2308	CRLTR	2052	1564	43.08
1671	#N/A	WRIDG	3054	2212	43.01
1672	904	PRMED	4401	2517	42.95
1673	384	LUFKN	1203	728	42.91
1674	1837	MLFRD	2101	1006	42.90
1675	2027	WNDWD	3621	2195	42.85
1676	2508	BRNWD	1206	1392	42.85

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
1677	1264	IRVNE	1306	1543	42.76
1678	2586	PFFRD	3431	576	42.71
1679	2780	ARLNG	1222	96	42.71
1680	1690	LMESA	2833	22	42.66
1681	1173	HKBRY	1117	140	42.65
1682	667	MCDMT	2532	1977	42.61
1683	2866	FRMBR	1853	61	42.58
1684	1868	DFWNW	2604	11	42.53
1685	359	TYSTH	1203	428	42.46
1686	751	MTLDA	0001	2670	42.46
1687	253	STAUG	0008	2077	42.36
1688	2265	KLNTF	1801	1100	42.35
1689	2090	MDWPK	9231	2423	42.29
1690	2138	RCHRD	1207	1549	42.19
1691	566	ALNSW	2653	3511	42.08
1692	1869	HURST	1882	1900	42.08
1693	1741	RRSTH	1705	1376	42.05
1694	1722	RWALE	3324	1526	42.03
1695	1794	PCUST	2009	2274	41.92
1696	586	CNTRY	2831	1609	41.90
1697	1863	MRTSP	1502	908	41.89
1698	1697	CHNDW	1203	839	41.87
1699	889	BNMAG	1202	407	41.81
1700	2262	BRNWD	1204	1770	41.79
1701	1270	BRLSN	2052	3052	41.78
1702	674	WWDWY	2022	1030	41.78
1703	886	LKWOD	7411	633	41.78
1704	1867	BDFRD	8841	813	41.68
1705	2978	FRMBG	1703	30	41.66
1706	85	MEXIA	4008	689	41.64
1707	1069	MDDTN	4331	1853	41.58
1708	177	PKRVL	1051	4763	41.54
1709	1410	TYLGE	1306	2371	41.52
1710	2032	ECTOR	1201	387	41.50
1711	1072	RWALL	1204	1072	41.42
1712	1665	WTAUG	4631	1143	41.40
1713	1084	WHOUS	4121	1349	41.34
1714	435	FSHSW	2111	312	41.31
1715	933	GNSVN	1403	297	41.30
1716	197	BLVUE	1111	358	41.28
1717	798	RSPCK	2102	1568	41.22
1718	2390	EULSO	9112	733	41.15

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
1719	44	WINKS	0521	40	41.09
1720	257	BRHLW	7612	710	41.06
1721	1720	DALRK	1303	1302	41.03
1722	2678	FRMNT	0008	1057	41.01
1723	1723	PLKST	0004	1303	41.00
1724	1085	MNWLL	1204	287	40.95
1725	859	ROSCO	2911	609	40.94
1726	805	GLNHV	3973	1528	40.93
1727	1673	EGFRD	0001	1826	40.83
1728	428	WATSN	5342	2030	40.81
1729	1252	PLSTH	1301	718	40.67
1730	2857	TYOMN	1402	1622	40.66
1731	2473	SMFLD	2323	617	40.65
1732	2551	BEAST	4088	113	40.64
1733	446	SSPNE	1403	1127	40.63
1734	1289	EUSTC	2402	835	40.61
1735	2249	WALST	0001	633	40.57
1736	995	BLTLN	0002	878	40.56
1737	2957	RNKSW	5413	38	40.54
1738	742	BEAST	4084	873	40.54
1739	461	HKBRY	1107	995	40.53
1740	2071	ARMST	0005	1506	40.52
1741	140	MDLNE	0131	2825	40.48
1742	2050	SHNRW	1609	1791	40.46
1743	1566	TRNTH	1504	826	40.45
1744	#N/A	ALKLK	4221	52	40.44
1745	1969	HUBRD	1401	899	40.43
1746	235	DALWT	2931	1566	40.39
1747	1151	MCGRG	0775	522	40.30
1748	2961	WWEST	1217	102	40.30
1749	42	HOWRD	3921	65	40.25
1750	1168	CRNTH	2405	3973	40.22
1751	41	FRNKS	1201	373	40.18
1752	1273	TYSTH	1201	1141	40.16
1753	2355	WDGWD	1513	864	40.14
1754	1845	BRCRK	6523	874	40.12
1755	#N/A	FRSCW	3701	1362	40.12
1756	944	RDLML	2591	1604	40.11
1757	935	IOWPK	0811	796	40.07
1758	209	COPEL	3055	2163	40.06
1759	2148	OAKHL	3062	2350	40.05
1760	809	PCUST	2006	1612	40.03

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
1761	265	CNEXP	0004	653	40.01
1762	2204	GMINI	5811	3276	39.94
1763	1785	PLANO	1105	57	39.90
1764	2215	SMFLD	2343	719	39.89
1765	2976	COTRD	0001	152	39.87
1766	1121	CNTRY	2823	1894	39.87
1767	1733	NYLDV	1202	145	39.86
1768	350	FSTVW	0003	1924	39.85
1769	1354	WTAUG	4641	578	39.83
1770	1017	PCUST	2012	1812	39.81
1771	2242	DALLW	0007	434	39.79
1772	#N/A	HORNE	1934	1640	39.78
1773	679	DUVAL	0441	1041	39.55
1774	1893	PFFRD	3462	1746	39.50
1775	539	HORNE	1932	1928	39.46
1776	2193	SHNRW	1608	1456	39.44
1777	1961	WNTHW	1118	1523	39.41
1778	1618	MESTE	1207	916	39.35
1779	1118	RECCR	0001	167	39.34
1780	1441	MKNSW	1601	1602	39.31
1781	714	MESFR	2103	368	39.28
1782	592	HUTCH	1503	543	39.27
1783	2166	FHLSW	1361	983	39.26
1784	591	WMRLD	0008	1592	39.25
1785	1814	ENNIS	1903	1386	39.16
1786	2420	VLYRN	2954	2739	38.90
1787	2089	CRLFR	2152	3532	38.89
1788	#N/A	CMINO	1204	558	38.87
1789	2322	ROWLT	1102	995	38.86
1790	2611	IRVNG	1404	1447	38.81
1791	2588	RCHHL	0353	1732	38.78
1792	1027	HMTRD	0001	967	38.77
1793	1909	BRCRK	6511	1295	38.71
1794	2571	RBNSN	2504	1662	38.70
1795	1147	COPEL	3056	2890	38.68
1796	1135	WCOLO	1315	1583	38.68
1797	341	LUFKN	1207	49	38.65
1798	2986	PTENN	2356	14	38.62
1799	1482	CRWLY	7011	2808	38.58
1800	1967	ALVDO	1901	1543	38.51
1801	1428	LFSTH	1404	506	38.47
1802	908	CDHIL	1801	1050	38.46

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
1803	2341	PSHIL	1601	1417	38.44
1804	2992	DFWSE	2713	18	38.30
1805	1660	CLCTY	1031	1220	38.30
1806	97	TYEST	1506	478	38.21
1807	2479	RRSTH	1704	3302	38.16
1808	2843	BRKRG	0213	405	38.11
1809	619	BRNAV	0753	1275	37.96
1810	1904	LFSTH	1402	1173	37.95
1811	1675	WTAUG	4632	1328	37.89
1812	1827	JNKNS	0005	589	37.74
1813	1623	HMPHL	2762	1042	37.74
1814	248	PLSTN	1004	1578	37.69
1815	2423	KLNCC	1701	2326	37.66
1816	1910	ALLEN	2402	3355	37.58
1817	2217	BKWST	0005	918	37.52
1818	2516	LWRDR	0004	813	37.49
1819	129	BRHLW	7622	1120	37.47
1820	578	DNISN	1203	1711	37.46
1821	1423	PSHIL	1602	1084	37.43
1822	2352	BRCRK	6513	1222	37.32
1823	535	TMPTV	2404	1441	37.26
1824	955	SHMNE	1409	893	37.25
1825	1124	KLRPR	9021	2032	37.12
1826	2553	RWDHV	1904	504	36.98
1827	2126	LKHLD	0003	1347	36.93
1828	1220	FROKS	0007	1507	36.93
1829	931	RVRFT	0002	341	36.92
1830	2448	STAUG	0004	2075	36.87
1831	1949	KILEN	1201	1853	36.87
1832	1898	ECTHM	3331	17	36.87
1833	632	TYLGE	1316	2872	36.76
1834	738	CRSCN	1206	1498	36.76
1835	2567	CLBNR	1404	1237	36.72
1836	#N/A	BUFLO	2603	1399	36.72
1837	2387	PRCRK	0004	1481	36.70
1838	833	RANGR	4321	837	36.56
1839	794	PAYSW	1202	1623	36.55
1840	343	MESQN	1505	1435	36.54
1841	2651	WEAST	0615	410	36.54
1842	440	PRKWY	1521	2367	36.50
1843	2832	MESFR	2104	164	36.50
1844	1290	CRTLD	4721	3053	36.50

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
1845	2371	LKBRN	2401	684	36.45
1846	2485	CRSWS	1402	917	36.43
1847	2059	GVODS	3031	1360	36.32
1848	378	TYLER	1004	182	36.16
1849	1849	WSOTH	1021	2134	36.15
1850	2664	WTAUG	4622	1010	36.14
1851	413	ALNTH	2832	1178	36.11
1852	1197	PTENN	2358	1439	36.09
1853	1841	COMSO	1405	741	36.09
1854	2764	BLNKT	0701	285	36.07
1855	190	MNWLE	1702	1289	36.04
1856	2065	WDGWD	1591	1131	36.04
1857	1162	WRBND	2312	1453	36.02
1858	924	AZLES	2111	3059	35.98
1859	2871	PARIS	1205	26	35.92
1860	172	CNI45	1202	823	35.89
1861	404	BLMND	3282	91	35.88
1862	2700	ALPHA	0007	1457	35.84
1863	1945	CRNTH	2403	2842	35.77
1864	2019	LTVSB	5451	1235	35.75
1865	2233	MKNGB	5342	1261	35.75
1866	959	RKDLE	1302	1163	35.68
1867	1586	MNWLW	1403	927	35.62
1868	1600	PCOIT	1005	1100	35.60
1869	1304	PCOIT	1008	1294	35.60
1870	2689	BDFWD	8932	1708	35.52
1871	2656	WDGWD	1561	1499	35.52
1872	111	BRIRV	6922	3419	35.50
1873	2328	PARIS	1202	1253	35.45
1874	1839	LFSTH	1408	2118	35.43
1875	734	RBNSN	2503	986	35.37
1876	2495	MKNGB	5331	1464	35.31
1877	1962	DESHR	1204	1151	35.30
1878	1993	RSNHT	1142	950	35.29
1879	964	DALRK	1354	1723	35.29
1880	717	STAUG	0001	712	35.28
1881	2778	WDGWD	1552	299	35.28
1882	1631	RRSTH	1703	3592	35.27
1883	985	BRTRD	7312	3859	35.26
1884	2016	MESQN	1503	1860	35.18
1885	1231	BRCRK	6521	1430	35.17
1886	#N/A	MDESA	4531	1758	35.13

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
1887	237	HKBRY	1105	176	35.09
1888	2486	WWDWY	2024	1440	35.05
1889	973	CDHCR	2054	1449	35.03
1890	2058	MNWLW	1401	1526	35.01
1891	2869	DESHR	1208	467	34.98
1892	2224	CDHIL	1803	1922	34.96
1893	712	TYLGE	1308	1585	34.93
1894	1122	IRVBL	2501	382	34.92
1895	1366	NCSFA	1706	1177	34.92
1896	690	WFALS	0153	1129	34.89
1897	1081	TYLNW	1910	628	34.85
1898	2023	SHRSW	6612	1936	34.79
1899	1139	NLNVL	2003	724	34.76
1900	819	AIRPK	8432	951	34.71
1901	2248	ODESA	0261	1493	34.67
1902	2020	SUNNY	2301	617	34.65
1903	#N/A	SLTLK	3511	24	34.64
1904	2836	DALWT	2992	332	34.63
1905	610	NCNTH	1808	771	34.61
1906	164	BSPSW	0812	1127	34.56
1907	2632	RDLML	2532	1787	34.55
1908	2935	SCHRD	0004	1924	34.55
1909	1496	BDFWD	8912	1038	34.51
1910	1862	GVODS	3011	2297	34.51
1911	760	MCDMT	2531	2448	34.47
1912	2114	LWSNR	2241	1082	34.46
1913	2319	LKHLD	0002	1529	34.46
1914	2345	OKCLS	0007	635	34.39
1915	90	LAVON	1401	1732	34.37
1916	2001	CNSES	3054	1580	34.33
1917	1830	WALNT	0005	1004	34.32
1918	594	INAIR	1432	3174	34.32
1919	1935	MSLSW	0008	189	34.26
1920	2373	FRMBR	1801	1246	34.18
1921	1048	PCUST	2007	1401	34.12
1922	1214	HHSTH	1501	3474	34.09
1923	1922	TMPTV	2402	3962	33.95
1924	1648	IRVGS	1901	1359	33.88
1925	1345	HRSMD	1907	2873	33.78
1926	#N/A	CRWLY	7021	3537	33.76
1927	2601	VGCRK	8031	1807	33.73
1928	757	IRVBL	2507	891	33.72

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
1929	590	NHNSW	0005	420	33.65
1930	1907	RGLRW	0005	51	33.59
1931	2502	DUVAL	0434	2526	33.55
1932	1739	ABRRD	0003	351	33.54
1933	1875	CLYVL	9321	836	33.53
1934	2673	MAYFD	5531	1183	33.53
1935	2558	CNEXP	0001	263	33.50
1936	486	MESQN	1507	694	33.48
1937	1486	IRVNR	1506	2976	33.39
1938	681	DALLW	0005	124	33.39
1939	1025	DNIWS	1601	910	33.34
1940	2627	EULSO	9121	117	33.34
1941	2115	CDHCR	2055	1326	33.23
1942	1514	MRSES	4012	377	33.21
1943	1108	IRVGS	1902	1500	33.18
1944	425	JREST	2102	1053	33.18
1945	2708	WTHRF	2002	1732	33.14
1946	1740	MDLNW	1564	1275	33.13
1947	953	CRLTR	2001	2497	33.12
1948	70	PRHLL	2402	59	33.10
1949	665	MDWPK	9241	1744	33.00
1950	1039	CRLJL	1503	752	32.99
1951	761	CMTSW	0916	565	32.99
1952	1098	PFFRD	3482	1088	32.94
1953	834	BLKST	1752	1291	32.88
1954	412	BNTDR	0004	1871	32.88
1955	1317	BLTLN	0007	779	32.84
1956	2192	LKWOD	7432	1623	32.83
1957	2637	WSANG	2802	637	32.81
1958	2298	RRSTH	1702	3291	32.77
1959	2212	PKRVL	1054	2626	32.74
1960	1811	BRHLW	7621	2468	32.64
1961	1211	MESFR	2102	679	32.62
1962	1896	HLSES	0542	756	32.49
1963	1261	TATSP	4311	1878	32.44
1964	813	EULES	8711	2051	32.39
1965	2669	FRMBG	1705	275	32.37
1966	941	LAVON	1454	3082	32.29
1967	2694	FRMNT	0012	463	32.28
1968	1712	DNISN	1205	1545	32.17
1969	2186	MSTLT	1084	814	32.13
1970	1078	DEALY	0002	1475	32.12

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
1971	2681	MNWLL	1202	678	32.12
1972	639	CRLUD	1307	289	32.07
1973	2132	RDRSE	2601	1961	32.05
1974	2330	STNVL	1202	75	32.05
1975	1682	MKNSW	2603	1260	32.03
1976	1362	SMFLD	2341	986	31.98
1977	1399	SMPST	0002	1467	31.97
1978	847	OKCLS	0003	1511	31.94
1979	1047	BNBOR	1201	815	31.90
1980	1028	ARTHR	0441	1900	31.85
1981	2419	LVBRD	0005	1377	31.83
1982	600	FERIS	1101	1193	31.80
1983	1833	KLNSO	4501	3458	31.75
1984	2436	RSPCK	2106	347	31.72
1985	1762	CDMIL	1201	596	31.71
1986	1311	RWALE	3326	3222	31.70
1987	1075	HLTOM	2472	1815	31.69
1988	1850	TMSTH	1401	1818	31.66
1989	2238	OKCLS	0005	243	31.66
1990	942	JUDCT	0007	525	31.57
1991	2180	WEBBS	8621	3004	31.56
1992	2026	BONHM	1204	834	31.55
1993	2270	RCHHL	0321	1732	31.54
1994	1529	BBTWN	1501	1980	31.52
1995	2149	KLNSO	4502	3385	31.50
1996	329	ALNSW	2651	2096	31.48
1997	2825	PLGRV	0004	384	31.43
1998	2107	BRCRK	6522	2219	31.42
1999	1007	HSKAV	0003	1423	31.41
2000	1546	EULES	8712	1074	31.41
2001	1915	PLSTN	1002	1216	31.38
2002	1361	RSKMN	3053	502	31.30
2003	401	NAVCO	0001	24	31.30
2004	1190	TMSTH	1408	758	31.29
2005	1470	HKHTS	1607	940	31.22
2006	2005	IRVBL	2502	182	31.17
2007	2082	RCHHL	0384	726	31.13
2008	1105	MESFR	2105	1043	31.09
2009	2336	CRLTR	2007	1445	31.08
2010	2776	MDWPK	9211	1305	31.03
2011	1768	STAUG	0003	2161	31.01
2012	2378	PKRVL	1053	1076	31.01

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
2013	2868	MDLNE	0132	30	30.97
2014	#N/A	MDESA	4511	1448	30.83
2015	612	LKMNT	0003	604	30.80
2016	2408	MDTHS	1002	1382	30.78
2017	2623	LFKHL	2101	168	30.76
2018	335	CRLUD	1303	622	30.76
2019	1159	CRLJL	1502	388	30.72
2020	570	SCYEN	0001	1801	30.71
2021	1559	LOMAL	0008	453	30.70
2022	2213	RDOAK	1303	2515	30.70
2023	2581	SSPNG	1203	1361	30.70
2024	2386	LOMAL	0014	585	30.68
2025	1687	WXNTH	2305	810	30.66
2026	2878	WHTRK	0006	1336	30.61
2027	705	SHNRW	1611	984	30.59
2028	1512	ADMDS	6521	1589	30.53
2029	1608	GRDPR	0852	1446	30.50
2030	792	WEBBS	8614	2509	30.45
2031	408	FHLSW	1332	309	30.43
2032	2105	TRLNW	1202	61	30.33
2033	1232	WELRD	0008	1121	30.33
2034	459	SHMNE	1407	794	30.32
2035	1536	PCOIT	1025	3153	30.31
2036	585	SMFLD	2352	597	30.31
2037	1790	BOWEN	3122	1266	30.21
2038	2079	WRBND	2322	825	30.20
2039	358	PLANO	1104	985	30.16
2040	1888	RDRSE	2604	4025	30.14
2041	2175	SPRDL	4812	1204	30.14
2042	2258	CLYVL	9312	1300	30.11
2043	2049	ESTLD	3611	1532	30.10
2044	#N/A	COYNW	8111	53	30.08
2045	181	PLKST	0007	1780	30.07
2046	2576	WHTRK	0007	1240	30.04
2047	2491	PNTGO	7122	870	29.94
2048	1996	BRCRK	6524	790	29.92
2049	962	WELRD	0006	732	29.91
2050	2122	BRNAV	0784	1894	29.91
2051	2536	PEGAS	2321	136	29.86
2052	2844	DALWT	2941	312	29.83
2053	2311	CRLTN	1405	1242	29.79
2054	139	TIODE	9632	414	29.78

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
2055	1876	HLSBR	1204	550	29.77
2056	1425	MDDTN	4312	1180	29.76
2057	1460	LTFRD	3021	893	29.74
2058	1416	BDFRD	8832	1003	29.71
2059	1259	MRLNS	4003	925	29.69
2060	2906	HMPHL	2733	120	29.69
2061	#N/A	LTMAN	1511	63	29.66
2062	2375	SHMNE	1405	795	29.66
2063	1525	ROWLT	1103	1088	29.64
2064	2527	CNEXP	0007	418	29.64
2065	683	FROKS	0003	644	29.60
2066	51	FSCRK	6732	3684	29.60
2067	1880	FARON	4052	1066	29.59
2068	1977	BRNSO	1801	1618	29.55
2069	2547	WTAUG	4651	561	29.52
2070	327	MKNSW	1602	820	29.51
2071	1315	ARTHR	0452	682	29.38
2072	4	NWARD	3511	63	29.26
2073	701	BRNAV	0723	1351	29.25
2074	1372	WND CR	0211	1183	29.24
2075	1179	RCHHL	0342	1011	29.23
2076	1484	MRTSP	1501	677	29.22
2077	1607	DNIWS	1602	1465	29.21
2078	2086	IRVVV	2853	3478	29.21
2079	1275	PWEST	1302	973	29.17
2080	1380	ROLTR	2922	2690	29.16
2081	2859	PJPTR	3221	47	29.11
2082	1938	DNISN	1201	1483	29.05
2083	1571	IRVVV	2851	2928	29.01
2084	1210	PRKRW	3372	1490	29.01
2085	1543	PLHWY	3703	14	28.91
2086	616	MESQW	1806	1668	28.86
2087	267	LNCST	1602	1895	28.85
2088	2060	PROAD	0005	122	28.82
2089	313	CRLTN	1454	346	28.81
2090	1454	PFFRD	3492	287	28.80
2091	1442	MURPH	2751	2333	28.78
2092	1792	SHMNE	1401	1207	28.76
2093	116	NHNSW	0006	951	28.76
2094	2803	FROKS	0008	1504	28.75
2095	2500	WITTS	1701	1285	28.57
2096	2022	BRLSN	2023	1851	28.57

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
2097	1975	CNTRD	0004	1079	28.55
2098	897	HLTOM	2431	1312	28.47
2099	2755	MDWPK	9221	765	28.46
2100	2518	ARLNG	1292	1557	28.46
2101	1791	BRNWD	1202	433	28.42
2102	1040	SYCRK	4512	4206	28.37
2103	1956	WNDWD	3641	1479	28.32
2104	2437	DUBLN	2214	696	28.23
2105	1856	PNTGO	7112	743	28.20
2106	2081	TMPNW	1105	848	28.07
2107	2806	HKBRY	1104	125	28.07
2108	1192	FSTVW	0006	1233	28.07
2109	1995	WNTHW	1116	679	28.02
2110	597	SPRDL	4841	953	28.01
2111	2282	TYSTH	1208	253	27.96
2112	1127	RECCR	0004	65	27.94
2113	2757	WALNT	0002	1231	27.86
2114	1458	BDFWD	8931	1731	27.83
2115	1342	TERSO	2503	1098	27.80
2116	2599	MCDMT	2551	3855	27.77
2117	2057	IRVNG	1403	521	27.76
2118	2128	RWALL	1201	1314	27.72
2119	1360	MDTHS	1001	1831	27.71
2120	2826	DESPR	1401	1787	27.51
2121	691	CMPWI	0002	1660	27.38
2122	2602	CMTSW	0927	558	27.24
2123	1892	CRTLD	4734	794	27.19
2124	1670	BMTWN	1611	1854	27.17
2125	2801	LOMAL	0012	721	27.16
2126	1628	OAKHL	3041	892	27.15
2127	1616	CRLJL	1508	340	27.14
2128	2462	PCOIT	1002	672	27.13
2129	1323	AYERS	4411	1210	27.05
2130	2538	EULTB	5731	499	27.03
2131	711	DESPR	1403	1800	26.89
2132	811	REYST	4040	560	26.86
2133	2011	WALST	0011	742	26.78
2134	2412	LKBLT	2101	772	26.71
2135	882	HNYGR	2403	601	26.69
2136	835	SMPST	0005	166	26.69
2137	1455	CDHIL	1802	817	26.67
2138	556	NPKWY	0010	3018	26.63

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
2139	1299	RCHRD	1201	1431	26.60
2140	1680	PALRD	2205	326	26.50
2141	2693	IRVRS	4413	1362	26.46
2142	752	SYCRK	4532	4202	26.39
2143	2533	SMFLD	2392	1163	26.35
2144	2438	ARTHR	0422	1051	26.29
2145	1763	TAYLR	1203	1314	26.26
2146	2391	GRPVN	8211	130	26.26
2147	1756	EDGCF	2262	1021	26.24
2148	2995	PAULN	2503	905	26.23
2149	1041	SMFLD	2313	2124	26.20
2150	2671	GRDPR	0891	890	26.18
2151	2788	CRNRD	0005	363	26.13
2152	2736	CNEXP	0003	1415	26.13
2153	554	MSHLN	0001	1043	26.10
2154	2414	GRFRD	1002	395	26.03
2155	1465	PFLGV	2002	2271	26.02
2156	403	CHSPG	2401	3039	25.97
2157	1414	CMPWI	0004	2603	25.95
2158	2580	GODRD	8122	1057	25.88
2159	2476	LKHLD	0008	1461	25.87
2160	1713	BLKST	1732	1230	25.86
2161	2346	PRCTR	1601	204	25.86
2162	2892	TMPNW	1103	719	25.82
2163	1307	MKNSO	3614	2460	25.79
2164	2426	RCLNS	1408	108	25.76
2165	649	BRIRV	6911	3239	25.76
2166	541	NCRST	2204	447	25.73
2167	1601	MKNSO	3613	3316	25.70
2168	2064	PRKWY	1532	2149	25.67
2169	1282	CRNRD	0004	484	25.63
2170	1831	BLTON	1802	1434	25.52
2171	2072	FRMBG	1751	809	25.51
2172	1684	BONHM	1210	1178	25.51
2173	2849	SHDYG	7812	129	25.48
2174	2779	WATSN	5352	1899	25.46
2175	1064	IRVVV	2803	157	25.40
2176	1219	ALLEN	2408	2283	25.30
2177	1668	ENNIS	1901	364	25.25
2178	523	LKWOD	7442	716	25.25
2179	769	BRHLW	7641	43	25.20
2180	574	EDGCF	2272	1086	25.17

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
2181	917	BBTWN	1504	2099	25.17
2182	1641	CDCSW	0008	721	25.13
2183	2884	AMLIA	0006	82	25.04
2184	2692	WRTHM	5012	318	25.02
2185	2428	CKRHL	0003	474	25.01
2186	152	MDLNW	1531	251	25.00
2187	779	SCHRD	0007	1402	24.99
2188	1991	TMSTH	1403	1553	24.95
2189	1982	WNTHW	1119	1321	24.93
2190	1848	ALVRD	1504	162	24.83
2191	2734	BLTLN	0001	680	24.78
2192	727	BRNAV	0711	1630	24.77
2193	429	HURST	1811	1253	24.72
2194	990	BRIRV	6912	819	24.64
2195	2118	GRMES	0511	1179	24.63
2196	2395	LIGSW	1603	2520	24.59
2197	871	RSPVY	1708	985	24.58
2198	2240	ALLEN	2403	1384	24.57
2199	2444	SHAMP	0003	1760	24.53
2200	1824	TRLWD	7721	1613	24.48
2201	2535	AMLIA	0008	103	24.47
2202	2639	BLMGR	1901	266	24.40
2203	2133	CRLTN	1451	485	24.39
2204	2294	ELMGV	3651	2357	24.35
2205	176	WNDCR	0221	572	24.35
2206	1330	RCHRD	1206	688	24.25
2207	2063	TYBLR	2804	2434	24.21
2208	2349	BRYAN	0006	1006	24.19
2209	2367	BLMED	1620	2032	24.17
2210	2076	OKCLS	0004	1506	24.04
2211	288	FLRTN	3721	71	24.01
2212	2830	FRMNT	0005	488	24.01
2213	631	LFEST	1904	1341	23.94
2214	2435	DAVIS	3713	847	23.90
2215	2364	PPARK	1807	1025	23.73
2216	1339	BSPRG	1905	1611	23.69
2217	946	CTYVW	2222	1378	23.67
2218	2305	HUTTO	2711	3812	23.65
2219	2519	GRSMN	4029	962	23.59
2220	258	BLKST	1781	1939	23.56
2221	2300	WHTRK	0002	1432	23.56
2222	2178	EZACH	0006	1100	23.55

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
2223	530	WCITY	2401	925	23.54
2224	2078	WATCO	2605	2699	23.46
2225	1801	ROWLT	1104	1144	23.43
2226	2102	GSTHW	1623	2492	23.41
2227	#N/A	WRIDG	3056	3166	23.40
2228	1633	EULES	8723	5155	23.39
2229	2226	PCUST	2001	574	23.31
2230	911	TMNTH	1602	475	23.19
2231	1619	RRSTH	1706	3688	23.12
2232	2589	FRNKS	1202	92	23.12
2233	858	WFALS	0184	1231	23.05
2234	1522	CRLTR	2054	105	23.04
2235	928	MSHLN	0008	682	23.02
2236	1691	ARLNG	1212	123	23.01
2237	533	SFTLK	4021	38	23.00
2238	291	DEALY	0003	1817	22.97
2239	135	CHICW	1302	204	22.97
2240	2147	CLYVL	9313	1995	22.95
2241	1101	WEBBS	8611	2612	22.95
2242	774	ARLNG	1261	1349	22.94
2243	2271	MRSES	4014	19	22.92
2244	2101	HRSMD	1953	602	22.88
2245	2261	BRNSO	1806	2173	22.85
2246	496	TIODE	9611	368	22.79
2247	2488	MDDTN	4321	917	22.74
2248	675	TYWST	2003	1386	22.66
2249	878	PSHIL	1608	1940	22.59
2250	2743	CLLVL	0001	496	22.54
2251	1408	PRMED	4403	2640	22.51
2252	1091	EULSO	9131	1980	22.50
2253	2592	CHROW	0002	111	22.48
2254	718	LSCOL	2114	152	22.45
2255	1364	BLKST	1742	1728	22.38
2256	522	FINKS	1804	2301	22.38
2257	1978	TMSTH	1407	205	22.37
2258	2031	HORNE	1933	1279	22.36
2259	252	RWDHV	1902	964	22.29
2260	#N/A	SLAKE	8312	2834	22.24
2261	2168	DENAV	0642	879	22.17
2262	2783	HKBRY	1111	28	22.11
2263	394	ALNTH	2853	3022	22.02
2264	726	ATHNS	1202	786	22.01

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
2265	2711	TYOMN	1411	309	22.00
2266	2250	HKBRY	1115	15	21.98
2267	1301	BELLS	1201	581	21.96
2268	368	LGVST	8522	382	21.95
2269	2201	RRNES	2404	4456	21.90
2270	1074	GRHWY	5522	1726	21.84
2271	1942	VENSW	2601	1502	21.82
2272	1344	MCGHR	2003	1304	21.81
2273	2645	RCHHL	0344	1254	21.78
2274	2501	HUTTO	2723	3617	21.78
2275	1120	BLMND	3252	1145	21.67
2276	2521	GSTHW	1611	826	21.67
2277	791	WDGWD	1572	1482	21.65
2278	1843	CMTSW	0957	1186	21.62
2279	2030	PCUST	2002	817	21.62
2280	2216	DALRK	1326	2852	21.61
2281	848	BNDRA	0003	811	21.57
2282	2278	PERIN	1511	656	21.55
2283	2306	LKBLT	2107	1108	21.55
2284	147	BLMND	3241	233	21.46
2285	2202	CHROW	0008	88	21.45
2286	150	MDWCK	0004	1744	21.44
2287	1388	PALRD	2201	799	21.39
2288	1775	CRKET	2401	152	21.39
2289	1131	LMBLN	0004	49	21.36
2290	1931	MESTE	1211	1202	21.34
2291	1172	TMNTH	1607	10	21.31
2292	2628	PLANO	1102	145	21.27
2293	1001	WNDWD	3682	784	21.20
2294	2528	HHSTH	1503	1789	21.15
2295	2583	FROKS	0006	996	21.12
2296	2255	CLMET	0001	1596	21.06
2297	2197	KRGRV	2401	16	21.05
2298	2290	PFLGV	2005	3857	21.05
2299	286	ANDNR	2231	1098	21.03
2300	1479	MESQN	1501	1801	21.03
2301	153	PRKRW	3321	161	20.94
2302	2840	MRSES	3016	43	20.93
2303	1813	PWEST	1312	1846	20.93
2304	2441	CRTLD	4722	4452	20.93
2305	2415	ARMST	0001	277	20.84
2306	1754	WWDWY	2020	1240	20.84

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
2307	2360	MDTHN	1701	1606	20.84
2308	2691	ROANW	9511	1508	20.80
2309	1113	CRTLD	4723	2339	20.80
2310	866	ARLNG	1223	1854	20.73
2311	1406	MKNNY	1254	684	20.69
2312	2163	ODNTH	2073	684	20.66
2313	211	KLNPS	1105	1514	20.63
2314	2402	CRLFR	2155	1329	20.62
2315	1036	WDGWD	1512	829	20.57
2316	781	HSKAV	0007	1881	20.56
2317	930	FORSW	2015	3133	20.51
2318	1585	BRHLW	7611	1620	20.50
2319	2430	CPRCV	1401	1880	20.49
2320	2251	BLTON	1804	478	20.47
2321	2219	KLNTF	1802	826	20.41
2322	1114	PROAD	0004	992	20.34
2323	192	SMFLD	2381	851	20.33
2324	2790	MKNSW	2604	2098	20.31
2325	708	WNDWD	3631	313	20.30
2326	2865	FRNKF	0006	1720	20.25
2327	1263	LIPAN	1303	273	20.24
2328	2489	MTLDA	0006	2300	20.21
2329	1545	HUDSN	1602	1726	20.18
2330	1348	BLTSW	3203	1204	20.16
2331	2195	FSTVW	0005	1771	20.12
2332	2002	WHTRK	0001	2748	20.05
2333	1912	BNBRK	4111	2896	20.01
2334	1789	WATSN	5331	1116	20.00
2335	1846	MESWE	3611	1924	19.97
2336	1291	MDLNW	1513	2468	19.91
2337	1695	FRMNT	0010	2517	19.91
2338	2522	DGNST	0007	530	19.69
2339	1816	HMPHL	2772	303	19.67
2340	2440	MTLDA	0005	1588	19.64
2341	239	KNLTR	0011	1849	19.58
2342	1154	BNDRA	0007	496	19.57
2343	1804	HLTOM	2411	1406	19.56
2344	948	LNCST	1604	642	19.50
2345	2872	TIODE	9622	973	19.46
2346	2362	WXNTH	2302	1592	19.44
2347	1805	SACRC	5521	113	19.44
2348	2503	JKSES	3028	387	19.44

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
2349	426	FARON	4041	1029	19.43
2350	686	BKBNT	1842	562	19.41
2351	2211	LOMAL	0005	400	19.38
2352	1861	WNRTH	1419	304	19.35
2353	201	WBROK	3011	198	19.31
2354	2051	MDLNW	1594	1657	19.20
2355	2464	WMRNR	0002	430	19.17
2356	1550	WRTHM	5004	219	19.16
2357	2274	SHMNE	1403	996	19.15
2358	640	GNSVL	1213	739	19.15
2359	2458	SORCY	0003	849	19.09
2360	837	PRCTR	1602	234	19.05
2361	281	ADISN	1605	1148	19.03
2362	1138	BRGPR	1103	902	19.01
2363	2597	NMAIN	0262	302	18.97
2364	2498	WTAUG	4642	1276	18.97
2365	987	DAVIS	3772	1709	18.91
2366	1610	CNTRY	2814	1103	18.86
2367	1706	DALWT	2911	345	18.78
2368	2127	PPARK	1806	847	18.76
2369	1523	MDLNW	1511	854	18.75
2370	1874	MKNGB	5352	693	18.74
2371	1806	KLNCC	1704	2651	18.71
2372	872	MDWCK	0003	1879	18.68
2373	220	GLNHV	3992	1210	18.68
2374	703	ATHNW	1402	506	18.65
2375	491	CDHCR	2051	2131	18.57
2376	2797	CRLUD	1302	153	18.54
2377	2359	DALWT	2921	283	18.51
2378	830	CKRHL	0002	429	18.51
2379	2793	PSHIL	1605	136	18.48
2380	2650	FRMBR	1806	149	18.46
2381	824	WFALS	0174	1205	18.44
2382	584	FSTVW	0004	2240	18.44
2383	2880	HKBRY	1109	131	18.43
2384	771	GLNHV	3983	1670	18.32
2385	2463	BRKNR	1221	1134	18.25
2386	1702	FRMBG	1750	58	18.25
2387	2069	WCOLO	1318	1661	18.24
2388	1593	MESTE	1209	1446	18.24
2389	2154	DESPR	1408	2008	18.19
2390	1563	CRLTR	2002	1484	18.17

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
2391	249	LTFRD	3011	965	18.17
2392	643	WCOLO	1319	2077	18.15
2393	790	GODRD	8171	835	18.13
2394	1202	CNTRY	2824	3030	18.12
2395	1745	THRNE	0004	815	18.10
2396	620	PRKWY	1552	562	18.03
2397	905	FSCRK	6711	3799	18.01
2398	2295	MEXIA	4040	860	17.99
2399	2183	FRNKF	0002	943	17.98
2400	1516	MESTE	1202	815	17.95
2401	1738	WCOLO	1316	2079	17.95
2402	1953	CRYVE	3011	283	17.94
2403	2766	PSHIL	1607	457	17.92
2404	2449	FRNKF	0003	498	17.91
2405	2648	BLTON	1805	1542	17.91
2406	2886	GAVSW	0008	105	17.90
2407	2174	RNDRK	1505	1326	17.89
2408	1343	KNEDL	6322	3861	17.87
2409	2893	SHDYG	7832	785	17.84
2410	1817	ROWLT	1101	1261	17.78
2411	472	CHROW	0007	81	17.78
2412	2483	WTAUG	4621	440	17.69
2413	2574	WCOLO	1317	1258	17.66
2414	1089	KIMBL	5012	1038	17.62
2415	2039	EGFRD	0004	1869	17.60
2416	1430	BLMND	3221	95	17.57
2417	2029	CRLFR	2157	2425	17.56
2418	476	PLSTN	1005	1907	17.55
2419	1054	BRCRK	6533	1874	17.55
2420	1057	CMPST	0004	1605	17.44
2421	854	WNDWD	3652	1004	17.33
2422	#N/A	CMINO	1201	788	17.32
2423	2112	VGCRK	8011	1652	17.27
2424	151	MSHLN	0007	722	17.23
2425	540	CPLSO	4321	157	17.19
2426	2221	WATSN	5361	2528	17.15
2427	2469	EMPCT	0005	72	17.08
2428	1840	WNRTH	1418	1784	17.06
2429	2275	RGLRW	0003	90	17.05
2430	1056	HRSMD	1951	4413	17.00
2431	2954	COTRD	0003	111	16.98
2432	2130	SHSTH	1301	2239	16.95

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
2433	2921	EULES	8714	817	16.95
2434	2604	ABBOT	1902	119	16.93
2435	234	WBOSE	1102	354	16.90
2436	1683	LOMAL	0010	1560	16.85
2437	1272	SCHRD	0001	1403	16.85
2438	2289	GNSVL	1204	507	16.77
2439	2808	HKHTS	1608	1288	16.76
2440	2882	BAYLC	1201	118	16.75
2441	1494	BANGS	1201	1499	16.75
2442	1238	MSTLT	1054	611	16.72
2443	1222	HLTOM	2442	1099	16.64
2444	1104	COVEE	3403	1377	16.63
2445	423	BSPSW	0822	398	16.60
2446	2035	ROWLT	1105	1072	16.59
2447	986	PARIS	1201	1138	16.58
2448	2515	CRNRD	0007	759	16.56
2449	2525	SHRSW	6631	1297	16.48
2450	2243	TMPLE	1204	1030	16.47
2451	549	IOWPK	0821	747	16.47
2452	2606	WALST	0013	386	16.46
2453	2171	CRLTN	1402	792	16.46
2454	#N/A	DPCRK	1831	1452	16.43
2455	1235	WFALS	0133	1660	16.40
2456	1917	RGLRW	0004	82	16.38
2457	108	FORSN	5611	11	16.33
2458	1221	CMPWI	0001	1928	16.32
2459	1760	WCOLO	1320	1431	16.28
2460	2889	LMBLN	0008	116	16.24
2461	2443	ALPHA	0008	1788	16.21
2462	2410	MTLDA	0004	878	16.21
2463	565	MNFLD	2611	2088	16.20
2464	2199	PRKWY	1561	1758	16.19
2465	1925	RNDRK	1507	895	16.15
2466	2661	VANAL	1201	609	16.13
2467	615	EULES	8724	2407	16.10
2468	647	MESTE	1201	23	16.07
2469	1812	MESTE	1203	172	16.06
2470	2334	CMNCH	1401	1194	16.05
2471	2389	ADMDS	6511	1386	16.05
2472	2816	HORNE	1923	1249	16.05
2473	2850	PRKRW	3331	134	16.00
2474	2629	MSTLT	1073	221	15.99

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
2475	613	STAUG	0002	1418	15.99
2476	2297	WATCO	2603	3175	15.98
2477	2225	MCKMY	0812	133	15.94
2478	2702	KLELM	2202	2544	15.93
2479	2075	HLTOM	2421	1588	15.89
2480	#N/A	DPCRK	1821	1615	15.88
2481	2256	EDGCF	2211	2099	15.85
2482	2572	BKBNT	1811	686	15.82
2483	1974	TMSTH	1406	1151	15.74
2484	891	PJPTR	3211	116	15.71
2485	2610	SCHRD	0006	485	15.69
2486	687	HMPHL	2781	318	15.65
2487	2385	RDRSE	2607	5347	15.63
2488	2947	LUFKN	1204	33	15.60
2489	1145	WNDWD	3611	297	15.51
2490	#N/A	WRIDG	3053	1245	15.51
2491	2425	PALRD	2208	1028	15.45
2492	1908	ROANW	9521	2161	15.44
2493	1365	CRTLD	4742	913	15.38
2494	1651	FLMSO	3712	890	15.36
2495	292	MDLNW	1522	1220	15.35
2496	2254	WHITE	3511	1338	15.27
2497	2837	COMRC	1204	580	15.23
2498	1947	LMESA	1561	1422	15.22
2499	2363	MRTNS	1501	497	15.22
2500	2220	PTENN	2354	542	15.14
2501	2630	CRLTN	1408	127	15.12
2502	1136	CRSCN	1204	645	15.12
2503	2761	IRLBJ	3231	2523	15.09
2504	#N/A	SCYEN	0007	1283	15.08
2505	1940	DENDR	0003	2205	15.07
2506	2715	FARON	4031	1136	15.04
2507	2394	GRPVN	8222	2081	15.01
2508	2594	FRNKF	0004	1606	14.98
2509	2492	PJPTR	3212	29	14.81
2510	1143	BMTWN	1621	1421	14.77
2511	520	CHROW	0003	157	14.76
2512	2301	KNEDL	6332	2386	14.73
2513	1606	GNSVL	1223	1247	14.69
2514	2348	TLRWT	2201	1890	14.66
2515	1889	MESTE	1213	994	14.57
2516	2874	GSTHW	1613	94	14.56

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
2517	232	AIRPK	8411	794	14.56
2518	1240	TYOMN	1410	1537	14.55
2519	2772	CHROW	0005	181	14.53
2520	2968	CURIE	7212	369	14.42
2521	2280	BLKST	1771	1274	14.40
2522	415	TMNTH	1603	135	14.28
2523	1897	PRKRW	3341	553	14.28
2524	1574	ALNTH	2842	2032	14.25
2525	2134	MDLNE	0172	372	14.18
2526	2721	RNDRK	1501	795	14.16
2527	2860	ALPHA	0016	1813	14.09
2528	57	PLKST	0001	786	14.05
2529	1242	MESQW	1808	1339	14.05
2530	2366	RNDRK	1506	1683	14.02
2531	1701	RTHGB	1421	1576	13.90
2532	2137	ATHNW	1405	886	13.87
2533	2634	FRNKF	0005	1085	13.84
2534	894	ARTHR	0481	1248	13.84
2535	2934	ARMST	0003	375	13.83
2536	1491	AMLIA	0003	25	13.81
2537	2786	DESPR	1404	568	13.79
2538	1544	CRTLD	4724	3171	13.77
2539	2746	PFLGV	2007	4322	13.76
2540	238	WNDCR	0241	694	13.71
2541	1617	LVBRD	0008	1764	13.69
2542	881	GSTHW	1692	1235	13.67
2543	598	TMPSE	1503	607	13.64
2544	2646	ENTOH	0007	927	13.64
2545	636	WGROB	8421	3779	13.64
2546	1418	PLGRV	0001	1202	13.56
2547	2117	WEAST	0616	774	13.55
2548	2914	BRYAN	0002	213	13.45
2549	2398	WNRTH	1420	1172	13.41
2550	2291	HURST	1852	1527	13.37
2551	2798	CMTSW	0946	871	13.33
2552	241	KLELM	2201	2440	13.27
2553	204	WXHNW	2901	177	13.27
2554	2785	GODRD	8151	799	13.22
2555	766	GRMES	0521	544	13.22
2556	2004	BLTON	1801	831	13.19
2557	2354	WFALS	0114	417	13.17
2558	2804	PRMED	4404	1158	13.10

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
2559	1767	DAVST	0008	1548	13.01
2560	2368	FHLSW	1311	1536	13.00
2561	786	CURIE	7211	757	12.99
2562	416	ENTOH	0001	890	12.95
2563	2598	COPEL	3054	839	12.93
2564	1483	BNBOR	1202	752	12.91
2565	1877	ANDNR	2242	284	12.88
2566	991	PNTGO	7111	729	12.85
2567	2312	PWEST	1310	691	12.80
2568	2012	FSTVW	0001	806	12.75
2569	2835	JNKNS	0008	408	12.71
2570	2667	HNTNG	1302	42	12.71
2571	2534	LIPAN	1301	515	12.68
2572	2370	LEMON	0001	2143	12.68
2573	2966	MAPLE	0008	214	12.65
2574	163	TYLNE	1624	95	12.60
2575	2139	WATSN	5382	1713	12.54
2576	949	SIKES	2421	2005	12.50
2577	2467	EDGCF	2221	876	12.49
2578	2820	BNMNW	1101	205	12.46
2579	2047	SHRSW	6641	1012	12.44
2580	2091	CDCSW	0003	731	12.43
2581	#N/A	INWRD	0001	206	12.42
2582	546	BOWEN	3161	1542	12.36
2583	2413	LOMAL	0007	150	12.33
2584	117	MCHSN	1201	247	12.31
2585	2098	DAVIS	3731	771	12.30
2586	1030	SWDTN	1611	1495	12.22
2587	547	RWALL	1202	2593	12.16
2588	312	ATNRN	3412	6308	12.13
2589	1771	MTLDA	0007	2151	12.08
2590	2894	WFALS	0143	176	12.05
2591	1419	MTLDA	0003	952	12.02
2592	1117	ABRRD	0002	1375	12.01
2593	2185	STNVL	1207	989	12.00
2594	2172	MDESA	4541	323	11.98
2595	2335	ALNTH	2851	2100	11.96
2596	2674	KLBRG	0001	451	11.89
2597	645	PRCRK	0002	2245	11.85
2598	1742	LAVON	1404	960	11.85
2599	2286	GSTHW	1641	71	11.83
2600	838	SYCRK	4531	1598	11.81

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
2601	992	DAVST	0002	612	11.80
2602	#N/A	FRSCW	3703	1583	11.76
2603	2505	MURPH	2753	1067	11.74
2604	2361	ITSCA	1702	205	11.69
2605	1891	SORCY	0004	601	11.65
2606	1620	TYWST	2001	178	11.64
2607	342	EMPCT	0008	40	11.63
2608	2815	WEBBS	8634	1418	11.58
2609	1749	BRLSN	2062	823	11.55
2610	2688	PFFRD	3411	312	11.50
2611	2156	WHITE	3542	1663	11.45
2612	1661	DAVIS	3762	49	11.44
2613	553	ABRRD	0006	444	11.43
2614	1797	ENTOH	0006	1976	11.42
2615	215	ANDRD	0931	84	11.41
2616	2608	WALNT	0004	1473	11.40
2617	2177	BLMED	1617	317	11.39
2618	1477	FSTVW	0007	1621	11.37
2619	2605	CTYVW	2211	1477	11.35
2620	2867	ALPHA	0015	1233	11.30
2621	2912	JUDCT	0003	1771	11.29
2622	1703	CRNSO	3913	1568	11.27
2623	936	ARTHR	0492	53	11.23
2624	1879	ROWLT	1107	516	11.22
2625	2620	HUTCH	1505	25	11.12
2626	1286	WHITE	3522	1818	11.10
2627	2561	LKBLT	2102	1412	11.07
2628	1577	ARTHR	0472	1292	10.95
2629	2712	KLNTF	1803	1042	10.91
2630	2450	BLMED	1618	35	10.90
2631	1826	MSHLN	0005	500	10.81
2632	2591	RSNHT	1131	2911	10.68
2633	2858	RSKMN	3078	136	10.67
2634	1635	WEBBS	8624	2341	10.62
2635	2643	GAVSW	0002	1117	10.62
2636	2497	NMAIN	0282	1334	10.55
2637	1959	NCSFA	1702	1297	10.54
2638	1061	MNHNS	1921	1881	10.48
2639	1326	WHOUS	4128	363	10.43
2640	1368	REAST	1509	141	10.37
2641	922	JKSNR	4107	326	10.32
2642	2652	DLEON	0131	736	10.26

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
2643	2545	TMPSE	1501	550	10.25
2644	2299	WFALS	0193	2266	10.23
2645	2409	PFLGV	2003	3052	10.22
2646	1857	BRKRG	0221	694	10.22
2647	2988	WMMMR	2704	18	10.13
2648	2520	ROLTR	2911	1817	10.10
2649	2357	RDRSE	2602	3796	10.10
2650	1822	NHNSW	0003	536	10.10
2651	2748	WGROB	8412	4111	10.05
2652	2246	FSCRK	6721	1657	10.01
2653	1800	ARTHR	0411	725	9.90
2654	1501	HNRTA	0311	1061	9.86
2655	1346	GODRD	8131	1537	9.80
2656	2407	SCHRD	0003	360	9.74
2657	2720	KERNS	2402	382	9.73
2658	1710	CGRSW	9811	60	9.67
2659	1976	WNDWD	3672	244	9.67
2660	1302	WELRD	0001	1213	9.66
2661	1555	CLLVL	0003	618	9.66
2662	2713	TMPNW	1106	1031	9.57
2663	2900	COMSO	1403	441	9.55
2664	1664	LIGSW	1604	732	9.53
2665	2920	JUDCT	0004	219	9.42
2666	2494	SFTLK	4011	46	9.41
2667	2812	WALNT	0001	1396	9.33
2668	1092	FSTVW	0008	1770	9.31
2669	2446	KLNCC	1703	4115	9.26
2670	#N/A	CMINO	1207	703	9.24
2671	2876	DGNST	0005	150	9.22
2672	715	TERSO	2501	190	9.15
2673	2672	BRHLW	7631	639	9.13
2674	996	LOMAL	0016	660	9.11
2675	2014	INAIR	1423	231	9.10
2676	2930	CURIE	7222	957	9.02
2677	1050	SMFLD	2391	294	8.92
2678	99	FROKS	0004	117	8.91
2679	1732	WXNTH	2301	1311	8.91
2680	2687	IRLBJ	3212	3458	8.88
2681	1191	PRKWY	1542	513	8.87
2682	1778	CDHIL	1805	620	8.86
2683	2596	SMFLD	2372	626	8.86
2684	2159	LFSTH	1405	216	8.84

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
2685	1609	OKCLS	0008	1554	8.82
2686	134	CNANG	1804	184	8.78
2687	2615	LAVON	1402	154	8.73
2688	1900	NPKWY	0014	6115	8.72
2689	2818	WFALS	0163	354	8.69
2690	2750	STERT	2702	19	8.68
2691	2550	GSTHW	1622	19	8.68
2692	2577	PRNTH	1403	19	8.63
2693	2477	ATNRN	3421	2361	8.63
2694	2625	HMPHL	2792	441	8.61
2695	247	EGFRD	0005	957	8.59
2696	971	PALRD	2203	1102	8.57
2697	2585	WRTHM	5017	154	8.54
2698	2153	JUDCT	0002	1391	8.52
2699	1989	DAVIS	3741	1266	8.50
2700	2703	RRNES	2402	4583	8.47
2701	2116	GRLRD	0001	1786	8.44
2702	1195	RCHHL	0374	541	8.31
2703	1156	MEANS	4411	37	8.29
2704	1187	FSCRK	6712	2634	8.27
2705	1946	FARON	4082	1589	8.19
2706	2353	WMMMR	2702	1556	8.11
2707	1920	MCWHT	3512	2411	7.95
2708	2915	FHLSW	1382	118	7.92
2709	2562	MURPH	2756	3667	7.89
2710	2941	FRMBG	1702	61	7.84
2711	454	CLLVL	0006	1366	7.83
2712	2855	STERT	2701	39	7.81
2713	1928	BOWEN	3181	772	7.77
2714	2903	CNEXP	0002	1103	7.52
2715	861	GRPVN	8213	274	7.49
2716	1293	WELRD	0004	799	7.41
2717	2321	SHDYG	7821	95	7.41
2718	2317	MSTLT	1011	67	7.39
2719	2744	ARLNG	1291	85	7.35
2720	2640	LOMAL	0002	512	7.33
2721	2073	MESQW	1805	83	7.30
2722	2800	BRKRG	0211	317	7.28
2723	2514	PALRD	2207	1131	7.25
2724	352	IRASB	3211	277	7.24
2725	2609	CRLFR	2159	1509	7.21
2726	2007	CHROW	0001	137	7.18

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
2727	262	SUNNY	2303	654	7.18
2728	1819	SHNRW	1612	843	7.15
2729	1316	PROAD	0003	1131	7.14
2730	2936	WEBBS	8613	716	7.09
2731	#N/A	ODESA	0252	650	7.06
2732	#N/A	HORNE	1922	1466	6.89
2733	1318	MLKF2	1202	472	6.85
2734	#N/A	BAKKE	6921	2175	6.84
2735	1750	RCLNS	1404	714	6.83
2736	481	IRVNE	1302	1411	6.82
2737	2264	BRTRD	7311	1200	6.78
2738	398	FARON	4062	1151	6.72
2739	2447	HUDSN	1605	148	6.67
2740	744	TYLER	1001	153	6.66
2741	2203	MAPLE	0001	1063	6.58
2742	1541	WALST	0003	127	6.56
2743	2730	REGST	0003	988	6.55
2744	1309	WSOTH	1019	827	6.54
2745	767	DGNST	0006	1158	6.53
2746	2775	BRNSO	1808	725	6.48
2747	2140	BLKST	1721	1030	6.48
2748	914	HORNE	1911	1509	6.47
2749	2952	RRWES	1603	11	6.39
2750	464	WBOSE	1103	926	6.39
2751	945	GRLWS	1706	279	6.25
2752	2922	RGFTW	6822	23	6.24
2753	1181	RRSTH	1707	612	6.22
2754	629	PTENN	2355	180	6.16
2755	2152	PFFRD	3452	856	6.12
2756	1288	RGLRW	0008	38	6.07
2757	2718	KLELM	2204	3058	6.05
2758	1457	BLMND	3262	119	6.03
2759	1464	BRNSO	1805	790	6.00
2760	2593	DCATR	1204	656	5.99
2761	285	BNDRA	0013	152	5.97
2762	1459	MSHLN	0004	1304	5.86
2763	399	PRFTW	4222	3327	5.80
2764	2388	IRVNR	1510	492	5.75
2765	1485	FARON	4072	1545	5.74
2766	#N/A	HORNE	1912	1845	5.66
2767	385	MDAIR	2911	422	5.63
2768	2327	RSPCK	2141	19	5.63

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
2769	1972	FRMBG	1753	727	5.61
2770	272	BRGPR	1101	623	5.59
2771	1700	BLMND	3211	13	5.59
2772	96	CHICC	1701	55	5.58
2773	2461	WMRLD	0009	31	5.51
2774	695	PAYSW	1213	1449	5.40
2775	2379	CRLTN	1404	101	5.39
2776	2584	GRHWY	5521	1583	5.38
2777	2686	CNTRD	0001	2052	5.35
2778	2603	CRLFR	2153	249	5.14
2779	2337	EDGCF	2231	868	5.06
2780	2897	ROBNW	1501	843	5.01
2781	2695	CMTSW	0983	1169	4.97
2782	2613	NPKWY	0011	4142	4.95
2783	2910	ENTOH	0004	1996	4.92
2784	2526	RNDRK	1504	975	4.92
2785	1587	LSCOL	2138	1471	4.91
2786	1445	KRUMS	1201	499	4.88
2787	2738	DGNST	0008	120	4.88
2788	2088	PPARK	1802	600	4.72
2789	2654	RWDHV	1908	2339	4.71
2790	1599	BRTL	1402	117	4.70
2791	627	MDAIR	2921	73	4.65
2792	2946	SCHRD	0008	75	4.65
2793	1379	BNDRA	0011	391	4.57
2794	#N/A	LKBLT	2104	909	4.55
2795	260	WALST	0008	19	4.52
2796	1983	RRNES	2405	2932	4.50
2797	2552	EMPCT	0002	101	4.50
2798	2641	GRAHM	0713	392	4.43
2799	#N/A	DPCRK	1822	1314	4.36
2800	280	BSPSW	0832	401	4.29
2801	1759	BRNSO	1807	237	4.29
2802	480	MNFLD	2621	2311	4.28
2803	2767	HMPHL	2752	282	4.17
2804	1000	EMPCT	0001	33	4.15
2805	1916	JUDCT	0006	1208	4.10
2806	#N/A	DPCRK	1842	1421	4.09
2807	1994	HUTTO	2721	2955	3.92
2808	2916	COTRD	0008	1355	3.91
2809	2642	BLMGR	1902	188	3.91
2810	2749	MNSTR	1202	274	3.87

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
2811	320	VALVW	1802	440	3.77
2812	685	LVBRD	0004	1065	3.76
2813	2933	FRMNT	0007	809	3.71
2814	456	DENDR	0009	65	3.68
2815	1918	GMINI	5821	1439	3.66
2816	1506	BNDRA	0005	1204	3.64
2817	2802	TMNTH	1604	56	3.61
2818	660	GODRD	8161	2224	3.61
2819	909	MKNGB	5322	1046	3.59
2820	698	BRYAN	0001	14	3.55
2821	2422	RCLNS	1402	915	3.54
2822	2513	SWDTN	1621	712	3.53
2823	2847	CKRHL	0007	72	3.49
2824	1322	CRSGL	1301	147	3.45
2825	2187	WSOTH	1022	2213	3.43
2826	605	RGFTW	6841	20	3.41
2827	2911	WMRNR	0003	800	3.31
2828	407	FRMNT	0004	2378	3.30
2829	1644	DAVIS	3752	504	3.29
2830	1853	BNDRA	0006	673	3.28
2831	2777	HKBRY	1102	1709	3.25
2832	2805	SHNRW	1610	438	3.24
2833	831	ALPHA	0009	65	3.23
2834	473	JKREA	1201	29	3.20
2835	2530	GRPTT	9921	573	3.19
2836	202	TRLNW	2401	22	3.19
2837	865	FSCRK	6713	3159	3.14
2838	2824	ARMST	0011	889	3.11
2839	168	WATSN	5372	1335	3.07
2840	2873	HMPHL	2742	488	2.98
2841	2831	RSNHT	1152	1221	2.92
2842	2752	ALPHA	0006	295	2.84
2843	2474	CMPST	0003	208	2.81
2844	650	CNTRY	2862	717	2.80
2845	2109	WMMMR	2706	20	2.78
2846	2877	SMFLD	2362	64	2.70
2847	270	ARMST	0006	823	2.67
2848	457	PCOMM	3313	472	2.56
2849	1899	RSNHT	1111	349	2.50
2850	1230	ZEPHR	2404	184	2.35
2851	#N/A	DPCRK	1832	327	2.30
2852	2841	TMSTH	1405	520	2.24

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
2853	#N/A	MOSSW	4632	985	2.20
2854	1737	GRLRD	0003	654	2.19
2855	2008	DGNST	0002	480	2.17
2856	132	MKNGB	5311	457	2.16
2857	#N/A	BUFLO	2601	1092	2.16
2858	2021	SHAMP	0005	1725	2.15
2859	2054	RGFTW	6813	22	2.13
2860	2973	ARMST	0008	246	2.12
2861	1847	RGLRW	0006	31	2.10
2862	2587	IRVHF	2303	87	2.05
2863	2496	SHNRW	1601	260	2.02
2864	1226	CMTSW	0966	126	2.01
2865	2864	PROAD	0008	1219	2.00
2866	2908	WALNT	0008	875	1.96
2867	#N/A	MLKF2	1203	1416	1.92
2868	2638	CRSCN	1202	630	1.89
2869	1913	DFWNW	2602	27	1.88
2870	2773	FRMBR	1802	1128	1.87
2871	#N/A	BRNSO	1803	10	1.83
2872	773	WWEST	1222	185	1.82
2873	73	OKCLS	0006	1675	1.78
2874	2460	JNKNS	0006	673	1.75
2875	2554	IRLBJ	3221	854	1.63
2876	1310	RECCR	0002	95	1.63
2877	1838	LEMON	0008	985	1.60
2878	2633	HLTOM	2461	848	1.59
2879	2814	WWEST	1218	1011	1.56
2880	863	ALLEN	2401	2252	1.55
2881	2807	MSTLT	1032	27	1.54
2882	#N/A	INWRD	0002	553	1.45
2883	2819	WWEST	1221	49	1.43
2884	2972	ALLEN	2405	27	1.41
2885	2756	CLBNR	1401	22	1.40
2886	2975	COMRC	1202	48	1.40
2887	#N/A	MKNSO	3612	1949	1.40
2888	2888	BRYAN	0007	242	1.38
2889	963	ARMST	0010	878	1.35
2890	1431	WHITE	3532	1350	1.33
2891	363	INAIR	1413	2747	1.32
2892	1268	MCDMT	2553	595	1.29
2893	123	FRNKF	0007	1110	1.29
2894	2887	DGNST	0001	309	1.27

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
2895	2660	EMPCT	0004	327	1.25
2896	618	RSPCK	2132	70	1.23
2897	2822	PROAD	0001	126	1.23
2898	2863	SHAMP	0002	1745	1.22
2899	2684	NCRST	2202	32	1.22
2900	2953	CHROW	0006	88	1.15
2901	1303	ALPHA	0002	1261	1.14
2902	1367	ABRRD	0008	1439	1.09
2903	2870	JNKNS	0002	199	1.07
2904	550	ARTHR	0462	205	1.05
2905	1685	WALST	0010	1123	1.04
2906	2728	TYLER	1010	69	1.02
2907	2932	CKRHL	0004	423	1.00
2908	2919	CURIE	7241	720	0.97
2909	2813	LSCOL	2135	616	0.93
2910	1255	GAVSW	0012	806	0.93
2911	#N/A	RYSSW	2801	1275	0.91
2912	2624	LKHLD	0006	745	0.89
2913	2967	INAIR	1442	111	0.86
2914	1531	FSCRK	6724	1399	0.81
2915	#N/A	DFWSW	2322	55	0.81
2916	2795	EULSO	9141	67	0.80
2917	2817	PSHIL	1606	1549	0.74
2918	2901	MSTLT	1042	498	0.74
2919	1990	LTVSB	5461	800	0.74
2920	968	KIMBL	5011	160	0.73
2921	2719	NPKWY	0009	1295	0.72
2922	2925	TYLGE	1314	968	0.71
2923	2913	TYBLR	2806	208	0.70
2924	2938	RECCR	0005	158	0.68
2925	2239	FARON	4021	284	0.65
2926	1730	HORNE	1913	1585	0.64
2927	2939	BKWST	0004	1072	0.63
2928	1808	LOMAL	0015	172	0.62
2929	2070	MDLNE	0121	230	0.62
2930	2732	ALPHA	0001	573	0.57
2931	2401	HMPHL	2711	643	0.51
2932	1169	MAPLE	0004	478	0.49
2933	2926	KNLTR	0009	864	0.47
2934	2970	BRNAV	0774	203	0.46
2935	543	FRMNT	0011	1307	0.44
2936	1894	FRMNT	0001	896	0.44

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
2937	1902	LSCOL	2137	784	0.42
2938	980	PLANO	1101	414	0.41
2939	2293	RRNES	2401	2635	0.38
2940	1625	FRMNT	0014	481	0.36
2941	2899	RSPCK	2105	659	0.33
2942	2862	ELKTN	2503	847	0.29
2943	2680	LEMON	0002	977	0.29
2944	2416	WWEST	1216	247	0.21
2945	2927	INAIR	1414	765	0.18
2946	2848	CNEXP	0005	460	0.16
2947	2481	WEAST	0620	1931	0.16
2948	2811	BRTRD	7322	642	0.12
2949	1043	JREST	2103	458	0.12
2950	2618	PLHWY	3701	496	0.11
2951	2727	BKWST	0006	802	0.10
2952	2165	DNINR	1402	391	0.10
2953	2928	BDFWD	8911	934	0.09
2954	2626	DALWT	2952	656	0.08
2955	2482	NPKWY	0008	858	0.07
2956	2851	DGNST	0003	1166	0.05
2957	1183	ARMST	0004	1253	0.04
2958	#N/A	DELTA	1701	1254	0.02
2959	#N/A	ALKLK	4211	48	0.00
2960	#N/A	ALPHA	0004	21	0.00
2961	#N/A	ALPHA	0005	137	0.00
2962	#N/A	ARPCM	4169	10	0.00
2963	#N/A	BKWST	0001	384	0.00
2964	#N/A	BRNSO	1804	10	0.00
2965	#N/A	CLBSN	8821	10	0.00
2966	#N/A	COTRD	0004	105	0.00
2967	#N/A	COTRD	0006	278	0.00
2968	#N/A	CRLTR	2004	236	0.00
2969	#N/A	CRLTR	2006	54	0.00
2970	#N/A	CRLUD	1301	26	0.00
2971	#N/A	DCATR	1205	119	0.00
2972	#N/A	DELTA	1702	322	0.00
2973	#N/A	DENAV	0631	1714	0.00
2974	#N/A	DENAV	0641	22	0.00
2975	#N/A	DENDR	0008	81	0.00
2976	#N/A	DFWNW	2603	11	0.00
2977	#N/A	DFWNW	2606	20	0.00
2978	#N/A	DFWSE	2710	73	0.00

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
2979	#N/A	DFWSE	2712	25	0.00
2980	#N/A	DFWSE	2715	10	0.00
2981	#N/A	DFWSW	2323	42	0.00
2982	#N/A	DFWSW	2325	15	0.00
2983	#N/A	DFWSW	2326	36	0.00
2984	#N/A	ELZCK	4922	20	0.00
2985	#N/A	ENTOH	0003	13	0.00
2986	#N/A	ENTOH	0008	123	0.00
2987	2941	EXPKY	8112	14	0.00
2988	#N/A	EXPKY	8141	24	0.00
2989	#N/A	FRMBG	1704	36	0.00
2990	#N/A	FRMBG	1708	45	0.00
2991	2943	FRMNT	0006	11	0.00
2992	#N/A	GAVSW	0011	113	0.00
2993	#N/A	GRLTC	3803	12	0.00
2994	2950	GSTHW	1662	13	0.00
2995	#N/A	GSTHW	1672	41	0.00
2996	#N/A	HMPHL	2723	50	0.00
2997	2952	INAIR	1421	19	0.00
2998	#N/A	IRLBJ	3222	1035	0.00
2999	#N/A	JNKNS	0001	249.00	0.00
3000	2956	KNLTR	0007	12.00	0.00
3001	#N/A	LEMON	0004	580.00	0.00
3002	2596	LKWOD	7421	42.00	0.00
3003	#N/A	LOMAL	0004	147.00	0.00
3004	#N/A	LSCOL	2140	1077.00	0.00
3005	#N/A	LSCOL	2142	15.00	0.00
3006	#N/A	LVBRD	0001	40.00	0.00
3007	#N/A	NNTWK	TWK4	586.00	0.00
3008	#N/A	PCOMM	3311	30.00	0.00
3009	2968	PJPTR	3231	26.00	0.00
3010	2970	PJPTR	3242	76.00	0.00
3011	#N/A	PLANO	1108	482.00	0.00
3012	#N/A	RCHHL	0394	235.00	0.00
3013	#N/A	RNGMG	8421	10.00	0.00
3014	#N/A	RNKSW	5412	23.00	0.00
3015	2638	RVRFT	0001	24.00	0.00
3016	#N/A	SHSTH	1302	20.00	0.00
3017	#N/A	SMFLD	2322	41.00	0.00
3018	#N/A	SORCY	0002	66.00	0.00
3019	#N/A	STERT	2704	10.00	0.00
3020	#N/A	WEAST	0621	14.00	0.00

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2017 SAIDI Ranking	2016 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2017 SAIDI Value
3021	#N/A	WEAST	0628	241.00	0.00
3022	#N/A	WFALS	0124	131.00	0.00
3023	#N/A	WNTWK	K601	78.00	0.00
3024	#N/A	WNTWK	K652	11.00	0.00
3025	#N/A	WNTWK	K656	48.00	0.00
3026	#N/A	WOVER	6131	2367.00	0.00
3027	#N/A	WXOCF	1402	13.00	0.00

NOTES

Feeders listed below underwent significant reconfigurations during 2017. Customer Count from 2016 SQR was used for calculations.

DENAV0621
CMPWI0002
IRVNE1310
WEAST0619
SSPNG1201
HKBRY1113
COLNY2405
THSES2402
CNSES3054
RKCRK6112
CNTRY2833
LKMNT0008
HORNE1921
BRLSN2041
RYSSW2802

Oncor Electric Delivery

INTERRUPTION CAUSES

Provide the percentage of interruptions attributable to each cause.

2016 Reporting Year

Causes of Forced Interruptions	Percentage
Weather (Including Lightning)	13%
Vegetation	13%
Animals and Birds	18%
People (Including cars and farm equip	7%
Utility-owned Equipment	43%
Unknown	6%