



Control Number: 48005



Item Number: 21

Addendum StartPage: 0

DOCKET NO. 48005

RECEIVED

APPLICATION OF NORTHSIDE  
WATER SUPPLY CORPORATION  
AND RED RIVER AUTHORITY OF  
TEXAS FOR SALE, TRANSFER, OR  
MERGER OF FACILITIES AND  
CERTIFICATE RIGHTS IN  
WILBARGER COUNTY

§  
§  
§  
§  
§  
§  
§

PUBLIC UTILITY COMMISSION

2018 JUL 19 AM 10:07  
PUBLIC UTILITY COMMISSION  
OF TEXAS FILING CLERK

**RED RIVER AUTHORITY'S SECOND SUPPLEMENTAL RESPONSE TO  
COMMISSION STAFF'S SECOND REQUEST FOR INFORMATION**

**QUESTION NUMBER STAFF 2-1**

Red River Authority of Texas, provides the following Supplemental Response to Question Staff 2-1. This Supplemental Response is a supplement to the response Question Staff 2-1 filed on May 14, 2018, as supplemented by First Supplemental Response filed on May 24, 2018. This response was prepared under the direct supervision of **Randy Whiteman**, General Manager of Red River Authority, who is the sponsoring witness for the responses.

**RESPONSE**

**Staff 2-1** Reference Red River Authority's Response to Commission Staff's First Request for Information (RFI), filed on March 26, 2018. Provide plan approvals from the Texas Commission on Environmental Quality for the ongoing improvements at Red River's water treatment plants as identified in the response to Staff RFI 1-1.

**Response:** Attached is a letter dated July 3, 2018, from the TCEQ providing conditional approval for the project.



Respectfully submitted,

**SHERRILL & GIBSON, PLLC**



D. Todd Davenport  
State Bar No. 24031988  
3711 Maplewood Ave., Suite 200  
Wichita Falls, Texas 76308  
(940) 264-4400  
(940) 264-4401  
tdavenport@sgpllc.law

**CERTIFICATE OF SERVICE**

I certify that a copy of this document will be served on all parties of record on July 9, 2018, in accordance with 16 TAC §22.74.




D. Todd Davenport

# VERIFICATION


STATE OF TEXAS       §  
                                  §  
COUNTY OF WICHITA   §


BEFORE ME, the undersigned authority, on this date personally appeared Randy Whiteman, General Manager of Red River Authority of Texas, who after being by me duly sworn, states on his oath, deposed and stated that he is duly competent and qualified to make this Verification from his own personal knowledge, information, and belief, and that he has read the foregoing answers and the averments thereof are true and correct and within his personal knowledge, information, and belief.

FURTHER AFFIANT SAYETH NAUGHT.

  
\_\_\_\_\_  
Randy Whiteman

Sworn to and subscribed before me this 9<sup>th</sup> day of July, 2018, by Randy Whiteman.



  
\_\_\_\_\_  
Notary Public in and for the State of Texas

My commission expires: 08/29/2019

Bryan W. Shaw, Ph.D., P.E., *Chairman*  
Toby Baker, *Commissioner*  
Jon Niermann, *Commissioner*  
Stephanie Bergeron Perdue, *Interim Executive Director*



PWS\_2440005\_CO\_20180703\_Plan Ltr

## TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

*Protecting Texas by Reducing and Preventing Pollution*

July 3, 2018

Mr. Kerry Maroney, Jr., P.E.  
Biggs & Mathews, Inc.  
2500 Brook Ave.  
Wichita Falls, TX 76301

Re: RRA Hinds Wildcat Water System - Public Water System ID No. 2440005  
Hines-Wildcat & Northside WSC Treated Water Improvements - Phase I  
Engineer Contact Telephone: (940) 766-0156  
Plan Review Log No. P-05042018-019  
Wilbarger County, Texas

CN: 600630479; RN: 101244374

Dear Mr. Maroney:

On May 4, 2018, the Texas Commission on Environmental Quality (TCEQ) received planning material for the proposed water system improvements. Based on our review, the project generally meets the minimum requirements of Title 30 Texas Administrative Code (TAC) Chapter 290 - Rules and Regulations for Public Water Systems and is conditionally approved for construction if the project meets the following requirement(s):

- Executed contract between the Red River Authority and the City of Vernon to deliver treated water at a rate of 0.6 gallons per minute (gpm) per active connection.
- Approval of the certificate of convenience and necessity (CCN) sale, transfer, merger (STM) application from the Public Utility Commission.
- Ground storage tanks shall be air-gapped in accordance with Chapter 290.38(1).
- Waterline locations shall comply with Chapter 290.44(e) with regard to separation distances from sources of potential contamination.
- Stream crossings shall comply with Chapter 290.44(f) with regard to valving.

The submittal consisted of 42 sheets of engineering drawings, technical specifications and an engineering summary. The proposed project, to deliver treated water from the City of Vernon, consists of:

- 20,800 linear feet (lf) of 8-inch ASTM D2241 SDR21 PVC pipe;
- Various lengths of 6-inch and 8-inch AWWA C-906, PE4710, DR13.5, or thicker, HDPE pipe;
- Hines Wildcat Pump Station (11734 CR 103)-
  - One 60,000 gallon AWWA D100 welded steel ground storage tank;
  - Two 15 horsepower (hp) high service pumps rated at 175 gpm each at 190 feet total dynamic head (tdh);
  - One 3,000 gallon ASME welded steel pressure tank;
  - Gaseous chlorine disinfection;
  - Demolition of existing facilities;

Mr. Kerry Maroney, Jr., P.E.  
Page 2  
July 3, 2018

- Two 15 hp transmission pumps rated at 175 gpm each at 190 feet tdh;
- 30,700 lf of 6-inch ASTM D2241 SDR21 PVC pipe;
- Northside WSC Pump Station (11502 FM 924W) -
  - One 35,000 gallon AWWA D100 welded steel ground storage tank;
  - Two 15 hp high service pumps rated at 175 gpm each at 190 feet tdh;
  - One 3,000 gallon ASME welded steel pressure tank;
  - Gaseous chlorine disinfection;
  - Demolition of existing facilities.

This approval is for the construction of the above listed items only. Any wastewater components contained in this design were not considered.

An appointed engineer must notify the TCEQ's Region 3 Office in Abilene at (325) 698-9674 when construction will start. Please keep in mind that upon completion of the water works project, the engineer or owner will notify the commission's Water Supply Division, in writing, as to its completion and attest to the fact that the completed work is substantially in accordance with the plans and change orders on file with the commission as required in 30 TAC §290.39(h)(3).

Please refer to the Plan Review Team's Log No. P-05042018-019 in all correspondence for this project.

Please complete a copy of the most current Public Water System Plan Review Submittal form for any future submittals to TCEQ. Every blank on the form must be completed to minimize any delays in the review of your project. The document is available on TCEQ's website at the address shown below. You can also download the most current plan submittal checklists and forms from the same address.

<https://www.tceq.texas.gov/drinkingwater/udpubs.html>

For future reference, you can review part of the Plan Review Team's database to see if we have received your project. This is available on TCEQ's website at the following address:

<https://www.tceq.texas.gov/drinkingwater/planrev.html/#status>


You can download the latest revision of 30 TAC Chapter 290 - Rules and Regulations for Public Water Systems from this site.

Mr. Kerry Maroney, Jr., P.E.  
Page 3  
July 3, 2018


If you have any questions, please contact John Lock at (512)239-4710 or by email at john.lock@tceq.texas.gov or by correspondence at the following address:

Plan Review Team, MC-159  
Texas Commission on Environmental Quality  
P.O. Box 13087  
Austin, Texas 78711-3087

Sincerely,



John Lock, P.E.  
Plan Review Team  
Plan and Technical Review Section  
Water Supply Division  
Texas Commission on Environmental Quality



Vera Poe, P.E., Team Leader  
Plan Review Team  
Plan and Technical Review Section  
Water Supply Division  
Texas Commission on Environmental Quality

VP/JL/db

cc: RRA Hinds Wildcat Water System, P.O. Box 240, Wichita Falls, TX 76307  
Northside WSC, 11502 FM 924W, Vernon, TX 76384  
City of Vernon, 1725 Wilbarger St., Vernon, TX 76384



Mr. Kerry Maroney, Jr., P.E.  
Page 4  
July 3, 2018

bcc: TCEQ Central Records PWS File 2440005 (RRA Hinds Wildcat/P-05042018-019)  
TCEQ Region No. 3 Office - Abilene  
TCEQ PWSINV, MC-155  
PUC, Attn: Tammy Benter, Manager, P.O. Box 13326, Austin, TX 78711