



Control Number: 49068



Item Number: 10

Addendum StartPage: 0

RECEIVED
2019 FEB 14 PM 2:55
PUBLIC UTILITY COMMISSION
FILING CLERK

Service Quality Report
To The
Public Utility Commission of Texas
In Accordance With
Substantive Rule §25.81
2019 Reporting Year

AEP Texas Inc.

Project 49068

10

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

System SAIFI	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced													
2018	1.32248	0.09149	0.08353	0.10345	0.10803	0.11160	0.15304	0.11002	0.10453	0.14243	0.10028	0.10720	0.10688
Scheduled													
2018	0.08150	0.00681	0.00541	0.00623	0.00743	0.00626	0.00618	0.00878	0.00734	0.00656	0.00820	0.00644	0.00587
Outside Causes													
2018	0.24257	0.01225	0.01315	0.03598	0.01822	0.03704	0.02994	0.01350	0.00253	0.01499	0.02972	0.02628	0.00897
Major Events													
2018	0.11543	0.06687	0.00596			0.02599							0.01660

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

System SAIDI	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced													
2018	136.85598	11.49834	6.23587	10.97405	11.84167	12.47983	16.04029	10.53316	10.29364	16.01241	10.56082	10.18671	10.19919
Scheduled													
2018	9.59343	0.68079	0.65373	0.85948	0.85568	0.74335	0.67210	1.11278	0.80559	0.71621	1.05484	0.69830	0.74057
Outside Causes													
2018	18.75591	1.14166	1.16095	2.03113	1.49843	3.63602	1.07338	0.57353	0.13573	1.14480	1.42203	4.29282	0.64541
Major Events													
2018	28.43438	16.02664	2.17884			5.83440							4.39449

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

Total Number of Feeders

With 10 or more Customers

1200

Add or Delete Rows as Necessary

AEP Texas Inc.

2018 SAIFI Ranking	2017 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIFI Value
1	463	JOURDANTON	94LA5685	351	24.664
2	523	ALPINE 12KV	97SA3875	536	13.369
3	11	LAGUNA	94CS9590	2284	9.187
4	77	RAYMONDVILLE #2	94SB3250	28	8.464
5	676	RIO RICO	94SB8330	444	7.577
6	735	MERTZON (CVEC)	97SA2905	584	7.461
7	84	RIO RICO	94SB8290	428	7.243
8	139	TATTON	94CS8200	1060	7.190
9	45	FOSTER FIELD	94CN2550	54	6.907
10	141	RANGERVILLE	94SB3410	202	6.465
11	823	ALICE	94LA2530	1453	6.460
12	389	KITTIE WEST	94CN3765	318	6.450
13	613	BLESSING	94CN1030	286	6.430
14	851	TATTON	94CN8490	329	6.371
15	23	EAST HARRISON	94SB3950	632	5.831
16	2	ELSA	94SB710	2100	5.709
17	356	EL GATO	94SB720	2450	5.427
18	376	ANNA STREET	94LA850	1572	5.422
19	174	HARLINGEN SWITCH	94SB4230	1335	5.360
20	857	STADIUM	94LA8540	1574	5.355
21	890	CHILDRESS 69	97AB1480	292	5.298
22	965	ALPINE 12KV	97SA3160	1085	5.287
23	36	ALAZAN	94CS620	167	5.102
24	655	PREMONT	94LA2730	148	4.966
25	352	GOLIAD	94CN8220	1043	4.900
26	1053	MILO	94LA3065	210	4.848
27	264	CASA BLANCA	94CS1300	282	4.766
28	108	BANQUETTE	94CS9000	453	4.689
29	670	GREENLAKE	94CN2740	363	4.664
30	962	EL GATO	94SB890	2853	4.599
31	898	ALICE	94LA2540	1002	4.555
32	1012	SAN BENITO	94SB4135	1272	4.497
33	478	FOSTER FIELD	94CN8880	293	4.464
34	4	PORT LAVACA	94CN8310	354	4.452
35	88	WEST HARLINGEN	94SB3720	2121	4.440
36	134	LA GRULLA	94SB6150	1537	4.427
37	245	MATTHEWS	94CN1740	158	4.329
38	466	PECOS VALLEY	97SA4080	126	4.183
39	127	MCKENZIE ROAD	94CS140	278	4.176
40	216	SOUTH EAST EDINBURG	94SB6580	1567	4.161
41	1005	GARWOOD CITY	94CN2560	195	4.159
42	1077	HAINE DRIVE	94SB9240	38	4.158
43	1037	VERNON	97AB1750	247	4.105

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIFI Ranking	2017 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIFI Value
44	27	WOOLRIDGE	94CS1120	2715	4.094
45	103	SONORA 138 SUB	97SA4810	898	4.081
46	46	HALL ACRES ROAD	94SB3670	1082	4.007
47	60	WOODSON OIL FIELD	97AB30	33	3.970
48	1057	CEDAR GAP (TEC)	97AB5445	312	3.962
49	156	WEST MCALLEN	94SB4965	923	3.947
50	643	WESMER	94SB9705	1048	3.925
51	275	SHROPSHIRE	94CN3575	33	3.909
52	128	DEL RIO CITY	94LA430	2013	3.870
53	112	TAFT	94CS1180	973	3.850
54	913	MARKHAM	94CN6440	460	3.843
55	287	PHARR	94SB1650	829	3.831
56	1112	PRAIRIE PUMP	94CN1940	78	3.821
57	973	ALPINE 12KV	97SA3155	1139	3.796
58	67	KNIPPA	94LA6365	324	3.787
59	116	MORAN	97AB2107	220	3.777
60	158	LOS FRESNOS	94SB4315	1093	3.768
61	897	LAREDO PLANT	94LA8505	1007	3.766
62	28	ELSA	94SB700	1464	3.671
63	162	ARCADIA	94CS8570	1447	3.661
64	154	ALBANY	97AB2029	235	3.660
65	635	INGLESIDE CITY	94CS6040	394	3.645
66	940	WEST MCALLEN	94SB4555	1664	3.608
67	61	CONOCO-CHITTAM RANCH	94LA8580	25	3.600
68	317	MORRIS STREET	94CS8715	1593	3.596
69	155	MEDIO CREEK	94CN1380	769	3.584
70	248	PHARR	94SB1645	2364	3.549
71	668	REFUGIO	94CN1040	167	3.503
72	206	BROWNSVILLE	94SB3050	1979	3.497
73	90	SUN VALLEY	97SA4300	64	3.484
74	488	JOURDANTON	94LA250	765	3.482
75	359	CARRIZO SPRINGS	94LA370	545	3.479
76	619	EAST HARRISON	94SB3190	1493	3.429
77	513	CLARKWOOD	94CS5525	663	3.404
78	986	GREGORY	94CS420	453	3.404
79	6	RAYMONDVILLE #2	94SB3170	737	3.388
80	7	GILA	94CS350	142	3.380
81	486	EAGLE LAKE	94CN320	638	3.370
82	146	MCCOLL ROAD	94SB2810	2671	3.341
83	197	CABANISS	94CS80	1312	3.329
84	279	TUSCOLA	97AB3730	1381	3.284
85	278	CRESTONIO	94LA260	1760	3.270
86	515	KLEBERG	94CS280	1306	3.269
87	243	CASA BLANCA	94CS4170	1044	3.268
88	465	MORAN	97AB2108	312	3.260
89	56	MCELROY	97SA5165	124	3.258
90	303	AB RAINEY CREEK	97AB4220	194	3.247
91	745	WEST MCALLEN	94SB4515	877	3.244

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIFI Ranking	2017 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIFI Value
92	272	CAUSEWAY	94SB4765	965	3.239
93	383	SPUDDER FLAT	97SA4180	45	3.222
94	878	WESMER	94SB6900	1626	3.214
95	151	MCCAMEY	97SA2415	157	3.210
96	1006	EDNA	94CN5765	1122	3.198
97	302	LAGUNA	94CS9065	2353	3.191
98	886	KLEBERG	94CS9395	1283	3.187
99	30	RIO RICO	94SB5050	1798	3.184
100	257	SAN BENITO	94SB3920	2595	3.176
101	976	UNIVERSITY	94LA305	2089	3.168
102	325	LYTLE	94LA2850	708	3.167
103	236	LAREDO PLANT	94LA8565	1681	3.165
104	370	PALMVIEW	94SB3930	1125	3.159
105	531	KENEDY	94CN6270	551	3.158
106	826	ANNA STREET	94LA2250	1543	3.149
107	743	BLESSING	94CN8780	62	3.145
108	1145	SHEFFIELD	97SA6430	227	3.137
109	21	MAYO	94CS625	203	3.128
110	598	CABANISS	94CS75	2205	3.125
111	712	O CONNER	94CN390	200	3.115
112	362	TAFT	94CS1260	179	3.106
113	26	AB RAINEY CREEK	97AB4550	991	3.097
114	695	WESMER	94SB4480	1119	3.082
115	943	PALMHURST	94SB3890	2660	3.075
116	337	SOUTH EAST EDINBURG	94SB5045	2219	3.074
117	505	MERKEL	97AB1895	704	3.060
118	1162	AB COUNTRY CLUB	97AB4725	223	3.058
119	194	ALBANY	97AB3540	622	3.053
120	622	COTULLA	94LA610	744	3.040
121	120	SOUTHSIDE	94CS5335	1301	3.032
122	575	PETTUS	94CN8210	333	2.991
123	1178	TRENT	97AB2850	28	2.964
124	335	PEARSALL	94LA5580	837	2.945
125	273	PORT ISABEL S.S.	94SB3820	183	2.940
126	41	VERHALEN	97SA4465	14	2.929
127	375	PARKER	94CN9260	108	2.926
128	630	GOVERNMENT WELLS	94LA6800	225	2.867
129	150	BRUNI	94LA5440	138	2.855
130	63	PHARAOH	94CS1365	690	2.841
131	450	AB WALNUT ST	97AB3785	544	2.825
132	169	WESMER	94SB7760	2506	2.792
133	N/A	JOURDANTON	94LA7880	584	2.788
134	125	CRYSTAL CITY	94LA8380	1334	2.777
135	609	THREE RIVERS	94CN8430	192	2.771
136	468	SAND ROAD	97AB5295	538	2.768
137	854	CATARINA	94LA2380	200	2.765
138	181	CHERRY CREEK TAP	97SA5245	49	2.755
139	698	KLEBERG	94CS1560	1440	2.752

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIFI Ranking	2017 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIFI Value
140	997	HEARN ROAD	94CS8980	1250	2.750
141	93	CROSS PLAINS	97AB2920	570	2.746
142	266	GOLIAD	94CN6540	1201	2.743
143	263	MOORE FIELD	94SB3120	162	2.741
144	270	PREMONT	94LA6570	761	2.735
145	220	RAYMONDVILLE #1	94SB620	642	2.731
146	421	CLARKWOOD	94CS7230	613	2.724
147	641	WEIL TRACT (138/12KV)	94CS2520	155	2.723
148	347	CASA BLANCA	94CS55	853	2.706
149	966	PAISANO	97SAPAI SAN	136	2.699
150	199	EL GATO	94SB780	1732	2.687
151	330	SOUTHSIDE	94CS8005	744	2.684
152	316	SOUTHSIDE	94CS7995	1555	2.681
153	306	HEARN ROAD	94CS8990	1266	2.661
154	163	CABANISS	94CS240	1548	2.659
155	291	GILA	94CS345	68	2.647
156	298	PREMONT	94LA6610	817	2.644
157	948	BAY CITY	94CN7480	2093	2.626
158	790	NORTH PADRE ISLAND	94CS5170	1280	2.620
159	1029	HAWLEY	97AB4455	600	2.612
160	427	ARMSTRONG	94CS6050	81	2.605
161	234	QUANAH	97AB100	90	2.600
162	638	EL CAMPO	94CN2800	821	2.596
163	769	OLMITO	94SB905	1598	2.591
164	210	AIRLINE	94CS7280	645	2.589
165	931	AB OIL MILL	97AB3900	678	2.581
166	889	MUNDAY REA (BKEC)	97AB2015	21	2.571
167	938	CLYDE	97AB1760	430	2.563
168	89	GOVERNMENT WELLS	94LA7240	225	2.556
169	509	POLK AVENUE	94SB4520	939	2.555
170	475	COLUMBUS	94CN9060	369	2.545
171	429	LAREDO PLANT	94LA9305	1047	2.544
172	178	NORTH VICTORIA	94CN7440	1603	2.522
173	392	HAMLIN SHELL	97AB6330	25	2.520
174	318	BEEVILLE	94CN1760	1831	2.520
175	179	WESLACO UNIT	94SB5970	2439	2.517
176	588	PALMHURST	94SB1300	2176	2.506
177	99	STAMFORD	97AB2815	711	2.505
178	713	SINTON	94CS6860	1658	2.501
179	100	RANDADO	94LA8350	135	2.489
180	301	SOUTHSIDE	94CS7955	1062	2.455
181	33	BROWNSVILLE	94SB4290	499	2.453
182	572	PALMHURST	94SB2535	2329	2.449
183	591	MUNDAY	97AB6715	249	2.438
184	881	HIGHWAY 9	94CS6760	1019	2.425
185	295	SARAGOSA	97SA1590	79	2.418
186	345	HOLCOMB	94LA2240	451	2.415
187	91	SANTA RITA	97SA1105	73	2.411

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIFI Ranking	2017 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIFI Value
188	360	DILLEY	94LA510	557	2.408
189	37	MALONE	94CN7560	117	2.402
190	12	RIO GRANDE CITY	94SB3210	1851	2.398
191	797	AB ELM CREEK	97AB5045	379	2.396
192	639	VALENTINE	97SA6325	577	2.392
193	525	NORTH MCALLEN	94SB5055	3230	2.391
194	254	PHARAOH	94CS1285	1782	2.383
195	47	SEAWALL	94CS9420	714	2.375
196	604	HAINE DRIVE	94SB9690	555	2.366
197	187	BEEVILLE	94CN8510	820	2.365
198	354	PALACIOS	94CN6840	1540	2.356
199	693	NORTH ALAMO	94SB4370	1542	2.347
200	1122	PORTLAND	94CS9270	1610	2.345
201	117	TATTON	94CS950	464	2.343
202	320	WESLACO UNIT	94SB7455	1189	2.338
203	80	CRESTONIO	94LA270	627	2.322
204	160	OLMITO	94SB4275	788	2.319
205	328	WESLACO UNIT	94SB2195	1071	2.314
206	1034	WEST MCALLEN	94SB4595	1190	2.310
207	1007	CISCO	97AB7400	820	2.310
208	677	RANDADO	94LA8360	172	2.308
209	595	HUMBLE KEMPER	97SA72103	27	2.296
210	342	LIVE OAK	94CS1090	230	2.291
211	858	HOLLY	94CS1370	1891	2.284
212	231	ELDORADO	97SA2880	342	2.284
213	958	PHARR	94SB1640	1342	2.278
214	671	REFUGIO	94CN5120	688	2.278
215	70	LULING - LCRA	94CN10	410	2.271
216	467	MCCOLL ROAD	94SB4400	1422	2.262
217	425	RIO GRANDE CITY	94SB3740	2284	2.261
218	751	HEARN ROAD	94CS870	1178	2.258
219	1019	EAGLE PASS CITY	94LA7060	861	2.250
220	227	BEEVILLE	94CN2380	217	2.244
221	59	SOUTHSIDE	94CS8045	1008	2.240
222	388	KENEDY	94CN1970	568	2.236
223	105	CROSS PLAINS	97AB2915	759	2.236
224	787	ASHERTON	94LA2660	628	2.234
225	941	MORRIS STREET	94CS7625	560	2.227
226	810	NORTH EDINBURG	94SB560	2120	2.221
227	170	WESLACO UNIT	94SB7630	2567	2.211
228	39	BROWNSVILLE	94SB4280	320	2.209
229	294	HARLINGEN	94SB660	1942	2.209
230	414	RAYMONDVILLE #1	94SB630	792	2.203
231	891	AB ONYX REA	97AB3260	138	2.203
232	92	PHARAOH	94CS1185	1638	2.201
233	683	NORTH MERCEDES	94SB3840	652	2.187
234	288	COFFEE PORT	94SB1090	1203	2.183
235	583	AFTON	97AB2355	45	2.178

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIFI Ranking	2017 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIFI Value
236	15	LA PRYOR	94LA570	151	2.172
237	626	CITRUS CITY	94SB6000	2177	2.170
238	1161	POINT COMFORT	94CN6060	367	2.166
239	758	SABINAL	94LA485	492	2.157
240	228	KINGSVILLE	94CS1350	388	2.152
241	407	EAGLE LAKE	94CN310	734	2.151
242	290	HOLLY	94CS5820	928	2.149
243	990	COTULLA	94LA110	36	2.139
244	44	FULTON	94CS6070	3282	2.128
245	1071	AB OVER STREET 12KV	97AB3140	651	2.127
246	484	POLK AVENUE	94SB4610	1179	2.125
247	371	PHARAOH	94CS5175	1283	2.123
248	202	COFFEE PORT	94SB1095	1017	2.122
249	956	DEVINE	94LA7100	1081	2.120
250	285	WADSWORTH	94CN7660	1407	2.117
251	1110	VERNON	97AB1520	721	2.117
252	415	ANNA STREET	94LA5780	669	2.114
253	507	SA EMERSON ST	97SA4630	1191	2.111
254	233	PETTUS	94CN1020	459	2.109
255	42	WEIL TRACT (138/12KV)	94CS5405	171	2.105
256	561	STAMFORD	97AB2835	133	2.105
257	182	DEL RIO CITY	94LA420	1998	2.103
258	76	GILA	94CS7840	770	2.101
259	43	NORTH MCCAMEY	97SA6555	502	2.100
260	265	HARLINGEN SWITCH	94SB320	1544	2.097
261	532	BANQUETTE	94CS130	230	2.087
262	1096	SA LAKE DR	97SA6030	669	2.085
263	358	LIVE OAK	94CS1080	1315	2.084
264	1060	AB SHELTON ST	97AB3145	1076	2.073
265	472	TRENT	97AB4245	181	2.072
266	474	ALBANY	97AB3655	627	2.072
267	1152	EAGLE PASS CITY	94LA2510	578	2.069
268	286	MORRIS STREET	94CS8820	1243	2.063
269	35	BLESSING	94CN8790	768	2.060
270	1026	MORRIS STREET	94CS8840	651	2.057
271	95	AB CANYON ROCK	97AB5035	965	2.052
272	1004	MUSTANG ISLAND	94CS9470	678	2.050
273	462	CROSS PLAINS	97AB1795	432	2.039
274	341	MORRIS STREET	94CS5655	402	2.032
275	1163	ROTAN	97AB1865	191	2.031
276	395	HIGHWAY 9	94CS6770	1089	2.031
277	581	AB COUNTRY CLUB	97AB4730	533	2.024
278	1181	MCCOLL ROAD	94SB4910	340	2.024
279	841	YELLOW JACKET	97SA5505	532	2.008
280	909	NORTH MCALLEN	94SB9640	1504	2.007
281	51	GRETA	94CN7890	259	1.996
282	1062	WEST MCALLEN	94SB6385	241	1.992
283	66	BEEVILLE	94CN300	1665	1.983

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIFI Ranking	2017 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIFI Value
284	652	NAVAL BASE	94CS7950	329	1.979
285	860	PORT ARANSAS	94CS3030	675	1.973
286	224	ELSA	94SB690	2389	1.957
287	725	BAY CITY	94CN5960	2115	1.952
288	1142	MUSTANG ISLAND	94CS8510	453	1.949
289	607	CLARKWOOD	94CS7220	864	1.938
290	508	PALMHURST	94SB2525	2093	1.927
291	402	NORTH MERCEDES	94SB4860	1499	1.925
292	522	UVALDE	94LA6620	2795	1.920
293	241	KARNES CITY	94CN2325	663	1.917
294	546	PERKINS PROTHO	97SA3180	23	1.913
295	900	AB WALNUT ST	97AB3445	68	1.912
296	N/A	NORTH MCCAMEY	97SA6560	10	1.900
297	627	CITRUS CITY	94SB5070	914	1.896
298	597	OLMITO	94SB715	627	1.876
299	1101	EDEN	97SA3195	517	1.868
300	789	ROCKPORT	94CS5930	1312	1.861
301	133	GREENLAKE	94CN2760	1160	1.849
302	877	SA COKE ST	97SA3905	648	1.844
303	918	FT CHADBOURNE	97SA6515	91	1.835
304	573	SOUTH MISSION	94SB3980	2146	1.827
305	528	PLEASANTON	94LA9475	1346	1.825
306	431	CARANCAHUA	94CN5870	501	1.822
307	13	SOUTH PADRE ISLAND	94SB6440	2688	1.820
308	101	PECOS VALLEY	97SA4075	21	1.810
309	269	THREE RIVERS	94CN5190	476	1.809
310	14	ARANSAS PASS	94CS590	395	1.785
311	645	MORRIS STREET	94CS2515	1078	1.782
312	102	RIO GRANDE CITY	94SB3220	1357	1.782
313	172	MOORE FIELD	94SB3960	2092	1.761
314	401	DEVINE	94LA8100	1659	1.759
315	1040	RODD FIELD	94CS3010	1996	1.756
316	372	HALL ACRES ROAD	94SB3460	3108	1.746
317	953	SOUTH MCALLEN	94SB5065	132	1.742
318	916	DIMMIT	94LA5545	565	1.736
319	284	EAGLE PASS CITY	94LA2770	2955	1.708
320	1031	AB RAINEY CREEK	97AB4270	1390	1.697
321	530	AIRLINE	94CS7390	2160	1.688
322	198	ELSA	94SB3520	501	1.681
323	833	NORTH MCALLEN	94SB2980	1773	1.677
324	682	SOUTHSIDE	94CS7905	1765	1.672
325	312	PLEASANTON	94LA120	1226	1.667
326	1158	MILO	94LA6940	447	1.662
327	818	SAN BENITO	94SB4945	1722	1.660
328	368	BIG WELLS	94LA1570	436	1.658
329	602	SOUTH SANTA ROSA	94SB1225	854	1.658
330	859	RAYMONDVILLE #2	94SB1280	986	1.655
331	644	WEST OSO	94CS9090	1667	1.651

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIFI Ranking	2017 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIFI Value
332	240	NORTH MCALLEN	94SB4995	2417	1.630
333	277	PORT ISABEL S.S.	94SB9295	2268	1.627
334	656	PALMHURST	94SB2530	1818	1.627
335	684	LIVE OAK	94CS1070	2411	1.626
336	733	FLOMOT	97AB1852	74	1.622
337	406	ARCADIA	94CS1400	444	1.619
338	304	ELSA	94SB3500	1242	1.619
339	483	SEAWALL	94CS9450	291	1.608
340	547	NORTH ALAMO	94SB3610	1882	1.607
341	837	PORT LAVACA	94CN2490	1054	1.602
342	1089	AIRLINE	94CS9390	2937	1.602
343	442	TANKERSLY (CVEC)	97SA5260	463	1.600
344	1177	ONYX REA	97AB3255	30	1.600
345	118	QUANAH	97AB1830	611	1.599
346	424	LOS FRESNOS	94SB7270	2207	1.598
347	964	AIRLINE	94CS6970	1394	1.595
348	499	BIG OAK	94CN420	151	1.589
349	364	INGLESIDE CITY	94CS8050	1245	1.584
350	404	SEAWALL	94CS9325	1438	1.581
351	657	FALFURRIAS	94LA1080	450	1.580
352	54	GREGORY	94CS5900	103	1.563
353	72	PORT ARANSAS	94CS1000	1981	1.557
354	369	AMISTAD DAM	94LA5450	1250	1.556
355	10	LA PRYOR	94LA580	238	1.550
356	887	WEIL TRACT (138/12KV)	94CS1990	1387	1.545
357	479	PALACIOS	94CN8550	46	1.543
358	694	SAND ROAD	97AB5655	613	1.537
359	872	PALMVIEW	94SB9680	1026	1.529
360	355	SINTON	94CS180	972	1.526
361	664	HIDALGO	94SB4845	1264	1.525
362	701	SAN DIEGO	94LA1980	595	1.524
363	104	PLEASANTON	94LA9505	1734	1.515
364	611	AIRLINE	94CS9030	416	1.514
365	844	WEST HARLINGEN	94SB3700	1799	1.513
366	24	FALFURRIAS	94LA5210	1108	1.513
367	186	NIXON	94CN6630	675	1.508
368	83	ALBANY	97AB3640	326	1.500
369	543	KINGSVILLE	94CS1660	1998	1.495
370	659	NORTH MCALLEN	94SB5060	2482	1.492
371	755	SA NORTH	97SA3115	559	1.490
372	49	FREER	94LA1500	205	1.488
373	706	SHARYLAND	94SB6745	2155	1.487
374	711	NORTH PADRE ISLAND	94CS7900	2258	1.480
375	927	AB MCMURRY	97AB4355	994	1.478
376	461	HOLLY	94CS1950	819	1.477
377	417	MCCOLL ROAD	94SB4790	2045	1.473
378	487	STERLING CITY	97SA1445	876	1.473
379	452	HASKELL 12KV	97AB3770	444	1.468

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIFI Ranking	2017 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIFI Value
380	776	SA GRAPE CREEK	97SA4700	716	1.468
381	747	HAINE DRIVE	94SB270	1092	1.465
382	1072	RIO BRAVO	94LA300	793	1.460
383	381	SKIDMORE	94CS600	350	1.460
384	71	MASTERTON FIELD	97SA800	194	1.459
385	571	RIO BRAVO	94LA1130	1016	1.459
386	168	BISHOP	94CS7180	924	1.455
387	3	MAYBERRY	94SB3160	554	1.451
388	955	BRONTE	97SA3590	177	1.446
389	307	BAY CITY	94CN1110	1261	1.445
390	268	TWILIGHT TRAIL	97AB4290	983	1.444
391	326	MILO	94LA5020	108	1.435
392	665	CRESTONIO	94LA6660	765	1.416
393	305	ARANSAS PASS	94CS660	728	1.409
394	612	THREE RIVERS	94CN5100	66	1.409
395	819	EAGLE LAKE	94CN9455	594	1.404
396	876	ROBY	97AB3795	72	1.403
397	998	EAST HARRISON	94SB4620	774	1.402
398	512	WESLACO UNIT	94SB8195	1649	1.395
399	978	DEVINE	94LA7090	1002	1.391
400	82	NIXON	94CN3300	583	1.386
401	177	BAIRD	97AB5125	599	1.384
402	520	HARLINGEN	94SB360	2456	1.379
403	808	OZONA	97SA3555	164	1.378
404	218	SOUTHSIDE	94CS7925	1265	1.378
405	894	PORT ARANSAS	94CS990	1328	1.373
406	9	SUNCHASE	94SB1150	1297	1.373
407	252	AIRLINE	94CS8260	1450	1.373
408	367	RAYMONDVILLE #2	94SB3240	944	1.373
409	831	MCCOLL ROAD	94SB1655	1334	1.372
410	152	PORTLAND	94CS6505	1802	1.372
411	126	FULTON	94CS9050	1543	1.371
412	357	GARCENO	94SB5490	595	1.370
413	788	SA GRAPE CREEK	97SA5220	684	1.363
414	229	GATEWAY	94LA350	1916	1.358
415	615	ARCADIA	94CS1440	1680	1.355
416	861	ODEM	94CS5575	68	1.353
417	259	SPUDDER FLAT	97SA4175	51	1.353
418	351	SAN DIEGO	94LA2890	1033	1.347
419	260	BIG WELLS	94LA2630	29	1.345
420	253	MCCOLL ROAD	94SB4780	1971	1.344
421	518	HARLINGEN	94SB380	2695	1.338
422	353	KLEBERG	94CS6000	1478	1.336
423	38	GARCENO	94SB2135	2182	1.333
424	926	KINGSVILLE	94CS1140	1031	1.330
425	720	VILLA CAVAZOS	94SB1980	1681	1.327
426	642	GOODWIN	94SB4380	1540	1.321
427	1095	AB DYESS 1	97AB1775	727	1.320

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIFI Ranking	2017 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIFI Value
428	879	GONZALES	97SA15390	1331	1.313
429	235	KENEDY S.S.	94CN8340	339	1.304
430	222	SOUTH SANTA ROSA	94SB1240	1590	1.304
431	145	GREGORY	94CS5920	689	1.300
432	495	PALMVIEW	94SB7595	3151	1.299
433	142	NAVAL BASE	94CS9720	2464	1.297
434	835	MCCAMEY	97SA2830	464	1.295
435	157	HALL ACRES ROAD	94SB8870	2365	1.293
436	616	PLACEDO	94CN7980	424	1.292
437	930	KINGSVILLE	94CS1130	2310	1.291
438	977	PREMONT	94LA2720	762	1.289
439	267	TWILIGHT TRAIL	97AB5855	1435	1.284
440	338	STADIUM	94LA7490	1296	1.281
441	1121	INDIAN MESA	97SA2690	69	1.275
442	68	RISING STAR	97AB5080	584	1.274
443	985	KLEBERG	94CS6410	243	1.267
444	327	LOLITA	94CN6330	30	1.267
445	545	BEN FICKLIN	97SA6180	1050	1.266
446	438	BEEVILLE	94CN2200	750	1.263
447	618	SA GRAPE CREEK	97SA5365	797	1.262
448	385	POLK AVENUE	94SB4190	1697	1.262
449	809	FT CHADBOURNE	97SA6520	543	1.256
450	608	BUENA VISTA	94LA9035	1913	1.252
451	384	GANADO	94CN5795	487	1.248
452	552	SOUTH SANTA ROSA	94SB1215	1660	1.246
453	856	NORTH VICTORIA	94CN6390	1498	1.246
454	825	PALMVIEW	94SB9685	2838	1.239
455	25	DEL RIO CITY	94LA9850	1013	1.236
456	391	FULTON	94CS3070	1390	1.235
457	529	SONORA	97SA2045	620	1.234
458	521	TURKEY	97AB2980	314	1.229
459	447	SOUTHSIDE	94CS8055	857	1.229
460	280	RISING STAR	97AB5075	663	1.225
461	1136	AIRLINE	94CS8370	287	1.223
462	724	RIO PECOS	97SA3835	126	1.222
463	195	MESA VIEW	97SA7045	99	1.222
464	132	EDNA	94CN5785	1328	1.222
465	281	NORTH PADRE ISLAND	94CS720	1309	1.216
466	53	ROBSTOWN	94CS1650	361	1.216
467	732	RULE	97AB3396	430	1.212
468	1139	KIRKLAND	97AB3545	29	1.207
469	1022	GANADO	94CN5815	597	1.206
470	423	ALICE	94LA1780	243	1.206
471	419	EL GATO	94SB910	2466	1.202
472	750	EL CAMPO	94CN2860	1479	1.201
473	914	YELLOW JACKET	97SA7935	794	1.199
474	123	MAGRUDER	94CN245	1233	1.195
475	497	MUNDAY	97AB2080	472	1.195

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIFI Ranking	2017 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIFI Value
476	251	DEL RIO CITY	94LA1930	1547	1.195
477	646	WADSWORTH	94CN8630	673	1.193
478	258	ALAZAN	94CS2740	37	1.189
479	862	MARFA	97SA1900	770	1.188
480	398	WINTERS	97SA3765	800	1.186
481	718	BROOKHOLLOW	94CN8960	592	1.186
482	55	PORT ISABEL S.S.	94SB4070	280	1.182
483	444	MELVIN	97SA940	44	1.182
484	760	RIO PECOS	97SA513	33	1.182
485	932	HASKELL 12KV	97AB3495	801	1.181
486	746	BROOKHOLLOW	94CN8950	899	1.180
487	501	AB COUNTRY CLUB	97AB4855	785	1.180
488	557	MELVIN	97SA4955	91	1.176
489	593	WASHINGTON STREET	94LA2470	456	1.175
490	1143	MILO	94LA3060	133	1.173
491	556	MAYBERRY	94SB1790	744	1.169
492	40	INDIAN MESA	97SA2695	169	1.166
493	1002	SA JACKSON ST	97SA4265	796	1.165
494	961	NORTH PADRE ISLAND	94CS1010	2169	1.163
495	696	DILLEY	94LA3795	816	1.162
496	721	NORTH VICTORIA	94CN2240	744	1.161
497	58	SINTON	94CS360	313	1.160
498	803	CROWELL	97AB3490	177	1.158
499	679	SAN DIEGO	94LA2930	571	1.158
500	567	AIRLINE	94CS7270	1026	1.155
501	994	HARLINGEN SWITCH	94SB5350	918	1.154
502	50	PUTNAM	97AB2129	216	1.153
503	492	RUSSEK STREET	97SA7705	1345	1.152
504	455	SONORA 138 SUB	97SA4805	441	1.150
505	192	THOMASTON	94CN9580	47	1.149
506	1094	SA SOUTHLAND HILLS	97SA5455	1403	1.148
507	314	PORT ARANSAS	94CS6940	1431	1.147
508	256	CEDAR GAP (TEC)	97AB4115	520	1.144
509	69	NAVAL BASE	94CS8540	1586	1.144
510	211	RODD FIELD	94CS225	2645	1.142
511	1092	SHARYLAND	94SB2010	1150	1.141
512	498	PUEBLO	94LA275	2794	1.139
513	377	BLACK BAYOU	94CN1120	317	1.139
514	1023	AB ELM CREEK	97AB4775	885	1.136
515	334	TUSCOLA	97AB3305	1068	1.131
516	1010	HAINE DRIVE	94SB3490	1134	1.131
517	821	HASKELL 12KV	97AB5240	654	1.130
518	1116	MORRIS STREET	94CS7465	811	1.128
519	1055	SANTO NINO	94LA645	1412	1.127
520	136	VICTORIA POWER PLANT	94CN1390	1093	1.127
521	379	DEL MAR	94LA220	2670	1.122
522	1011	AB WALNUT ST	97AB3110	928	1.121
523	562	STAMFORD	97AB6255	392	1.120

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIFI Ranking	2017 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIFI Value
524	173	SHROPSHIRE	94CN1240	67	1.119
525	344	BUSH KNOB	97AB5200	290	1.114
526	1086	EAST HARRISON	94SB3030	682	1.113
527	579	SIERRA VISTA	94LA7360	1571	1.108
528	963	KARNES CITY	94CN2340	807	1.103
529	1079	AB OIL MILL	97AB2780	742	1.101
530	933	CISCO	97AB1020	422	1.097
531	476	MIDWAY LANE	97SA3440	62	1.097
532	223	AIRLINE	94CS8890	529	1.096
533	200	AB RAINEY CREEK	97AB4225	116	1.095
534	812	SPUR	97AB260	161	1.093
535	131	ARANSAS PASS	94CS1250	620	1.092
536	1115	CHILDRESS 20TH ST	97AB5720	179	1.089
537	489	ROTAN	97AB1860	717	1.089
538	939	NORDHEIM	94CN4275	82	1.085
539	654	MALONE	94CN7550	193	1.083
540	780	KITTIE WEST	94CN3760	234	1.081
541	315	FASHING	94CN360	37	1.081
542	373	WASHINGTON STREET	94LA7015	1534	1.081
543	242	TURKEY	97AB3825	394	1.079
544	524	WINTERS	97SA2113	807	1.078
545	794	ROCHESTER	97AB3290	77	1.078
546	580	LOS FRESNOS	94SB2160	1465	1.077
547	422	STAMFORD	97AB4565	786	1.076
548	629	ARANSAS PASS	94CS9130	367	1.076
549	1008	SA EMERSON ST	97SA4625	412	1.075
550	949	EAST HARRISON	94SB3000	520	1.071
551	688	CHRISTOVAL	97SA6615	422	1.069
552	650	ZACATE CREEK	94LA2665	1706	1.067
553	685	HAINE DRIVE	94SB8065	1354	1.066
554	905	CISCO	97AB9715	1009	1.066
555	734	CHILDRESS 69	97AB4865	775	1.065
556	191	AB MAPLE ST	97AB5755	1689	1.063
557	982	CONTINENTAL	94SB4080	65	1.062
558	485	WYLIE	97AB6340	734	1.061
559	1154	SPUR	97AB300	214	1.061
560	1038	SA SOUTHLAND HILLS	97SA5055	840	1.061
561	N/A	MESQUITE	94SB3360	639	1.059
562	936	DEL MAR	94LA3440	1449	1.059
563	838	BLUFFS	97SA9110	597	1.055
564	944	KLEBERG	94CS8140	644	1.054
565	847	HIGHWAY 9	94CS6720	1309	1.048
566	502	RODD FIELD	94CS205	2018	1.048
567	910	STAMFORD PUMP	97AB3930	43	1.047
568	289	ASPERMONT	97AB3380	403	1.045
569	262	HAROLD	97AB1495	24	1.042
570	448	FREISS RANCH	97SA4870	99	1.040
571	514	VERNON	97AB3340	532	1.039

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIFI Ranking	2017 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIFI Value
572	603	SA SOUTH	97SA4795	1269	1.033
573	204	ELDORADO	97SA1845	772	1.030
574	1075	AB OVER STREET 12KV	97AB1840	886	1.026
575	904	AB COUNTRY CLUB	97AB4735	120	1.025
576	539	PUEBLO	94LA130	1425	1.019
577	1042	LAREDO PLANT	94LA8705	214	1.019
578	767	CHARLOTTE	94LA2780	54	1.019
579	576	KENEDY S.S.	94CN6750	58	1.017
580	741	HIGHLAND	97SA6380	422	1.014
581	874	BUENA VISTA	94LA8965	924	1.009
582	250	BARNHART	97SA3725	145	1.007
583	871	AB MAPLE ST	97AB5750	398	1.005
584	N/A	SIERRA VISTA	94LA7170	1439	1.005
585	57	ASPR CONTINENTAL	97AB4800	33	1.000
586	399	BRONTE AMBASSADOR	97SA6650	16	1.000
587	594	AB WALNUT ST	97AB3250	11	1.000
588	319	LEARY LANE	94CN6175	2523	0.997
589	634	EAST HARRISON	94SB4360	1717	0.995
590	339	SA MATHIS FIELD	97SA4790	175	0.994
591	310	SOUTH MCALLEN	94SB3850	1341	0.993
592	459	AILEEN	97AB4600	253	0.992
593	1087	EDEN	97SA1780	243	0.992
594	549	SOUTHSIDE	94CS5345	401	0.990
595	382	HEARN ROAD	94CS2220	1644	0.987
596	1141	ACME BESTWALL	97AB4150	64	0.984
597	193	EL CAMPO	94CN7710	1052	0.984
598	5	SABINAL	94LA200	437	0.975
599	436	POLK AVENUE	94SB4740	1690	0.968
600	950	CITRUS CITY	94SB3470	1582	0.965
601	764	TYNAN	94CS1855	135	0.963
602	79	NORTH MCALLEN	94SB2750	2796	0.958
603	300	CLARKWOOD	94CS9570	1156	0.955
604	460	SARAGOSA	97SA1552	766	0.952
605	1090	CROCKETT HEIGHTS	97SA73703	78	0.949
606	544	EL CAMPO	94CN6370	747	0.942
607	74	EDROY	94CS6990	283	0.940
608	834	ARANSAS PASS	94CS650	858	0.930
609	480	STAFFORD HILL	94CN1550	227	0.921
610	111	SOUTH MCALLEN	94SB3640	314	0.920
611	689	ARCADIA	94CS1450	1996	0.919
612	704	SOUTH EAST EDINBURG	94SB4550	2128	0.901
613	675	GREGORY	94CS8560	250	0.900
614	292	DILLEY	94LA6400	179	0.894
615	144	POLK AVENUE	94SB4900	2928	0.893
616	405	SHAFTER	97SA5110	52	0.885
617	374	KINGSVILLE	94CS1670	412	0.879
618	412	UVALDE	94LA480	1314	0.877
619	526	ANSON 12KV	97AB6635	401	0.873

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIFI Ranking	2017 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIFI Value
620	804	THREE RIVERS	94CN2580	125	0.864
621	52	DARST	94CN790	254	0.862
622	770	ARCADIA	94CS1460	2120	0.860
623	109	PEARSALL	94LA7050	943	0.859
624	906	MCCAMEY	97SA2420	113	0.858
625	493	NORTH EDINBURG	94SB4240	2656	0.829
626	396	SOUTH SANTA ROSA	94SB1235	648	0.829
627	207	ROARING SPRINGS	97AB6155	29	0.828
628	774	WEAVER ROAD	94CN1900	57	0.825
629	731	GOODWIN	94SB7380	1804	0.818
630	1085	MINES ROAD	94LA4275	194	0.814
631	121	BRUNI	94LA1120	286	0.797
632	892	CISCO	97AB6530	528	0.795
633	662	RUNGE	94CN4465	385	0.795
634	261	CAUSEWAY	94SB4795	1222	0.792
635	791	SAN BENITO	94SB4030	2672	0.788
636	140	MAVERICK	94LA9680	755	0.784
637	1104	SHARYLAND	94SB2150	1452	0.780
638	647	ABILENE PLANT	97AB1735	86	0.779
639	756	MAGRUDER	94CN7870	1263	0.762
640	65	FALFURRIAS	94LA2830	1458	0.757
641	167	HOLLY	94CS1480	1714	0.755
642	255	PALMHURST	94SB2820	1799	0.753
643	86	CHOKY CANYON	94CN9255	355	0.749
644	589	BRADY	97SA5015	200	0.745
645	669	DUNE FIELD (N CRANE)	97SA3885	74	0.743
646	673	VERNON	97AB4275	588	0.743
647	772	SANTO NINO	94LA515	2165	0.739
648	171	LA PRYOR	94LA2440	713	0.738
649	19	HOLCOMB	94LA3025	333	0.736
650	817	EAGLE PASS CITY	94LA2745	933	0.735
651	440	MORRIS STREET	94CS8830	1542	0.724
652	1138	GOODWIN	94SB3530	340	0.724
653	895	LEARY LANE	94CN1890	1626	0.716
654	849	KARNES CITY	94CN2315	1018	0.711
655	959	ROCKSPRINGS	94LA2600	379	0.710
656	785	UVALDE	94LA5060	1341	0.706
657	96	PORTLAND	94CS9290	1770	0.705
658	283	WEST MCALLEN	94SB4535	2851	0.703
659	1	ARANSAS PASS	94CS8270	377	0.698
660	863	SOUTH MISSION	94SB3590	568	0.690
661	115	CLIMAX/BRADSHAW	97AB11301	67	0.687
662	703	LANTANA	94CS7150	274	0.668
663	29	BONNIEVIEW	94CS8020	477	0.665
664	542	ROCKPORT	94CS5950	525	0.663
665	413	WEST HARLINGEN	94SB4870	1047	0.657
666	1013	WEAVER ROAD	94CN1910	23	0.652
667	464	ZAPATA	94LA2710	1295	0.649

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIFI Ranking	2017 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIFI Value
668	648	ESCONDIDO	94LA5730	1208	0.648
669	700	WESMER	94SB4050	1932	0.646
670	870	WEST MCALLEN	94SB4815	673	0.645
671	814	NORTH MERCEDES	94SB3770	1777	0.636
672	884	NORTH EDINBURG	94SB3570	1022	0.626
673	763	SAN DIEGO	94LA2880	1310	0.618
674	1176	FLOMONT	97AB81335	34	0.618
675	651	VILLA CAVAZOS	94SB7615	1058	0.617
676	138	PHARAOH	94CS5185	2350	0.615
677	336	ARCADIA	94CS6930	1493	0.614
678	500	SOUTH PADRE ISLAND	94SB5850	1305	0.612
679	209	BAY CITY	94CN6450	963	0.610
680	742	LOS FRESNOS	94SB5335	2511	0.606
681	795	POLK AVENUE	94SB4600	3138	0.606
682	1099	SHARYLAND	94SB2035	741	0.606
683	749	GOODWIN	94SB4625	1949	0.605
684	660	POWELL FIELD	97SA2528	25	0.600
685	631	CRYSTAL CITY	94LA1425	1167	0.599
686	185	SOUTH PADRE ISLAND	94SB4695	1324	0.597
687	394	CARRIZO SPRINGS	94LA860	32	0.594
688	728	HEIGHTS	94LA6810	2024	0.591
689	1016	RANKIN	97SA5735	177	0.576
690	97	ZAPATA	94LA8290	490	0.576
691	882	CITRUS CITY	94SB9775	1533	0.571
692	34	PLACEDO	94CN7970	478	0.571
693	296	GARCENO	94SB2130	1767	0.571
694	212	ROBERT LEE	97SA4120	556	0.567
695	845	MOCKINGBIRD	94CN400	408	0.566
696	439	QUANAH	97AB3975	206	0.563
697	979	NORTH VICTORIA	94CN7860	1492	0.561
698	777	SAN YGNACIO	94LA16060	486	0.556
699	621	RANKIN	97SA7425	119	0.555
700	147	HAMILTON ROAD	94LA9665	1234	0.553
701	226	SOUTHSIDE	94CS8025	1071	0.542
702	8	POLK AVENUE	94SB4170	1455	0.539
703	723	CRYSTAL CITY	94LA7425	435	0.536
704	380	PECAN BAYOU	97AB6810	395	0.534
705	714	FREER	94LA6320	166	0.530
706	110	VICTORIA POWER PLANT	94CN7600	161	0.528
707	737	GARWOOD CITY	94CN2570	144	0.528
708	119	CHILLICOTHE	97AB4530	495	0.527
709	1032	GATEWAY	94LA5055	1691	0.523
710	299	RACHAL	94LA8145	346	0.523
711	730	ALICE	94LA1770	1636	0.520
712	868	DIMMIT	94LA4120	1320	0.516
713	893	EL CAMPO	94CN7260	522	0.513
714	238	SOUTH SANTA ROSA	94SB7485	1068	0.512
715	555	SAND ROAD	97AB5290	803	0.504

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIFI Ranking	2017 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIFI Value
716	159	MARKHAM	94CN5550	22	0.500
717	410	SOUTH MCALLEN	94SB3790	1435	0.498
718	624	YORKTOWN	94CN3130	470	0.489
719	1165	SA EMERSON ST	97SA4860	242	0.488
720	786	VILLA CAVAZOS	94SB5680	1796	0.486
721	219	ASPR CONTINENTAL	97AB3830	27	0.481
722	188	HAMILTON ROAD	94LA9655	1256	0.480
723	213	ASPERMONT	97AB1070	327	0.477
724	867	BAY CITY	94CN2050	540	0.476
725	729	BAY CITY	94CN6670	1601	0.473
726	143	BEN FICKLIN	97SA6175	705	0.468
727	587	GATEWAY	94LA3595	1481	0.467
728	390	AB VOGEL ST	97AB4405	574	0.463
729	365	ESCONDIDO	94LA2035	2639	0.460
730	516	BANDERA ELECTRIC (LEAKEY)	94LAL30	271	0.454
731	386	SOUTHSIDE	94CS8035	1108	0.449
732	1045	HIGHLAND	97SA6385	1317	0.449
733	989	ABILENE PLANT	97AB1575	614	0.445
734	558	CONTINENTAL	94SB3650	18	0.444
735	739	HALL ACRES ROAD	94SB5585	1448	0.443
736	816	WASHINGTON STREET	94LA2350	3013	0.439
737	798	ARCADIA	94CS5020	1468	0.438
738	81	EDROY	94CS6980	201	0.438
739	792	RODD FIELD	94CS2190	2779	0.438
740	925	HIGHWAY 9	94CS6780	760	0.437
741	691	ZAPATA	94LA8300	2034	0.436
742	293	ODEM	94CS375	1082	0.435
743	311	COMSTOCK	94LA230	184	0.435
744	N/A	MESQUITE	94SB8340	753	0.433
745	232	NORTH ALAMO	94SB3580	848	0.430
746	322	LAREDO PLANT	94LA8745	758	0.430
747	1017	EAST HARRISON	94SB4310	1187	0.429
748	779	ARCADIA	94CS5030	1581	0.425
749	885	AB VOGEL ST	97AB4410	775	0.425
750	426	GEORGE WEST	94CN730	923	0.421
751	1036	SA AVENUE N	97SA1695	1462	0.421
752	538	EOLA	97SA4950	237	0.418
753	934	NORTH WESLACO	94SB4810	1487	0.416
754	852	MAGRUDER	94CN7690	553	0.414
755	864	STADIUM	94LA7810	1596	0.413
756	443	TAFT	94CS5230	830	0.412
757	920	AIRLINE	94CS9605	713	0.410
758	917	ANNA STREET	94LA900	2833	0.408
759	331	HIGHWAY 9	94CS6730	541	0.405
760	161	QUANAH	97AB3100	547	0.404
761	674	MOORE FIELD	94SB3110	651	0.404
762	32	LA GRULLA	94SB5110	989	0.403
763	903	SA AVENUE N	97SA1730	795	0.401

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIFI Ranking	2017 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIFI Value
764	705	SHARYLAND	94SB5105	1759	0.400
765	832	NORTH EDINBURG	94SB3810	1264	0.400
766	1020	SANTO NINO	94LA80	1887	0.397
767	848	WESLACO UNIT	94SB8610	1150	0.395
768	1030	CARRIZO SPRINGS	94LA750	600	0.392
769	699	AB SHELTON ST	97AB3050	647	0.391
770	271	BRYANTS RANCH	97SA205	18	0.389
771	843	CARRIZO SPRINGS	94LA910	873	0.387
772	20	FULTON	94CS2020	1674	0.387
773	183	CITRUS CITY	94SB7985	1131	0.386
774	175	FALFURRIAS	94LA1070	984	0.386
775	215	BRACKETTVILLE	94LA8460	1164	0.385
776	740	WESLACO UNIT	94SB9805	2131	0.384
777	915	WASHINGTON STREET	94LA6525	2081	0.381
778	430	HEIGHTS	94LA2450	2064	0.379
779	323	GRAYBACK	97AB3315	45	0.378
780	N/A	MESQUITE	94SB2900	907	0.377
781	94	LULING - LCRA	94CN20	284	0.377
782	617	RUSSEK STREET	97SA11370	202	0.376
783	1153	AB EAST 12KV	97AB4820	1140	0.375
784	350	PORT LAVACA	94CN2480	1544	0.374
785	715	CRYSTAL CITY	94LA2170	723	0.372
786	999	SA SOUTH	97SA4255	871	0.372
787	130	REFUGIO	94CN1170	828	0.370
788	766	ASHERTON	94LA2670	87	0.368
789	991	EAST HARRISON	94SB3080	420	0.367
790	540	CLYDE	97AB1755	131	0.366
791	387	INGLESIDE CITY	94CS2495	254	0.366
792	829	JOURDANTON	94LA5695	312	0.365
793	309	FRIO	94LA2270	595	0.363
794	1056	HOLLY	94CS9675	1783	0.362
795	551	BUENA VISTA	94LA9385	1956	0.361
796	801	MERKEL	97AB1890	582	0.361
797	738	MATHIS	94CS340	1363	0.359
798	348	JOURDANTON	94LA880	932	0.355
799	565	CHARLOTTE	94LA2790	198	0.354
800	781	THREE RIVERS	94CN2010	309	0.353
801	165	PALACIOS	94CN6830	818	0.352
802	17	BEEVILLE	94CN8090	1362	0.352
803	899	HARLINGEN SWITCH	94SB4090	2310	0.351
804	457	INGLESIDE CITY	94CS8060	2243	0.350
805	153	ESCONDIDO	94LA3350	475	0.349
806	783	NORTH WESLACO	94SB4830	524	0.349
807	1149	AB ELM CREEK	97AB1815	374	0.348
808	1018	MARFA	97SA1905	1111	0.346
809	988	GONZALES	97SA14685	1065	0.345
810	409	NORTH VICTORIA	94CN1580	1019	0.342
811	773	COTULLA	94LA90	1057	0.342

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIFI Ranking	2017 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIFI Value
812	449	ROUNDTOP	97AB4490	50	0.340
813	601	UNIVERSITY	94LA950	2483	0.338
814	249	VERHALEN	97SA4460	74	0.338
815	727	RACHAL	94LA6595	330	0.336
816	433	UVALDE	94LA540	1204	0.336
817	661	GARCENO	94SB2165	1960	0.334
818	397	CAMPWOOD	94LA3430	111	0.333
819	1175	SA CONCHO	97SA1725	24	0.333
820	470	SANTA RITA	97SA1135	9	0.333
821	880	HALL ACRES ROAD	94SB4895	865	0.333
822	606	MINES ROAD	94LA3680	1151	0.333
823	839	EL CAMPO	94CN5745	902	0.331
824	782	RULE	97AB3378	106	0.330
825	793	SA LAKE DR	97SA5865	1027	0.330
826	992	SINTON	94CS1750	501	0.329
827	957	MATHIS	94CS1410	420	0.329
828	762	RUNGE	94CN3250	266	0.323
829	1114	POLK AVENUE	94SB4180	1297	0.321
830	135	WOOLRIDGE	94CS1170	1991	0.319
831	681	CAMPWOOD	94LA2610	959	0.316
832	649	MAGRUDER	94CN6700	1357	0.315
833	428	ENCINAL	94LA2160	232	0.315
834	970	RAYMONDVILLE #1	94SB800	725	0.314
835	1125	NORTH MCALLEN	94SB3830	1360	0.314
836	494	SHARYLAND	94SB5635	2206	0.310
837	16	NIXON	94CN2025	507	0.308
838	722	RAYMONDVILLE #1	94SB3130	274	0.307
839	707	ABILENE PLANT	97AB1570	659	0.305
840	343	RIO GRANDE CITY	94SB3230	2577	0.303
841	796	TANKERSLY (CVEC)	97SA5265	367	0.302
842	246	HOLLY	94CS7740	2204	0.302
843	363	RIO BRAVO	94LA5	699	0.299
844	491	HEIGHTS	94LA2100	1958	0.298
845	164	VICTORIA POWER PLANT	94CN8170	806	0.297
846	308	ARCADIA	94CS1360	1481	0.295
847	574	GATEWAY	94LA390	3044	0.294
848	692	PAULANN	97SA6280	425	0.294
849	972	COTULLA	94LA460	521	0.294
850	75	PHARR	94SB1620	2696	0.293
851	907	SOUTH MISSION	94SB3620	1982	0.293
852	129	PAWNEE (STEC OWNED)	94CN22202	199	0.291
853	923	CLYDE	97AB3630	565	0.290
854	830	SA SOUTH	97SA3995	1378	0.287
855	912	MATHIS	94CS1420	897	0.284
856	506	MOCKINGBIRD	94CN305	311	0.283
857	757	AB SHELTON ST	97AB3060	1574	0.282
858	453	AB SHELTON ST	97AB4640	651	0.281
859	846	EDITH HUMBLE	97SA6170	82	0.280

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIFI Ranking	2017 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIFI Value
860	393	ALPINE 12KV	97SA6825	1920	0.278
861	196	HOMEPORT	94CS4665	435	0.276
862	276	LEARY LANE	94CN7530	3032	0.275
863	78	BOBCAT HILLS	97SA6655	22	0.273
864	678	LA GRULLA	94SB4120	1422	0.272
865	813	MAGRUDER	94CN6680	691	0.272
866	1171	ZACATE CREEK	94LA2675	1208	0.272
867	189	UVALDE	94LA550	704	0.271
868	666	PUEBLO	94LA95	1205	0.270
869	768	ANSON REA (SEC)	97AB5215	245	0.269
870	752	AB OVER STREET 12KV	97AB1645	796	0.269
871	490	YORKTOWN	94CN8380	783	0.268
872	1140	SA WALNUT ST	97SA3910	154	0.266
873	806	HIDALGO	94SB3400	887	0.266
874	533	CLARKWOOD	94CS7610	106	0.264
875	190	MCKENZIE ROAD	94CS330	2393	0.264
876	230	REFUGIO	94CN1210	178	0.264
877	702	LANTANA	94CS4095	197	0.264
878	775	GEORGE WEST	94CN1320	710	0.262
879	446	SOUTH EAST EDINBURG	94SB4570	1389	0.261
880	247	HEARN ROAD	94CS9665	682	0.261
881	954	CROWELL	97AB3980	488	0.260
882	840	CHARLOTTE	94LA1960	502	0.259
883	753	VERNON CITY PLANT	97AB5775	817	0.258
884	888	ROCKPORT	94CS5940	43	0.256
885	820	SA JACKSON ST	97SA4260	665	0.253
886	822	LA GRULLA	94SB5005	1157	0.252
887	184	AB MCMURRY	97AB3245	794	0.252
888	432	WEST MCALLEN	94SB4505	1873	0.251
889	759	YORKTOWN	94CN8420	663	0.250
890	827	CHILDRESS 69	97AB1800	540	0.250
891	48	ODEM	94CS385	419	0.248
892	744	GOODWIN	94SB4390	415	0.248
893	947	NORTH VICTORIA	94CN1470	464	0.248
894	221	JUNCTION	97SA4340	784	0.247
895	1039	CONTINENTAL	94SB4880	73	0.247
896	149	BAY CITY	94CN2700	1080	0.244
897	578	IRAAN	97SA2050	185	0.243
898	811	STADIUM	94LA6950	536	0.243
899	454	WESMER	94SB1850	1403	0.242
900	865	NORTH VICTORIA	94CN7770	838	0.240
901	945	SOUTH MISSION	94SB4650	1014	0.238
902	85	WEST OSO	94CS9095	1603	0.236
903	458	HEIGHTS	94LA2390	1706	0.235
904	754	RUSSEK STREET	97SA250	154	0.234
905	1080	UNIVERSITY	94LA920	691	0.233
906	346	BISHOP	94CS2690	628	0.232
907	1014	MILES	97SA4670	534	0.232

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIFI Ranking	2017 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIFI Value
908	614	PLEASANTON	94LA2080	1637	0.232
909	554	COLLEGE HILLS	97SA6145	714	0.231
910	873	CHILLICOTHE	97AB4525	117	0.231
911	113	BRUNI	94LA1100	600	0.228
912	1035	CLYDE	97AB3635	714	0.227
913	924	LEARY LANE	94CN1430	1667	0.227
914	1052	HALL ACRES ROAD	94SB9595	1468	0.225
915	765	DEL MAR	94LA7930	1469	0.225
916	378	BEEVILLE	94CN490	964	0.225
917	560	MILO	94LA8365	1855	0.223
918	935	SOUTH MISSION	94SB3940	846	0.222
919	297	PUTNAM	97AB2131	127	0.220
920	620	AILEEN	97AB4605	760	0.218
921	1102	CHILDRESS 20TH ST	97AB5725	664	0.218
922	951	MINES ROAD	94LA3745	1891	0.218
923	690	AB MCMURRY	97AB4510	831	0.217
924	971	SHARYLAND	94SB2020	2412	0.216
925	866	MERTZON (CVEC)	97SA1530	331	0.215
926	340	DEL RIO CITY	94LA440	1103	0.211
927	408	PECAN BAYOU	97AB530	19	0.211
928	623	PALMVIEW	94SB6790	1855	0.210
929	541	PHARR	94SB1625	1711	0.209
930	568	THROCKMORTON	97AB2090	67	0.209
931	658	PORT ISABEL S.S.	94SB3760	711	0.208
932	1051	HAROLD	97AB3055	29	0.207
933	282	HIGHWAY 9	94CS9830	150	0.207
934	937	AB OIL MILL	97AB2785	248	0.206
935	473	SA NORTH	97SA3130	234	0.205
936	106	UVALDE	94LA9770	1521	0.204
937	632	NORTH VICTORIA	94CN7430	1691	0.204
938	855	LEARY LANE	94CN6005	1376	0.203
939	1015	AB ELM CREEK	97AB1820	94	0.202
940	686	ZACATE CREEK	94LA2635	977	0.202
941	922	EDNA	94CN5775	507	0.201
942	434	ROBERT LEE	97SA4125	264	0.201
943	566	MCCAMEY	97SA3670	369	0.201
944	548	CHOKE CANYON	94CN5390	410	0.200
945	1044	AB CANYON ROCK	97AB5030	861	0.197
946	N/A	FRIO	94LA1815	1074	0.197
947	975	SA COKE ST	97SA4910	1721	0.196
948	534	MOCKINGBIRD	94CN370	47	0.191
949	901	EAGLE PASS CITY	94LA2650	1353	0.190
950	1074	HEIGHTS	94LA6820	1895	0.189
951	800	DEL MAR	94LA490	790	0.189
952	1166	AB EAST 12KV	97AB4825	425	0.188
953	570	JUNCTION	97SA4335	789	0.186
954	995	ROARING SPRINGS	97AB2065	221	0.186
955	324	ROMA	94SB3060	1549	0.183

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIFI Ranking	2017 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIFI Value
956	778	LEARY LANE	94CN1540	794	0.180
957	N/A	PUEBLO	94LA9870	1346	0.179
958	1100	ABILENE PLANT	97AB1910	257	0.179
959	952	PADUCAH CITY	97AB1930	570	0.179
960	771	SA NORTH	97SA3125	1242	0.179
961	321	TYNAN	94CS4000	28	0.179
962	503	MORRIS STREET	94CS8850	417	0.177
963	1084	AB SHELTON ST	97AB3660	649	0.177
964	610	GREGORY	94CS2420	839	0.176
965	87	VICTORIA POWER PLANT	94CN8070	614	0.173
966	418	PECAN BAYOU	97AB6815	1502	0.172
967	1033	AB ELM CREEK	97AB1810	846	0.171
968	996	BALLINGER	97SA4395	531	0.171
969	815	THROCKMORTON	97AB3190	609	0.171
970	807	COLUMBUS	94CN930	922	0.169
971	1024	SIERRA VISTA	94LA3540	899	0.169
972	974	AB MCMURRY	97AB4350	709	0.168
973	477	MAGNOLIA	94CN315	12	0.167
974	1082	BRONTE	97SA3560	252	0.167
975	993	SAN BENITO	94SB3910	1780	0.166
976	122	HOLLY	94CS7620	2700	0.166
977	437	MUNDAY	97AB3365	400	0.165
978	663	HARLINGEN SWITCH	94SB4110	850	0.164
979	1001	ROMA	94SB3070	890	0.162
980	205	OZONA	97SA4185	1309	0.161
981	333	SUNCHASE	94SB1155	1459	0.161
982	416	ARANSAS PASS	94CS8280	588	0.160
983	201	ASPHALT MINES	94LA500	44	0.159
984	1081	SOUTH MCALLEN	94SB3935	985	0.158
985	114	PARKER	94CN9010	19	0.158
986	577	SIERRA VISTA	94LA9900	2132	0.157
987	62	FREER	94LA2900	160	0.156
988	535	MATHIS	94CS2870	864	0.156
989	1041	WYLIE	97AB2665	1033	0.156
990	1083	WAGGONER	97AB5900	26	0.154
991	842	AFTON	97AB2225	53	0.151
992	980	SA WALNUT ST	97SA4635	1543	0.149
993	73	DEL RIO CITY	94LA9790	2329	0.149
994	883	WASHINGTON STREET	94LA2360	218	0.147
995	313	CHRISTOVAL	97SA6620	580	0.147
996	1135	TWILIGHT TRAIL	97AB3150	726	0.145
997	736	SOUTH PADRE ISLAND	94SB4675	166	0.145
998	719	COLLEGE HILLS	97SA4835	443	0.144
999	1078	CHILDRESS 69	97AB2800	334	0.144
1000	1173	SILVER	97SA4295	14	0.143
1001	967	SPUR	97AB5170	374	0.142
1002	633	WYLIE	97AB6495	316	0.139
1003	400	PADUCAH CITY	97AB1935	282	0.138

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIFI Ranking	2017 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIFI Value
1004	166	HEIGHTS	94LA9400	1384	0.138
1005	853	HARLINGEN	94SB370	1197	0.137
1006	1025	BALLINGER	97SA4375	1039	0.136
1007	672	CHARLOTTE	94LA8120	214	0.136
1008	1091	AB MAPLE ST	97AB4070	15	0.133
1009	22	FULTON	94CS440	1910	0.131
1010	717	SOUTH EAST EDINBURG	94SB4015	451	0.131
1011	1068	KEPLER	94CS1700	23	0.130
1012	18	WOODSBORO	94CS8330	287	0.129
1013	1046	AB HARTFORD ST	97AB3820	921	0.128
1014	1131	ZAPATA	94LA7330	1342	0.127
1015	802	WEST HARLINGEN	94SB3800	1385	0.127
1016	687	SANTA RITA	97SA1100	112	0.125
1017	1117	SA SOUTHLAND HILLS	97SA5050	891	0.123
1018	928	QUANAH	97AB3530	333	0.123
1019	1157	SA JACKSON ST	97SA4695	561	0.123
1020	1137	UNIVERSITY	94LA465	862	0.122
1021	361	STADIUM	94LA7800	675	0.121
1022	563	RODD FIELD	94CS245	2845	0.121
1023	332	HOLLY	94CS1220	3337	0.120
1024	217	AB DYESS 2	97AB6335	358	0.120
1025	1054	BALLINGER	97SA4370	816	0.120
1026	596	ANNA STREET	94LA780	475	0.120
1027	511	ANSON 12KV	97AB6630	693	0.120
1028	1133	COLLEGE HILLS	97SA4840	210	0.119
1029	239	EAGLE PASS CITY	94LA450	950	0.118
1030	653	RODD FIELD	94CS1730	2182	0.118
1031	329	BERCLAIR	94CN990	209	0.115
1032	981	NORTH MCALLEN	94SB9660	2000	0.115
1033	1130	SA LAKE DR	97SA5880	804	0.114
1034	441	FREER	94LA5200	1036	0.114
1035	1169	AB EAST 12KV	97AB4830	607	0.114
1036	349	FT DAVIS	97SA4515	982	0.113
1037	564	BEN FICKLIN	97SA6185	565	0.112
1038	716	ALICE	94LA1790	467	0.111
1039	469	WYLIE	97AB2675	801	0.111
1040	1106	JOSLIN POWER PLANT	94CN8720	18	0.111
1041	869	SOUTH MISSION	94SB5215	1245	0.111
1042	942	SA JACKSON ST	97SA4690	1124	0.109
1043	708	HALL ACRES ROAD	94SB5465	1402	0.109
1044	N/A	LAS CRUSES	94LA7325	1719	0.108
1045	1124	MAYBERRY	94SB3010	93	0.108
1046	496	HIGHWAY 9	94CS7200	659	0.106
1047	504	HAMLIN	97AB3270	879	0.106
1048	1164	COLLEGE HILLS	97SA5520	436	0.106
1049	559	HIGHWAY 9	94CS7210	353	0.105
1050	850	AB HARTFORD ST	97AB3815	1108	0.105
1051	176	AB MCMURRY	97AB3240	763	0.104

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIFI Ranking	2017 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIFI Value
1052	471	RAYMONDVILLE #2	94SB4160	339	0.103
1053	640	MAYBERRY	94SB5770	812	0.102
1054	1063	KNOX CITY	97AB3300	471	0.102
1055	805	MAGRUDER	94CN6690	748	0.102
1056	1148	ROWENA	97SA4480	218	0.101
1057	1190	JOSLIN POWER PLANT	94CN7915	10	0.100
1058	625	PORTLAND	94CS9370	2052	0.099
1059	784	GOVERNMENT WELLS	94LA7250	556	0.095
1060	517	PORT LAVACA	94CN6850	683	0.095
1061	697	WEST OSO	94CS9085	900	0.094
1062	1067	SA EMERSON ST	97SA4620	435	0.094
1063	1098	OZONA	97SA3810	620	0.092
1064	1066	SANTO NINO	94LA695	1592	0.091
1065	896	PONDER KENNEDY	97SA50208	11	0.091
1066	1118	GIRARD	97AB6260	44	0.091
1067	366	MCCAMEY	97SA2855	78	0.090
1068	1120	SA NORTH	97SA3120	1108	0.089
1069	550	SANTA ANNA	97SA3420	359	0.089
1070	1105	HEIGHTS	94LA9080	685	0.089
1071	1009	PAINT ROCK	97SA1110	68	0.088
1072	1000	HIGHLAND	97SA6370	517	0.087
1073	208	MCKENZIE ROAD	94CS150	23	0.087
1074	875	NORDHEIM	94CN3380	173	0.087
1075	1147	HAMLIN	97AB3775	245	0.086
1076	1103	TWILIGHT TRAIL	97AB4285	1141	0.085
1077	1048	SANTA ANNA	97SA3415	331	0.085
1078	98	IRAAN	97SA2055	536	0.084
1079	824	AB ELMDALE	97AB4520	256	0.082
1080	1069	SA JACKSON ST	97SA4685	1415	0.081
1081	1128	AB REBECCA LANE	97AB6915	999	0.080
1082	1073	DEL MAR	94LA10	1859	0.079
1083	225	SA WALNUT ST	97SA3920	886	0.079
1084	1160	SA CONCHO	97SA1705	901	0.078
1085	987	SANTO NINO	94LA70	1164	0.077
1086	180	AB MCMURRY	97AB3235	796	0.077
1087	1059	AFTON	97AB2310	242	0.074
1088	636	MILO	94LA3070	2812	0.072
1089	420	TYNAN	94CS4010	42	0.071
1090	403	WEINERT	97AB6490	127	0.071
1091	1119	AB ELMDALE	97AB4085	43	0.070
1092	1187	CASA BLANCA	94CS5440	134	0.067
1093	1043	SANTO NINO	94LA75	1491	0.067
1094	1126	AIRLINE	94CS5870	917	0.067
1095	921	COLUMBUS	94CN6180	470	0.066
1096	482	AB EAST 12KV	97AB5760	229	0.066
1097	929	SAND ROAD	97AB5195	247	0.065
1098	1172	PAULANN	97SA6310	1021	0.065
1099	748	SONORA ATLANTIC (SWTEC)	97SA4415	31	0.065

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIFI Ranking	2017 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIFI Value
1100	969	ROCHESTER	97AB3295	218	0.064
1101	N/A	PEARSALL	94LA9905	402	0.062
1102	435	BROOKHOLLOW	94CN7580	502	0.062
1103	537	ABILENE PLANT	97AB1565	279	0.061
1104	828	ROCKSPRINGS	94LA8040	347	0.061
1105	919	SA WALNUT ST	97SA3925	882	0.059
1106	456	WOOLRIDGE	94CS1110	1733	0.059
1107	1061	RANKIN	97SA6400	69	0.058
1108	585	AB SHELTON ST	97AB3040	173	0.058
1109	1155	AB VOGEL ST	97AB4650	797	0.058
1110	1050	MATADOR	97AB3090	313	0.058
1111	1003	VERNON	97AB5000	246	0.057
1112	1097	AB MCMURRY	97AB4360	1087	0.056
1113	536	HAINE DRIVE	94SB9700	1078	0.056
1114	1108	RUSSEK STREET	97SA12295	310	0.055
1115	1146	SA AVENUE N	97SA1655	489	0.053
1116	761	KNOX CITY	97AB3390	363	0.052
1117	N/A	SIERRA VISTA	94LA8205	921	0.052
1118	911	BENJAMIN (BEPC)	97AB5680	155	0.052
1119	1049	AB ELM CREEK	97AB4745	958	0.051
1120	451	AB VOGEL ST	97AB4560	1474	0.051
1121	1151	KEPLER	94CS2665	41	0.049
1122	586	AB SHELTON ST	97AB3435	313	0.048
1123	908	ESCONDIDO	94LA3775	167	0.048
1124	968	AB ELM CREEK	97AB4780	533	0.047
1125	605	KENEDY	94CN1960	64	0.047
1126	1021	BAIRD	97AB5120	440	0.045
1127	1058	KNOX CITY	97AB3985	22	0.045
1128	519	LAREDO PLANT	94LA8695	1346	0.045
1129	1174	SA CONCHO	97SA3325	47	0.043
1130	1185	KNIPPA	94LA6535	24	0.042
1131	1182	LA GRULLA	94SB3045	1130	0.041
1132	553	AB OVER STREET 12KV	97AB1635	519	0.040
1133	1047	BROOKHOLLOW	94CN7190	281	0.039
1134	1076	SA SOUTH	97SA3990	738	0.038
1135	836	BLUFFS	97SA7280	1483	0.038
1136	680	SAN BENITO	94SB3860	240	0.038
1137	1109	FT DAVIS	97SA3345	430	0.037
1138	203	SA SOUTH	97SA2595	970	0.036
1139	569	SA MATHIS FIELD	97SA5100	225	0.036
1140	1027	AB HARTFORD ST	97AB3690	171	0.035
1141	584	CAUSEWAY	94SB4775	1057	0.035
1142	510	TRUSCOTT	97AB3845	29	0.034
1143	1129	SA SOUTHLAND HILLS	97SA5860	1190	0.034
1144	1113	SA WALNUT ST	97SA3915	779	0.033
1145	64	HAMILTON ROAD	94LA9645	303	0.033
1146	411	SKIDMORE	94CS380	158	0.032
1147	984	PAINT ROCK	97SA5235	129	0.031

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIFI Ranking	2017 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIFI Value
1148	590	AB REBECCA LANE	97AB5555	1263	0.031
1149	527	HIDALGO	94SB3680	326	0.031
1150	902	WASHINGTON STREET	94LA6355	978	0.031
1151	244	VERNON CITY PLANT	97AB5770	98	0.031
1152	1144	BRONTE	97SA4160	210	0.029
1153	1093	MATADOR	97AB3030	213	0.028
1154	137	VALENTINE	97SA5590	216	0.028
1155	1167	SA SOUTH	97SA3500	293	0.027
1156	1189	KENEDY S.S.	94CN8320	147	0.027
1157	726	PLASTERCO (MWEC)	97AB2720	113	0.027
1158	1065	AB REBECCA LANE	97AB5550	718	0.025
1159	1150	AB REBECCA LANE	97AB2710	263	0.023
1160	1028	ESCONDIDO	94LA1510	729	0.022
1161	1159	JAYTON	97AB6125	352	0.020
1162	1064	ABILENE PLANT	97AB1915	61	0.016
1163	637	ROBY	97AB2276	314	0.016
1164	946	PAULANN	97SA6285	63	0.016
1165	214	AB SHELTON ST	97AB3045	555	0.014
1166	1179	AB ELM CREEK	97AB1825	217	0.014
1167	148	VALERA HUMBLE	97SA7015	75	0.013
1168	582	AILEEN	97AB6435	831	0.013
1169	599	SA JACKSON ST	97SA4250	347	0.012
1170	1184	UNIVERSITY	94LA930	94	0.011
1171	124	SA CONCHO	97SA1700	498	0.010
1172	1170	COLLEGE HILLS	97SA4845	426	0.009
1173	1123	ABILENE PLANT	97AB3175	115	0.009
1174	1088	HIGHLAND	97SA6375	267	0.007
1175	1134	AB OIL MILL	97AB3895	139	0.007
1176	1168	SA CONCHO	97SA1715	286	0.007
1177	1111	SA AVENUE N	97SA1975	327	0.006
1178	1127	AB HARTFORD ST	97AB3685	372	0.005
1179	709	ALPINE 12KV	97SA6820	769	0.005
1180	592	COLLEGE HILLS	97SA5515	350	0.003
1181	960	CLARKWOOD	94CS2170	545	0.002
1182	31	RANKIN	97SA6405	391	0.000
1183	107	CHASE FIELD	94CN460	14	0.000
1184	237	IRAAN	97SA4305	76	0.000
1185	274	BARNHART	97SA590	20	0.000
1186	445	TALPA ATLANTIC	97SA5180	66	0.000
1187	600	PEACOCK	97AB1375	47	0.000
1188	628	BLUFFS	97SA3005	239	0.000
1189	799	ESPY WELLS	97SA50207	29	0.000
1190	983	SWENSON	97AB136	32	0.000
1191	1070	MAYBERRY	94SB5340	35	0.000
1192	1107	SA COKE ST	97SA4915	17	0.000
1193	1132	MAYBERRY	94SB6450	27	0.000
1194	1156	AB CANYON ROCK	97AB5025	51	0.000
1195	1180	ABILENE PLANT	97AB1740	18	0.000

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIFI Ranking	2017 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIFI Value
1196	1183	WASHINGTON STREET	94LANETLAR	163	0.000
1197	1186	MORRIS STREET	94CSNET CC	317	0.000
1198	1188	VICTORIA POWER PLANT	94CNNETVIC	88	0.000
1199	N/A	LAS CRUSES	94LA8530	118	0.000
1200	N/A	SANTA RITA	97SA1140	10	0.000

Feeders from last year that are not in this year's list

2017 Ranking	Substation Identification	Feeder ID	Reason not in 2018
595	KEMPER EXXON HUMBLE	97SA1490	Retired
667	PEARSALL	94LA3675	Count is now less than 10
710	RANGERVILLE	94SB4060	Count is now less than 10
481	RANGERVILLE	94SB3420	Count is now less than 10

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

Total Number of Feeders

With 10 or more Customers

1200

Add or Delete Rows as Necessary

AEP Texas Inc.

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
1	70	ALPINE 12KV	97SA3875	536	4,208.9
2	48	RAYMONDVILLE #2	94SB3250	28	1,595.0
3	50	SPUDDER FLAT	97SA4180	45	1,595.0
4	295	PREMONT	94LA2730	148	1,012.4
5	196	TATTON	94CS8200	1,060	1,006.2
6	605	TATTON	94CN8490	329	962.9
7	411	PECOS VALLEY	97SA4080	126	945.3
8	6	SUN VALLEY	97SA4300	64	905.0
9	506	TAFT	94CS1260	179	886.0
10	589	RIO RICO	94SB8330	444	864.1
11	65	WOODSON OIL FIELD	97AB30	33	863.1
12	37	ALAZAN	94CS620	167	829.6
13	328	GREENLAKE	94CN2740	363	805.7
14	256	RANDADO	94LA8360	172	764.2
15	85	MCELROY	97SA5165	124	757.7
16	126	BANQUETTE	94CS9000	453	742.2
17	961	SAN BENITO	94SB4135	1,272	741.1
18	241	SHROPSHIRE	94CN3575	33	739.6
19	437	JOURDANTON	94LA5685	351	715.5
20	698	CONTINENTAL	94SB4080	65	713.5
21	861	MUSTANG ISLAND	94CS9470	678	699.6
22	285	GOVERNMENT WELLS	94LA6800	225	694.4
23	193	MATTHEWS	94CN1740	158	694.3
24	964	RODD FIELD	94CS3010	1,996	687.4
25	137	MCCAMEY	97SA2415	157	686.5
26	788	BLESSING	94CN8780	62	684.6
27	22	GRETA	94CN7890	259	681.9
28	1114	MUSTANG ISLAND	94CS8510	453	676.8
29	782	ALICE	94LA2530	1,453	659.6
30	46	GOVERNMENT WELLS	94LA7240	225	645.4
31	279	RAYMONDVILLE #1	94SB620	642	644.0
32	257	ARMSTRONG	94CS6050	81	636.7
33	56	FOSTER FIELD	94CN2550	54	630.8
34	254	FOSTER FIELD	94CN8880	293	628.0
35	896	ALICE	94LA2540	1,002	623.7
36	1153	SHEFFIELD	97SA6430	227	622.7
37	119	CABANISS	94CS80	1,312	618.7
38	89	RIO RICO	94SB5050	1,798	617.8
39	553	BLESSING	94CN1030	286	610.6
40	24	CRESTONIO	94LA270	627	605.7
41	1091	PRAIRIE PUMP	94CN1940	78	601.9
42	163	RIO RICO	94SB8290	428	593.3
43	233	SEAWALL	94CS9420	714	592.0
44	261	THREE RIVERS	94CN8430	192	589.8
45	435	CRESTONIO	94LA260	1,760	576.2

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
46	145	HALL ACRES ROAD	94SB3670	1,082	565.4
47	92	GREGORY	94CS5920	689	564.8
48	9	EAST HARRISON	94SB3950	632	560.8
49	565	INGLESIDE CITY	94CS6040	394	557.3
50	179	LOLITA	94CN6330	30	555.8
51	1015	MILO	94LA3065	210	555.5
52	116	ALBANY	97AB2029	235	554.7
53	153	LOS FRESNOS	94SB4315	1,093	551.0
54	249	ARCADIA	94CS8570	1,447	547.9
55	121	PORT ARANSAS	94CS1000	1,981	547.6
56	442	KITTIE WEST	94CN3765	318	546.5
57	41	LAGUNA	94CS9590	2,284	545.1
58	18	PORT LAVACA	94CN8310	354	537.6
59	603	GOLIAD	94CN8220	1,043	536.7
60	467	AIRLINE	94CS7280	645	535.0
61	175	MEDIO CREEK	94CN1380	769	534.2
62	339	ANNA STREET	94LA850	1,572	530.8
63	956	MUNDAY REA (BKEC)	97AB2015	21	526.9
64	641	EAGLE LAKE	94CN320	638	523.7
65	303	CLARKWOOD	94CS7220	864	521.3
66	27	SANTA RITA	97SA1105	73	518.3
67	649	O CONNER	94CN390	200	518.0
68	95	LA GRULLA	94SB6150	1,537	512.2
69	172	PETTUS	94CN1020	459	505.2
70	10	ELSA	94SB710	2,100	487.7
71	25	MAYO	94CS625	203	484.6
72	1024	MORRIS STREET	94CS8840	651	483.0
73	57	RANDADO	94LA8350	135	467.6
74	414	CARRIZO SPRINGS	94LA370	545	466.7
75	32	MASTERSON FIELD	97SA800	194	465.4
76	661	ASHERTON	94LA2660	628	461.8
77	367	POLK AVENUE	94SB4520	939	454.5
78	236	MCKENZIE ROAD	94CS140	278	452.2
79	140	PETTUS	94CN8210	333	450.5
80	2	CONOCO-CHITTAM RANCH	94LA8580	25	446.8
81	461	WADSWORTH	94CN8630	673	445.5
82	248	WEST MCALLEN	94SB4965	923	442.9
83	901	MARKHAM	94CN6440	460	442.1
84	325	ALBANY	97AB3540	622	440.4
85	120	FREER	94LA1500	205	436.8
86	204	NAVAL BASE	94CS7950	329	431.8
87	49	MALONE	94CN7560	117	427.2
88	498	HARLINGEN SWITCH	94SB4230	1,335	425.5
89	836	CHILDRESS 69	97AB1480	292	418.8
90	178	BIG OAK	94CN420	151	416.0
91	1178	TRENT	97AB2850	28	414.6
92	345	CLARKWOOD	94CS7230	613	412.5
93	58	RANGERVILLE	94SB3410	202	409.5
94	700	CATARINA	94LA2380	200	409.2
95	139	PREMONT	94LA6570	761	405.4

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
96	690	WESMER	94SB4480	1,119	401.7
97	101	ELDORADO	97SA2880	342	401.6
98	676	COTULLA	94LA610	744	400.2
99	596	SAN DIEGO	94LA1980	595	400.0
100	356	RAYMONDVILLE #1	94SB630	792	395.5
101	26	LA PRYOR	94LA570	151	390.5
102	464	BROWNSVILLE	94SB3050	1,979	385.1
103	383	SARAGOSA	97SA1590	79	384.8
104	552	THREE RIVERS	94CN5100	66	380.8
105	7	LA PRYOR	94LA580	238	380.1
106	71	SHROPSHIRE	94CN1240	67	379.6
107	995	PAISANO	97SAPAISAN	136	375.8
108	950	ALPINE 12KV	97SA3160	1,085	374.8
109	508	NORTH MERCEDES	94SB3840	652	374.6
110	1146	ROTAN	97AB1865	191	370.1
111	539	ELDORADO	97SA1845	772	369.4
112	333	MCCOLL ROAD	94SB2810	2,671	368.5
113	541	SINTON	94CS6860	1,658	367.8
114	199	QUANAH	97AB100	90	367.6
115	815	UNIVERSITY	94LA305	2,089	366.7
116	697	SOUTH EAST EDINBURG	94SB5045	2,219	364.9
117	327	LYTLE	94LA2850	708	360.9
118	813	ANNA STREET	94LA2250	1,543	357.8
119	1124	FT CHADBOURNE	97SA6515	91	357.2
120	486	CLARKWOOD	94CS5525	663	356.4
121	1143	POINT COMFORT	94CN6060	367	355.9
122	858	MUNDAY	97AB6715	249	348.2
123	389	CASA BLANCA	94CS1300	282	346.0
124	457	SONORA 138 SUB	97SA4810	898	345.9
125	1032	HAINE DRIVE	94SB9240	38	345.4
126	160	MORAN	97AB2107	220	343.7
127	110	PHARAOH	94CS1365	690	339.6
128	76	RAYMONDVILLE #2	94SB3170	737	339.5
129	296	LAREDO PLANT	94LA9305	1,047	339.0
130	40	PECOS VALLEY	97SA4075	21	338.2
131	99	BIG WELLS	94LA1570	436	337.5
132	594	KLEBERG	94CS280	1,306	337.5
133	281	HOLCOMB	94LA2240	451	336.8
134	189	CABANISS	94CS240	1,548	335.7
135	3	VERHALEN	97SA4465	14	334.4
136	801	SABINAL	94LA485	492	334.2
137	580	RIO PECOS	97SA3835	126	333.6
138	699	KLEBERG	94CS1560	1,440	329.6
139	957	PALMHURST	94SB3890	2,660	327.9
140	260	GOLIAD	94CN6540	1,201	326.9
141	885	STADIUM	94LA8540	1,574	326.7
142	297	CASA BLANCA	94CS4170	1,044	323.9
143	418	TRENT	97AB4245	181	320.4
144	274	SEAWALL	94CS9450	291	319.3
145	572	BAY CITY	94CN5960	2,115	319.1

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
146	745	ROCKPORT	94CS5930	1,312	316.1
147	370	KENEDY	94CN1970	568	315.7
148	33	BIG WELLS	94LA2630	29	315.2
149	360	GILA	94CS345	68	314.3
150	88	LAREDO PLANT	94LA8565	1,681	313.6
151	1003	ALPINE 12KV	97SA3155	1,139	312.4
152	511	CITRUS CITY	94SB5070	914	311.8
153	240	ALBANY	97AB3640	326	310.8
154	52	TATTON	94CS950	464	309.9
155	686	QUANAH	97AB1830	611	308.0
156	142	GREENLAKE	94CN2760	1,160	307.5
157	938	GREGORY	94CS420	453	306.2
158	N/A	JOURDANTON	94LA7880	584	303.8
159	566	TUSCOLA	97AB3730	1,381	303.6
160	134	TAFT	94CS1180	973	301.6
161	155	ELSA	94SB3500	1,242	300.8
162	550	ARANSAS PASS	94CS9130	367	299.3
163	374	CROSS PLAINS	97AB2915	759	297.3
164	976	WEST MCALLEN	94SB4555	1,664	295.0
165	931	WESMER	94SB6900	1,626	294.7
166	394	MIDWAY LANE	97SA3440	62	294.0
167	106	BLESSING	94CN8790	768	293.2
168	154	FULTON	94CS6070	3,282	292.3
169	663	CITRUS CITY	94SB6000	2,177	291.5
170	796	WEST MCALLEN	94SB4515	877	290.0
171	399	EL GATO	94SB720	2,450	289.8
172	1112	EDEN	97SA3195	517	289.8
173	12	INDIAN MESA	97SA2695	169	288.9
174	742	BRADY	97SA5015	200	288.4
175	701	NORTH EDINBURG	94SB560	2,120	285.9
176	584	MCCOLL ROAD	94SB4400	1,422	284.8
177	1152	KIRKLAND	97AB3545	29	284.6
178	287	PALACIOS	94CN8550	46	284.1
179	463	ALBANY	97AB3655	627	283.6
180	422	HOLLY	94CS1950	819	282.4
181	766	HUMBLE KEMPER	97SA72103	27	282.2
182	613	HARLINGEN	94SB360	2,456	282.0
183	263	PORT ISABEL S.S.	94SB3820	183	279.5
184	16	CROSS PLAINS	97AB2920	570	279.4
185	725	CHARLOTTE	94LA2780	54	278.7
186	244	MOORE FIELD	94SB3120	162	277.4
187	174	DEL RIO CITY	94LA420	1,998	276.6
188	224	NORTH VICTORIA	94CN7440	1,603	276.1
189	575	BEEVILLE	94CN1760	1,831	276.0
190	935	GARWOOD CITY	94CN2560	195	275.0
191	234	FREISS RANCH	97SA4870	99	274.5
192	620	SA EMERSON ST	97SA4630	1,191	272.3
193	108	REFUGIO	94CN1040	167	271.3
194	967	HEARN ROAD	94CS8980	1,250	269.3
195	11	HOLCOMB	94LA3025	333	267.6

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
196	55	BRUNI	94LA5440	138	266.6
197	943	OLMITO	94SB905	1,598	266.2
198	28	LIVE OAK	94CS1090	230	264.6
199	373	MORRIS STREET	94CS2515	1,078	262.2
200	62	LULING - LCRA	94CN10	410	262.1
201	482	BEEVILLE	94CN2380	217	261.8
202	135	CRYSTAL CITY	94LA8380	1,334	261.0
203	226	MORRIS STREET	94CS8715	1,593	258.5
204	188	SOUTHSIDE	94CS8005	744	258.4
205	975	CEDAR GAP (TEC)	97AB5445	312	257.7
206	243	PREMONT	94LA6610	817	257.3
207	591	AIRLINE	94CS7270	1,026	255.5
208	632	MERTZON (CVEC)	97SA2905	584	255.5
209	465	CHRISTOVAL	97SA6615	422	254.4
210	487	WEST OSO	94CS9090	1,667	254.3
211	376	SOUTHSIDE	94CS5335	1,301	253.0
212	932	KLEBERG	94CS9395	1,283	251.8
213	157	NIXON	94CN3300	583	250.7
214	864	OZONA	97SA3555	164	250.6
215	369	TANKERSLY (CVEC)	97SA5260	463	250.3
216	634	PERKINS PROTHO	97SA3180	23	247.9
217	128	EDNA	94CN5785	1,328	247.8
218	83	ELSA	94SB700	1,464	246.9
219	195	NORTH MCCAMEy	97SA6555	502	246.5
220	705	SOUTH EAST EDINBURG	94SB6580	1,567	246.2
221	637	HEARN ROAD	94CS870	1,178	246.2
222	983	AB WALNUT ST	97AB3445	68	245.5
223	878	MORRIS STREET	94CS7625	560	245.5
224	79	WEIL TRACT (138/12KV)	94CS5405	171	245.1
225	305	NORTH MCALLEN	94SB5055	3,230	244.0
226	351	GATEWAY	94LA350	1,916	243.6
227	642	COLUMBUS	94CN9060	369	242.5
228	35	BROWNSVILLE	94SB4280	320	241.7
229	809	SA GRAPE CREEK	97SA5220	684	241.6
230	449	PALMVIEW	94SB3930	1,125	240.6
231	1038	WEST MCALLEN	94SB4595	1,190	239.0
232	156	RIO GRANDE CITY	94SB3210	1,851	238.7
233	75	SOUTH PADRE ISLAND	94SB6440	2,688	237.9
234	577	EAST HARRISON	94SB3190	1,493	237.1
235	348	HEARN ROAD	94CS8990	1,266	237.0
236	1050	HAWLEY	97AB4455	600	235.6
237	286	LIVE OAK	94CS1080	1,315	233.9
238	547	MILO	94LA5020	108	233.8
239	1010	EDNA	94CN5765	1,122	232.7
240	177	AFTON	97AB2355	45	232.4
241	436	WEIL TRACT (138/12KV)	94CS2520	155	231.0
242	659	LAREDO PLANT	94LA8505	1,007	230.4
243	304	ANNA STREET	94LA5780	669	229.7
244	53	MORAN	97AB2108	312	229.7
245	362	CAUSEWAY	94SB4765	965	229.3

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
246	337	WESMER	94SB7760	2,506	228.6
247	812	NORTH ALAMO	94SB3610	1,882	227.6
248	758	NORTH ALAMO	94SB4370	1,542	227.4
249	378	BLACK BAYOU	94CN1120	317	226.6
250	183	KNIPPA	94LA6365	324	226.3
251	309	CROSS PLAINS	97AB1795	432	225.0
252	828	FT CHADBOURNE	97SA6520	543	224.4
253	412	OLMITO	94SB4275	788	224.4
254	939	EL GATO	94SB890	2,853	222.7
255	251	MORRIS STREET	94CS8820	1,243	222.1
256	624	ROTAN	97AB1860	717	221.8
257	4	FULTON	94CS3070	1,390	221.5
258	355	HALL ACRES ROAD	94SB3460	3,108	220.0
259	149	PHARAOH	94CS1285	1,782	219.9
260	454	CABANISS	94CS75	2,205	219.9
261	171	TURKEY	97AB3825	394	219.9
262	130	ARANSAS PASS	94CS1250	620	218.8
263	270	JOURDANTON	94LA250	765	218.5
264	146	SAN BENITO	94SB3920	2,595	218.0
265	143	HAMLIN SHELL	97AB6330	25	216.8
266	507	EAGLE LAKE	94CN310	734	216.6
267	513	PARKER	94CN9260	108	216.3
268	512	VALENTINE	97SA6325	577	215.7
269	375	PLACEDO	94CN7980	424	213.5
270	232	RIO GRANDE CITY	94SB3740	2,284	212.3
271	740	YELLOW JACKET	97SA5505	532	212.1
272	104	LAGUNA	94CS9065	2,353	210.7
273	229	HEARN ROAD	94CS2220	1,644	210.5
274	144	DUNE FIELD (N CRANE)	97SA3885	74	210.4
275	198	KINGSVILLE	94CS1350	388	208.9
276	308	FALFURRIAS	94LA1080	450	208.4
277	350	SOUTHSIDE	94CS7995	1,555	208.4
278	500	FLOMOT	97AB1852	74	208.2
279	441	MALONE	94CN7550	193	208.0
280	391	PLEASANTON	94LA120	1,226	207.6
281	1137	EAGLE PASS CITY	94LA2510	578	205.6
282	653	DEL MAR	94LA3440	1,449	205.6
283	951	DEVINE	94LA7100	1,081	205.2
284	440	THREE RIVERS	94CN5190	476	205.1
285	408	SAN DIEGO	94LA2890	1,033	204.0
286	81	GILA	94CS350	142	203.9
287	219	PLEASANTON	94LA9505	1,734	203.9
288	36	STAMFORD	97AB2815	711	203.6
289	762	AB OIL MILL	97AB3900	678	203.2
290	388	COFFEE PORT	94SB1095	1,017	202.6
291	814	RAYMONDVILLE #2	94SB1280	986	202.5
292	704	HIGHWAY 9	94CS6760	1,019	202.2
293	719	SA GRAPE CREEK	97SA4700	716	201.6
294	636	NORTH PADRE ISLAND	94CS5170	1,280	201.3
295	184	ELSA	94SB3520	501	201.2

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
296	635	CARANCAHUA	94CN5870	501	200.9
297	324	HARLINGEN SWITCH	94SB320	1,544	200.8
298	1181	MCCOLL ROAD	94SB4910	340	200.3
299	504	NORTH PADRE ISLAND	94CS7900	2,258	199.5
300	272	AIRLINE	94CS7390	2,160	199.3
301	650	EAGLE PASS CITY	94LA2745	933	199.3
302	318	PORT ISABEL S.S.	94SB9295	2,268	197.8
303	797	PORT LAVACA	94CN2490	1,054	196.9
304	86	BRUNI	94LA1120	286	196.1
305	808	WEIL TRACT (138/12KV)	94CS1990	1,387	195.5
306	311	HIGHWAY 9	94CS6770	1,089	195.4
307	392	ARCADIA	94CS1400	444	194.9
308	102	WADSWORTH	94CN7660	1,407	194.6
309	395	DEVINE	94LA8100	1,659	194.2
310	15	TURKEY	97AB2980	314	194.1
311	1177	ONYX REA	97AB3255	30	193.8
312	68	SOUTHSIDE	94CS8045	1,008	193.5
313	557	BEEVILLE	94CN300	1,665	193.2
314	631	DEL MAR	94LA220	2,670	193.1
315	447	SEAWALL	94CS9325	1,438	192.9
316	217	MELVIN	97SA4955	91	192.8
317	1005	EAGLE PASS CITY	94LA7060	861	192.8
318	652	SA GRAPE CREEK	97SA5365	797	192.8
319	1074	WEST MCALLEN	94SB6385	241	192.5
320	21	ALAZAN	94CS2740	37	192.3
321	1012	RIO BRAVO	94LA300	793	191.8
322	832	KINGSVILLE	94CS1660	1,998	190.8
323	651	VILLA CAVAZOS	94SB1980	1,681	190.6
324	567	PEARSALL	94LA5580	837	190.4
325	558	NORTH MERCEDES	94SB4860	1,499	190.2
326	531	POLK AVENUE	94SB4610	1,179	189.7
327	63	GREGORY	94CS5900	103	188.8
328	381	ARCADIA	94CS1440	1,680	187.7
329	19	WOOLRIDGE	94CS1120	2,715	187.3
330	54	CLIMAX/BRADSHAW	97AB11301	67	186.4
331	428	EL CAMPO	94CN2800	821	186.2
332	480	PHARR	94SB1650	829	186.0
333	364	PALACIOS	94CN6840	1,540	185.0
334	307	MAGRUDER	94CN245	1,233	184.9
335	320	PHARAOH	94CS1185	1,638	184.0
336	335	SKIDMORE	94CS600	350	183.7
337	793	SAN BENITO	94SB4945	1,722	182.5
338	894	ROBY	97AB3795	72	182.3
339	738	SOUTH MISSION	94SB3980	2,146	181.4
340	211	RIO GRANDE CITY	94SB3220	1,357	181.1
341	13	FALFURRIAS	94LA5210	1,108	181.0
342	476	KINGSVILLE	94CS1670	412	180.0
343	301	AMISTAD DAM	94LA5450	1,250	179.5
344	159	INGLESIDE CITY	94CS8050	1,245	178.8
345	329	ARANSAS PASS	94CS660	728	178.6

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
346	517	WESLACO UNIT	94SB2195	1,071	176.4
347	1004	LAREDO PLANT	94LA8705	214	175.7
348	421	GANADO	94CN5795	487	175.4
349	573	BEEVILLE	94CN2200	750	174.7
350	669	CASA BLANCA	94CS55	853	174.5
351	258	WESLACO UNIT	94SB5970	2,439	174.1
352	180	GARCENO	94SB5490	595	174.0
353	933	SOUTHSIDE	94CS5345	401	173.2
354	208	MELVIN	97SA940	44	171.9
355	724	HASKELL 12KV	97AB3770	444	171.7
356	124	PHARR	94SB1645	2,364	171.0
357	997	GANADO	94CN5815	597	169.5
358	246	SOUTHSIDE	94CS7955	1,062	169.0
359	78	ASPR CONTINENTAL	97AB4800	33	168.6
360	N/A	NORTH MCCAMEY	97SA6560	10	168.0
361	568	HOLLY	94CS1370	1,891	167.4
362	674	HAINE DRIVE	94SB270	1,092	167.1
363	598	SOUTH SANTA ROSA	94SB1225	854	166.8
364	43	EDROY	94CS6990	283	166.8
365	739	BROOKHOLLOW	94CN8950	899	166.7
366	905	ODEM	94CS5575	68	165.8
367	658	WEAVER ROAD	94CN1900	57	165.7
368	419	DEL RIO CITY	94LA430	2,013	165.1
369	804	GOODWIN	94SB4380	1,540	164.9
370	972	BAY CITY	94CN7480	2,093	164.5
371	776	MCCAMEY	97SA2420	113	164.5
372	82	ARANSAS PASS	94CS590	395	163.7
373	1027	SA SOUTHLAND HILLS	97SA5055	840	163.6
374	259	RIO BRAVO	94LA1130	1,016	162.6
375	205	SA MATHIS FIELD	97SA4790	175	161.7
376	176	BROWNSVILLE	94SB4290	499	161.4
377	911	PHARR	94SB1640	1,342	161.2
378	31	MAVERICK	94LA9680	755	161.1
379	69	CHERRY CREEK TAP	97SA5245	49	161.0
380	525	WESLACO UNIT	94SB7455	1,189	160.5
381	138	BANQUETTE	94CS130	230	160.0
382	622	RODD FIELD	94CS205	2,018	159.7
383	587	UVALDE	94LA6620	2,795	159.3
384	1084	VERNON	97AB1750	247	159.2
385	216	STAMFORD	97AB2835	133	157.4
386	970	SOUTH MCALLEN	94SB5065	132	156.1
387	654	ZACATE CREEK	94LA2665	1,706	156.0
388	569	HARLINGEN	94SB660	1,942	155.9
389	115	WESLACO UNIT	94SB7630	2,567	155.8
390	713	SOUTH EAST EDINBURG	94SB4550	2,128	154.2
391	795	CITRUS CITY	94SB3470	1,582	152.7
392	60	FULTON	94CS9050	1,543	151.2
393	386	NORTH MCALLEN	94SB4995	2,417	150.3
394	588	CRESTONIO	94LA6660	765	150.2
395	629	KENEDY	94CN6270	551	149.8

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
396	206	PUTNAM	97AB2129	216	149.4
397	1129	CHILDRESS 20TH ST	97AB5720	179	149.3
398	593	SAND ROAD	97AB5295	538	148.8
399	648	LANTANA	94CS7150	274	148.6
400	532	WINTERS	97SA2113	807	148.3
401	131	AB RAINEY CREEK	97AB4225	116	147.9
402	361	ROCKPORT	94CS5950	525	146.9
403	129	SPUDDER FLAT	97SA4175	51	146.1
404	403	KARNES CITY	94CN2325	663	144.6
405	17	DARST	94CN790	254	144.5
406	313	EL GATO	94SB780	1,732	144.2
407	1126	SA LAKE DR	97SA6030	669	144.0
408	267	HOLLY	94CS1480	1,714	143.3
409	316	NORTH EDINBURG	94SB4240	2,656	142.8
410	610	UVALDE	94LA480	1,314	142.7
411	430	SOUTHSIDE	94CS7905	1,765	142.1
412	647	OLMITO	94SB715	627	141.5
413	893	CISCO	97AB1020	422	141.5
414	475	ARCADIA	94CS1450	1,996	140.2
415	271	HOLLY	94CS5820	928	140.2
416	1008	EAST HARRISON	94SB3000	520	140.1
417	346	AB RAINEY CREEK	97AB4220	194	140.1
418	173	MOORE FIELD	94SB3960	2,092	139.4
419	677	PALMVIEW	94SB9680	1,026	139.3
420	472	DILLEY	94LA510	557	138.8
421	756	AB WALNUT ST	97AB3785	544	138.7
422	990	AB OIL MILL	97AB2780	742	138.4
423	290	MESA VIEW	97SA7045	99	137.7
424	1160	AB COUNTRY CLUB	97AB4725	223	136.9
425	623	SAN BENITO	94SB4030	2,672	136.8
426	1075	PORTLAND	94CS9270	1,610	136.7
427	501	STADIUM	94LA7490	1,296	136.6
428	959	HAINE DRIVE	94SB3490	1,134	135.6
429	599	SOUTH SANTA ROSA	94SB1215	1,660	135.6
430	563	PLEASANTON	94LA9475	1,346	135.5
431	330	ELSA	94SB690	2,389	135.5
432	948	EAST HARRISON	94SB4620	774	134.6
433	909	CLYDE	97AB1760	430	134.4
434	827	ROCKSPRINGS	94LA2600	379	134.2
435	548	AIRLINE	94CS9030	416	133.8
436	519	HIDALGO	94SB4845	1,264	133.8
437	934	RIO PECOS	97SA513	33	133.8
438	551	PALMHURST	94SB2535	2,329	133.4
439	187	SARAGOSA	97SA1552	766	132.8
440	214	SOUTH SANTA ROSA	94SB1240	1,590	132.3
441	1140	MILO	94LA6940	447	132.1
442	769	COTULLA	94LA110	36	131.7
443	474	WEST HARLINGEN	94SB3720	2,121	131.6
444	222	PORTLAND	94CS9290	1,770	131.3
445	398	PALMHURST	94SB2525	2,093	131.2

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
446	150	THOMASTON	94CN9580	47	131.1
447	977	YELLOW JACKET	97SA7935	794	130.8
448	98	RISING STAR	97AB5080	584	130.3
449	789	MERKEL	97AB1895	704	130.0
450	595	WESMER	94SB9705	1,048	129.8
451	491	RISING STAR	97AB5075	663	129.5
452	197	MORRIS STREET	94CS5655	402	129.3
453	715	EL CAMPO	94CN2860	1,479	129.1
454	400	STAFFORD HILL	94CN1550	227	128.9
455	103	CHOKE CANYON	94CN9255	355	128.9
456	265	AIRLINE	94CS8890	529	128.8
457	716	EAGLE LAKE	94CN9455	594	128.2
458	338	HAROLD	97AB1495	24	128.0
459	929	KINGSVILLE	94CS1140	1,031	127.6
460	1134	MILO	94LA3060	133	127.3
461	608	BROOKHOLLOW	94CN8960	592	126.9
462	616	LOS FRESNOS	94SB7270	2,207	126.3
463	1040	CISCO	97AB7400	820	126.0
464	600	BEEVILLE	94CN8510	820	125.3
465	805	ABILENE PLANT	97AB1735	86	124.3
466	425	TWILIGHT TRAIL	97AB5855	1,435	124.3
467	958	KLEBERG	94CS8140	644	124.0
468	743	NORTH MERCEDES	94SB3770	1,777	123.7
469	190	FASHING	94CN360	37	123.2
470	484	PALMHURST	94SB2820	1,799	122.8
471	44	SABINAL	94LA200	437	122.6
472	72	GILA	94CS7840	770	122.4
473	824	THREE RIVERS	94CN2580	125	121.8
474	445	BAY CITY	94CN1110	1,261	121.4
475	802	RANKIN	97SA5735	177	121.4
476	365	PEARSALL	94LA7050	943	119.1
477	1086	EAST HARRISON	94SB3030	682	118.7
478	736	RUNGE	94CN3250	266	118.3
479	1073	AIRLINE	94CS8370	287	118.2
480	377	BAIRD	97AB5125	599	117.9
481	132	FALFURRIAS	94LA2830	1,458	117.8
482	768	GREGORY	94CS8560	250	117.8
483	527	HAINE DRIVE	94SB9690	555	117.7
484	1056	HARLINGEN SWITCH	94SB5350	918	117.5
485	1100	MINES ROAD	94LA4275	194	117.2
486	730	SOUTHSIDE	94CS8055	857	117.0
487	865	HASKELL 12KV	97AB5240	654	116.5
488	570	LIVE OAK	94CS1070	2,411	116.4
489	107	RACHAL	94LA8145	346	116.4
490	638	NORTH PADRE ISLAND	94CS1010	2,169	115.8
491	87	MARKHAM	94CN5550	22	115.1
492	679	NORTH EDINBURG	94SB3570	1,022	114.9
493	854	AB MAPLE ST	97AB5750	398	114.5
494	1171	ACME BESTWALL	97AB4150	64	114.0
495	694	SAN DIEGO	94LA2880	1,310	113.7

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
496	915	DEVINE	94LA7090	1,002	113.7
497	161	LEARY LANE	94CN6175	2,523	113.3
498	93	BRONTE AMBASSADOR	97SA6650	16	112.9
499	597	SA NORTH	97SA3115	559	112.4
500	1102	SHARYLAND	94SB2010	1,150	112.4
501	227	POLK AVENUE	94SB4900	2,928	112.1
502	978	HOLLY	94CS9675	1,783	111.9
503	992	HASKELL 12KV	97AB3495	801	111.7
504	859	DIMMIT	94LA5545	565	111.5
505	912	SOUTH MISSION	94SB3590	568	110.7
506	529	BUENA VISTA	94LA9035	1,913	110.6
507	413	FREER	94LA6320	166	110.6
508	122	AIRLINE	94CS8260	1,450	109.6
509	314	SAN DIEGO	94LA2930	571	109.6
510	899	WEST HARLINGEN	94SB3700	1,799	109.4
511	29	SINTON	94CS360	313	109.2
512	559	TUSCOLA	97AB3305	1,068	109.0
513	744	BUENA VISTA	94LA8965	924	108.9
514	459	PUEBLO	94LA130	1,425	108.9
515	538	PALMHURST	94SB1300	2,176	108.1
516	223	SOUTH SANTA ROSA	94SB1235	648	107.7
517	332	DEL RIO CITY	94LA1930	1,547	107.5
518	499	STERLING CITY	97SA1445	876	107.0
519	275	AB RAINEY CREEK	97AB4550	991	106.9
520	1026	AB OVER STREET 12KV	97AB3140	651	106.1
521	462	EL CAMPO	94CN6370	747	105.9
522	560	GARCENO	94SB2135	2,182	105.7
523	960	AB ONYX REA	97AB3260	138	105.4
524	574	MCCOLL ROAD	94SB4790	2,045	104.6
525	385	COFFEE PORT	94SB1090	1,203	104.4
526	655	ARCADIA	94CS1460	2,120	104.2
527	876	AIRLINE	94CS6970	1,394	103.9
528	168	VICTORIA POWER PLANT	94CN1390	1,093	103.6
529	947	NORDHEIM	94CN4275	82	103.5
530	38	BONNIEVIEW	94CS8020	477	103.3
531	273	CLARKWOOD	94CS9570	1,156	103.2
532	23	MAYBERRY	94SB3160	554	103.1
533	937	KINGSVILLE	94CS1130	2,310	102.8
534	1118	MORRIS STREET	94CS7465	811	102.1
535	845	SPUR	97AB260	161	101.9
536	1055	KARNES CITY	94CN2340	807	101.7
537	141	LULING - LCRA	94CN20	284	101.3
538	535	HEIGHTS	94LA6810	2,024	100.8
539	980	BLUFFS	97SA9110	597	100.6
540	847	TYNAN	94CS1855	135	100.5
541	42	SUNCHASE	94SB1150	1,297	100.4
542	8	ARANSAS PASS	94CS8270	377	99.6
543	606	HAINE DRIVE	94SB8065	1,354	98.7
544	728	SA SOUTH	97SA4795	1,269	98.7
545	923	NORTH VICTORIA	94CN7860	1,492	98.6

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
546	341	SOUTH PADRE ISLAND	94SB4695	1,324	97.6
547	1065	AIRLINE	94CS9390	2,937	97.3
548	581	EAST HARRISON	94SB4360	1,717	97.0
549	410	TWILIGHT TRAIL	97AB4290	983	96.9
550	426	SOUTH MCALLEN	94SB3640	314	96.2
551	312	CONTINENTAL	94SB3650	18	95.6
552	820	SHARYLAND	94SB6745	2,155	95.3
553	366	WASHINGTON STREET	94LA7015	1,534	95.0
554	555	RULE	97AB3396	430	94.9
555	941	WESLACO UNIT	94SB8610	1,150	94.0
556	429	SINTON	94CS180	972	93.7
557	288	NORTH MCALLEN	94SB5060	2,482	93.7
558	618	AB VOGEL ST	97AB4405	574	93.4
559	586	SOUTH MCALLEN	94SB3850	1,341	93.0
560	851	POLK AVENUE	94SB4600	3,138	92.2
561	617	RAYMONDVILLE #2	94SB3240	944	92.1
562	269	ARCADIA	94CS6930	1,493	91.6
563	683	HIGHWAY 9	94CS6720	1,309	91.5
564	456	LOS FRESNOS	94SB2160	1,465	91.3
565	630	THREE RIVERS	94CN2010	309	90.8
566	720	AB COUNTRY CLUB	97AB4855	785	90.7
567	965	MCCAMEY	97SA2830	464	90.5
568	292	SOUTHSIDE	94CS7925	1,265	90.1
569	993	KARNES CITY	94CN2315	1,018	89.7
570	1135	VERNON	97AB1520	721	89.3
571	693	MOCKINGBIRD	94CN400	408	88.8
572	759	PUEBLO	94LA275	2,794	88.6
573	97	BISHOP	94CS7180	924	88.2
574	862	HIGHWAY 9	94CS6780	760	87.7
575	1136	SPUR	97AB300	214	87.5
576	592	EL GATO	94SB910	2,466	87.4
577	850	DIMMIT	94LA4120	1,320	87.3
578	707	SAN YGNACIO	94LA16060	486	87.2
579	39	BRYANTS RANCH	97SA205	18	87.0
580	821	CISCO	97AB6530	528	87.0
581	354	POLK AVENUE	94SB4190	1,697	86.5
582	609	PALMHURST	94SB2530	1,818	86.3
583	336	PORT ARANSAS	94CS6940	1,431	86.2
584	91	BARNHART	97SA3725	145	86.2
585	347	KLEBERG	94CS6000	1,478	86.1
586	554	HALL ACRES ROAD	94SB8870	2,365	85.9
587	888	LEARY LANE	94CN1890	1,626	85.6
588	890	PORT ARANSAS	94CS3030	675	85.5
589	238	NAVAL BASE	94CS8540	1,586	85.4
590	545	ARCADIA	94CS5030	1,581	85.3
591	817	UVALDE	94LA5060	1,341	85.2
592	657	RUSSEK STREET	97SA7705	1,345	84.8
593	344	MORRIS STREET	94CS8830	1,542	84.7
594	729	MAGRUDER	94CN7870	1,263	84.5
595	765	RUNGE	94CN4465	385	84.3

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
596	220	PORTLAND	94CS6505	1,802	83.8
597	940	ROCHESTER	97AB3290	77	83.6
598	397	HIGHWAY 9	94CS6730	541	83.5
599	444	ASPERMONT	97AB3380	403	83.4
600	74	BUSH KNOB	97AB5200	290	83.1
601	944	NORTH MCALLEN	94SB9640	1,504	82.8
602	363	PALMVIEW	94SB7595	3,151	82.8
603	151	VICTORIA POWER PLANT	94CN7600	161	82.6
604	996	WEST MCALLEN	94SB4815	673	82.5
605	284	CAUSEWAY	94SB4795	1,222	82.5
606	382	KENEDY S.S.	94CN8340	339	82.4
607	619	VILLA CAVAZOS	94SB7615	1,058	82.4
608	853	GATEWAY	94LA5055	1,691	81.9
609	510	SAND ROAD	97AB5290	803	81.9
610	546	SOUTHSIDE	94CS8035	1,108	81.8
611	1111	INDIAN MESA	97SA2690	69	81.8
612	317	EAGLE PASS CITY	94LA2770	2,955	81.7
613	209	NORTH PADRE ISLAND	94CS720	1,309	81.5
614	607	PECAN BAYOU	97AB6810	395	80.5
615	818	HIGHLAND	97SA6380	422	80.1
616	443	BEN FICKLIN	97SA6175	705	79.9
617	706	ARCADIA	94CS5020	1,468	79.7
618	819	NORTH MCALLEN	94SB2980	1,773	79.4
619	612	HAMILTON ROAD	94LA9665	1,234	79.3
620	640	NORTH WESLACO	94SB4830	524	78.5
621	380	QUANAH	97AB3975	206	78.3
622	111	ZAPATA	94LA2710	1,295	78.2
623	276	ROARING SPRINGS	97AB6155	29	78.2
624	181	NIXON	94CN6630	675	77.6
625	644	WESMER	94SB4050	1,932	77.6
626	349	CEDAR GAP (TEC)	97AB4115	520	77.5
627	672	SA COKE ST	97SA3905	648	77.2
628	770	CARRIZO SPRINGS	94LA910	873	77.0
629	971	BRONTE	97SA3590	177	76.8
630	162	ALICE	94LA1780	243	76.5
631	194	LA PRYOR	94LA2440	713	76.5
632	493	HAMILTON ROAD	94LA9655	1,256	76.3
633	856	SAND ROAD	97AB5655	613	76.3
634	237	ESCONDIDO	94LA2035	2,639	76.2
635	1014	KLEBERG	94CS6410	243	76.1
636	579	WASHINGTON STREET	94LA2470	456	76.0
637	202	DILLEY	94LA6400	179	75.2
638	919	PREMONT	94LA2720	762	74.8
639	907	CHILDRESS 69	97AB4865	775	74.7
640	469	RACHAL	94LA6595	330	74.6
641	170	PHARAOH	94CS5175	1,283	74.5
642	646	ALICE	94LA1770	1,636	73.8
643	671	SIERRA VISTA	94LA7360	1,571	73.7
644	203	NAVAL BASE	94CS9720	2,464	73.7
645	169	ODEM	94CS375	1,082	73.6

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
646	777	GOODWIN	94SB7380	1,804	73.3
647	293	THROCKMORTON	97AB2090	67	73.1
648	405	SOUTH PADRE ISLAND	94SB5850	1,305	72.7
649	562	NORTH VICTORIA	94CN2240	744	71.6
650	986	AB SHELTON ST	97AB3145	1,076	71.4
651	665	GARWOOD CITY	94CN2570	144	71.3
652	1089	AB RAINEY CREEK	97AB4270	1,390	71.3
653	164	EL CAMPO	94CN7710	1,052	71.1
654	340	SHAFTER	97SA5110	52	70.8
655	913	NORTH VICTORIA	94CN6390	1,498	70.7
656	639	PORT ARANSAS	94CS990	1,328	70.0
657	626	REFUGIO	94CN5120	688	69.8
658	685	RODD FIELD	94CS2190	2,779	69.8
659	165	NORTH MCALLEN	94SB2750	2,796	69.5
660	420	BANDERA ELECTRIC (LEAKEY)	94LAL30	271	69.1
661	869	CITRUS CITY	94SB9775	1,533	68.4
662	166	NORTH ALAMO	94SB3580	848	68.3
663	1107	AB DYESS 1	97AB1775	727	68.2
664	974	GONZALES	97SA15390	1,331	68.1
665	952	WEAVER ROAD	94CN1910	23	68.0
666	404	RANKIN	97SA7425	119	67.5
667	231	CAMPWOOD	94LA3430	111	67.4
668	764	STAMFORD PUMP	97AB3930	43	67.0
669	1039	EAST HARRISON	94SB4310	1,187	66.1
670	746	LOS FRESNOS	94SB5335	2,511	66.0
671	989	SA SOUTH	97SA4255	871	66.0
672	542	BAY CITY	94CN6670	1,601	66.0
673	1019	SA EMERSON ST	97SA4625	412	65.9
674	748	DILLEY	94LA3795	816	65.6
675	1155	GOODWIN	94SB3530	340	65.5
676	994	EL CAMPO	94CN7260	522	65.5
677	621	AILEEN	97AB4600	253	65.3
678	826	WASHINGTON STREET	94LA2350	3,013	64.8
679	682	GOODWIN	94SB4625	1,949	64.0
680	841	KITTIE WEST	94CN3760	234	63.7
681	14	PLACEDO	94CN7970	478	63.3
682	1054	EDEN	97SA1780	243	63.1
683	61	POLK AVENUE	94SB4170	1,455	62.8
684	916	RAYMONDVILLE #1	94SB800	725	62.7
685	94	RIO BRAVO	94LA5	699	62.1
686	282	MCCOLL ROAD	94SB4780	1,971	61.8
687	664	GARCENO	94SB2130	1,767	61.6
688	754	MATHIS	94CS340	1,363	61.5
689	543	VERNON	97AB3340	532	61.5
690	415	MINES ROAD	94LA3680	1,151	61.5
691	133	BRUNI	94LA1100	600	61.3
692	123	BRACKETTVILLE	94LA8460	1,164	61.3
693	470	WEST MCALLEN	94SB4535	2,851	61.0
694	148	COMSTOCK	94LA230	184	60.3
695	534	ESCONDIDO	94LA5730	1,208	60.3

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
696	921	SANTO NINO	94LA645	1,412	59.8
697	277	BAY CITY	94CN6450	963	59.8
698	1007	AB WALNUT ST	97AB3110	928	59.6
699	210	ARCADIA	94CS1360	1,481	59.5
700	30	LA GRULLA	94SB5110	989	59.4
701	118	PORT ISABEL S.S.	94SB4070	280	59.1
702	1079	SA SOUTHLAND HILLS	97SA5455	1,403	58.6
703	182	HOMEPORT	94CS4665	435	58.6
704	384	CRYSTAL CITY	94LA1425	1,167	58.6
705	722	BAY CITY	94CN2050	540	58.5
706	1080	SHARYLAND	94SB2035	741	58.4
707	186	STAMFORD	97AB4565	786	58.3
708	215	STAMFORD	97AB6255	392	58.1
709	839	AB MCMURRY	97AB4355	994	58.1
710	310	BEN FICKLIN	97SA6180	1,050	58.1
711	147	PALACIOS	94CN6830	818	58.0
712	561	GEORGE WEST	94CN730	923	57.8
713	109	FALFURRIAS	94LA1070	984	57.8
714	73	FREER	94LA2900	160	57.7
715	922	COTULLA	94LA460	521	57.5
716	684	SOUTH MCALLEN	94SB3790	1,435	57.4
717	822	CROWELL	97AB3490	177	57.4
718	495	DEL MAR	94LA7930	1,469	57.3
719	533	CHARLOTTE	94LA2790	198	56.8
720	874	NORTH WESLACO	94SB4810	1,487	56.3
721	481	GATEWAY	94LA3595	1,481	56.2
722	458	HOLLY	94CS7740	2,204	56.1
723	763	ARANSAS PASS	94CS8280	588	56.0
724	280	RUSSEK STREET	97SA11370	202	56.0
725	255	RIO GRANDE CITY	94SB3230	2,577	55.8
726	N/A	PUEBLO	94LA9870	1,346	55.7
727	590	VERNON	97AB4275	588	55.5
728	837	SANTO NINO	94LA515	2,165	55.4
729	1122	CHILDRESS 20TH ST	97AB5725	664	55.4
730	230	ENCINAL	94LA2160	232	55.4
731	673	VILLA CAVAZOS	94SB5680	1,796	55.0
732	838	CROCKETT HEIGHTS	97SA73703	78	54.8
733	302	CITRUS CITY	94SB7985	1,131	54.7
734	266	SOUTH SANTA ROSA	94SB7485	1,068	54.2
735	835	AB COUNTRY CLUB	97AB4730	533	54.0
736	718	SONORA	97SA2045	620	53.7
737	645	CLARKWOOD	94CS7610	106	53.7
738	191	BEEVILLE	94CN8090	1,362	53.2
739	522	CLYDE	97AB1755	131	52.9
740	721	TAFT	94CS5230	830	52.6
741	299	HIGHWAY 9	94CS9830	150	52.5
742	678	NORTH EDINBURG	94SB3810	1,264	52.3
743	N/A	MESQUITE	94SB2900	907	52.2
744	152	DEL RIO CITY	94LA9850	1,013	52.2
745	925	IRAAN	97SA2050	185	52.1

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
746	928	KENEDY S.S.	94CN6750	58	51.8
747	1025	MARFA	97SA1900	770	51.4
748	490	YORKTOWN	94CN3130	470	51.1
749	353	BUENA VISTA	94LA9385	1,956	51.1
750	880	HALL ACRES ROAD	94SB4895	865	51.1
751	879	RULE	97AB3378	106	50.5
752	955	ANNA STREET	94LA900	2,833	50.4
753	549	WESLACO UNIT	94SB8195	1,649	50.3
754	505	LA GRULLA	94SB4120	1,422	50.2
755	1061	AB OVER STREET 12KV	97AB1840	886	49.8
756	262	MOORE FIELD	94SB3110	651	49.6
757	113	FULTON	94CS2020	1,674	49.4
758	514	GREGORY	94CS2420	839	49.0
759	689	INGLESIDE CITY	94CS8060	2,243	49.0
760	207	VICTORIA POWER PLANT	94CN8170	806	48.3
761	825	AB ELM CREEK	97AB5045	379	48.0
762	423	CAMPWOOD	94LA2610	959	47.7
763	611	ZAPATA	94LA8300	2,034	47.7
764	830	WESLACO UNIT	94SB9805	2,131	47.6
765	359	MOCKINGBIRD	94CN305	311	47.6
766	656	WASHINGTON STREET	94LA6525	2,081	47.4
767	64	NIXON	94CN2025	507	47.1
768	492	PALMVIEW	94SB6790	1,855	46.8
769	416	INGLESIDE CITY	94CS2495	254	46.6
770	264	EDROY	94CS6980	201	46.1
771	1176	FLOMONT	97AB81335	34	46.1
772	1058	SA AVENUE N	97SA1695	1,462	46.1
773	737	WYLIE	97AB6340	734	46.1
774	668	AB WALNUT ST	97AB3250	11	46.0
775	315	MATHIS	94CS1410	420	45.4
776	20	ROBSTOWN	94CS1650	361	44.9
777	200	CHILLICOTHE	97AB4530	495	44.8
778	455	ASPERMONT	97AB1070	327	44.6
779	781	MAGRUDER	94CN7690	553	44.5
780	780	MCCOLL ROAD	94SB1655	1,334	44.0
781	105	ODEM	94CS385	419	43.4
782	283	LEARY LANE	94CN7530	3,032	42.8
783	870	SOUTH MISSION	94SB3620	1,982	42.8
784	787	AB MAPLE ST	97AB5755	1,689	42.6
785	604	WEST OSO	94CS9095	1,603	42.3
786	1035	AB ELM CREEK	97AB4775	885	42.3
787	298	HEIGHTS	94LA2100	1,958	42.1
788	731	CRYSTAL CITY	94LA2170	723	41.9
789	N/A	SIERRA VISTA	94LA7170	1,439	41.4
790	714	MAGRUDER	94CN6700	1,357	41.4
791	278	ROUNDTOP	97AB4490	50	41.4
792	985	SA AVENUE N	97SA1730	795	41.2
793	848	STADIUM	94LA7810	1,596	41.1
794	662	MAYBERRY	94SB1790	744	41.0
795	882	JOURDANTON	94LA5695	312	40.9

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
796	785	ANSON REA (SEC)	97AB5215	245	40.7
797	1167	SA EMERSON ST	97SA4860	242	40.4
798	1006	WYLIE	97AB2665	1,033	40.3
799	807	CLYDE	97AB3630	565	40.3
800	1049	SANTO NINO	94LA80	1,887	40.0
801	954	SA SOUTH	97SA3995	1,378	39.6
802	799	ARANSAS PASS	94CS650	858	39.6
803	889	EAST HARRISON	94SB3080	420	39.5
804	924	MINES ROAD	94LA3745	1,891	39.4
805	352	SOUTHSIDE	94CS8025	1,071	39.4
806	530	CRYSTAL CITY	94LA7425	435	39.3
807	578	ZAPATA	94LA8290	490	39.3
808	358	WESMER	94SB1850	1,403	39.3
809	460	NORTH VICTORIA	94CN1580	1,019	39.2
810	323	REFUGIO	94CN1170	828	39.1
811	792	DEL MAR	94LA490	790	39.0
812	334	FRIO	94LA2270	595	38.9
813	212	PHARR	94SB1620	2,696	38.9
814	407	UNIVERSITY	94LA950	2,483	38.8
815	438	ZACATE CREEK	94LA2635	977	38.6
816	681	CARRIZO SPRINGS	94LA860	32	38.6
817	357	GATEWAY	94LA390	3,044	38.3
818	253	HEARN ROAD	94CS9665	682	38.2
819	321	MCKENZIE ROAD	94CS330	2,393	38.2
820	322	EOLA	97SA4950	237	38.1
821	1016	CARRIZO SPRINGS	94LA750	600	37.9
822	427	PHARR	94SB1625	1,711	37.6
823	692	LA GRULLA	94SB5005	1,157	37.4
824	871	MERKEL	97AB1890	582	37.4
825	884	AFTON	97AB2225	53	37.4
826	602	SHARYLAND	94SB5635	2,206	36.9
827	213	SONORA 138 SUB	97SA4805	441	36.8
828	136	PAWNEE (STEC OWNED)	94CN22202	199	36.5
829	873	LEARY LANE	94CN1430	1,667	36.4
830	59	LAREDO PLANT	94LA8745	758	36.3
831	520	ANSON 12KV	97AB6635	401	36.0
832	488	JOURDANTON	94LA880	932	36.0
833	695	WEST HARLINGEN	94SB4870	1,047	35.8
834	51	WOODSBORO	94CS8330	287	35.6
835	733	GOODWIN	94SB4390	415	35.6
836	439	ASHERTON	94LA2670	87	35.6
837	192	REFUGIO	94CN1210	178	35.4
838	803	PALMVIEW	94SB9685	2,838	35.2
839	712	SA LAKE DR	97SA5865	1,027	35.2
840	294	MILO	94LA8365	1,855	35.2
841	863	ROCKPORT	94CS5940	43	35.1
842	987	AB VOGEL ST	97AB4410	775	35.1
843	910	AB COUNTRY CLUB	97AB4735	120	35.0
844	571	PUEBLO	94LA95	1,205	34.9
845	1037	MARFA	97SA1905	1,111	34.4

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
846	949	HARLINGEN SWITCH	94SB4090	2,310	34.3
847	633	EDITH HUMBLE	97SA6170	82	34.3
848	125	WOOLRIDGE	94CS1170	1,991	34.2
849	432	WINTERS	97SA3765	800	34.2
850	723	TANKERSLY (CVEC)	97SA5265	367	34.1
851	892	HALL ACRES ROAD	94SB5585	1,448	33.9
852	556	AB CANYON ROCK	97AB5035	965	33.9
853	502	GARCENO	94SB2165	1,960	33.8
854	576	HARLINGEN	94SB380	2,695	33.6
855	379	HEIGHTS	94LA2450	2,064	33.5
856	760	AB SHELTON ST	97AB3050	647	33.5
857	468	POLK AVENUE	94SB4740	1,690	33.4
858	953	NORTH VICTORIA	94CN1470	464	33.4
859	860	CISCO	97AB9715	1,009	33.2
860	625	RAYMONDVILLE #1	94SB3130	274	33.1
861	483	PECAN BAYOU	97AB6815	1,502	32.9
862	1034	GONZALES	97SA14685	1,065	32.9
863	811	CHARLOTTE	94LA1960	502	32.8
864	755	MERTZON (CVEC)	97SA1530	331	32.8
865	158	PHARAOH	94CS5185	2,350	32.6
866	906	SHARYLAND	94SB5105	1,759	32.6
867	945	EL CAMPO	94CN5745	902	32.6
868	1001	MUNDAY	97AB2080	472	32.4
869	84	PARKER	94CN9010	19	32.3
870	810	MAGRUDER	94CN6680	691	32.2
871	368	MORRIS STREET	94CS8850	417	32.1
872	794	HIDALGO	94SB3400	887	32.0
873	1051	HIGHLAND	97SA6385	1,317	32.0
874	749	AIRLINE	94CS9605	713	32.0
875	767	LANTANA	94CS4095	197	32.0
876	1154	AB EAST 12KV	97AB4820	1,140	31.9
877	485	ROBERT LEE	97SA4120	556	31.4
878	1132	SA WALNUT ST	97SA3910	154	31.4
879	1077	AB HARTFORD ST	97AB3820	921	31.3
880	342	JUNCTION	97SA4340	784	31.3
881	688	SOUTH EAST EDINBURG	94SB4570	1,389	31.2
882	601	GEORGE WEST	94CN1320	710	31.1
883	518	POWELL FIELD	97SA2528	25	30.8
884	842	NORTH VICTORIA	94CN7770	838	30.5
885	1021	MATHIS	94CS1420	897	30.5
886	515	YORKTOWN	94CN8380	783	30.1
887	1096	AILEEN	97AB4605	760	30.1
888	834	COTULLA	94LA90	1,057	29.9
889	852	ALPINE 12KV	97SA6825	1,920	29.7
890	1066	BALLINGER	97SA4395	531	29.6
891	696	QUANAH	97AB3100	547	29.4
892	857	WYLIE	97AB2675	801	29.4
893	1	ASPHALT MINES	94LA500	44	29.4
894	711	EAGLE PASS CITY	94LA2650	1,353	29.3
895	1070	HALL ACRES ROAD	94SB9595	1,468	29.3

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
896	127	VERHALEN	97SA4460	74	29.3
897	1068	SINTON	94CS1750	501	29.2
898	973	SHARYLAND	94SB2020	2,412	28.8
899	371	HOLLY	94CS7620	2,700	28.6
900	806	ABILENE PLANT	97AB1570	659	28.5
901	1031	ABILENE PLANT	97AB1575	614	28.4
902	446	CHOKE CANYON	94CN5390	410	28.4
903	523	PORT ISABEL S.S.	94SB3760	711	28.3
904	917	VERNON CITY PLANT	97AB5775	817	28.1
905	471	PORT LAVACA	94CN2480	1,544	27.8
906	477	ROBERT LEE	97SA4125	264	27.6
907	201	BISHOP	94CS2690	628	27.5
908	887	STADIUM	94LA6950	536	27.1
909	786	PUTNAM	97AB2131	127	26.9
910	1020	CROWELL	97AB3980	488	26.7
911	1011	AB ELM CREEK	97AB1820	94	26.6
912	753	HEIGHTS	94LA2390	1,706	26.3
913	489	UVALDE	94LA550	704	26.2
914	779	PAULANN	97SA6280	425	26.1
915	877	LEARY LANE	94CN6005	1,376	25.9
916	521	UVALDE	94LA540	1,204	25.8
917	886	SAN BENITO	94SB3910	1,780	25.7
918	5	BOBCAT HILLS	97SA6655	22	25.6
919	289	UVALDE	94LA9770	1,521	25.4
920	291	ROMA	94SB3060	1,549	25.4
921	1113	CHILDRESS 69	97AB2800	334	25.3
922	537	COLLEGE HILLS	97SA6145	714	25.0
923	1095	NORTH MCALLEN	94SB3830	1,360	24.8
924	406	BAY CITY	94CN2700	1,080	24.6
925	N/A	MESQUITE	94SB3360	639	24.1
926	872	MUNDAY	97AB3365	400	23.9
927	757	THROCKMORTON	97AB3190	609	23.9
928	666	BEEVILLE	94CN490	964	23.9
929	628	YORKTOWN	94CN8420	663	23.7
930	747	RUSSEK STREET	97SA250	154	23.7
931	891	HARLINGEN	94SB370	1,197	23.7
932	1071	SIERRA VISTA	94LA3540	899	23.6
933	735	LEARY LANE	94CN1540	794	23.4
934	N/A	MESQUITE	94SB8340	753	23.2
935	402	RODD FIELD	94CS1730	2,182	23.0
936	585	AB DYESS 2	97AB6335	358	22.7
937	914	AB OVER STREET 12KV	97AB1645	796	22.5
938	1069	HEIGHTS	94LA6820	1,895	22.5
939	1120	POLK AVENUE	94SB4180	1,297	22.3
940	268	ESCONDIDO	94LA3350	475	22.2
941	1044	HAROLD	97AB3055	29	22.2
942	478	RODD FIELD	94CS225	2,645	22.0
943	771	AB ELMDALE	97AB4520	256	21.9
944	1131	AB SHELTON ST	97AB3660	649	21.8
945	503	WEST MCALLEN	94SB4505	1,873	21.5

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
946	926	UNIVERSITY	94LA920	691	21.4
947	409	AB MCMURRY	97AB3245	794	21.3
948	791	DEL RIO CITY	94LA440	1,103	21.2
949	829	SA NORTH	97SA3130	234	21.1
950	881	CONTINENTAL	94SB4880	73	21.0
951	536	PLEASANTON	94LA2080	1,637	20.7
952	823	SA JACKSON ST	97SA4260	665	20.6
953	691	NORTH VICTORIA	94CN7430	1,691	20.6
954	709	AB SHELTON ST	97AB4640	651	20.6
955	1141	MAYBERRY	94SB3010	93	20.4
956	846	MATHIS	94CS2870	864	20.3
957	1083	AB MCMURRY	97AB4350	709	20.2
958	496	HIGHWAY 9	94CS7200	659	20.1
959	1082	SA JACKSON ST	97SA4265	796	20.0
960	981	SOUTH MISSION	94SB3940	846	19.8
961	393	STADIUM	94LA7800	675	19.6
962	1042	JOSLIN POWER PLANT	94CN8720	18	19.6
963	90	TYNAN	94CS4000	28	19.5
964	867	ROMA	94SB3070	890	19.3
965	734	MAGRUDER	94CN6690	748	19.2
966	1088	UNIVERSITY	94LA465	862	19.0
967	112	MAGNOLIA	94CN315	12	19.0
968	875	CHILLICOTHE	97AB4525	117	18.9
969	451	BERCLAIR	94CN990	209	18.5
970	988	MILES	97SA4670	534	18.0
971	1093	KNOX CITY	97AB3300	471	17.7
972	1047	CLYDE	97AB3635	714	17.7
973	494	HOLLY	94CS1220	3,337	17.6
974	235	GRAYBACK	97AB3315	45	17.5
975	114	CHRISTOVAL	97SA6620	580	17.2
976	883	WASHINGTON STREET	94LA2360	218	16.9
977	528	JUNCTION	97SA4335	789	16.7
978	1148	COLLEGE HILLS	97SA4840	210	16.6
979	245	FREER	94LA5200	1,036	16.5
980	396	SONORA ATLANTIC (SWTEC)	97SA4415	31	16.5
981	N/A	LAS CRUSES	94LA7325	1,719	16.1
982	798	HARLINGEN SWITCH	94SB4110	850	16.0
983	908	WEST HARLINGEN	94SB3800	1,385	16.0
984	1147	KEPLER	94CS1700	23	15.8
985	936	AB SHELTON ST	97AB3060	1,574	15.8
986	1168	ZACATE CREEK	94LA2675	1,208	15.7
987	1029	SHARYLAND	94SB2150	1,452	15.6
988	326	FT DAVIS	97SA4515	982	15.6
989	1078	TWILIGHT TRAIL	97AB3150	726	15.5
990	1018	AB CANYON ROCK	97AB5030	861	15.4
991	239	SUNCHASE	94SB1155	1,459	15.3
992	1085	SOUTH MCALLEN	94SB3935	985	15.2
993	77	ASPR CONTINENTAL	97AB3830	27	15.0
994	920	AB OIL MILL	97AB2785	248	14.8
995	643	AB MCMURRY	97AB4510	831	14.7

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
996	761	COLLEGE HILLS	97SA4835	443	14.4
997	466	SOUTH PADRE ISLAND	94SB4675	166	14.4
998	424	WYLIE	97AB6495	316	14.4
999	1081	HEIGHTS	94LA9080	685	14.4
1000	167	VICTORIA POWER PLANT	94CN8070	614	14.3
1001	898	EDNA	94CN5775	507	14.1
1002	969	DEL MAR	94LA10	1,859	13.9
1003	703	HALL ACRES ROAD	94SB5465	1,402	13.9
1004	1123	SA EMERSON ST	97SA4620	435	13.9
1005	962	SPUR	97AB5170	374	13.9
1006	526	WEST OSO	94CS9085	900	13.8
1007	774	GOVERNMENT WELLS	94LA7250	556	13.6
1008	434	CHARLOTTE	94LA8120	214	13.5
1009	702	PECAN BAYOU	97AB530	19	13.5
1010	453	HIGHWAY 9	94CS7210	353	13.3
1011	783	MCCAMEY	97SA3670	369	13.3
1012	1000	AB ELM CREEK	97AB4780	533	13.1
1013	991	SOUTH MISSION	94SB4650	1,014	13.0
1014	1164	COLLEGE HILLS	97SA5520	436	13.0
1015	343	MCCAMEY	97SA2855	78	13.0
1016	680	SA NORTH	97SA3125	1,242	12.9
1017	849	PONDER KENNEDY	97SA50208	11	12.7
1018	627	SIERRA VISTA	94LA9900	2,132	12.7
1019	390	HEIGHTS	94LA9400	1,384	12.5
1020	1099	ABILENE PLANT	97AB1910	257	12.5
1021	509	SANTA RITA	97SA1100	112	12.4
1022	927	NORTH MCALLEN	94SB9660	2,000	12.3
1023	448	ANNA STREET	94LA780	475	12.2
1024	930	AB HARTFORD ST	97AB3815	1,108	12.2
1025	1106	GIRARD	97AB6260	44	11.8
1026	775	PADUCAH CITY	97AB1930	570	11.8
1027	524	ANSON 12KV	97AB6630	693	11.7
1028	1041	AB ELM CREEK	97AB1810	846	11.6
1029	66	FULTON	94CS440	1,910	11.6
1030	1145	BRONTE	97SA3560	252	11.5
1031	1097	BALLINGER	97SA4370	816	11.5
1032	242	EAGLE PASS CITY	94LA450	950	11.5
1033	902	AB OVER STREET 12KV	97AB1635	519	11.5
1034	544	BROOKHOLLOW	94CN7580	502	11.2
1035	1028	SA COKE ST	97SA4910	1,721	11.1
1036	942	SOUTH MISSION	94SB5215	1,245	10.9
1037	1057	BALLINGER	97SA4375	1,039	10.7
1038	185	WEINERT	97AB6490	127	10.6
1039	479	HAINE DRIVE	94SB9700	1,078	10.6
1040	840	CAUSEWAY	94SB4775	1,057	10.6
1041	1022	SANTO NINO	94LA695	1,592	10.5
1042	1064	OZONA	97SA3810	620	10.5
1043	1116	ROARING SPRINGS	97AB2065	221	10.5
1044	816	AB SHELTON ST	97AB3040	173	10.4
1045	1104	ZAPATA	94LA7330	1,342	10.4

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
1046	868	ROCKSPRINGS	94LA8040	347	10.2
1047	117	WOOLRIDGE	94CS1110	1,733	10.2
1048	855	COLUMBUS	94CN6180	470	10.1
1049	800	PADUCAH CITY	97AB1935	282	10.0
1050	670	MAYBERRY	94SB5770	812	9.9
1051	900	CHILDRESS 69	97AB1800	540	9.8
1052	331	OZONA	97SA4185	1,309	9.7
1053	1165	AB EAST 12KV	97AB4825	425	9.7
1054	1002	SA WALNUT ST	97SA4635	1,543	9.4
1055	564	IRAAN	97SA2055	536	9.3
1056	710	RAYMONDVILLE #2	94SB4160	339	9.2
1057	67	RODD FIELD	94CS245	2,845	9.2
1058	946	SOUTH EAST EDINBURG	94SB4015	451	9.1
1059	984	HIGHLAND	97SA6370	517	9.1
1060	1138	AB ELM CREEK	97AB1815	374	9.1
1061	963	QUANAH	97AB3530	333	9.0
1062	1110	SA SOUTHLAND HILLS	97SA5050	891	8.9
1063	784	ALICE	94LA1790	467	8.9
1064	1052	AB ELM CREEK	97AB4745	958	8.9
1065	452	TYNAN	94CS4010	42	8.9
1066	1187	CASA BLANCA	94CS5440	134	8.8
1067	1045	ROCHESTER	97AB3295	218	8.8
1068	866	NORDHEIM	94CN3380	173	8.7
1069	750	COLUMBUS	94CN930	922	8.7
1070	897	HAMLIN	97AB3270	879	8.7
1071	1060	WAGGONER	97AB5900	26	8.7
1072	979	SANTO NINO	94LA70	1,164	8.5
1073	540	BEN FICKLIN	97SA6185	565	8.5
1074	1108	SANTA ANNA	97SA3415	331	8.4
1075	1105	SA AVENUE N	97SA1655	489	8.4
1076	772	PORTLAND	94CS9370	2,052	8.3
1077	1156	HAMLIN	97AB3775	245	8.3
1078	1175	SA CONCHO	97SA1725	24	8.3
1079	N/A	FRIO	94LA1815	1,074	8.1
1080	1172	PAULANN	97SA6310	1,021	8.1
1081	1013	ESCONDIDO	94LA1510	729	8.0
1082	1159	SA JACKSON ST	97SA4695	561	8.0
1083	1076	AFTON	97AB2310	242	8.0
1084	773	AB EAST 12KV	97AB5760	229	7.8
1085	1125	AB ELMDALE	97AB4085	43	7.8
1086	300	MOCKINGBIRD	94CN370	47	7.8
1087	433	MILO	94LA3070	2,812	7.7
1088	1150	SA LAKE DR	97SA5880	804	7.7
1089	1173	SILVER	97SA4295	14	7.6
1090	1169	AB EAST 12KV	97AB4830	607	7.5
1091	1017	SA WALNUT ST	97SA3925	882	7.5
1092	667	AB VOGEL ST	97AB4560	1,474	7.4
1093	1090	TWILIGHT TRAIL	97AB4285	1,141	7.3
1094	N/A	PEARSALL	94LA9905	402	7.2
1095	968	SA JACKSON ST	97SA4690	1,124	7.1

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
1096	319	SA WALNUT ST	97SA3920	886	7.0
1097	726	ABILENE PLANT	97AB1565	279	6.9
1098	998	SANTO NINO	94LA75	1,491	6.8
1099	252	DEL RIO CITY	94LA9790	2,329	6.7
1100	431	AB MCMURRY	97AB3240	763	6.5
1101	1162	ROWENA	97SA4480	218	6.4
1102	1053	AB MCMURRY	97AB4360	1,087	6.3
1103	1092	SA NORTH	97SA3120	1,108	6.2
1104	516	SANTA ANNA	97SA3420	359	6.2
1105	751	PORT LAVACA	94CN6850	683	6.1
1106	1115	AIRLINE	94CS5870	917	6.0
1107	1062	SA SOUTHLAND HILLS	97SA5860	1,190	5.9
1108	732	SAN BENITO	94SB3860	240	5.9
1109	833	AB REBECCA LANE	97AB5555	1,263	5.8
1110	1043	BAIRD	97AB5120	440	5.8
1111	1149	KEPLER	94CS2665	41	5.7
1112	250	AB MCMURRY	97AB3235	796	5.5
1113	1101	SA JACKSON ST	97SA4685	1,415	5.5
1114	247	HIDALGO	94SB3680	326	5.5
1115	1144	SA CONCHO	97SA1705	901	5.4
1116	417	SA MATHIS FIELD	97SA5100	225	5.4
1117	831	AB SHELTON ST	97AB3435	313	5.3
1118	1117	SA SOUTH	97SA3990	738	5.3
1119	982	RANKIN	97SA6400	69	5.2
1120	47	VALERA HUMBLE	97SA7015	75	5.2
1121	966	ESCONDIDO	94LA3775	167	5.0
1122	221	VALENTINE	97SA5590	216	5.0
1123	918	PAULANN	97SA6285	63	4.9
1124	999	KNOX CITY	97AB3985	22	4.7
1125	1179	AB ELM CREEK	97AB1825	217	4.7
1126	1009	AB MAPLE ST	97AB4070	15	4.5
1127	904	BENJAMIN (BEPC)	97AB5680	155	4.5
1128	1139	AB VOGEL ST	97AB4650	797	4.4
1129	1059	BROOKHOLLOW	94CN7190	281	4.4
1130	1067	PAINT ROCK	97SA1110	68	4.1
1131	1128	AB REBECCA LANE	97AB6915	999	3.9
1132	1182	LA GRULLA	94SB3045	1,130	3.9
1133	1098	FT DAVIS	97SA3345	430	3.7
1134	1185	KNIPPA	94LA6535	24	3.5
1135	473	LAREDO PLANT	94LA8695	1,346	3.5
1136	1063	AB HARTFORD ST	97AB3690	171	3.5
1137	1166	SA SOUTH	97SA3500	293	3.4
1138	N/A	SIERRA VISTA	94LA8205	921	3.4
1139	790	SAND ROAD	97AB5195	247	3.3
1140	225	MCKENZIE ROAD	94CS150	23	3.3
1141	1109	AB REBECCA LANE	97AB2710	263	3.1
1142	1158	JAYTON	97AB6125	352	3.0
1143	717	KENEDY	94CN1960	64	3.0
1144	1119	SA WALNUT ST	97SA3915	779	3.0
1145	218	SA SOUTH	97SA2595	970	2.9

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
1146	1174	SA CONCHO	97SA3325	47	2.9
1147	1036	VERNON	97AB5000	246	2.9
1148	306	TRUSCOTT	97AB3845	29	2.8
1149	1184	UNIVERSITY	94LA930	94	2.7
1150	843	WASHINGTON STREET	94LA6355	978	2.7
1151	1030	AB REBECCA LANE	97AB5550	718	2.7
1152	80	SANTA RITA	97SA1135	9	2.7
1153	752	BLUFFS	97SA7280	1,483	2.5
1154	687	KNOX CITY	97AB3390	363	2.4
1155	708	PLASTERCO (MWEC)	97AB2720	113	2.3
1156	1127	RUSSEK STREET	97SA12295	310	2.0
1157	228	SKIDMORE	94CS380	158	1.9
1158	1087	MATADOR	97AB3090	313	1.9
1159	675	AILEEN	97AB6435	831	1.9
1160	1157	BRONTE	97SA4160	210	1.9
1161	1189	KENEDY S.S.	94CN8320	147	1.9
1162	100	HAMILTON ROAD	94LA9645	303	1.8
1163	583	AB SHELTON ST	97AB3045	555	1.6
1164	1023	PAINT ROCK	97SA5235	129	1.5
1165	1133	MATADOR	97AB3030	213	1.5
1166	450	ROBY	97AB2276	314	1.3
1167	1048	SA JACKSON ST	97SA4250	347	1.3
1168	387	VERNON CITY PLANT	97AB5770	98	1.2
1169	727	ALPINE 12KV	97SA6820	769	0.8
1170	1190	JOSLIN POWER PLANT	94CN7915	10	0.6
1171	1033	ABILENE PLANT	97AB1915	61	0.6
1172	1151	AB OIL MILL	97AB3895	139	0.6
1173	401	SA CONCHO	97SA1700	498	0.5
1174	844	CLARKWOOD	94CS2170	545	0.5
1175	1046	AB HARTFORD ST	97AB3685	372	0.4
1176	1161	SA CONCHO	97SA1715	286	0.4
1177	1121	ABILENE PLANT	97AB3175	115	0.4
1178	1170	COLLEGE HILLS	97SA4845	426	0.4
1179	1130	SA AVENUE N	97SA1975	327	0.3
1180	903	HIGHLAND	97SA6375	267	0.3
1181	660	COLLEGE HILLS	97SA5515	350	0.2
1182	34	RANKIN	97SA6405	391	0.0
1183	45	CHASE FIELD	94CN460	14	0.0
1184	895	IRAAN	97SA4305	76	0.0
1185	96	BARNHART	97SA590	20	0.0
1186	372	TALPA ATLANTIC	97SA5180	66	0.0
1187	615	PEACOCK	97AB1375	47	0.0
1188	614	BLUFFS	97SA3005	239	0.0
1189	582	ESPY WELLS	97SA50207	29	0.0
1190	1094	SWENSON	97AB136	32	0.0
1191	1072	MAYBERRY	94SB5340	35	0.0
1192	1142	SA COKE ST	97SA4915	17	0.0
1193	1103	MAYBERRY	94SB6450	27	0.0
1194	1163	AB CANYON ROCK	97AB5025	51	0.0
1195	1180	ABILENE PLANT	97AB1740	18	0.0

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
1196	1183	WASHINGTON STREET	94LANETLAR	163	0.0
1197	1186	MORRIS STREET	94CSNET CC	317	0.0
1198	1188	VICTORIA POWER PLANT	94CNNETVIC	88	0.0
1199	N/A	LAS CRUSES	94LA8530	118	0.0
1200	N/A	SANTA RITA	97SA1140	10	0.0

Feeders from last year that are not in this year's list

2017 Ranking	Substation Identification	Feeder ID	Reason not in 2018
766	KEMPER EXXON HUMBLE	97SA1490	Retired
778	PEARSALL	94LA3675	Count is now less than 10
497	RANGERVILLE	94SB4060	Count is now less than 10
741	RANGERVILLE	94SB3420	Count is now less than 10

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

INTERRUPTION CAUSES

Provide the percentage of interruptions attributable to each cause.

2018 Reporting Year

Causes of Forced Interruptions	Percentage
Utility-Owned Equipment	43.24%
Weather (including lightning)	20.44%
Vegetation	15.98%
Unknown	12.25%
Animals and Birds	5.51%
People (including cars and farm eqpt)	2.55%
Other	0.01%