

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
797	302	LWSNR	2232	2304	105.28
798	2392	WCOLO	1319	2084	104.96
799	2524	ALNTH	2842	2072	104.85
800	45	KMASB	1711	299	104.43
801	136	WLWSP	1201	530	104.40
802	154	MRSES	4005	745	104.40
803	161	BONHM	1202	741	104.29
804	1848	TYLER	1004	192	104.24
805	1069	MSLSW	0002	1021	104.16
806	3	CWIND	6311	29	103.97
807	1006	SHDYG	7811	377	103.96
808	610	DENDR	0006	43	103.93
809	2510	BMTWN	1621	1403	103.51
810	500	GLNHV	3931	1331	103.37
811	2186	MDLNW	1531	259	103.35
812	2384	GLNHV	3983	1677	103.09
813	2389	DESPR	1408	2012	102.95
814	474	TYLNE	1605	1214	102.93
815	345	EDWDS	5921	19	102.79
816	1256	ODNTH	2013	1637	102.79
817	2857	BUFLO	2601	1178	102.66
818	331	COLNY	2405	1681	102.38
819	2515	MESTE	1213	995	101.90
820	2034	SHMNE	1407	805	101.79
821	1582	RCHHL	0363	675	101.71
822	2282	PERIN	1511	656	101.54
823	891	TMPLE	1205	2484	101.54
824	1914	OKCLS	0007	640	101.50
825	770	BARRY	1802	311	101.40
826	2395	THRNE	0004	764	101.38
827	595	ENNIS	1904	1259	101.35
828	557	MESQN	1502	1090	101.08
829	822	STAUG	0006	1811	100.84
830	1137	TYLER	1005	2006	100.65
831	1450	MNSTR	1201	672	100.62
832	69	ADISN	1601	593	100.04
833	251	ENTOH	0005	1117	99.62
834	2390	CRLTR	2002	1485	99.59
835	1167	PRSTN	0008	776	99.56
836	710	HUBRD	1402	1015	99.53

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
837	844	CLKVL	1202	1258	99.41
838	2058	BDFRD	8832	1019	99.32
839	1063	MCTYE	1721	518	99.26
840	798	RECCR	0003	210	99.24
841	774	EMPCT	0003	1361	99.23
842	380	GRDNE	9211	443	98.98
843	1659	GODRD	8141	851	98.73
844	1383	TRPMN	4023	427	98.62
845	533	LVBRD	0002	514	98.62
846	2132	REYST	4040	562	98.62
847	2037	BOWEN	3122	1270	98.56
848	809	DCVSO	1101	1484	98.52
849	1725	ROSCO	2911	526	98.51
850	2128	PCOIT	1002	732	98.37
851	2471	ADMDS	6511	1396	98.32
852	723	TYRSW	1701	2542	98.21
853	108	LWSNR	2211	1432	98.15
854	1274	WNDCR	0232	634	98.08
855	18	ELMAR	3212	37	97.92
856	913	BLMND	3231	1217	97.89
857	930	DALWT	2991	1221	97.79
858	1023	MNFLD	2672	2348	97.71
859	2284	BLMND	3241	234	97.66
860	535	MESTE	1215	1524	97.62
861	437	HUTCH	1501	1355	97.61
862	1563	CRLTR	2053	1729	97.55
863	1769	WTAUG	4641	572	97.47
864	1158	HMTRD	0003	419	97.39
865	1157	BOWEN	3171	1716	97.39
866	2774	PAYSW	1213	1453	97.35
867	827	ODNTH	2044	2143	97.34
868	967	WXNTH	2308	1082	97.29
869	2619	CTYVW	2211	1442	97.17
870	32	TSLVL	4001	1320	96.93
871	2406	GAVSW	0008	106	96.85
872	2098	HLTOM	2431	1316	96.78
873	707	SMPST	0001	2094	96.71
874	1724	MNWLL	1204	282	96.69
875	1689	MDWPK	9231	2404	96.66
876	1583	JKWST	4033	756	96.63

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
877	2646	BRKRG	0221	710	96.59
878	1746	DALWT	2931	1566	96.49
879	1192	WTAUG	4612	1251	96.46
880	636	LIGSW	1607	1466	96.34
881	2475	STAUG	0002	1423	96.33
882	1653	CDHIL	1613	3009	96.29
883	510	CNTRY	2822	2829	96.13
884	2674	LOMAL	0016	664	96.07
885	1816	ALLEN	2402	3369	95.88
886	1580	CRLTN	1406	1190	95.86
887	914	IRVHF	2305	1451	95.66
888	2713	BOWEN	3181	768	95.66
889	2935	FRMNT	0011	1304	95.63
890	2423	VGCRK	8011	1670	95.45
891	2767	MDAIR	2911	467	95.39
892	1876	MKNGB	5331	1469	95.38
893	1909	BDFWD	8912	1012	95.33
894	2568	FSTVW	0001	809	95.06
895	480	GRPVN	8212	4091	94.99
896	1413	MYPTX	2401	316	94.97
897	507	GRSMN	3027	367	94.91
898	681	LIGSW	1608	382	94.76
899	#N/A	WSMWS	9821	1045	94.67
900	466	MCKMY	0822	1396	94.59
901	449	HMTRD	0004	1058	94.39
902	2523	PRKRW	3341	223	94.25
903	1595	CTYVW	2221	1856	94.24
904	1047	STAUG	0005	1226	94.23
905	1846	CRSWS	1402	919	93.92
906	1471	MESQW	1801	2112	93.85
907	1762	GMINI	5811	3416	93.83
908	2210	OKCLS	0004	1521	93.78
909	194	SGOVL	1401	1866	93.77
910	1405	SALSW	3003	696	93.72
911	#N/A	WSMWS	9811	4745	93.66
912	86	PPARK	1805	994	93.46
913	771	BLTLN	0004	641	93.22
914	61	TYLGE	1311	838	93.18
915	1980	ARTHR	0441	1870	93.07
916	1252	WLSPT	1001	1998	93.07

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
917	1127	PFLGV	2001	5113	92.99
918	1477	JSHUA	1302	1365	92.90
919	1931	DUVAL	0434	2572	92.76
920	763	MRDCK	0001	2316	92.74
921	2199	SHAMP	0003	1772	92.68
922	1474	SPRDL	4821	1355	92.63
923	1855	MNWLE	1702	1293	92.43
924	2231	RRSTH	1706	3262	92.41
925	2704	FSCRK	6712	2674	92.33
926	2023	SSPNG	1203	1367	92.29
927	1215	CMPST	0002	1619	92.23
928	845	LOMAL	0011	1124	92.23
929	239	HKHTS	1601	1483	92.08
930	2669	KLNCC	1703	4287	91.98
931	1147	TATSP	4312	2519	91.96
932	394	DCATR	1201	1280	91.95
933	419	KEENE	1501	1603	91.88
934	565	LTLRV	1701	1098	91.72
935	219	WICKT	0411	266	91.65
936	2160	BLKST	1732	1247	91.52
937	1187	LOMAL	0003	1053	91.51
938	2620	ALPHA	0015	1242	91.49
939	1884	MESQN	1503	1858	91.33
940	381	KLNTF	1804	990	91.18
941	1718	EULSO	9112	765	91.13
942	1854	BLNKT	0701	285	91.09
943	2393	GODRD	8171	833	91.03
944	418	OAKHL	3072	2538	90.67
945	932	IRVNG	1405	1164	90.66
946	687	PCOIT	1022	2126	90.66
947	2817	TMNTH	1604	56	90.49
948	1163	WALST	0009	829	90.34
949	1530	GRDPR	0871	1568	90.26
950	649	TRIRA	6222	1006	90.08
951	939	SHRSW	6622	1516	90.04
952	1259	OVRTN	4037	107	89.87
953	964	RRNES	2403	4900	89.81
954	1500	FLINT	3212	3631	89.80
955	2159	LKHLD	0008	1458	89.41
956	978	NLNVL	2002	555	89.33

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
957	2943	LEMON	0002	983	89.33
958	1265	WRBND	2311	1419	89.19
959	496	KLELM	2205	3267	89.18
960	957	WTHRF	2001	632	89.18
961	2508	FRNKF	0004	1599	89.16
962	2901	ALPHA	0002	1256	89.10
963	2503	IRLBJ	3231	2544	89.01
964	2505	DENDR	0003	2234	88.92
965	1933	CLYVL	9321	845	88.84
966	1755	FRSCW	3701	1698	88.82
967	1520	MKNNY	1203	1008	88.73
968	2376	CRLUD	1302	149	88.67
969	155	BRLSN	2041	2460	88.60
970	1879	DALRK	1354	1950	88.58
971	690	MRTSP	1504	702	88.56
972	1462	OKLND	0002	1289	88.13
973	1011	HNRTA	0321	902	88.11
974	825	DUVAL	0462	1057	88.11
975	867	KLNPS	1101	2276	88.09
976	2080	ROLTR	2922	2787	88.00
977	2430	HRSMD	1951	4386	87.77
978	#N/A	JNDAY	3311	710	87.71
979	846	ECTHM	3321	1732	87.64
980	680	MDLNW	1582	2120	87.60
981	1234	DNINR	1401	82	87.39
982	408	THRNE	0001	1784	87.27
983	2000	EULES	8712	1076	87.21
984	1071	PPARK	1801	1338	87.20
985	950	BNBOR	1203	325	87.16
986	648	SGOVL	1404	2315	87.14
987	1542	FRSTN	1602	1283	87.12
988	1614	HSKAV	0005	1361	87.11
989	2109	WNTHW	1116	677	87.09
990	543	ODESA	0251	1906	87.01
991	1189	KLBRG	0003	1598	86.87
992	1573	WHITE	3512	1550	86.84
993	430	SIKES	2422	1096	86.76
994	620	COLNY	2403	2732	86.74
995	2254	LSCOL	2114	203	86.69
996	1419	GRPVN	8223	2069	86.54

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
997	1005	CRLJL	1507	920	86.45
998	1707	MDDTN	4331	1904	86.43
999	185	PCUST	2011	1648	86.42
1000	174	ALKLK	4222	47	86.41
1001	1287	SWTWR	1382	435	86.25
1002	1190	ELGIN	1002	2726	86.14
1003	1283	TATSP	4321	1449	85.96
1004	15	HOWRD	3911	33	85.96
1005	876	RCLNS	1407	1406	85.94
1006	1668	DUVAL	0414	657	85.73
1007	903	MTLDA	0002	1764	85.48
1008	2997	INAIR	1421	19	85.46
1009	1016	DENAV	0611	846	85.43
1010	1150	SGOVL	1402	893	85.43
1011	1299	ANDNR	2211	1017	85.42
1012	1887	HKBRY	1105	178	85.31
1013	1645	PFFRD	3472	1289	85.30
1014	84	ALNTH	2854	775	85.23
1015	996	LIGSW	1602	1112	85.21
1016	1703	LKWOD	7411	634	85.15
1017	831	FINKS	1801	1721	85.05
1018	604	IRVND	1201	973	84.97
1019	2345	TIODE	9622	977	84.85
1020	730	IRVNE	1304	649	84.72
1021	793	ECTHP	4911	1329	84.56
1022	628	COPEL	3051	1605	84.37
1023	2653	ARTHR	0411	716	84.33
1024	1110	PLSTH	1302	1006	84.32
1025	1751	FRNKS	1201	376	84.30
1026	728	SHDYG	7831	97	84.30
1027	347	PLKST	0008	1696	84.21
1028	1634	DESPR	1402	1305	84.14
1029	2157	CMPWI	0004	2686	84.14
1030	2179	BRHLW	7641	48	84.12
1031	1741	MDLNE	0131	2885	84.11
1032	1445	FLMSO	3714	1975	84.02
1033	382	TMNTH	1601	32	84.02
1034	879	ODNTH	2024	2673	83.76
1035	2354	MDLNW	1594	1653	83.68
1036	1350	IRVGS	1908	935	83.66

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
1037	214	KLBRG	0004	1258	83.60
1038	828	LWSNR	2221	1663	83.60
1039	1792	HMTRD	0001	967	83.50
1040	477	NCSTH	1503	932	83.50
1041	1586	FKLCY	5121	38	83.45
1042	284	IRVNE	1303	1704	83.40
1043	#N/A	THRDN	1921	1134	83.39
1044	1970	DEALY	0002	1482	83.38
1045	137	RHOME	2402	1353	83.37
1046	2407	RNDRK	1505	1323	83.34
1047	987	LNGLK	1602	638	83.33
1048	103	THSES	2402	923	83.09
1049	2403	PSHIL	1607	458	83.03
1050	1511	WXNTH	2306	2590	82.99
1051	1177	NHNSW	0002	405	82.91
1052	896	CRSCN	1205	757	82.91
1053	1468	IRVNE	1309	1069	82.89
1054	2248	TYWST	2003	1396	82.71
1055	2830	BNDRA	0006	675	82.67
1056	2699	DAVIS	3741	1265	82.65
1057	1709	TYLGE	1306	2459	82.64
1058	1893	TYLGE	1308	1570	82.57
1059	2096	BRLSN	2023	1856	82.53
1060	860	WEAST	0618	839	82.52
1061	616	CMTSW	0936	517	82.33
1062	71	PTENN	2351	1556	82.33
1063	1340	HURST	1841	995	82.24
1064	1637	WHITE	3541	951	82.21
1065	1184	BRCRK	6543	1676	82.14
1066	2563	COPEL	3054	832	82.08
1067	621	IRVVV	2802	1051	82.03
1068	928	ELKHR	1201	965	81.97
1069	527	ELKTN	2501	783	81.93
1070	1328	ODESW	5211	506	81.93
1071	1098	KNEDL	6321	2461	81.92
1072	1965	FRMBG	1705	279	81.85
1073	2029	GRDPR	0852	1454	81.76
1074	1928	IRVBL	2507	890	81.74
1075	2632	RSNHT	1131	3043	81.63
1076	2290	MESTE	1211	1200	81.53

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
1077	1730	TYOMN	1402	1617	81.53
1078	1912	LWSNR	2241	1084	81.48
1079	1451	EULES	8722	2135	81.48
1080	924	BDFRD	8821	882	81.45
1081	2479	HLTOM	2421	1581	81.12
1082	311	REYST	4118	741	80.99
1083	2091	MURPH	2751	2349	80.97
1084	1408	LWRDR	0003	1796	80.91
1085	1346	KLRPR	9011	2745	80.83
1086	934	NCRST	2201	1957	80.78
1087	739	CRSCN	1203	2000	80.76
1088	8	SNDHL	3821	16	80.75
1089	363	WXHCH	1204	1844	80.74
1090	1681	HKBRY	1117	136	80.74
1091	1625	DALLW	0006	1985	80.66
1092	1375	WALST	0005	233	80.64
1093	897	OKLND	0001	1232	80.50
1094	1362	HRSMD	1905	2834	80.35
1095	576	MSHLN	0006	1106	80.32
1096	2544	ENTOH	0007	969	80.24
1097	1208	TATSP	4323	2489	80.22
1098	2118	RWALL	1201	1321	80.13
1099	954	GNSVL	1203	1642	80.12
1100	2418	PLSTN	1005	1900	80.06
1101	296	IRVNG	1408	1072	79.95
1102	1062	MDWCK	0001	819	79.90
1103	1065	PREST	1601	1184	79.87
1104	2142	SYCRK	4532	1131	79.85
1105	1677	IRVNE	1306	1530	79.84
1106	2398	MEXIA	4040	843	79.79
1107	1670	CRLTR	2052	1554	79.79
1108	1004	HLSBR	1202	1237	79.71
1109	586	PLGRV	0002	2370	79.65
1110	341	CNTRY	2842	1151	79.61
1111	1381	RSPVY	1704	1398	79.58
1112	2139	RCHRD	1201	1433	79.52
1113	221	GVODS	3052	1334	79.45
1114	#N/A	BLMND	3272	12	79.40
1115	1368	TAYLR	1204	2023	79.35
1116	1570	LKHLN	0007	1220	79.31

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
1117	1553	CDHCR	2050	808	79.18
1118	558	FRMNT	0003	839	79.06
1119	269	CRNDL	2403	1038	79.03
1120	1592	EZACH	0004	1161	78.76
1121	743	SWTWR	1341	250	78.70
1122	1549	CLYVL	9322	2202	78.66
1123	1033	HOLDY	0911	1143	78.60
1124	455	ALDTU	9411	3013	78.54
1125	2860	ARMST	0008	247	78.48
1126	2842	ALPHA	0006	294	78.39
1127	2332	WHTRK	0001	2716	78.36
1128	631	BRKRG	0223	290	78.31
1129	102	LVOAK	1602	977	78.31
1130	826	JNKNS	0003	903	78.30
1131	1325	IRVVV	2801	2450	78.26
1132	2008	MESFR	2105	1025	78.19
1133	1889	CDHCR	2054	1471	77.90
1134	2318	BRHLW	7611	1629	77.76
1135	1671	WRIDG	3054	2391	77.55
1136	619	BRHLW	7651	1144	77.46
1137	937	LNDAL	2201	1977	77.45
1138	1920	FRMBR	1801	1244	77.34
1139	810	DCVSO	1103	1847	77.28
1140	765	IRVNG	1402	1135	77.07
1141	823	TYSTH	1202	1054	77.06
1142	989	RKDLN	1401	932	77.02
1143	338	TYBLR	2805	2248	76.92
1144	2514	TLRWT	2201	1948	76.84
1145	73	BNBRK	4122	3009	76.77
1146	#N/A	ODNTH	2015	578	76.63
1147	2904	ARTHR	0462	213	76.63
1148	172	ALNSW	2654	1984	76.58
1149	1118	BOWEN	3151	1932	76.57
1150	2087	LNCST	1602	1913	76.54
1151	2695	EGFRD	0005	1000	76.44
1152	1182	CDCSW	0006	1375	76.37
1153	2703	MEANS	4411	38	76.34
1154	1024	OAKHL	3031	620	76.24
1155	2595	ALNTH	2851	2138	76.19
1156	2228	EULES	8723	5150	76.01

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
1157	402	KERNS	2401	546	75.93
1158	2361	ADISN	1605	1325	75.88
1159	544	HUTTO	2742	3095	75.87
1160	912	VENSW	2603	31	75.86
1161	1298	BSPRW	2532	1602	75.78
1162	1111	MLDR2	1603	521	75.71
1163	332	MLFRD	2103	1007	75.61
1164	1139	MESQW	1804	1324	75.53
1165	2003	NAVCO	0001	20	75.39
1166	2484	PJPTR	3211	116	75.30
1167	1992	BONHM	1204	835	75.25
1168	142	CHYNE	9121	80	75.10
1169	2900	CHROW	0006	91	75.03
1170	293	JEWET	1204	1326	75.01
1171	1390	MESTE	1206	1287	74.99
1172	1454	KFMNW	1202	871	74.85
1173	1338	PCOIT	1001	1236	74.83
1174	2045	PLKST	0007	1783	74.77
1175	589	LWRDR	0001	1172	74.75
1176	1433	REGST	0004	917	74.70
1177	2559	DAVST	0008	1628	74.63
1178	659	LKMNT	0002	993	74.52
1179	2286	MDWCK	0004	1745	74.50
1180	2083	IRVVV	2851	2944	74.44
1181	801	BNBRK	4112	2258	74.30
1182	3026	WOVER	6131	2438	74.22
1183	39	ANARN	1911	17	74.19
1184	217	BRNCH	1411	549	74.18
1185	2856	MKNGB	5311	473	74.09
1186	1199	LIGSW	1621	47	74.08
1187	547	SPRDL	4811	1373	74.08
1188	2517	AIRPK	8411	807	73.93
1189	497	MAYFD	5524	2596	73.80
1190	145	MDTHN	1703	1050	73.78
1191	2092	SHMNE	1401	1226	73.56
1192	1436	RENSW	3121	1952	73.54
1193	1945	WTHRF	2002	1774	73.53
1194	2431	COTRD	0003	112	73.45
1195	789	MRSDO	9611	1897	73.38
1196	995	GVODS	3072	2316	73.29

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
1197	2681	PRKWY	1542	518	73.24
1198	1964	EULES	8711	2052	73.21
1199	2451	IOWPK	0821	747	73.21
1200	2016	MDTHS	1002	1506	73.20
1201	169	TYLER	1002	862	73.18
1202	1083	LMBLN	0003	177	73.17
1203	2672	TERSO	2501	190	73.05
1204	2329	HUDSN	1602	1720	72.98
1205	2634	WEBBS	8624	2358	72.91
1206	777	ARLNG	1251	565	72.89
1207	1801	LFSTH	1404	505	72.74
1208	2234	CRLTR	2054	107	72.71
1209	2155	PFLGV	2002	2273	72.67
1210	1109	MESFR	2101	2025	72.67
1211	2648	ROLTR	2911	1817	72.67
1212	1370	LKMNT	0007	1536	72.65
1213	1094	RWALS	1853	2440	72.65
1214	759	KLNPS	1102	1914	72.59
1215	2073	BRNAV	0723	1348	72.57
1216	101	CLCTY	1011	951	72.41
1217	2154	GRFRD	1002	391	72.38
1218	997	COLNY	2401	744	72.37
1219	2217	CTYVW	2222	1358	72.30
1220	1535	PRSTN	0002	1330	72.03
1221	1482	WTAUG	4623	731	71.93
1222	1594	DUVAL	0421	1351	71.88
1223	787	ALPHA	0010	516	71.83
1224	2170	BLTON	1802	1459	71.78
1225	1285	MRDCK	0002	1707	71.77
1226	1766	CNTRY	2823	1883	71.76
1227	2093	NHNSW	0006	676	71.75
1228	2843	CMPST	0003	208	71.74
1229	1937	IRVNR	1506	2958	71.52
1230	385	HMTRD	0002	2200	71.52
1231	434	ADISN	1604	1152	71.38
1232	1000	CLKVL	1201	420	71.36
1233	2529	MESQW	1808	1338	71.35
1234	1086	RENSW	3122	1430	71.29
1235	1578	HKHTS	1604	917	71.19
1236	1466	BLKST	1711	2035	71.14

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
1237	612	LNCST	1605	813	71.13
1238	1480	DESPR	1407	952	71.09
1239	1360	RSPCK	2104	1981	71.06
1240	2264	ATHNS	1202	787	70.92
1241	143	NCSTH	1501	790	70.91
1242	1962	HLSES	0542	757	70.88
1243	2191	BLTLN	0001	676	70.85
1244	783	HNYGR	2401	625	70.83
1245	2343	HLTOM	2411	1449	70.78
1246	835	GODRD	8132	2719	70.57
1247	114	MNFLD	2682	2482	70.53
1248	2818	GODRD	8161	2229	70.50
1249	2365	DAVIS	3772	1731	70.38
1250	#N/A	CHYNE	9122	36	70.32
1251	1353	CMPST	0001	416	70.32
1252	1103	KIMBL	5021	2377	70.31
1253	2311	MKNNY	1254	1283	70.23
1254	1060	KLNCC	1702	3846	70.12
1255	1890	MNWLW	1401	1520	70.05
1256	2158	GODRD	8122	1066	70.03
1257	2247	MDDTN	4321	825	69.98
1258	2436	LOMAL	0010	1519	69.96
1259	819	WHTRK	0008	1545	69.89
1260	1802	CDHIL	1801	1051	69.80
1261	267	PCOIT	1006	1043	69.75
1262	1891	DESHR	1208	476	69.64
1263	756	CMINO	1206	1075	69.53
1264	1642	RWDHV	1906	638	69.45
1265	1106	LUFKN	1201	1339	69.43
1266	1574	GRDPR	0842	1348	69.36
1267	1847	GVODS	3031	1371	69.33
1268	1974	STNVL	1202	82	69.28
1269	218	TRNTY	7541	667	69.11
1270	472	BNBRK	4121	5048	69.08
1271	2618	FSTVW	0007	1613	68.93
1272	176	TMPLE	1203	124	68.81
1273	1763	PLANO	1105	56	68.68
1274	2145	TAYLR	1203	1301	68.67
1275	475	COVEE	3405	1417	68.56
1276	983	RANGR	4311	889	68.53

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
1277	2220	BLKST	1781	1934	68.53
1278	227	ODESA	0231	2140	68.37
1279	1556	IRVNR	1508	2034	68.31
1280	1758	COPEL	3055	2157	68.22
1281	191	DALLW	0004	1332	68.22
1282	495	CNTRY	2811	2862	68.16
1283	1022	BKBNT	1832	182	68.09
1284	2078	IRVVV	2853	3863	68.07
1285	393	CDCSW	0005	1827	67.97
1286	780	RWALS	1852	2305	67.91
1287	2117	IRVNG	1403	521	67.83
1288	904	PARIS	1206	1021	67.80
1289	575	BLMND	3213	3286	67.78
1290	340	RYSSW	2802	3090	67.76
1291	1195	KFMSSO	1301	938	67.74
1292	1603	CRLJL	1505	938	67.71
1293	1559	CRNTH	2401	2583	67.54
1294	1780	MKNSW	1601	1607	67.51
1295	2996	HMPHL	2723	48	67.47
1296	1327	PALMR	2202	1114	67.42
1297	624	BSPRG	1903	1714	67.37
1298	372	RDOAK	1302	1401	67.33
1299	776	WKATY	1718	1744	67.26
1300	1494	BAKKE	6911	301	67.25
1301	303	CRNRD	0006	350	67.19
1302	872	BRHLW	7642	968	67.03
1303	1334	IRVNR	1559	2618	67.00
1304	1125	HORNE	1914	1024	66.98
1305	972	TRNTY	7511	1408	66.95
1306	755	CRTLD	4711	3187	66.94
1307	517	SPRTN	1802	910	66.94
1308	488	MKNNY	1202	1911	66.82
1309	2725	CRLFR	2159	1508	66.74
1310	2820	BRYAN	0001	15	66.73
1311	2917	PSHIL	1606	1548	66.71
1312	200	SHLMT	1802	548	66.56
1313	2553	WXHNW	2901	179	66.51
1314	2424	MSHLN	0007	726	66.50
1315	911	PRKRW	3311	1132	66.37
1316	465	EZACH	0008	1523	66.32

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
1317	1099	LUFKN	1205	1334	66.27
1318	1607	HURST	1861	1863	66.25
1319	821	CRLTR	2003	1350	66.22
1320	337	JSHUA	1301	1016	66.17
1321	856	RICES	0206	677	66.13
1322	738	EULSO	9122	1295	66.10
1323	2075	RCHHL	0342	1012	66.07
1324	446	BLTLN	0003	595	66.01
1325	1168	CPRCV	1407	2229	65.94
1326	1485	PRNTH	1401	1312	65.86
1327	1403	BRNAV	0741	2013	65.82
1328	941	LSCOL	2116	94	65.77
1329	1053	CNTRD	0002	1478	65.73
1330	1546	NMAIN	0272	392	65.65
1331	1034	RWDHV	1907	878	65.64
1332	2444	COVEE	3403	1427	65.57
1333	1950	CRLJL	1503	751	65.52
1334	1132	CRNRD	0001	733	65.52
1335	1632	POWEL	2706	241	65.48
1336	123	MDLNE	0151	307	65.43
1337	1610	HUDSN	1601	985	65.25
1338	2225	ROWLT	1104	1150	65.14
1339	2102	SYCRK	4512	4367	64.88
1340	548	WDGWD	1541	1133	64.83
1341	243	LMESA	1531	619	64.74
1342	577	DNCNV	1903	1195	64.65
1343	3013	RNGMG	8421	10	64.63
1344	1871	WDGWD	1561	1505	64.63
1345	1591	EZACH	0003	1290	64.51
1346	2664	LIGSW	1604	686	64.51
1347	1705	FRMBG	1703	30	64.49
1348	2952	DNINR	1402	393	64.47
1349	1835	CLBNR	1404	1253	64.47
1350	1311	SANSM	3913	4698	64.41
1351	562	ATNRN	3411	3012	64.40
1352	36	GYVLM	8611	12	64.34
1353	1148	BLTSW	3201	2588	64.31
1354	1209	PRSTN	0004	671	64.20
1355	1261	BONHM	1206	2155	64.17
1356	2562	ENTOH	0001	944	64.16

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
1357	760	MOSSW	4621	2140	64.15
1358	1229	BKWST	0007	1779	63.97
1359	2028	ADMDS	6521	1596	63.96
1360	2059	MRLNS	4003	928	63.91
1361	542	FHLSW	1351	1454	63.88
1362	2597	PRCRK	0002	1586	63.88
1363	2317	FORSW	2015	3706	63.86
1364	409	BRKTN	1202	124	63.86
1365	1968	DNISN	1205	1562	63.78
1366	732	KFMNW	1201	1026	63.77
1367	1046	WMRLD	0005	1614	63.72
1368	78	SSPSW	1604	1267	63.68
1369	2723	PALRD	2207	1130	63.56
1370	361	TYLNE	1607	811	63.51
1371	908	MDLNW	1532	2020	63.37
1372	2925	FARON	4021	287	63.36
1373	2896	RSPCK	2132	69	63.26
1374	2574	TYLNE	1624	97	63.25
1375	839	BLTON	1803	549	63.11
1376	2163	MKNSO	3614	2475	63.10
1377	531	SSPNE	1401	1344	63.06
1378	2831	HKBRY	1102	1708	63.04
1379	2269	RRNES	2404	4462	63.03
1380	352	LMBLN	0001	1973	63.01
1381	1716	BLVUE	1111	350	62.99
1382	410	HKBRY	1101	550	62.95
1383	645	MKNNY	1252	3113	62.92
1384	546	WMRLD	0002	1563	62.90
1385	1216	EZACH	0001	979	62.84
1386	566	WXHCH	1201	1760	62.78
1387	2253	CHROW	0002	108	62.73
1388	224	CDHIL	1623	2194	62.73
1389	2120	DESPR	1401	1879	62.61
1390	1463	CRLJL	1506	1960	62.58
1391	1301	CRYVE	3021	1300	62.42
1392	2409	SHDYG	7832	783	62.40
1393	1501	SWDTN	1631	1587	62.32
1394	1630	ROWLT	1106	1329	62.24
1395	1649	LUFKN	1208	1785	62.22
1396	2806	DPCRK	1842	1398	62.00

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
1397	1954	BNTDR	0004	1912	62.00
1398	2470	CMNCH	1401	1193	61.91
1399	2546	PLGRV	0001	1196	61.91
1400	1249	CPRCV	1405	1541	61.89
1401	193	SIKES	2411	2048	61.88
1402	2790	BRTL	1402	126	61.83
1403	644	PWEST	1307	962	61.82
1404	1179	IRVBL	2505	493	61.79
1405	#N/A	DENAV	0622	603	61.69
1406	450	PRNTH	1404	1496	61.65
1407	829	EDDYS	0712	1097	61.64
1408	2249	PSHIL	1608	1933	61.61
1409	921	BDFRD	8822	1050	61.45
1410	1226	MESQT	1304	653	61.43
1411	1303	IRVND	1204	1346	61.40
1412	2046	WHTRK	0007	1242	61.34
1413	485	CLBRN	1206	1023	61.32
1414	2625	HUTCH	1505	25	61.13
1415	471	MNWLW	1402	1537	61.11
1416	288	ROANW	9522	48	61.07
1417	2472	HORNE	1923	1254	61.04
1418	2377	DALWT	2921	284	61.04
1419	1621	BLTLN	0006	921	60.98
1420	848	HKHTS	1606	2022	60.97
1421	1938	DALLW	0005	126	60.88
1422	1406	MEXIA	4024	344	60.86
1423	590	TMPLE	1201	1715	60.79
1424	2729	PROAD	0003	1103	60.66
1425	2531	RTHGB	1421	1469	60.59
1426	1805	CLCTY	1031	1231	60.54
1427	447	KNLTR	0003	626	60.51
1428	1154	PSHIL	1603	1668	60.44
1429	1532	BDFRD	8842	1337	60.41
1430	1185	CDCRK	1201	1259	60.37
1431	1251	BDFRD	8812	765	60.24
1432	1567	RCHRD	1203	835	60.10
1433	1541	CRLFR	2154	3458	60.08
1434	1441	LWSNR	2212	1410	59.94
1435	277	CANTN	1302	1367	59.86
1436	2349	FARON	4041	1026	59.85

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
1437	2408	KNEDL	6322	3992	59.81
1438	2116	MCDMT	2551	3813	59.75
1439	1845	LKBRN	2401	699	59.55
1440	715	WMRNR	0001	196	59.49
1441	2325	WNDWD	3631	316	59.37
1442	1241	CNEXP	0006	1344	59.31
1443	3008	PCOMM	3311	33	59.29
1444	2513	GNSVL	1223	1255	59.23
1445	2005	HKHTS	1607	960	59.16
1446	1825	KLRPR	9021	2046	59.03
1447	1253	MESQW	1807	1497	58.95
1448	1052	ALNSW	2652	3665	58.83
1449	1080	MESQT	1305	1152	58.76
1450	1529	WSTHL	3652	3130	58.66
1451	1806	TYEST	1506	475	58.63
1452	2051	PEGAS	2321	139	58.46
1453	2099	MDWPK	9221	747	58.39
1454	2847	ARMST	0006	1010	58.34
1455	2416	BLMND	3221	96	58.34
1456	1988	TMSTH	1401	1826	58.32
1457	1352	MOSSW	4611	1063	58.29
1458	479	FSCRK	6723	4529	58.27
1459	2012	PKRVL	1053	1145	58.21
1460	1239	LKMNT	0004	2180	58.16
1461	313	NMAIN	0211	1927	58.15
1462	2540	WNDCR	0241	690	58.06
1463	2385	BRKNR	1221	1146	58.03
1464	2258	HORNE	1933	1186	58.03
1465	386	DAVST	0006	1310	58.01
1466	2323	SMFLD	2381	853	57.99
1467	422	FARON	4011	623	57.99
1468	2245	BRNSO	1806	2237	57.94
1469	2557	WFALS	0114	419	57.91
1470	2528	PLKST	0001	789	57.79
1471	163	MDTHN	1702	1452	57.73
1472	943	GSMTH	1742	29	57.72
1473	1291	KILEN	1205	1351	57.59
1474	1395	MNWLL	1206	1120	57.50
1475	1227	PRFTW	4211	3896	57.44
1476	389	CMHBL	8121	51	57.41

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
1477	1113	TRLWD	7722	4065	57.28
1478	574	SWDTN	1641	1564	57.25
1479	1981	LVBRD	0005	1394	57.12
1480	963	BKBNT	1821	1145	57.03
1481	757	PROAD	0006	140	56.97
1482	1258	TATSP	4313	1612	56.96
1483	253	DALRK	1309	901	56.94
1484	2661	CLLVL	0003	625	56.92
1485	2755	PFFRD	3452	853	56.91
1486	894	PFFRD	3441	1200	56.90
1487	2230	TMNTH	1602	476	56.89
1488	1787	CRLFR	2152	3538	56.87
1489	212	LVOAK	1601	889	56.86
1490	559	MSTLT	1063	1304	56.82
1491	257	PPARK	1804	248	56.81
1492	165	BLMED	1619	84	56.75
1493	2789	RWDHV	1908	2421	56.60
1494	1800	ALVDO	1901	1587	56.59
1495	871	ARLNG	1241	657	56.56
1496	960	GODRD	8112	1434	56.43
1497	371	ENTOH	0002	921	56.39
1498	403	TYEST	1503	1065	56.30
1499	1844	CRTLD	4721	3049	56.28
1500	581	WSTHL	3631	3845	56.24
1501	1018	TAYLR	1201	1788	56.19
1502	2493	CRTLD	4742	911	56.16
1503	718	ADISN	1607	1226	56.15
1504	1823	TMPTV	2404	1451	56.12
1505	2296	CLMET	0001	1592	56.10
1506	2314	CRLFR	2155	1331	56.10
1507	1961	MESFR	2102	675	56.09
1508	2019	CRLJL	1502	386	56.03
1509	946	GNSVE	1602	1725	56.03
1510	1525	REAST	1506	1205	56.02
1511	779	SCYEN	0002	2010	56.00
1512	1750	CRNTH	2405	4145	55.96
1513	720	DCVSO	1102	689	55.95
1514	445	WEBBS	8622	1681	55.91
1515	2714	CNEXP	0002	1150	55.88
1516	1074	GLSCN	6221	19	55.85

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
1517	273	MSLMN	4131	134	55.72
1518	1312	LNCST	1603	1710	55.65
1519	405	ALLEN	2410	2388	55.64
1520	2722	BRKRG	0211	310	55.62
1521	2766	HORNE	1912	1796	55.47
1522	790	CDHCR	2052	1405	55.44
1523	1356	EULES	8731	1425	55.39
1524	2877	LEMON	0008	995	55.36
1525	802	RSPCK	2108	953	55.29
1526	2386	FRMBG	1750	48	55.22
1527	899	CDCSW	0004	1393	55.07
1528	2435	WBOSE	1102	355	55.06
1529	1035	CLKVL	1203	615	55.03
1530	1656	FSHSW	2121	1706	54.98
1531	865	PRFTW	4221	1381	54.83
1532	1717	RSPCK	2102	1570	54.82
1533	521	WHOUS	4122	2246	54.75
1534	1333	TYOMN	1405	1684	54.64
1535	1087	HLSES	0561	1821	54.63
1536	2762	MSHLN	0004	1303	54.62
1537	2338	DGNST	0007	531	54.58
1538	2838	ARMST	0011	859	54.54
1539	630	TYEST	1508	633	54.41
1540	2938	PLANO	1101	409	54.39
1541	1225	ARLNG	1213	1324	54.39
1542	2068	BRNSO	1801	1632	54.38
1543	874	GRAHM	0711	1605	54.36
1544	812	REAST	1505	1010	54.33
1545	2441	BANGS	1201	1498	54.33
1546	775	CANTN	1301	2168	54.26
1547	1120	NCSTH	1506	95	54.25
1548	1078	MCWHT	3522	2995	54.24
1549	2148	PAULN	2503	935	54.22
1550	1296	GRLND	1606	969	54.20
1551	948	WITTS	1703	1547	54.14
1552	889	KILEN	1204	1578	54.09
1553	2446	ROWLT	1105	1072	53.84
1554	587	IRVRS	4411	981	53.83
1555	772	RCHRD	1202	796	53.77
1556	515	IRVND	1205	223	53.75

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
1557	1326	HSKAV	0002	1760	53.75
1558	623	FORSW	2051	1987	53.74
1559	685	KILEN	1202	1745	53.73
1560	262	WELRD	0003	530	53.70
1561	2161	PRCTR	1601	200	53.67
1562	926	CLBNR	1402	2468	53.50
1563	1963	TATSP	4311	1873	53.50
1564	1865	MKNGB	5342	1301	53.36
1565	805	CKRHL	0001	436	53.27
1566	2229	PCUST	2001	578	53.23
1567	414	GSMTH	1721	44	53.18
1568	1246	WELRD	0002	742	53.15
1569	1206	ALVDO	1902	960	53.08
1570	1134	PRKRW	3392	1536	53.05
1571	2461	ALPHA	0008	1785	53.03
1572	2474	MSTLT	1073	105	53.01
1573	1721	DALRK	1303	1442	52.97
1574	858	DALRK	1305	1169	52.90
1575	518	ROLTR	2921	2434	52.86
1576	2100	ARLNG	1292	1565	52.85
1577	2972	DELTA	1702	490	52.79
1578	255	DCATR	1202	1690	52.73
1579	725	FRMNT	0002	657	52.65
1580	#N/A	HORNE	1931	935	52.62
1581	519	CPRCV	1404	1624	52.41
1582	210	PRKWY	1511	1304	52.40
1583	505	MESQN	1504	1350	52.39
1584	2481	EDGCF	2211	2105	52.35
1585	2287	PALRD	2201	795	52.28
1586	2190	ALVRD	1504	166	52.12
1587	2319	CPRCV	1401	1898	52.05
1588	1534	RDRSE	2603	2822	52.04
1589	1815	KLNCC	1701	2358	52.02
1590	2048	BRCRK	6524	798	51.93
1591	1708	PKRVL	1051	4794	51.89
1592	2152	CNEXP	0003	1414	51.80
1593	237	DCATR	1203	973	51.72
1594	2397	FSCRK	6711	3771	51.71
1595	2138	NPKWY	0010	3026	51.70
1596	735	GNSVE	1603	1719	51.65

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
1597	2076	MRTSP	1501	695	51.61
1598	1824	SHMNE	1409	915	51.52
1599	2372	MDWCK	0003	1716	51.48
1600	976	PCUST	2010	2264	51.46
1601	2194	BRIRV	6912	821	51.29
1602	1488	RBNSN	2501	1990	51.27
1603	888	RCLNS	1405	641	51.26
1604	2654	HNRTA	0311	1062	51.22
1605	400	FRMBR	1805	748	51.21
1606	1838	RANGR	4321	836	51.08
1607	1397	KLNTF	1805	1350	51.00
1608	1648	LNCST	1601	690	50.96
1609	2189	WNTHW	1119	1321	50.91
1610	766	CRLJL	1504	1312	50.87
1611	1076	MNWLL	1203	869	50.86
1612	2939	RRNES	2401	2785	50.79
1613	2346	WXNTH	2302	1670	50.79
1614	991	LEMON	0009	1094	50.70
1615	2293	WNDWD	3682	788	50.67
1616	74	PGSTH	7012	169	50.58
1617	188	LOMAL	0001	703	50.57
1618	1305	CRLUD	1305	1425	50.57
1619	2491	PALRD	2208	1009	50.53
1620	1465	KRUMS	1202	744	50.53
1621	467	TRNTH	1502	567	50.43
1622	2702	RCHHL	0374	545	50.40
1623	2538	CRTLD	4724	3171	50.40
1624	2330	BLTSW	3203	1105	50.28
1625	1919	MSLSW	0008	187	50.24
1626	1426	LOMAL	0006	1415	50.22
1627	208	SANSM	3922	1842	50.14
1628	979	CLBRN	1204	1194	50.08
1629	2224	WATCO	2605	2710	50.07
1630	2706	WMMMR	2702	1842	49.92
1631	1593	PKRMX	4701	2915	49.92
1632	1783	FHLSW	1361	995	49.89
1633	560	LGVST	8521	1805	49.88
1634	1976	SMFLD	2341	979	49.83
1635	186	ROBNW	1503	1409	49.80
1636	2070	MKNSW	1602	834	49.77

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
1637	1476	MESQT	1302	666	49.74
1638	758	MRDCK	0004	846	49.70
1639	1059	CRNSO	3911	531	49.63
1640	1977	SMPST	0002	1481	49.62
1641	697	IRLBJ	3211	2683	49.59
1642	702	CDHIL	1804	1260	49.58
1643	1902	SUNNY	2301	636	49.55
1644	2590	WFALS	0143	177	49.54
1645	582	HUDSN	1604	1801	49.49
1646	1036	TMPLE	1202	1366	49.44
1647	2375	CDHCR	2051	2122	49.42
1648	1536	LAVON	1452	2048	49.39
1649	3006	LVBRD	0001	39	49.28
1650	428	KNEDL	6312	3289	49.26
1651	1248	KLNPS	1103	2195	49.26
1652	442	SMFLD	2333	1065	49.12
1653	1341	ALVRD	1501	1198	49.10
1654	731	ALPHA	0003	863	49.05
1655	2336	MDLNW	1513	2457	49.05
1656	965	SALSW	3004	1492	48.78
1657	1772	HORNE	1934	1681	48.75
1658	2622	CRNSO	3913	1660	48.74
1659	2025	WXNTH	2305	150	48.74
1660	3021	WEAST	0628	275	48.59
1661	1690	RCHRD	1207	1547	48.59
1662	1674	MLFRD	2101	1267	48.50
1663	2421	WNDWD	3652	1013	48.46
1664	968	REYST	4129	532	48.39
1665	325	CRANE	0331	1220	48.37
1666	2602	FRSCW	3703	2377	48.27
1667	1342	CLBRN	1201	1802	48.24
1668	2260	SLAKE	8312	2926	48.23
1669	1196	WESTS	1601	1077	48.23
1670	2705	FARON	4082	1439	48.20
1671	444	PCOIT	1003	1502	48.07
1672	1840	MESQN	1505	1425	48.04
1673	729	CMPWI	0005	1638	48.03
1674	711	SHAMP	0004	1153	48.00
1675	1017	BRLSN	2013	1078	47.95
1676	1293	TMNTH	1605	1855	47.88

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
1677	1345	OAKHL	3052	781	47.75
1678	1538	HKHTS	1602	1035	47.74
1679	1012	WITTS	1707	772	47.65
1680	2621	JUDCT	0003	1798	47.64
1681	2090	PFFRD	3492	298	47.62
1682	915	CLBRN	1203	1589	47.56
1683	1675	WNDWD	3621	2217	47.49
1684	355	ENSSO	2004	1253	47.43
1685	1123	WTAUG	4652	806	47.41
1686	1745	HUBRD	1401	912	47.29
1687	655	BRIRV	6921	2434	47.26
1688	1554	LOMAL	0013	1067	47.13
1689	762	MURPH	2752	1204	47.02
1690	564	SCHRD	0002	295	47.01
1691	1487	OVRTN	4019	660	47.00
1692	2301	PRKRW	3321	164	46.92
1693	398	DNCNV	1904	1473	46.86
1694	1803	PSHIL	1601	1416	46.85
1695	1439	BRCRK	6514	579	46.84
1696	2586	SWDTN	1611	1487	46.83
1697	1550	CNTRY	2813	3096	46.70
1698	463	WXNTH	2304	870	46.69
1699	305	PROAD	0002	834	46.68
1700	1669	STAUG	0007	1199	46.67
1701	1918	INAIR	1432	2941	46.67
1702	1165	RCHRD	1205	1030	46.66
1703	806	PREST	1602	1572	46.64
1704	683	THRNE	0005	1365	46.60
1705	709	WLSPT	1002	610	46.58
1706	1495	GRNGR	1801	913	46.55
1707	2829	DAVIS	3752	503	46.55
1708	795	LKBRN	2402	1154	46.51
1709	717	RSNHT	1181	1718	46.51
1710	1133	THRNE	0002	1695	46.41
1711	2304	CRTL D	4722	4452	46.39
1712	1456	MKNGB	5312	677	46.38
1713	974	CRLTR	2005	674	46.36
1714	2802	MNFLD	2621	2316	46.31
1715	2149	SMFLD	2313	2118	46.21
1716	2604	ITSCA	1702	207	46.18

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
1717	1459	PALRD	2204	694	46.16
1718	843	WHTRK	0004	1158	46.12
1719	1273	DALRK	1301	1271	46.02
1720	2587	RWALL	1202	2661	45.95
1721	2201	AMLIA	0008	108	45.85
1722	2226	GSTHW	1623	2396	45.80
1723	263	ALLNC	6421	71	45.71
1724	2449	SHRSW	6631	1300	45.69
1725	883	CPLSO	4311	90	45.67
1726	1193	RWDHV	1901	922	45.64
1727	1539	GVFTW	1801	709	45.59
1728	984	ABRRD	0005	1527	45.44
1729	1092	HLSBR	1203	1652	45.38
1730	1560	NHNSW	0007	585	45.24
1731	981	ITALY	2101	593	45.22
1732	742	EULES	8713	1588	45.19
1733	1038	TYLNW	1912	2102	45.17
1734	2018	CRLUD	1303	623	45.17
1735	1260	CLCRK	1011	201	45.16
1736	1747	MCGRG	0775	532	45.10
1737	1411	WEAST	0629	1593	45.04
1738	50	BNMAG	1201	248	45.01
1739	368	IRVGS	1907	967	44.95
1740	2440	BAYLC	1201	121	44.91
1741	1710	ECTOR	1201	392	44.90
1742	330	TYWST	2004	995	44.78
1743	2501	CRLTN	1408	132	44.77
1744	2931	HMPHL	2711	778	44.76
1745	181	BRLSN	2033	1689	44.71
1746	561	HSKAV	0006	756	44.64
1747	1149	MNWLL	1207	2129	44.61
1748	1794	RBNSN	2504	1684	44.54
1749	2967	COTRD	0006	549	44.48
1750	494	KNLTR	0008	771	44.41
1751	1813	HMPHL	2762	1045	44.38
1752	949	CLNSE	4201	968	44.36
1753	1596	BSPRG	1904	1666	44.10
1754	1377	DAVST	0005	1820	44.08
1755	1540	PCOIT	1007	781	44.07
1756	1791	RCHHL	0353	1722	44.03

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
1757	1943	IRVGS	1902	1500	44.02
1758	2167	MKNSO	3613	3325	43.97
1759	695	DALWT	2982	1027	43.76
1760	1676	BRNWD	1206	1359	43.73
1761	2066	FSCRK	6732	3924	43.71
1762	2184	WRTHM	5012	316	43.68
1763	1698	CHNDW	1203	851	43.66
1764	2611	WHITE	3542	1639	43.64
1765	1032	ODESA	0272	1340	43.61
1766	1577	NHNSW	0001	473	43.50
1767	614	RDOAK	1304	3542	43.40
1768	1322	FHLSW	1372	1320	43.40
1769	980	SCYEN	0003	1949	43.36
1770	592	MNRVA	1301	751	43.30
1771	1983	KLNSO	4501	3575	43.30
1772	3015	RVRFT	0001	27	43.23
1773	1900	AIRPK	8432	945	43.18
1774	112	PMBRK	1811	20	43.13
1775	2150	GRDPR	0891	892	43.07
1776	654	RDOAK	1301	2521	43.02
1777	37	MAYFD	5521	3909	42.96
1778	1214	MURPH	2754	2212	42.91
1779	2970	CRLUD	1301	25	42.85
1780	#N/A	ALKLK	4223	70	42.85
1781	2178	LKWOD	7442	723	42.84
1782	947	LSCOL	2148	1583	42.75
1783	1101	IRVHF	2302	1410	42.75
1784	1987	HLTOM	2472	1811	42.68
1785	2985	ENTOH	0003	12	42.67
1786	1336	WWDWY	2015	1221	42.64
1787	272	WNRTH	1421	1490	42.59
1788	609	PREST	1603	1534	42.58
1789	1619	DIBOL	1506	565	42.51
1790	2044	COYNW	8111	60	42.50
1791	752	QNLAN	1201	846	42.42
1792	2677	SMFLD	2391	297	42.41
1793	1995	KLNSO	4502	3608	42.41
1794	1771	DALLW	0007	439	42.38
1795	195	IRVND	1208	166	42.37
1796	2453	CRLTN	1402	931	42.35

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
1797	1666	SHRSW	6611	1231	42.34
1798	241	PRKRW	3362	1100	42.30
1799	2732	HORNE	1922	1465	42.28
1800	1723	PLKST	0004	1221	42.26
1801	1470	RCHRD	1204	1146	42.21
1802	2356	WRTHM	5004	224	42.18
1803	931	BLTLN	0005	892	42.16
1804	670	CPRCV	1402	2214	42.15
1805	1623	MESQT	1303	838	42.14
1806	852	WEBBS	8633	2488	42.07
1807	2108	FSTVW	0006	1233	42.03
1808	840	GRDPR	0892	1331	41.99
1809	2141	IRVRS	4413	1670	41.97
1810	1585	BAKKE	6912	1479	41.88
1811	2277	WDGWD	1572	1479	41.87
1812	1996	ALNSW	2651	2172	41.86
1813	1097	DAVST	0001	563	41.84
1814	2394	CNTRY	2824	3032	41.76
1815	1268	JKSNR	4111	457	41.64
1816	2467	EULES	8724	2414	41.59
1817	2111	TYSTH	1208	255	41.51
1818	1172	GRLWS	1704	176	41.50
1819	1364	FINKS	1803	1373	41.46
1820	1528	DEALY	0001	1187	41.42
1821	1993	RCHHL	0321	1736	41.42
1822	1156	MURPH	2755	3277	41.40
1823	2351	LOMAL	0005	400	41.24
1824	2414	KIMBL	5012	1045	41.19
1825	1872	BRIRV	6922	3416	41.14
1826	1720	BRHLW	7612	712	41.12
1827	985	RWALS	1851	2077	41.11
1828	1321	TRNTH	1503	1889	41.10
1829	2235	MSHLN	0008	683	41.01
1830	598	FINKS	1802	770	40.94
1831	1688	KLNTF	1801	1090	40.87
1832	2852	TMSTH	1405	516	40.83
1833	1130	RWDHV	1905	1145	40.82
1834	2378	CKRHL	0002	430	40.76
1835	2822	SWDTN	1621	707	40.76
1836	1789	ROWLT	1102	1074	40.72

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
1837	671	GODRD	8142	1062	40.71
1838	1930	RGLRW	0005	50	40.69
1839	2825	WSOTH	1022	2231	40.65
1840	156	JKSBR	1401	738	40.59
1841	1064	AYERS	4421	1491	40.55
1842	907	PRFTW	4212	2004	40.53
1843	1412	MEXIA	4007	450	40.39
1844	1831	KILEN	1201	1898	40.39
1845	1469	TRLSW	1201	1171	40.38
1846	1942	MRSES	4012	390	40.37
1847	1152	EDGWD	1102	945	40.37
1848	2666	SFTLK	4011	43	40.33
1849	1448	CRLJL	1501	1463	40.31
1850	2086	MESQW	1806	1668	40.22
1851	1367	FORSW	2053	2107	40.09
1852	2875	IRLBJ	3221	856	40.08
1853	1687	STAUG	0008	2073	40.04
1854	1907	RDLML	2532	1789	39.99
1855	523	CPLSO	4312	1821	39.96
1856	2079	PWEST	1302	978	39.96
1857	1371	ADISN	1608	365	39.91
1858	1700	BRNWD	1204	1792	39.82
1859	553	SLBLF	1201	137	39.79
1860	1828	FROKS	0007	1524	39.52
1861	2140	PALRD	2205	340	39.51
1862	1202	HMPHL	2721	634	39.42
1863	1810	LFSTH	1402	1187	39.35
1864	706	SHDYG	7842	783	39.34
1865	1638	PJPTR	3222	186	39.34
1866	541	LFKHL	2103	1911	39.28
1867	1819	BRHLW	7622	1089	39.23
1868	2921	NPKWY	0009	1293	39.18
1869	2591	MTLDA	0003	1375	39.11
1870	526	HORNE	1944	439	39.08
1871	884	SHDYG	7841	341	39.07
1872	109	TRSES	1202	528	38.94
1873	2279	PCUST	2002	819	38.91
1874	2512	KNEDL	6332	2391	38.84
1875	2359	SORCY	0003	847	38.77
1876	1257	LWRDR	0002	1011	38.69

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
1877	1921	PCUST	2007	1402	38.59
1878	2137	CDHIL	1802	841	38.57
1879	2340	MTLDA	0005	1581	38.47
1880	2720	LOMAL	0002	513	38.47
1881	861	DNINR	1403	1203	38.46
1882	2811	VALVW	1802	450	38.37
1883	895	ALPHA	0011	1160	38.30
1884	1543	MCDMT	2552	486	38.26
1885	2177	ENNIS	1901	361	38.24
1886	647	WHTRK	0003	1279	38.24
1887	268	CLBRN	1202	1024	38.23
1888	2738	FARON	4062	1150	38.15
1889	147	NCNTH	1806	865	38.09
1890	611	TMPLE	1206	720	38.08
1891	1389	DALRK	1307	1286	38.04
1892	2188	TMSTH	1403	1558	38.04
1893	2227	WRIDG	3056	3370	38.00
1894	1030	DUVAL	0473	1749	37.96
1895	2715	GRPVN	8213	281	37.81
1896	2121	CMPWI	0002	92	37.79
1897	2608	WEBBS	8634	1475	37.75
1898	1331	DALLW	0001	1117	37.71
1899	1323	MAYFD	5511	4148	37.63
1900	334	ELGIN	1003	2154	37.61
1901	1049	RNDRK	1503	3920	37.44
1902	1731	SMFLD	2323	625	37.43
1903	2171	FRMBG	1751	811	37.42
1904	2949	JREST	2103	843	37.38
1905	2344	LNCST	1604	639	37.31
1906	2631	MSHLN	0005	503	37.21
1907	1604	RRSTH	1708	4199	37.21
1908	1378	TSLVL	4002	2875	37.18
1909	1361	DUVAL	0452	1422	37.17
1910	863	GRHWY	5512	3138	37.07
1911	#N/A	GRVPT	7521	138	37.07
1912	782	TMPNW	1104	1931	37.03
1913	248	BLTSW	3205	1889	36.99
1914	2381	WFALS	0174	1183	36.95
1915	545	DAVST	0004	1722	36.94
1916	225	CRLTN	1403	215	36.92

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
1917	2693	ATNRN	3421	2427	36.91
1918	152	CRNDL	2401	513	36.89
1919	2411	CHROW	0007	82	36.79
1920	832	GRMES	0512	1197	36.78
1921	451	IRVNR	1553	1354	36.68
1922	2166	NCRST	2204	1902	36.67
1923	1272	LUFKN	1202	1070	36.59
1924	1809	BRNAV	0753	1277	36.59
1925	1544	JKSNR	4105	82	36.54
1926	1561	IRVNG	1401	1504	36.50
1927	1999	HSKAV	0003	1491	36.43
1928	433	MYPRL	1801	177	36.41
1929	1602	FROKS	0005	1412	36.40
1930	2814	DENDR	0009	69	36.25
1931	1770	PCUST	2012	1810	36.23
1932	799	PCOIT	1004	733	36.22
1933	859	GSMTH	1731	38	36.21
1934	238	MNWLL	1205	445	36.20
1935	365	FRMNT	0013	3130	36.19
1936	1374	MLKF2	1201	789	36.13
1937	2758	BLMND	3262	125	36.07
1938	2001	PLSTN	1002	1217	36.06
1939	1278	ARMST	0009	1140	36.04
1940	1358	MDLNW	1521	1802	35.90
1941	1082	PRSTN	0001	870	35.89
1942	2878	HLTOM	2461	849	35.86
1943	2799	DPCRK	1822	1336	35.84
1944	2413	WCOLO	1317	1243	35.81
1945	2458	CMPWI	0001	1945	35.81
1946	2660	WELRD	0001	1216	35.79
1947	2337	FRMNT	0010	2560	35.68
1948	665	TRLWD	7712	3298	35.60
1949	441	IVANS	1612	1039	35.54
1950	327	PCUST	2008	695	35.53
1951	2679	WXNTH	2301	1317	35.30
1952	290	RSPVY	1702	533	35.29
1953	100	HURST	1822	1581	35.27
1954	890	MKNSW	2602	2634	35.26
1955	192	GODLY	1601	921	35.22
1956	2124	BMTWN	1611	1861	35.22

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
1957	761	PWEST	1306	344	35.20
1958	2206	RCHRD	1206	684	35.17
1959	1369	RSNHT	1122	2032	35.12
1960	2172	BONHM	1210	1170	35.12
1961	383	IRVGS	1904	957	35.12
1962	1329	DUBLN	1360	1116	35.07
1963	1126	NCDSW	3813	405	34.96
1964	2796	RRNES	2405	4328	34.91
1965	1143	WXHCH	1203	1253	34.89
1966	955	PFFRD	3421	856	34.87
1967	1191	TYSTH	1206	1277	34.87
1968	1359	PPARK	1803	1059	34.84
1969	2310	ARLNG	1223	1861	34.79
1970	2754	PTENN	2355	179	34.78
1971	1764	SMFLD	2343	717	34.77
1972	1396	ARLNG	1232	1272	34.69
1973	1622	OAKHL	3021	2010	34.67
1974	1050	RYSSW	2804	2379	34.55
1975	2887	MKNSO	3612	1947	34.54
1976	2063	ROWLT	1103	1090	34.54
1977	1612	WMMMR	2707	1547	34.53
1978	2300	MESQN	1501	1796	34.46
1979	326	ODNTH	2053	2392	34.39
1980	2954	DALWT	2952	657	34.32
1981	1641	KLNTF	1806	1183	34.27
1982	1522	TATSP	4322	2548	34.26
1983	1218	CRLCC	2703	632	34.22
1984	1859	PARIS	1205	26	34.17
1985	813	RDLML	2561	894	34.11
1986	1151	MSLSW	0003	191	34.10
1987	469	AMMFG	5611	809	34.05
1988	1786	VLYRN	2954	2733	34.03
1989	1736	BLTLN	0002	881	34.03
1990	1655	FHLSW	1342	2240	34.00
1991	1863	CRNTH	2403	2913	33.99
1992	2548	BRYAN	0002	215	33.95
1993	2327	LIPAN	1303	284	33.94
1994	1394	PCUST	2005	1712	33.89
1995	1548	EULSO	9132	2032	33.89
1996	2721	MESQW	1805	84	33.88

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
1997	643	SSPNG	1204	1002	33.77
1998	2670	CMINO	1207	705	33.75
1999	2205	WNDCR	0221	585	33.73
2000	676	WRBND	2321	1526	33.71
2001	2119	MDTHS	1001	1924	33.68
2002	1571	WSOTH	1020	1129	33.63
2003	2192	BRNAV	0711	1624	33.59
2004	1505	PWEST	1304	1616	33.57
2005	2204	ELMGV	3651	2389	33.56
2006	3020	WEAST	0621	19	33.53
2007	916	SYCRK	4521	3225	33.43
2008	2630	BLMED	1618	34	33.40
2009	1108	HURST	1872	2097	33.35
2010	440	RNDRK	1509	1320	33.33
2011	1833	TYLGE	1316	2893	33.32
2012	12	MIDWY	0612	523	33.27
2013	498	PRMED	4402	870	33.27
2014	424	COPEL	3052	1313	33.24
2015	1765	COTRD	0001	343	33.21
2016	1760	PCUST	2006	1613	33.00
2017	2275	BLMND	3252	1160	32.99
2018	448	CLBWS	8111	1801	32.92
2019	2027	SHNRW	1611	997	32.91
2020	2259	RWDHV	1902	963	32.86
2021	2450	TMPLE	1204	1053	32.84
2022	1781	MESFR	2103	357	32.78
2023	2728	SHNRW	1612	859	32.78
2024	2040	RDRSE	2604	4185	32.77
2025	1892	CDHIL	1803	1927	32.73
2026	452	BDFWD	8922	2011	32.72
2027	1088	PROAD	0007	428	32.72
2028	1128	MESTE	1208	988	32.68
2029	849	WWEST	1219	945	32.67
2030	1231	LORAN	9711	381	32.66
2031	1457	TYEST	1509	381	32.64
2032	838	PLSTH	1304	1319	32.59
2033	2465	RNDRK	1507	896	32.48
2034	668	SHAMP	0007	699	32.40
2035	1492	GRAHM	0721	1237	32.31
2036	1551	ELMGV	3653	2128	32.30

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
2037	2637	NCSFA	1702	1307	32.19
2038	2335	MESWE	3611	1926	32.18
2039	411	CNTRY	2833	1236	32.16
2040	747	CURIE	7231	1075	32.14
2041	2821	RCLNS	1402	908	32.11
2042	1624	PCUST	2004	1202	32.08
2043	626	CRLTN	1407	1559	32.07
2044	818	LMESA	1522	1326	31.93
2045	556	MESQT	1301	1458	31.89
2046	286	MDWCK	0006	877	31.86
2047	2711	CLLVL	0006	1410	31.83
2048	714	DNISN	1204	1233	31.83
2049	958	ATHNS	1203	1057	31.81
2050	1514	ACRLY	1711	170	31.74
2051	328	WALST	0012	554	31.72
2052	2031	FHLSW	1332	354	31.66
2053	1421	SHDYG	7822	526	31.63
2054	1829	RVRFT	0002	346	31.62
2055	443	BRNWD	1205	1137	31.61
2056	2168	PRKWY	1532	2161	31.60
2057	1504	ITSCA	1701	758	31.56
2058	1842	PRKWY	1521	2395	31.55
2059	2322	PROAD	0004	994	31.47
2060	2339	HMPHL	2772	300	31.36
2061	2147	EDGCF	2262	1023	31.34
2062	1973	RDRSE	2601	3582	31.27
2063	1266	WEBBS	8631	3961	31.25
2064	2419	BRCRK	6533	1893	31.23
2065	2549	WNRTH	1420	1162	31.23
2066	1727	EGFRD	0001	1803	31.21
2067	2734	BAKKE	6921	2201	31.18
2068	1901	ODESA	0261	1485	31.17
2069	1521	PWEST	1301	1262	31.12
2070	1407	IRVGS	1905	763	31.12
2071	1998	BRCRK	6522	2230	31.07
2072	1042	BLTON	1806	925	31.01
2073	2009	CRLTR	2007	1425	31.01
2074	54	CRLSP	1703	257	30.98
2075	817	WSTHL	3621	2074	30.89
2076	1399	FRMBG	1701	98	30.89

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
2077	502	PWEST	1311	957	30.75
2078	1294	ROLTR	2912	1927	30.69
2079	2280	DALRK	1326	2873	30.64
2080	1982	FERIS	1101	1228	30.59
2081	2726	CHROW	0001	136	30.50
2082	1868	PCOIT	1005	1098	30.46
2083	1444	MDLNW	1573	1055	30.43
2084	2030	WEBBS	8614	2517	30.43
2085	1136	GLNHV	3963	1601	30.37
2086	1949	MDWPK	9241	1760	30.36
2087	2864	CMTSW	0966	131	30.36
2088	1238	BDFRD	8811	1688	30.36
2089	1923	TMPTV	2402	4499	30.35
2090	2041	SPRDL	4812	1203	30.30
2091	82	RHOME	2401	1212	30.30
2092	804	SYCRK	4522	2014	30.27
2093	909	ARLNG	1271	1965	30.21
2094	2530	RNDRK	1506	1688	30.19
2095	416	WNRTH	1416	724	30.15
2096	2053	CRLTN	1405	1244	30.07
2097	1910	GVODS	3011	2293	30.04
2098	1027	TRNTH	1501	1820	29.99
2099	1349	RECCR	0006	486	29.98
2100	2241	WEBBS	8611	2618	29.97
2101	538	MDAIR	2912	830	29.90
2102	959	HOLDY	0921	644	29.88
2103	552	COHMA	1111	750	29.87
2104	1056	SORCY	0001	2577	29.84
2105	2948	BRTRD	7322	659	29.83
2106	2004	TMSTH	1408	759	29.75
2107	881	EULES	8732	644	29.75
2108	2764	IRVNR	1510	525	29.71
2109	2872	WWEST	1222	184	29.70
2110	2360	PRCTR	1602	243	29.68
2111	1636	MESTE	1205	1630	29.61
2112	322	BOWEN	3142	1254	29.55
2113	1664	PRCRK	0003	1885	29.54
2114	800	RWDHV	1903	1248	29.54
2115	992	LAVON	1406	1522	29.44
2116	2804	EMPCT	0001	35	29.38

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
2117	1808	BRKRG	0213	408	29.36
2118	716	PRKRW	3382	328	29.30
2119	1491	BSPRG	1902	2387	29.28
2120	1423	EDGCF	2252	394	29.27
2121	2084	PRKRW	3372	1493	29.24
2122	1883	BRTRD	7312	3984	29.24
2123	1545	ELZCK	4921	2217	29.22
2124	1475	BLKST	1762	1025	29.14
2125	1826	RWDHV	1904	506	29.06
2126	1039	AYERS	4431	1673	29.04
2127	2010	MDWPK	9211	1314	29.03
2128	1590	DNISN	1206	938	29.00
2129	2355	WMRNR	0002	430	28.96
2130	312	TYSTH	1209	818	28.95
2131	324	MESQN	1506	71	28.94
2132	1162	TIODE	9621	446	28.94
2133	1650	BRYAN	0004	2117	28.92
2134	744	FRMBR	1803	2797	28.88
2135	596	WDGWD	1592	1161	28.82
2136	1768	FSTVW	0003	1883	28.82
2137	2263	ALNTH	2853	3022	28.81
2138	153	LNDAL	2202	1267	28.74
2139	2655	GODRD	8131	1538	28.72
2140	2958	DELTA	1701	1090	28.72
2141	2388	MESTE	1209	1441	28.70
2142	2309	CRTL D	4723	2338	28.70
2143	727	SHSTH	1303	874	28.67
2144	1043	AMMFG	5631	1473	28.64
2145	2209	BLMED	1620	2051	28.64
2146	1114	WDGWD	1531	1502	28.62
2147	875	LKHLD	0004	1257	28.57
2148	1489	TMSTH	1404	1333	28.49
2149	1289	GVFTW	1802	968	28.48
2150	1629	TYBLR	2801	1234	28.46
2151	2251	PRMED	4403	2641	28.45
2152	2369	MDLNW	1511	840	28.44
2153	1631	WNDWD	3662	891	28.37
2154	2077	DNIWS	1602	1383	28.35
2155	1778	MESTE	1207	946	28.34
2156	2105	PNTGO	7112	739	28.33

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
2157	2536	AMLIA	0003	27	28.33
2158	2483	TMSTH	1406	1155	28.32
2159	1531	SMPST	0006	840	28.30
2160	2315	WDGWD	1512	824	28.26
2161	2195	GRMES	0511	1179	28.25
2162	207	MSHLN	0003	539	28.24
2163	1873	PARIS	1202	1247	28.10
2164	1117	BRYAN	0005	1273	28.09
2165	854	GRDPR	0822	628	28.09
2166	2082	DNISN	1201	1484	28.06
2167	549	BRNWD	1203	826	28.03
2168	748	VGCRK	8021	212	27.98
2169	179	BAKKE	6922	1544	27.97
2170	2978	DFWSE	2710	89	27.95
2171	2700	RRNES	2402	4280	27.93
2172	833	ARMST	0012	1368	27.89
2173	1169	NCRST	2203	896	27.89
2174	1820	DNISN	1203	1721	27.88
2175	2650	NHNSW	0003	319	27.87
2176	693	MESQT	1306	990	27.83
2177	1785	ENNIS	1903	1590	27.80
2178	1527	HKHTS	1605	1474	27.79
2179	2047	PNTGO	7122	871	27.77
2180	1506	WSOTH	1018	797	27.76
2181	2801	BRNSO	1807	242	27.73
2182	1959	PKRVL	1054	2673	27.68
2183	1678	PFFRD	3431	578	27.67
2184	1672	PRMED	4401	2518	27.62
2185	857	ALLEN	2404	2070	27.54
2186	1882	RRSTH	1703	3598	27.47
2187	754	JUDCT	0008	140	27.47
2188	1608	GRPTT	9911	694	27.39
2189	2420	CMPST	0004	1670	27.39
2190	2555	GRMES	0521	546	27.38
2191	1270	IRVGS	1906	729	27.34
2192	2627	LKBLT	2102	1438	27.33
2193	1096	WTHRE	2101	1210	27.27
2194	2656	SCHRD	0003	359	27.25
2195	1496	HLSES	0522	1736	27.14
2196	2294	HHSTH	1503	1870	27.14

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
2197	2270	GRHWY	5522	1783	27.10
2198	1777	WNTHW	1118	1527	27.09
2199	2065	FROKS	0003	643	27.08
2200	2760	DCATR	1204	658	27.02
2201	#N/A	MCTYE	1711	1515	26.99
2202	2603	MURPH	2753	1075	26.98
2203	2642	DLEON	0131	729	26.96
2204	1170	WDGWD	1522	1447	26.92
2205	2926	HORNE	1913	1566	26.88
2206	1188	GAVSW	0009	1025	26.83
2207	2851	DPCRK	1832	328	26.78
2208	1233	BBTWN	1502	1784	26.49
2209	2577	EDGCF	2221	875	26.47
2210	1446	PLKST	0005	1175	26.42
2211	197	DALRK	1358	2406	26.40
2212	1135	THRNE	0008	2237	26.39
2213	354	LAVON	1453	1409	26.32
2214	2463	MNFLD	2611	2240	26.21
2215	2707	MCWHT	3512	1956	26.18
2216	1564	WNTHW	1121	747	26.13
2217	910	SPRDL	4822	1200	26.12
2218	1180	MDDTN	4311	192	26.11
2219	#N/A	MNWLL	1201	23	26.07
2220	2240	CLYVL	9313	2002	26.06
2221	1728	WATSN	5342	2026	26.06
2222	2353	WBROK	3011	198	26.02
2223	1744	ALKLK	4221	52	26.01
2224	1651	PLKST	0002	817	25.97
2225	57	PPARK	1808	600	25.96
2226	1601	MSHLN	0002	1581	25.95
2227	2507	GRPVN	8222	2304	25.95
2228	1600	GLNHV	3911	1364	25.92
2229	642	CPLSO	4322	296	25.89
2230	308	BSPRW	2542	784	25.84
2231	2532	ATHNW	1405	902	25.83
2232	1138	HMPHL	2743	934	25.82
2233	2364	WTAUG	4642	1328	25.78
2234	2321	KLNTF	1802	828	25.76
2235	2404	FRNKF	0003	498	25.69
2236	2180	EDGCF	2272	1082	25.63

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
2237	2736	IRVNE	1302	1393	25.62
2238	397	IRVNR	1557	3180	25.58
2239	2558	PRMED	4404	1157	25.57
2240	1164	BRNAV	0732	811	25.50
2241	1200	KLNPS	1104	1397	25.35
2242	2035	PCOIT	1025	3187	25.33
2243	2401	WCOLO	1316	2081	25.29
2244	366	NHNSW	0008	590	25.27
2245	2162	TMPNW	1103	772	25.27
2246	1014	VLYRN	2952	3436	25.18
2247	571	WXHCH	1205	1013	25.09
2248	1222	OTTOJ	3060	17	25.07
2249	2610	PFFRD	3411	315	25.04
2250	688	AZLES	2121	2991	25.01
2251	2371	KLNCC	1704	2865	24.99
2252	1178	GRSMN	4028	690	24.98
2253	1911	MCDMT	2531	2456	24.97
2254	1694	RWALE	3324	1551	24.97
2255	2015	LKMNT	0003	580	24.89
2256	1613	LKBLT	2103	2180	24.87
2257	1737	RNKSU	5413	37	24.82
2258	1796	WCOLO	1315	1646	24.73
2259	1483	IRVND	1203	436	24.67
2260	1131	BSPSW	0841	2143	24.61
2261	2628	ARTHR	0472	1296	24.60
2262	2861	RGLRW	0006	31	24.58
2263	2144	ARTHR	0422	1051	24.47
2264	1144	REYST	4051	1069	24.46
2265	2756	RGLRW	0008	36	24.46
2266	1647	LKHLD	0005	1340	24.45
2267	2114	BDFWD	8931	1730	24.44
2268	2106	TMPNW	1105	850	24.44
2269	1264	BNDRA	0004	734	24.41
2270	1966	LAVON	1454	3137	24.35
2271	1925	HRSMD	1907	3155	24.33
2272	696	OKCLS	0001	722	24.29
2273	298	LWSNR	2242	1433	24.27
2274	2447	PARIS	1201	1099	24.27
2275	1066	FRMBR	1807	839	24.24
2276	1382	LOMAL	0009	1015	24.20

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
2277	2207	TYBLR	2804	2441	24.18
2278	1221	CRTLD	4731	2988	24.17
2279	796	SANSM	3923	3985	24.16
2280	2626	WHITE	3522	1817	24.09
2281	2342	BNDRA	0007	486	23.97
2282	2525	MDLNE	0172	376	23.96
2283	1597	HLTOM	2482	1054	23.95
2284	#N/A	GSTHW	1614	865	23.89
2285	2919	LTVSB	5461	803	23.85
2286	353	BRKTN	1201	491	23.80
2287	2753	RRSTH	1707	618	23.78
2288	2050	BRNAV	0784	1896	23.77
2289	373	MKNNY	1253	152	23.76
2290	961	CRSWS	1403	1917	23.74
2291	1978	OKCLS	0003	1526	23.67
2292	1288	ELGIN	1001	558	23.66
2293	2879	WWEST	1218	1010	23.61
2294	1924	IRVGS	1901	1384	23.60
2295	1021	BRKRG	0242	24	23.58
2296	1019	PLSTH	1305	502	23.55
2297	1201	PARIS	1204	1159	23.53
2298	1376	FORSN	5632	245	23.52
2299	126	IRVNR	1551	1363	23.50
2300	1732	BEAST	4088	115	23.42
2301	656	COPEL	3053	2078	23.40
2302	2214	DAVIS	3713	849	23.39
2303	969	PRCRK	0001	66	23.37
2304	1037	MDLNW	1552	691	23.36
2305	2487	RDRSE	2607	5479	23.35
2306	2685	OKCLS	0008	1544	23.30
2307	2033	WELRD	0008	1110	23.26
2308	1121	MSTLT	1021	993	23.24
2309	2410	ROWLT	1101	1256	23.24
2310	2022	RDOAK	1303	2510	23.19
2311	2412	WTAUG	4621	444	23.17
2312	1009	MCWHT	3511	3328	23.14
2313	1095	TMPNW	1101	2710	23.12
2314	2748	HORNE	1911	1570	23.11
2315	2244	HRSMD	1953	415	23.10
2316	993	BRNAV	0762	2383	23.09

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
2317	1913	LKHLD	0002	1534	23.07
2318	#N/A	MAPOI	1201	153	23.05
2319	2502	CRSCN	1204	644	23.05
2320	2556	BLTON	1801	840	22.91
2321	1899	NLNVL	2003	740	22.84
2322	2889	ARMST	0010	877	22.81
2323	1428	MDTHS	1003	1426	22.73
2324	2064	CNEXP	0007	423	22.71
2325	713	EULSO	9111	1988	22.71
2326	2400	MESTE	1202	816	22.70
2327	966	KNEDL	6342	2123	22.61
2328	1932	ABRRD	0003	353	22.60
2329	2357	SHMNE	1403	996	22.58
2330	2278	CMTSW	0957	1207	22.56
2331	675	WEBBS	8612	3450	22.51
2332	607	ARLNG	1282	837	22.47
2333	2298	PFLGV	2005	3932	22.45
2334	374	CRTLD	4732	2842	22.45
2335	2333	BNBRK	4111	2912	22.40
2336	1425	EDGCF	2282	1056	22.33
2337	701	PLKST	0006	813	22.06
2338	1498	JKSNR	4109	635	22.00
2339	2316	HSKAV	0007	80	21.97
2340	2095	WITTS	1701	1295	21.96
2341	2874	JNKNS	0006	685	21.94
2342	1947	CRLTR	2001	2497	21.88
2343	1355	WEAST	0617	1581	21.85
2344	2854	GRLRD	0003	656	21.82
2345	1850	WTAUG	4622	1006	21.77
2346	2043	ESTLD	3611	1526	21.75
2347	1217	PRNTH	1406	993	21.72
2348	2476	WATCO	2603	3651	21.70
2349	1956	LKWOD	7432	1624	21.63
2350	2923	TYBLR	2806	204	21.56
2351	2306	WWDWY	2020	1242	21.47
2352	1849	WSOTH	1021	2140	21.38
2353	1635	WHITE	3531	1917	21.35
2354	1424	AIRPK	8421	1105	21.27
2355	2588	ATNRN	3412	6358	21.14
2356	1722	FRMNT	0008	1403	21.08

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
2357	2459	WCOLO	1320	1435	21.06
2358	971	DCDAM	2001	818	21.02
2359	977	HHSTH	1504	2569	20.99
2360	2334	WATSN	5331	1127	20.99
2361	1104	DNIWS	1603	1366	20.95
2362	1003	KILEN	1203	753	20.90
2363	2858	SHAMP	0005	1632	20.82
2364	128	PNTGO	7121	1500	20.74
2365	1685	TYSTH	1203	430	20.74
2366	2202	BLMGR	1901	271	20.68
2367	395	MESQT	1307	591	20.60
2368	1320	PTENN	2352	2478	20.59
2369	2649	RDRSE	2602	4604	20.56
2370	2794	LKBLT	2104	916	20.48
2371	1969	MSTLT	1084	1052	20.42
2372	2911	RYSSW	2801	1288	20.39
2373	2560	FHLSW	1311	1591	20.38
2374	530	CRLTR	2051	3925	20.37
2375	2374	ATHNW	1402	515	20.28
2376	1926	CRWLY	7021	3534	20.28
2377	641	BRLSN	2051	2848	20.25
2378	376	HRSMD	1955	2111	20.24
2379	2222	EZACH	0006	1100	20.15
2380	741	SHRSW	6621	1808	20.11
2381	1743	TRNTH	1504	834	20.00
2382	866	SHLMT	1801	300	20.00
2383	1203	FRMBR	1808	681	19.92
2384	1665	DALWT	2962	470	19.87
2385	1254	DLEON	0111	831	19.82
2386	2765	FARON	4072	1544	19.80
2387	1997	PLGRV	0004	379	19.74
2388	1776	SHNRW	1608	1442	19.65
2389	300	WHTRK	0005	723	19.64
2390	2724	IRASB	3211	274	19.63
2391	2151	CRNRD	0005	365	19.61
2392	1415	IRVND	1206	106	19.55
2393	2464	PRKWY	1561	1753	19.55
2394	2382	FSTVW	0004	2268	19.53
2395	2876	RECCR	0002	94	19.51
2396	664	FRMBR	1804	296	19.51

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
2397	1432	BLMED	1622	1009	19.50
2398	2543	TMPSE	1503	624	19.49
2399	632	CANTN	1303	928	19.48
2400	662	DAVIS	3743	198	19.47
2401	722	ARTHR	0431	498	19.46
2402	855	GORMN	0411	539	19.45
2403	2094	FROKS	0008	1501	19.42
2404	2890	WHITE	3532	1432	19.37
2405	935	WSTHL	3642	2245	19.34
2406	674	RTHGB	1411	722	19.25
2407	2123	CRTLD	4734	794	19.24
2408	1575	WOVER	6122	890	19.19
2409	1946	MDLNW	1564	1269	19.08
2410	1161	BNDRA	0009	592	19.06
2411	508	IRVNE	1310	307	18.96
2412	1584	CMTSW	0987	391	18.90
2413	2362	BRGPR	1103	926	18.89
2414	1934	MAYFD	5531	1188	18.87
2415	2291	TMNTH	1607	11	18.85
2416	1620	TRLSW	1204	590	18.84
2417	1443	WSTHL	3613	3365	18.82
2418	2788	PPARK	1802	596	18.73
2419	1576	TRNTY	7551	1583	18.72
2420	2281	BNDRA	0003	810	18.66
2421	1735	WALST	0001	630	18.64
2422	1497	DEALY	0004	1185	18.62
2423	1726	GLNHV	3973	1576	18.49
2424	850	VLYRN	2951	2224	18.43
2425	2616	WALNT	0004	1475	18.39
2426	2308	ROANW	9511	1542	18.33
2427	2834	JKREA	1201	29	18.23
2428	2552	KLELM	2201	2441	18.21
2429	2007	RCHHL	0384	722	18.12
2430	1616	LWSNR	2231	786	18.11
2431	803	NLNVL	2001	458	18.10
2432	573	STNVL	1206	2680	18.09
2433	2957	ARMST	0004	1202	18.09
2434	240	ARCTY	1321	897	18.05
2435	734	FRMBG	1706	64	17.98
2436	2785	LSCOL	2138	1524	17.97

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
2437	1020	MDWCK	0008	1261	17.94
2438	2216	BSPRG	1905	1607	17.92
2439	1028	NMAIN	0231	636	17.89
2440	2534	ARTHR	0481	1247	17.89
2441	464	IRVNR	1555	2200	17.89
2442	999	CTYVW	2212	147	17.88
2443	421	BLMED	1621	589	17.85
2444	2731	ODESA	0252	555	17.80
2445	2668	FSTVW	0008	1755	17.69
2446	1434	WGROB	8422	3032	17.65
2447	1040	WNTHW	1120	1035	17.62
2448	1936	MESQN	1507	697	17.61
2449	682	MABNK	2402	1021	17.53
2450	489	SSPNG	1202	1235	17.51
2451	1958	RRSTH	1702	3296	17.49
2452	945	OAKHL	3011	2318	17.45
2453	1197	LENSW	0321	68	17.41
2454	#N/A	WOVER	6162	25	17.41
2455	105	FORSN	5642	39	17.40
2456	2776	GRHWY	5521	1956	17.40
2457	2024	LOMAL	0014	578	17.34
2458	1031	STNVL	1204	799	17.31
2459	2438	GNSVL	1204	503	17.31
2460	962	PLANO	1103	1883	17.28
2461	2747	BLKST	1721	1018	17.25
2462	1084	ROGRS	1301	779	17.24
2463	1479	BOWEN	3112	908	17.24
2464	2974	DENAV	0641	21	17.19
2465	2880	ALLEN	2401	2614	17.16
2466	1589	HLSES	0511	1831	17.09
2467	1385	SPRTN	1801	1867	17.08
2468	2777	CNTRD	0001	2042	17.07
2469	2146	GRPVN	8211	135	17.04
2470	1839	PAYSW	1202	1636	17.00
2471	704	MAPLE	0006	2540	16.99
2472	484	CLMET	0002	1415	16.98
2473	390	EZACH	0005	540	16.97
2474	2097	CNTRD	0004	1083	16.87
2475	1481	DALWT	2972	241	16.85
2476	#N/A	DIBOL	1507	462	16.81

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
2477	1957	WSANG	2802	639	16.80
2478	2910	GAVSW	0012	844	16.79
2479	1116	COLNY	2406	826	16.74
2480	918	CMBTP	1201	256	16.73
2481	#N/A	HUTTO	2713	2539	16.69
2482	1972	CRLUD	1307	294	16.66
2483	2274	HUTTO	2723	3627	16.65
2484	457	GAVSW	0006	514	16.62
2485	2268	LGVST	8522	429	16.61
2486	2689	WFALS	0163	353	16.52
2487	2520	CURIE	7212	706	16.50
2488	1615	PARIS	1203	944	16.42
2489	2813	FRMNT	0007	987	16.38
2490	#N/A	EXPKY	8121	54	16.34
2491	2193	HURST	1811	1258	16.32
2492	2038	WRBND	2322	815	16.31
2493	1581	REAST	1502	1320	16.25
2494	2566	PNTGO	7111	731	16.25
2495	2499	MRTNS	1501	495	16.18
2496	2593	STNVL	1207	1004	16.18
2497	2402	CRYVE	3011	282	16.15
2498	1516	HMPHL	2791	23	16.14
2499	2596	KLBRG	0001	471	16.10
2500	2143	SMFLD	2392	1168	16.08
2501	1391	KNLTR	0004	1367	16.06
2502	2405	BLTON	1805	1548	16.03
2503	1960	BRHLW	7621	2466	16.03
2504	1754	BRCRK	6523	879	15.98
2505	2741	MAPLE	0001	1047	15.88
2506	1878	RSNHT	1142	1099	15.88
2507	2115	TERSO	2503	1106	15.88
2508	2432	SHSTH	1301	2337	15.82
2509	1452	STHRL	0001	598	15.77
2510	#N/A	STLWC	2104	330	15.72
2511	2837	FSCRK	6713	3317	15.70
2512	2696	PALRD	2203	1093	15.67
2513	2521	BLKST	1771	1420	15.55
2514	923	WMMMR	2703	1138	15.53
2515	2718	MSTLT	1011	60	15.47
2516	2272	MCGHR	2003	1311	15.46

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
2517	692	RNDRK	1508	4037	15.45
2518	1478	GRLTC	3805	945	15.45
2519	1427	CMTSW	0973	1599	15.42
2520	2452	WALST	0013	378	15.42
2521	792	CURIE	7221	897	15.31
2522	773	MESTE	1204	1829	15.25
2523	#N/A	KRGRV	9999	764	15.18
2524	1908	SCHRD	0004	1916	15.15
2525	1344	CRNRD	0002	363	15.09
2526	1797	LUFKN	1207	46	15.05
2527	1633	RDLML	2512	1216	15.03
2528	1112	WTAUG	4643	996	15.03
2529	2198	ALLEN	2403	2700	15.02
2530	1211	BRHLW	7632	1491	14.95
2531	2617	BLMED	1617	326	14.88
2532	2399	FRNKF	0002	943	14.88
2533	2582	BOWEN	3161	1541	14.78
2534	1739	HKBRY	1107	995	14.75
2535	567	LKMNT	0001	200	14.70
2536	2633	RSKMN	3078	136	14.70
2537	1990	JUDCT	0007	526	14.69
2538	629	MYPRL	1803	606	14.69
2539	1276	DAVIS	3782	1382	14.68
2540	2067	FARON	4052	1061	14.66
2541	1319	PRSTN	0003	2961	14.56
2542	2032	TRLNW	1202	62	14.55
2543	2017	LFKHL	2101	172	14.51
2544	#N/A	GSTHW	1624	2208	14.49
2545	1599	WESTS	1602	862	14.47
2546	2640	REAST	1509	139	14.46
2547	2242	ARLNG	1261	1184	14.44
2548	878	GRPVN	8231	398	14.44
2549	1922	HHSTH	1501	3539	14.42
2550	2358	GNSVL	1213	743	14.41
2551	2480	DPCRK	1821	1624	14.39
2552	1105	RCLNS	1401	105	14.35
2553	990	IOWPK	0831	1073	14.34
2554	2026	WHTRK	0006	1330	14.32
2555	2636	NMAIN	0282	1368	14.29
2556	265	JUDCT	0001	1897	14.27

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
2557	2983	DFWSW	2326	41	14.17
2558	1856	WDGWD	1591	1127	14.17
2559	1667	SMFLD	2311	1510	14.15
2560	1210	HLSBR	1201	1161	14.10
2561	1070	MSLSW	0006	109	14.09
2562	2500	PTENN	2354	545	14.09
2563	2739	HUDSN	1605	147	14.09
2564	432	GVODS	3021	799	14.07
2565	2049	WELRD	0006	730	14.06
2566	944	WMRLD	0001	224	14.06
2567	2185	CKRHL	0003	473	14.03
2568	2690	STERT	2702	19	13.94
2569	2673	BRHLW	7631	642	13.90
2570	2567	PWEST	1310	691	13.88
2571	1861	BLMND	3282	91	13.86
2572	2135	HNYGR	2403	607	13.84
2573	3002	LKWOD	7421	42	13.78
2574	2527	ALPHA	0016	1810	13.75
2575	3014	RNKSW	5412	30	13.73
2576	1255	CRKET	1201	325	13.73
2577	2506	FARON	4031	1145	13.73
2578	1811	WTAUG	4632	1337	13.59
2579	902	FROKS	0002	1684	13.54
2580	1683	FRMBR	1853	64	13.52
2581	1091	PAYSW	1203	882	13.49
2582	2643	TMPSE	1501	533	13.45
2583	2208	BRYAN	0006	1063	13.40
2584	2807	HUTTO	2721	3492	13.37
2585	933	PROAD	0009	123	13.36
2586	#N/A	CHALK	0911	59	13.28
2587	2570	HNTNG	1302	42	13.25
2588	1155	ANDNR	2252	252	13.24
2589	625	DENAV	0621	907	13.23
2590	658	MSLSW	0007	396	13.18
2591	1857	WRBND	2312	1437	13.09
2592	1140	CRLUD	1306	26	13.04
2593	2367	DALWT	2911	345	13.01
2594	929	INAIR	1411	1735	12.92
2595	2576	SIKES	2421	2014	12.90
2596	1951	CMTSW	0916	561	12.90

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
2597	2598	LAVON	1404	955	12.89
2598	2183	AMLIA	0006	80	12.88
2599	781	NPKWY	0006	4893	12.86
2600	1953	BLKST	1752	1236	12.85
2601	2445	BSPSW	0822	400	12.85
2602	1243	CRSCN	1201	821	12.83
2603	606	MEXIA	3016	272.00	12.82
2604	1870	BDFWD	8932	1717.00	12.71
2605	1566	CMTSW	0977	255.00	12.68
2606	1644	WMMMR	2705	1221.00	12.63
2607	2303	PWEST	1312	1979.00	12.61
2608	785	PWEST	1309	58.00	12.58
2609	745	CKRHL	0005	1224.00	12.47
2610	2583	LOMAL	0007	152.00	12.43
2611	887	GLNHV	3953	1911.00	12.37
2612	1284	DAVIS	3721	1313.00	12.37
2613	2936	FRMNT	0001	974.00	12.29
2614	2798	GRAHM	0713	390.00	12.28
2615	454	BKWST	0002	1571.00	12.28
2616	2331	FSTVW	0005	1772.00	12.27
2617	2873	OKCLS	0006	1681.00	12.23
2618	1640	GNSVL	1205	890.00	12.23
2619	1807	RRSTH	1704	3382.00	12.21
2620	2667	WALNT	0001	1393.00	12.21
2621	1654	BNDRA	0001	886.00	12.20
2622	1991	WEBBS	8621	3004.00	12.13
2623	2659	WNDWD	3672	246.00	12.07
2624	1663	GAVSW	0004	838.00	12.01
2625	2478	KLELM	2202	2667.00	11.98
2626	2763	PRFTW	4222	3380.00	11.92
2627	2122	CMTSW	0927	581.00	11.86
2628	183	CUMBY	1201	768.00	11.85
2629	1971	MNWLL	1202	678.00	11.83
2630	2579	SHRSW	6641	1005.00	11.79
2631	2988	EXPKY	8141	24.00	11.77
2632	2174	WATSN	5352	1898.00	11.75
2633	2443	HLTOM	2442	1103.00	11.75
2634	1843	MESFR	2104	170.00	11.65
2635	2021	LOMAL	0008	457.00	11.61
2636	2683	SMFLD	2372	636.00	11.58

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
2637	1437	KEENE	1503	864.00	11.56
2638	650	PREST	1604	1375.00	11.52
2639	2712	STERT	2701	39.00	11.51
2640	1753	WDGWD	1513	861.00	11.50
2641	2074	WNDCR	0211	1195.00	11.45
2642	2698	JUDCT	0002	1410.00	11.40
2643	2533	FRNKF	0005	1077.00	11.35
2644	2176	ALLEN	2408	2611.00	11.32
2645	2955	NPKWY	0008	859.00	11.30
2646	1611	MESQN	1508	1777.00	11.30
2647	#N/A	ODNTH	2025	1175.00	11.20
2648	830	GVGLF	9601	54.00	11.15
2649	1562	DGNST	0004	1225.00	11.10
2650	2112	RECCR	0004	68.00	11.06
2651	2912	LKHLD	0006	741.00	11.05
2652	#N/A	LUTHR	2104	281.00	11.02
2653	2541	LVBRD	0008	1760.00	10.98
2654	2203	CRLTN	1451	562.00	10.98
2655	282	GRSMN	3071	326.00	10.95
2656	2426	WATSN	5361	2517.00	10.95
2657	2942	ELKTN	2503	850.00	10.91
2658	847	RDLML	2552	280.00	10.87
2659	2039	PLANO	1104	978.00	10.84
2660	778	FROKS	0001	1354.00	10.84
2661	2676	CURIE	7222	967.00	10.83
2662	2757	KLELM	2204	3206.00	10.75
2663	2232	FRNKS	1202	96.00	10.70
2664	2233	WFALS	0184	1257.00	10.66
2665	2750	WBOSE	1103	948.00	10.62
2666	2641	JKSNR	4107	326.00	10.61
2667	2585	DAVIS	3731	761.00	10.60
2668	2694	HMPHL	2792	447.00	10.52
2669	2551	CMTSW	0946	878.00	10.52
2670	2782	NPKWY	0011	4160.00	10.52
2671	#N/A	RSPCK	2107	1339.00	10.32
2672	2477	MCKMY	0812	131.00	10.31
2673	1393	HURST	1831	1375.00	10.28
2674	2164	RCLNS	1408	112.00	10.22
2675	1704	BDFRD	8841	816.00	10.11
2676	2629	KLNTF	1803	1047.00	10.09

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
2677	2759	BRNSO	1805	795.00	10.05
2678	1775	HORNE	1932	2037.00	9.94
2679	1453	BNDRA	0002	536.00	9.93
2680	3003	LOMAL	0004	146.00	9.83
2681	2036	SMFLD	2352	603.00	9.81
2682	#N/A	PLOWB	2921	53.00	9.81
2683	2126	OAKHL	3041	975.00	9.73
2684	309	VLYRN	2955	4541.00	9.72
2685	973	CNTRD	0003	1376.00	9.71
2686	396	DESHR	1206	2303.00	9.69
2687	689	LKTMS	2412	12.00	9.68
2688	1715	GNSVN	1403	293.00	9.68
2689	2550	HURST	1852	1532.00	9.66
2690	2085	PLHWY	3703	13.00	9.61
2691	2918	MSTLT	1042	765.00	9.55
2692	2071	ARTHR	0452	679.00	9.55
2693	2701	GRLRD	0001	1786.00	9.54
2694	536	SYCRK	4511	2005.00	9.50
2695	1579	WTAUG	4633	1049.00	9.48
2696	2243	MRSES	4014	20.00	9.42
2697	1569	KNLTR	0005	3055.00	9.42
2698	2647	WMMMR	2704	18.00	9.36
2699	1388	SHAMP	0001	1006.00	9.32
2700	1935	CNEXP	0001	262.00	9.23
2701	2784	RNDRK	1504	983.00	9.21
2702	2835	GRPTT	9921	595.00	9.19
2703	2906	TYLER	1010	71.00	9.19
2704	2922	TYLGE	1314	997.00	9.14
2705	1302	RSPVY	1706	1341.00	9.10
2706	2885	CLBNR	1401	22.00	9.09
2707	2824	CRSGL	1301	146.00	9.06
2708	2571	LIPAN	1301	529.00	9.01
2709	2645	PFLGV	2003	3221.00	8.99
2710	1841	WEAST	0615	416.00	8.99
2711	2165	BRIRV	6911	3230.00	8.98
2712	2273	RCHHL	0344	1252.00	8.96
2713	2326	FRNKF	0006	1719.00	8.96
2714	2615	ANDRD	0931	85.00	8.90
2715	2088	PROAD	0005	121.00	8.87
2716	1526	ABRRD	0001	2065.00	8.87

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
2717	2797	EMPCT	0002	97.00	8.86
2718	1300	WMRLD	0003	488.00	8.77
2719	#N/A	EGFRD	0002	24.00	8.74
2720	1438	STNVL	1203	2371.00	8.71
2721	2779	EDGCF	2231	871.00	8.71
2722	222	FORSW	2025	705.00	8.71
2723	2428	WNRTH	1418	1776.00	8.71
2724	2134	LKBLT	2101	933.00	8.68
2725	2662	TMPNW	1106	1076.00	8.66
2726	16	NOLNW	2111	22.00	8.64
2727	982	ALPHA	0013	454.00	8.62
2728	2606	TYWST	2001	179.00	8.61
2729	2454	DPCRK	1831	1457.00	8.47
2730	2697	WRTHM	5017	152.00	8.47
2731	917	FRMNT	0009	973.00	8.44
2732	2283	LKBLT	2107	1130.00	8.40
2733	1618	ABBOT	1901	112.00	8.38
2734	2539	PFLGV	2007	4843.00	8.36
2735	119	PAYSW	1205	720.00	8.31
2736	2573	MAPLE	0008	217.00	8.26
2737	2810	MNSTR	1202	280.00	8.19
2738	2609	BRLSN	2062	823.00	8.17
2739	1940	EULSO	9121	112.00	8.16
2740	2589	MTLDA	0007	2260.00	8.15
2741	2832	SHNRW	1610	436.00	8.13
2742	2302	MRSES	3016	42.00	8.07
2743	1881	WDGWD	1552	300.00	7.94
2744	1565	COMRC	1201	987.00	7.93
2745	2812	LVBRD	0004	1068.00	7.88
2746	#N/A	GDPRW	9621	237.00	7.83
2747	534	MDAIR	2922	468.00	7.81
2748	#N/A	GRVPT	7511	54.00	7.80
2749	2535	ARMST	0003	369.00	7.79
2750	2492	ROANW	9521	2289.00	7.75
2751	2644	WFALS	0193	2248.00	7.68
2752	#N/A	CRWLY	7012	4034.00	7.63
2753	2221	WHTRK	0002	1432.00	7.59
2754	2980	DFWSE	2715	10.00	7.57
2755	2396	PRKWY	1552	572.00	7.51
2756	483	IRVNE	1305	241.00	7.51

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
2757	1057	WELRD	0007	443.00	7.43
2758	951	PLANO	1106	497.00	7.42
2759	1682	MCDMT	2532	1982.00	7.40
2760	1862	ALPHA	0007	1462.00	7.36
2761	2816	BNDRA	0005	1271.00	7.36
2762	2236	ARLNG	1212	124.00	7.32
2763	2489	WNDWD	3611	308.00	7.25
2764	2485	SCHRD	0006	487.00	7.23
2765	2680	IRLBJ	3212	3881.00	7.22
2766	2947	WEAST	0620	2014.00	7.14
2767	1309	CLBNR	1407	269.00	7.13
2768	667	ALPHA	0014	687.00	7.11
2769	2434	ABBOT	1902	121.00	7.04
2770	1967	FRMNT	0012	556.00	6.98
2771	588	RDRSE	2605	743.00	6.93
2772	1387	RSPCK	2133	1394.00	6.93
2773	2624	ROWLT	1107	517.00	6.88
2774	2819	MKNGB	5322	1129.00	6.88
2775	1386	TYEST	1511	868.00	6.79
2776	540	KNLTR	0001	2207.00	6.76
2777	2840	HMPHL	2742	360.00	6.74
2778	2488	LUFKN	1204	31.00	6.70
2779	2572	LEMON	0001	2143.00	6.68
2780	2062	SHMNE	1405	805.00	6.67
2781	2903	JNKNS	0002	622.00	6.64
2782	2687	LAVON	1402	160.00	6.64
2783	2883	WWEST	1221	60.00	6.53
2784	1212	WEAST	0626	289.00	6.51
2785	922	MRSES	3019	13.00	6.42
2786	2992	GAVSW	0011	114.00	6.41
2787	2868	CRSCN	1202	624.00	6.37
2788	2688	NPKWY	0014	6122.00	6.33
2789	2719	ARLNG	1291	86.00	6.24
2790	24	ODESW	5912	253.00	6.24
2791	2895	EMPCT	0004	709.00	6.21
2792	#N/A	DENAV	0612	61.00	6.18
2793	1697	MRTSP	1502	911.00	6.17
2794	1693	RRSTH	1705	1420.00	6.07
2795	#N/A	CRWLY	7022	2520.00	6.05
2796	1304	DNISN	1202	826.00	6.02

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
2797	1903	SLTLK	3511	22.00	5.90
2798	1194	WSANG	2801	1343.00	5.78
2799	2341	KNLTR	0011	1852.00	5.72
2800	2663	COMSO	1403	444.00	5.62
2801	2915	DFWSW	2322	60.00	5.61
2802	307	WEAST	0619	1234.00	5.55
2803	2845	WMMMR	2706	20.00	5.54
2804	#N/A	GRVPT	7531	44.00	5.50
2805	2727	SUNNY	2303	701.00	5.44
2806	1896	WFALS	0153	1137.00	5.40
2807	1236	LGVST	8511	760.00	5.36
2808	2945	INAIR	1414	2735.00	5.31
2809	551	JKWST	4035	79.00	5.30
2810	2125	LOMAL	0012	736.00	5.29
2811	2526	RNDRK	1501	733.00	5.24
2812	2516	GSTHW	1613	91.00	5.22
2813	1160	WNDCR	0262	222.00	5.19
2814	1307	DNCNV	1906	414.00	5.18
2815	2772	CHICC	1701	56.00	5.17
2816	750	LKHLD	0001	1657.00	5.13
2817	453	TYLNE	1613	476.00	5.12
2818	2773	WMRLD	0009	31.00	5.11
2819	1279	MRTNS	1502	516.00	5.10
2820	2328	MTLDA	0006	2392.00	5.10
2821	1073	ENNIS	1905	45.00	5.09
2822	853	PLSTH	1303	572.00	5.08
2823	2614	ENTOH	0006	2073.00	5.07
2824	1502	EULTB	5711	1781.00	5.04
2825	2971	DCATR	1205	122.00	4.94
2826	2497	COMRC	1204	593.00	4.91
2827	#N/A	NNTWK	0004	1914.00	4.84
2828	2791	MDAIR	2921	74.00	4.81
2829	#N/A	PLOWB	2911	59.00	4.77
2830	1679	ARLNG	1222	96.00	4.66
2831	1748	WWEST	1217	101.00	4.63
2832	2927	BKWST	0004	1080.00	4.59
2833	#N/A	GDNVL	1202	64.00	4.56
2834	429	GAVSW	0007	1538.00	4.52
2835	117	PAYSW	1223	124.00	4.46
2836	#N/A	SCYEN	0005	1917.00	4.46

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
2837	1048	RCLNS	1406	522.00	4.44
2838	2130	EULTB	5731	514.00	4.40
2839	2675	INAIR	1423	236.00	4.34
2840	2899	NCRST	2202	42.00	4.32
2841	1661	MSLSW	0004	395.00	4.32
2842	1503	RSPCK	2142	924.00	4.31
2843	2578	BNMNW	1101	211.00	4.27
2844	2537	DESPR	1404	563.00	4.12
2845	2809	BLMGR	1902	188.00	4.09
2846	769	NPKWY	0012	2248.00	4.06
2847	2350	BKBNT	1842	556.00	3.95
2848	1989	OKCLS	0005	245.00	3.93
2849	2173	SHDYG	7812	121.00	3.87
2850	2841	RSNHT	1152	1351.00	3.85
2851	522	SHNRW	1614	1174.00	3.85
2852	#N/A	ODNTH	2035	693.00	3.83
2853	1310	SSPNE	1402	70.00	3.81
2854	157	PALMR	2201	61.00	3.80
2855	2886	COMRC	1202	47.00	3.75
2856	3016	SHSTH	1302	20.00	3.74
2857	2735	RCLNS	1404	720.00	3.69
2858	1537	KRUMS	1204	1415.00	3.66
2859	2575	WATSN	5382	1712.00	3.64
2860	2826	RGFTW	6841	28.00	3.63
2861	80	STERT	2706	829.00	3.62
2862	602	REAST	1507	110.00	3.55
2863	2324	MKNSW	2604	2096.00	3.55
2864	794	BSPRG	1901	591.00	3.51
2865	1363	RGLRW	0002	213.00	3.46
2866	788	TNSCL	1104	203.00	3.46
2867	2775	CRLTN	1404	102.00	3.39
2868	2803	HMPHL	2752	415.00	3.37
2869	2749	RRWES	1603	11.00	3.35
2870	2671	DGNST	0005	154.00	3.33
2871	2781	CMTSW	0983	1393.00	3.22
2872	1205	FRMBG	1707	473.00	3.22
2873	228	NCSTH	1504	64.00	3.21
2874	1917	WALNT	0005	997.00	3.18
2875	2893	FRNKF	0007	1405.00	3.02
2876	287	DALLW	0002	66.00	2.98

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
2877	885	RRSTH	1701	3177.00	2.97
2878	2787	DGNST	0008	126.00	2.94
2879	1051	SANSM	3921	1480.00	2.94
2880	1643	FSTVW	0002	140.00	2.89
2881	2746	BRNSO	1808	731.00	2.85
2882	2827	WMRNR	0003	803.00	2.82
2883	2968	CRLTR	2004	237.00	2.81
2884	2914	FSCRK	6724	1401.00	2.78
2885	1401	HKBRY	1103	398.00	2.78
2886	1420	GRLRD	0002	974.00	2.78
2887	2771	BLMND	3211	15.00	2.76
2888	2708	FHLSW	1382	112.00	2.69
2889	1779	RECCR	0001	171.00	2.57
2890	2920	KIMBL	5011	167.00	2.50
2891	2769	FRMBG	1753	724.00	2.49
2892	493	STERT	2703	335.00	2.48
2893	2379	PSHIL	1605	138.00	2.46
2894	2862	IRVHF	2303	87.00	2.42
2895	2761	BNDRA	0013	385.00	2.42
2896	1486	RRNES	2407	3640.00	2.41
2897	2745	DGNST	0006	452.00	2.40
2898	2969	CRLTR	2006	54.00	2.37
2899	1119	MCDMT	2554	2309.00	2.33
2900	2902	ABRRD	0008	2077.00	2.31
2901	3018	SORCY	0002	66.00	2.27
2902	1812	JNKNS	0005	589.00	2.26
2903	2545	WGROB	8421	3295.00	2.23
2904	2352	WNRTH	1419	305.00	2.21
2905	2433	EULES	8714	819.00	2.10
2906	1409	KNLTR	0006	1083.00	2.08
2907	3004	LSCOL	2140	1331.00	2.01
2908	2469	MESTE	1203	176.00	1.92
2909	2561	CURIE	7211	751.00	1.92
2910	2665	JUDCT	0004	181.00	1.88
2911	2250	CLLVL	0001	512.00	1.85
2912	1851	ALNTH	2832	1172.00	1.84
2913	1587	HORNE	1921	284.00	1.83
2914	1927	VGCRK	8031	1808.00	1.78
2915	256	SANSM	3911	1755.00	1.77
2916	2285	CHROW	0008	88.00	1.75

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
2917	2892	MCDMT	2553	595.00	1.72
2918	2953	BDFWD	8911	935.00	1.67
2919	862	MAPLE	0002	1283.00	1.61
2920	#N/A	ROBNW	1505	1332.00	1.57
2921	1384	NMAIN	0241	712.00	1.55
2922	2963	BKWST	0001	387.00	1.55
2923	2808	COTRD	0008	1356.00	1.51
2924	1606	ARMST	0002	1699.00	1.45
2925	2839	WATSN	5372	1338.00	1.43
2926	814	FLMSO	3711	2157.00	1.39
2927	2460	LMBLN	0008	119.00	1.37
2928	2863	SHNRW	1601	414.00	1.36
2929	1836	BUFLO	2603	1400.00	1.35
2930	3001	LEMON	0004	931.00	1.29
2931	2717	SHDYG	7821	95.00	1.28
2932	2780	ROBNW	1501	72.00	1.21
2933	44	TYWST	2002	88.00	1.17
2934	1347	ADISN	1602	228.00	1.17
2935	942	BARRY	1801	88.00	1.16
2936	491	JNKNS	0004	328.00	1.13
2937	2961	ALPHA	0005	138.00	1.08
2938	87	CRLTN	1452	1291.00	1.07
2939	2846	SMFLD	2362	64.00	1.01
2940	2292	PLANO	1102	147.00	1.01
2941	2941	RSPCK	2105	705.00	1.01
2942	2425	CPLSO	4321	165.00	0.97
2943	2928	LOMAL	0015	169.00	0.96
2944	2792	SCHRD	0008	77.00	0.96
2945	1552	NPKWY	0007	181.00	0.95
2946	2924	RECCR	0005	160.00	0.93
2947	2951	BKWST	0006	163.00	0.92
2948	2486	HMPHL	2781	344.00	0.89
2949	213	RSPCK	2131	58.00	0.84
2950	2823	CKRHL	0007	71.00	0.83
2951	#N/A	SWNDL	2106	959.00	0.82
2952	768	COTRD	0005	227.00	0.82
2953	2383	HKBRY	1109	182.00	0.81
2954	#N/A	TYLOR	1101	728.00	0.73
2955	1464	WALST	0002	55.00	0.70
2956	#N/A	STLWC	2101	454.00	0.66

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
2957	2793	BNDRA	0011	396.00	0.55
2958	2882	INWRD	0002	885.00	0.54
2959	2849	RSNHT	1111	350.00	0.52
2960	2069	WTAUG	4651	578.00	0.50
2961	2320	BLTON	1804	478.00	0.48
2962	2950	PLHWY	3701	496.00	0.47
2963	2730	WEBBS	8613	1003.00	0.46
2964	3011	PLANO	1108	481.00	0.45
2965	1568	WEAST	0627	192.00	0.44
2966	2946	CNEXP	0005	457.00	0.44
2967	2907	CKRHL	0004	423.00	0.43
2968	1904	DALWT	2992	336.00	0.42
2969	2635	GAVSW	0002	1246.00	0.41
2970	1449	CNEXP	0008	340.00	0.40
2971	406	HMPHL	2713	510.00	0.36
2972	#N/A	GSTHW	1616	177.00	0.34
2973	#N/A	LIGSW	1623	802.00	0.33
2974	2929	MDLNE	0121	232.00	0.32
2975	2623	ARTHR	0492	54.00	0.30
2976	#N/A	NNTWK	0008	1786.00	0.29
2977	2998	IRLBJ	3222	1038.00	0.27
2978	2913	INAIR	1442	112.00	0.27
2979	786	ROLTR	2913	1906.00	0.26
2980	2060	HMPHL	2733	124.00	0.26
2981	2828	FRMNT	0004	2248.00	0.21
2982	2956	DGNST	0003	1171.00	0.14
2983	2940	FRMNT	0014	685.00	0.14
2984	2865	PROAD	0008	1184.00	0.14
2985	900	PCOIT	1023	410.00	0.12
2986	1435	GAVSW	0010	486.00	0.11
2987	#N/A	NNTWK	0006	928.00	0.11
2988	2908	CURIE	7241	730.00	0.10
2989	#N/A	SMLND	2103	1475.00	0.09
2990	2888	BRYAN	0007	548.00	0.08
2991	2569	JNKNS	0008	659.00	0.07
2992	#N/A	SWNDL	2104	1121.00	0.05
2993	#N/A	NNTWK	0002	754.00	0.04
2994	2932	MAPLE	0004	468.00	0.00
2995	#N/A	RVRFT	0004	87.00	0.00

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2018 SAIDI Ranking	2017 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2018 SAIDI Value
2996	2257	TMSTH	1407	207.00	0.00

Feeders listed below underwent significant reconfigurations during 2018. Customer Count from 2017 SQR was used for calculations.

ALLEN2402
CHYNE9121
ELMAR3211
FLRTN3711
MASON3431
MDLNW1541
MIDWY0612
NCWDN1121
PEGAS2311
PWEST1310
SCYEN0007
TIODE9611

Oncor Electric Delivery

INTERRUPTION CAUSES

Provide the percentage of interruptions attributable to each cause.

2018 Reporting Year

Causes of Forced Interruptions	Percentage
Weather (Including Lightning)	12%
Vegetation	11%
Animals and Birds	14%
People (Including cars and farm equip)	7%
Utility-owned Equipment	48%
Other	0%
Unknown	7%