



Control Number: 49269



Item Number: 24

Addendum StartPage: 0



RECEIVED

2020 JAN 22 AM 11:09

PUBLIC UTILITY COMMISSION
FILING CLERK

January 21, 2020

Public Utility Commission of Texas
1701 Congress Ave
Austin, Texas 78701

**Re: Docket 49269; Jackson Water Supply Corporation's CCN Amendment application
Request for "TCEQ Approval for Construction"**

PUC Reviewer:

After a thorough system study, the Jackson WSC does not require any additional capacity upgrades to absorb addition service connections from the proposed expansion of the existing CCN boundaries. The Jackson WSC has an abundance of total storage capacity, high service pump capacity, pressure tank capacity, and source water capacity in the system.


However, in an effort to be proactive, the Jackson WSC is in the process of drilling a new water well to expand their source water capabilities. There is a signed and executed engineering contract with Schaumburg & Polk, Inc. for this project. Currently, the project is in the property acquisition portion of the design phase. Once the property is acquired, plans can be completed and submitted to TCEQ for approval. Again, this is simply an exercise in proactiveness and is not necessary for Jackson WSC to appropriate these additional areas into their CCN.

Regarding the distribution system, Jackson WSC already has existing distribution lines and service connections in these proposed boundaries (see previously submitted maps). Although Jackson WSC does intend to install some additional line work in these areas once the CCN boundary amendment is approved, this does not need to be designed, engineer sealed, and sent to TCEQ for approval since it does not affect more than 10% of the distribution system. This is a TCEQ rule that we have been specifically admonished for in the past since busy TCEQ reviewers do not want to see distribution system improvements unless it will affect more than 10% of the system. For these reasons, there is currently no TCEQ construction approval letter filed by the applicant for distribution system upgrades.

Please let me know if I can be of further assistance.

Sincerely,

Schaumburg & Polk, Inc.
Travis Reed, P.E.
Project Manager



201