



Control Number: 49493



Item Number: 44

Addendum StartPage: 0



Entergy Services, LLC.
919 Congress Ave. Suite 701
Austin, TX 78701
Tel 512 487 3962
Fax 512 487 3958

RECEIVED

Wajiha Rizvi
Senior Counsel
Legal Services - Regulatory

2019 OCT 14 PM 4:36

PUBLIC UTILITY COMMISSION
AUSTIN, TEXAS

October 14, 2019

Ana Treviño
Filing Clerk
Public Utility Commission of Texas
1701 N. Congress Avenue
Austin, TX 78711-3326

Re: SOAH Docket No. 473-19-4420, PUC Docket No. 49493; Application of Entergy Texas, Inc. to Adjust its Energy Efficiency Cost Recovery Factor

Dear Ms. Treviño:

Entergy Texas, Inc. files the attached clarifications to its demand reduction goal showing kilowatts of lost load due to opt-outs. Included is a revised Table 4: Annual Growth in Demand and Energy Consumption to ETI's Revised Energy Efficiency Plan and Report ("EEPR"). Workpapers to support the revised Table 4 are also included showing a listing of ETI's opt-out customers and source documentation for Table 4 Columns D through G.

ETI hopes that this information provides additional clarity to the calculations included in EEPR Table 4. Please do not hesitate to contact our office should you have any questions or concerns.

Sincerely,

Wajiha Rizvi

Attachments

cc: All Parties of Record

|

174

Calendar Year	Peak Demand at Source (kW)				Industrial Opt Out	Energy Consumption at Meter (kWh)				Growth (kW)	Average Growth (kW)
	Total System		Residential & Commercial[1]			Total System		Residential & Commercial			
	Actual	Weather Adjusted	Actual	Weather Adjusted		Actual	Weather Adjusted	Actual	Weather Adjusted		
2013	3,602.000	3,704.000	2,808.000	2,851.000	NA*	15,945.000	16,743.000	10,410.000	10,443.000	297.000	NA
2014	3,256.000	3,321.000	2,653.000	2,650.000	NA*	18,706.000	18,828.000	11,838.000	11,830.000	-201.000	NA
2015	3,540.000	2,933.000	2,776.000	2,609.000	1,200	16,268.000	16,311.000	10,625.000	10,624.000	-41.000	NA
2016	3,536.000	3,549.000	2,691.000	2,701.000	1,200	16,526.000	16,726.000	10,802.000	10,785.000	92.000	NA
2017	3,468.000	3,481.000	2,647.000	2,704.000	1,200	16,861.250	17,152.000	10,919.000	10,921.000	-19.000	NA
2018	3,534.157	3,604.731	2,699.203	2,745.211	1,200	17,090.313	17,254.251	11,046.313	11,040.122	41.211	NA
2019	NA	NA	NA	NA	1,200	NA	NA	NA	NA	NA	25.600
2020	NA	NA	NA	NA	2,858	NA	NA	NA	NA	NA	-25.558

[1] These amounts already reflect the reduction for opt-outs included in "Industrial Opt Out" Column.

*ETI received no opt-outs for 2013 and 2014.

2

Calendar Year	Peak Demand at Source (MW)				Industrial Opt Out	Energy Consumption at Meter (GWh)				Growth (MW)	Average Growth (MW) ^[1]
	Total System		Residential & Commercial			Total System		Residential & Commercial			
	Actual	Weather Adjusted	Actual	Weather Adjusted		Actual	Weather Adjusted	Actual	Weather Adjusted		
2013	3,602	3,704	2,808	2,851		15,945	16,743	10,410	10,443	297	NA
2014	3,256	3,321	2,653	2,650	NA	18,706	18,828	11,838	11,830	-201	NA
2015	3,540	2,933	2,776	2,609	1	16,268	16,311	10,625	10,624	-41	NA
2016	3,536	3,549	2,691	2,701	1	16,526	16,726	10,802	10,785	92	NA
2017 [2]	3,468	3,481	2,647	2,682	1	16,861	17,152	10,919	10,921	-19	NA
2018	3,534	3,605	2,699	2,704	1	17,090	17,254	11,046	11,040	41	NA
2019	NA	NA	NA	NA	1	NA	NA	NA	NA	NA	25.6
2020	NA	NA	NA	NA	3	NA	NA	NA	NA	NA	-25.6

Calendar Year	Peak Demand at Source (kW)						Energy Consumption at Meter (kWh)				Growth (kW)	Average Growth (kW)
	Total System		Opt Out Customers		Residential & Commercial[1]		Total System		Residential & Commercial			
	Actual	Weather Adjusted	Customer Opt Out (<69 kV)	Transmission Opt Out (>69 KV) [2]	Actual	Weather Adjusted	Actual	Weather Adjusted	Actual	Weather Adjusted	Weather Adjusted	Weather Adjusted
2013	3,602,000	3,704,000	0*	892,671	2,808,155	2,850,669	15,945,000	16,743,000	10,410,000	10,443,000	297,000	NA
2014	3,256,000	3,321,000	0*	671,169	2,654,804	2,652,464	18,706,000	18,828,000	11,838,000	11,830,000	-201,000	NA
2015	3,540,000	2,933,000	1,187	762,663	2,775,915	2,609,045	16,268,000	16,311,000	10,625,000	10,624,000	-41,000	NA
2016	3,536,000	3,549,000	1,187	843,923	2,690,805	2,701,453	16,526,000	16,726,000	10,802,000	10,785,000	92,000	NA
2017	3,468,000	3,481,000	1,187	820,260	2,646,818	2,704,036	16,861,250	17,152,000	10,919,000	10,921,000	-19,000	NA
2018	3,534,157	3,604,731	1,187	833,430	2,699,540	2,744,838	17,090,313	17,254,251	11,046,313	11,040,122	40,802	NA
2019	NA	NA	2,858	NA	NA	NA	NA	NA	NA	NA	NA	25,600
2020	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	-25,640

[1] These amounts already reflect the reduction for opt-outs included in "Industrial Opt Out" Column.

[2] Coincident Factor x Industrial Load

*ETI received no opt-outs for 2013 and 2014.

1,200 in 2018 - 0 in 2013 = 1,200 kW Opt Out Growth

237.4 240 kW 5 Year Average Growth

720 kw

71.22 72 kW

Opt Out Customers

OpCo	Data Type	Revenue Class	Customer	Jan-18	Feb-18	Mar-18	Apr-18	May-18	Jun-18	Jul-18	Aug-18	Sep-18	Oct-18	Nov-18	Dec-18	2018
ETI	MWH	Ind	Customer 1	961	1,026	1,034	1,108	1,125	1,162	1,239	1,191	1,214	1,225	946	830	13,062
ETI	MWH	Ind	Customer 2a	1	1	0	0	0	0	0	1	1	0	0	0	6
ETI	MWH	Ind	Customer 2b	117	219	150	285	205	211	200	232	190	144	93	350	2,397
ETI	MWH	Ind	Customer 2c	123	178	144	267	210	216	213	197	218	203	194	176	2,338
ETI	MWH	Ind	Customer 2d	90	170	125	243	211	163	173	176	179	166	170	150	2,016
ETI	MWH	Ind	Customer 3	1,774	1,777	1,070	1,414	1,744	1,667	1,792	1,912	2,214	2,411	2,676	2,191	22,643
ETI	MWH	Ind	Customer 4	285	416	391	374	287	333	314	453	503	353	628	563	4,900
			Subtotal	3,351	3,786	2,915	3,691	3,783	3,753	3,931	4,161	4,519	4,503	4,707	4,261	47,361
				961	1,026	1,034	1,108	1,125	1,162	1,239	1,191	1,214	1,225	946	830	13,062
				2,390	2,760	1,880	2,583	2,657	2,591	2,692	2,970	3,305	3,278	3,760	3,432	34,300
			TOTAL EXEMPT (kW)													2,858.30

Summer Peaks		Actual Peak MW	Weather Adjusted Peak MW
	Year		
TX Peak (R&W)	1996	2764	2708
	1997	2928	2818
	1998	3221	3009
	1999	3205	3114
	2000	3338	3143
TX Peak (Retail only)	2001	2827	2925
TX Peak (Res. & Com)	2002	2311	2498
	2003	2484	2354
	2004	2569	2612
	2005	2471	2391
	2006	2530	2572
	2007	2663	2587
	2008	2567	2716
	2009	2534	2414
	2010	2642	2701
	2011	2787	2592
	2012	2611	2554
	2013	2808	2851
	2014	2655	2652
	2015	2776	2609
	2016	2691	2701
	2017	2647	2704
	2018	2700	2745
	Forecast	2019	2587
TX Retail Peak less Ind.	2020		
	2021		
	2022		
	2023		
	2024		

5

Winter Peaks		Actual Peak MW	Weather Adjusted Peak MW	
	Year			
TX Peak (Res. & Com)	2011	2391	2301	
	2012	1839	1782	
	2013	2227	2530	
	2014	2067	1982	
	2015	2205	2095	
	2016	1938	2076	
	2017	2229	2229	
	2018	2598	2495	
	Forecast	2019	2287	
	TX Retail Peak less Ind.	2020		
2021				
2022				
2023				
2024				

ETI Weather Adjusted (WA) Non-Coincident Peak Load (MW)

I. Summer Weather-Adjusted ETI Non-coincident Peak Load

1. Input Data

A. Load Data

ETI At Plant

		1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006
Date	[from ISB]								7/24/2001	8/1/2002	8/7/2003	8/5/2004	7/1/2005	8/16/2006
Time	[from ISB]								5pm	4pm	5pm	5pm	5pm	6pm
TX KW Load (kW)	[from ISB]								3,146,000	3,185,000	3,248,000	3,512,000	3,434,000	3,571,000
TX Wholesale (kW)	[from Fontenot/Load Research]								318,582	311,919	202,483	381,658	379,026	459,444
% TX Wholesale	[calc]								10%	10%	6%	11%	11%	13%
TX Retail (kW)	[calc]								2,827,418	2,873,081	3,045,517	3,130,342	3,054,974	3,111,556
TX Industrial Load (MW)	[from CLI]									660.9	660.9	660.9	686.8	684.7
Coincidence Factor	[from SPO]									86%				
Industrial (69kV) load	[calc]									561.7	561.7	561.7	583.8	582.0
Customer Opt Out	[from CLI]													

B. Weather Data

Non-coincident ETI Temperature Data

		1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006
Date	[from ISB]	6/9/1994	8/29/1995	7/22/1996	8/20/1997	8/5/1998	8/26/1999	8/30/2000	7/24/2001	8/1/2002	8/7/2003	8/5/2004	7/1/2005	8/16/2006
Time	[from ISB]	4pm	4pm	4pm	5pm	5pm	5pm	4pm	5pm	4pm	5pm	5pm	5pm	6pm
Port Arthur Max. Daily Temp	[from OPWAQ]	93	96	94	95	97	99	103	95	92	99	96	98	94
Beaumont Max. Daily Temp	[from OPWAQ]												99	97
Houston Max. Daily Temp	[from OPWAQ]												99	96
ETI Peak Temp.	[calc]	93	96	94	95	97	99	103	95	92	99	96	99	96
10-Yr Avg. ETI Peak Temp	[calc]					93	97	98	97	96	96	97	97	97

2. Weather Adjustment

Weather-adjusted Retail Peak

		1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006
Date		6/9/1994	8/29/1995	7/22/1996	8/20/1997	8/5/1998	8/26/1999	8/30/2000	7/24/2001	8/1/2002	8/7/2003	8/5/2004	7/1/2005	8/16/2006
ETI Load (MW)		3,201	2,776	2,764	2,928	3,221	3,205	3,338	2,827	2,311	2,484	2,569	2,471	2,530
ETI Peak Temperature		93	96	94	95	97	99	103	95	92	99	96	99	96
10-Yr Avg. ETI Peak Temp.		0	0	0	0	93	97	98	97	96	96	97	97	97
Temperature Variance (F)						-4	-2	-5	2	4	-3	1	-2	1
Weather Adjustment (MW)						-212	-91	-195	98	187	-130	43	-80	42
WA ETI Peak (MW)			2,614	2,708	2,818	3,009	3,114	3,143	2,925	2,498	2,354	2,612	2,391	2,572

II. Winter Weather-Adjusted ETI Non-coincident Peak Load

1. Input Data

A. Load Data

ETI At Plant

		1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006
Date	[from ISB]									1/4/2002	1/24/2003	1/28/2004	1/24/2005	12/8/2006
Time	[from ISB]									8am	7am	7am	8am	7pm
TX KW Load (kW)	[from ISB]									2,667,000	2,850,000	2,786,000	2,768,000	2,947,000
TX Wholesale (kW)	[from Fontenot/Load Research]									283,355	355,746	356,101	387,407	469,245
% TX Wholesale	[calc]									11%	12%	13%	14%	16%
TX Retail (kW)	[calc]									2,383,645	2,494,254	2,429,899	2,380,593	2,477,755
TX Industrial Load (MW)	[from acct mgr]									772.3	772.3	772.3	772.3	772.3
Coincidence Factor	[from SPO]									86%				

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X	Y											
1	EGSI-TX																																			
2	Weather Response Function																																			
3																																				
4																																				
5	WRF2018-S						WRF2018-W						WRF2017-S						WRF2017-W						WRF2016-S						WRF2016-W					
6	Third-order polynomial fit: $y=a+b*x+c*x^2+d'$																																			
7	Coefficient Data:																																			
8	a = -7887.47						a = 5026.571						a = 0						a = 4904.709						a = 0						a = 4952.094					
9	b = 186.35						b = -94.818						b = -86.54						b = -99.05						b = 53.594						b = -100.076					
10	c = -0.716						c = 0.762						c = 2.355						c = 0.86						c = -0.218						c = 0.86					
11	d =						d =						d = -0.011						d =						d =						d = 0					
12																																				
13																																				
14																																				
15		Temp	Peak Load	Increment Change		Temp	Peak Load	Increment Change		Temp	Peak Load	Increment Change		Temp	Peak Load	Increment Change		Temp	Peak Load	Increment Change		Temp	Peak Load	Increment Change												
16		76	2,140			16	3,705			76	2,197			16	3,540			76	2,814			16	3,571													
17		77	2,216	77		17	3,635	-70		77	2,277	81		17	3,469	-71		77	2,834	20		17	3,499	-72												
18		78	2,292	75		18	3,567	-68		78	2,358	80		18	3,400	-69		78	2,854	20		18	3,429	-70												
19		79	2,366	74		19	3,500	-67		79	2,437	80		19	3,333	-67		79	2,873	19		19	3,361	-68												
20		80	2,438	73		20	3,435	-65		80	2,517	79		20	3,268	-66		80	2,892	19		20	3,295	-67												
21		81	2,509	71		21	3,371	-64		81	2,596	79		21	3,204	-64		81	2,911	18		21	3,230	-65												
22		82	2,579	70		22	3,309	-62		82	2,674	78		22	3,142	-62		82	2,929	18		22	3,167	-63												
23		83	2,647	68		23	3,249	-61		83	2,751	77		23	3,081	-60		83	2,947	18		23	3,105	-61												
24		84	2,714	67		24	3,190	-59		84	2,828	77		24	3,023	-59		84	2,964	17		24	3,046	-60												
25		85	2,779	65		25	3,132	-57		85	2,904	76		25	2,966	-57		85	2,980	17		25	2,988	-58												
26		86	2,843	64		26	3,076	-56		86	2,979	75		26	2,911	-55		86	2,997	16		26	2,931	-56												
27		87	2,906	62		27	3,022	-54		87	3,052	74		27	2,857	-53		87	3,013	16		27	2,877	-54												
28		88	2,967	61		28	2,969	-53		88	3,125	73		28	2,806	-52		88	3,028	15		28	2,824	-53												
29		89	3,026	60		29	2,918	-51		89	3,197	72		29	2,756	-50		89	3,043	15		29	2,773	-51												
30		90	3,084	58		30	2,868	-50		90	3,268	71		30	2,707	-48		90	3,058	15		30	2,724	-49												
31		91	3,141	57		31	2,819	-48		91	3,337	69		31	2,661	-47		91	3,072	14		31	2,676	-48												
32		92	3,197	55		32	2,773	-47		92	3,405	68		32	2,616	-45		92	3,085	14		32	2,630	-46												
33		93	3,250	54		33	2,727	-45		93	3,472	67		33	2,573	-43		93	3,099	13		33	2,586	-44												
34		94	3,303	52		34	2,684	-44		94	3,538	65		34	2,531	-41		94	3,112	13		34	2,544	-42												
35		95	3,354	51		35	2,641	-42		95	3,601	64		35	2,491	-40		95	3,124	12		35	2,503	-41												
36		96	3,403	50		36	2,601	-41		96	3,664	62		36	2,453	-38		96	3,136	12		36	2,464	-39												
37		97	3,452	48		37	2,561	-39		97	3,724	61		37	2,417	-36		97	3,147	12		37	2,427	-37												
38		98	3,498	47		38	2,524	-38		98	3,783	59		38	2,383	-35		98	3,159	11		38	2,391	-36												
39		99	3,544	45		39	2,488	-36		99	3,841	57		39	2,350	-33		99	3,169	11		39	2,357	-34												
40		100	3,588	44		40	2,453	-35		100	3,896	55		40	2,319	-31		100	3,179	10		40	2,325	-32												
41		101	3,630	42		41	2,420	-33		101	3,950	54		41	2,289	-29		101	3,189	10		41	2,295	-30												
42		102	3,671	41		42	2,388	-32		102	4,001	52		42	2,262	-28		102	3,199	9		42	2,266	-29												
43		103	3,711	40		43	2,358	-30		103	4,051	50		43	2,236	-26		103	3,207	9		43	2,239	-27												
44		104	3,749	38		44	2,330	-29		104	4,098	47		44	2,211	-24		104	3,216	8		44	2,214	-25												
45		105	3,785	37		45	2,303	-27		105	4,143	45		45	2,189	-23		105	3,224	8		45	2,190	-24												
46																																				

Z	AA	AB	AC	AD	AE	AF	AG	AH	AI	AJ	AK	AL	AM
1													
2													
3													
4													
5	<u>WRF2015-S</u>			<u>WRF2015-W</u>				<u>WRF2014-S</u>					
6	Third-order polynomial fit: $y=a+b*x+c*x^2+d$			Third-order polynomial fit: $y=a+b*x+c*x^2+d$				Third-order polynomial fit: $y=a+b*x+c*x^2+d$					
7	Coefficient Data:			Coefficient Data:				Coefficient Data:					
8	a = 72650.85			a = 5302.347				a = 236187.325					
9	b = -2496.34			b = -113.521				b = -7967.226					
10	c = 28.87			c = 1.054				c = 89.986					
11	d = -0.108			d = -0.001				d = -0.336					
12													
13													
14													
15	Temps	Peak Load	Increment Change	Temps	Peak Load	Increment Change	Temps	Peak Load	Increment Change				
16	76	2,273		16	3,752		76	2,941					
17	77	2,297	25	17	3,672	-80	77	2,843	-99				
18	78	2,330	32	18	3,595	-78	78	2,769	-74				
19	79	2,369	40	19	3,519	-76	79	2,718	-51				
20	80	2,416	46	20	3,446	-74	80	2,688	-30				
21	81	2,468	52	21	3,374	-72	81	2,676	-12				
22	82	2,525	57	22	3,304	-70	82	2,681	5				
23	83	2,587	62	23	3,237	-68	83	2,701	20				
24	84	2,653	66	24	3,171	-66	84	2,733	32				
25	85	2,722	69	25	3,107	-64	85	2,776	43				
26	86	2,794	72	26	3,046	-62	86	2,828	52				
27	87	2,868	74	27	2,986	-60	87	2,886	58				
28	88	2,943	75	28	2,928	-58	88	2,948	63				
29	89	3,019	76	29	2,872	-56	89	3,014	65				
30	90	3,095	76	30	2,818	-54	90	3,080	66				
31	91	3,171	75	31	2,766	-52	91	3,144	64				
32	92	3,245	74	32	2,716	-50	92	3,205	61				
33	93	3,317	72	33	2,668	-48	93	3,260	55				
34	94	3,387	70	34	2,622	-46	94	3,308	48				
35	95	3,454	67	35	2,577	-44	95	3,347	38				
36	96	3,517	63	36	2,535	-42	96	3,373	27				
37	97	3,575	58	37	2,494	-41	97	3,387	13				
38	98	3,628	53	38	2,456	-39	98	3,384	-2				
39	99	3,676	47	39	2,419	-37	99	3,364	-20				
40	100	3,717	41	40	2,384	-35	100	3,325	-40				
41	101	3,751	34	41	2,351	-33	101	3,264	-61				
42	102	3,777	26	42	2,320	-31	102	3,179	-85				
43	103	3,795	18	43	2,290	-29	103	3,068	-110				
44	104	3,804	9	44	2,263	-28	104	2,930	-138				
45	105	3,803	-1	45	2,237	-26	105	2,762	-168				
46													

	AN	AO	AP	AQ	AR	AS	AT	AU	AV	AW	AX	AY	AZ	BA	BB	BC	BD	BE	BF	BG
1																				
2																				
3																				
4																				
5	<u>WRF2014-W</u>				<u>WRF2013-S</u>				<u>WRF2013-W</u>				<u>WRF2012-S</u>							
6	Second-order polynomial fit: $y=a+b*x+c*x^2$				Third-order polynomial fit: $y=a+b*x+c*x^2+d*x^3$				Third-order polynomial fit: $y=a+b*x+c*x^2+d*x^3$				Third-order polynomial fit: $y=a+b*x+c*x^2+d*x^3$							
7	Coefficient Data:				Coefficient Data:				Coefficient Data:				Coefficient Data:							
8	a =	7345.782			a =	140500.097			a =	4162.046			a =	118010.45						
9	b =	-205.196			b =	-4818.248			b =	-6.032			b =	-4063.21						
10	c =	1.978			c =	55.201			c =	-1.619			c =	46.80						
11					d =	-0.207			d =	0.019			d =	-0.18						
12																				
13																				
14																				
15	Temps	Peak Load	Increment Change		Temps	Peak Load	Increment Change		Temps	Peak Load	Increment Change		Temps	Peak Load	Increment Change					
16	16	4,569			76	2,286			16	3,729			76	2,281						
17	17	4,429	-140		77	2,279	-7		17	3,685	-44		77	2,288	8					
18	18	4,293	-136		78	2,287	8		18	3,640	-45		78	2,308	20					
19	19	4,161	-132		79	2,309	22		19	3,593	-46		79	2,339	31					
20	20	4,033	-128		80	2,343	34		20	3,546	-47		80	2,381	41					
21	21	3,909	-124		81	2,387	45		21	3,497	-48		81	2,431	50					
22	22	3,789	-120		82	2,442	55		22	3,448	-49		82	2,490	59					
23	23	3,673	-116		83	2,505	63		23	3,398	-50		83	2,555	66					
24	24	3,560	-112		84	2,576	71		24	3,347	-51		84	2,627	71					
25	25	3,452	-108		85	2,652	77		25	3,296	-51		85	2,703	76					
26	26	3,348	-104		86	2,734	81		26	3,245	-52		86	2,783	80					
27	27	3,247	-100		87	2,819	85		27	3,193	-52		87	2,866	83					
28	28	3,151	-96		88	2,906	87		28	3,141	-52		88	2,951	85					
29	29	3,059	-92		89	2,995	88		29	3,089	-52		89	3,037	85					
30	30	2,970	-88		90	3,083	88		30	3,037	-52		90	3,122	85					
31	31	2,886	-85		91	3,170	87		31	2,985	-52		91	3,205	84					
32	32	2,805	-81		92	3,254	84		32	2,934	-51		92	3,287	81					
33	33	2,728	-77		93	3,335	80		33	2,883	-51		93	3,364	78					
34	34	2,656	-73		94	3,410	75		34	2,832	-51		94	3,437	73					
35	35	2,587	-69		95	3,479	69		35	2,782	-50		95	3,504	67					
36	36	2,522	-65		96	3,540	61		36	2,733	-49		96	3,565	61					
37	37	2,461	-61		97	3,593	53		37	2,685	-48		97	3,618	53					
38	38	2,405	-57		98	3,635	43		38	2,638	-47		98	3,662	44					
39	39	2,352	-53		99	3,667	31		39	2,591	-46		99	3,696	34					
40	40	2,303	-49		100	3,685	19		40	2,546	-45		100	3,719	23					
41	41	2,258	-45		101	3,690	5		41	2,503	-44		101	3,731	11					
42	42	2,217	-41		102	3,680	-10		42	2,460	-42		102	3,729	-2					
43	43	2,180	-37		103	3,653	-26		43	2,420	-41		103	3,713	-16					
44	44	2,147	-33		104	3,609	-44		44	2,381	-39		104	3,682	-31					
45	45	2,117	-29		105	3,547	-63		45	2,344	-37		105	3,634	-47					
46																				

9

	BH	BI	BJ	BK	BL	BM	BN	BO	BP	BQ	BR	BS	BT	BU	BV	BW	BX	BY	BZ	CA	CB	CC
1																						
2																						
3																						
4																						
5	WRF2012-W																					
6	Second-order polynomial fit: $y=a+b*x+c*x^2$																					
7	Coefficient Data:																					
8	a = 5217.68																					
9	b = -97.99																					
10	c = 0.71																					
11																						
12																						
13																						
14																						
15																						
16	Temps	Peak Load	Increment Change																			
17	16	3,830																				
18	17	3,756	-75																			
19	18	3,682	-73																			
20	19	3,610	-72																			
21	20	3,540	-70																			
22	21	3,471	-69																			
23	22	3,403	-68																			
24	23	3,337	-66																			
25	24	3,272	-65																			
26	25	3,209	-63																			
27	26	3,147	-62																			
28	27	3,086	-61																			
29	28	3,027	-59																			
30	29	2,969	-58																			
31	30	2,912	-56																			
32	31	2,857	-55																			
33	32	2,804	-54																			
34	33	2,752	-52																			
35	34	2,701	-51																			
36	35	2,652	-49																			
37	36	2,604	-48																			
38	37	2,557	-47																			
39	38	2,512	-45																			
40	39	2,468	-44																			
41	40	2,426	-42																			
42	41	2,385	-41																			
43	42	2,346	-39																			
44	43	2,308	-38																			
45	44	2,271	-37																			
46	45	2,236	-35																			

WRF2011-S

Third-order polynomial fit: $y=a+b*x+c*x^2+d*x^3$
 Coefficient Data:
 a = 3,688,384
 b = -126,726
 c = 1,569
 d = -5.15

WRF2010-S

Third-order polynomial fit: $y=a+b*x+c*x^2$
 Coefficient Data:
 a = 2467.74
 b = -36 603
 c = 0.003423

WRF2000-S

Sinusoidal Fit: $y=a+b*cos(cx+d)$
 Coefficient Data:
 a = 2651 83010
 b = 815.02314
 c = 0.067686887
 d = -1.3094586

WRF-S

Sinusoidal Fit: $y=a+b*cos(cx+d)$
 Coefficient Data:
 a = 2459.3946
 b = 760.39451
 c = 0.078037081
 d = -2.2403384

10

	CD	CE	CF	CG
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				
26				
27				
28				
29				
30				
31				
32				
33				
34				
35				
36				
37				
38				
39				
40				
41				
42				
43				
44				
45				
46				

WRF2011-W
 Quadratic fit: $y=a+b*x+c*x^2$
 Coefficient Data:
 a = 3621.6
 b = -85.924
 c = 0.72747

Temps	Peak Load	Increment Change
21	2,138	
22	2,083	-55
23	2,030	-53
24	1,978	-52
25	1,928	-50
26	1,879	-49
27	1,832	-47
28	1,786	-46
29	1,742	-44
30	1,699	-43
31	1,657	-42
32	1,617	-40
33	1,578	-39
34	1,541	-37
35	1,505	-36
36	1,471	-34
37	1,438	-33
38	1,407	-31
39	1,377	-30
40	1,349	-28
41	1,322	-27
42	1,296	-26
43	1,272	-24
44	1,249	-23
45	1,228	-21
46	1,208	-20
47	1,190	-18
48	1,173	-17
49	1,158	-15
50	1,144	-14
51	1,132	-12