

Control Number: 49795



Item Number: 78

Addendum StartPage: 0

PUC DOCKE SOAH DOCKET	Г NO. 49795 NO. 473-20-1118	RECEIVED APR - 3 2020
COMPLAINT OF PETTY GROUP, LLPAGAINST RIO GRANDE ELECTRIC§COOPERATIVE, INC.§	BEFOR STATE O ADMINISTRAT	RETHEBY FFICE OF IVE HEARPICE

DIRECT TESTIMONY

OF

ROBERT D. GRUBB, P.E.

ON BEHALF OF

PETTY GROUP, LLP

Sponsoring Petty Exhibit Nos. RG-1 through RG-10

April 3, 2020

PUC DOCKET NO. 49795 SOAH DOCKET NO. 473-20-1118

COMPLAINT OF PETTY GROUP, LLP	§	BEFORE THE
AGAINST RIO GRANDE ELECTRIC	§	STATE OFFICE OF
COOPERATIVE, INC.	§	ADMINISTRATIVE HEARINGS

TABLE OF CONTENTS

I.	INTRODUCTION, EXPERIENCE AND QUALIFICATIONS	1
II.	SCOPE OF TESTIMONY	5
III.	EXPLANATION OF HARMONIC DISTORTION AND IEEE STANDARD 519	7
IV.	SAFETY AND RELIABILITY PROBLEMS CAUSED BY EXCESSIVE HARMONICS	14
V.	RGEC'S THIRD PARTY REPORTS NOTIFIED THE COOPERATIVE OF EXCESSIVE HARMONICS ON THE BRUNDAGE LINE	17
VI.	GEI POWER QUALITY MONITORING RESULTS SHOWING EXCESSIVE HARMONICS ON THE RGEC SIDE OF THE METER	23
VII.	PETTY'S LOAD DID NOT CAUSE OR CONTRIBUTE TO THE EXCESSIVE HARMONICS	25
VIII.	CONCLUSION	27

PUC DOCKET NO. 49795 SOAH DOCKET NO. 473-20-1118

§

ş ş

COMPLAINT OF PETTY GROUP, LLP AGAINST RIO GRANDE ELECTRIC COOPERATIVE, INC. BEFORE THE STATE OFFICE OF ADMINISTRATIVE HEARINGS

LIST OF EXHIBITS

Exhibit RG-1 List of Prior Appearances Exhibit RG-2 Resume Exhibit RG-3 GEI "Harmonic Analysis at the Petty Ranch" report (Confidential) Exhibit RG-4 RGEC Response to Petty RFI 1-25 Exhibit RG-5 **IEEE Standard 519** Exhibit RG-6 Line Diagram of Petty Electrical Service (Confidential) Exhibit RG-7 Eaton Report (October 2014) (Confidential) Exhibit RG-8 TXUE Report (March 19, 2015) (Confidential) Exhibit RG-9 Schneider Engineering Report (August 28, 2018) (Confidential) Exhibit RG-10 Chart of energy sales to oil and gas loads from 2010-2018 (Confidential) Exhibit RG-11 GEI Harmonic Monitoring Summary (Confidential) Exhibit RG-12 RGEC Response to Petty RFI 5-3

PUC DOCKET NO. 49795 SOAH DOCKET NO. 473-20-1118

	CON AGA COO	IPLAINT OF PETTY GROUP, LLP§BEFORE THEINST RIO GRANDE ELECTRIC§STATE OFFICE OFIPERATIVE, INC.§ADMINISTRATIVE HEARINGS	
I			
2		DIRECT TESTIMONY OF ROBERT D. GRUBB, P.E.	
3		I. INTRODUCTION, EXPERIENCE AND QUALIFICATIONS	
4	Q.	PLEASE STATE YOUR NAME, EMPLOYER, TITLE AND BUSINESS ADDRESS.	
5	А.	My name is Robert D. Grubb. I am the founder and Principal Engineer for Grubb	
6		Engineering. Inc. ("GEI"). My business address is 2727 North Saint Mary's Street, San	
7		Antonio, Texas 78212.	
8	Q.	ON WHOSE BEHALF ARE YOU SUBMITTING THIS TESTIMONY?	
9	A.	I am testifying on behalf of Petty Group, LLP ("Petty").	
10	Q.	PLEASE OUTLINE YOUR EDUCATIONAL BACKGROUND.	
11	A.	I have a Bachelor of Science in Electrical Engineering from the University of Texas at	
12		Austin. I have also attended 85 classroom hours (equivalent to a graduate course) for	
13		"Modeling and Analysis of Modern Power Systems" at the University of Texas at	
14		Arlington.	
15	Q.	ARE YOU A REGISTERED PROFESSIONAL ENGINEER?	
16	А.	Yes. I am a registered professional engineer in the State of Texas and the State of California.	
17	Q.	PLEASE DESCRIBE GEI'S CERTIFICATIONS AND ACCREDITATIONS.	
18	А.	GEI is registered as an engineering firm with the Texas Board of Professional Engineers.	
19		Its technical services division is an accredited, full-time member of the InterNational	
20		Electrical Testing Association ("NETA"). GEI's eleven Technical Service employees are	:
21		certified Electrical Test Technicians ("ETT") Levels 1 through 3.	
	DIRE	CT TESTIMONY OF ROBERT D. GRUBB, P.E. PAGE 1	

1

0.

ARE YOU A MEMBER OF ANY PROFESSIONAL ORGANIZATIONS?

- A. I am a Senior Life member of the Institute of Electrical and Electronic Engineers ("IEEE"),
 and a member of the IEEE Power Engineering Society.
- 4

Q. PLEASE DESCRIBE YOUR PROFESSIONAL EXPERIENCE.

A. I have nearly 50 years of experience in electrical engineering. I founded GEI in 1981 after
working for 11 years at City Public Service Energy ("CPSE") (formerly, City Public
Service Board, *et. al.*). The firm provides planning, design, engineering studies, and
technical services for electrical power systems. The firm has significant experience in the
design, analysis, commissioning, and maintenance of low, medium, and high voltage
electrical power systems, as well as instrumentation, control, and supervisory control and
data acquisition ("SCADA") design.

12 Since its inception, GEI has provided engineering services to electric utility 13 companies, water and wastewater utilities, and large industrial customers with electrical 14 infrastructure design needs. This includes utilities such as CPSE, New Braunfels Utilities, Medina Electric Cooperative, Austin Energy, Bandera Electric Cooperative, Magic Valley 15 Cooperative, Cal-Energy, Philippine National Oil Company, Magma Geothermal, Central 16 17 and Southwest, Central Power & Light, Guadalupe Valley Electric Coop. and Texas State 18 University Co-Gen. GEI has also provided engineering services to a number of water and 19 wastewater municipalities. Services have included low and medium voltage electrical 20 distribution design, instrumentation system design, SCADA systems design, control 21 system design, security system design, radio path studies, power system studies, and acceptance and maintenance testing. Municipalities include the San Antonio Water 22 System, San Antonio River Authority, Canyon Regional Water Authority, and Guadalupe 23

24

DIRECT TESTIMONY OF ROBERT D. GRUBB, P.E.

Blanco River Authority.

1		Prior to founding GEI, I served as Chief System Protection Engineer for City Public
2		Service (now CPSE) where I worked for 11 years. My duties at City Public Service
3		included planning, electrical design, coordination, and management of a wide range of
4		electric power substation, electric transmission, electric distribution, and water and
5		wastewater plant projects. I had oversight of electric substation design, transmission
6		planning, distribution planning, and relay testing and maintenance. I left City Public
7		Service in 1981 to found GEI.
8 9	Q.	AS THE PRINCIPAL ENGINEER FOR GEI, DO YOU HAVE OVERSIGHT OF GEI'S TECHNICAL, DESIGN, AND ENGINEERING SERVICES?
10	А.	Yes.
11 12	Q.	PLEASE DESCRIBE GEI'S EXPERIENCE WITH ENGINEERING SERVICES FOR ELECTRICAL POWER SYSTEMS.

13 In the beginning, GEI clients were primarily electric utilities and large industrial power Α. 14 users. The firm has done a number of Protective Device Coordination Studies primarily for electric cooperatives and municipal utilities to assure reliability. Some were done as a 15 sub-consultant to other engineering firms lacking the expertise in those studies. One of the 16 17 first projects GEI completed was for a mini steel mill where it designed an electric demand 18 control scheme removing electrodes from the furnace when a targeted not-to-exceed 19 demand was approached. In 1983, GEI began designing medium-voltage plant electrical 20 distribution for San Antonio Water Systems ("SAWS," formerly City Water Board). That 21 SAWS association is still intact today.

1Q.PLEASE DESCRIBE THE SERVICES PERFORMED BY GEI'S TECHNICAL2SERVICES DIVISION.

3 A. GEI's technical services division employees are NETA accredited. The technical services 4 division provides power system testing and maintenance for high, medium, and low voltage 5 equipment. This includes transformer testing, power cable testing and cable identification, 6 switchgear circuit breaker testing and maintenance, relay testing and calibration, auto 7 transfer switch testing and maintenance, low-voltage circuit breaker testing and repair, 8 motor testing, current transformer, potential transformer and control power transformer 9 testing, and panelboard and switchboard testing. The technical services division also 10 provides additional services, such as power quality and power consumption monitoring, 11 ground testing, thermal infrared scanning, load bank testing, and maintenance shutdowns.

12Q.PLEASE DESCRIBE GEI'S QUALIFICATIONS IN POWER QUALITY13MONITORING.

14 The mechanics of power quality monitoring are the same as any other voltage and current Α. 15 measurement on a power system. A device capable of measuring voltage and current with 16 powerful resolution is connected to the system and captures data pertinent to power 17 consumption, frequency, and harmonic content. The software inside the machine performs 18 calculations providing levels for measured parameters. The analysis of these levels are the 19 key to successful power quality monitoring. I was first introduced to harmonics 50 years ago, when a college senior, through a lab project wherein I had to analyze a distorted 20 21 waveform using Fourier Analysis to determine harmonic content. Over the next 50 years, 22 there have been a number of instances where my working knowledge was put to use. 23 During my employment at CPSE, I worked with settings for "harmonic restraint transformer differential relays." I have also worked with clients on investigations related 24 25 to harmonics issues.

DIRECT TESTIMONY OF ROBERT D. GRUBB, P.E.

1	Q.	WHAT TRAINING DO YOU HAVE IN POWER QUALITY MONITORING?
2	А.	Over the years GEI has had numerous informational presentations provided by suppliers
3		of harmonic monitoring and harmonic mitigating equipment. I have also had project and
4		research experience on harmonics.
5	Q.	HAVE YOU PREVIOUSLY TESTIFIED BEFORE THIS COMMISSION?
6	A.	No.
7 8	Q.	HAVE YOU PREVIOUSLY TESTIFIED BEFORE ANY REGULATORY COMMISSIONS OR COURTS?
9	А.	A list of the court proceedings where I have offered expert testimony is attached as Exhibit
10		RG-1. 1 also attach my current resume as Exhibit RG-2.
11 12	Q.	WAS THIS TESTIMONY PREPARED BY YOU OR UNDER YOUR DIRECT SUPERVISION AND CONTROL?
13	А.	Yes.
14		II. SCOPE OF TESTIMONY
15	Q.	WHAT IS THE SCOPE OF YOUR TESTIMONY?
16	А.	My testimony will address the following:
17 18		• An explanation of harmonics and IEEE Standard 519, IEEE Recommended
		Practices and Requirements for Harmonic Control in Electric Power Systems;
19		 Practices and Requirements for Harmonic Control in Electric Power Systems; Safety and reliability problems caused by excessive harmonics;
19 20 21		 Practices and Requirements for Harmonic Control in Electric Power Systems; Safety and reliability problems caused by excessive harmonics; Third-party engineering reports notifying Rio Grande Electric Cooperative ("RGEC" or "the "Cooperative") of excessive harmonics on the Brundage line;
19 20 21 22 23		 Practices and Requirements for Harmonic Control in Electric Power Systems; Safety and reliability problems caused by excessive harmonics; Third-party engineering reports notifying Rio Grande Electric Cooperative ("RGEC" or "the "Cooperative") of excessive harmonics on the Brundage line; GEI's investigation of the electric service disruptions experienced by Petty and the results of its power quality monitoring;
 19 20 21 22 23 24 25 		 Practices and Requirements for Harmonic Control in Electric Power Systems; Safety and reliability problems caused by excessive harmonics; Third-party engineering reports notifying Rio Grande Electric Cooperative ("RGEC" or "the "Cooperative") of excessive harmonics on the Brundage line; GEI's investigation of the electric service disruptions experienced by Petty and the results of its power quality monitoring; The basis of GEI's conclusion that Petty's load did not cause or contribute to the excessive harmonics; and

DIRECT TESTIMONY OF ROBERT D. GRUBB, P.E.

- 1 2
- Petty's disconnection from the grid as a result of the ongoing reliability problems on the RGEC distribution line and impaired power quality.

Q. DESCRIBE THE POWER QUALITY INVESTIGATION SERVICES GEI HAS PROVIDED PETTY.

5 Α. GEI was hired by Petty on or about April 2, 2019 to analyze power quality problems at the 6 Petty Ranch that Petty's electrician, Nathan Morgan, observed during construction of new 7 residences at the Petty Ranch in early 2019. GEI's technical services division installed a 8 power quality meter to monitor the point of common coupling ("PCC") between Petty and 9 the RGEC distribution system on or about April 29, 2019. GEI's technical services division 10 monitored harmonics at the PCC and provided technical support to Petty when the meter 11 readings showed excessive voltage harmonics on the RGEC distribution system that were 12 negatively impacting the electric power quality at the Petty Ranch. GEI provided technical 13 support to Petty during meetings with RGEC regarding the power quality problems at the 14 ranch. It also investigated the harmonics on Petty's load current after RGEC claimed that the Petty load was not compliant with IEEE Standard 519. GEI investigated whether 15 16 Petty's load had caused the harmonics issues raised in Petty's complaint, and it provided Petty a report to share with RGEC that concluded that the power quality problems at the 17 ranch were not created by the Petty Ranch load. GEI's report "Harmonic Analysis at the 18 19 Petty Ranch" is attached as Exhibit RG-3.

DIRECT TESTIMONY OF ROBERT D. GRUBB, P.E.

1Q.IN ADDITION TO POWER QUALITY MONITORING, WHAT2TROUBLESHOOTING DID GEI DO TO DETERMINE WHAT CAUSED THE3ELECTRICAL PROBLEMS AT THE PETTY RANCH?

A. The power quality monitoring included examination of voltage surges, sags, spikes, and
current impulses, along with harmonics. All of these parameters are measured by the same
machine. Before GEI started the monitoring, we had not confirmed what was causing the
problems, so all of these parameters needed to be measured. As a result of analyzing the
recordings, GEI determined that the electric service impairments were caused by excessive
harmonics in the RGEC supply voltage.

- 10 III. EXPLANATION OF HARMONIC DISTORTION AND IEEE STANDARD 519
- 11

О.

WHAT IS HARMONIC DISTORTION?

A. Harmonic distortion is a misshaping of waveforms, voltage, and current due to the addition
multiples of the fundamental frequency in an electrical distribution system. In a normal
alternating current system, the sine wave varies at a specific fundamental frequency, e.g.,
60 hertz. Harmonic distortion in a 60 hertz system is effectively a distortion of the 60 hertz
sine wave by multiples of the fundamental being added to the fundamental frequency sine
wave, *i.e.*, 3rd harmonic is 180 hertz, 5th is 300 hertz, etc.

18 Q. WHAT CAUSES HARMONIC DISTORTION?

19 A. Harmonics are caused by non-linear loads on electric power systems. All non-linear loads 20 can create some minor level of harmonic distortion on electrical current, but excessive 21 harmonic distortion from non-linear loads causes unsafe, unreliable and impaired electric 22 power, or what in the industry is called "dirty power." The main culprit of excessive 23 harmonic distortion on RGEC's electric distribution system are variable speed electronic 24 motor controls, i.e., variable frequency drives ("VFDs"), that are used to start large

DIRECT TESTIMONY OF ROBERT D. GRUBB, P.E.

industrial motors.¹ VFDs are known to cause harmful harmonics by drawing a 2 nonsinusoidal current and introducing nonlinear voltage throughout the distribution system.

4 Q. IS VFD USAGE COMMON ON THE DISTRIBUTION LINE THAT SERVES THE 5 **PETTY RANCH?**

6 А. Yes.

1

3

7 О. PLEASE EXPLAIN.

8 Α. The Petty Ranch is located in South Texas in the Eagle Ford Shale region. As described in 9 the direct testimony of Kyle Haley, the area has seen a large increase in oil and gas drilling 10 operations in the last ten years. Service to the Petty Ranch is from a 53-mile long 11 distribution line that originates at the RGEC Brundage Substation (the "Brundage line").² 12 The Brundage line serves primarily oil and gas loads and several operators. In 2019, load on the line was 78.3% industrial and 6.3% residential.³ Oil and gas customers commonly 13 14 use large motors and, as a result, they install VFDs to satisfy utility requirements of service 15 for soft starts to mitigate voltage drop during motor starts. For example, RGEC's tariff 16 requires that any customer with a large motor load in excess of 100 horsepower have "a reduced voltage start device as specified by the Cooperative's engineering department."⁴ 17 18 VFDs are approved by RGEC's engineering department for this purpose and widely used 19 by oil and gas loads, but installation of VFDs without harmonic mitigating equipment such 20 as a filter is known to cause excessive harmonic distortion, impaired power quality, and 21 problems with electrical equipment.

¹ See Deposition Exhibit 5, Notice letter from RGEC.

² Deposition Exhibit 7, Eaton Report at RGEC 1041.

³ See Exhibit RG-4, Deposition Exhibit 12, RGEC Response to RFI 1-25.

⁴ See RGEC Tariff at Sheet 20.

1Q.WHAT STANDARDS GOVERN RECOMMENDED UTILITY PRACTICE FOR2PERMISSIBLE LEVELS OF HARMONICS ON AN ELECTRIC POWER3SYSTEM?

A. IEEE Standard 519, *IEEE Recommended Practice for Requirements for Harmonic Control in Electric Power Systems*, is the electric utility industry standard for recommended
practices addressing harmonics. I am not a lawyer or an electric regulatory expert, but I
understand the Public Utility Commission of Texas ("PUCT" or the "Commission") Power
Quality Rule, PUCT Subst. R. 25.51(c), has adopted IEEE Standard 519 as the applicable
standard in addressing harmonics problems.⁵ RGEC CEO Roger Andrade also testified that
the Cooperative must comply with the Commission's Power Ouality Rule.⁶

11 Q. PLEASE EXPLAIN HOW IEEE STANDARD 519 DEFINES HARMONICS.

12 IEEE Standard 519 defines a harmonic as "a component of order greater than one of the **A**. 13 Fourier series of a periodic quantity. For example, in a 60 Hz system, the harmonic order 14 3, also known as the 'third harmonic,' is 180 Hz." PUCT Subst. R. § 25.51 adopts the IEEE 15 519 definition. Subsection (c) of the Power Quality Rule states: "In 60 Hertz electric power 16 systems, a harmonic is a sinusoidal component of the 60 Hertz fundamental wave having 17 a frequency that is an integral multiple of the fundamental frequency." In layman's terms, too much harmonics in a power system means that the harmonic values either add to, or 18 19 subtract from, the fundamental value of voltage in such a way as to cause overvoltage or undervoltage and create power quality problems. The same can be said for current 20 21 harmonics.

⁵ See 16 Tex. Admin. § 25.51(c).

⁶ Deposition Tr. R. Andrade at 37-43 (Jan. 31, 2020).

DIRECT TESTIMONY OF ROBERT D. GRUBB, P.E.





2 3

0.

WHAT ARE EXCESSIVE HARMONICS?

4 A. All non-linear loads can create harmonics, but excessive harmonics on an electrical power 5 system are harmonics at a level that jeopardize safe and reliable power to other customers 6 and damage electrical equipment on the system. The Commission's Power Quality Rule 7 defines "excessive harmonics" as "levels of current or voltage distortion at the point of 8 common coupling between the electric utility and the customer outside the levels recommended in [IEEE Standard 519]."7 IEEE Standard 519 is attached to my testimony 9 10 as Exhibit RG-5. The standard establishes both voltage distortion limits and current 11 distortion limits for systems rated 120 V through 69 kV.

12Table 1 of IEEE 519 sets Total Harmonic Distortion ("THD") voltage distortion13limits at the PCC as follows:

⁷ 16 TAC § 25.51(c).DIRECT TESTIMONY OF ROBERT D. GRUBB, P.E.

<u>Table 1</u> -	· Voltage	Distortion	Limits
------------------	-----------	------------	--------

Table 2 – Current distortion limits for systems rated 120 V through 69 kV

Bus voltage V at PCC	Individual harmonic (%)	Total harmonic distortion THD (%)
$V \le 1.0 \text{ kV}$	5.0	8.0
$1 \text{ kV} < \text{V} \le 69 \text{ kV}$	3.0	5.0
$69 \text{ kV} < \text{V} \le 161 \text{ kV}$	1.5	2.5
161 kV < V	1.0	1.5

2

1

Table 2 of IEEE 519 sets current distortion limits as follows:

3

Maximum harmonic current distortion in percent of I_L Individual harmonic order (odd harmonics)						
				I _{SC} /IL	$3 \le h < 11$	$11 \le h \le 17$
< 20	4.0	2.0	1.5	0.6	0.3	5.0
20 < 50	7.0	3.5	2.5	1.0	0.5	8.0
50 < 100	10.0	4.5	4.0	1.5	0.7	12.0
100 < 1000	12.0	5.5	5.0	2.0	1.0	15.0
> 1000	15.0	7.0	6.0	2.5	1.4	20.0

4

5

6

In calculating current distortion limits, IEEE Standard 519 states that current distortion limits should be calculated using maximum demand current during each of the twelve previous months divided by twelve.

1 **Q**. WHAT IS THE PCC?

2 Α. IEEE 519 defines the PCC as the "point on a public power supply system, electrically 3 nearest to a particular load, at which other loads are, or could be, connected. The PCC is a 4 point located upstream of the considered installation."

5 0. WHY IS THE DEFINITION OF PCC RELEVANT?

6 Per IEEE 519 and Table 1 above, the bus voltage at PCC determines the voltage THD A. 7 percent limit. For example, if bus voltage at the PCC is less than 1 kV, the voltage THD 8 limit is 8%. If bus voltage at the PCC is greater than 1 kV and less than or equal to 69 kV. 9 the voltage THD limit is 5%.

PLEASE DESCRIBE THE VOLTAGE OF ELECTRIC SERVICE AT THE PETTY 10 О. 11 RANCH.

- The Petty residences and hunting lodge are served off single-phase distribution service. 12 Α.
- The 250kVA service is 240/120V on the low side of the transformer and 14.4 kV on the 13 high (or primary) side of the transformer. A simplified line drawing of the service is 14 15 attached as Exhibit RG-6.

ARE ANY OTHER CUSTOMERS SERVED OFF THE LOW SIDE OF THE PETTY 16 **Q**. 17 **TRANSFORMER?**

18 No. Α.

HOW MANY METERS ARE SERVED OFF THE LOW SIDE OF THE PETTY 19 Q. 20 **TRANSFORMER?**

21 Α. One.

IF THERE ARE NO OTHER CUSTOMER LOADS SERVED ON THE LOW SIDE 22 0. OF THE PETTY TRANSFORMER, WHERE IS PETTY'S PCC WITH THE RGEC 23 24 **DISTRIBUTION SYSTEM?**

- Based on the IEEE 519 definition referenced above, the PCC is on the high side of the 25 A.
- Petty transformer, which is 14.4 kV. Based on IEEE 519's Table 1 above, this means 26

DIRECT TESTIMONY OF ROBERT D. GRUBB, P.E.

1		excessive harmonics at the Petty PCC would be voltage harmonics greater than the THD
2		limit of 5.0%.
3 4	Q.	HAS GEI MONITORED VOLTAGE HARMONICS ABOVE 5% AT THE PETTY PCC WITH RGEC?
5	А.	Yes, and on multiple occasions. I will address the results of GEI's monitoring in Section
6		VI of my testimony.
7 8		IV. SAFETY AND RELIABILITY PROBLEMS CAUSED BY EXCESSIVE HARMONICS
9 10	Q.	WHAT DANGERS DO EXCESSIVE VOLTAGE HARMONICS CAUSE TO PETTY AND OTHER RGEC CUSTOMERS ON THE BRUNDAGE LINE?
11	A.	Harmonic distortion can cause severe problems with electrical equipment connected to a
12		system. The most dangerous problem with excessive harmonics is the over-heating they
13		cause in electrical wiring and equipment, which can result in fires. Also, they can cause
14		equipment failures in motors and in electronic control devices, which are both problematic
15		and costly.
16 17 18	Q.	DO EXCESSIVE VOLTAGE HARMONICS CAUSE THE ELECTRIC SERVICE DISRUPTIONS DESCRIBED BY PETTY'S ELECTRICIAN NATHAN MORGAN IN HIS DIRECT TESTIMONY?
19	А.	Yes.
20 21 22	Q.	DO EXCESSIVE VOLTAGE HARMONICS CAUSE THE ELECTRIC SERVICE DISRUPTIONS DESCRIBED BY PETTY'S AIR CONDITIONING ("AC") TECHNICIAN GILBERT MARQUEZ IN HIS DIRECT TESTIMONY?
23	А.	Yes.
24 25 26	Q.	DO EXCESSIVE VOLTAGE HARMONICS CAUSE THE DAMAGE TO ELECTRIC EQUIPMENT DESCRIBED IN DIRECT TESTIMONY OF KYLE HALEY?
27	А.	Yes.
1		

DIRECT TESTIMONY OF ROBERT D. GRUBB, P.E.

1Q.IS IT REASONABLE TO CONCLUDE THAT EXCESSIVE VOLTAGE2HARMONICS ON RGEC'S DISTRIBUTION LINE CAUSED THE PROPERTY3DAMAGE DESCRIBED BY PETTY WITNESS KYLE HALEY?

4 A. Yes.

5 Q. WHAT IS THE BASIS OF THAT CONCLUSION?

A. As stated above, excessive harmonics are known to cause electrical equipment damage and
the type of damage experienced by Petty. Further, while the Petty residences and hunting
lodge were connected to the grid, the Brundage line exhibited excessive harmonics. When
the Petty residences and hunting lodge were disconnected from the grid and served by
generator power, the Petty electrical equipment functioned as designed. GEI also observed
that the electrical facilities at the ranch were properly designed. Accordingly, the dirty
power from the Cooperative's line caused the property damage.

Q. ARE THERE ANY FACILITIES A CUSTOMER CAN INSTALL TO PROTECT ELECTRICAL EQUIPMENT AT A RESIDENCE IF THE CUSTOMER IS SERVED BY A DISTRIBUTION LINE THAT IS EXHIBITING EXCESSIVE HARMONICS?

16 Α. There is effectively nothing a residential customer can reasonably do to protect its facilities 17 or equipment on its site against excessive voltage harmonics. Customers are at the mercy 18 of their utilities to monitor and police the power quality on their systems because they have 19 no authority over other customers who contribute to excessive harmonics on a utility 20 system. All a customer like Petty can do is hope that RGEC will monitor quality on its 21 system and timely require industrial and commercial customers that create excessive 22 harmonics to install equipment to mitigate negative harmonic impacts or follow the 23 appropriate steps to disconnect the customer.

1Q.DID PETTY ASK GEI TO INVESTIGATE EQUIPMENT IT COULD INSTALL TO2PROTECT ITS RESIDENCES FROM DIRTY POWER?

3 Α. Yes. Petty asked GEI to investigate whether there were any facilities or equipment Petty 4 could install to protect its residences and lodge against the dirty power. GEI could not find 5 any alternative on the market for a small customer like Petty with single phase service. 6 Petty then solicited the opinion of another engineering firm, which reached the same 7 conclusion. The direct testimony of Justin Lankutis describes the investigation and analysis 8 Mr. Lankutis conducted on this matter. 9 О. ARE YOU AWARE OF ANY PROVISION IN RGEC'S TARIFF THAT PLACES AN 10 **AFFIRMATIVE DUTY ON PETTY TO HAVE FACILITIES OR EOUIPMENT ON** 11 SITE TO PROTECT AGAINST EXCESSIVE HARMONICS? 12 Α. No. RGEC's tariff only addresses equipment that a customer may be required to install if 13 the customer is the source of harmonics that are adversely affecting other customers. 14 Section 323.3(D) of the RGEC tariff states: 15 D. Equipment Necessary to Limit Adverse Effects. 16 Cooperative may require Consumer to provide, at Consumer's expense, suitable apparatus to limit the effect of voltage fluctuations 17 18 caused by electric equipment in Consumer's installation where 19 Consumer is found to be operating electrical equipment which 20 produces voltage fluctuations, interference, harmonics or distorted 21 wave forms which adversely affect electric service provided by 22 Cooperative to other Consumers. 23 Consumers utilizing nonlinear loads, such as, but not limited to, adjustable speed drives and uninterruptible power supplies, must 24 25 employ devices that limit the harmonic voltage and current distortion limits to those set out in IEEE Std 519 5.1 and 5.2. 26 27 In lieu of requesting Consumer to install such suitable or special equipment limiting such adverse effect, Cooperative may, at its 28 29 option, install at Consumer's cost, additional transformer capacity (which may or may not be dedicated solely to such Consumer) or 30 other equipment specially designed to reasonably limit such adverse 31 32 effect.

DIRECT TESTIMONY OF ROBERT D. GRUBB, P.E.

1Q.WHAT FACILITIES CAN A CUSTOMER THAT IS CAUSING EXCESSIVE2VOLTAGE HARMONICS INSTALL TO MITIGATE THE HARMONICS FROM3VFDS?

A. Mitigation of harmonics caused by the customer can be achieved by using filters which
limit harmonic voltage caused by the harmonic current flow. Another approach might be
to install phase-shifting transformers in various locations within the offending customer's
electrical system.

8 V. RGEC'S THIRD PARTY REPORTS NOTIFIED THE COOPERATIVE OF 9 EXCESSIVE HARMONICS ON THE BRUNDAGE LINE

10Q.WAS RGEC AWARE THAT VFDS WERE CAUSING EXCESSIVE HARMONICS11ON THE BRUNDAGE LINE?

12 A. Yes. During his deposition, RGEC engineer Larry Powell testified that he was not aware

13 of harmonics on the Brundage line prior to 2010.⁸ Mr. Powell testified that in 2010

an oil and gas operator, paid the Cooperative to upgrade the capacity

15 of the Brundage line to serve its operations.⁹ After the expansion, harmonics problems

arose on the Brundage line. Discovery in this case indicates that RGEC was first notified

17 of excessive harmonics on the Brundage line in 2014.

14

18Q.HOW WAS RGEC INFORMED OF EXCESSIVE HARMONICS ON THE19BRUNDAGE LINE IN 2014?

A. In 2014, RGEC commissioned a report by Eaton Electrical Services & Systems ("Eaton")

21 in response to a power quality complaint from a second second

22 entitled "Power Quality Measurements for Rio Grande Electric Cooperative, Inc.," was

dated October 2014 ("Eaton Report"). It is attached to my testimony as Exhibit RG-7. The

⁸ Deposition Tr. of L. Powell at 52-53 (Jan. 29, 2020).

⁹ Deposition Tr. of L. Powell at 53-54 (Jan. 29, 2020).

¹⁰ Deposition Tr. G. Delfin at 36 (Jan. 29, 2020).



Eaton Report examined several power quality problems on the Brundage line, including harmonics.

¹¹ Deposition Tr. of G. Delfin at 40-41 (Jan. 29, 2020).

1

1 meter.¹² Mr. Powell also testified that RGEC did not require members that utilized VFDs 2 to install filters when they energized their sites. Nor did the Cooperative monitor power 3 quality when large loads with large motor loads were energized.¹³ Accordingly, after RGEC 4 closed out **complaint** complaint, the Cooperative did not inquire into whether the 5 company (which had paid RGEC in 2010 for the capacity expansion of the Brundage 6 distribution line) or other oil and gas loads were causing harmonics that would negatively 7 impact power quality of other customers taking service on the line.

8 Q. DID OTHER OUTSIDE ENGINEERING FIRMS WARN RGEC ABOUT ANY 9 HARMONICS ON THE BRUNDAGE LINE?

2015. 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25

10 A. Yes. RGEC was warned of harmonics on the line by another engineering consultant in

DIRECT TESTIMONY OF ROBERT D. GRUBB, P.E.

 ¹² Deposition Tr. of G. Delfin at 74-75, 94-95 (Jan, 29, 2020); Deposition Tr. of L. Powell at 34-36 (Jan. 29, 2020).
 ¹³ Deposition Tr. of L. Powell at 42 (Jan. 29, 2020).

1		
2		
3	Q.	WHAT OTHER RECOMMENDATIONS DID TXUE MAKE?
4	А.	
5		
6		
7	Q.	DID RGEC IMPLEMENT A MOTOR START EVALUATION REQUIREMENT?
8	А.	No. Both Mr. Delfin and Mr. Powell, RGEC's engineers, testified that RGEC did not test
9		customer compliance with their new motor starting requirements upon energization. ¹⁴ Nor
10		did RGEC begin collecting or tracking usage of VFDs or filters on the customer side of the
11		meter until after Petty filed its complaint with the Cooperative.
12 13	Q.	DO ANY OTHER FACTS INDICATE THAT RGEC WAS AWARE OF THE EXISTENCE OF EXCESSIVE HARMONICS ON THE BRUNDAGE LINE?
14	А.	Yes. Mr. Powell testified in his deposition that RGEC became aware of additional power
15		quality problems on the Brundage line in the spring of 2018. RGEC subsequently sent a
16		letter on July 27, 2018 to customers on the Brundage line stating:
17 18 19 20 21 22 23 24 25		[The Brundage line] is currently exhibiting very poor power quality such that electric service of several customers connected to this line are being affected. The root cause of this problem has been identified as being due to a condition called "harmonic distortion." The presence of this condition is now preventing other customers from receiving acceptable power quality from the electric grid. At RGEC, we strive to provide all of our customers with very reliable and "clean" power. Unfortunately, we are unable to achieve this for all of our customers connected to this Brundage distribution line.
26 27 28 29		Harmonic distortion is injected into the power system directly from certain customer's equipment. The most significant contribution to this phenomenon are variable speed electronic motor controls (VFDs), which are used to start large industrial type motors.

¹⁴ Deposition Tr. of G. Delfin at 74-75, 82 (Jan. 29, 2020).





¹⁵ Deposition Tr. of L. Powell at 46-50 (Jan. 28, 2020). *See also* Exhibit RG-10. **DIRECT TESTIMONY OF ROBERT D. GRUBB, P.E.**

1 2		
3		16
4		In short, RGEC was notified of the harmonics problems in 2014, but it did not do anything
5		to mitigate the problem until after Petty filed a complaint in February 2019.
6 7	VI.	GEI POWER QUALITY MONITORING RESULTS SHOWING EXCESSIVE HARMONICS ON THE RGEC SIDE OF THE METER
8 9 10	Q.	WHY DID GEI CONCLUDE THAT EXCESSIVE VOLTAGE HARMONICS FROM THE RGEC SIDE OF THE METER CAUSED THE ELECTRICAL PROBLEMS AT THE PETTY RANCH?
11	А.	GEI's conclusion was based on its own investigation and power quality metering, the
12		reports conducted by RGEC's outside engineering consultants, and RGEC's own data. For
13		example, RGEC's March 6, 2019 reading showed
14		¹⁷ RGEC and GEI's monitoring also showed voltage THD
15		above the IEEE Standard 519 limit of 5% after Petty was disconnected from the grid.
16 17	Q.	HOW DID GEI INDEPENDENTLY MONITOR POWER QUALITY AT THE PETTY RANCH?
18	А.	GEI installed a Fluke 1750 Power Quality Meter on the existing electrical service, on the
19		line-side terminals of the automatic transfer switch (i.e., the first customer-owned device
20		just below the RGEC meter). The Fluke meter was installed on April 29, 2019. A second
21		Fluke 1750 Power Quality Meter was also installed on the new electrical service that was
22		connected to the generator, on the line side terminals of the main breaker. That meter was
23		also installed on April 29, 2019. The meters were installed at the 240V locations stated

¹⁶ Deposition Tr. of L. Powell at 40 (Jan. 29, 2020).

¹⁷ See Direct Testimony of Kyle Haley (Exhibit KH-17, RGEC Updated Brundage Harmonics Location Summary (12-30-19)).

1		above and used the utility transformer as an instrument voltage and current transformer to
2		monitor the primary medium voltage parameters where applicable.
3 4	Q.	DO GEI'S METERING METHODS COMPORT WITH STANDARD ENGINEERING PRACTICES?
5	А.	Yes.
6 7	Q.	DESCRIBE THE RESULTS OF THE POWER QUALITY MONITORING THAT GEI CONDUCTED.
8	А.	Power quality data received from the monitor installed on the existing electrical service
9		indicated high voltage harmonic content above the IEEE Standard 519 limits. GEI recorded
10		data from April 29, 2019 to March 27, 2020. A summary showing the voltage harmonic
11		levels is attached as Exhibit RG-11. Power quality data received from the monitor installed
12		on the new electrical service did not indicate high voltage harmonic content.
13	Q.	WERE GEI'S RESULTS IMPACTED BY PETTY'S LOAD?
14	А.	No. Petty had been disconnected from the grid since March 18, 2019. Since that time, its
15		load ran off a generator. Accordingly, the voltage harmonics recorded at the PCC were
16		unaffected by Petty's load.
17 18	Q.	RGEC WITHDREW GENERATOR SERVICE FROM PETTY ON APRIL 18, 2019. WAS IT SAFE FOR PETTY TO RECONNECT TO THE GRID AT THAT TIME?
19	А.	No. RGEC's own records showed that voltage THD around that time was above . For
20		the period April 29, 2019 through May 8, 2019, GEI's monitoring data showed max voltage
21		THD of 12.9%. GEI's monitoring also showed sustained excessive harmonic levels at the
22		PCC above the IEEE Standard 519 THD limit of 5% throughout most of 2019.
23 24	Q.	WHEN DID GEI FINALLY NOTICE IMPROVEMENT IN THE POWER QUALITY AT THE PETTY PCC?
25	А.	GEI observed in late October 2019 the THD at the PCC finally improved.

DIRECT TESTIMONY OF ROBERT D. GRUBB, P.E.

1Q.WHAT DID YOU LEARN WAS SIGNIFICANT ABOUT THE OCTOBER 20192TIME PERIOD?

- 3 A. GEI learned during the deposition of RGEC witnesses that took place January 28 through
- 4 31, 2020 that the Cooperative temporarily in late
- 5 October 2019. Thereafter, GEI monitored levels as high as 6.4% voltage THD, but
- 6 nevertheless closer to the 5% voltage THD prescribed by IEEE Standard 519.

7 VII. PETTY'S LOAD DID NOT CAUSE OR CONTRIBUTE TO THE EXCESSIVE 8 HARMONICS

- 9 Q. DO YOU HAVE ANY REASON TO BELIEVE THAT CURRENT HARMONICS
 10 FROM THE PETTY SIDE OF THE METER CAUSED ITS ELECTRICAL
 11 EQUIPMENT TO FAIL WHEN THE RANCH WAS CONNECTED TO THE GRID?
- 12 A. No. After the Petty Ranch was removed from the RGEC service, it was placed on generator
- 13 power. During the ensuing months of operation there were no additional failures and the
- 14 equipment performed as designed and installed.

Q. DO YOU HAVE ANY REASON TO BELIEVE THAT ANY OTHER ELECTRICAL PROBLEMS ON THE PETTY SIDE OF THE METER CAUSED PETTY'S ELECTRICAL EQUIPMENT TO FAIL WHEN THE PETTY RANCH WAS CONNECTED TO THE GRID?

- 19 A. No, using the same reasoning as above. The Petty Ranch's loads and equipment performed
- 20 as expected when connected to generator, so there is no reason to believe that any other
- 21 electrical problem on the Petty side of the meter caused its electrical equipment to fail.

1Q.DID YOU MEET WITH RGEC TO DISCUSS THE POWER QUALITY2PROBLEMS AT THE PETTY RANCH?

3 Α. Yes. Petty and GEI met with RGEC on April 4, 2019 at RGEC's Brackettville headquarters. 4 At that meeting, RGEC made the claim that the Petty Ranch was out of compliance with 5 IEEE Standard 519 based on the amount of current THD levels the Cooperative said it 6 observed during a previous monitoring period. RGEC claimed it was Petty's responsibility 7 to "clean up" its load to reduce the THD. RGEC claimed that Petty THD was a contributor 8 to the harmonics seen on the Brundage line. However, RGEC did not acknowledge that 9 there had already was significant voltage harmonic content on the Brundage line prior to 10 the connection of the residences. Nor did RGEC offer information on its efforts to make it 11 safe for Petty to reconnect by offering a timetable on the reduction of harmonics on the 12 Brundage line.

13

Q. WAS RGEC'S CONCLUSION REASONABLE?

No. Per GEI's report attached as Exhibit RG-3, the current harmonic content measured by 14 Α. 15 RGEC was not outside the limits as determined by IEEE Standard 519. Discovery in this 16 case reveals that RGEC's employees reached this flawed conclusion by taking an isolated 17 snapshot of Petty's current THD percentage measured at 14.8/14.4 on March 6, 2019 at 2:35 p.m. based on current measured at 11.2/11.1 amps.¹⁸ At that time, the only load on the 18 19 Petty side was small construction load such as drills and saws, AC units and other 20 equipment being tested, and a battery charger for the Petty stand-by generator battery. However, IEEE Standard 519 states that current distortion limits should be established at 21 the PCC and should be taken using average maximum demand current over a 12-month 22

¹⁸ See Exhibit RG-12, RGEC Response to Petty 5-3 (reporting data collection for the 3/6/2019 snapshot from 3/6/2019 starting at 2:28 pm and ending at 3/8/2019 at 10:22 am). See also Direct Testimony of Kyle Haley (Exhibit KH-17, RGEC Updated Brundage Harmonics Location Summary (12-30-19)).

1		period. RGEC did not use average maximum demand or even an estimate of average
2		maximum demand, but instead cherry-picked an isolated reading, which did not yield a
3		reasonable conclusion or comply with IEEE Standard 519. The Cooperative's conclusion
4		was, therefore, not reasonable.
5		VIII. CONCLUSION
6 7 8	Q.	BASED ON YOUR EXPERIENCE IN THE UTILITY INDUSTRY, RGEC'S OWN THIRD-PARTY REPORTS, AND GEI'S MONITORING, WAS THE POWER DELIVERED TO THE PETTY PCC BY RGEC SAFE AND RELIABLE?
9	А.	No. The overheating of wiring and equipment is dangerous and a definite safety issue; in
10		particular, it is a fire hazard. Reliability is greatly affected by causing equipment failures
11		and by causing electronically controlled features to function improperly. Excessive
12		harmonics are known in the industry to cause problems and that is the reason that IEEE
13		Standard 519 was developed.
14 15 16	Q.	BASED ON YOUR EXPERIENCE IN THE UTILITY INDUSTRY, RGEC'S OWN THIRD-PARTY REPORTS, AND GEI'S MONITORING, WAS THE POWER DELIVERED TO THE PETTY PCC IMPAIRED BY EXCESSIVE HARMONICS?
17	A.	Yes. All of the reports commissioned by RGEC with Schneider, Eaton and TXUE pointed
18		out that the RGEC distribution line had excessive harmonic content attributable to the
19		larger industrial customers connected to the line. The GEI monitoring for a much longer
20		period of time affirmed those previous findings.
21 22 23 24	Q.	WAS IT SAFE FOR PETTY TO RECONNECT TO THE GRID AFTER RGEC PULLED GENERATOR SERVICE AND WHILE THE PCC WITH RGEC CONTINUED TO EXHIBIT POWER QUALITY IMPAIRED BY EXCESSIVE HARMONICS?
25	А.	No. RGEC system's excessive harmonics caused equipment failures at the Petty Ranch
26		previously. Those failures ceased to occur when Petty was removed from the RGEC system

1 and placed on generator. It is logical that, since the harmonics on the RGEC system 2 remained high, reconnection would result in a resumption of equipment failures. 3 IS IT SAFE FOR PETTY TO RECONNECT TO THE GRID AFTER THE 0. CUSTOMER 4 CAUSED THE THAT PROBLEM WAS TEMPORARILY 5 **DISCONNECTED?** 6 A. It depends on whether RGEC will meet its obligations to provide safe and reliable electric 7 service to Petty upon reconnection. I understand that intends to reconnect to RGEC upon the purchase of certain filtering equipment.¹⁹ I also understand that 8 has 9 previously installed filtering equipment that did not work and that RGEC nevertheless 10 allowed the member to stay online for 14 months after Schneider Engineering issued a 11 report to the Cooperative identifying the operator as one of the leading culprits of the 12 excessive harmonics. Accordingly, there is certainly risk that the high harmonic content 13 will return. WHAT DO YOU RECOMMEND RGEC DO TO PROVIDE PETTY SAFE AND 14 Q. 15 **RELIABLE POWER?** 16 Α. RGEC should timely identify and work with commercial and industrial customers who 17 create system harmonic problems on the Cooperative's distribution line. If the customer 18 cannot timely resolve the problem, the Cooperative should either disconnect the customer 19 or pay to install the necessary facilities to correct the problem and charge the customer. 20 Once the problems are resolved to a point where the RGEC system is constantly in 21 compliance with IEEE 519, RGEC also needs to implement a plan to monitor and police 22 customer impacts on the their system. **DOES THIS CONCLUDE YOUR TESTIMONY?** 23 Q. 24 Yes.

¹⁹ Deposition Tr. of A. Conrad at 51 (Jan. 30, 2020). DIRECT TESTIMONY OF ROBERT D. GRUBB, P.E.

VERIFICATION

Robert D. Grubb, swearing under penalty of perjury, states:

I am the witness identified in the preceding testimony. I have read the testimony and am familiar with the contents. Based upon my personal knowledge, I affirm that the facts stated in the testimony are true and correct to the best of my knowledge. In addition, in my judgment and based upon my professional experience, the opinions and conclusions stated in the testimony are true, valid, and accurate.

Robert D. Grubb Date: <u>4/2/2020</u>

EXHIBIT RG-1

Exhibit RG-1 List of Prior Appearances

Docket No. 3:01cv54, SMS Demag vs. North American Stainless, U.S. District Court, Eastern District of Kentucky, Arbitration Board in Fall 2003

Wendlands Feed vs. Miller's Mutual, Waco, Texas 2000

Sanchez vs. City of San Antonio, Sub-contractor to Independent Test Firm Raba-Kistner directed by Judge Pat Boone, San Antonio, Texas 2001

EXHIBIT RG-2
Robert Grubb, P.E.

Principal Engineer





Education: B.S., Electrical Engineering / University of Texas at Austin / 1970 Registration: Professional Engineer / Texas #38772 / 1975 Title: Principal Engineer Location: San Antonio, Texas Experience: He has more than 48 years of experience in the planning, design, coordination and management of a wide range of water and wastewater plants, electric power substation, electric transmission, and electric distribution projects. Robert Grubb's background experience includes 11 years of electric substation design, transmission planning, distribution planning and relay testing and maintenance for the City Public Service Board (now CPS Energy) of San Antonio. Prior to his resignation, Mr. Grubb served as Chief System Protection Engineer. Robert Grubb formed Grubb Engineering, Inc. in 1981. Grubb Engineering has had a role in the design of many different projects ranging from water/wastewater facilities to electric transmission systems and substations. Robert Grubb is the author of two papers presented at the Annual International Conference for Protective Relay Engineers at Texas A&M University, as well as a paper presented at Cebu City, Philippines to the IIEE.

REPRESENTATIVE PROJECTS:

- Alliance Water Owner's Representative / Alliance Water / Central Texas / 2018 Present: Serves as electrical system advisor to Alliance. Duties include negotiation/planning with electrical utilities.
- **Power Quality Monitoring/Harlingen Water Works/Harlingen, Texas/2019** Served as engineering manager for analysis of power quality monitoring at two water plants and one wastewater treatment plant. Helped troubleshoot reasons for equipment damage involving motors and electronic controls.
- Vista Ridge Technical Advisor / SAWS / San Antonio, Texas / 2016 Present: Serves as electrical system advisor to SAWS for the supply side of the Vista Ridge Project. Duties include negotiation/planning with electrical utilities and design submittal review.
- DSP Water Production Facility Upgrades / SAWS / Bexar County, Texas/ 2013-2015: Project Manager for the new electrical distribution and SCADA system design for four (4) existing DSP Pump Stations. Stations include well pump(s), pump control valves and chlorine system.
- (DSP) Somerset Facility High Service Pump Upgrades/ SAWS / Somerset, Texas/ 2012–2016: Served as Project Manager for the electrical, control, and instrumentation design for this upgrades project which involves the replacement of the entire electrical distribution and SCADA system to serve the new pump station and control valves.
- Mission Pump Station Improvements / SAWS / San Antonio, Texas / 2008-2014:
 Served as Principal Project Manager for the upgrades which included new electrical motor control center, piping,
 chlorine scrubber, well rehabilitation and a new site plat. GEI was the prime consultant.
- Lift Stations SCADA Project / SAWS / San Antonio, Texas / 2008-2010: Served as Principal Project Manager for the SCADA system upgrades of 14 lift stations. GEI was the prime consultant.



EXHIBIT RG-4

PUBLIC UTILITY COMMISSION OF TEXAS

PUC NO. 49795

REQUEST NUMBER ONE: QUESTION NO. PETTY 1-25

COMPANY NAME: Rio Grande Electric Cooperative, Inc.

INFORMATION REQUESTED:

Petty 1-25: Please identify the class characteristics of the customers served by the Brundage Line for the years 2015 to the present. In your answer, please identify by year the percentage of load that is residential, commercial, industrial, seasonal or other customer classification.

REQUESTED BY: Petty Group, LLP

RESPONSE:

Will supplement.

SUPPLEMENTAL RESPONSE:

See attachment 1-25.

SPONSOR:

Roger Andrade

Attachment 1-25

LEGAL\43394864\1

	Residential	Seasonal	Irrigation	Commercial	Industrial	Total
2015	9.6%	2.0%	10.2%	6.3%	71.8%	100.0%
2016	8.9%	1.9%	8.9%	5.8%	74.5%	100.0%
2017	8.4%	1.9%	12.4%	5.4%	71.8%	100.0%
2018	6.7%	1.6%	9.7%	4.5%	77.5%	100.0%
2019	6.3%	1.5%	9.8%	4.2%	78.3%	100.0%

EXHIBIT RG-5



IEEE Recommended Practice and Requirements for Harmonic Control in Electric Power Systems

IEEE Power and Energy Society

Sponsored by the Transmission and Distribution Committee

IEEE 3 Park Avenue New York, NY 10016-5997 USA

IEEE Std 519™-2014 (Revision of IEEE Std 519-1992)

IEEE Recommended Practice and Requirements for Harmonic Control in Electric Power Systems

Sponsor

Transmission and Distribution Committee of the IEEE Power and Energy Society

Approved 27 March 2014

IEEE-SA Standards Board

Abstract: Goals for the design of electrical systems that include both linear and nonlinear loads are established in this recommended practice. The voltage and current waveforms that may exist throughout the system are described, and waveform distortion goals for the system designer are established. The interface between sources and loads is described as the point of common coupling and observance of the design goals will reduce interference between electrical equipment.

This recommended practice addresses steady-state limitations. Transient conditions exceeding these limitations may be encountered. This document sets the quality of power that is to be provided at the point of common coupling. This document does not cover the effects of radio-frequency interference; however, guidance is offered for wired telephone systems.

Keywords: harmonics, IEEE 519[™], power quality

Copyright © 2014 by The Institute of Electrical and Electronics Engineers, Inc All rights reserved. Published 11 June 2014. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by The Institute of Electrical and Electronics Engineers, Incorporated.

PDF: ISBN 978-0-7381-9005-1 STD98587 Print: ISBN 978-0-7381-9006-8 STDPD98587

IEEE prohibits discrimination, harassment, and bullying. For more information, visit <u>http://www.ieee.org/web/aboutus/whatis/policies/p9-26.html</u>. No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

The Institute of Electrical and Electronics Engineers, Inc. 3 Park Avenue, New York, NY 10016-5997, USA

Important Notices and Disclaimers Concerning IEEE Standards Documents

IEEE documents are made available for use subject to important notices and legal disclaimers. These notices and disclaimers, or a reference to this page, appear in all standards and may be found under the heading "Important Notice" or "Important Notices and Disclaimers Concerning IEEE Standards Documents."

Notice and Disclaimer of Liability Concerning the Use of IEEE Standards Documents

IEEE Standards documents (standards, recommended practices, and guides), both full-use and trial-use, are developed within IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association ("IEEE-SA") Standards Board. IEEE ("the Institute") develops its standards through a consensus development process, approved by the American National Standards Institute ("ANSI"), which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and participate without compensation from IEEE. While IEEE administers the process and establishes rules to promote fairness in the consensus development process, IEEE does not independently evaluate, test, or verify the accuracy of any of the information or the soundness of any judgments contained in its standards.

IEEE does not warrant or represent the accuracy or content of the material contained in its standards, and expressly disclaims all warranties (express, implied and statutory) not included in this or any other document relating to the standard, including, but not limited to, the warranties of: merchantability; fitness for a particular purpose; non-infringement; and quality, accuracy, effectiveness, currency, or completeness of material. In addition, IEEE disclaims any and all conditions relating to: results; and workmanlike effort. IEEE standards documents are supplied "AS IS" and "WITH ALL FAULTS."

Use of an IEEE standard is wholly voluntary. The existence of an IEEE standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard.

In publishing and making its standards available, IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity nor is IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing any IEEE Standards document, should rely upon his or her own independent judgment in the exercise of reasonable carc in any given circumstances or, as appropriate, seek the advice of a competent professional in determining the appropriateness of a given IEEE standard.

IN NO EVENT SHALL IEEE BE LIABLE FOR ANY DIRECT, INDIRECT, INCIDENTAL, SPECIAL, EXEMPLARY, OR CONSEQUENTIAL DAMAGES (INCLUDING, BUT NOT LIMITED TO: PROCUREMENT OF SUBSTITUTE GOODS OR SERVICES; LOSS OF USE, DATA, OR PROFITS; OR BUSINESS INTERRUPTION) HOWEVER CAUSED AND ON ANY THEORY OF LIABILITY. WHETHER IN CONTRACT, STRICT LIABILITY, OR TORT (INCLUDING NEGLIGENCE OR OTHERWISE) ARISING IN ANY WAY OUT OF THE PUBLICATION, USE OF, OR RELIANCE UPON ANY STANDARD, EVEN IF ADVISED OF THE POSSIBILITY OF SUCH DAMAGE AND REGARDLESS OF WHETHER SUCH DAMAGE WAS FORESEEABLE.

Translations

The IEEE consensus development process involves the review of documents in English only. In the event that an IEEE standard is translated, only the English version published by IEEE should be considered the approved IEEE standard.

Official statements

A statement, written or oral, that is not processed in accordance with the IEEE-SA Standards Board Operations Manual shall not be considered or inferred to be the official position of IEEE or any of its committees and shall not be considered to be, or be relied upon as, a formal position of IEEE. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position of IEEE.

Comments on standards

Comments for revision of IEEE Standards documents are welcome from any interested party, regardless of membership affiliation with IEEE. However, IEEE does not provide consulting information or advice pertaining to IEEE Standards documents. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Since IEEE standards represent a consensus of concerned interests, it is important that any responses to comments and questions also receive the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to comments or questions except in those cases where the matter has previously been addressed. For the same reason, IEEE does not respond to interpretation requests. Any person who would like to participate in revisions to an IEEE standard is welcome to join the relevant IEEE working group.

Comments on standards should be submitted to the following address:

Secretary, IEEE-SA Standards Board 445 Hoes Lane Piscataway, NJ 08854 USA

Laws and regulations

Users of IEEE Standards documents should consult all applicable laws and regulations. Compliance with the provisions of any IEEE Standards document does not imply compliance to any applicable regulatory requirements. Implementers of the standard are responsible for observing or referring to the applicable regulatory regulatory requirements. IEEE does not, by the publication of its standards, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

Copyrights

IEEE draft and approved standards are copyrighted by IEEE under U.S. and international copyright laws. They are made available by IEEE and are adopted for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of engineering practices and methods. By making these documents available for use and adoption by public authorities and private users, IEEE does not waive any rights in copyright to the documents.

Photocopies

Subject to payment of the appropriate fee. IEEE will grant users a limited, non-exclusive license to photocopy portions of any individual standard for company or organizational internal use or individual, non-commercial use only. To arrange for payment of licensing fees, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA: +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

Updating of IEEE Standards documents

Users of IEEE Standards documents should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of amendments, corrigenda, or errata. An official IEEE document at any point in time consists of the current edition of the document together with any amendments, corrigenda, or errata then in effect.

Every IEEE standard is subjected to review at least every ten years. When a document is more than ten years old and has not undergone a revision process, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE standard.

In order to determine whether a given document is the current edition and whether it has been amended through the issuance of amendments, corrigenda, or errata, visit the IEEE-SA Website at http://ieeexplore.ieee.org/xpl/standards.jsp or contact IEEE at the address listed previously. For more information about the IEEE-SA or IEEE's standards development process, visit the IEEE-SA Website at http://standards.ieee.org/xpl/standards.jsp or contact IEEE at the address listed previously. For more information about the IEEE-SA or IEEE's standards development process, visit the IEEE-SA Website at http://standards.ieee.org.

Errata

Errata, if any, for all IEEE standards can be accessed on the IEEE-SA Website at the following URL: <u>http://standards.ieee.org/findstds/errata/index.html</u>. Users are encouraged to check this URL for errata periodically.

Patents

Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken by the IEEE with respect to the existence or validity of any patent rights in connection therewith. If a patent holder or patent applicant has filed a statement of assurance via an Accepted Letter of Assurance, then the statement is listed on the IEEE-SA Website at http://standards.ieee.org/about/sasb/patcom/patents.html. Letters of Assurance may indicate whether the Submitter is willing or unwilling to grant licenses under patent rights without compensation or under reasonable rates, with reasonable terms and conditions that are demonstrably free of any unfair discrimination to applicants desiring to obtain such licenses.

Essential Patent Claims may exist for which a Letter of Assurance has not been received. The IEEE is not responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity or scope of Patents Claims, or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this standard are expressly advised that determination of the validity of any patent rights, and the risk of infringement of such rights, is entirely their own responsibility. Further information may be obtained from the IEEE Standards Association.

Participants

At the time this IEEE recommended practice was completed, the Harmonics Working Group had the following membership:

Mark Halpin, Chair

Reuben Burch Jim Burke Randy Collins Doug Dorr Russell Ehrlich Thomas Gentile David Gilmer Daryl Hallmark Dennis Hansen Fred Hensley Randy Horton Bill Howe John Kennedy Albert Keri Roberto Langella Theo Laughner Mike Lowenstein Alex McEachern Mark McGranaghan Chris Melhorn William Moncrief Dave Mueller Marty Page Paulo Ribeiro Daniel Sabin Bob Saint Surva Santoso Ken Sedziol Harish Sharma Jeff Smith Nicholas Smith Mike Swearingen Steve Fatum Alfredo Testa Rao Thallam Timothy Unruh Dan Ward James Wikston Charlie Williams Wilson Xu Francise Zavoda

The following members of the individual balloting committee voted on this recommended practice. Balloters may have voted for approval, disapproval, or abstention.

William Ackerman Alı Al Awazı Roy Alexander Saleman Alibhav Thomas Barnes G. Bartok David Bassett Thomas Basso Steven Bezner Wallace Binder Michael Bio Thomas Bishop William Bloethe Frederick Brockhurst Andrew Brown Gustavo Brunello Jeffrey Burnworth William Bush William Byrd Brent Cain Paul Cardinal Antonio Cardoso Keith Chow Robert Christman Bryan Cole Larry Conrad Stephen Conrad Luis Coronado Glenn Davis Andrew Dettloff Carlo Donati Gary Donner Neal Dowling

Robert Durham Russell Ehrlich Gearold O. H. Eidhin Ahmed ElSerafi C. Erven Dan Evans Jorge Fernandez Daher William Finley Carl Fredericks Fredric Friend Doaa Galal David Garrett Thomas Gentile Kenneth Gettman David Gilmer Mietek Glinkowski Thomas Grebe Randall Groves Thomas Gruzs Erich Gunther Ajıt Gwal Daryl Hallmark Robert Hanna Dennis Hansen Edward Hare Gregory Hartzo James Harvey Jeffrey Helzer Werner Hoelzl Robert Hoerauf Randy Horton Ronald Hotchkiss John Houdek

Farris Jıbrıl Brian Johnson Gerald Johnson Lars Juhlin Laszlo Kadar Innocent Kamwa Haran Karmaker John Kay Gael Kennedy John Kennedy Yuri Khersonsky Chad Kiger James Kinney Stanley Klein Joseph L Koepfinger Edwin Kramer Jim Kulchisky Asok Kumar Senthil Kumar Saumen Kundu Chung-Yiu Lam Thomas La Rose Theo Laughner Wei-Jen Lee Steven Liggio Keym Little Albert Livshitz William Lockley Lawrenc Long Greg Luri Richard Marek John Mcalhanev, Jr William McBride

Kenneth McClenahan Peter Megna Dean Mehlberg John Merando T. David Mills Daleep Mohla William Moncrief Kimberly Mosley Jerry Murphy Ryan Musgrove Arun Narang Dennis Neitzel Arthur Neubauer Michael Newman David Nichols Joe Nuns Gary Nissen Tim Olsen Gary Olson Gregory Olson Lorraine Padden Richard Paes Marty Page Mirko Palazzo Donald Parker David Parman Bansı Patel S Patel

Shawn Patterson Wesley Patterson K. James Phillips Percy Pool Iulian Profir John Rama Moises Ramos Reynaldo Ramos John Roach Michael Roberts Charles Rogers Thomas Rozek D. Daniel Sabin Randall Safier Bob Saint Steven Sano Bartien Sayogo Colin Schauder Robert Schuerger Ken Sedziol Robert Seitz Nikun_J Shah Nigel Shore Gil Shultz Hyeong Sim David Singleton James Smith Jeremy Smith

Jerry Smith John Spare Gary Stoedter Raymond Strittmatter K. Stump Peter Sutherland Michael Swearingen Steve Tatum Richard Taylor Eric Udren Timothy Unruh John Vergis Carl Wall Daniel Ward Karl Weber Yingli Wen Kenneth White Matthew Wilkowski George Wood Wilson Xu Edward Yandek Thomas Yohn Larry Young Jian Yu Francisc Zavoda James Ziebarth Donald Zipse Ahmed Zobaa

When the IEEE-SA Standards Board approved this recommended practice on 27 March 2014, it had the following membership:

John Kulick, Chair Jon Walter Rosdahl, Vice Chair Richard H. Hulett, Past Chair Konstantinos Karachalios, Secretary

Peter Balma Farooq Barı Ted Burse Clınt Chaplaın Stephen Dukes Jean-Phillippe Faure Gary Hoffman Michael Janezic Jeffrey Katz Joseph L. Koepfinger* David J. Law Hung Ling Oleg Logvinov Ted Olsen Glenn Parsons Ron Peterson Adrian Stephens Peter Sutherland Yatın Trıvedi Phil Winston Don Wrıght Yu Yuan

*Member Emeritus

Also included are the following nonvoting IEEE-SA Standards Board liaisons:

Richard DeBlasio, DOE Representative Michael Janezic, NIST Representative

Catherine Berger Senior Program Manager, IEEE-SA Content Publishing

Erin Spiewak Program Manager, IEEE-SA Technical Community

vii Copyright © 2014 IEEE. All rights reserved

Introduction

This introduction is not part of IEEE Std 519-2014, IEEE Recommended Practice and Requirements for Harmonic Control in Electric Power Systems.

The uses of nonlinear loads connected to electric power systems include static power converters, are discharge devices, saturated magnetic devices, and, to a lesser degree, rotating machines. Static power converters of electric power are the largest nonlinear loads and are used in industry for a variety of purposes, such as electrochemical power supplies, adjustable speed drives, and uninterruptible power supplies. These devices are useful because they can convert ac to dc, dc to dc, and ac to ac.

Nonlinear loads change the sinusoidal nature of the ac power current (and consequently the ac voltage drop), thereby resulting in the flow of harmonic currents in the ac power system that can cause interference with communication circuits and other types of equipment. These harmonic currents also lead to increased losses and heating in numerous electromagnetic devices (motors, transformers, etc.). When reactive power compensation, in the form of power factor improvement capacitors, is used, resonant conditions can occur that may result in high levels of harmonic voltage and current distortion when the resonant condition occurs at a harmonic associated with nonlinear loads.

Common sources of harmonic currents in power systems include power electronic converters, arc furnaces, static VAR systems, inverters for distributed generation, ac phase controllers, cycloconverters, and ac-dc converters (rectifiers) commonly used in switched mode power supplies and pulse width modulated (PWM) motor drives. Each of these harmonic-producing devices can have fairly consistent harmonic current emission characteristics over time or each may present a widely-varying characteristic depending on the control of the device, the characteristics of the system, and other variables. This recommended practice is to be used for guidance in the design of power systems with nonlinear loads. The limits set are for steady-state operation and are recommended for "worst case" conditions. Transient conditions exceeding these limits may be encountered. In any case, the limit values given in this document are recommendations and should not be considered binding in all cases. Because of the nature of the recommendations, some conservatism is present that may not be necessary in all cases.

This recommended practice should be applied at interface points between system owners or operators and users in the power system. The limits in this recommended practice are intended for application at a point of common coupling (PCC) between the system owner or operator and a user, where the PCC is usually taken as the point in the power system closest to the user where the system owner or operator could offer service to another user. Frequently for service to industrial users (i.e., manufacturing plants) via a dedicated service transformer, the PCC is at the HV side of the transformer. For commercial users (office parks, shopping malls, etc.) supplied through a common service transformer, the PCC is commonly at the LV side of the service transformer.

The limits in this recommended practice represent a shared responsibility for harmonic control between system owners or operators and users. Users produce harmonic currents that flow through the system owner's or operator's system, which lead to voltage harmonics in the voltages supplied to other users. The amount of harmonic voltage distortion supplied to other users is a function of the aggregate effects of the harmonic current producing loads of all users and the impedance characteristics of the supply system.

Harmonic voltage distortion limits are provided to reduce the potential negative effects on user and system equipment. Maintaining harmonic voltages below these levels necessitates that

- All users limit their harmonic current emissions to reasonable values determined in an equitable manner based on the inherent ownership stake each user has in the supply system and
- Each system owner or operator takes action to decrease voltage distortion levels by modifying the supply system impedance characteristics as necessary.

viii Copyright © 2014 IEEE. All rights reserved

In order to allow the system owner or operator to control the system impedance characteristics to reduce voltage distortion when necessary, users should not add passive equipment that affects the impedance characteristic in a way such that voltage distortions are increased. In effect, such actions by a user could amount to producing excessive voltage harmonic distortion. Such passive equipment additions (that lead to undesirable system impedance characteristics) should be controlled by the user in the same manner as current harmonic-producing devices operated by the user.



Contents

1. Overview	1
1.1 Scope	2
1.2 Purpose	2
2. Normative references	3
3. Definitions	3
4. Harmonic measurements	4
4.1 Measurement window width	4
4.2 Very short time harmonic measurements	5
4.3 Short time harmonic measurements	5
4.4 Statistical evaluation	5
5. Recommended harmonic limits	5
5.1 Recommended harmonic voltage limits	6
5.2 Recommended current distortion limits for systems nominally rated 120 V through 69 kV	6
5.3 Recommended current distortion limits for systems nominally rated above 69 kV through 161 kV.	7
5.4 Recommended current distortion limits for systems nominally rated above 161 kV	8
5.5 Recommendations for increasing harmonic current limits	9
Annex A (informative) Interharmonic voltage limits based on flicker 1	11
Annex B (informative) Telephone influence factor (TIF) 1	13
Annex C (informative) Limits on commutation notches 1	15
Annex D (informative) Bibliography 1	17

IEEE Recommended Practice and Requirements for Harmonic Control in Electric Power Systems

IMPORTANT NOTICE: IEEE Standards documents are not intended to ensure safety, security, health, or environmental protection, or ensure against interference with or from other devices or networks. Implementers of IEEE Standards documents are responsible for determining and complying with all appropriate safety, security, environmental, health, and interference protection practices and all applicable laws and regulations.

This IEEE document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading "Important Notice" or "Important Notices and Disclaimers Concerning IEEE Documents." They can also be obtained on request from IEEE or viewed at <u>http://standards.ieee.org/IPR/disclaimers.html</u>.

1. Overview

The uses of nonlinear loads connected to electric power systems include static power converters, arc discharge devices, saturated magnetic devices, and, to a lesser degree, rotating machines. Static power converters of electric power are the largest nonlinear loads and are used in industry for a variety of purposes, such as electrochemical power supplies, adjustable speed drives, and uninterruptible power supplies. These devices are useful because they can convert ac to dc, dc to ac, and ac to ac.

Nonlinear loads change the sinusoidal nature of the ac power current (and consequently the ac voltage drop), thereby resulting in the flow of harmonic currents in the ac power system that can cause interference with communication circuits and other types of equipment. These harmonic currents also lead to increased losses and heating in numerous electromagnetic devices (motors, transformers, etc.). When reactive power compensation, in the form of power factor improvement capacitors, is used, resonant conditions can occur that may result in high levels of harmonic voltage and current distortion when the resonant condition occurs at a harmonic associated with nonlinear loads.

Common sources of harmonic currents in power systems include power electronic converters, are furnaces, static VAR systems, inverters for distributed generation, ac phase controllers, cycloconverters, and ac-dc converters (rectifiers) commonly used in switched mode power supplies and pulse width modulated (PWM) motor drives. Each of these harmonic-producing devices can have fairly consistent harmonic current emission characteristics over time or each may present a widely-varying characteristic depending on the control of the device, the characteristics of the system, and other variables.

Copyright © 2014 IEEE. All rights reserved.

1.1 Scope

This recommended practice establishes goals for the design of electrical systems that include both linear and nonlinear loads. The voltage and current waveforms that may exist throughout the system are described, and waveform distortion goals for the system designer are established. The interface between sources and loads is described as the point of common coupling and observance of the design goals will minimize interference between electrical equipment.

This recommended practice addresses steady-state limitations. Transient conditions exceeding these limitations may be encountered. This document sets the quality of power that is to be provided at the point of common coupling. This document does not cover the effects of radio-frequency interference; however, guidance is offered for wired telephone systems.

1.2 Purpose

This recommended practice is to be used for guidance in the design of power systems with nonlinear loads. The limits set are for steady-state operation and are recommended for "worst case" conditions. Transient conditions exceeding these limits may be encountered. In any case, the limit values given in this document are recommendations and should not be considered binding in all cases. Because of the nature of the recommendations, some conservatism is present that may not be necessary in all cases.

This recommended practice should be applied at interface points between system owners or operators and users in the power system. The limits in this recommended practice are intended for application at a point of common coupling (PCC) between the system owner or operator and a user, where the PCC is usually taken as the point in the power system closest to the user where the system owner or operator could offer service to another user. Frequently for service to industrial users (i.e., manufacturing plants) via a dedicated service transformer, the PCC is at the HV side of the transformer. For commercial users (office parks, shopping malls, etc.) supplied through a common service transformer, the PCC is commonly at the LV side of the service transformer.

The limits in this recommended practice represent a shared responsibility for harmonic control between system owners or operators and users. Users produce harmonic currents that flow through the system owner's or operator's system which lead to voltage harmonics in the voltages supplied to other users. The amount of harmonic voltage distortion supplied to other users is a function of the aggregate effects of the harmonic current producing loads of all users and the impedance characteristics of the supply system.

Harmonic voltage distortion limits are provided to reduce the potential negative effects on user and system equipment. Maintaining harmonic voltages below these levels necessitates that

- All users limit their harmonic current emissions to reasonable values determined in an equitable manner based on the inherent ownership stake each user has in the supply system and
- Each system owner or operator takes action to decrease voltage distortion levels by modifying the supply system impedance characteristics as necessary.

In order to allow the system owner or operator to control the system impedance characteristics to reduce voltage distortion when necessary, users should not add passive equipment that affects the impedance characteristic in a way such that voltage distortions are increased. In effect, such actions by a user could amount to producing excessive voltage harmonic distortion. Such passive equipment additions (that lead to undesirable system impedance characteristics) should be controlled by the user in the same manner as current harmonic-producing devices operated by the user.

IEEE Std 519-2014 IEEE Recommended Practice and Requirements for Harmonic Control in Electric Power Systems

2. Normative references

The following referenced documents are indispensable for the application of this document (i.e., they must be understood and used, so each referenced document is cited in text and its relationship to this document is explained). For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments or corrigenda) applies.

IEC Standard 61000-4-7. General Guide on Harmonics and Interharmonics Measurement and Instrumentation, for Power Supply Systems and Equipment Connected Thereto.¹

IEC Standard 61000-4-30, Power Quality Measurement Methods.

IEC Standard 61000-4-15, Testing and Measurement Techniques—Flickermeter—Functional and Design Specifications.

IEEE Std 1453TM, IEEE Recommended Practice—Adoption of IEC 61000-4-15:2010, Electromagnetic compatibility (EMC)—Testing and Measurement Techniques—Flickermeter—Functional and Design Specifications.²

3. Definitions

For the purposes of this document, the following terms and definitions apply. The *IEEE Standards* Dictionary Online should be consulted for terms not defined in this clause.³

harmonic (component): A component of order greater than one of the Fourier series of a periodic quantity. For example, in a 60 Hz system, the harmonic order 3, also known as the "third harmonic," is 180 Hz.

interharmonic (component): A frequency component of a periodic quantity that is not an integer multiple of the frequency at which the supply system is operating (e.g., 50 Hz or 60 Hz).

I-T product: The inductive influence expressed in terms of the product of root-mean-square current magnitude (I), in amperes, times its telephone influence factor (TIF).

kV-T product: Inductive influence expressed in terms of the product of root-mean-square voltage magnitude (V), in kilovolts, times its telephone influence factor (TIF).

maximum demand load current: This current value is established at the point of common coupling and should be taken as the sum of the currents corresponding to the maximum demand during each of the twelve previous months divided by 12.

notch: A switching (or other) disturbance in the normal power voltage waveform, lasting less than 0.5 cycles, which is initially of opposite polarity than the waveform and is thus subtracted from the normal waveform in terms of the peak value of the disturbance voltage. This includes complete loss of voltage for up to 0.5 cycles.

¹ IEC publications are available from the Sales Department of the International Electrotechnical Commission. Case Postale 131, 3, rue de Varembé, CH-1211, Genève 20, Switzerland/Suisse (http://www.iec.ch/). IEC publications are also available in the United States from the Sales Department, American National Standards Institute, 25 West 43rd Street, 4th Floor, New York, NY 10036, USA (http://www.ansi org').

² IEEE publications are available from the Institute of Electrical and Electronics Engineers. Inc., 445 Hoes Lane, Piscataway, NJ 08854, USA (http://standards.ieee.org.).

³ IEEE Standards Dictionary Online subscription is available at:

http://www.ieee.org/portal innovate products/standard standards_dictionary.html.

IEEE Recommended Practice and Requirements for Harmonic Control in Electric Power Systems

notch depth: The average depth of the line voltage notch from the sine wave of voltage.

notch area: The area of the line voltage notch. It is the product of the notch depth, in volts, times the width of the notch measured in microseconds.

point of common coupling (PCC): Point on a public power supply system, electrically nearest to a particular load, at which other loads are, or could be, connected. The PCC is a point located upstream of the considered installation.

pulse number: The total number of successive nonsimultaneous commutations occurring within the converter circuit during each cycle when operating without phase control. It is also equal to the order of the principal harmonic in the direct voltage, that is, the number of pulses present in the dc output voltage in one cycle of the supply voltage.

short-circuit ratio: At a particular location, the ratio of the available short-circuit current, in amperes, to the load current, in amperes.

telephone influence factor (TIF): For a voltage or current wave in an electric supply circuit, the ratio of the square root of the sum of the squares of the weighted root-mean-square values of all the sine-wave components (including alternating current waves both fundamental and harmonic) to the root-mean-square value (unweighted) of the entire wave.

total demand distortion (TDD): The ratio of the root mean square of the harmonic content, considering harmonic components up to the 50th order and specifically excluding interharmonics, expressed as a percent of the maximum demand current. Harmonic components of order greater than 50 may be included when necessary.

total harmonic distortion (THD): The ratio of the root mean square of the harmonic content, considering harmonic components up to the 50th order and specifically excluding interharmonics, expressed as a percent of the fundamental. Harmonic components of order greater than 50 may be included when necessary.

4. Harmonic measurements

For the purposes of assessing harmonic levels for comparison with the recommended limits in this document, any instrument used should comply with the specifications of IEC 61000-4-7 and IEC 61000-4-30 The most relevant portions of the IEC specifications are summarized in 4.1 through 4.4.

4.1 Measurement window width

The width of the measurement window used by digital instruments employing Discrete Fourier Transform techniques should be 12 cycles (approximately 200 ms) for 60 Hz power systems (10 cycles for 50 Hz power systems). With this window width, spectral components will be available every 5 Hz (e.g., 0, 5, 10...50, 55, 60, 65, 70,... Hz). For the purposes of this document, a harmonic component magnitude is considered to be the value at a center frequency (60, 120, 180, etc. and 50, 100, 150, etc. Hz for 60 Hz and 50 Hz power systems, respectively) combined with the two adjacent 5 Hz bin values. The three values are combined into a single rms value that defines the harmonic magnitude for the particular center frequency component.

4.2 Very short time harmonic measurements

Very short time harmonic values are assessed over a 3-second interval based on an aggregation of 15 consecutive 12 (10) cycle windows for 60 (50) Hz power systems. Individual frequency components are aggregated based on an rms calculation as shown in Equation (1) where F represents voltage (V) or current (I), n represents the harmonic order, and i is a simple counter. The subscript vs is used to denote "very short." In all cases, F represents an rms value.

$$F_{n,vs} = 2 \sqrt{\frac{1}{15} \sum_{i=1}^{15} F_{n,i}^2}$$

(1)

4.3 Short time harmonic measurements

Short time harmonic values are assessed over a 10-minute interval based on an aggregation of 200 consecutive very short time values for a specific frequency component. The 200 values are aggregated based on an rms calculation as shown in Equation (2) where F represents voltage (V) or current (l), n represents the harmonic order, and i is a simple counter. The subscript sh is used to denote "short." In all cases, F represents an rms value.

$$F_{n,sh} = 2 \sqrt{\frac{1}{200} \sum_{i=1}^{200} F_{(n,vs),i}^2}$$

(2)

4.4 Statistical evaluation

Very short and short time harmonic values should be accumulated over periods of one day and one week, respectively. For very short time harmonic measurements, the 99th percentile value (i.e., the value that is exceeded for 1% of the measurement period) should be calculated for each 24-hour period for comparison with the recommend limits in Clause 5. For short time harmonic measurements, the 95th and 99th percentile values (i.e., those values that are exceeded for 5% and 1% of the measurement period) should be calculated for each 7-day period for comparison with the recommended limits in Clause 5. These statistics should be used for both voltage and current harmonics with the exception that the 99th percentile short time value is not recommended for use with voltage harmonics.

5. Recommended harmonic limits

Because managing harmonics in a power system is considered a joint responsibility involving both endusers and system owners or operators, harmonic limits are recommended for both voltages and currents. The recommended values in this clause are based on the fact that some level of voltage distortion is

IEEE Recommended Practice and Requirements for Harmonic Control in Electric Power Systems

generally acceptable and both system owners or operators and users must work cooperatively to keep actual voltage distortion below objectionable levels. The underlying assumption of these recommended limits is that by limiting harmonic current injections by users, voltage distortion can be kept below objectionable levels. In the event that limiting harmonic currents alone does not result in acceptable levels of voltage distortion, system owners or operators should take action to modify system characteristics so that voltage distortion levels are acceptable. The acceptable voltage distortion levels form the basis of the harmonic voltage limits in 5.1.

The recommended limits in this clause apply only at the point of common coupling and should not be applied to either individual pieces of equipment or at locations within a user's facility. In most cases, harmonic voltages and currents at these locations could be found to be significantly greater than the limits recommended at the PCC due to the lack of diversity, cancellation, and other phenomena that tend to reduce the combined effects of multiple harmonic sources to levels below their algebraic summation.

5.1 Recommended harmonic voltage limits

At the PCC, system owners or operators should limit line-to-neutral voltage harmonics as follows:

- -- Daily 99th percentile very short time (3 s) values should be less than 1.5 times the values given in Table 1.
- Weekly 95th percentile short time (10 min) values should be less than the values given in Table 1.

All values should be in percent of the rated power frequency voltage at the PCC. Table 1 applies to voltage harmonics whose frequencies are integer multiples of the power frequency.

Bus voltage V at PCC	Individual harmonic (%)	Total harmonic distortion THD (%)
$V \le 1.0 \text{ kV}$	5.0	8.0
$1 \text{ kV} < l' \leq 69 \text{ kV}$	3 0	5.0
$69 \text{ kV} < V \leq 161 \text{ kV}$	15	2.5
161 kV < V	1.0	1 5ª

Table 1---Voltage distortion limits

^dHigh-voltage systems can have up to 2 0% THD where the cause is an HVDC terminal whose effects will have attenuated at points in the network where future users may be connected

Information on voltage interharmonic limits is given in Annex A and is based on lamp flicker assessed using the measurement technique described in IEEE Std 1453 and IEC 61000-4-15. The information of Annex A is not based on the effects of interharmonics on other equipment and systems such as generator mechanical systems, motors, transformers, signaling and communication systems, and filters. Due consideration should be given to these effects and appropriate interharmonic current limits should be developed starting from the information in Annex A on a case-by-case basis using specific knowledge of the supply system, connected user loads, and provisions for future users.

5.2 Recommended current distortion limits for systems nominally rated 120 V through 69 kV

The limits in this subclause apply to users connected to systems where the rated voltage at the PCC is 120 V to 69 kV. At the PCC, users should limit their harmonic currents as follows:

IEEE Recommended Practice and Requirements for Harmonic Control in Electric Power Systems

- Daily 99th percentile very short time (3 s) harmonic currents should be less than 2.0 times the values given in Table 2.
- Weekly 99th percentile short time (10 min) harmonic currents should be less than 1.5 times the values given in Table 2.
- Weekly 95th percentile short time (10 min) harmonic currents should be less than the values given in Table 2.

All values should be in percent of the maximum demand current, $I_{\rm L}$. This current value is established at the PCC and should be taken as the sum of the currents corresponding to the maximum demand during each of the twelve previous months divided by 12. Table 2 applies to harmonic currents whose frequencies are integer multiples of the power frequency.

Maximum harmonic current distortion in percent of I _L										
	Individual harmonic order (odd harmonics) ^{a, b}									
$I_{SC}/I_{L} = 3 \le h < 11 1 \le h < 17 17 \le h < 23 23 \le h < 35 35 \le h \le 50 \text{TDD}$										
< 20°	40	2.0	15	0.6	0.3	50				
20 < 50	70	3.5	2.5	1.0	0.5	80				
50 < 100	10 0	4.5	4.0	1.5	0.7	12.0				
100 < 1000	12 0	5.5	5.0	20	10	15 0				
> 1000	150	7.0	60	2.5	14	20.0				

Table 2-Current distortion limits for systems rated 120 V through 69 kV

^aEven harmonics are limited to 25% of the odd harmonic limits above

^bCurrent distortions that result in a dc offset, e.g., half-wave converters, are not allowed.

°All power generation equipment is limited to these values of current distortion, regardless of actual $I_{\rm sc}/I_{\rm L}$

where

 $I_{\rm sc}$ = maximum short-circuit current at PCC

 $I_{\rm L}$ = maximum demand load current (fundamental frequency component)

at the PCC under normal load operating conditions

For interharmonic current components with frequencies that are not integer multiples of the power frequency, users should limit the components to sufficiently low levels so as to not produce undesirable effects on the power system and connected equipment. Limiting values and appropriate statistical indices should be developed on a case-by-case basis starting from the guidance of Annex A and considering the specifics of the supply system, connected user loads, and provisions for other users.

5.3 Recommended current distortion limits for systems nominally rated above 69 kV through 161 kV

The limits in this subclause apply to users connected to systems where the rated voltage V at the PCC is $69 \text{ kV} \le V \le 161 \text{ kV}$. At the PCC, users should limit their harmonic currents as follows:

— Daily 99th percentile very short time (3 s) harmonic currents should be less than 2.0 times the values given in Table 3.

IEEE Recommended Practice and Requirements for Harmonic Control in Electric Power Systems

- -- Weekly 99th percentile short time (10 min) harmonic currents should be less than 1.5 times the values given in Table 3.
- Weekly 95th percentile short time (10 min) harmonic currents should be less than the values given in Table 3.

All values should be in percent of the maximum demand current, I_L . This current value is established at the PCC and should be taken as the sum of the currents corresponding to the maximum demand during each of the twelve previous months divided by 12. Table 3 applies to harmonic currents whose frequencies are integer multiples of the power frequency.

Maximum harmonic current distortion in percent of I _L Individual harmonic order (odd harmonics) ^{a, b}									
< 20 ^e	2.0	1.0	0.75	03	0.15	2.5			
20 < 50	3.5	1 75	1 25	05	0.25	4.0			
50 < 100	5.0	2 2 5	20	0.75	0 35	6.0			
100 < 1000	6.0	2.75	25	10	0.5	7.5			
> 1000	7.5	3.5	3.0	1.25	0.7	10 0			

Table 3—Current	distortion	limits for s	vstems rated	above 69 kV	through 161 kV

⁴Even harmonics are limited to 25% of the odd harmonic limits above.

^bCurrent distortions that result in a dc offset, e g., half-wave converters, are not allowed.

°All power generation equipment is limited to these values of current distortion, regardless of actual I_{sc}/I_L

where

 I_{sc} = maximum short-circuit current at PCC

 $I_{\rm L}$ = maximum demand load current (fundamental frequency component)

at the PCC under normal load operating conditions

For interharmonic current components with frequencies that are not integer multiples of the power frequency, users should limit the components to sufficiently low levels so as to not produce undesirable effects on the power system and connected equipment. Limiting values and appropriate statistical indices should be developed on a case-by-case basis starting from the guidance of Annex A and considering the specifics of the supply system, connected user loads, and provisions for other users.

5.4 Recommended current distortion limits for systems nominally rated above 161 kV

The limits in this subclause apply to users connected to general transmission systems where the rated voltage V at the PCC is greater than 161 kV. At the PCC, users should limit their harmonic currents as follows:

- Daily 99th percentile very short time (3 s) harmonic currents should be less than 2.0 times the values given in Table 4.
- Weekly 99th percentile short time (10 min) harmonic currents should be less than 1.5 times the values given in Table 4.
- Weekly 95th percentile short time (10 min) harmonic currents should be less than the values given in Table 4.

8 Copyright © 2014 IEEE. All rights reserved

IEEE Std 519-2014 IEEE Recommended Practice and Requirements for Harmonic Control in Electric Power Systems

All values should be in percent of the maximum demand current, $I_{\rm L}$. This current value is established at the PCC and should be taken as the sum of the currents corresponding to the maximum demand during each of the twelve previous months divided by 12. Table 4 applies to harmonic currents whose frequencies are integer multiples of the power frequency.

Maximum harmonic current distortion in percent of I _L										
Individual harmonic order (odd harmonics) ^{a, b}										
$I_{\rm sc}/I_{\rm L}$	$3 \le h < 11$	$11 \le h \le 17$	$17 \le h < 23$	$23 \le h < 35$	$35 \le h \le 50$	TDD				
< 25 [°]	1.0	0.5	0.38	0 15	0.1	1.5				
25 < 50	20	10	0.75	0.3	0.15	2 5				
≥ 50	3.0	1.5	1 15	0.45	0 22	3.75				

Table 4Cur	rent distortion	limits for s	vstems ra	ated >	161 kV
			y =		

^aEven harmonics are limited to 25% of the odd harmonic limits above.

^bCurrent distortions that result in a dc offset, e g., half-wave converters, are not allowed

^cAll power generation equipment is limited to these values of current distortion, regardless of actual I_{sc}/I_{L}

where

 $I_{\rm sc}$ = maximum short-circuit current at PCC

 $I_{\rm L}$ = maximum demand load current (fundamental frequency component)

at the PCC under normal load operating conditions

For interharmonic current components with frequencies which are not integer multiples of the power frequency, users should limit the components to sufficiently low levels so as to not produce undesirable effects on the power system and connected equipment. Limiting values and appropriate statistical indices should be developed on a case-by-case basis starting from the guidance of Annex A and considering the specifics of the supply system, connected user loads, and provisions for other users.

5.5 Recommendations for increasing harmonic current limits

It is recommended that the values given in Table 2, Table 3, and Table 4 be increased by a multiplying factor when actions are taken by a user to reduce lower-order harmonics. The multipliers given in the second column of Table 5 are applicable when steps are taken to reduce the harmonic orders given in the first column.

Harmonics orders limited to 25% of values given in Table 2, Table 3, and Table 4	Multiplier		
5,7	1.4		
5,7,11,13	17		
5,7,11,13,17,19	2.0		
5,7,11,13,17,19,23,25	2.2		
\downarrow	\downarrow		

Table 5—Recommended	multinliers	for increases	in harmonic	current limits
Table J	mulupliers	IVI IIICIEdaea		current minta

IEEE Std 519-2014 IEEE Recommended Practice and Requirements for Harmonic Control in Electric Power Systems

The multipliers in Table 5 can be obtained as shown in Equation (3) where p is the pulse-order of a threephase rectifier-based converter (p = 6, 12, 18, 24, etc.). These converters produce dominant or characteristic harmonic currents at orders of $p(n \pm 1)$, where n is a simple counter, n = 1, 2, 3 etc., and significantly lower current magnitudes at other orders. However, the recommended multipliers in Table 3 apply regardless of the method used to reduce the harmonics that would be considered "non-characteristic harmonics" for a ppulse converter as long as all "non-characteristic harmonics," including even-order harmonics, are kept below 25% of the limit values given in Table 2, Table 3, or Table 4 as appropriate.

Multiplier =
$$\sqrt{\frac{p}{6}}$$
 (3)

Annex A

(informative)

Interharmonic voltage limits based on flicker

For interharmonic components that are not integer multiples of the power frequency, system owners or operators may limit the weekly 95^{th} percentile short time harmonic voltages to the values shown graphically in Figure A-1 up to 120 Hz for 60 Hz systems. Depending on the voltage level, the integer harmonic limits in Table 1 may be more restrictive and should be used. The portions of the 0–120 Hz range where the integer harmonic limits of Table 1 are more restrictive are appropriately labeled in Figure A-1. The numerical values corresponding to Figure A-1 are given in Table A-1 for voltages at the PCC less than 1 kV. It is important to recognize that the suggested voltage interharmonic limits are based on lamp flicker assessed using the measurement technique described in IEEE Std 1453 and IEC 61000-4-15. These voltage interharmonic limits correlate with a short-term flicker severity Pst value equal to 1.0 for 60 Hz systems; different (but similar) limit values can be derived for 50 Hz systems. The recommended limits in Figure A-1 are not based on the effects of interharmonics on other equipment and systems such as generator mechanical systems, motors, transformers, signaling and communication systems, and filters. Due consideration should be given to these effects and appropriate interharmonic current limits should be developed on a case-by-case basis using specific knowledge of the supply system, connected user loads, and provisions for future users.

There is no limit on the 60 Hz component in Figure A-1. The 5% maximum applies to frequency components very near (but not equal to) 60 Hz.





l l Copyright © 2014 IEEE. All rights reserved.

80 Authorized licensed use limited to: UNIVERSIDADE DE SAO PAULO. Downloaded on September 30,2015 at 17:59:00 UTC from IEEE Xplore. Restrictions apply.

Frequency (Hz)	Magnitude (%)	Frequency (Hz)	Magnitude (%)	Frequency (Hz)	Magnitude (%)	Frequency (Hz)	Magnitude (%)
16	5.00	27	1.78	38	0 81	49	0 28
[17	4 50	28	164	39	0 78	50	0 25
18	3 90	29	1.54	40	0.71	51	0 23
19	3.45	30	1 43	41	0 64	52	0 25
20	3.00	31	1 33	42	0.57	53	027
21	2 77	32	1.26	43	0.50	54	0.29
22	2.53	33	1 20	44	0 48	55	0 35
23	2.30	34	1 13	45	0.43	56	0.40
24	2.15	35	1 05	46	0 38	57	0 58
25	2.03	36	0 95	47	0 34	58	0 77
26	1.90	37	0.85	48	0.31	59	0 95

Table A-1—Voltage interharmonic limits corresponding to Figure A-1 for PCC voltage less than 1 $kV^{a,\,b}$

^aThe values for frequencies above 60 (but less than 120) Hz are identical to those given in this table except the frequency of interest must be subtracted from 120 Hz before reading the corresponding value For example, the interharmonic voltage limit for 61 Hz is equal to that given in the table for 120-61 = 59 Hz, which is 0.95% ^bThe frequency resolution in Table A-1 is 1 Hz. The resolution available using the methods recommended in Clause 4 is 5 Hz. Special instrumentation to be agreed upon at the time of its use, may be needed to obtain 1 Hz resolution.

Annex B

(informative)

Telephone influence factor (TIF)

The TIF weighting is a combination of the C message weighting characteristic, which accounts for the relative interfering effect of various frequencies in the voice band (including the response of the telephone set and the ear), and a capacitor, which provides weighting that is directly proportional to frequency to account for the assumed coupling function. TIF is a dimensionless quantity that is indicative of the waveform and not the amplitude and is given by Equation (B.1).

$$TIF = \sqrt{\sum \left[\frac{(X_n \cdot W_n)}{X}\right]^2}$$
(B.1)

where

X =total rms voltage or current

- X_n = single frequency rms current or voltage at the frequency corresponding to harmonic order *n*
- W_n = single frequency TIF weighting at the frequency corresponding to harmonic order *n*

In practice, telephone interference is often expressed as a product of the current and the TIF, i.e., the *I*-*T* product, where the *I* is rms current in amperes and *T* is TIF as calculated in Equation (B.1). Alternatively, it is sometimes expressed as a product of the voltage and the TIF weighting, where the voltage is in rms kV, i.e., the kV-T product. The single frequency weighting values, based on 1960-vintage C-message weighting, are listed in Table B-1. Linear interpolation may be used as necessary in Table B-1.

FREQ	W_f	FREQ	W_f	FREQ	W_f	FREQ	W_f
60	0.5	1020	5100	1860	7820	3000	9670
180	30	1080	5400	1980	8330	3180	8740
300	225	1140	5630	2100	8830	3300	8090
360	400	1260	6050	2160	9080	3540	6730
420	65 0	1380	6370	2220	9330	3660	6130
540	1320	1440	6560	2340	9840	3900	4400
660	2260	1500	6680	2460	10340	4020	3700
720	2760	1620	6970	2580	10600	4260	2750
780	3360	1740	7320	2820	10210	4380	2190
900	4350	1800	7570	2940	9820	5000	840
1000	5000	1		}		í	

Table B-1—Weighting values (W_i)

B.1 Guidelines for *I-T* product

Table B-2 provides representative I-T guidelines for distribution systems operating at voltages less than (or equal to) 34.5 kV where it is more likely to have joint use of facilities, particularly poles and structures, involving electric power and telephone/communications companies. These guidelines should not be considered as recommended limits due to the wide range of variability in system and equipment

IEEE Std 519-2014 IEEE Recommended Practice and Requirements for Harmonic Control in Electric Power Systems

compatibility that is encountered in practice. The use of categories is for illustration purposes only and is provided in the event that it is desirable to assess or compare interference potentials in multiple areas of a particular electrical system.

Category	Description	I-T
Ι	Levels most unlikely to cause interference	Up to 10 000 ^b
II	Levels that might cause interference	10 000 up to 25 000
III	Levels that probably will cause interference	Greater than 25 000

Table B-2—/-T guidelines for distribution systems^a

^aThese values of *I-T* product are for circuits with an exposure between overhead systems, both power and telephone. Within an industrial plant or commercial building, the exposure between power distribution cables and telephone lines with twisted pairs is extremely low and no interference is normally encountered, the use of fiber optic cables for communications virtually eliminates the entire concern. ^bFor some areas that use a ground return for either telephone or power circuits, this value may be as low as 1500.

Annex C

(informative)

Limits on commutation notches

C.1 Recommended limits on commutation notches

The notch depth and the notch area of the line-to-line voltage at PCC should be limited as shown in Table C-1.

|--|

	Special applications ^a	G e neral system	Dedicated system ^b
Notch depth	10%	20%	50%
Notch area $(A_N)^{c, d}$	16400	22800	36500

^aSpecial applications include hospitals and airports

^bA dedicated system exclusively supplies a specific user or user load

^cIn volt-microseconds at rated voltage and current.

^dThe values for A_N have been developed for 480 V systems. It is necessary to

multiply the values given by V/480 for application at all other voltages.

These limits are recommended for low-voltage systems in which the notch area is easily measured on an oscilloscope or power quality monitor with oscilloscope capability. In the event that direct measurement is not possible, detailed simulations including advanced models of the supply system and loads may provide approximate waveforms that may be used in place of oscilloscope measurements. The relevant variables for use in Table C-1 are defined in Figure C-1.

IEEE Std 519-2014 IEEE Recommended Practice and Requirements for Harmonic Control in Electric Power Systems



Figure C-1—Definition of notch depth and notch area

EXHIBIT RG-12

PUBLIC UTILITY COMMISSION OF TEXAS

PUC NO. 49795 SOAH DOCKET NO. 473-20-1118

COMPANY NAME: Rio Grande Electric Cooperative, Inc.

INFORMATION REQUESTED:

Petty 5-3: Please refer to the "Current" tab of Deposition Exhibit 34. Over what time period did the PMI recorder record data for the following entries? Please specify start date and time and end date and time.

a. Petty Ranch Prior to Generator at 2:35 pm, Data Collection Date 3/6/2019

b. Petty Ranch --- Generator Data at 10:41 am, Data Collection Date 3/21/2019

c. Petty Ranch — Generator Data at 12:16 pm, Data Collection Date 3/21/2019

REQUESTED BY: Petty Group, LLP

RESPONSE:

- a. Petty Ranch prior to generator at 2:35pm, data collection date 3/6/2019. PMI recorded data from 3/6/2019 starting at 2:28pm and ending at 3/8/2019 at 10:22am.
- b. Petty Ranch generator data at 10:41am, data collection date 3/21/2019. PMI recorded data from 3/19/2019 starting at 1:22pm and ending at 3/21/2019 at 1:40pm.
- c. Petty Ranch generator data at 12:16pm, data collection date 3/21/2019. PMI recorded data from 3/19/2019 starting at 1:22pm and ending at 3/21/2019 at 1:40pm.

SPONSOR:

Roger Andrade
CONFIDENTIAL EXHIBITS RG-3, RG-6, RG-7, RG-8, RG-9, RG-10, RG-11 ARE BEING SUBMITTED UNDER CONFIDENTIAL COVER