

Control Number: 50421



Item Number: 299


Addendum StartPage: 0

Garland Power Light  
TRANSMISSION CONSTRUCTION PROGRESS REPORT  
for  
October 2020

Public Utility Commission of Texas  
Project No. **50421**

Utility's Project Number	Project Name	Location (City/County)	Description	Estimated (or Actual) Start Date	Finish Date (Construction Complete)	Date Energized (If Applicable)	Initial Estimated Project Cost (\$)	Final Estimated Project Cost (\$)	Final Actual Project Cost (\$)	% Variance	Percent Complete	Existing Voltage (kV)	Upgraded or New Voltage (kV)	Circuit Length (Miles)	Conductor Type & Size & Bundling	Structure Type(s)	Existing ROW Width (Feet)	Existing ROW Length (Miles)	New ROW Width (Feet)	New ROW Length (Miles)	Rule Section or PUC Control Number	Comments
na	Dent Road Expansion to Shelby 138kV Transmission Line	Greenville, Hunt County	GPL proposes to construct a new single-circuit 138-kV electric transmission line. The new transmission line will connect the proposed Dent Road 138-kV Switching Station owned by GPL to the existing Shelby Substation owned by TMPA.	08/01/17	na	03/06/20	9,230,000	13,942,737	14,262,077	2%	100%	138		5.7	1926 9 ACSS/TW	Single pole with vertical circuit	na	na	120	5.7	47379	
na	Dent Road 138kV Switching Station	Greenville, Hunt County	GPL switchyard to terminate the proposed transmission lines from Wallace Switch (RCEC) and Shelby(TMPA). A 138/69 kV autotransformer will interconnect with Dent Road substation (GEUS).	03/15/19	na	03/06/20	11,284,000	9,100,000	9,567,891	5%	100%	69	138	na	na	na	na	na	na	na	na	
na	Rusk To Panola Transmission Line	Rusk/Panola Counties	The proposed Project is a double-circuit 345-kV transmission line from the new Rusk Switching Station in Rusk County, Texas to the new Panola Switching Station, in Panola County, Texas, adjacent to the border with Louisiana. The Rusk Switching Station will be constructed and owned by Oncor Electric Delivery company (Oncor) and the Panola Switching Station will be constructed by Rusk Interconnection LLC and owned by Garland.	03/01/17	na	na	110,000,000			0%		345	76	2-bundled 1590 ACSS	Single pole double circuit	na	na	150	38	45624		
na	Nevill Road Switch to Greasewood Solar 345kV Transmission Line	Pecos County	GPL proposes to construct a new single-circuit 345kV electric transmission line. The new transmission line will connect the proposed 345kV Nevill Road Switch owned by GPL to the proposed Greasewood Solar Station owned by the generator.	02/01/20	na	na	11,563,000			99%	na	345	10	2-bundled 795 ACSR	Single pole with delta configured circuit	na	na	125	10	49513		
na	Nevill Road Switch - 345kV switching station	Pecos County	GPL switchyard to terminate the Nevill Road Switch to Greasewood Solar 345kV line and out in the existing 345kV Bakersfield to N McCamey line.	02/01/20	na	na	14,922,000			99%	na	345	na	na	na	na	na	na	na	na	na	
na	Olinger Wylie East	Nevada & Lavon, Collin Counties	GPL upgrade timber double circuit 138kV electric transmission lines Olinger to Wylie 2 and Olinger Wylie 3. Upgrade includes separating double circuit to single vertical steel monopoles with conductor rating upgrades. Project consists of upgrading two double circuit steel monopole 138kV lines, Olinger-Wylie 1, 2, 3, and Olinger-Ben Davis separating into four single vertical steel monopole 138kV transmission lines with conductor rating upgrades.	09/16/20	na	na	5,627,874	5,627,874		25%	138	138	5.3	959 6 ACSS/TW	Single pole with vertical circuit	100 and 120	5.3	20 Lavon Crossing only	0.45	na		

Steve Zaragoza  
Transmission Engineering Administrator  
510 W. Avenue B  
Garland, TX 75040  
szaragoza@gpilotexas.org



GPL1020  
Revised 10/14/2020