

SOAH DOCKET NO. 473-21-0538
PUC DOCKET NO. 51415

RECEIVED
2021 MAY 20 AM 11:04
FILED IN PUBLIC UTILITY SUMMIT
FILING OFFICE

SOUTHWESTERN ELECTRIC POWER COMPANY'S RESPONSE TO
CITIES ADVOCATING REASONABLE DEREGULATION'S
SECOND SET OF REQUESTS FOR INFORMATION

Question No. CARD 2-24:

Reference page 19, of SWEPCO witness Seidel's direct testimony, please provide the CMI, SAIDI and SAIFI related to vegetation causes for SWEPCO's total system and for the Company's Texas service area for each of the last three calendar years and for the test year.

Response No. CARD 2-24:

Please see CARD 2-24 Attachment 1 for the CMI, SAIDI and SAIFI related to vegetation causes for SWEPCO's total system and SWEPCO's Texas service area for each of the last three calendar years and for the test year.

Prepared By: Paul D. Flory
Sponsored By: Drew W. Seidel

Title: Regulatory Consultant Sr
Title: VP Dist Region Opers

Vegetation Related Outages Total Company

Year	Jurisdiction	CMI	SAIDI	SAIFI
2017	SWEPKO	47,201,737	88.20	0.58
2018	SWEPKO	65,296,834	121.63	0.73
2019	SWEPKO	59,047,868	109.55	0.65
Test Year	SWEPKO	63,779,935	118.33	0.65

Vegetation Related Outages SWEPKO TX

Year	Jurisdiction	CMI	SAIDI	SAIFI
2017	TEXAS	14,163,483	76.40	0.54
2018	TEXAS	18,701,703	100.70	0.75
2019	TEXAS	23,043,627	123.72	0.73
Test Year	TEXAS	23,073,976	123.88	0.72