



Control Number: 51415



Item Number: 578

Addendum StartPage: 0

SOAH DOCKET NO. 473-21-0538
PUC DOCKET NO. 51415

2021 MAY 20 PM 4:31

FILED
FILING CLERK

**SOUTHWESTERN ELECTRIC POWER COMPANY'S RESPONSE TO CITIES
ADVOCATING REASONABLE DEREGULATION'S NINTH SET OF REQUESTS FOR
INFORMATION**

Question No. CARD 9-21:

Provide SWEPCO's annual system SAIDI and SAIFI due to transmission line outages, excluding major storm events, for each of the last ten calendar years.

Response No. CARD 9-21:

See CARD 9-21 Attachment 1 for SWEPCO's annual system SAIDI and SAIFI due to transmission line outages, excluding major storm events, for each of the last ten calendar years.

Prepared By: William M. Romine

Title: Regulatory Consultant Staff

Sponsored By: Daniel R. Boezio

Title: VP Trans Field Services

Month End Date	SAIDI	SAIFI
12/31/2011	45.50	0.366
12/31/2012	33.25	0.326
12/31/2013	30.05	0.262
12/31/2014	31.09	0.287
12/31/2015	37.09	0.285
12/31/2016	29.69	0.283
12/31/2017	22.22	0.216
12/31/2018	40.11	0.313
12/31/2019	53.16	0.361
12/31/2020	60.41	0.405

Exclude Major Event Days (Traditional)

Include Major Cause Code Distribution Station,
Transmission Line, Transmission Station
Exclude Interrupt Type Momentary; Include
Current Record Status Approved