



Control Number: 51488



Item Number: 1

Addendum StartPage: 0

51488


**TCEQ PUBLIC WATER SYSTEM PLAN REVIEW SUBMITTAL FORM**  
(Complete, Seal and Attach to Submittal Package)

**WATER SYSTEM INFORMATION**

Date: 07/17/2019

TCEQ PWS Identification No.:  
(Facilities will be assigned this PWS No.)

Water System Name: Sandhurst Water System



**OWNER INFORMATION**

Water System Owner: Nafta Freeway Joint Ventures

Address: 1718 State St., Houston, TX 77007

(AC) Phone: 713-681-0070 ext. 101

Responsible Official: Ray Schneider

Title: Manager

County (System Location): Medina

Mechanism & Source of Financing: (i.e. loans, rates, self-financed, etc.)

Loan

Subdivision Sec., Phase, Unit, Etc.: Section 1-4 - Sandhurst

**ENGINEER INFORMATION**

Engineer Name: Steve Mangold

Registration No.: PE 57956

Firm Name: Mangold Engineering

Firm No.: F-5549

Phone: 210-213-3912

(AC) Fax: ~~713-681-0070~~ NONE

Firm Address: 5596 CR 5710, Devine TX 78016

**SUBMITTAL INFORMATION**

Is this submittal for a new public water system? YES: ☒ NO: ☐

If no, proceed to the Project Information section on Page 2. If no PWS number exists, the owner must submit a core data form and business plan, if required, in accordance with §290.39(f) and (g).

**NEW (PROPOSED) WATER SYSTEMS**

(Only complete this section if this submittal is for a NEW water system)

For new (proposed) system submittals, please provide 2 copies of the submittal and attach the following:

☒ A list of all water utilities within 1/2 mile of the proposed service area boundaries (reference 30 TAC 290.39(c)(1))

☐ Copies of written responses from each of the entities listed above (reference 30 TAC 290.39(c)(1))

☐ Copies of formal applications for service from each of the following (reference 30 TAC 290.39(c)(1)) :

☐ Any municipality if the system is within its ETJ

NONE

☐ Any district or other political subdivision whose corporate boundaries are within 1/2 mile of the proposed service area boundaries

NONE

☐ Any other water service provider whose certificated service area boundary is within 1/2 mile of the proposed service area boundaries

NONE

☐ Documentation that all application requirements, including fee payments, are current.

**Business plan:** Please complete the financial ability form, provide a cost summary for the proposed project, and submit a business plan (reference 30 TAC 290.39 (f)). The business plan must confirm capital available to construct the system according to TCEQ requirements. Acceptable financial information can include some of the following:

Financial statements (preferably audited), CPA compilation report, tax returns, statements of net worth, bank statements. If the project is being funded with loan proceeds, provide a loan commitment letter from the lender specific to this project.

If the plan submittal is for a community system, also provide a copy of the Certificate of Convenience and Necessity (CCN) application submitted to the Public Utility Commission of Texas (PUC), and complete items referenced in 30 TAC 290.39 (f) (1 - 13).



# TCEQ PUBLIC WATER SYSTEM PLAN REVIEW SUBMITTAL FORM

(Complete, Seal and Attach to Submittal Package)

- ☐ Justification for constructing a separate system (if one of the entities listed above is willing to provide service)
- ☐ TCEQ Core Data Form (No. 10400)
- ☐ Emergency Preparedness Plan (No. 20536) if serving water in Harris or Fort Bend Counties and have overnight accommodations

## CERTIFICATE OF CONVENIENCE AND NECESSITY (CCN)

Certificates of Convenience and Necessity (CCN) applications are processed by the Public Utility Commission of Texas (PUC) and are required for privately owned systems and water supply corporations. If a CCN is required and a CCN does not exist, the applicant must obtain a CCN number or have the application accepted for filing at the PUC before a PWS project submittal can be technically reviewed. In addition, if a submittal is for a project located outside the CCN area, a CCN amendment application must be submitted before a project may be reviewed for construction approval. Please refer to PUC for additional information at: <http://www.puc.texas.gov/industry/water/guidance/UtilRulesGuidance.aspx>.

Will the proposed PWS be owned by either an investor owned utility (IOU) or water supply corporation (WSC)? If yes, please indicate which type of entity \_\_\_\_\_

YES: ☒ NO: ☐

Has a CCN application been submitted to the PUC? If yes, please provide the date of acceptance \_\_\_\_\_

YES: ☐ NO: ☒

List the name, license number and class of the operator for the proposed system: \_\_\_\_\_

## PROJECT INFORMATION

If a system does NOT have a PWS number, the sections above must be filled out

All engineering documents must be sealed, signed, and dated by a Texas registered professional engineer. An engineering report that includes the number of connections to be served must accompany each project. Please check each box that is applicable.

If this submittal is a revision of previously submitted plans, please provide the assigned TCEQ log number: \_\_\_\_\_

### New Projects/Facilities

### Modifications to Existing Facilities

☒ Water well construction – Proposed

☐ Surface water treatment plant modifications

☐ Well completion data for approved well

☐ Storage capacity modifications

☐ Ground water treatment plant – New

☐ Distribution system modifications

☐ Surface water treatment plant – New

☐ Pressure maintenance facilities modifications

☐ Proposed Innovative/Alternative Treatment

☐ Disinfection facilities or other modifications

☐ Request for rule exception

☒

☐ Preliminary engineering report without plans

☐ Texas Water Development Board Project No.:

☐ As-Built Plans & Engineering Report

☐ Other (please describe): \_\_\_\_\_

## SIGNATURE AND CERTIFICATION

The following certification indicates I have the authority to make submittals on behalf of the PWS referenced on Page 1. I hereby certify that the above information is, to the best of my knowledge, true and correct:

Engineer's Signature: \_\_\_\_\_

*Stephen Mangold*


Engineer's Printed Name: \_\_\_\_\_

STEPHEN MANGOLD

Date: \_\_\_\_\_

9/4/2019

**Signature/P.E. Seal Required below:**



Please call (512) 239-4691 if you have questions regarding this form. Your cooperation will help us provide better service. Additional helpful information and rules are available at the Public Water System Plan Review website.





# TCEQ Core Data Form

TCEQ Use Only

For detailed instructions regarding completion of this form, please read the Core Data Form Instructions or call 512-239-5175.

## SECTION I: General Information

1. Reason for Submission (If other is checked please describe in space provided.)		
<input checked="" type="checkbox"/> New Permit, Registration or Authorization (Core Data Form should be submitted with the program application.)		
<input type="checkbox"/> Renewal (Core Data Form should be submitted with the renewal form)	<input type="checkbox"/> Other	
2. Customer Reference Number (if issued)	Follow this link to search for CN or RN numbers in <a href="#">Central Registry**</a>	3. Regulated Entity Reference Number (if issued)
CN		RN

## SECTION II: Customer Information

4. General Customer Information		5. Effective Date for Customer Information Updates (mm/dd/yyyy)		07/17/2019	
<input checked="" type="checkbox"/> New Customer <input type="checkbox"/> Update to Customer Information <input type="checkbox"/> Change in Regulated Entity Ownership					
<input type="checkbox"/> Change in Legal Name (Verifiable with the Texas Secretary of State or Texas Comptroller of Public Accounts)					
<b>The Customer Name submitted here may be updated automatically based on what is current and active with the Texas Secretary of State (SOS) or Texas Comptroller of Public Accounts (CPA).</b>					
6. Customer Legal Name (If an individual, print last name first: e.g.: Doe, John) <u>If new Customer, enter previous Customer below:</u>					
Nafta Freeway Joint Venture					
7. TX SOS/CPA Filing Number		8. TX State Tax ID (11 digits)		9. Federal Tax ID (9 digits)	
				205677723	
11. Type of Customer:		<input type="checkbox"/> Corporation <input type="checkbox"/> Individual		Partnership: <input checked="" type="checkbox"/> General <input type="checkbox"/> Limited	
Government: <input type="checkbox"/> City <input type="checkbox"/> County <input type="checkbox"/> Federal <input type="checkbox"/> State <input type="checkbox"/> Other		<input type="checkbox"/> Sole Proprietorship		<input type="checkbox"/> Other:	
12. Number of Employees				13. Independently Owned and Operated?	
<input checked="" type="checkbox"/> 0-20 <input type="checkbox"/> 21-100 <input type="checkbox"/> 101-250 <input type="checkbox"/> 251-500 <input type="checkbox"/> 501 and higher				<input type="checkbox"/> Yes <input type="checkbox"/> No	
14. Customer Role (Proposed or Actual) - as it relates to the Regulated Entity listed on this form. Please check one of the following:					
<input checked="" type="checkbox"/> Owner <input type="checkbox"/> Operator <input type="checkbox"/> Owner & Operator					
<input type="checkbox"/> Occupational Licensee <input type="checkbox"/> Responsible Party <input type="checkbox"/> Voluntary Cleanup Applicant <input type="checkbox"/> Other:					
15. Mailing Address:					
1718 State Street					
City		Houston		State	
		TX		ZIP	
		77007		ZIP + 4	
16. Country Mailing Information (if outside USA)				17. E-Mail Address (if applicable)	
				sandhurstwater@gmail.com	
18. Telephone Number		19. Extension or Code		20. Fax Number (if applicable)	
( 713 ) 681 - 0070		101		( 713 ) 681 - 0570	

## SECTION III: Regulated Entity Information

21. General Regulated Entity Information (If "New Regulated Entity" is selected below this form should be accompanied by a permit application)	
<input checked="" type="checkbox"/> New Regulated Entity <input type="checkbox"/> Update to Regulated Entity Name <input type="checkbox"/> Update to Regulated Entity Information	
<b>The Regulated Entity Name submitted may be updated in order to meet TCEQ Agency Data Standards (removal of organizational endings such as Inc, LP, or LLC).</b>	
22. Regulated Entity Name (Enter name of the site where the regulated action is taking place.)	
Sandhurst Water System	



23. Street Address of the Regulated Entity: (No PO Boxes)	1718 State Street						
	City	Houston	State	TX	ZIP	77007	ZIP + 4
24. County							

Enter Physical Location Description if no street address is provided.

25. Description to Physical Location:							
26. Nearest City	Devine			State	TX	Nearest ZIP Code	78016
27. Latitude (N) In Decimal:			28. Longitude (W) In Decimal:				
Degrees	Minutes	Seconds	Degrees	Minutes	Seconds		
29. Primary SIC Code (4 digits)	6552		30. Secondary SIC Code (4 digits)			31. Primary NAICS Code (5 or 6 digits)	32. Secondary NAICS Code (5 or 6 digits)
33. What is the Primary Business of this entity? (Do not repeat the SIC or NAICS description.) Providing Water to development							
34. Mailing Address:	1718 State Street						
	City	Houston	State	TX	ZIP	77007	ZIP + 4
35. E-Mail Address:							
36. Telephone Number		37. Extension or Code		38. Fax Number (if applicable)			
( 713 ) 681 - 0070		101		( 713 ) 681 - 0570			

39. TCEQ Programs and ID Numbers Check all Programs and write in the permits/registration numbers that will be affected by the updates submitted on this form. See the Core Data Form instructions for additional guidance.


<input type="checkbox"/> Dam Safety	<input type="checkbox"/> Districts	<input type="checkbox"/> Edwards Aquifer	<input type="checkbox"/> Emissions Inventory Air	<input type="checkbox"/> Industrial Hazardous Waste
<input type="checkbox"/> Municipal Solid Waste	<input type="checkbox"/> New Source Review Air	<input type="checkbox"/> OSSF	<input type="checkbox"/> Petroleum Storage Tank	<input checked="" type="checkbox"/> PWS
<input type="checkbox"/> Sludge	<input type="checkbox"/> Storm Water	<input type="checkbox"/> Title V Air	<input type="checkbox"/> Tires	<input type="checkbox"/> Used Oil
<input type="checkbox"/> Voluntary Cleanup	<input type="checkbox"/> Waste Water	<input type="checkbox"/> Wastewater Agriculture	<input type="checkbox"/> Water Rights	<input type="checkbox"/> Other:

#### SECTION IV: Preparer Information

40. Name:	Ray Schneider		41. Title:	Manager
42. Telephone Number	43. Ext./Code	44. Fax Number	45. E-Mail Address	
( 832 ) 731 - 3937		( 713 ) 681 - 0570	raymschneider@yahoo.com	

#### SECTION V: Authorized Signature

46. By my signature below, I certify, to the best of my knowledge, that the information provided in this form is true and complete, and that I have signature authority to submit this form on behalf of the entity specified in Section II, Field 6 and/or as required for the updates to the ID numbers identified in field 39.

Company	NAFTA FREEWAY JOINT VENTURE	Job Title:	WATER PLANT MANAGER
Name/(In Print)	Ray Schneider	Phone:	( 713 ) 681 - 0070
Signature		Date:	Sept. 10, 19

# ENGINEERING REPORT


for  
Sandhurst Water System  
Report #: 400-204R  
Date: 9/4/2019

Report as required by  
30 TAC 290.39(e)



MANGOLD ENGINEERING COMPANY  
5596 CR 5710  
DEVINE, TEXAS 78016  
PHONE: (830) 931-0400  
PHONE: (210) 213-3912  
FIRM NO. F-5549





***MANGOLD Engineering Company***

5596 CR 5710

Devine, TX 78016


Phone: (830) 931-0400 Cell: (210) 213-3912

FIRM NO. F-5549

---

## **SUMMARY**

This report presents a design for the Sandhurst Water System. The water system has been designed to provide potable water to residential lots in a subdivision which will consist of 75 lots. There are no future plans for expansion of the water system and the system well and equipment have been designed for the 75 connections. A new public water well shall be drilled as the water source. A survey of existing and potential pollution hazards was completed for the new well site and is contained in Appendix 1 of this report. The new well shall have an 8" well casing and the annular space surrounding the casing shall be pressure cemented down to the aquifer being developed. A submersible pump capable of pumping at least 59 gpm against the total developed head shall be set in the well. The water system shall have one 2,500 gallon pressure tank and a 25,000 gallon ground storage tank. Two service pumps capable of delivering at least 128 gpm to the distribution system shall be installed. The distribution system shall consist of Class 200 pipe sufficiently sized to maintain at least 35 psi in all parts of the distribution system, with a flow rate of 113 gpm which is the estimated peak flow rate. This report is written in compliance with 30 TAC 290.39 (e).



***MANGOLD Engineering Company***

5596 CR 5710

Devine, TX 78016

Phone: (830) 931-0400 Cell: (210) 213-3912

FIRM NO F-5549


---

**CONTENTS**

Summary .....	ii
1.0 Introduction / Statement of problem .....	1
2.0 Present and future areas to be served with population data .....	1
3.0 Water source with quantity and quality.....	1
4.0 Present and future water use .....	1
5.0 Description of proposed site and surroundings .....	2
6.0 Water treatment .....	2
7.0 Basic design data .....	2
7.1 Pumping capacities .....	2
7.2 Water storage .....	3
7.3 Pressure maintenance .....	3
7.4 Flexibility of operation .....	4
8.0 Plans and Drawings .....	4
9.0 Abandoned or inoperative wells .....	4
10.0 Staged construction .....	4
11.0 General maps .....	5
12.0 System capacities .....	5
12.1 Well capacity and well pump .....	5
12.2 Ground storage capacity .....	5
12.3 Pressure tank capacity .....	5
13.0 Well description .....	5

---





**MANGOLD Engineering Company**

5596 CR 5710

Devine, TX 78016

Phone: (830) 931-0400 Cell. (210) 213-3912


FIRM NO F-5549

---

**CONTENTS (continued)**

<b>14.0</b>	<b>Conclusions and Recommendations .....</b>	<b>6</b>
<b>15.0</b>	<b>References .....</b>	<b>6</b>
<b>Appendices</b>		
	<b>Appendix 1 Survey of existing and potential pollution hazards</b>	
	<b>Appendix 2 Scale drawings</b>	
	<b>Appendix 3 General maps</b>	
	<b>Appendix 4 Manufacturer's specifications of equipment used in water system design</b>	
	<b>Appendix 5 List of water utilities within 1/2 mile of the proposed service area boundaries and copies of written responses from each of the water utilities</b>	
	<b>Appendix 6 Business Plan</b>	
	<b>Appendix 7 Sanitary Control Easement around new well site</b>	

---



## ***MANGOLD Engineering Company***

5596 CR 5710

Devine, TX 78016

Phone: (830) 931-0400 Cell: (210) 213-3912

FIRM NO. F-5549

---

### **1.0 Introduction / Statement of problem**

The new Sandhurst Subdivision is being developed in Medina County, Texas. The subdivision lots require potable water to serve the residents. Since the water system will be serving the general public, and will be serving more than 14 connections, it qualifies as a public water system. A new public water well along with water treatment, pressure maintenance facilities, and a distribution system, which currently does not exist, is required. This report presents the design of the new water system and demonstrates compliance with the applicable requirements of 30 TAC, Chapter 290, Subchapter D, Rules and Regulations for Public Water Systems.

### **2.0 Present and future areas to be served with population data**

The proposed water system shall serve 75 connections at present. To the best of my knowledge, there are no plans for expansion. The pressure maintenance design presented here is for 75 connections. To increase the number of connections above the 75 which are currently shown, will require upgrades to the entire system.

### **3.0 Water source with quantity and quality**

The water source for the new subdivision shall be a new public water well. It is estimated that the well yield will be 50 gpm. Information obtained from a study of other wells in the area of the proposed new public well indicates that the water quality will meet all TCEQ standards without additional treatment. Additional water treatment other than chlorination will be added if water tests show deficiencies in the water quality.

### **4.0 Present and future water use**

At present it is estimate that the maximum daily demand on the water system will be 25,125 gallons per day with a peak flow rate of 113 gpm. See 2.0 above for information on future use.





***MANGOLD Engineering Company***

5596 CR 5710

Devine, TX 78016

Phone: (830) 931-0400 Cell: (210) 213-3912

FIRM NO. F-5549

---

**5.0 Description of proposed site and surroundings**

The new water well and water system is located along the northwest access road of Interstate Hwy. 35, approximately 4.2 southwest of Devine, Texas. The property where the Sandhurst Water System is being constructed is bordered on one side by the I.H. 35 access road and on all other sides by undeveloped land. See Appendix 3 for General maps and Appendix 2 for scale drawings of the site.

**6.0 Water treatment**

The new water supply shall have a liquid chlorination treatment system. The system shall consist of a 30 gallon liquid chlorine solution tank, a Stenner Classic Series 45 feed pump capable of delivering 3 gpd of chlorine solution against pressures ranging from 0.2 to 25 psi. The pump is self priming up to 25 feet and has an adjustable feed rate with a 20:1 turndown ratio. The system also has feed tubing routed to the storage tank inlet line to meter the chlorine solution to the flow into the storage tank. See Appendix 4 for manufacturer's specifications for both the pump and tank. See Appendix 2 for design drawings.

**7.0 Basic design data**

**7.1 Pumping capacities**

The well pump shall be a 6" submersible jet pump capable of delivering 59 gpm against the calculated dynamic head of 302 feet. The pump setting depth is estimated to be 280 feet and the static water level in the



**MANGOLD Engineering Company**

5596 CR 5710

Devine, TX 78016

Phone: (830) 931-0400 Cell: (210) 213-3912

FIRM NO. F-5549

---

well is estimated to be 200 feet. There shall be two service pumps installed which shall be capable of delivering at least 128 gpm to the distribution system against the maximum pressure tank setting of 65 psig. The peak flow rate for the system is estimated to be 113 gpm. See Appendix 2 for specific pump callouts for both the well and service pumps. Also see Appendix 4 for pump curves and manufacturer's specifications for the pumps.


## **7.2 Water Storage**

The ground storage tank shall be a steel tank, fiberglass tank or other approved material which is covered and designed, fabricated, erected, tested, and disinfected in strict accordance with current American Water Works Association (AWWA) standards and shall be provided with the minimum number of inlets and outlets, size and type of roof vents, man ways, drains, sample connections, access ladders, overflows, liquid level indicators, and other appurtenances as specified in the applicable TCEQ rules. See Appendix 2 for more specific information. Also see Appendix 4 for tank manufacturer's specifications.

## **7.3 Pressure Maintenance**

The system shall be provided with an air over water hydropneumatic tank. The tank shall be located wholly above grade and must be of steel construction with welded seams. The metal thickness of the tanks must be sufficient to withstand the highest expected working pressure (65 psig for this system) with a four to one factor of safety. The tanks selected have a minimum burst pressure of 450 psig which gives them an 6.9 factor of safety. See Appendix 2 for more specific information. Also see Appendix 4 for tank manufacturer's specifications.





**MANGOLD Engineering Company**

5596 CR 5710

Devine, TX 78016

Phone: (830) 931-0400 Cell (210) 213-3912

FIRM NO. F-5549

---

**7.4 Flexibility of operation**

The pressure switch for the pressure tank shall be set to maintain the tank pressure between 45 psig and 65 psig. An 8" PVC main line shall supply water to the subdivision lots. The peak flow rate is 113 gpm. With these parameters, the calculations show that the pressure will be well above 35 psig at all points in the system at minimum hydropneumatic tank pressure. The required pressure of 35 psig in the system could be maintained with a wide range of flow rates to the system.

**8.0 Plans and Drawings**


Complete engineering plans and drawings for the water well, pressure maintenance facilities, distribution system, and treatment system were completed and are contained in Appendix 2.

**9.0 Abandoned or inoperative wells**

To the best of my knowledge there are no abandoned or inoperative wells within 1/4 mile of the proposed site for the new propose public water well. See Appendix 1 for a Survey of Existing and Potential Pollution Hazards.

**10.0 Staged construction**

To the best of my knowledge the entire system consisting of a new water well, pressure maintenance facilities and distribution system shall be constructed together. No staged construction is anticipated.



**MANGOLD Engineering Company**

5596 CR 5710

Devine, TX 78016

Phone: (830) 931-0400 Cell: (210) 213-3912

FIRM NO. F-5549

---

**11.0 General maps**

See Appendix 3 for a USGS Quadrangle map and a general locator map showing the location of the site for the new proposed public water well.

**12.0 System capacities**

The system is a community water system with ground storage which is designed to serve 75 connections.

**12.1 Well capacity (designed for 75 connections)**

The required minimum well capacity is 0.6 gpm per connection. The required minimum well yield is, therefore, 45 gpm for 75 connections.

**12.2 Ground storage capacity (designed for 75 connections)**

The required ground storage capacity must be at least 200 gallons per connection. The proposed storage tank is 25,000 gallons. The required capacity is 15,000 gallons.


**12.3 Pressure tank capacity (designed for 75 connections)**

The minimum required pressure tank capacity is 20 gallons per connection. The proposed pressure tank capacity is 2,500 gallons. The required capacity is 1,500 gallons.

**13.0 Well description**

The new proposed public water well shall be located as shown on the scale drawings in Appendix 2 and as shown on the general maps in Appendix 3. The drilled hole shall be 12 1/4" diameter down to 300 ft. total depth. The well casing shall be 8 5/8" outside diameter and the well shall be cased to a depth of 200 ft. The annular space between the well casing and the drilled hole shall be sealed by using enough cement under pressure to completely fill and seal the annular space from the top of the shallowest formation to be developed to the earth's surface. The static water level is





**MANGOLD Engineering Company**

5596 CR 5710

Devine, TX 78016

Phone: (830) 931-0400 Cell: (210) 213-3912

FIRM NO. F-5549

---


expected to be at approximately 200 ft. The well slab shall be reinforced concrete and shall slope downward away from the well casing at 1/4" per foot, minimum. It shall be a minimum of 6" thick and shall extend laterally at least 38" from the edge of the well casing. The casing shall have a cap which is securely attached and sealed to the well casing in a way which prevents tampering and the entrance of pollutants into the well. The well casing shall extend at least 18 inches above the upper surface of the well slab adjacent to the casing. The foregoing description is a partial description which highlights the major parts of the water well. See Appendix 2 for a complete description.

#### **14.0 Conclusions and Recommendations**

The design for Sandhurst Water System has been presented and discussed in this report. The major items comprising the system are a new public water well, a 25,000 gallon ground storage tank, one 2,500 gallon pressure tank, one submersible well pump, two service pumps, a chlorination system, and a distribution system. The water system must be under the direct supervision of a certified water works operator holding a valid certificate of competency issued under the direction of the TCEQ.

#### **15.0 References**

30 TAC, Chapter 290, Subchapter D, Rules and Regulations for Public Water Systems, Effective July 30, 2015.



***MANGOLD Engineering Company***

5596 CR 5710

Devine, TX 78016

Phone. (830) 931-0400 Cell: (210) 213-3912

FIRM NO. F-5549


---

## **Appendix 1**

**Survey of existing and potential pollution hazards**

---





**MANGOLD Engineering Company**

5596 CR 5710  
Devine, TX 78016  
Phone: (830) 931-0400 Cell (210) 213-3912  
FIRM NO F-5549

Water Utilities Division  
P.O. Box 13087  
Austin, Texas 78711-3087

September 18, 2019  
Sheet 1 of 1

Subject: Survey of existing and potential pollution hazards for the proposed well which will serve Sandhurst Water System located as shown on the attached plans in Medina County, Texas.

Dear Sirs:

A survey of existing and potential pollution hazards relating to the subject well was conducted with the following findings.

To the best of my knowledge, there are no improperly constructed, abandoned, or inoperative wells or existing/potential pollution hazards as described in the TCEQ "Guidance For a Survey of Existing/Potential Sources of Ground Water Pollution", within a 1/4 mile radius of the proposed site of the subject well.

To the best of my knowledge, there are no sewage treatment plants, lands on which sewage plant or septic tank sludge or effluent is applied, lands irrigated by sewage plant effluent, animal feed lots, or (livestock and animal pens), or solid waste disposal sites, within a 500 ft. radius of the proposed site of the subject well.

To the best of my knowledge, there are no sewage wet wells, sewage pump stations, or ditches containing sewage treatment waste, municipal wastes or industrial wastes, within a 300 ft. radius of the proposed site of the subject well.


To the best of my knowledge, there are no septic tank perforated drainfields, absorption beds, evapotranspiration beds, privies, underground fuel storage tanks, cemeteries, areas irrigated by low pressure dosage, drip irrigation drainfields, low angle spray on-site sewage facilities, underground petroleum or chemical storage tanks or liquid transmission pipelines, military and industrial facilities, landfills and dumpsites, or water wells that do not meet Public Drinking Water Standards, within a 150 ft. radius of the proposed site of the subject well.

To the best of my knowledge, there are no tile or concrete sanitary sewers, septic tanks, livestock in pastures, or storm sewers within a 50 ft. radius of the proposed site of the subject well.

If further information is required, please don't hesitate to call.

Sincerely,

Stephen A. Mangold, P.E.



***MANGOLD Engineering Company***

5596 CR 5710

Devine, TX 78016

Phone: (830) 931-0400 Cell: (210) 213-3912

FIRM NO. F-5549

---


## **Appendix 2**

**Scale drawings**


---







EXPLODED VIEW OF PRESSURE MAINTENANCE FACILITIES



MATERIALS LIST FOR WATER DISTRIBUTION SYSTEM

ITEM	DESCRIPTION	UNIT	QUANTITY
1	2" PVC Class 200 Water Pipe	LF	0
2	3" PVC Class 200 Water Pipe	LF	3572
3	4" PVC Class 200 Water Pipe	LF	0
4	6" PVC Class 200 Water Pipe	LF	0
5	8" PVC Class 200 Water Pipe	LF	4802
6	2" Gate Valve & Box	EA	0
7	3" Gate Valve & Box	EA	0
8	4" Gate Valve & Box	EA	4
9	6" Gate Valve & Box	EA	5
10	8" Gate Valve & Box	EA	43
11	Single Service	EA	16
12	Dual Service	EA	6
13	Fire Hydrant (Standard)	EA	0
14	3/4" Meter	EA	A/R
15	Plastic Water Boxes	A/R	

LEGEND  
 (V) = 2" GATE VALVE & BOX  
 (V) = 3" GATE VALVE & BOX  
 (V) = 4" GATE VALVE & BOX  
 (V) = 6" GATE VALVE & BOX  
 (V) = 8" GATE VALVE & BOX

#### SIZING OF SYSTEM CAPACITY

THE WATER SYSTEM SHALL BE SIZED TO SERVE CONNECTIONS TO 125 RESIDENTIAL LOTS

$Q_{Total} = 41,875$  GPD

ESTIMATED PEAK FLOW RATE = 188 GALLONS/MINUTE

EXPECTED WELL YIELD = 150 GALLONS/MINUTE

STORAGE 25,000 GALLONS

PRESSURE TANK ONE 2,500 GALLON TANK

SERVICE PUMPS TWO BERKELEY B2TPM, 10 HP, 230 VOLT, SINGLE PHASE PUMPS, OR EQUAL

WELL PUMP ONE GOULDS MODEL 160L-30, 30 HP, 6" DIA. THREE PHASE PUMP, OR EQUAL



SCALE: 1" = 200'

#### SYSTEM LAYOUT

0 200 400 600

ALL WATER MAINS WILL BE PRESSURE TESTED BY THE WATER SYSTEM CONTRACTOR

ALL PIPES IN THE DISTRIBUTION SYSTEM SHALL BE PVC CLASS 200-SDR 21, WITH GASKETED INTERNAL BELL JOINTS. PIPE DESIGN SHALL MEET ASTM D-2241

4 INCHES OF SAND WILL BE PLACED IN THE TRENCH BELOW ALL MAINS WHERE THERE IS NO ROCK. IF ROCK IS ENCOUNTERED THE MAIN WILL BE COVERED WITH SAND ALSO

ALL VALVES IN THE DISTRIBUTION SYSTEM ARE TO BE LEFT CLOSED UNTIL AFTER THE SYSTEM HAS BEEN DISINFECTED AND ACCEPTED

ALL FIRE HYDRANTS AND VALVE TOPS ARE TO BE SET TO GRADE BY THE WATER SYSTEM CONTRACTOR, IF APPLICABLE

THE TOPS OF ALL MAINS SHALL BE INSTALLED A MINIMUM OF 24" BELOW FINISHED GRADE

CONSTRUCTION OF THE DISTRIBUTION SYSTEM SHALL NOT BEGIN UNTIL ALL ROADS, AND PARKING AREAS HAVE BEEN CUT OR FILLED TO FINAL SUBGRADE

ALL WATER LINES CONNECTING THE WATER MAIN TO A BUILDING OR OTHER SITE SHALL BE AS SPECIFIED ON THE DRAWING

ALL CONCRETE REINFORCING SHALL BE 1/2" DIA. REBARS SPACED @ 12" O.C. EACH WAY LOCATED @ THE CENTER OF THE SLAB THICKNESS, UNLESS OTHERWISE DETAILED

ALL EXPOSED WATER PIPES AND OTHER EXPOSED EQUIPMENT SHALL BE INSULATED FOR PROTECTION AGAINST FREEZING

Plans For:

SANDHURST  
WATER SYSTEM

MANGOLD ENGINEERING COMPANY

Phone: (830) 931-0400  
Phone: (210) 213-3912

5596 CR 5710  
Devine, Texas 78016  
FIRM NO. F-5549



Dwg: 400-203


Date: 9/4/18

Revision: 1P


Drawn: S Mangold

Sheet: 2 of 4





Schematic of Pressurization system  
(See general notes)



#### PRESSURE TANK DETAIL

The pressure tank shall conform to the ASME section VIII, Division 1, code and construction regulations ASME. Tank shall be permanently attached with a pressure release device per TCEQ requirements.

Tank shall have a minimum working pressure of 100 psi and a minimum burst pressure of 150 psi which gives the tank more than a 1.5 safety factor over the expected working pressure of 60 psi.

#### STORAGE TANK NOTES:


All portions of the roof of the storage tank shall drain toward the edges of the tank and shall have a slope of not less than 1/4" per foot. The roof opening in the tank shall be a minimum of 20 inches in diameter and shall have a raised curb at least 6 inches high. The opening shall be covered by a lockable cover that overlaps the curb at least 2 inches in a downward direction. The cover shall be locked at all times except during periods of necessary access to the tank.

The storage tank roof shall be vented with a gooseneck vent. The vent opening shall be securely covered by a 16 mesh or finer screen made of corrosion resistant material.

The storage tank shall be equipped with a 1" or larger overflow line which shall terminate between 15 feet and 20 feet above ground level. The opening to the overflow line shall be fitted with a gravity hanger and weighted cover which fits tightly and has no gap greater than 1/8". The storage tank shall use its equipment with a means of visually determining the water level in the tank from outside of the tank. This shall be accomplished by installing a pressure gauge at the tank bottom. The gauge shall be 1/2" diameter or larger and shall be calibrated in 1 foot increments.

All coatings for the inside surface of the storage tank must conform to ANSI/NF Standards 61 and must be certified by an organization accredited by ANSI.

All coatings for the inside surface of the storage tank must conform to ANSI/NF Standards 61.



#### STORAGE TANK DETAIL

The storage tank shall be covered and designed, fabricated, erected, tested, and disinfected in strict accordance with current American Water Works Association (AWWA) standards and shall be provided with all items as specified in 30 TAC 290.43(c).

Cap securely attached and sealed to well casing in a way which prevents sanding and the entrance of pollutants into the well.

Well casing vent turned down with an opening that is covered by 16-mesh or finer corrosion resistant screen.

10 3/4" OD well casing material shall be new ASTM A199 Grade B carbon steel, ASTM A502 Type A high-strength low-alloy steel or 10K-17 PVC pipe. The material shall conform with AWWA standards.

Concrete sealing block separated from well casing by plastic or nastic coating. Upper surface of block shall be sealed to drain away from the well casing a minimum of 125 inches per foot.

Ground surface line grader so that well site is free of depressions, reverse grades or areas too rough for proper ground maintenance so as to ensure that surface water will drain away from the well.

Electric conduit for meter wiring. Conduit is to be weather tight and sealed at its entry point to the wellhead.

Concrete sealing block separated from well casing by plastic or nastic coating. Upper surface of block shall be sealed to drain away from the well casing a minimum of 125 inches per foot.

Ground surface line grader so that well site is free of depressions, reverse grades or areas too rough for proper ground maintenance so as to ensure that surface water will drain away from the well.

Electric wire for meter wiring. Conduit is to be weather tight and sealed at its entry point to the wellhead.

Concrete sealing block separated from well casing by plastic or nastic coating. Upper surface of block shall be sealed to drain away from the well casing a minimum of 125 inches per foot.


Ground surface line grader so that well site is free of depressions, reverse grades or areas too rough for proper ground maintenance so as to ensure that surface water will drain away from the well.

Electric wire for meter wiring. Conduit is to be weather tight and sealed at its entry point to the wellhead.

Concrete sealing block separated from well casing by plastic or nastic coating. Upper surface of block shall be sealed to drain away from the well casing a minimum of 125 inches per foot.

#### Well Detail (Minimum)

Expected well yield is 150 gpm  
(See general notes)



#### Discharge Piping Detail

Plans For:

SANDHURST  
WATER SYSTEM

MANGOLD ENGINEERING COMPANY

Phone: (830) 931-0400  
Phone: (210) 213-3912

5596 CR 5710  
Devine, Texas 78016

FIRM NO. F-5549



Dwg: 400-203

Date: 9/4/18



Revision: 1 R

Drawn: S Mangold


Sheet: 3 of 4











Concrete Support Behind Fittings




Valve and Box Installation (Typical)




Fire Hydrant Assembly (Typical)



Service Connection (Typical)



2" Blowoff Installation (Typical)



Trench Section (Typical)


**STANDARD DETAILS SHEET**  
ONLY USE THOSE DETAILS  
WHICH APPLY TO THIS DESIGN

Plans For:  
**SANDHURST  
WATER SYSTEM**

**MANGOLD ENGINEERING COMPANY**  
5596 CR 5710  
Devine, Texas 78016  
FIRM NO. F-5549  
Phone: (830) 931-0400  
Phone: (210) 213-3912

Dwg: 400-203  
Date: 9/4/18  
Revision: 1 R  
Drawn: S. Mangold  
Sheet: 4 of 4





***MANGOLD Engineering Company***

5596 CR 5710

Devine, TX 78016

Phone (830) 931-0400 Cell (210) 213-3912


FIRM NO. F-5549

---

## **Appendix 3**

**General maps**

---



Data use subject to license.


© DeLorme, XMap® 7.


www.delorme.com



Scale 1 : 12,000  
 0 200 400 600 800 1000  
 0 100 200 300 400 500  
 1" = 1,000.0 ft Data Zoom 14-1







***MANGOLD Engineering Company***

5596 CR 5710

Devine, TX 78016

Phone: (830) 931-0400 Cell: (210) 213-3912




FIRM NO. F-5549

---


## **Appendix 4**

**Manufacturer's specifications of equipment  
used in water system design**


---




SEE DETAIL FOR SPINWELD SEALING




COUPLING DETAIL  
HTS




FLANGE DETAIL  
HTS



ELLIPTICAL MANWAY DETAIL  
HTS




CRADLE DETAIL  
HTS



JOINT "1"



LUG DETAIL  
HTS



SPINWELD DETAIL  
HTS

BULLDOG STEEL PRODUCTS, INC.									
BULLDOG STEEL PRODUCTS, INC.									
ITEM	QTY	DESCRIPTION	UNIT	REMARKS	DATE	BY	CHKD	APPD	REV
1	1	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE
2	1	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE
3	1	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE
4	1	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE
5	1	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE
6	1	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE
7	1	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE
8	1	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE
9	1	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE
10	1	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE
11	1	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE
12	1	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE
13	1	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE
14	1	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE
15	1	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE
16	1	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE
17	1	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE
18	1	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE
19	1	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE
20	1	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE	2" DIA. FLANGE

**DESIGN + TEST DATA**

VESSEL DESIGN DATA  
DESIGN PRESSURE: 150 PSI  
DESIGN TEMPERATURE: 150°F  
DESIGN MATERIAL: HTS  
DESIGN CODE: ASME VIII DIV 1  
DESIGNER: BULLDOG STEEL PRODUCTS, INC.  
DATE: 1/1/18  
BY: [Signature]  
CHKD: [Signature]  
APPD: [Signature]

TESTING REQUIREMENTS  
HYDROSTATIC TEST PRESSURE: 1.5X DESIGN PRESSURE  
TEMPERATURE: 150°F  
HOLD TIME: 30 MIN  
INSPECTION: 100% UT  
REPAIR: AS REQUIRED  
RETEST: AS REQUIRED

WELDING AND INSPECTION  
WELDING: ASME VIII DIV 1  
INSPECTION: 100% UT  
REPAIR: AS REQUIRED  
RETEST: AS REQUIRED

CONSTRUCTION  
CONSTRUCTION: ASME VIII DIV 1  
INSPECTION: 100% UT  
REPAIR: AS REQUIRED  
RETEST: AS REQUIRED

**CERTIFIED BY**  
BULLDOG STEEL PRODUCTS, INC.  
150 PSI AT 150 DEGREE F  
100% UT  
DATE: 1/1/18  
BY: [Signature]  
CHKD: [Signature]  
APPD: [Signature]

RF-4


**60" x 14" LONG / 3,000 GALLON CAPACITY**

BULLDOG STEEL PRODUCTS, INC.  
P.O. BOX 569 EAST 120  
CLYDE, TX 79510-0569  
(325) 893-5806


DATE: 1/1/18  
BY: [Signature]  
CHKD: [Signature]  
APPD: [Signature]

ISSUED FOR CONSTRUCTION






ELEVATION VIEW



ORIENTATION VIEW

### JOINT DETAILS



### CONSTRUCTION NOTES:

ROOF FLAT Ø 15'-6"  
 ROOF RATCH (7512) COATED 19"  
 SHELL RING 1-4, 2 SHEETS/RING 72" x 202 11/16 x 1/4" A36  
 ROOF FLAT Ø 15'-2"  
 COMPLETE TANK WEIGHT 18,000 LBS  
 ANGULAR CONVERSIONS  
 ARC LENGTHS (at shell O.D.)  
 45° = 5'-10 11/16"  
 67.5° = 8'-10"  
 90° = 11'-9 1/8"

### TANK SCHEDULE \*

- 1 30" FLANGED & RIGID MANWAY
- 2 30" x 30" ROOF RATCH
- 3 20" HANGDOWN-TYPE ROOF VENT
- 4 6" FLANGED INLET w/ FULL HEIGHT RISE & TURNED w/ 90°
- 5 10" FULL LENGTH OVERFLOW w/ FLANGED FLAP - 45°
- 6 6" FLANGED OUTLET w/ Ø1 FLAP - 45°
- 7 4" FLANGED DRAIN
- 8 BULBDOOR STEEL FLAT-TYPE ROUND LEVEL INDICATOR
- 9 SELF-ADHESIVE STRIP ON CONNECTIONS
- 10 (END) 1" THROUGH COUPLERS
- 11 WELDED STEEL CAGED LADDER - REMOVABLE
- 12 CARBIDE-TIP FALL PROTECTION SYSTEM - GALVANIZED
- 13 12" x 15" TALL x 1/4" THICK STEEL REINFORCING RING GALVANIZED


ITEMS OMITTED FOR CLARITY

### PAINT SCHEDULE

INSIDE BLAST TO SSPC SP-10 "NEAR WHITE FINISH"  
 2-3 COATS THEVEEC SERIES 20 POLY-POX  
 MINIMUM TOTAL DRY FILM THICKNESS 10 MILS  
 OUTSIDE BLAST TO SSPC SP-6 "COMMERCIAL FINISH"  
 1 COAT THEVEEC SERIES 91120 HYDROZINC  
 1-2 COATS THEVEEC SERIES 20 POLY-POX  
 1 COAT THEVEEC SERIES 10750 ENDURASIELD  
 MINIMUM TOTAL DRY FILM THICKNESS 8 MILS  
 FINISH COLOR TO BE CHOSEN BY OWNER  
 FLOOR UNDERSIDES ROLLED WITH ONE COAT OF COA. TAR EPOXY

### MATERIAL SCHEDULE

ROOF 1/4" A36  
 SHELL 1/4" A36  
 FLOOR 1/4" A36




SHIPPING DIMENSIONS

REV	DATE	DESCRIPTION
1	10/10/18	ISSUED FOR COMMENT
2	11/5/18	ISSUED FOR CONSTRUCTION




  


15'0" x 24' TALL / 30,000 GALLON CAPACITY	NOT TO SCALE
BUILDING STEEL PRODUCTS, INC.	DRYING STG
P.O. BOX 569 EAST 1-20	10/10/18
CLYDE, TEXAS 79510 (325)893-5806	APP'D [Signature]

\* ALL PIPING FLANGES ARE A105, 150#, RF&O UNO ALL FILLET WELDS ON TANK OPENINGS AND ATTACHMENTS ARE COMPLETE SEA WELDS



### LADDER DETAILS



		BUILDING STEEL PRODUCTS, INC P O BOX 569 EAST I-20 CIVIL, TEXAS 79510 (375)993-5606	NOT TO SCALE
DIMENSIONS DATE	COMMENTS		

# CENTRIFUGAL PUMPS

# B SERIES



Pump Size: 1-1/2 x 2 x 6 L

Model: B1-1/2T\_L

Curve No. 5035

Type	CCMD	FM CPLG	FM BELT	SAE	Hydraulic	AC Engine
Model	B1-1/2TPL	B1-1/2TRLS	B1-1/2TRLS			

Nominal RPM: 3450  
Based on Fresh Water@ 68 deg. F.  
Maximum Working Pressure: 266 PSI








# CENTRIFUGAL PUMPS

# B SERIES

## Motor Drive Dimensions



Note: Options T1A - T4A are rotated 45° from T1 - T4. Consult Factory for dimensions.

### NPT (Threaded) – Single Stage

PUMP MODEL	SHAFT SEAL	RPM/ PHASE	FRAME GROUP*	SUCTION	DISCHARGE	X	Y	MP	LP	Z	T1	T2	T3	T4	D1†	CP (MAX)
B1WP	Packing	3600/1	C-1	1 1/2	1	5.00	2.50	4.19	5.44	4.12	4.94	4.94	5.00	5.06	5.25	23.30
		3600/3	C-1	1 1/2	1	5.00	2.50	4.19	6.69	4.12	4.94	4.94	5.00	5.06	5.25	25.05
B1WPS	Mechanical	3600/1	C-1	1 1/2	1	5.00	2.50	4.19	2.38	4.12	4.94	4.94	5.00	5.06		20.74
		3600/3	C-1	1 1/2	1	5.00	2.50	4.19	2.38	4.12	4.94	4.94	5.00	5.06		19.23
B1-1/2TPL	Packing	3600/1	C-1	2	1-1/2	5.38	2.69	4.25	5.56	3.81	4.25	4.06	5.38	5.25		22.65
		3600/3	C-1	2	1-1/2	5.38	2.69	4.25	5.56	3.81	4.25	4.06	5.38	5.25		21.47
B1-1/2TPLS	Mechanical	3600/1	C-1	2	1-1/2	5.38	2.69	4.25	2.50	3.81	4.25	4.06	5.38	5.25		19.59
		3600/3	C-1	2	1-1/2	5.38	2.69	4.25	2.50	3.81	4.25	4.06	5.38	5.25		17.98
B1-1/2TPM	Packing	3600/1	C-1	2	1-1/2	5.38	2.69	4.25	5.56	3.81	4.25	4.06	5.38	5.25		26.48
						5.38	2.69	4.25	5.56	3.81	4.25	4.06	5.38	5.25		25.48
		3600/3	C-1	2	1-1/2	5.38	2.69	4.25	5.56	3.81	4.25	4.06	5.38	5.25		23.87
B1-1/2TPMS	Mechanical	3600/1	C-1	2	1-1/2	5.38	2.69	4.25	2.50	3.81	4.25	4.06	5.38	5.25		22.42
		3600/3	C-1	2	1-1/2	5.38	2.69	4.25	2.50	3.81	4.25	4.06	5.38	5.25		20.81
B1-1/2ZPL	Packing	3600/1	C-1	2	1-1/2	5.38	2.88	4.50	6.69	5.06	5.06	5.94	5.38	6.25	5.25	26.66
		3600/3	C-1	2	1-1/2	5.38	2.88	4.50	6.44	5.06	5.06	5.94	5.38	6.25	5.25	25.50
B1-1/2ZPLS	Mechanical	3600/1	C-1	2	1-1/2	5.38	2.88	4.50	2.38	5.06	5.06	5.94	5.38	6.25		22.55
		3600/3	C-1	2	1-1/2	5.38	2.88	4.50	2.38	5.06	5.06	5.94	5.38	6.25		22.44
B1-1/2ZPH	Packing		C-2	2	2-1/2	5.38	2.88	4.50	3.75	5.06	5.06	5.94	5.38	6.25		25.42
			C-1	2	1-1/2	5.38	2.88	4.50	6.69	5.06	5.06	5.94	5.38	6.25		26.75
		3600/3	C-2	2	1-1/2	5.38	2.88	4.50	2.38	5.06	5.06	5.94	5.38	6.25		30.11
B1-1/2ZPHS	Mechanical	3600/3	C-1	2	1-1/2	5.38	2.88	4.50	2.38	5.06	5.06	5.94	5.38	6.25		22.44
			C-2	2	1-1/2	5.38	2.88	4.50	3.75	5.06	5.06	5.94	5.38	6.25		27.17
		1800/1	C-1	2	1-1/2	5.38	2.88	4.50	2.38	5.06	5.06	5.94	5.38	6.25		20.22
B1-1/2EPL	Packing	1801/3	C-1	2	1-1/2	5.38	2.88	4.50	2.38	5.06	5.06	5.94	5.38	6.25		18.11
		3600/3	C-2	2	1-1/2	6.50	2.63	4.19	6.25	6.69	6.19	6.63	6.50	6.94		29.36
B1-1/2EPLS	Mechanical	3600/3	C-2	2	1-1/2	6.50	2.63	4.19	3.36	6.69	6.19	6.63	6.50	6.94		26.49

### NPT (Threaded) – Two Stage


PUMP MODEL	SHAFT SEAL	RPM/ PHASE	FRAME GROUP*	SUCTION	DISCHARGE	X	Y	MP	LP	Z	T1	T2	T3	T4	D1†	CP (MAX)
B1-1/2WP2S	Mechanical	3600/1	C-1	2	1-1/2	NA	1.78	6.13	3.69	7.44	NA	NA	NA	NA		23.50
						NA	1.78	6.13	3.69	7.44	NA	NA	NA	NA		24.63
		3600/3	C-1	2	1-1/2	NA	1.78	6.13	3.69	7.44	NA	NA	NA	NA		21.94
						NA	1.78	6.13	3.69	7.44	NA	NA	NA	NA		23.78
						NA	1.78	6.13	3.69	7.44	NA	NA	NA	NA		23.76

\* See Motor Frame Size Chart.

† If Dimension "D1" is not referenced, no drain connection is available.

TECHNICAL BROCHURE

B50-320L R7



---

50L, 65L, 95L, 120L,  
160L, 250L, 320L

6" Stainless Steel Submersible Pumps

60 HZ HIGH CAPACITY - FOR 6" AND LARGER WELLS

---

 **GOULDS**

a xylem brand

---

**Model 50L**  
RPM 3450  
60 Hz

**RECOMMENDED RANGE**  
17 - 70 GPM

**EFFICIENCY**

**50L20**  
**50L15**  
**50L10**  
**50L07**  
**50L05**  
**50L05R**  
**50L03**

**TOTAL DYNAMIC HEAD**

**FEET**

**METERS**

**GPM**

**m<sup>3</sup>/hr**

**CAPACITY**

**EFFICIENCY %**

**Model 65L**  
RPM 3450  
60 Hz

**RECOMMENDED RANGE**  
20 - 90 GPM

**EFFICIENCY**

**65L40**  
**65L30**  
**65L25**  
**65L20**  
**65L15**  
**65L10**  
**65L07**  
**65L05**  
**65L03**

**TOTAL DYNAMIC HEAD**  
METERS FEET

**EFFICIENCY - %**

**CAPACITY**  
GPM m<sup>3</sup>/hr



## Residential Water Systems

### FEATURES

**Powered for Continuous Operation:** All ratings are within the working limits of the motor. Pump can be operated continuously.

**New Design Features:** Cast 304 SS discharge head and motor adapter.

**Field Serviceable:** Easy to install and service. All parts easily dismantled if field service is ever necessary.

**Diverse Application:** Designed for commercial, municipal and agricultural water needs.

**Stainless Steel Construction:** Durable in most waters.

**Bearings:** Replaceable, silicon carbide bearings allow excellent abrasives handling and wear resistance.

**Built-in Check Valve:** Positive sealing, stainless steel check valve assembly incorporated into discharge head.

**Impellers:** New stainless steel impeller design provides improved efficiency.

**Maximum Temperature:** 140°F (60°C) for pump.

**Four-Fluted Shaft Design:** Four sided stainless steel shaft eliminates impeller keys and provides positive drive.

**Coupling:** Removable heavy duty stainless steel, splined coupling for maximum load-carrying capability.

**Suction Strainer:** Stainless steel strainer restricts gravel and other debris from entering the pump.

**Cable Guard:** Stainless steel cable guard surrounds and protects motor leads.

**Fasteners:** All fasteners are stainless steel.

**CentriPro Motors:** Designed to NEMA standards. Stainless steel casing resists corrosion. Water filled design provides a constant supply of lubrication. Hermetically sealed stator assures moisture free windings. Durable Kingsbury type thrust bearing absorbs all thrust. Replaceable motor lead assembly.

**Certified to NSF/ANSI 61, Annex G.**

### SPECIFICATIONS

Model	Horsepower Range	Discharge Connection	Recommended GPM Operating Range	GPM at Best Efficiency	Minimum* Well Size	Rotation at Discharge End
50L	3 - 20	3" NPT	17 - 70	50	6" / 8" *	CCW
65L	3 - 40		20 - 90	65		
95L	5 - 40		25 - 130	90		
120L	5 - 50		40 - 170	120		
160L	3 - 60		50 - 240	160		
250L	7.5 - 60	4" NPT	70 - 300	250	6"	
320L	7.5 - 60		100 - 400	320		

\* Minimum well size refers only to dimensional fit in a well; the specifier or installer must determine the minimum required well diameter that will insure an adequate supply of water to the pump and also properly cool the motor. See Water End Data Chart for specific diameter by model number.

### AGENCY LISTINGS



NSF/ANSI 372 - Drinking Water System Components - Lead Content

CLASS 6853 01 - Low Lead Content Certification Program - Plumbing Products



Pump/Water End - Drinking Water System Components - Certified to NSF/ANSI 61, Annex G



## Residential Water Systems

### MOTOR DATA

**NOTE:** 4" diameter motors are required for 3 and 5 HP "L" Series pumps.  
4" or 6" diameter motors can be used for 7.5 HP "L" Series pumps. See Water End Data Chart.  
6" diameter motors are required for 10 HP and larger "L" Series pumps.

### CENTRIPRO 4" MOTORS


Single Phase Motors - Dimensions and Weights					
Motor Order No.	HP	Motor Dia.	Volts	Length in. (mm)	Weight lbs. (Kg)
M30412	3	4"	230	18.3 (466)	40 (18.1)
M50412	5			27.7 (703)	70 (31.8)
Three Phase Motors - Dimensions and Weights					
M30430	3	4"	200	15.3 (389)	32 (14.5)
M30432			230		
M30434			460		
M50430	5	4"	200	21.7 (550)	55 (24.9)
M50432			230		
M50434			460		
M75430	7.5	4"	200	27.7 (703)	70 (31.8)
M75432			230		
M75434			460		

### CENTRIPRO 6" MOTORS

Single Phase Motors - Dimensions and Weights					
Motor Order No.	HP	Motor Dia.	Volts	Length (inches)	Weight (lbs)
6M071	7.5	6"	230	29.9	128
6M101	10	6"	230		
6M151	15	6"	230	33.5	148
Three Phase Motors - Dimensions and Weights					
6M078	7.5	6"	200	24.8	99
6M072			230		
6M074			460		
6M108	10	6"	200	27.0	110
6M102			230		
6M104			460		
6M158	15	6"	200	29.9	128
6M152			230		
6M154			460		
6M208	20	6"	200	31.5	137
6M202			230		
6M204			460		
6M258	25	6"	200	36.2	161
6M252			230		
6M254			460		
6M308	30	6"	200	38.2	176
6M302			230		
6M304			460		
6M404	40	6" x 8"	460	40.6	187
6M504	50		460	41.7	198
86M504	50		460	46.4	353

### CENTRIPRO FM-SERIES 6" MOTORS

Single Phase Motors Dimensions and Weights					
Motor Order No.	HP	Motor Dia.	Volts	Length (inches)	Weight (lbs)
6F051	5	6"	230	25.6	143
6F071	7.5			28.1	161
6F101	10			30.3	161
6F151	15			32.8	181
Three Phase Motors Dimensions and Weights					
Motor Order No.	HP	Motor Dia.	Volts	Length (inches)	Weight (lbs)
6F058	5	6"	200-208	23.0	107.0
6F052			230		
6F054			460		
6F078	7.5	6"	200-208	24.3	117.0
6F072			230		
6F074			460		
6F108	10	6"	200-208	25.6	124.0
6F102			230		
6F104			460		
6F158	15	6"	200-208	28.1	127.0
6F152			230		
6F154			460		
6F208	20	6"	200-208	30.3	152.0
6F202			230		
6F204			460		
6F258	25	6"	200-208	32.8	164.0
6F252			230		
6F254			460		
6F308	30	6"	200-208	35.6	185.0
6F302			230		
6F304			460		
6F404	40	6"	460	39.3	207.0
6F504	50		460	54.1	285.0



# Goulds Water Technology

## Residential Water Systems

### WATER END (PUMP) DATA

Model	Order No.	No. Stages	Min. HP Required	Required Motor Dia.	Dimensions & Weights					
					Length		Diameter		Weight	
					in.	mm	in.	mm	lbs.	kg.
50L →	50L03	4	3	4	20.6	522	5.59	142	25	11
	50L05**	7	5	4/6	25.8	656	5.67	144	35	16
	50L05**	8	5		27.8	706			40	18
	50L07**	11	7.5		33.3	844			49	22
	50L10	15	10	6	40.2	1020			57	26
	50L15	23	15		56.9	1446			62	37
65L	65L20	28	20		65.8	1670			94	43
	65L03	3	3	4	18.6	472	5.59	142	26	12
	65L05**	5	5	4/6	22.2	564	5.67	144	31	14
	65L07**	7	7.5		25.8	656			35	16
	65L10	10	10		31.3	794			44	20
	65L15	16	15	6	42.7	1070			60	27
	65L20	27	20		53.0	1346			75	34
	65L25	27	25		63.9	1622			90	41
95L	95L30*	32	30		98.7	2508	6.97*	177	220	100
	95L40*	47	40		115.0	2922			253	115
	95L05**	3	5	4/6	18.6	472	5.59	142	26	12
	95L07**	5	7.5		22.2	564	5.67	144	31	14
	95L10	7	10		25.8	656			35	16
	95L15	10	15	6	31.3	794			44	20
	95L20	14	20		38.5	978			53	24
	95L25	17	25		43.9	1116			62	28
120L	120L30	27	30		53.0	1346			75	34
	120L40*	28	40		67.3	1710	6.97*	177	156	71
	120L05**	2	5	4/6	16.8	426	5.59	142	22	10
	120L07**	3	7.5		19.5	495	5.67	144	26	12
	120L10	5	10		24.9	633			33	15
	120L15	7	15	6	30.4	771			40	18
	120L20	10	20		38.5	978			51	23
	120L25	12	25		43.9	1116			57	26
160L	160L30	15	30		52.1	1323			68	31
	160L40	20	40		65.7	1668			86	39
	160L50*	24	50		80.9	2055	6.97*	177	179	81
	160L03	1	3	4	14.5	367	5.59	142	18	8
	160L05**	2	5	4/6	17.2	436	5.67	144	22	10
	160L07**	3	7.5		19.9	505			26	12
	160L10	4	10		22.6	574			31	14
	160L15	6	15	6	28.0	712			37	17
	160L20	8	20		33.5	850			44	20
250L	250L25	9	25		36.2	919			46	21
	250L30	11	30		41.6	1057			53	24
	250L40	15	40		52.5	1333			68	31
	250L50	18	50		60.6	1540			77	35
	250L60	20	60		65.7	1668			86	39
	250L07**	2	7.5	4/6	20.8	528	5.67	144	26	12
	250L10	3	10	6	25.3	643			33	15
	250L15	5	15		34.4	873			44	20
	250L20	7	20		43.4	1103			55	25
	250L25	8	25		48.0	1218			60	27
	250L30	9	30		52.5	1333			66	30
320L	320L40	13	40	6	70.6	1793			88	40
	320L50	16	50		84.2	2138			104	47
	320L60	19	60		97.8	2484			128	58
	320L07**	2	7.5	4/6	21.8	553	5.67	144	27	12
	320L15	4	15	6	30.8	783			38	17
	320L20	5	20		35.4	898			45	20
	320L25	6	25		39.9	1013			50	22
	320L30	8	30		49.0	1243			61	27
	320L40	11	40		62.5	1588			78	35
	320L50	13	50		71.6	1818			89	40
	320L60	16	60		84.2	2138			104	47

\* Note pump diameter - high pressure models have an exterior casing and larger diameters; verify they will fit your well.

\*\* Pumps can be configured to accommodate a 4 pole motor. See product order code.









JUL 23 '90 TUE 10:00

**SPEEDAIRE**

## OPERATING INSTRUCTIONS &amp; PARTS MANUAL

## COMPRESSOR PUMPS

MODELS 2Z498B, 4B244 AND 4B245

FORM 5S1185

02433

0395/039/039VP

READ CAREFULLY BEFORE ATTEMPTING TO ASSEMBLE, INSTALL, OPERATE OR MAINTAIN THE PRODUCT DESCRIBED. PROTECT YOURSELF AND OTHERS BY OBSERVING ALL SAFETY INFORMATION. FAILURE TO COMPLY WITH INSTRUCTIONS COULD RESULT IN PERSONAL INJURY AND/OR PROPERTY DAMAGE! RETAIN INSTRUCTIONS FOR FUTURE REFERENCE.

*Description*

Speedaire compressor pumps are equipped with a solid cast iron cylinder and crankcase, an aluminum head and Swedish steel valves. Models 4B244 and 4B245 also include ball bearings, felt filter element and oil level dipstick.

*Unpacking*

When unpacking, inspect carefully for any damage that may have occurred during transit. Make sure any loose fittings, bolts, etc., are tightened before putting unit into service.

*General Safety Information*

Since the air compressor and other components (material pump, spray guns, filters, lubricators, hoses, etc.) used, make up a high pressure pumping system, the following safety precautions must be observed at all times:

1. Read all manuals included with this product carefully. Be thoroughly familiar with the controls and the proper use of the equipment.
2. Only persons well acquainted with these rules of safe operation should be allowed to use the compressor.

**▲ DANGER ▲***Breathable Air Warning*

This compressor/pump is not equipped and should not be used "as is" to supply breathing quality air. For any application of air for human consumption, the air compressor/pump will need to be fitted with suitable in-line safety and alarm equipment. This additional equipment is necessary to properly filter and purify the air to meet specifications for Grade D breathing as described in Compressed Gas Association Commodity Specification G 7.1 -1955, OSHA 29 CFR 1910.134, and/or Canadian Standards Association (CSA).

**DISCLAIMER OF WARRANTIES**

In the event the compressor is used for the purpose of breathing air application and proper in-line safety and alarm equipment is not simultaneously used, existing warranties shall be voided, and Dayton Electric Mfg. Co. disclaims any liability whatsoever for any loss, personal injury or damage.

*Specifications and Dimensions*

MODEL	BORE & STROKE	DISCHARGE PIPE SIZE	CYL	WEIGHT	MAX PSI	H	W	D	MOUNTING HOLES CENTER TO CENTER
2Z498B	2 1/4" 1 1/2"	3/8"	1	21	125	9 1/2"	8 1/4"	5 1/4"	5 1/2" x 3 1/4"
4B244	2 1/4" 1 1/2"	3/8"	2	32	125	10 1/2"	6 3/4"	11"	5 7/8" x 5 1/2"
4B245	2 1/4" 2"	3/8"	2	33	125	10 1/2"	7 1/2"	11 1/2"	6 1/8" x 5 1/2"

*Performance*

MODEL	AT RUNNING MOTOR HP	PUMP RPM	OD OF 3450 RPM MOTOR SHEAVE, IN	MAXIMUM PSI	DISPLACEMENT CFM	FREE AIR CFM @ PSI
2Z498B	1/3	530	2.63	125	2.7	1.9 1.6
	1/2	640	3.25	125	3.3	2.4 2.0
	3/4	715	3.63	125	3.7	2.7 2.3
4B244	1	620	2.00	100	6.4	4.8 3.7
	1 1/2	800	2.50	100	8.2	6.8 5.6
	2	955	2.95	125	9.6	8.1 6.6
4B245	3	955	2.95	125	13.1	10.5 9.2
	4	1030	3.15	125	14.1	11.2 9.6