



Filing Receipt

Received - 2022-01-21 01:34:12 PM

Control Number - 51923

ItemNumber - 25

DOCKET NO 51923

APPLICATION OF QUADVEST, L.P. TO § PUBLIC UTILITY COMMISSION
AMEND ITS CERTIFICATE OF §
CONVEINIENCE AND NECEISSTY IN § OF TEXAS
MONTGOMERY COUNTY

Enclosed is the TCEQ approval for construction of underground.

Yvette McNellie

Yvette McNellie
Quadvest, L.P.
26926 FM 2978
Magnolia, TX 77354
Telephone: 281-305-1124
Fax: 281-356-5382
yvette@quadvest.com

61923

Jon Niermann, *Chairman*
Emily Lindley, *Commissioner*
Bobby Janecka, *Commissioner*
Toby Baker, *Executive Director*



PWS_1700922_CO_20220103_Plan Ltr

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Protecting Texas by Reducing and Preventing Pollution

January 3, 2022

Ms. Amanda Edmondson, P.E.
Pape-Dawson Engineers, Inc.
10350 Richmond Avenue, Suite 200
Houston, TX 77042

Re: Decker Farms Water Plant - Public Water System ID No. 1700922
Proposed Distribution System - Decker Farms Section 1
Engineer Contact Telephone: (713) 428-2400
Plan Review Log No. P-11032021-022
Montgomery County, Texas

CN602944746; RN111285185

Dear Ms. Edmondson:

On November 3, 2021, the Texas Commission on Environmental Quality (TCEQ) received planning material with your letter dated October 18, 2021 for the proposed distribution system - Decker Farms Section 1. Based on our review of the information submitted, the project generally meets the minimum requirements of Title 30 Texas Administrative Code (TAC) Chapter 290 - Rules and Regulations for Public Water Systems and is **approved for construction**.

The submittal consisted of 41 sheets of engineering drawings and technical specifications. The approved project consists of:

- Approximately 312 linear feet (lf) of 4-inch, American Society for Testing and Materials (ASTM) Standard D2241, Class 160, standard dimension ratio (SDR) 26, polyvinyl chloride (PVC) pipe;
- Approximately 835 lf of 6-inch, ASTM Standard D2241, Class 160, SDR 26, PVC pipe;
- Approximately 4,773 lf of 8-inch, ASTM Standard D2241, Class 160, SDR 26, PVC pipe; and,
- Various valves, fittings, and appurtenances.


This approval is for the construction of the above listed items only. Any wastewater components contained in this design were not considered.

Ms. Amanda Edmondson, P.E.
Page 3
January 3, 2022

If you have any questions concerning this letter or need further assistance, please contact Ms. Fatima Selami at (512) 239-5259 or by email at Fatima.Selami@tceq.texas.gov. If you are unable to contact Ms. Selami, please contact another member of the Plan Review Team at (512) 239-4691 or by correspondence at the following:

Plan Review Team, MC-159
Texas Commission on Environmental Quality
P.O. Box 13087
Austin, Texas 78711-3087

Sincerely,



David H. Yager, P.E.
Plan Review Team
Plan and Technical Review Section
Water Supply Division
Texas Commission on Environmental Quality



Vera Poc, P.E., Team Leader
Plan Review Team
Plan and Technical Review Section
Water Supply Division
Texas Commission on Environmental Quality

VP/DHY/fs/av

cc: Decker Farms Water Plant, Attn: Mr. Simon O. Sequeria, 26926 Farm to Market 2978
Road, Magnolia, TX 77354-5148