



Filing Receipt

Received - 2021-11-01 09:51:58 AM
Control Number - 52299
ItemNumber - 887



MAYOR
DAVID PLYLER
DEPUTY MAYOR
DARON HOLLAND

CITY COUNCIL
WILLIE STEELE
PAMELA L. HOWETH
SANDRA MELTON

JOSH STEVENSON
SHAWN C. TEAMANN
CITY MANAGER
ROBBY HEFTON

November 1st, 2021

Project 52299
Senate Bill 3, 87th Legislature, Regular Session
Compliance Guidance – Texas Water Code (TWC) 13.1396

City of Sherman (Affected Utility)

Per Project 52299 requirements, please accept this as our formal filing of the critical load facilities we submitted to Oncor and GCEC for approval. Attached is a copy of the Critical Load Application. The City of Sherman operates a Water Treatment Plant, a Wastewater Treatment Plant and multiple pump stations, ground water wells, sewer lift stations. See attached spreadsheet for locations and details about each critical load facility.

City of Sherman Water System (CCN #10203)
City of Sherman Sewer System (CCN #20076)

Affiliates:
City of Howe (Sewer Treatment Only)
City of Knollwood (Water and Sewer Treatment)

Emergency Contacts for each City Department with Critical Load Facilities:

Water Treatment Plant:
Jim Cross Water Systems Manager JimCross@cityofsherman.com O: 903-892-7258 C: 903-870-6445
Oscar Canales Maintenance Sup oscarc@cityofsherman.com O: 903-892-7312 C: 903-436-4104

Sewer Treatment Plant:
Nathan Whiddon WW Manager nathanw@cityofsherman.com O: 903-892-7286 C: 903-357-0842
Jeff Rigdon WW Super jeffr@cityofsherman.com O: 903-892-2846 C: 903-375-2142

Emergency Management Coordinator:
Moises Duran moisesd@cityofsherman.com O: 903-892-7363 C: 903-487-6020

City Management:
Robby Hefton City Manager O: 903-892-7200 C: 903-819-7452
Clint Philpott Assistant City Manager O: 903-892-7203 C: 806-317-5961

Please review the submitted information and let me know if you have questions or need additional information.

Clint Philpott
Assistant City Manager
clintp@cityofsherman.com
903-892-7203

Facility Type	Service Street Address	Application Type	SHERMAN	Emergency Cont:	Emergency Contact (Title)	Emergency Contact (Phone)	Emergency Contact	Emergency Contact (Email)
Water/Wastewater Treatment Plant	243 LA CIMA RD	Annual Renewal	SHERMAN	Jim Cross	Water System Manager	(903) 892-7258	(903) 870-6445	jimcross@cityofsherman.com
Fire	1100 S DEWEY AVE	Annual Renewal	SHERMAN	Danny Jones	Fire Chief	903-892-7263	903-357-0020	dannyj@cityofsherman.com
Fire	318 S TRAVIS ST	Annual Renewal	SHERMAN	Danny Jones	Fire Chief	903-892-7263	903-357-0020	dannyj@cityofsherman.com
Fire	3200 N FM 1417	Annual Renewal	SHERMAN	Danny Jones	Fire Chief	903-892-7263	903-357-0020	dannyj@cityofsherman.com
Water/Wastewater Treatment Plant	1800 E FM 1417	Annual Renewal	SHERMAN	Jeff Rigdon	Wastewater Plant Supervisor	(903)868-2846	(903)375-2142	jeffr@cityofsherman.com
Pump Station	12457 FM 902	Annual Renewal	SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com
Fire	3704 N FRISCO RD	Annual Renewal	SHERMAN	Danny Jones	Fire Chief	903-892-7263	903-357-0020	dannyj@cityofsherman.com
Fire	3117 NORTHGATE DRIVE	New Critical Load Application	SHERMAN	Danny Jones	Fire Chief	903-892-7263	903-357-0020	dannyj@cityofsherman.com
Water/Wastewater Treatment Plant	243 LA CIMA RD	New Critical Load Application	SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com
Major Lift Station	600 E MULBERRY	New Critical Load Application	SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com
Pump Station	8700 FARMINGTON RD	New Critical Load Application	SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com
Pump Station	3025 FM 902	New Critical Load Application	SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com
Pump Station	1900 IDA RD	New Critical Load Application	SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com
Pump Station	4524 LUELLA RD	New Critical Load Application	SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com
Pump Station	200 E SHEPARD RD	New Critical Load Application	SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com
Pump Station	1319 E SHEPARD RD	New Critical Load Application	SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com
Pump Station	4500 S US HWY 75	New Critical Load Application	SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com
Pump Station	5100 HOWE DR	New Critical Load Application	SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com
Pump Station	2720 S HWY 75	New Critical Load Application	SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com
Pump Station	915 W BIRGE ST	New Critical Load Application	SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com
Pump Station	1722 N ROSS AVE	New Critical Load Application	SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com
Pump Station	1413 E KING ST	New Critical Load Application	SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com
Pump Station	300 STEPHENS ST	New Critical Load Application	SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com
Pump Station	3400 E HWY 82	New Critical Load Application	SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com
Pump Station	2200 S HERITAGE PKW	New Critical Load Application	SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com
Water Tower	415 W DUPREE ST	New Critical Load Application	SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com
Water Tower	1416 N HARRISON AVE	New Critical Load Application	SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com
Water Tower	1400 GALLAGHER RD A	New Critical Load Application	SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com
Water Tower	2200 S HERITAGE PKWY	New Critical Load Application	SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com
Water Tower	1401 MARSHALL ST	New Critical Load Application	SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com
Water Tower	3202 REX CRUISE DR	New Critical Load Application	SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com
Water Tower	517 W SHEPARD DR	New Critical Load Application	SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com
Major Lift Station	4709 DRIPPING SPRINGS RD	New Critical Load Application	SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com
Major Lift Station	4001 DRIPPING SPRINGS RD	New Critical Load Application	SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com
Major Lift Station	1708 BURKETT DR	New Critical Load Application	SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com
Major Lift Station	1901 E FALLON DR	New Critical Load Application	SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com
Major Lift Station	4709 DRIPPING SPRINGS RD	New Critical Load Application	SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com
Major Lift Station	3400 E HWY 82	New Critical Load Application	SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com
Major Lift Station	2420 W HOUSTON ST	New Critical Load Application	SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com
Major Lift Station	3175 DRIPPING SPRINGS RD	New Critical Load Application	SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com
Major Lift Station	1009 US HWY 82 EAST	New Critical Load Application	SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com
Major Lift Station	1121 SARA SWAMY DR	New Critical Load Application	SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com
Major Lift Station	2924 FM 691 EAST	New Critical Load Application	SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com
Major Lift Station	1715 FALLON DR	New Critical Load Application	SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com
Major Lift Station	2525 S CROCKETT ST	New Critical Load Application	SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com
Pump Station	Well - C - 2	New Critical Load Application	CITY OF SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com
Pump Station	Well - C - 4	New Critical Load Application	CITY OF SHERMAN	Jim Cross	Water System Manager	903-892-7258	903-870-6445	jimcross@cityofsherman.com

City of Sherman							
Facility Type	Service Street Address	Alternate Contact (Name)	Alternate Contact (Phone)	Alternate Contact (Mobile)	Alternate Contact (Email)	ESI ID (17 Digits)	Service Street Address
Water/Wastewater Treatment Plant	243 LA CIMA RD	Oscar Canales	(903) 892-7258	(903) 436-4104	oscarc@cityofsherman.com	10443720006567847	243 LA CIMA RD
Fire	1100 S DEWEY AVE	Chris Olson	903-892-7396	903-209-8141	chriso@cityofsherman.com	10443720004072316	1100 S DEWEY AVE DEPT FIRE
Fire	318 S TRAVIS ST	Chris Olson	903-892-7396	903-209-8141	chriso@cityofsherman.com	10443720003771740	318 S TRAVIS ST DEPT FIRE
Fire	3200 N FM 1417	Chris Olson	903-892-7396	903-209-8141	chriso@cityofsherman.com	10443720008655046	3200 N FM 1417 DEPT FIRE
Water/Wastewater Treatment Plant	1800 E FM 1417	Nathan Whiddon	(903)357-0842	(903)647-8527	nathanw@cityofsherman.com	10443720004109764	1800 E FM 1417
Pump Station	12457 FM 902	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	10443720004168323	12457 FM 902
Fire	3704 N FRISCO RD	Chris Olson	903-892-7396	903-209-8141	chriso@cityofsherman.com	10443720003911147	3704 N FRISCO RD DEPT FIRE
Fire	3117 NORTHGATE DRIVE	Chris Olson	903-892-7396	903-209-8141	chriso@cityofsherman.com		3117 NORTHGATE DRIVE DEPT FIRE
Water/Wastewater Treatment Plant	243 LA CIMA RD	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	10443720000703252	243 LA CIMA RD
Major Lift Station	600 E MULBERRY	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	10443720003712158	600 E MULBERRY
Pump Station	8700 FARMINGTON RD	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	10443720004169997	8700 FARMINGTON RD
Pump Station	3025 FM 902	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	10443720004169966	3025 FM 902
Pump Station	1900 IDA RD	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	10443720004082546	1900 IDA RD
Pump Station	4524 LUELLA RD	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	10443720004108152	4524 LUELLA RD
Pump Station	200 E SHEPARD RD	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	10443720003745793	200 E SHEPARD RD
Pump Station	1319 E SHEPARD RD	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	10443720003745514	1319 E SHEPARD RD
Pump Station	4500 S US HWY 75	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	10443720003745297	4500 S US HWY 75
Pump Station	5100 HOWE DR	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	10443720003745049	5100 HOWE DR
Pump Station	2720 S HWY 75	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	10443720003744491	2720 S HWY 75
Pump Station	915 W BIRGE ST	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	10443720003644206	915 W BIRGE ST UNIT POLE
Pump Station	1722 N ROSS AVE	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	10443720003731874	1722 N ROSS AVE
Pump Station	1413 E KING ST	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	10443720008673615	1413 E KING ST
Pump Station	300 STEPHENS ST	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	10443720003858044	300 STEPHENS ST
Pump Station	3400 E HWY 82	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	10443720003857052	3400 E HWY 82 UNIT MAIN
Pump Station	2200 S HERITAGE PKW	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	10443720007403614	2200 S HERITAGE PKWY UNIT TRAN
Water Tower	415 W DUPREE ST	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	10443720003882193	415 W DUPREE ST
Water Tower	1416 N HARRISON AVE	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	10443720006565491	1416 N HARRISON AVE
Water Tower	1400 GALLAGHER RD A	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	10443720006728416	1400 GALLAGHER RD A
Water Tower	2200 S HERITAGE PKWY	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	10443720007355898	2200 S HERITAGE PKWY
Water Tower	1401 MARSHALL ST	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	10443720007616701	1401 MARSHALL ST
Water Tower	3202 REX CRUISE DR	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	10443720006536072	3202 REX CRUISE DR
Water Tower	517 W SHEPARD DR	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	10443720007258527	517 W SHEPARD DR
Major Lift Station	4709 DRIPPING SPRINGS RD	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	10443720003849922	4709 DRIPPING SPRINGS RD SEWER LIFT
Major Lift Station	4001 DRIPPING SPRINGS RD	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	10443720009417460	4001 DRIPPING SPRINGS RD
Major Lift Station	1708 BURKETT DR	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	10443720009603367	1708 BURKETT DR
Major Lift Station	1901 E FALLON DR	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	10443720009270830	1901 E FALLON DR
Major Lift Station	4709 DRIPPING SPRINGS RD	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	10443720008872697	4709 DRIPPING SPRINGS RD SEWER LIFT
Major Lift Station	3400 E HWY 82	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	10443720003857083	3400 E HWY 82
Major Lift Station	2420 W HOUSTON ST	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	10443720003992026	2420 W HOUSTON ST
Major Lift Station	3175 DRIPPING SPRINGS RD	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	10443720008411851	3175 DRIPPING SPRINGS RD
Major Lift Station	1009 US HWY 82 EAST	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	10443720004011432	1009 US HWY 82 EAST
Major Lift Station	1121 SARA SWAMY DR	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	10443720009631856	1121 SARA SWAMY DR
Major Lift Station	2924 FM 691 EAST	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	10443720008890312	2924 FM 691 EAST SEWER LIFT
Major Lift Station	1715 FALLON DR	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	10443720008694175	1715 FALLON DR SEWER
Major Lift Station	2525 S CROCKETT ST	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	10443720004111407	2525 S CROCKETT ST
Pump Station	Well - C - 2	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	91981662	Well - C - 2
Pump Station	Well - C - 4	Oscar Canales	903-892-7258	903-436-4104	oscarc@cityofsherman.com	6770133	Well - C - 4

Facility Type	Service Street Address	Service City	Service Zip Code	Mailing Address	Mailing Zip (Details t	Backup Equipmen	Generati				Battery Backup Capacity (kW)	on Backup Capacity (kW)	Length of Time facility can operate without power	Start-up time needed following a power outage
						t (Yes or No)	Battery Backup	Utility	Owner of Tra					
Water/Wastewater Tr	243 LA CIMA RD	SHERMAN	75092-6609	PO Box 1106	75091	Critical Ir No	No	No	Yes	Customer	N/A	No	Zero Hours	2 hours
Fire	1100 S DEWEY AVE	SHERMAN	75090-8335	1100 S DEWEY AVE DEPT	75090	Critical Ir No	No	No	No		N/A			
Fire	318 S TRAVIS ST	SHERMAN	75090-7147	318 S TRAVIS ST DEPT FIR	75090	Critical Ir No	No	Yes	No		N/A	50	12 hours	7 to 10 seconds
Fire	3200 N FM 1417	SHERMAN	75092-3429	3200 N FM 1417 DEPT FIF	75092	Critical Ir No	No	No	No		N/A			
Water/Wastewater Tr	1800 E FM 1417	SHERMAN	75090-0000	PO Box 1106	75090	Critical Ir No	No	No	Yes	Customer	N/A	No	Less than one hour	30 Minutes
Pump Station	12457 FM 902	DORCHESTER	75459-2015	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Zero Hours	30 Minutes
Fire	3704 N FRISCO RD	SHERMAN	75090-1945	3704 N FRISCO RD DEPT F	75090	Critical Ir No	No	No	No		N/A			
Fire	3117 NORTHGATE DRIVE	SHERMAN	75092-3429	3117 NORTHGATE DRIVE	75092	Critical Ir No	No	Yes	No		N/A	250	12 hours	5 to 10 seconds
Water/Wastewater Tr	243 LA CIMA RD	SHERMAN	75092-6609	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Zero Hours	2 Hours
Major Lift Station	600 E MULBERRY	SHERMAN	75090-6041	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Zero Hours	30 Minutes
Pump Station	8700 FARMINGTON RD	HOWE	75092	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Zero Hours	30 Minutes
Pump Station	3025 FM 902	DORCHESTER	75459	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Zero Hours	30 Minutes
Pump Station	1900 IDA RD	SHERMAN	75090	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Zero Hours	30 Minutes
Pump Station	4524 LUELLA RD	SHERMAN	75090-5284	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Zero Hours	30 Minutes
Pump Station	200 E SHEPARD RD	SHERMAN	75090	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Zero Hours	30 Minutes
Pump Station	1319 E SHEPARD RD	SHERMAN	75090	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Zero Hours	30 Minutes
Pump Station	4500 S US HWY 75	SHERMAN	75092	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Zero Hours	30 Minutes
Pump Station	5100 HOWE DR	SHERMAN	75092-8030	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Zero Hours	30 Minutes
Pump Station	2720 S HWY 75	SHERMAN	75090-9393	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Zero Hours	30 Minutes
Pump Station	915 W BIRGE ST	SHERMAN	75092-5101	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Zero Hours	30 Minutes
Pump Station	1722 N ROSS AVE	SHERMAN	75090-4060	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Zero Hours	30 Minutes
Pump Station	1413 E KING ST	SHERMAN	75090-6731	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Zero Hours	30 Minutes
Pump Station	300 STEPHENS ST	SHERMAN	75090-7171	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Zero Hours	30 Minutes
Pump Station	3400 E HWY 82	SHERMAN	75090	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Zero Hours	30 Minutes
Pump Station	2200 S HERITAGE PKW	SHERMAN	75090	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Zero Hours	30 Minutes
Water Tower	415 W DUPREE ST	SHERMAN	75092-2729	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Zero Hours	Immediate
Water Tower	1416 N HARRISON AVE	SHERMAN	75090-4124	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Zero Hours	Immediate
Water Tower	1400 GALLAGHER RD A	SHERMAN	75090-0000	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Zero Hours	Immediate
Water Tower	2200 S HERITAGE PKWY	SHERMAN	75092	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Zero Hours	Immediate
Water Tower	1401 MARSHALL ST	SHERMAN	75090	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Zero Hours	Immediate
Water Tower	3202 REX CRUISE DR	SHERMAN	75092-3820	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Zero Hours	Immediate
Water Tower	517 W SHEPARD DR	SHERMAN	75092-7071	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Zero Hours	Immediate
Major Lift Station	4709 DRIPPING SPRINGS RD	SHERMAN	75090-4062	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Zero Hours	30 Minutes
Major Lift Station	4001 DRIPPING SPRINGS RD	SHERMAN	75090-4310	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Zero Hours	30 Minutes
Major Lift Station	1708 BURKETT DR	SHERMAN	75092-6609	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Zero Hours	30 Minutes
Major Lift Station	1901 E FALLON DR	SHERMAN	75090	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Zero Hours	30 Minutes
Major Lift Station	4709 DRIPPING SPRINGS RD	SHERMAN	75090-2776	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Zero Hours	30 Minutes
Major Lift Station	3400 E HWY 82	SHERMAN	75090	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Zero Hours	30 Minutes
Major Lift Station	2420 W HOUSTON ST	SHERMAN	75092-7634	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Zero Hours	30 Minutes
Major Lift Station	3175 DRIPPING SPRINGS RD	SHERMAN	75090	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Zero Hours	30 Minutes
Major Lift Station	1009 US HWY 82 EAST	SHERMAN	75090-1705	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Zero Hours	30 Minutes
Major Lift Station	1121 SARA SWAMY DR	SHERMAN	75090-1779	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Zero Hours	30 Minutes
Major Lift Station	2924 FM 691 EAST	SHERMAN	75090	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Zero Hours	30 Minutes
Major Lift Station	1715 FALLON DR	SHERMAN	75090	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Zero Hours	30 Minutes
Major Lift Station	2525 S CROCKETT ST	SHERMAN	75090-8973	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Zero Hours	30 Minutes
Pump Station	Well - C - 2	HOWE	75459	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Two Hours	Two Hours
Pump Station	Well - C - 4	HOWE	75459	PO Box 1106	75091	Critical Ir No	No	No	No		N/A	No	Two Hours	Two Hours

UTILI-FACTS

Project 52299 Senate Bill 3, 87th Legislature, Regular Session Compliance Guidance - Texas Water Code (TWC) §13.1396

By **November 1, 2021**, entities that meet the definition of “affected utilities” under TWC §13.1394 must file specific information with the Public Utility Commission of Texas (PUCT) in Project 52299. This information must also be filed with each transmission and distribution service provider, each retail electric provider, and the office of emergency management of each county where the utility has water or sewer facilities that qualify for critical load status.

Q: Am I an “affected utility”?

A: TWC §13.1394 defines an “affected utility” as a retail public utility, exempt utility, or provider or conveyor of potable or raw water service that:

- Furnishes water service to more than one customer; and
- Is not an affected utility under TWC §13.1395 (Fort Bend or Harris Counties).

Q: Who is required to file this information with the PUCT?

A: All entities that meet the definition of an “affected utility” as defined in TWC §13.1394 are required to file this information with the PUCT. Entities located in Fort Bend and Harris Counties are exempt from this requirement as they do not meet the definition of “affected utility” in TWC §13.1394.

Q: What information must be filed to meet this requirement?

A: You must file a letter identifying the name of your water or sewer utility. Please also include the names of any affiliates and assumed names, if any. In addition, include a list of all the public water systems and sewer systems owned by your utility for which you are filing the information.

- Identify the location and provide a written, general description of all water and sewer facilities that qualify for critical load status (may include maps if this would help you identify the location of your facilities); and
- Emergency contact information for the affected utility, including:
 - The name of the person who will serve as a point of contact and the person’s telephone number;

- The person who will serve as an alternative point of contact and the person’s telephone number; and
- The affected utility’s mailing address.

Q: Where must this information be filed?

A: This information must be filed with each of the following:

- 1) the PUCT,
- 2) each electric utility that provides transmission and distribution services to you. Your electric utility is the company that distributes electricity from power generation facilities to homes and businesses in Texas.
- 3) each retail electric provider that sells electric power to you (applies only in competitive areas of ERCOT),
- 4) the office of emergency management of each county in which the utility has water and wastewater facilities that qualify for critical load status, and
- 5) the division of emergency management of the governor by emailing: Texas Division of Emergency Management, soc@tdem.texas.gov (You may call the SOC for alternate filing methods at 512-424-2208).

Please file this information in Central Records, Project 52299. You may request that the information be filed confidentially if you feel that publicly filing facility location and possibly maps will make your water or wastewater utilities more vulnerable. For instructions on the PUCT’s filing requirements and on how to file with the PUCT, please click on the link below. Instructions on how to file confidentially are also located at this link.

<https://www.puc.texas.gov/industry/filings/FilingProceed.aspx>

For instructions on how to file with your electric providers and the office of emergency management of each county in which you have water or wastewater facilities, please contact them directly.

Q: Is there a deadline?

A: **Yes, the deadline to comply with this new requirement is November 1, 2021.**

Q: What if I have additional questions?

A: Please email the PUCT at DUO@puc.texas.gov or call (512)936-7405 if you have additional questions.

The following files are not convertible:

Critical Load Application -
Sherman.xlsx

Please see the ZIP file for this Filing on the PUC Interchange in order to access these files.

Contact centralrecords@puc.texas.gov if you have any questions.