



Filing Receipt

Received - 2023-03-23 10:37:25 AM
Control Number - 52370
ItemNumber - 74

Docket 52370

This is serving as notice that East Houston Utilities had to issue a Boil Water Notice for the Whitewing Subdivision due to intermittent times of low pressure or disinfectant levels caused by the failure of the main well system. We are working hard to procure funds for the replacement of the well pump and will welcome any help that SOAH could provide to EHU and our customers; especially concerning the timing of the rate change hearing.

Thank you,
Hannah Krebs
EHU