



Filing Receipt

Received - 2022-08-08 11:45:09 AM

Control Number - 52440

ItemNumber - 32



WATERENGINEERS, INC.

WATER & WASTEWATER TREATMENT CONSULTANTS

17230 HUFFMEISTER ROAD, SUITE A~CYPRESS, TEXAS 77429-1643

TEL: 281-373-0500 FAX: 281-373-1113

June 29, 2022

Public Utility Commission of Texas
Central Records
1701 N. Congress, Suite 8-100
Austin, TX 78701

Re: APPLICATION OF CRYSTAL SPRINGS WATER COMPANY, INC. TO AMEND ITS
CERTIFICATES OF CONVENIENCE AND NECESSITY IN MONTGOMERY COUNTY
DOCKET NO. 52440

Dear Public Utility Commission of Texas:

Per our recent conversations regarding severance of this Docket between water and the sewer CCNs, please find attached the TCEQ approval of the distribution system for the first phase of the development. The approval for the second phase is imminent.

Please feel free to contact me if you require any additional information or if you have any questions regarding this submittal.

Sincerely,
WATERENGINEERS, INC.

Shelley Young


Shelley Young, P.E.
Project Engineer

Encl. as noted

Jon Niermann, *Chairman*
Emily Lindley, *Commissioner*
Bobby Janecka, *Commissioner*
Toby Baker, *Executive Director*



PWS_1700931_CO_20220622_Plan Ltr



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY
Protecting Texas by Reducing and Preventing Pollution

June 22, 2022

Mr. Robert N. Dirosa, P.E.
Bleyl Engineering
100 Nugent Street
Conroe, Texas 77301

Re: White Rock Water Plant 1 - Public Water System ID No. 1700931
Proposed Distribution System - Spring Branch Crossing Section 1
Engineer Contact Telephone: (936) 441-7833
Plan Review Log No. P-04282022-180
Montgomery County, Texas

CN600633655; RN111363115

Dear Mr. Dirosa:

On April 28, 2022, the Texas Commission on Environmental Quality (TCEQ) received planning material with your letter dated April 28, 2022 for the proposed distribution system - Spring Branch Crossing Section 1. Based on our review of the information submitted, the project generally meets the minimum requirements of Title 30 Texas Administrative Code (TAC) Chapter 290 - Rules and Regulations for Public Water Systems and is **conditionally approved for construction** if the project plans and specifications meet the following requirement:

- Waterline and wastewater line separation distances must comply with all requirements in 30 TAC Section 290.44(e) of the latest edition of the TCEQ's rules.

The submittal consisted of 23 sheets of engineering drawings and technical specifications. The approved project consists of:

- 4,172 linear feet (LF) of 8-inch, American Water Works Association (AWWA) Standard C-900, dimension ratio (DR) 18 polyvinyl chloride (PVC) waterline;
- 10 LF of 4-inch, AWWA Standard C-900, DR 18 PVC waterline;
- 2,711 LF of 2-inch, American Society for Testing and Materials D1785, Schedule 40, minimum pressure class 150 psi PVC waterline; and
- Various valves, fittings, and appurtenances.

Mr. Robert N. Dirosa, P.E.
Page 3
June 22, 2022

If you have any questions concerning this letter or need further assistance, please contact Raj Khadka at 512-239-1188 or by email at Raj.Khadka@Tceq.Texas.Gov. If you are unable to contact Mr. Khadka, please contact another member of the Plan Review Team at 512-239-4691 or by correspondence at the following address:

Plan Review Team, MC-159
Texas Commission on Environmental Quality
P.O. Box 13087
Austin, Texas 78711-3087

Sincerely,



Jonathan Pi, P.E.
Plan Review Team
Plan and Technical Review Section
Water Supply Division
Texas Commission on Environmental Quality



Vera Poe, P.E., Team Leader
Plan Review Team
Plan and Technical Review Section
Water Supply Division
Texas Commission on Environmental Quality

VP/JP/RK/av

cc: White Rock Water Plant 1 - Attn: Water Utilities Official, P.O. Box 603, Porter, Texas 77365-0603