


## CAPITAL EXPENDITURES – GREATER THAN 1,000 MW

The results of the regression analysis of CAPEX spending for gas/oil CC plants greater than 1,000 MW are summarized in the table below and plotted in the figure below. Since the p-value for the age coefficient (“slope”) is 0.30, which is greater than 0.05, age is not a statistically significant predictor of CAPEX spending.

**Table C-7 — Regression Statistics – CC CAPEX > 1,000 MW**

	<i>t statistic</i>	<i>p-value</i>
<b>Observations</b>	177	
<b>Simple Average (\$/kW)</b>	13.566	
<b>Intercept</b>	9.464	2.0308
<b>Slope</b>	0.507	1.0309
<b>R<sup>2</sup></b>	0.00604	

**Figure C-7 — Gas/Oil CC Dataset – CAPEX for Greater than 1,000-MW Plant Size**




Note: Age coefficient in above regression equation is not statistically significant.

## OPERATIONS & MAINTENANCE EXPENDITURES – GREATER THAN 1,000 MW

The results of the regression analysis of O&M spending for gas/oil CC plants greater than 1,000 MW are summarized in the table below and plotted in the figure below. Since the p-value for the age coefficient (“slope”) is 0.13, which is greater than 0.05, age is not a statistically significant predictor of O&M spending.

**Table C-8 — Regression Statistics – CC O&M > 1,000 MW**

		<i>t statistic</i>	<i>p-value</i>
<b>Observations</b>	177		
<b>Simple Average (\$/kW)</b>	11.676		
<b>Intercept</b>	16.545	4.4651	1.43E-05
<b>Slope</b>	-0.601	-1.5389	1.26E-01
<b>R<sup>2</sup></b>	0.01335		

**Figure C-8 — Gas/Oil CC Dataset – O&M for Greater than 1,000 MW Plant Size**


Note: Age coefficient in above regression equation is not statistically significant.

The simple average O&M and CAPEX values for each 20-year age band, expressed in constant 2017 \$/kW-year, are summarized in the table below.

Average \$/kW (years 1 - 20) =	Average \$/kW (years 21 - 40) =	Average \$/kW (years 41 - 80) =	Average \$/kW (all years) =	Data Points (years 1 - 20) =	Data Points (years 21 - 40) =	Data Points (years 41 - 80) =	Data Points (all years) =
--------------------------------	---------------------------------	---------------------------------	-----------------------------	------------------------------	-------------------------------	-------------------------------	---------------------------

#### > 1000 MW, All Capacity Factors

Net Total O&M- 2017 \$/kW

Net Total Capex - 2017 \$/kW

Net Total O&M and Capex - 2017 \$/kW

11.85	4.14	-	11.68	173	4	0	177
13.37	22.06	-	13.57	173	4	0	177
25.22	26.20	-	25.24	173	4	0	177

Starting with the initial analysis of CAPEX and O&M raw data, as presented above, Sargent & Lundy developed recommended changes to the existing values used in the EMM. The recommended changes for existing gas/oil CC plants are described in Section 5.


## CAPITAL EXPENDITURES – CAPACITY FACTOR LESS THAN 50%

The results of the regression analysis of CAPEX spending for gas/oil CC plants of all MW sizes (full dataset) with capacity factors under 50% are summarized in the table below and plotted in the figure below. Since the p-value for the age coefficient (“slope”) is 0.71, which is greater than 0.05, age is not a statistically significant predictor of CAPEX spending.

**Table C-9 — Regression Statistics – CC CAPEX for Capacity Factor < 50%**

		<i>t</i> statistic	p-value
Observations	844		
Simple Average (\$/kW)	15.554		
Intercept	14.774	5.7075	1.59E-08
Slope	0.041	0.3659	7.15E-01
R <sup>2</sup>	0.00016		

**Figure C-9 — CC Dataset – CAPEX for All Plant Sizes and Avg. Net Capacity Factor < 50%**



Notes: Age coefficient in above regression equation is not statistically significant.  
 Sequential data points with identical values are forecasted values for the same plant.


## OPERATIONS & MAINTENANCE EXPENDITURES – CAPACITY FACTOR LESS THAN 50%

The results of the regression analysis of O&M spending for gas/oil CC plants of all MW sizes (full dataset) with capacity factors under 50% are summarized in the table below and plotted in the figure below. Since the p-value for the age coefficient (“slope”) is less than 0.05, age is a statistically significant predictor of O&M spending (on a linear trend across all plant ages). However, the outliers before year 20 and relatively low number of data points after year 40 may distort the regression analysis.

**Table C-10 — Regression Statistics – CC O&M for Capacity Factor < 50%**

		<i>t statistic</i>	<i>p-value</i>
<b>Observations</b>	864		
<b>Simple Average (\$/kW)</b>	10.791		
<b>Intercept</b>	12.292	13.9850	3.33E-40
<b>Slope</b>	-0.077	-2.0625	3.95E-02
<b>R<sup>2</sup></b>	0.00491		

**Figure C-10 — CC Dataset – O&M for All Plant Sizes and Avg. Net Capacity Factor < 50%**



Note: Sequential data points with identical values are forecasted values for the same plant.

The simple average O&M and CAPEX values for each 20-year age band, expressed in constant 2017 \$/kW-year, are summarized in the table below.

Average \$/kW (years 1 - 20) =	Average \$/kW (years 21 - 40) =	Average \$/kW (years 41 - 80) =	Average \$/kW (all years) =	Data Points (years 1 - 20) =	Data Points (years 21 - 40) =	Data Points (years 41 - 80) =	Data Points (all years) =
---	--	--	-----------------------------------	---------------------------------------	---	---	------------------------------

### All MW, Capacity Factors 0 - 50%

Net Total O&M- 2017 \$/kW

11.54	9.65	10.26	10.79	500	298	66	864
-------	------	-------	-------	-----	-----	----	-----

Net Total Capex - 2017 \$/kW

15.35	15.46	17.56	15.55	501	280	63	844
-------	-------	-------	-------	-----	-----	----	-----

Net Total O&M and Capex - 2017 \$/kW

26.95	25.41	28.19	26.53	499	280	63	842
-------	-------	-------	-------	-----	-----	----	-----


Starting with the initial analysis of CAPEX and O&M raw data, as presented above, Sargent & Lundy developed recommended changes to the existing values used in the EMM. The recommended changes for existing gas/oil CC plants are described in Section 5.

### CAPITAL EXPENDITURES – CAPACITY FACTOR GREATER THAN 50%

The results of the regression analysis of CAPEX spending for gas/oil CC plants of all MW sizes (full dataset) with capacity factors greater than 50% are summarized in the table below and plotted in the figure below. Since the p-value for the age coefficient (“slope”) is 0.37, which is greater than 0.05, age is not a statistically significant predictor of CAPEX spending.

**Table C-11 — Regression Statistics – CC CAPEX for Capacity Factor > 50%**

	<i>t statistic</i>	<i>p-value</i>
Observations	524	
Simple Average (\$/kW)	16.104	
Intercept	14.630	7.3893
Slope	0.149	0.9054
R <sup>2</sup>	0.00157	

**Figure C-11 — CC Dataset – CAPEX for All Plant Sizes and Avg. Net Capacity Factor > 50%**



Notes: Age coefficient in above regression equation is not statistically significant.  
 Sequential data points with identical values are forecasted values for the same plant.

## OPERATIONS & MAINTENANCE EXPENDITURES – CAPACITY FACTOR GREATER THAN 50%

The results of the linear regression analysis of O&M spending for gas/oil CC plants of all MW sizes (full dataset) with capacity factors greater than 50% are summarized in the table below. Since the p-value for the age coefficient (“slope”) is 0.33, which is greater than 0.05, age is not a statistically significant predictor of CAPEX spending (on a linear trend across all plant ages).

**Table C-12 — Regression Statistics – CC O&M for Capacity Factor > 50%**

	<i>t statistic</i>	<i>p-value</i>
<b>Observations</b>	524	
<b>Simple Average (\$/kW)</b>	16.855	
<b>Intercept</b>	17.665	17.5298
<b>Slope</b>	-0.082	-0.9777
<b>R<sup>2</sup></b>	0.00183	

**Figure C-12 — CC Dataset – O&M for All Plant Sizes and Avg. Net Capacity Factor > 50%**


Notes: Age coefficient in above regression equation is not statistically significant.  
 Sequential data points with identical values are forecasted values for the same plant.

The simple average O&M and CAPEX values for each 20-year age band, expressed in constant 2017 \$/kW-year, are summarized in the table below.

Average \$/kW (years 1 - 20) =	Average \$/kW (years 21 - 40) =	Average \$/kW (years 41 - 80) =	Average \$/kW (all years) =	Data Points (years 1 - 20) =	Data Points (years 21 - 40) =	Data Points (years 41 - 80) =	Data Points (all years) =
--------------------------------	---------------------------------	---------------------------------	-----------------------------	------------------------------	-------------------------------	-------------------------------	---------------------------

#### All MW, Capacity Factors 50% - 100%

Net Total O&M - 2017 \$/kW	16.90	16.44	-	16.85	478	46	0	524
Net Total Capex - 2017 \$/kW	15.55	21.89	-	16.10	478	46	0	524
Net Total O&M and Capex - 2017 \$/kW	32.46	38.32	-	32.98	477	46	0	523

Starting with the initial analysis of CAPEX and O&M raw data, as presented above, Sargent & Lundy developed recommended changes to the existing values used in the EMM. The recommended changes for existing gas/oil CC plants are described in Section 5.

Exhibit DG-6

**Sargent & Lundy**  
Consulting

---

## Appendix D. Regression Analysis – Gas/Oil Combustion Turbine

---


## CAPITAL EXPENDITURES – ALL PLANT SIZES

The results of the regression analysis of CAPEX spending for gas/oil CT plants of all MW sizes (full dataset) are summarized in the table below and plotted in the figure below. Since the p-value for the age coefficient (“slope”) is 0.09, which is greater than 0.05, dataset does not support age as a statistically significant predictor of CAPEX spending (on a linear trend across all plant ages).

**Table D-1 — Regression Statistics – CT CAPEX for All MW**

		<i>t statistic</i>	<i>p-value</i>
Observations	5065		
Simple Average (\$/kW)	6.897		
Intercept	8.737	7.3087	3.12E-13
Slope	-0.068	-1.6948	9.02E-02
R <sup>2</sup>	0.00057		

**Figure D-1 — Gas/Oil CT Dataset – CAPEX for All Plant MW Sizes**




Note: Age coefficient in above regression equation is not statistically significant.

## OPERATIONS & MAINTENANCE EXPENDITURES – ALL PLANT SIZES

The results of the regression analysis of O&M spending for gas/oil CT plants of all MW sizes (full dataset) are summarized in the table below and plotted in the figure below. Since the p-value for the age coefficient (“slope”) is 0.062, which is greater than 0.05, the dataset does not support age as a statistically significant predictor of O&M spending (on a linear trend across all plant ages).

**Table D-2 — Regression Statistics – CT O&M for All MW**

	<i>t statistic</i>	<i>p-value</i>
<b>Observations</b>	5283	
<b>Simple Average (\$/kW)</b>	5.331	
<b>Intercept</b>	6.641	8.5764
<b>Slope</b>	-0.048	-1.8683
<b>R<sup>2</sup></b>	0.00066	

**Figure D-2 — Gas/Oil CT Dataset – O&M for All Plant MW Sizes**


Notes: Age coefficient in above regression equation is not statistically significant.  
 Sequential data points with identical values are forecasted values for the same plant.

The simple average O&M and CAPEX values for each 20-year age band, expressed in constant 2017 \$/kW-year, are summarized in the table below.

	Average \$/kW (years 1 - 20) =	Average \$/kW (years 21 - 40) =	Average \$/kW (years 41 - 80) =	Average \$/kW (all years) =	Data Points (years 1 - 20) =	Data Points (years 21 - 40) =	Data Points (years 41 - 80) =	Data Points (all years) =
--	---	--	--	-----------------------------------	---------------------------------------	---	---	------------------------------------

**All MW, All Capacity Factors**

Net Total O&amp;M - 2017 \$/kW

7.86	3.99	6.11	<b>5.33</b>	1,418	3,118	747	<b>5,283</b>
------	------	------	-------------	-------	-------	-----	--------------

Net Total Capex - 2017 \$/kW

9.17	5.78	7.40	<b>6.90</b>	1,360	3,054	651	<b>5,065</b>
------	------	------	-------------	-------	-------	-----	--------------

Net Total O&amp;M and Capex - 2017 \$/kW

16.43	9.43	10.92	<b>11.49</b>	1,341	3,040	640	<b>5,021</b>
-------	------	-------	--------------	-------	-------	-----	--------------

Starting with the initial analysis of CAPEX and O&M raw data, as presented above, Sargent & Lundy developed recommended changes to the existing values used in the EMM. The recommended changes for existing gas/oil CT plants are described in Section 6.

## CAPITAL EXPENDITURES – LESS THAN 100 MW


The results of the regression analysis of CAPEX spending for gas/oil CT plants less than 100 MW are summarized in the table below and plotted in the figure below. Since the p-value for the age coefficient (“slope”) is 0.002, which is less than 0.05, age is a statistically significant predictor of CAPEX spending (on a linear trend across all plant ages). Therefore, CAPEX spending for this dataset may be estimated by the regression equation:

Annual CAPEX spending in 2017 \$/kW-year = 15.651 + (-0.227 × age)
--

**Table D-3 — Regression Statistics – CT CAPEX < 100 MW**

	<i>t statistic</i>	<i>p-value</i>
Observations	2,911	
Simple Average (\$/kW)	9.003	
Intercept	15.651	6.6753
Slope	-0.227	-3.0345
R <sup>2</sup>	0.00316	

**Figure D-3 — Gas/Oil CT Dataset – CAPEX for Less than 100-MW Plant Size**




## OPERATIONS & MAINTENANCE EXPENDITURES – LESS THAN 100 MW

The results of the regression analysis of O&M spending for gas/oil CT plants less than 100 MW are summarized in the table below and plotted in the figure below. Since the p-value for the age coefficient (“slope”) is 0.966, which is greater than 0.05, the dataset does not support age as a statistically significant predictor of O&M spending (on a linear trend across all plant ages).

**Table D-4 — Regression Statistics – CT O&M < 100 MW**

		<i>t statistic</i>	<i>p-value</i>
<b>Observations</b>	3,062		
<b>Simple Average (\$/kW)</b>	5.958		
<b>Intercept</b>	6.001	5.5008	4.09E-08
<b>Slope</b>	-0.001	-0.0423	9.66E-01
<b>R<sup>2</sup></b>	0.00000		

**Figure D-4 — Gas/Oil CT Dataset – O&M for Less than 100-MW Plant Size**



Notes: Age coefficient in above regression equation is not statistically significant.  
 Sequential data points with identical values are forecasted values for the same plant.

The simple average O&M and CAPEX values for each 20-year age band, expressed in constant 2017 \$/kW-year, are summarized in the table below.

Average \$/kW (years 1 - 20) =	Average \$/kW (years 21 - 40) =	Average \$/kW (years 41 - 80) =	Average \$/kW (all years) =	Data Points (years 1 - 20) =	Data Points (years 21 - 40) =	Data Points (years 41 - 80) =	Data Points (all years) =
---	--	--	-----------------------------------	---------------------------------------	---	---	------------------------------

### < 100 MW, All Capacity Factors

Net Total O&M- 2017 \$/kW

8.76	4.93	7.40	<b>5.96</b>	489	2,060	513	<b>3,062</b>
------	------	------	-------------	-----	-------	-----	--------------

Net Total Capex - 2017 \$/kW

15.08	7.98	6.64	<b>9.00</b>	497	1,999	415	<b>2,911</b>
-------	------	------	-------------	-----	-------	-----	--------------

Net Total O&M and Capex - 2017 \$/kW

24.04	12.31	10.26	<b>14.02</b>	489	1,978	406	<b>2,873</b>
-------	-------	-------	--------------	-----	-------	-----	--------------


Starting with the initial analysis of CAPEX and O&M raw data, as presented above, Sargent & Lundy developed recommended changes to the existing values used in the EMM. The recommended changes for existing gas/oil CT plants are described in Section 6.

### CAPITAL EXPENDITURES – BETWEEN 100 MW AND 300 MW

The results of the regression analysis of CAPEX spending for CT plants between 100 MW and 300 MW are summarized in the table below and plotted in the figure below. Since the p-value for the age coefficient (“slope”) is 0.939, which is greater than 0.05, age is not a statistically significant predictor of CAPEX spending.

**Table D-5 — Regression Statistics – CT CAPEX 100 MW to 300 MW**

	<i>t statistic</i>	<i>p-value</i>
<b>Observations</b>	1,350	
<b>Simple Average (\$/kW)</b>	6.183	
<b>Intercept</b>	6.254	6.0376
<b>Slope</b>	-0.003	-0.0768
<b>R<sup>2</sup></b>	0.00000	

**Figure D-5 — Gas/Oil CT Dataset – CAPEX for Between 100-MW and 300-MW Plant Size**


Note: Age coefficient in above regression equation is not statistically significant.


## OPERATIONS & MAINTENANCE EXPENDITURES – BETWEEN 100 MW AND 300 MW

The results of the regression analysis of O&M spending for gas/oil CT plants between 100 MW and 300 MW are summarized in the table below and plotted in the figure below. Since the p-value for the age coefficient (“slope”) is 0.023, which is less than 0.05, age is a statistically significant predictor of O&M spending (on a linear trend across all plant ages). Therefore, O&M spending for this dataset may be estimated by the regression equation:

$$\text{Annual O\&M spending in 2017 \$/kW-year} = 10.569 + (-0.162 \times \text{age})$$

**Table D-6 — Regression Statistics – CT O&M 100 MW to 300 MW**

	<i>t statistic</i>	<i>p-value</i>
Observations	1,416	
Simple Average (\$/kW)	6.430	
Intercept	10.569	5.1759
Slope	-0.162	-2.2723
R <sup>2</sup>	0.00364	

**Figure D-6 — Gas/Oil CT Dataset – O&M for Between 100-MW and 300-MW Plant Size**


Note: Sequential data points with identical values are forecasted values for the same plant.

The simple average O&M and CAPEX values for each 20-year age band, expressed in constant 2017 \$/kW-year, are summarized in the table below.

Average \$/kW (years 1 - 20) =	Average \$/kW (years 21 - 40) =	Average \$/kW (years 41 - 80) =	Average \$/kW (all years) =	Data Points (years 1 - 20) =	Data Points (years 21 - 40) =	Data Points (years 41 - 80) =	Data Points (all years) =
--------------------------------	---------------------------------	---------------------------------	-----------------------------	------------------------------	-------------------------------	-------------------------------	---------------------------

#### 100 MW - 300 MW, All Capacity Factors

Net Total O&M - 2017 \$/kW	9.97	5.18	3.24	6.43	442	794	180	1,416
Net Total Capex - 2017 \$/kW	6.32	6.07	6.38	6.18	407	762	181	1,350
Net Total O&M and Capex - 2017 \$/kW	15.14	9.09	9.66	10.98	402	759	180	1,341

Starting with the initial analysis of CAPEX and O&M raw data, as presented above, Sargent & Lundy developed recommended changes to the existing values used in the EMM. The recommended changes for existing gas/oil CT plants are described in Section 6.

## CAPITAL EXPENDITURES – GREATER THAN 300 MW


The results of the regression analysis of CAPEX spending for gas/oil CT plants greater than 300 MW are summarized in the table below and plotted in the figure below. Since the p-value for the age coefficient (“slope”) is 0.010, which is less than 0.05, age is a statistically significant predictor of CAPEX spending (on a linear trend across all plant ages). Therefore, CAPEX spending for this dataset may be estimated by the regression equation:

Annual CAPEX spending in 2017 \$/kW-year = 2.945 + (0.193 × age)
--

**Table D-7 — Regression Statistics – CT CAPEX > 300 MW**

	<i>t statistic</i>	<i>p-value</i>
<b>Observations</b>	909	
<b>Simple Average (\$/kW)</b>	6.952	
<b>Intercept</b>	2.945	1.6382
<b>Slope</b>	0.193	2.5842
<b>R<sup>2</sup></b>	0.00731	

**Figure D-7 — Gas/Oil CT Dataset – CAPEX for Greater than 300-MW Plant Size**



## OPERATIONS & MAINTENANCE EXPENDITURES – GREATER THAN 300 MW


The results of the regression analysis of O&M spending for CT plants greater than 300 MW are summarized in the table below and plotted in the figure below. Since the p-value for the age coefficient (“slope”) is significantly less than 0.05, age is a statistically significant predictor of O&M spending (on a linear trend across all plant ages). Therefore, O&M spending for this dataset may be estimated by the regression equation:

$$\text{Annual O&M spending in 2017 \$/kW-year} = 5.474 + (-0.072 \times \text{age})$$

**Table D-8 — Regression Statistics – CT O&M > 300 MW**

		<i>t Statistic</i>	<i>p-value</i>
Observations	938		
Simple Average (\$/kW)	3.994		
Intercept	5.474	12.8980	3.75E-35
Slope	-0.072	-4.0612	5.29E-05
R <sup>2</sup>	0.01732		

**Figure D-8 — Gas/Oil CT Dataset – O&M for Greater than 300-MW Plant Size**



The simple average O&M and CAPEX values for each 20-year age band, expressed in constant 2017 \$/kW-year, are summarized in the table below.

Average \$/kW (years 1 - 20) =	Average \$/kW (years 21 - 40) =	Average \$/kW (years 41 - 80) =	Average \$/kW (all years) =	Data Points (years 1 - 20) =	Data Points (years 21 - 40) =	Data Points (years 41 - 80) =	Data Points (all years) =
---	--	--	-----------------------------------	---------------------------------------	---	---	------------------------------

**> 300 MW, All Capacity Factors**

Net Total O&amp;M- 2017 \$/kW

5.03	2.78	3.46	3.99	488	396	54	938
------	------	------	------	-----	-----	----	-----

Net Total Capex - 2017 \$/kW

5.26	7.58	16.50	6.95	457	397	55	909
------	------	-------	------	-----	-----	----	-----

Net Total O&amp;M and Capex - 2017 \$/kW

9.30	10.38	20.11	10.42	451	396	54	901
------	-------	-------	-------	-----	-----	----	-----

Starting with the initial analysis of CAPEX and O&M raw data, as presented above, Sargent & Lundy developed recommended changes to the existing values used in the EMM. The recommended changes for existing gas/oil CT plants are described in Section 6.

Exhibit DG-6



---

## Appendix E. Regression Analysis – Conventional Hydroelectric

---

## CAPITAL EXPENDITURES – ALL PLANT SIZES


The results of the linear regression analysis of CAPEX spending for conventional hydroelectric plants of all MW sizes (full dataset) are summarized in the table below and plotted in the figure below. Since the p-value for the age coefficient (“slope”) is significantly less than 0.05, age is a statistically significant predictor of CAPEX spending (on a linear trend across all plant ages). Therefore, CAPEX spending for this dataset may be estimated by the regression equation:

$$\text{Annual CAPEX spending in 2017 \$/kW-year} = 7.269 + (0.296 \times \text{age})$$

**Table E-1 — Regression Statistics – Hydroelectric CAPEX for All MW**

		<i>t statistic</i>	<i>p-value</i>
Observations	2180		
Simple Average (\$/kW)	21.999		
Intercept	7.269	1.4681	1.42E-01
Slope	0.296	3.1441	1.69E-03
R <sup>2</sup>	0.00452		

**Figure E-1 — Conventional Hydroelectric Dataset – CAPEX for All MW Plant Sizes**



♦ Data Points ■ Regression Fit

## OPERATIONS & MAINTENANCE EXPENDITURES – ALL PLANT SIZES

The results of the linear regression analysis of O&M spending for conventional hydroelectric plants of all MW sizes (full dataset) are summarized in the table below and plotted in the figure below. Since the p-value for the age coefficient (“slope”) is significantly less than 0.05, age is a statistically significant predictor of O&M spending (on a linear trend across all plant ages). Therefore, O&M spending for this dataset may be estimated by the regression equation:

$$\text{Annual O&M spending in 2017 \$/kW-year} = 22.360 + (0.073 \times \text{age})$$

**Table E-2 — Regression Statistics – Hydroelectric O&M for All MW**

		<i>t statistic</i>	<i>p-value</i>
<b>Observations</b>	1,272		
<b>Simple Average (\$/kW)</b>	24.473		
<b>Intercept</b>	22.360	13.7360	3.92E-40
<b>Slope</b>	0.073	2.5053	1.24E-02
<b>R<sup>2</sup></b>	0.00492		

**Figure E-2 — Conventional Hydroelectric – O&M for All MW Plant Sizes**




Exhibit DG-6

**Sargent & Lundy**  
Consulting

---

## **Appendix F. Regression Analysis – Pumped Hydroelectric Storage**

---


## CAPITAL EXPENDITURES – ALL PLANT SIZES

The results of the linear regression analysis of CAPEX spending for pumped hydroelectric storage plants of all MW sizes (full dataset) are summarized in the table below and plotted in the figure below. Since the p-value for the age coefficient (“slope”) is greater than 0.05, the dataset does not support age as a statistically significant predictor of CAPEX spending (on a linear trend across all plant ages). The dataset was not divided by unit capacity due to the limited number of data points.

**Table F-1 — Regression Statistics – Pumped Hydroelectric CAPEX for All MW**

	<i>t statistic</i>	<i>p-value</i>
<b>Observations</b>	227	
<b>Simple Average (\$/kW)</b>	11.398	
<b>Intercept</b>	-6.907	-0.4501
<b>Slope</b>	0.743	1.2723
<b>R<sup>2</sup></b>	0.01278	

**Figure F-1 — Pumped Hydroelectric Dataset – CAPEX for All MW Plant Sizes**



◆ Data Points ■ Regression Fit

Note: Age coefficient in above regression equation is not statistically significant.


## OPERATIONS & MAINTENANCE EXPENDITURES – ALL PLANT SIZES

The results of the linear regression analysis of O&M spending for pumped hydroelectric storage plants of all MW sizes (full dataset) are summarized in the table below and plotted in the figure below. Since the p-value for the age coefficient (“slope”) is greater than 0.05, the dataset does not support age as a statistically significant predictor of O&M spending (on a linear trend across all plant ages). The dataset was not divided by unit capacity due to the limited number of data points.

**Table F-2 — Regression Statistics – Pumped Hydroelectric O&M for All MW**

	<i>t statistic</i>	<i>p-value</i>
<b>Observations</b>	226	
<b>Simple Average (\$/kW)</b>	23.634	
<b>Intercept</b>	15.296	2.9021
<b>Slope</b>	0.288	1.7010
<b>R<sup>2</sup></b>	0.01275	

**Figure F-2 — Pumped Hydroelectric – O&M for All Plant MW Sizes**



Note: Age coefficient in above regression equation is not statistically significant.

The simple average O&M and CAPEX values for each 20-year age band, expressed in constant 2017 \$/kW-year, are summarized in the table below.



## Exhibit DG-6

F-4

SL-014201

Regression Analysis – Pumped Hydroelectric Storage

Final v01

Average \$/kW (years 1 - 20) =	Average \$/kW (years 21 - 40) =	Average \$/kW (years 41 - 80) =	Average \$/kW (all years) =	Data Points (years 1 - 20) =	Data Points (years 21 - 40) =	Data Points (years 41 - 80) =	Data Points (all years) =
-----------------------------------	------------------------------------	------------------------------------	--------------------------------	---------------------------------	----------------------------------	----------------------------------	------------------------------

### All MW, All Capacity Factors

Net Total O&M- 2017 \$/kW

Net Total Capex - 2017 \$/kW

Net Total O&M and Capex - 2017 \$/kW

18.97	23.41	31.00	<b>23.63</b>	50	140	36	<b>226</b>
22.94	11.93	14.92	<b>14.83</b>	50	141	36	<b>227</b>
41.91	35.34	45.92	<b>38.46</b>	--	--	--	--

Starting with the initial analysis of CAPEX and O&M raw data, as presented above, Sargent & Lundy developed recommended changes to the existing values used in the EMM. The recommended changes for existing pumped hydroelectric storage plants are described in Section 8.



---

## **Appendix G. Regression Analysis – Solar Photovoltaic**

---

## CAPITAL EXPENDITURES

Annual CAPEX, labeled in FERC Form 1 as TCP, are broken down into subcategories, including:

- Land & Land Rights
- Structures & Improvements
- Reservoirs, Dams & Waterways
- Water Wheels
- Turbines & Generators
- Accessory Electric Equipment
- Equipment
- Asset Retirement Costs
- Roads, and Railroads & Bridges

These subcategories are based on traditional power generation technologies and have minimal applicability to solar PV. Expected CAPEX for solar PV, such as inverter replacement and repair or module replacement, are clearly not applicable to any of the categories listed in FERC Form 1.

In the FERC Form 1 data, only 10 of the solar PV sites had a breakdown of TCP into the above subcategories, with even fewer providing such a breakdown for more than one year. As discussed in Section 9, the year-over-year change in TCP is the sole source of annual CAPEX information in FERC Form 1. Of this data, Sargent & Lundy determined that a significant portion of it needed to be filtered out due to the following reasons:

- A negative change in the TCP between two consecutive years
- A change in the capacity of the plant greater than 20%
- A significant increase in TCP without a capacity increase
- Large unexplained fluctuations (e.g., negative to positive) in TCP from year to year
- Large gaps in annual data


After filtering out clearly suspect data, about one-third of the remaining data was for plants having only three years of data or less. In addition, many of the plants reported no changes in TCP, suggesting that most annual expenditures at those sites were being reported as O&M rather than being capitalized.

Thus, Sargent & Lundy had to rely on a limited dataset for solar PV consisting of 15 sites. The average change in TCP for these sites was approximately \$26/kW-year. Based on the available FERC Form 1 information, it cannot be determined whether this change in TCP was due to typical CAPEX for solar PV, such as inverter or module replacement, or other factors.

The results of the linear regression analysis of CAPEX spending for solar PV plants of all MW sizes (full dataset) are summarized in the table below and plotted in the figure below. Since the p-value for the age coefficient (“slope”) is 0.16, which is greater than 0.05, the dataset does not support age as a statistically significant predictor of CAPEX spending (on a linear trend across all plant ages). In addition, as indicated in the table below, there are a relatively small number of data points for CAPEX (less than 60 points). The average CAPEX across all years is approximately \$26/kW-year (2017 dollars).

**Table G-1 — Regression Statistics – Solar PV CAPEX for All MW**

		<i>t statistic</i>	<i>p-value</i>
<b>Observations</b>	57		
<b>Simple Average (\$/kW)</b>	26.026		
<b>Intercept</b>	42.978	3.2248	2.12E-03
<b>Slope</b>	-5.618	-1.4387	1.56E-01
<b>R<sup>2</sup></b>	0.03627		

**Figure G-1 — Solar PV Dataset – CAPEX for All MW Plant Sizes**


Note: Age coefficient in above regression equation is not statistically significant.

## OPERATIONS & MAINTENANCE EXPENDITURES

Solar PV O&M activities include a variety of work scopes, including administrative work, monitoring, cleaning, preventative maintenance, and corrective maintenance. Some specific examples of O&M activities may include cleaning modules, monitoring system voltage and current, inspecting and cleaning electrical equipment, inspecting modules for damage, inspecting mounting systems, and checking inverter settings. The cost of O&M is dependent on several factors, including the number of components, the type of system (e.g., roof, tracking, ground mount, fixed, etc.), warranty coverage, and location. Environmental conditions, such as hail, sand/dust, snow, salt in air, high winds, etc., also play a significant role in O&M costs. For these reasons, a higher level of variation is expected when compared to traditional generating technologies.

The total production cost, which is the sum of the total operating expense and total maintenance expense, was reported for slightly over half of the sites. Of the sites reporting, several sites only reported this data in certain years, leaving gaps in the data. Subcategories for operating costs and maintenance cost were provided in the FERC Form 1 data, but rarely was the reported data broken into subcategories.

Sargent & Lundy organized the FERC Form 1 data into two presentation formats. In the first format, the annual O&M cost was averaged across all years of the reported data to obtain the average annual O&M cost per plant. This resulted in approximately 60 data points. In the second format, the annual O&M cost was averaged across each year of operation. This resulted in approximately 200 data points. The average O&M cost results are not equal between the two presentation formats. Table G-2 provides a simple example of these differing results, using FERC Form 1 O&M data from three plants.

**Table G-2 — Example of Calculation Method Differences**


Age (Years)	O&M Cost (\$/kW-year)															
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	Plant Average
Example Plant 1	127.8	0.0	0.1	0.0	-	-	-	-	-	-	-	-	-	-	-	32.0
Example Plant 2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Example Plant 3	32.2	15.3	24.8	-	-	-	-	-	-	-	-	-	-	-	-	24.1

Example Average (All Data Points)	9.1
Example Average (of Plant Averages)	18.7


In the example above, a single plant with more data points is able to sway the average O&M cost across the three plants. The values calculated below are based on averaged data points (i.e., a data point is the average annual O&M cost across the reported data for a given plant).

Figure G-2 and Figure G-3 show the average site O&M cost, expressed in \$/MWh, for sites with a capacity less than 5 MW and greater than 5 MW, respectively. In general, these figures show a high level of variability across sites, with smaller sites having a higher O&M cost per MWh produced. Several data points were for sites having very low capacity factors (less than 5%), which also results in higher O&M costs per MWh. For the sites greater than 5 MW, the average O&M cost was \$8.5/MWh. When expressed on the basis of cost per kW of capacity (see Figure G-4 and Figure G-5), the average O&M for sites greater than 5 MW was \$15/kW-year.


**Figure G-2 — Average Site O&M Cost per MWh Generated vs. Project Nameplate Capacity (< 5 MW)**




**Figure G-3 — Average Site O&M Cost per MWh Generated vs. Project Nameplate Capacity (> 5 MW)**



**Figure G-4 — Average Site O&M Cost per kW-Year Capacity vs. Project Nameplate Capacity (< 5 MW)**





**Figure G-5 — Average Site O&M Cost per kW-Year Capacity vs. Project Nameplate Capacity (> 5 MW)**



The figures below show the annual site O&M cost (in \$/MWh and \$/kW-year) versus the age of the project. In general, little correlation can be seen between age and O&M cost.

**Figure G-6 — Annual Site O&M Cost per MWh vs. Age of Project**



**Figure G-7 — Annual Site O&M Cost per kW-Year Capacity vs. Age of Project**


Sargent & Lundy compiled O&M data from other sources in Table G-3 below for comparison against the FERC data. In general, the O&M costs in \$/kW-year capacity are in the same range as the FERC data for sites over 5-MW capacity.

**Table G-3 — Summary of Industry O&M Cost Data for Solar PV**

O&M Cost Sources	O&M Cost \$/kW-yr	Notes	Report Source Data Year
NREL & Sunshot	15	Fixed	2015
NREL & Sunshot	18	Single-Axis Tracking	2015
Sunshot + NREL	20.5	Good O&M	2016
Sunshot + NREL	25.0	Optimal O&M	2016
IRENA Power to Change	10	Minimum	2015
IRENA Power to Change	18	Maximum	2015
Utility Scale Solar	17	Overall	2014
Utility Scale Solar 2016	7	Minimum	2016
Utility Scale Solar 2016	27	Maximum	2016
Utility Scale Solar 2016	18	Mean	2016
NREL U.S. Solar Photovoltaic System Cost Benchmark: Q1 2017	15.4	Fixed LCOE Assumption	2017
NREL U.S. Solar Photovoltaic System Cost Benchmark: Q1 2018	18.5	SAT LCOE Assumption	2017



## Exhibit DG-6

G-9

SL-014201

Regression Analysis – Solar Photovoltaic  
Final v01

Starting with the initial analysis of CAPEX and O&M raw data, as presented above, Sargent & Lundy developed recommended changes to the existing values used in the EMM. The recommended changes for existing solar PV plants are described in Section 9.

Exhibit DG-6



---

## **Appendix H. Regression Analysis – Solar Thermal**

---



## Exhibit DG-6

H-2

SL-014201

Regression Analysis – Solar Thermal  
Final v01

There are no solar thermal power plants that report operating data in FERC Form 1. Industry-wide, there are a limited number of solar thermal projects; a majority of which have been constructed within the last 10 years—the exception being small test facilities and the Solar Energy Generating Systems (SEGS) plants built in the 1980s.

Exhibit DG-6

**Sargent & Lundy**  
Consulting

---

## **Appendix I. Regression Analysis – Geothermal**

---


## CAPITAL EXPENDITURES

The results of the linear regression analysis of CAPEX spending for geothermal plants of all MW sizes (full dataset) are summarized in the table below and plotted in the figure below. Although the p-value is less than 0.05, the dataset is inconclusive because the intercept is negative due to no plants reporting data between ages and 0 and 10.

**Table I-1 — Regression Statistics – Geothermal CAPEX for All MW**

		<i>t statistic</i>	<i>p-value</i>
Observations	36		
Simple Average (\$/kW)	40.948		
Intercept	-150.830	-1.7907	8.23E-02
Slope	10.006	2.3736	2.34E-02
R <sup>2</sup>	0.14215		

**Figure I-1 — Geothermal Dataset – CAPEX for All MW Plant Sizes**




## OPERATIONS & MAINTENANCE EXPENDITURES

The results of the linear regression analysis of O&M spending for geothermal plants of all MW sizes (full dataset) are summarized in the table below and plotted in the figure below. Since the p-value for the age coefficient is 0.071, which is greater than 0.05, the dataset does not support age as a statistically significant predictor of O&M spending (on a linear trend across all plant ages).

**Table I-2 — Regression Statistics – Geothermal O&M for All MW**

		<i>t Statistic</i>	<i>p-value</i>
Observations	36		
Simple Average (\$/kW)	157.103		
Intercept	175.369	2.6984	1.08E-02
Slope	-0.953	-0.2930	7.71E-01
R <sup>2</sup>	0.00252		

**Figure I-2 — Geothermal Dataset – O&M for All MW Plant Sizes**



Note: Age coefficient in above regression equation is not statistically significant.

The simple average O&M and CAPEX values for each five-year age band, expressed in constant 2017 \$/kW-year, are summarized in the table below.



## Exhibit DG-6

I-4

SL-014201

Regression Analysis – Geothermal  
Final v01

Table I-3 — Geothermal All MW Summary of Results

	Average \$/kW-yr (Years 1-5)	Average \$/kW-yr (Years 6-10)	Average \$/kW-yr (Years 11-15)	Average \$/kW-yr (Years 16-20)	Average \$/kW-yr (Years 21-25)	Average \$/kW-yr (Years 26-30)	Average \$/kW-yr (All Years)	Data Points (Years 1-5)	Data Points (Years 6-10)	Data Points (Years 11-15)	Data Points (Years 16-20)	Data Points (Years 21-25)	Data Points (Years 26-30)	Data Points (All Years)
All MW, All Capacity Factors														
Net Total O&M – 2017 \$/kW-yr	--	300.62	170.44	124.24	149.97	166.77	157.10	--	1	12	10	6	7	36
Net Total CAPEX – 2017 \$/kW-yr	--	--	72.05	30.16	27.64	114.45	40.94	--	1	12	10	6	7	36

Starting with the initial analysis of CAPEX and O&M raw data, as presented above, Sargent & Lundy developed recommended changes to the existing values used in the EMM. The recommended changes for existing geothermal plants are described in Section 11.

Exhibit DG-6



---

## Appendix J. Regression Analysis – Wind

---

## CAPITAL EXPENDITURES


### Full Dataset

The results of the linear regression analysis of CAPEX spending for wind plants of all MW sizes (full dataset) are summarized in the table below and plotted in the figure below. Since the p-value for the age coefficient is 0.224, which is greater than 0.05, the dataset does not support age as a statistically significant predictor of CAPEX spending (on a linear trend across all plant ages).

**Table J-1 — Regression Statistics – Wind CAPEX for All MW**

	<i>t Statistic</i>	<i>p-value</i>
Observations	310	
Simple Average (\$/kW)	18.285	
Intercept	22.241	5.7807
Slope	-0.686	-1.2194
R <sup>2</sup>	0.00480	

**Figure J-1 — Wind Dataset – CAPEX for All MW Plant Sizes**



Note: Age coefficient in above regression equation is not statistically significant.

The simple average O&M and CAPEX values for each five-year age band, expressed in constant 2017 \$/kW-year, are summarized in the table below.

**Table J-2 — Wind All MW Summary of Results**

	Average \$/kW-yr (Years 1-5)	Average \$/kW-yr (Years 6-10)	Average \$/kW-yr (Years 11-15)	Average \$/kW-yr (Years 16-20)	Average \$/kW-yr (All Years)	Data Points (Years 1-5)	Data Points (Years 6-10)	Data Points (Years 11-15)	Data Points (Years 16-20)	Data Points (All Years)
<b>All MW, All Capacity Factors</b>										
Net Total CAPEX – 2017 \$/kW-yr	21.06	10.97	32.62	21.60	<b>18.29</b>	168	112	23	7	<b>310</b>


Starting with the initial analysis of CAPEX raw data, as presented above, Sargent & Lundy developed recommended changes to the existing values used in the EMM. The recommended changes for existing wind plants are described in Section 12.

### **0-100 MW**

The results of the linear regression analysis of CAPEX spending for wind plants between 0 MW and 100 MW are summarized in the table below and plotted in the figure below. Since the p-value for the age coefficient is 0.706, which is greater than 0.05, the dataset does not support age as a statistically significant predictor of CAPEX spending (on a linear trend across all plant ages). Therefore, a more appropriate predictor of CAPEX spending for this dataset is a simple average by plant age band, as discussed in Section 12.

**Table J-3 — Regression Statistics – Wind CAPEX for 0-100 MW**

	<i>t Statistic</i>	<i>p-value</i>
Observations	174	
Simple Average (\$/kW)	20.483	
Intercept	22.342	3.7750
Slope	-0.297	-0.3779
R <sup>2</sup>	0.00083	

**Figure J-2 — Wind Dataset – CAPEX for 0-100-MW Plant Sizes**


Note: Age coefficient in above regression equation is not statistically significant.

The simple average CAPEX values for each five-year age band, expressed in constant 2017 \$/kW-year, are summarized in the table below.

**Table J-4 — Wind < 100-MW Summary of Results**

Average \$/kW-yr (Years 1-5)	Average \$/kW-yr (Years 6-10)	Average \$/kW-yr (Years 11-15)	Average \$/kW-yr (Years 16-20)	Average \$/kW-yr (All Years)	Data Points (Years 1-5)	Data Points (Years 6-10)	Data Points (Years 11-15)	Data Points (Years 16-20)	Data Points (All Years)	
<b>&lt; 100 MW, All Capacity Factors</b>										
Net Total CAPEX – 2017 \$/kW-yr	22.83	11.62	35.35	21.60	<b>20.48</b>	89	58	20	7	<b>174</b>


Starting with the initial analysis of CAPEX raw data, as presented above, Sargent & Lundy developed recommended changes to the existing values used in the EMM. The recommended changes for existing wind plants are described in Section 12.

**100-200 MW**

The results of the linear regression analysis of CAPEX spending for wind plants between 100 MW and 200 MW are summarized in the table below. Since the p-value for the age coefficient is 0.224, which is greater than 0.05, the dataset does not support age as a statistically significant predictor of CAPEX spending (on a linear trend across all plant ages).

**Table J-5 — Regression Statistics – Wind CAPEX for 100-200 MW**

	<i>t Statistic</i>	<i>p-value</i>
<b>Observations</b>	310	
<b>Simple Average (\$/kW)</b>	16.935	
<b>Intercept</b>	22.241	5.7807 1.82E-08
<b>Slope</b>	-0.686	-1.2194 2.24E-01
<b>R<sup>2</sup></b>	0.00480	

**Figure J-3 — Wind Dataset – CAPEX for 100-200-MW Plant Sizes**


Note: Age coefficient in above regression equation is not statistically significant.

The simple average CAPEX values for each five-year age band, expressed in constant 2017 \$/kW-year, are summarized in the table below.

**Table J-6 — Wind 100-200-MW Summary of Results**

	Average \$/kW-yr (Years 1-5)	Average \$/kW-yr (Years 6-10)	Average \$/kW-yr (Years 11-15)	Average \$/kW-yr (Years 16-20)	Average \$/kW-yr (All Years)	Data Points (Years 1-5)	Data Points (Years 6-10)	Data Points (Years 11-15)	Data Points (Years 16-20)	Data Points (All Years)
<b>100 - 200 MW, All Capacity Factors</b>										
Net Total CAPEX – 2017 \$/kW-yr	20.36	12.20	14.41	--	<b>16.93</b>	52	36	3	--	91


Starting with the initial analysis of CAPEX raw data, as presented above, Sargent & Lundy developed recommended changes to the existing values used in the EMM. The recommended changes for existing wind plants are described in Section 12.

### **Greater than 200 MW**

The results of the linear regression analysis of CAPEX spending for wind plants greater than 200 MW are summarized in the table below and plotted in the figure below. Since the p-value for the age coefficient is 0.006, which is less than 0.05, the dataset does support age as a statistically significant predictor of CAPEX spending (on a linear trend across all plant ages). However, a visual inspection of the data in the graph below shows that there are a limited number of data points over 10 years, which may be skewing the regression.

**Table J-7 — Regression Statistics – Wind CAPEX for Greater than 200 MW**

	<i>t Statistic</i>		<i>p-value</i>
<b>Observations</b>	91		
<b>Simple Average (\$/kW)</b>	16.935		
<b>Intercept</b>	29.387	5.6538	1.87E-07
<b>Slope</b>	-2.474	-2.7612	6.99E-03
<b>R<sup>2</sup></b>	0.07891		

**Figure J-4 — Wind Dataset – CAPEX for Greater than 200-MW Plant Sizes**


The simple average CAPEX values for each five-year age band, expressed in constant 2017 \$/kW-year, are summarized in the table below.

**Table J-8 — Wind Greater than 200-MW Summary of Results**

	Average \$/kW-yr (Years 1-5)	Average \$/kW-yr (Years 6-10)	Average \$/kW-yr (All Years)	Data Points (Years 1-5)	Data Points (Years 6-10)	Data Points (All Years)
> 200 MW, All Capacity Factors						
Net Total CAPEX – 2017 \$/kW-yr	16.61	8.65	13.48	31	20	51

Starting with the initial analysis of CAPEX raw data, as presented above, Sargent & Lundy developed recommended changes to the existing values used in the EMM. The recommended changes for existing wind plants are described in Section 12.

## OPERATIONS & MAINTENANCE EXPENDITURES

### Full Dataset


The results of the linear regression analysis of O&M spending for wind plants of all MW sizes (full dataset) are summarized in the table below and plotted in the figure below. Since the p-value for the age coefficient is significantly less than 0.05, age is a statistically significant predictor of O&M spending (on a linear trend across all plant ages). Therefore, O&M spending for the dataset may be estimated by the regression equation:

$$\text{Annual O&M spending in 2017 \$/kW-year} = 31.661 + (1.222 \times \text{age})$$

**Table J-9 — Regression Statistics – Wind O&M for All MW**

	<i>t statistic</i>	<i>p-value</i>
Observations	580	
Simple Average (\$/kW)	42.680	
Intercept	31.661	12.7763
Slope	1.222	5.3515
R <sup>2</sup>	0.04721	1.26E-07

**Figure J-5 — Wind Dataset – O&M for All MW Plant Sizes**




**0-100 MW**

The results of the linear regression analysis of O&M spending for wind plants between 0 MW and 100 MW are summarized in the table below and plotted in the figure below. Since the p-value for the age coefficient is 0.003, which is less than 0.05, the dataset age is a statistically significant predictor of O&M spending (on a linear trend across all plant ages). Therefore, O&M spending for the dataset may be estimated by the regression equation:

$$\text{Annual O\&M spending in 2017 \$/kW-year} = 39.083 + (1.119 \times \text{age})$$

**Table J-10 — Regression Statistics – Wind O&M for 0-100 MW**

		<i>t Statistic</i>	<i>p-value</i>
Observations	339		
Simple Average (\$/kW)	49.888		
Intercept	39.083	9.0574	1.10E-17
Slope	1.119	2.9310	3.61E-03
R <sup>2</sup>	0.02486		

**Figure J-6 — Wind Dataset – O&M for 0-100-MW Plant Sizes**



**100-200 MW**

The results of the linear regression analysis of O&M spending for wind plants between 100 MW and 200 MW are summarized in the table below and plotted in the figure below. Since the p-value for the age coefficient is significantly less than 0.05, age is a statistically significant predictor of O&M spending (on a linear trend across all plant ages). Therefore, O&M spending for the dataset may be estimated by the regression equation:

Annual O&M spending in 2017 \$/kW-year = 23.797 + (1.174 × age)
---

**Table J-11 — Regression Statistics – Wind O&M for 100-200 MW**

	<i>t Statistic</i>	<i>p-value</i>
Observations	147	
Simple Average (\$/kW)	35.645	
Intercept	23.797	14.1919
Slope	1.174	6.5971
R <sup>2</sup>	0.23086	

**Figure J-7 — Wind Dataset – O&M for 100-200-MW Plant Sizes**


**Greater than 200 MW**

The results of the linear regression analysis of O&M spending for wind plants greater than 200 MW are summarized in the table below and plotted in the figure below. Since the p-value for the age coefficient is significantly less than 0.05, age is a statistically significant predictor of O&M spending (on a linear trend across all plant ages). Therefore, O&M spending for the dataset may be estimated by the regression equation:

Annual O&M spending in 2017 \$/kW-year = 26.783 + (0.925 × age)
---

**Table J-12 — Regression Statistics – Wind O&M Greater than 200 MW**

	<i>t statistic</i>	<i>p-value</i>
Observations	124	
Simple Average (\$/kW)	35.645	
Intercept	26.783	17.5334
Slope	0.925	7.0885
R <sup>2</sup>	0.29171	


**Figure J-8 — Wind Dataset – O&M for Plant Sizes Greater than 200 MW**


Exhibit DG-7

**Southwestern Public Service Company**

**Capital Additions**

**April 1, 2018 through March 31, 2019**

Asset Class	Additions to Plant-in-Service (April 1, 2018 - March 31, 2019)		Additions to Plant-in-Service (April 1, 2018 - March 31, 2019) NM Retail
	Total Company		
Steam Production	\$ 39,843,569	\$	11,029,215
Other Production	1,210,856		335,181
Electric Transmission	256,772,854		52,507,979
Electric Distribution	100,309,251		35,534,299
Electric General	42,013,242		11,663,475
Electric Intangible	18,371,298		5,101,149
<b>Grand Total</b>	<b>\$ 458,521,070</b>	<b>\$</b>	<b>116,171,298</b>

Witness	Additions to Plant-in-Service (April 1, 2018 - March 31, 2019)		Additions to Plant-in-Service (April 1, 2018 - March 31, 2019) NM Retail
	Total Company		
Harkness	\$ 27,021,325	\$	7,502,520
Bick	8,221,359		2,282,366
Lytal	42,028,513		11,634,816
Meeks	111,597,408		38,668,052
Cooley	269,652,466		56,083,543
<b>Grand Total</b>	<b>\$ 458,521,070</b>	<b>\$</b>	<b>116,171,298</b>

Production Assets allocated using 12CP-PROD (27.68%).

Transmission Assets primarily allocated using 12CP-TRAN (20.45%). Radial Line assets direct assigned.

Distribution Assets direct assigned according to location.

General Plant allocated using LABXAG (27.76%).

Intangible Plant primarily allocated using LABXAG (27.76%) with one project allocated by CUST-RET (31.08%).

# Exhibit DG-7

Attachment LJW-2

Page 2 of 25

Case No. 19-00170-UT

Southwestern Public Service Company  
Capital Additions  
April 1, 2018 through March 31, 2019

(A)	(B)	(C)	(D)	(E)	(F)	(G)
Line No.	Asset Class	Witness	Project Category	WBS Level 2	Project Description (WBS Level 2 Description)	Additions to Plant-in- Service (April 1, 2018 - March 31, 2019) Total Company
1	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001555.500	TOL1-C-Rpl MDBRP Discharge Vlv	\$ 178,334
2	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001555.500	TOL1-C-Rpl Boiler Frt Elevator	3,175
3	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001555.500	TOL1-C-Rpl BlrDrn E Ccenter Sfty	25,208
4	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001555.500	TOL1-C-Rpl West Main Stm Shy	(9,986)
5	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001555.500	TOL1-C-HydrogenGen Power Sys	49,176
6	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001555.500	TOL1-C-Rwd W Blr Circ Pump Mtr	100,489
7	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001555.500	TOL1-C-Rpl CT Partition Walls	238,005
8	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001555.500	TOL1-C-Rpl Reactor 1 Inlet Pipe	23,986
9	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001555.500	TOL2-C-Rewind Generator Rotor	602,248
10	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001555.500	TOL1-C-Rpl Millf MainVrt Shaft	1,374,614
11	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001555.500	TOL2-C-Gen Stator Rewedge	271,793
12	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001555.500	TOL2-C-Inst Reactor Xlmr DisGasAnly	75,236
13	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001555.500	TOL2-C-Bull Ring Assembly	12,811
14	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001555.500	TOL2-C-Inst Recifier RMU	6,467
15	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001555.500	TOL1-C-Rewind CT Cell #6 Motor	7,820
16	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001555.500	TOL1-C-Rewind CT Cell #14 Motor	7,418
17	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001555.500	TOL1-C-Rewind CT Cell #18 Motor	7,558
18	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001555.500	TOL2-C-Inst SwingGate&LadderProt	2,092
19	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001555.500	TOL2-C-Inst SSBAC Oil Cooler	57,831
20	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001555.500	TOL2-C-Rpl Center AuxCirc Dis Vlv	8,864
21	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001555.500	TOL2-C-Rpl Bull Ring Assmbly 2C	16,949
22	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001555.500	TOL2-C-Rpl Horz Well 99E Pump	20,245
23	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001555.500	TOL2-C-S SBAC OYH 2017-22573	83,440
24	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001555.500	TOL1-C-W Rev Gas Mir Rvnd	(881)
25	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.035	HAR2-C-Rpl Boiler Economizer	(294)
26	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.500	HAR2-C-CT S Cond Pump Element	4,189,538
27	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.500	HAR2-C-Rpl CT Cell #2 Mechanicals	80,736
28	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.500	HAR2-C-Rpl W #2 O2 Probe	6,004
29	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.500	HAR2-C-W Circ Pump Wire Replaced	22,246
30	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.500	HAR2-C-Install Eye Wash Station	23,337
31	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.500	HAR2-C-CT N Circ Pump Mtr Rewind	136,533
32	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.500	HAR2-C-Rpl O2 Probes	37,795
33	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.500	HAR2-C-CTMU Pump Rpl Rotating Assy	21,631
34	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.500	HAR2-C-Rpl W FD Fn Oil Clr' Tubes	19,678
35	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.500	HAR2-C-Rpl Pond 7 Floating Pump	6,158
36	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.500	HAR2-C-Rpl ACI Diverter Valves	4,460
37	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.500	HAR2-C-SUBPP Motor Rewind	3,168
38	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.500	HAR2-C-CESP BFP Element	58,603
39	Steam Production	Lytal	Environmental Compliance	A.0001550.500	HAR2-C-Rpl BGase Inlet Duct Exp Jnts	46,389
40	Steam Production	Lytal	Environmental Compliance	A.0001550.500	HAR2-C-Rpl Defation Fan Motors	36,325
41	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.500	HAR2-C-Rpl #2 FWHT 2B Valve	17,716
42	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.500	HAR2-C-3D SBAC Motor Rewind	40,365
43	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.500	HAR2-C-Rpl N CT Circ Pump cable	17,174
44	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.500	HAR2-C-Swing gates and ladder	47,086
						118,168
						32,710

Southwestern Public Service Company  
Capital Additions  
April 1, 2018 through March 31, 2019

Exhibit DG-7

Attachment LJW-2  
Page 3 of 25  
Case No. 19-00170-UT

Line No.	Asset Class	Witness	Project Category	WBS Level 2	Project Description (WBS Level 2 Description)	(E)	(F)	(G)
				Additions to Plant-in-Service (April 1, 2018 - March 31, 2019)		Total Company	NM Retail	Additions to Plant-in-Service (April 1, 2018 - March 31, 2019)
45	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.500	HAR2C-Inst CT Cable tray	59.589	59.589	16,495
46	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.500	HAR3C-Aux Ctg Wtr Pmp Mrk Rwd	60,012	60,012	16,612
47	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.500	HARC-Inst Vln on BD Recovery	80,571	80,571	22,303
48	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.500	HAR3C-Rpl FWH3 Steam Separator	10,673	10,673	2,954
49	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.500	HAR3C-Rpl W44 O2 Probe	11,002	11,002	3,046
50	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.500	HAR3C-N ACW Pump Mrk Rwd	17,393	17,393	4,815
51	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.500	HAR3C-C BCP Mrk Rwd	46,210	46,210	12,791
52	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.500	HAR3C-Rpl N Cond Bst Pump Cable	20,253	20,253	5,606
53	Steam Production	Lytal	Environmental Compliance	A.0001550.500	HAR3C-Rpl Dust Spkrn Pump Cable	25,697	25,697	7,113
54	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.500	HAR3C-Rpl FWH3 Shell relief vlv	8,758	8,758	2,424
55	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.500	HAR2C-W Seal Trough Wtr Pump Rpl	5,485	5,485	1,518
56	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.500	HAR3C-Rpl #2 Corne Tilt Drives	48,276	48,276	13,363
57	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.500	HAR3C-Rpl FWH2 Steam Separator	10,058	10,058	2,784
58	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.283	HAR3C-Rpl APH Baskets	1,623,841	1,623,841	449,500
59	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.296	TOL2C-Rpl Main Pwr Transformer	1,603,155	1,603,155	443,774
60	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.475	HAR3C-Rpl CT Bottom Structure	1,227,170	1,227,170	339,596
61	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.226	TOL2C-Rpl Mill E Gearbx & Jour	1,175,533	1,175,533	325,403
62	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.113	TOL2C-Rpl RR Ties PH 3 of 5	1,123,730	1,123,730	311,063
63	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.257	TOL1C-UplDCCSOpSIn& CutnProc	1,105,121	1,105,121	305,912
64	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.093	TOL2C-Rpl RR Ties PH 4 of 5	1,036,417	1,036,417	286,894
65	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.223	TOL1C-Rpl MillC Gearbx & Jrnls	856,916	856,916	237,206
66	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.309	HAR3C-H3 Upgr DCS Opr stn	776,877	776,877	215,050
67	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.597	TOL1C-Rpl Coal Pipe & Elbows	776,483	776,483	214,941
68	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001545.500	CHCOC-Waste Water P-Pond Pump	203	203	56
69	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001545.500	CHC2C-Sphlt Spray Blck Vlv	26,817	26,817	7,423
70	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001545.500	CHCOC-Rpl Gas Sys SRV	37,149	37,149	10,283
71	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001545.500	CHC2C-Anodamine Cf System	1,139	1,139	315
72	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001545.500	CHCOC-MaxiVol Equipment	12,058	12,058	3,338
73	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001545.500	CHC2C-HRH Piping Abate&Reins	530,070	530,070	146,730
74	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001545.500	CHC2C-Sphlt Spray Blck Vlv	13,138	13,138	3,637
75	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001545.500	CHC2C-Rpl Elevator Gearbox	63,842	63,842	17,672
76	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001545.500	CHCOC-Inst Ladder Swing Gates	53,990	53,990	14,945
77	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001545.500	JON3C-Fire System Iso Vlvs	502	502	139
78	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001545.500	JON3C-Rpl UF Modules	40,559	40,559	11,227
79	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001545.500	JON2C-Rpl Diesel Fire Pmp Vlv	13,540	13,540	3,748
80	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001545.500	JON3C-Inst Rectifier RMU	3,774	3,774	1,045
81	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001545.500	JON3C-Smart Pig Test	472,480	472,480	130,788
82	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001545.500	JON3C-Rpl HP FWH #1 & #2	27,941	27,941	7,734
83	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001545.500	JON2C-Rpl HP FWH #2	27,485	27,485	7,608
84	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001545.500	JON2C-Rpl CT Motor Cell #3	12,939	12,939	3,582
85	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001545.500	JON2C-Rpl CT Motors	23,786	23,786	6,584
86	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001545.500	JON3C-Inst Ladder Swing Gates	34,174	34,174	9,460
87	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001545.500	JON2C-Rpl Aux Blr Wtr Vlv	11,187	11,187	3,097
88	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001545.500	JON3C-Rpl Fire Sys Chk Vlv	10,655	10,655	2,950

# Exhibit DG-7.

Attachment LJW-2

Page 4 of 25

Case No. 19-00170-UT

**Southwestern Public Service Company  
Capital Additions  
April 1, 2018 through March 31, 2019**

(A) Line No.	(B) Asset Class	(C) Witness	(D)	(E)	(F) Additions to Plant-in- Service (April 1, 2018 - March 31, 2019) Total Company	(G) Additions to Plant-in- Service (April 1, 2018 - March 31, 2019) NM Retail
89	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001586.500 A.0001586.500	JON2C-Rpl Gas Density Analyzer JON2C-E Rpl CT Bypass Vlv	5,394
90	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001586.500	JON2C-Rpl Economizer Exp Jnts	39
91	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001586.500	MADIC-Rpl Main Sim SeaReg Vlv	(202)
92	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001529.500	MADIC-Rpl DC Lube Oil Motor	7291
93	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001529.500	MADIC-Rpl Basement Heater	(71)
94	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001529.500	MADOC-Rpl Main Pinnacle Gas Vlv	232
95	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001529.500	MADOC-Inst Ladder Swing Gates	7,696
96	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001529.500	MADIC-Rpl HRH Terminal Tubes	6,733
97	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001529.500	PLX0C-Rpl 50T-ST Turb Crane-20816	166,608
98	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001534.157	TOLI-C-Rpl Burner Assemblies	185,020
99	Steam Production	Lytal	Reliability & Performance Enhancement	A.000155.043	HARDC-H2 Install Ash Silo Elev	160,928
100	Steam Production	Lytal	Reliability & Performance Enhancement	A.000155.006	MADIC-Rpl #1 HP FWH-20820	156,651
101	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001529.067	NIC3C-CT Fan Stacks	146,612
102	Steam Production	Lytal	Reliability & Performance Enhancement	A.000156.117	NIC3C-Rpl Roof-Turb High	529,643
103	Steam Production	Lytal	Reliability & Performance Enhancement	A.000155.244	HARDC-Rpl SBAC Controls	144,952
104	Steam Production	Lytal	Environmental Compliance	A.000155.089	TOL2C-Rpl Baghouse Bags 2018	486,622
105	Steam Production	Lytal	Reliability & Performance Enhancement	A.000155.446	HARIC-CT Fan Stacks	134,703
106	Steam Production	Lytal	Reliability & Performance Enhancement	A.000155.450	HARIC-Rpl CT Fan Stacks	131,690
107	Steam Production	Lytal	Reliability & Performance Enhancement	A.000156.123	NIC3C-CT Mechanicals Phase 1	129,735
108	Steam Production	Lytal	Reliability & Performance Enhancement	A.000154.122	CHC2C-Urg DCS Hardware	468,675
109	Steam Production	Lytal	Reliability & Performance Enhancement	A.000152.024	MADIC-Rpl CS APH Basket&Seals	404,132
110	Steam Production	Lytal	Reliability & Performance Enhancement	A.000155.250	HARIC-Rpl CT Mechanicals Ph2	128,778
111	Steam Production	Lytal	Reliability & Performance Enhancement	A.000152.032	MADIC-Rpl MI Elevator	461,611
112	Steam Production	Lytal	Environmental Compliance	A.000156.118	NIC3C-Rpl Root-Turb Low	127,780
113	Steam Production	Lytal	Reliability & Performance Enhancement	A.000155.458	HARIC-Rpl Bgase Doors	427,632
114	Steam Production	Lytal	Reliability & Performance Enhancement	A.000158.253	JON1C-BP Elec Comp Rpl-21019	118,374
115	Steam Production	Lytal	Reliability & Performance Enhancement	A.000154.035	CHC2C-Rpl BFD Discharge Vlvs	397,843
116	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001586.287	JON2C-Rpl CT Makeup Piping	110,128
117	Steam Production	Lytal	Reliability & Performance Enhancement	A.000155.366	TOL1C-T1 #1FWH valves	107,326
118	Steam Production	Lytal	Reliability & Performance Enhancement	A.000156.500	NIC2C-BP Element Refurb	105,733
119	Steam Production	Lytal	Reliability & Performance Enhancement	A.000156.500	NIC0C-Inst #6 Slaker RR Supply	100,945
120	Steam Production	Lytal	Reliability & Performance Enhancement	A.000156.500	NIC3C-Rpl Hogging Jet Valves	364,027
121	Steam Production	Lytal	Reliability & Performance Enhancement	A.000156.500	NIC2C-Rpl Boiler Sump Pipe	100,167
122	Steam Production	Lytal	Reliability & Performance Enhancement	A.000156.500	NIC3C-Rpl SSR Bypass Actuator	95,152
123	Steam Production	Lytal	Reliability & Performance Enhancement	A.000156.500	NIC3C-Rpl Reverse Power Relays RP1-	677
124	Steam Production	Lytal	Reliability & Performance Enhancement	A.000156.500	NIC1C-Rewind N FD Motor *Corrected*	(226)
125	Steam Production	Lytal	Reliability & Performance Enhancement	A.000156.500	NIC2C-Rpl Hogging Jet Valves	4,647
126	Steam Production	Lytal	Reliability & Performance Enhancement	A.000156.500	NIC0C-Swing gates and ladders	21,166
127	Steam Production	Lytal	Reliability & Performance Enhancement	A.000156.500	NIC0C-Rpl Demin Sump Drain Line	5,329
128	Steam Production	Lytal	Reliability & Performance Enhancement	A.000156.500	NIC0C-Pond 1.8 Motor Rpl	4,235
129	Steam Production	Lytal	Reliability & Performance Enhancement	A.000156.500	NIC0C-House Air Comp Mtr	15,300
130	Steam Production	Lytal	Reliability & Performance Enhancement	A.000156.500	NIC1C-Rpl CT Makeup Cntr Vlv	1,708
131	Steam Production	Lytal	Reliability & Performance Enhancement	A.000156.500	NIC0C-Rpl System Lab HVAC	(35)
132	Steam Production	Lytal	Reliability & Performance Enhancement	A.000156.500	NIC0C-Rpl Aux Boiler Feed Pump	2,602
						16,194

Southwestern Public Service Company  
Capital Additions  
April 1, 2018 through March 31, 2019

Exhibit DG-7

Attachment LJW-2  
Page 5 of 25  
Case No. 19-00170-UT

Line No.	Asset Class	Witness	Project Category	WBS Level 2	Project Description (WBS Level 2 Description)	(E)	(F)	(G)
						Additions to Plant-in-Service (April 1, 2018 - March 31, 2019)	Total Company	Additions to Plant-in-Service (April 1, 2018 - March 31, 2019)
133	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001534.500	PLXIC-Rpl DA Pressure Rel Vlv	(0)	(0)	(0)
134	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001534.500	PLXIC-Rpl Yarway Drumlvl Xmtir	24,922	6,899	6,899
135	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001534.500	PLXIC-Rpl West Blowdown Vlv	10,031	2,777	2,777
136	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001534.500	PLXIC-Rpl SH/RH Spray block Vlv	5,791	1,603	1,603
137	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001534.500	PLXIC-Rpl Bldn Throttling Vlv	6,491	1,797	1,797
138	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001534.500	PLXIC-Rpl Inst Air Comp	81,211	22,480	22,480
139	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001534.500	PLXOC-Inst SwingGate&LadderProt	23,690	6,558	6,558
140	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001534.500	PLXOC-Rpl SH/RH Stay Auto Blk/VLV	29,904	8,278	8,278
141	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001534.500	PLXAC-Rpl HP Heater Safeties	14,537	4,024	4,024
142	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001534.500	PLXOC-Replace Water Wells	30,780	8,520	8,520
143	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001534.500	PLXOC-E FD Fan Motor Rwd	51,768	14,330	14,330
144	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001534.500	TOLOC-Rpl Receiving WH Roof	273,849	75,805	75,805
145	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001534.031	CHC2C-Rpl BFP Fluid Drives	270,951	75,003	75,003
146	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001530.479	HAR3C-Rpl EHC Pump Sys	261,741	72,453	72,453
147	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001560.115	NICO-C-Install Demin Wtr Supply	260,255	72,042	72,042
148	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.021	HAROC-Rpl Paving Phase 5/6	252,260	69,829	69,829
149	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.057	MAD1C-Rpl Air Preht Exp Joint	243,217	67,326	67,326
150	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.455	HAR3C- ACW Heat Exchangers	234,268	64,848	64,848
151	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001555.120	TOLOC-Inst Permit FencePonds	232,148	64,262	64,262
152	Steam Production	Lytal	Environmental Compliance	A.0001586.265	JON2C-CEM's Upgrade-19975	216,486	59,926	59,926
153	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.028	HAR2C-Rpl CT Acid Tank	210,340	58,225	58,225
154	Steam Production	Lytal	Environmental Compliance	A.0001586.264	JON1C-CBEM's Upgrade-19976	208,087	57,601	57,601
155	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001555.370	TOLC2-RPL Boiler Stump Line T2	203,910	56,445	56,445
156	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001556.073	JON1C-Inst Backflow Prv on HT	193,923	53,680	53,680
157	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.034	HAROC-Rpl Paving Phase 6/6	180,040	49,837	49,837
158	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001555.595	TOLIC-Cooling Tower Bypass	173,448	48,013	48,013
159	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001586.285	JON2C-Rpl Circ Pump Svc Hood	170,659	47,241	47,241
160	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001555.254	TOLIC-Rpl SSC Chain 2018	163,793	45,894	45,894
161	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.083	HAR3C-H3 Rpl Lab Analyzers 201	151,767	42,011	42,011
162	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001534.172	PLXOC-Rpl Lab Analyzers	140,631	38,929	38,929
163	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001555.594	TOLIC-Int Online Vib Mtrr Sys	140,414	38,868	38,868
164	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.151	HAR3C-H3 Rebag Partial 2018	132,478	36,672	36,672
165	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001555.599	TOLOC-Int Online Vib Mtrr Sys	120,957	33,483	33,483
166	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001555.060	TOLOC-Rpl Water Well Pump 2018	118,257	32,735	32,735
167	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001560.079	NICO-C-Rpl Lab Analyzers	111,612	30,896	30,896
168	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001555.358	TOLIC-RPL Boiler Stump Line	107,985	29,892	29,892
169	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001545.254	CHC2C-Rpl Burner Trits-21235	104,421	28,905	28,905
170	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001545.255	CHC2C-Rpl CT Suction Screens-21237	100,689	27,872	27,872
171	Steam Production	Lytal	Environmental Compliance	A.0001500.443	HAR1C- ESP Re-build TR-sets PH2	91,868	25,430	25,430
172	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.473	HAR3C-Inst Online Vib Mtrr Sys	88,416	24,475	24,475
173	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001560.116	NICO-C-Rpl Roof-Maint Shop	82,782	22,915	22,915
174	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001545.073	CHCOC-Rpl Watervel 1 Pmp Mtr	80,176	22,194	22,194
175	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001545.300	CHCOC-Rpl Lab Analyzers	73,779	20,423	20,423
176	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001534.171	PLXOC-Rof Drains Reader	73,699	20,401	20,401

# Exhibit DG-7

Attachment LJW-2

Page 6 of 25

Case No. 19-00170-UT

Southwestern Public Service Company  
Capital Additions  
April 1, 2018 through March 31, 2019

(A)	(B)	(C)	(D)	(E)	(F)	(G)
Line No.	Asset Class	Witness	Project Category	WBS Level 2	Project Description (WBS Level 2 Description)	Additions to Plant-in- Service (April 1, 2018 - March 31, 2019) Total Company
177	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.082	HAR3-C-H3 Rpl Drag Chain 2018	71,344
178	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001545.083	CHC0-C-Rpl Water Well Mtr 2017	71,264
179	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001555.363	TOL1-C-Rpl Rev gas expansion joints	69,636
180	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001545.305	CHC2-C-Rpl Lab Analyzers	65,132
181	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001545.046	CHC0-C-Refurb Plant Bathroom	60,166
182	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001545.257	CHC0-C-Rpl TUCO Roof 21291	56,709
183	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001534.185	PLX3-C-Condensate Suction Pipe	53,483
184	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001534.190	PLX4-C-Rpl Feedwater Analyzers	51,241
185	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001529.036	MADIC-C-Rpl Turbine Oil Centrifuge	46,676
186	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.481	HAR0-C-Tmg Cntr Fire Detection	42,399
187	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001534.184	PLX3-C-Rpl Feedwater Analyzers	40,505
188	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001545.304	CHC2-C-Inst Onln Vib Mtr Sys	37,599
189	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001534.072	JON2-C-Rpl Gas Firing Valve	37,199
190	Steam Production	Lytal	Environmental Compliance	A.0001550.461	HAR0-C-Inst Above Grade Fuel Tanks	31,468
191	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001529.052	MADOC-Tornado Shelter	28,874
192	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001586.260	JON1-C-CT See pH Probe-21239	27,971
193	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.278	TOL0-C-Drill Horizontal Water Well	27,463
194	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001586.072	PLX0-C-Rpl Relay & Conduit/RinFloors	26,704
195	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.461	JON2-C-CT See pH Probe-21238	26,343
196	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001555.364	TOL1-C-Rpl east rev gas fan damper	23,338
197	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.262	HAR1-C-SBA/C 1B Mfr Rebid 2017	18,120
198	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001545.303	CHC1-C-Rpl Lab Analyzers	13,664
199	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001534.194	HAR2-C-Rpl H2 Mill E Exhauster	11,862
200	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001534.174	PLX1-C-Rpl Boiler PH Analyzers	11,589
201	Steam Production	Lytal	Environmental Compliance	A.0001555.990	TOL1-C-Ahate & Reinstate DA	9,754
202	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001534.178	PLX2-C-Rpl Boiler pH Analyzers	8,442
203	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001555.596	TOL0-C-Rpl Lab Sample System	8,000
204	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001555.212	TOL0-C-Rpl Water Well Pmp 2019	7,085
205	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001536.142	JON1-C-Rpl Oil Circ Brk JK00	4,923
206	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001586.055	JON1-C-Ahate & Reinstate DA	2,288
207	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001555.057	TOL0-C-Rpl Water Well Pmp 2017	1,492
208	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001586.262	JON1-C-Circ Water Struct Liner 19992	1,025
209	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001529.065	MADIC-C-Rpl Lab Analyzers-21292	508
210	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001586.261	JON1-C-Replace CP's-19974	485
211	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001586.129	JON1-C-Rpl Rosemount 1151 XMTR'S	210
212	Steam Production	Lytal	Environmental Compliance	A.0001550.462	HAR0-C-Remove UG Fuel Tanks	186
213	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001555.030	TOL0-C-TolEx Water Well Ph 7	176
214	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001586.283	JON1-C-Rpl CT Bypass Vv	160
215	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.275	HAR2-C-Rpl SH Spray Valves	37
216	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001586.014	JON2-C-E-Rpl Mech Draft 3&8	28
217	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.137	HAR2-C-H2 Rpl Lab Analyzers 201	10
218	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.142	HAR1-C-Cooling Tower Structure	(1)
219	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001555.219	TOL1-C-Rpl MillB Gearbox & Jml	(20)
220	Steam Production	Lytal	Reliability & Performance Enhancement	A.000156.141	JON1-C-Rpl IP's with DVC	(87)

Southwestern Public Service Company  
Capital Additions  
April 1, 2018 through March 31, 2019

Exhibit DG-7

Attachment LJW-2  
Page 7 of 25  
Case No. 19-00170-UT

Line No.	Asset Class	Witness	Project Category	WBS Level 2	Project Description (WBS Level 2 Description)	(E)	(F)	(G)
					Additions to Plant-in-Service (April 1, 2018 - March 31, 2019) Total Company		Additions to Plant-in-Service (April 1, 2018 - March 31, 2019) NM Retail	
221	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001550.109	HARI-C-H1 Rpl Condenser Circ Pi			
222	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001586.295	JON/C-Rpl Portable Vibration DAS	(7,956)	(2,203)	
223	Steam Production	Lytal	Reliability & Performance Enhancement	A.0001586.081	JON/C-Rpl Seamed HRF Piping	(123,637)	(34,224)	
224	Steam Production	Lytal	Environmental Compliance	A.0001555.088	TOL/C-Rpl Baghouse Bags 2018	(137,462)	(33,051)	
	<b>Steam Production Total</b>					<b>\$ 39,843,569</b>	<b>\$ 11,025,215</b>	
226	Other Production	Lytal	Reliability & Performance Enhancement	A.0001586.291	JON3/C-Rpl Exh Expansion Joint			
227	Other Production	Lytal	Reliability & Performance Enhancement	A.0001545.501	CHC3/C-Rpl GT Inlet Air Filters			
228	Other Production	Lytal	Reliability & Performance Enhancement	A.0001545.501	CHC4/C-Rpl GT Inlet Air Filters			
229	Other Production	Lytal	Reliability & Performance Enhancement	A.0001545.501	CHC3/C-Rpl Submersible Pump			
230	Other Production	Lytal	Reliability & Performance Enhancement	A.0001545.501	CHC3/C-Rpl Generator Prot Relays			
231	Other Production	Lytal	Reliability & Performance Enhancement	A.0001545.501	CHC4/C-Rpl Generator Prot Relays			
232	Other Production	Lytal	Reliability & Performance Enhancement	A.0001586.294	JON4/C-Rpl Exh Expansion Joint			
233	Other Production	Lytal	Reliability & Performance Enhancement	A.0001529.501	MAD2C-Xfmr Rewind and Wire			
234	Other Production	Lytal	Reliability & Performance Enhancement	A.0001529.501	MAD2C-Rpl Fuel Ctrl V/V			
235	Other Production	Lytal	Reliability & Performance Enhancement	A.0001529.501	MAD2C-Rpl Crane Pwr Supply			
236	Other Production	Lytal	Reliability & Performance Enhancement	A.0001529.501	MAD2C-Rpl AC Units Elec Pkg			
237	Other Production	Lytal	Reliability & Performance Enhancement	A.0001529.080	MAD3C-Rpl Exhaust Stack			
238	Other Production	Lytal	Reliability & Performance Enhancement	A.0001586.501	JON4/C-Rpl Turning Gear Gearbox			
239	Other Production	Lytal	Reliability & Performance Enhancement	A.0001586.501	JON3/C-Rpl Gen Cooler Bypass Act			
240	Other Production	Lytal	New Generation	A.0001577.002	Hale-Land & Land Rights			
241	Other Production	Lytal	Reliability & Performance Enhancement	A.0001554.501	QUAC-C-Rpl Starting Diesel Rad			
242	Other Production	Lytal	Reliability & Performance Enhancement	A.0001554.003	QUAC-C-Rpl Emergency Diesel Generator			
243	Other Production	Lytal	Reliability & Performance Enhancement	A.0001621.001	GMSOC-Gaines City Gen Project			
	<b>Other Production Total</b>					<b>\$ 139</b>	<b>\$ 3,944</b>	<b>39</b>
244	<b>Other Production Total</b>					<b>\$ 1,210,856</b>	<b>\$ 335,181</b>	
245	Electric Transmission	Cooley	RE		Kiowa-North Loving 345kV Line			
246	Electric Transmission	Cooley	RE		N Loving-China Draw 345kV Line			
247	Electric Transmission	Cooley	RE		Atoka-Eagle Creek 115kV Line			
248	Electric Transmission	Cooley	RE		Walkemeyer 345/115 Sub			
249	Electric Transmission	Cooley	SR		SPS ELR 115kV TX 2016			
250	Electric Transmission	Cooley	RE		Roosevelt County Substation			
251	Electric Transmission	Cooley	RE		Carlisle to Wofforth Crisile			
252	Electric Transmission	Cooley	RE		N Loving Sub Xfm 345kV/115kV			
253	Electric Transmission	Cooley	RE		Road Runner Sub Xfm 345kV_UID			
254	Electric Transmission	Cooley	RE		C Draw 345kV Sub N Loving Term			
255	Electric Transmission	Cooley	RE		Kiowa Sub Xfm Bus/Rotash Ter			
256	Electric Transmission	Cooley	RE		TUCO-Yoakum 345kV ROW UID 5044			
257	Electric Transmission	Cooley	RE		C Draw Sub Xfm 345kV/115kV_UU			
258	Electric Transmission	Cooley	SR		SPS ELR 115kV NM 2016			
259	Electric Transmission	Cooley	RE		N Loving Sub Kiowa/C Draw Term			
260	Electric Transmission	Cooley	RE		NE Hensford to New Center St.			
261	Electric Transmission	Cooley	LI		Inst 230kV Sw Station XcelPortion			
262	Electric Transmission	Cooley	RE		OPIE Potash-Livingston Ridge			

Southwestern Public Service Company  
 Capital Additions  
 April 1, 2018 through March 31, 2019

Exhibit DG-7

Attachment LJW-2

Page 8 of 25

Case No. 19-00170-UT

Line No.	Asset Class	Witness	Project Category	WBS Level 2	Project Description (WBS Level 2 Description)	(D)	(E)	(F)	(G)
						Additions to Plant-in-Service (April 1, 2018 - March 31, 2019)	Total Company	Additions to Plant-in-Service (April 1, 2018 - March 31, 2019)	NM Retail
263	Electric Transmission	Cooley	RE	A.0000199.001	Custer Mountain-Ochoa Recondutor SPS 2016 S&E B 230kV Line	3,761,552	3,660,266	759,207	748,495
264	Electric Transmission	Cooley	SR	A.0000303.007	NE Hereford Sub	3,649,792	3,609,270	746,353	738,067
265	Electric Transmission	Cooley	RE	A.0000296.008	SPS S&E 115kV Line TX 2016	3,333,790	3,333,790	681,733	665,174
266	Electric Transmission	Cooley	SR	A.0000303.045	South Ponales-Market Street L	3,252,815	3,252,815	641,155	641,155
267	Electric Transmission	Cooley	RE	A.0000463.008	345/115kV 448MVVA XfmrspareSub	3,135,356	3,135,356	618,521	589,061
268	Electric Transmission	Cooley	SR	A.0001267.001	W40 Rebuild Dawn to Panda Tap	3,024,673	2,880,609	576,662	538,103
269	Electric Transmission	Cooley	RE	A.0001319.006	Seminole Xmn 1	2,819,976	2,819,976	534,105	534,105
270	Electric Transmission	Cooley	RE	A.0000494.001	SPS Physical Security Sub Infrastru	2,467,078	2,442,386	499,448	475,547
271	Electric Transmission	Cooley	OT	A.0000710.003	Curry Co Dist Xfmr Conversion	2,325,506	2,325,506	444,474	444,474
272	Electric Transmission	Cooley	RE	A.0000860.003	Cochran 115 Cap Bank	2,173,554	2,173,554	422,214	422,214
273	Electric Transmission	Cooley	RE	A.0000194.001	Road Runner Sub 345kV Conv UID	2,084,695	2,084,695	419,158	419,158
274	Electric Transmission	Cooley	RE	A.0000424.093	IMC1-Innreipd West 115kv Recd	1,916,371	1,916,371	391,882	390,638
275	Electric Transmission	Cooley	RE	A.0000424.143	Monument-Byrd 115kvRecord Line	1,848,868	1,848,868	378,079	378,079
276	Electric Transmission	Cooley	RE	A.0000424.136	Yoakum 23/115 Xfmr 1 Upgrade	1,826,818	1,826,818	373,570	373,570
277	Electric Transmission	Cooley	RE	A.0001326.001	Potash Sub 115 kv Terminal Sub	1,784,111	1,784,111	364,836	364,836
278	Electric Transmission	Cooley	RE	A.0002049.001	Wreckout/Rebuild 115KV Line#24	1,758,973	1,758,973	359,696	355,288
279	Electric Transmission	Cooley	RE	A.0001300.014	AMOCO Breaker Relimit	1,737,417	1,737,417	346,023	346,023
280	Electric Transmission	Cooley	SR	A.0000640.023	Kiowa 345kV Sub N Loving Term	1,692,109	1,692,109	344,160	344,160
281	Electric Transmission	Cooley	RE	A.0000424.160	New 230/115KV Transformer	1,683,000	1,683,000	333,024	333,024
282	Electric Transmission	Cooley	RE	A.0000481.012	SPS 23/10kV ELR TX 2016	1,628,544	1,628,544	329,200	329,200
283	Electric Transmission	Cooley	SR	A.0000499.015	OPIE 2_Hobbs-Kiowa 145kV Line	1,609,843	1,609,843	324,140	324,140
284	Electric Transmission	Cooley	RE	A.0000424.037	Capill 14.4 Myan Cap Bank	1,578,973	1,578,973	312,600	312,600
285	Electric Transmission	Cooley	RE	A.0001272.001	W40 Reblid Panda Tap Deaf Smith	1,572,678	1,572,678	298,209	298,209
286	Electric Transmission	Cooley	RE	A.0001319.005	Kiowa 345kV/Sub Road Runner Ter	1,458,291	1,458,291	293,848	293,848
287	Electric Transmission	Cooley	RE	A.0000424.089	SPS Major Line Reblid 69kV TX 2016	1,436,966	1,436,966	282,765	282,765
288	Electric Transmission	Cooley	SR	A.0000469.015	Lea Co. Plains Sw. Cap Bank	1,398,907	1,398,907	267,877	267,877
289	Electric Transmission	Cooley	RE	A.0001283.001	Cochran Whiteface Z26 Rebuild	1,369,966	1,369,966	256,784	256,784
290	Electric Transmission	Cooley	RE	A.0000194.008	Outpost Highside	1,343,366	1,343,366	233,809	233,809
291	Electric Transmission	Cooley	RE	A.0000846.001	Texas Co Rpt Breakers 800, 804	1,309,966	1,309,966	198,134	198,134
292	Electric Transmission	Cooley	SR	A.0000220.006	SPS 2016 S&E Sub	962,879	962,879	196,901	196,901
293	Electric Transmission	Cooley	RE	A.0000424.145	Potash-Jeffrid West 115kvRecd	962,702	962,702	196,865	196,865
294	Electric Transmission	Cooley	SR	A.0000303.044	SPS S&E 69kV Line TX 2016	890,170	890,170	182,033	182,033
295	Electric Transmission	Cooley	RE	A.000078.012	Soney Dist. Transformer Conv.	861,651	861,651	176,201	176,201
296	Electric Transmission	Cooley	SR	A.0000640.020	Monument-Byrd ROW	840,491	840,491	171,874	171,874
297	Electric Transmission	Cooley	RE	A.0001300.013	NEP-Targa Recondutor				
298	Electric Transmission	Cooley	RE	A.0000424.040	115kV Line Tap to Soncy Line				
299	Electric Transmission	Cooley	RE	A.0000616.001	SPS S&E 145kV Line KS 2016				
300	Electric Transmission	Cooley	RE	A.0000424.137	New Centre St 115kV Sub				
301	Electric Transmission	Cooley	RE	A.0001285.001	Z09 69kV Line Removal Trans				
302	Electric Transmission	Cooley	RE	A.0000616.002	Finnley Holcomb Relay Upgrade				
303	Electric Transmission	Cooley	SR	A.0000303.050					
304	Electric Transmission	Cooley	RE	A.0000296.006					
305	Electric Transmission	Cooley	RE	A.0000522.009					
306	Electric Transmission	Cooley	SR	A.0000893.001					

Southwestern Public Service Company  
Capital Additions  
April 1, 2018 through March 31, 2019

Exhibit DG-7

Attachment LJW-2

Page 9 of 25

Case No. 19-00170-UT

(A) Line No.	(B) Asset Class	(C) Witness	(D) Project Category	(E) WBS Level 2	(F) Project Description (WBS Level 2 Description)	(G) Additions to Plant-in-Service (April 1, 2018 - March 31, 2019) Total Company NM Retail
307	Electric Transmission	Cooley	RE	A.0001310.002	Retern 345kV Line Old 37	747,384
308	Electric Transmission	Cooley	RE	A.0001310.001	Retern 345kV Line 37	746,883
309	Electric Transmission	Cooley	SR	A.0001273.020	Roosevelt Breaker 4K65 Replacement	740,745
310	Electric Transmission	Cooley	RE	A.0000259.005	Cunningham Ing. Upgrade Eddy 230kV	735,193
311	Electric Transmission	Cooley	GI	A.0000736.005	Toll Needmore Termination	690,440
312	Electric Transmission	Cooley	RE	A.0002949.002	Potash Kiowa 115kV Line	651,515
313	Electric Transmission	Cooley	RE	A.0000424.120	N Loving-S Loving 115 kVROW	647,472
314	Electric Transmission	Cooley	OT	A.0000795.001	SPS Sub Conn Network Group 1 L	629,734
315	Electric Transmission	Cooley	GI	A.0000105.007	Plant X Terminal Upgrades TX	629,421
316	Electric Transmission	Cooley	RE	A.0000424.088	Kiowa-Road Runner 345kV Line_U	617,448
317	Electric Transmission	Cooley	SR	A.0000459.018	Line BLR SPS OK 115kV	601,494
318	Electric Transmission	Cooley	SR	A.0000286.005	Horz Cap and Pin Replacement TX	593,242
319	Electric Transmission	Cooley	RE	A.0000513.005	Denver City Breaker W900 Replacement	567,130
320	Electric Transmission	Cooley	OT	A.0000710.001	NM PHYSICAL SECURITY Sub Infrastruc	554,950
321	Electric Transmission	Cooley	GI	A.0001183.006	ROG NEEDMORE TO YOAKUM 230kV LINE	549,752
322	Electric Transmission	Cooley	RE	A.0001319.007	W40 Recond Canyon W/Def Smith	509,341
323	Electric Transmission	Cooley	RE	A.0000511.021	Carl-W/Sundown Relay at Wo	502,881
324	Electric Transmission	Cooley	RE	A.0000916.010	Plant X 230kV LRU to Dead Smith	496,684
325	Electric Transmission	Cooley	RE	A.0000513.004	Denver City Breaker W970 Replacement	484,085
326	Electric Transmission	Cooley	RE	A.0000916.007	Remote End Upgrade for ring bus add	471,351
327	Electric Transmission	Cooley	SR	A.0000459.012	SPS ELR 69kV TX 2016	431,038
328	Electric Transmission	Cooley	RE	A.0000519.004	Oasis Relay Upgrade Sub	418,996
329	Electric Transmission	Cooley	RE	A.0000424.055	Custer Mt 115kV Sub Ponderosa	403,189
330	Electric Transmission	Cooley	LJ	A.0001048.009	R11 230kV BRU Mahoney TLLINE	400,415
331	Electric Transmission	Cooley	SR	A.0001067.001	Lubbock East K57 Relay Upgrade	382,017
332	Electric Transmission	Cooley	RE	A.0000511.001	Carlisle to Wolfforth 230 kVli	364,982
333	Electric Transmission	Cooley	RE	A.0000463.002	Portales Interchange Sub	359,947
334	Electric Transmission	Cooley	GI	A.0000736.006	Yakum Needmore Termination	359,027
335	Electric Transmission	Cooley	RE	A.0000126.004	Artesia Cy Club Switch	350,231
336	Electric Transmission	Cooley	GI	A.0000736.001	Needmore Substation T/O/F	349,078
337	Electric Transmission	Cooley	SR	A.0000220.018	SPS 2016 NM S&E Sub	344,910
338	Electric Transmission	Cooley	LJ	A.0001008.010	R12 230kV AWOR Mahoney TLLINE	343,735
339	Electric Transmission	Cooley	RE	A.0001319.011	Def Smith W40 Term Upgr	338,211
340	Electric Transmission	Cooley	RE	A.0000658.001	Yakum	335,589
341	Electric Transmission	Cooley	RE	A.0000511.004	Carlisle to Wolfforth Wolfforth	333,755
342	Electric Transmission	Cooley	RE	A.0000513.002	Castro Co Breaker 8825 Replacement	333,142
343	Electric Transmission	Cooley	RE	A.0000424.150	OPIE PTIJU Intrepid Term Sub	333,124
344	Electric Transmission	Cooley	SR	A.0000153.006	V02 Switch 2915 Replacement	313,476
345	Electric Transmission	Cooley	SR	A.0000153.008	V77 Switch 4963 Replacement NM	304,985
346	Electric Transmission	Cooley	SR	A.0001067.004	Lubbock-South K64 Relay Upgrade	304,349
347	Electric Transmission	Cooley	RE	A.0000290.006	Seven Rivers Ing. Upgrade Eddy 230	301,696
348	Electric Transmission	Cooley	RE	A.0000540.016	Atoka to Eagle Creek 115kV ROW	299,680
349	Electric Transmission	Cooley	SR	A.0000427.016	W14 798 Clearance Violations	296,067
350	Electric Transmission	Cooley	SR	A.0000153.005	NM Trans Switch Replace Line 69kV	290,042
						53,311

# Exhibit DG-7

Attachment LJW-2

Page 10 of 25

Case No. 19-00170-UT

**Southwestern Public Service Company  
Capital Additions  
April 1, 2018 through March 31, 2019**

(A)	(B)	(C)	(D)	(E)	(F)	(G)
Line No.	Asset Class	Witness	Project Category	WBS Level 2	Project Description (WBS Level 2 Description)	Additions to Plant-in-Service (April 1, 2018 - March 31, 2019) Total Company
351	Electric Transmission	Cooley	RE	A.0000488.009	Ochoa Terminal Work	271,959
352	Electric Transmission	Cooley	RE	A.00001300.022	Relay Upgr Roswell City Rosw Ing	266,550
353	Electric Transmission	Cooley	GI	A.00000350.005	Lost Draw to Cochran Retermination	263,538
354	Electric Transmission	Cooley	LI	A.00001126.002	Inst 3 1 Way 115kV Switch	252,239
355	Electric Transmission	Cooley	RE	A.00000424.099	China Draw-Wood Draw 115kV Lin	250,317
356	Electric Transmission	Cooley	SR	A.00000640.021	W07 Tx City SS Fr DCUB Rpl SE	249,194
357	Electric Transmission	Cooley	RE	A.00000658.003	Terry Co	246,342
358	Electric Transmission	Cooley	RE	A.00000663.001	Sandown Sub Amoco Terminal	245,645
359	Electric Transmission	Cooley	GI	A.00000350.006	Lost Draw to Lea Co Plains Rtermin	242,304
360	Electric Transmission	Cooley	SR	A.00000427.014	K21 Clearance Violations	236,935
361	Electric Transmission	Cooley	RE	A.00001310.013	Hitchland I26 Terminal UPLC	235,592
362	Electric Transmission	Cooley	RE	A.00001319.010	Dawn Sub Terminal Upgrades	231,429
363	Electric Transmission	Cooley	RE	A.00000424.044	Hobbs Sub Xflir 345kV/230kV UUD	223,515
364	Electric Transmission	Cooley	LI	A.00001008.001	Inst 230kV Ssw Station TOFFportion	210,708
365	Electric Transmission	Cooley	RE	A.00000658.002	Seagraves	207,192
366	Electric Transmission	Cooley	RE	A.00000194.005	Coodian Z226 Terminal	205,865
367	Electric Transmission	Cooley	SR	A.00001273.015	Deaf Smith Breaker 2k/20 Replacement	203,986
368	Electric Transmission	Cooley	RE	A.00000767.003	Osage Substation	203,983
369	Electric Transmission	Cooley	SR	A.00000220.007	SPS 2017 S&EE Sub	191,951
370	Electric Transmission	Cooley	RE	A.00001310.012	Flinney I25 Terminal UPLC	184,926
371	Electric Transmission	Cooley	RE	A.00000463.015	Market St.-South Portales ROW	182,693
372	Electric Transmission	Cooley	RE	A.00000979.004	115 ROW ROW Portion ROW	180,749
373	Electric Transmission	Cooley	RE	A.00001300.009	Retern 115kV Roswell City	177,640
374	Electric Transmission	Cooley	LI	A.00001008.005	AWOR Relay Upgrade Sub	176,958
375	Electric Transmission	Cooley	RE	A.00000979.011	K56 Structure Raise	174,471
376	Electric Transmission	Cooley	RE	A.00000489.003	Install Capacitor Bank at Kiser Sub	173,970
377	Electric Transmission	Cooley	SR	A.00001078.001	Yeakum UPLC Upgrade	165,180
378	Electric Transmission	Cooley	RE	A.00000290.003	K23 Retermination, Eddy Co Sub	163,239
379	Electric Transmission	Cooley	GI	A.00001183.001	Cochran Terminal Upgrade Sub	156,433
380	Electric Transmission	Cooley	RE	A.00000663.002	Amoco Sub, Sundown Terminal	151,731
381	Electric Transmission	Cooley	SR	A.00000640.034	COCO 115kV Brkt 9910 Replacement	149,864
382	Electric Transmission	Cooley	RE	A.00001271.004	Cardinal-Teeague Record 115kV	144,758
383	Electric Transmission	Cooley	GI	A.00001183.004	U19 Plains to LTDW Line Side	139,621
384	Electric Transmission	Cooley	RE	A.00000488.004	RDRN 115kV Line Terminal Upgrade	133,258
385	Electric Transmission	Cooley	RE	A.00001300.025	Wreckout Rebuild Z09 Dble Ckt	127,913
386	Electric Transmission	Cooley	RE	A.00001300.023	T24 ROW	123,925
387	Electric Transmission	Cooley	LI	A.00001008.006	BRU Relay Upgrade Sub	122,515
388	Electric Transmission	Cooley	SR	A.00001000.001	Hutchinson LTC Replacement	121,866
389	Electric Transmission	Cooley	RE	A.00001319.008	W40 Rebuild ROW	109,876
390	Electric Transmission	Cooley	SR	A.00000286.014	LNCIO Rplc 69kV Bypass Switches	107,435
391	Electric Transmission	Cooley	SR	A.00001273.017	Jones Transformer Pad	101,886
392	Electric Transmission	Cooley	RE	A.00001188.002	Amoco Oxy UF Relay	93,599
393	Electric Transmission	Cooley	SR	A.00001078.002	Tolk UPLC Upgrade	88,685
394	Electric Transmission	Cooley	RE	A.0000126.003	Artesia City Club Line ROW	83,836
						17,144

Southwestern Public Service Company  
Capital Additions  
April 1, 2018 through March 31, 2019

Exhibit DG-7

Attachment LJW-2

Page 11 of 25

Case No. 19-00170-UT

Line No.	Asset Class	Witness	Project Category	WBS Level 2	Project Description (WBS Level 2 Description)	(E)	(F)	(G)
						Additions to Plant-in-Service (April 1, 2018 - March 31, 2019)	Total Company	Additions to Plant-in-Service (April 1, 2018 - March 31, 2019) NM Retail
395	Electric Transmission	Cooley	GI	A.0001183.005	U20 LTDW to Cochran Line Side	80,559	16,474	16,188
396	Electric Transmission	Cooley	SR	A.0000401.049	Seven Rivers BPRO Upgrade	79,161	16,109	
397	Electric Transmission	Cooley	SR	A.0000303.041	SPS S&E 115kV Line NM 2016	78,777		
398	Electric Transmission	Cooley	RE	A.0000663.005	K03 Structure Upgrade	78,006	15,952	
399	Electric Transmission	Cooley	RE	A.0000511.020	Carl-Wolf Lubbock S Relay at	77,986	15,948	
400	Electric Transmission	Cooley	SR	A.0000303.040	SPS S&E 69kV Line NM 2016	77,767	15,903	
401	Electric Transmission	Cooley	RE	A.0000781.016	U16 Bushland to Outpost	75,471	15,433	
402	Electric Transmission	Cooley	RE	A.0000781.017	U17 Coulier to Outpost	74,085	15,150	
403	Electric Transmission	Cooley	SR	A.0000303.047	SPS S&E 115kV Line OK 2016	71,040	14,527	
404	Electric Transmission	Cooley	RE	A.0000424.068	L Ridge Sub 115kV Conn/S Brush	65,806	13,457	
405	Electric Transmission	Cooley	SR	A.0000401.025	Carlsbad 115kV (C900)Sub	64,126	13,113	
406	Electric Transmission	Cooley	SR	A.0000153.004	SPS Trans Switch Rplmnt 115kV	63,304	12,945	
407	Electric Transmission	Cooley	GI	A.0000105.008	K45 Semiconductor Transmission Portio	62,682	12,818	
408	Electric Transmission	Cooley	SR	A.0000220.024	SPS 2015 KS SE Sub	61,270	12,329	
409	Electric Transmission	Cooley	RE	A.0000424.157	Whitten Sub Terminal Upgrades	60,690	12,411	
410	Electric Transmission	Cooley	SR	A.0001273.012	Amoco Switch Replacement	60,116	12,293	
411	Electric Transmission	Cooley	OT	A.0695269	E&S Elec Trans Lines SPS	59,099	12,085	
412	Electric Transmission	Cooley	RE	A.0000424.155	Cust Mt Whitten Rebuild Line	56,590	11,572	
413	Electric Transmission	Cooley	RE	A.0000673.041	Yosakum 345-kV Land	53,024	10,843	
414	Electric Transmission	Cooley	RE	A.0001051.001	Hale V72 Treminal Upgrade	50,372	10,301	
415	Electric Transmission	Cooley	RE	A.0000424.045	Hobbs 345kV Sub Reactor/Kiowa	47,419	9,977	
416	Electric Transmission	Cooley	RE	A.0002033.002	Market St Sub Greyhound 50565	47,290	9,670	
417	Electric Transmission	Cooley	GI	A.0000706.001	Hitchland and New 345kV Terminal -	46,918	9,594	
418	Electric Transmission	Cooley	RE	A.0000511.022	Carl-Wolf Tuco Relay at Carl	46,285	9,465	
419	Electric Transmission	Cooley	SR	A.0000220.026	SPS 2015 OK SE Sub	45,306	9,265	
420	Electric Transmission	Cooley	RE	A.00001325.004	ROW W77/T75	45,183	9,240	
421	Electric Transmission	Cooley	OT	A.0000103.001	Lighthouse Switch Install Transmiss	42,247	8,639	
422	Electric Transmission	Cooley	GI	A.0000902.001	Hale Co Wind 230kV Y Terminal at	41,968	8,582	
423	Electric Transmission	Cooley	SR	A.0000401.024	Bushland 230kV (2K05)Sub	41,285	8,443	
424	Electric Transmission	Cooley	SR	A.00001273.005	Facil Upg/Sub Ancillary Eq 2016	39,461	8,069	
425	Electric Transmission	Cooley	TI	A.0000974.012	Optima Land	32,699	6,687	
426	Electric Transmission	Cooley	RE	A.0000552.005	Chaves-Price-Capitan 115 kV C	31,178	6,376	
427	Electric Transmission	Cooley	GI	A.0000768.006	Floyd Relay Upgrade for Blanco	31,096	6,359	
428	Electric Transmission	Cooley	RE	A.0000463.010	Market St-Pontales Line	30,360	6,208	
429	Electric Transmission	Cooley	RE	A.0000511.015	Carl-Wolf K-24 Return at Carl	29,536	6,040	
430	Electric Transmission	Cooley	RE	A.0001283.004	Lea Plains Metering	27,459	5,615	
431	Electric Transmission	Cooley	SR	A.0001078.003	Needmore DPLC Upgrade	26,428	5,404	
432	Electric Transmission	Cooley	GI	A.0000350.007	Cochran 115kV Sub Term Upg	26,371	5,393	
433	Electric Transmission	Cooley	RE	A.0000424.060	L Ridge-Sage Brush 115kV Line	26,369	5,392	
434	Electric Transmission	Cooley	SR	A.0000401.039	Wipp Cap Bank Volt Diff NM	25,931	5,303	
435	Electric Transmission	Cooley	RE	A.0000424.070	Potash Sub Rly Mod's Livingston	25,125	5,138	
436	Electric Transmission	Cooley	GI	A.0000350.002	Lost Draw TOIF	24,251	4,959	
437	Electric Transmission	Cooley	RE	A.0000511.026	K39 PL Line Retern at Carlisle	23,636	4,833	
438	Electric Transmission	Cooley	RE	A.0000424.104	China Draw-Wood Draw 115kV ROW	21,947	4,488	

# Exhibit DG-7

Attachment LJW-2

Page 12 of 25

Case No. 19-00170-UT

**Southwestern Public Service Company  
Capital Additions  
April 1, 2018 through March 31, 2019**

(A)	(B)	(C)	(D)	(E)	(F)	(G)
Line No.	Asset Class	Witness	Project Category	WBS Level 2	Project Description (WBS Level 2 Description)	Additions to Plant-in-Service (April 1, 2018 - March 31, 2019) Total Company
439	Electric Transmission	Cooley	RE	A.0006424.232	S Brush 115kV Sub Liv Line Terminal	20,315
440	Electric Transmission	Cooley	RE	A.0006463.009	Kilgore-Portales Return Line	19,918
441	Electric Transmission	Cooley	RE	A.0006673.026	TX/NM Border-Hobbs 345kV ROW_U	4,073
442	Electric Transmission	Cooley	RE	A.0006424.071	WIPP Sub Relay Mod/Livingston	4,056
443	Electric Transmission	Cooley	SR	A.0001068.001	T97 Structure Relocate	2,961
444	Electric Transmission	Cooley	RE	A.0006463.006	Oasis T-32 Relay Upgrade Sub	2,895
445	Electric Transmission	Cooley	EC/TI	A.0006655.005	TUCO Mooreland Woodward TX RO	2,799
446	Electric Transmission	Cooley	RE	A.0006424.102	W Draw 115kV Sub C/Draw Term	2,713
447	Electric Transmission	Cooley	RE	A.0001319.009	Canyon West Sub W40 Term Upgr	2,649
448	Electric Transmission	Cooley	RE	A.0006424.226	OPIE Potash Livingston Ridge ROW	2,630
449	Electric Transmission	Cooley	RE	A.0006463.007	Oasis-Portales T-32 Return Lin	2,320
450	Electric Transmission	Cooley	RE	A.0006424.063	S Brush-Cardinal 115kV ROW_UID 5	2,103
451	Electric Transmission	Cooley	GI	A.0007058.005	Crosby Relay Upgrade for Blanc	2,102
452	Electric Transmission	Cooley	SR	A.0001223.013	Mustang Switch Replacement	2,100
453	Electric Transmission	Cooley	RE	A.0006424.058	T38 Potash Re-Term. UID 50924	2,090
454	Electric Transmission	Cooley	RE	A.0009767.005	South Georgia Substation	2,069
455	Electric Transmission	Cooley	RE	A.0001312.003	Target Cardinal Sub	2,067
456	Electric Transmission	Cooley	SR	A.0006220.005	SPS 2015 S&E Sub	2,067
457	Electric Transmission	Cooley	RE	A.0006522.013	Roswell Interchange W49 Relay	2,060
458	Electric Transmission	Cooley	RE	A.0006767.004	Randall County Interchange Sub	2,059
459	Electric Transmission	Cooley	RE	A.0000223.001	Carlsbad 230/115kV XMrn Upgrade	1,970
460	Electric Transmission	Cooley	RE	A.0000511.016	Carl-Wolf K-02 Return at Wolf	1,960
461	Electric Transmission	Cooley	RE	A.0001310.004	Walkemeyer 345/115 Sub_Land	1,952
462	Electric Transmission	Cooley	LI	A.0001270.001	Bensing 115/12.4/kV Dist(TAM)	1,944
463	Electric Transmission	Cooley	RE	A.0006424.062	S Brush-Cardinal 115kV L_UID 5	1,936
464	Electric Transmission	Cooley	SR	A.0000427.007	W20_Line Capacity Work	1,928
465	Electric Transmission	Cooley	RE	A.0000224.005	Zodiac Substation sub	1,924
466	Electric Transmission	Cooley	RE	A.0006424.105	W-39 Return at Wood Draw UID 5	1,916
467	Electric Transmission	Cooley	RE	A.0000087.001	Roosevelt T33 Terminal Upgrade	1,908
468	Electric Transmission	Cooley	RE	A.0006424.049	Ponderosa-Custer Mt 115kV Line	1,890
469	Electric Transmission	Cooley	SR	A.0000220.031	SPS OK S&E Sub	1,885
470	Electric Transmission	Cooley	RE	A.0000866.033	Lamb County Land	1,876
471	Electric Transmission	Cooley	RE	A.0006424.183	Intercon Potash Conn 230kV Li	1,874
472	Electric Transmission	Cooley	RE	A.0000540.018	W-92 ROW	1,866
473	Electric Transmission	Cooley	RE	A.0000421.013	Eagle Creek Project(Artesia Tw	1,858
474	Electric Transmission	Cooley	RE	A.0000616.006	69kV Line Tap to Soncy Line	1,850
475	Electric Transmission	Cooley	RE	A.0000511.008	Carlsbad to Wofforth ROW	1,843
476	Electric Transmission	Cooley	RE	A.0000226.013	NE Hereford- New Centre St 115	1,835
477	Electric Transmission	Cooley	RE	A.0006424.107	Potash Junction 230/115 Auto U	1,827
478	Electric Transmission	Cooley	RE	A.0000421.013	Newhart to Lamont ROW	1,820
479	Electric Transmission	Cooley	GI	A.0000105.005	Tolk Terminal Upgrades	1,812
480	Electric Transmission	Cooley	RE	A.0000463.005	Roosevelt T-33 Relay Upgrade S	1,804
481	Electric Transmission	Cooley	RE	A.0006424.086	Kiowa-North Lovin 345kV ROW_U	1,796
482	Electric Transmission	Cooley	SR	A.0006401.034	Potter 230kV K59 Sub	1,788

**Southwestern Public Service Company**  
**Capital Additions**  
**April 1, 2018 through March 31, 2019**

(A)	(B)	(C)	(D)	(E)	(F)	(G)
Line No.	Asset Class	Witness	Project Category	WBS Level 2	Project Description (WBS Level 2 Description)	Additions to Plant-in-Service (April 1, 2018 - March 31, 2019) NM Retail
483	Electric Transmission	Cooley	RE	A.0000424.225	Roadrunner Kiowa I23 ROW	1,263
484	Electric Transmission	Cooley	RE	A.0000511.009	Car-Wolf K-10 Reterm at Wolf	1,187
485	Electric Transmission	Cooley	RE	A.0000424.219	Hopi to Copano Hopi Substation	243
486	Electric Transmission	Cooley	RE	A.0000916.002	Deaf Smith Reterm K21 Line	1,162
487	Electric Transmission	Cooley	RE	A.0000424.032	China Draw-Yeso Hills 115kV RO	141
488	Electric Transmission	Cooley	LI	A.0000626.002	Z86 New Tap to Oxy Cedar Lake ROW	137
489	Electric Transmission	Cooley	RE	A.0000673.024	YeaKam-TX/NM Border 345kV ROW	97
490	Electric Transmission	Cooley	RE	A.0000463.013	Market St.-Portales ROW	458
491	Electric Transmission	Cooley	SR	A.0000258.049	Plant X Rpl SPW 111 FT	412
492	Electric Transmission	Cooley	RE	A.0000616.008	Soncy ROW	357
493	Electric Transmission	Cooley	RE	A.0000424.185	West Jal Sub	266
494	Electric Transmission	Cooley	RE	A.0000610.004	Curry to Bailey 115kV - Curry	257
495	Electric Transmission	Cooley	RE	A.0000424.131	N. Loving 115kV Terminal -Chin	253
496	Electric Transmission	Cooley	RE	A.0000646.001	Wade Substation/Sub	185
497	Electric Transmission	Cooley	LI	A.0000675.001	Pringle Dist Transformer Sub	177
498	Electric Transmission	Cooley	SR	A.0000429.004	Line EIR SPS 2016 Line	177
499	Electric Transmission	Cooley	RE	A.0000767.011	T-66 Reterm Line	156
500	Electric Transmission	Cooley	SR	A.0000303.028	SPS 2015 S&E/T B 69kV Line	89
501	Electric Transmission	Cooley	OT	A.0000820.006	SPS Physical Security	78
502	Electric Transmission	Cooley	SR	A.0000514.003	Rocky Point Switch Replmmt	15
503	Electric Transmission	Cooley	RE	A.0000424.100	China Draw 115kV Sub WDraw Ter	69
504	Electric Transmission	Cooley	RE	A.0000424.010	Potash Junction 115/69 Xfmr Up	50
505	Electric Transmission	Cooley	RE	A.0000424.187	Potash to West Jal 230kV ROW	25
506	Electric Transmission	Cooley	SR	A.0000427.003	Lidar Oklahoma SPS Line	20
507	Electric Transmission	Cooley	RE	A.0000481.011	New Ink Basin 230/115kV Substation	19
508	Electric Transmission	Cooley	RE	A.0000853.001	Hereford High Side Sub	18
509	Electric Transmission	Cooley	GI	11495216	Campbell St. Bus Modification,Sub	4
510	Electric Transmission	Cooley	RE	A.0000224.006	Kilgore Sub Higiside Sub	18
511	Electric Transmission	Cooley	RE	A.0000424.076	Cardinal 115kV Sub Sage Brush	11
512	Electric Transmission	Cooley	LI	A.0000936.003	South Springlake-T28 Tap&Switc	2
513	Electric Transmission	Cooley	RE	A.0001310.006	Finnley Relay Settings	(2)
514	Electric Transmission	Cooley	RE	A.0000424.016	Wreckout of Z22.2 Structures	(5)
515	Electric Transmission	Cooley	RE	A.0001310.007	Hitchhail Relay Settings Texas	(10)
516	Electric Transmission	Cooley	RE	A.0000540.004	Seven Rivers Relay Sub	(27)
517	Electric Transmission	Cooley	RE	A.0000574.005	Inst Arms at Pucket W TapT37	(40)
518	Electric Transmission	Cooley	SR	A.0000427.001	SPS Line Capacity Line	(213)
519	Electric Transmission	Cooley	RE	A.0000224.007	Zodiac Substation NM Line	(254)
520	Electric Transmission	Cooley	SR	A.0000298.001	Eddy County SVC Control/Sub	(24)
521	Electric Transmission	Cooley	RE	A.0000540.003	Atoka Substation	(56)
522	Electric Transmission	Cooley	RE	A.0000610.007	Curry to Bailey 115kV NM ROW	(61)
523	Electric Transmission	Cooley	RE	A.0000773.001	Andrews County Substation	(80)
524	Electric Transmission	Cooley	RE	A.0000463.016	Roosevelt-Portales T-33 Reterm	(125)
525	Electric Transmission	Cooley	RE/SSR	A.0000800.001	Oasis T32 Terminal Upgrade	(266)
526	Electric Transmission	Cooley	RE	A.0000488.008	Opie Roadrunner Agave Ociosa Pre Con	(342)
						(348)

## Exhibit DG-7

Attachment LJW-2  
 Page 13 of 25  
 Case No. 19-00170-UT

Southwestern Public Service Company  
Capital Additions  
April 1, 2018 through March 31, 2019

Line No.	Asset Class	Witness	Project Category	WBS Level 2	Project Description (WBS Level 2 Description)	(E) Additions to Plant-in-Service (April 1, 2018 - March 31, 2019) Total Company	(F) Additions to Plant-in-Service (April 1, 2018 - March 31, 2019) Total Company	(G) Additions to Plant-in-Service (April 1, 2018 - March 31, 2019) NM Retail
527	Electric Transmission	Cooley	RE	A.0000522.002	Price-Chaves 115 kV Line Line	(2,137)	(2,137)	(437)
528	Electric Transmission	Cooley	RE	A.0000707.002	Graham Intg/Add 115/69 Transfo	(2,595)	(2,595)	(531)
529	Electric Transmission	Cooley	LI	A.0000838.001	T38 Bopco SWay Sw Inst Ste#41	(3,021)	(3,021)	(618)
530	Electric Transmission	Cooley	GI	A.0000557.001	Novus Wind IV - Highland Sub	(4,044)	(4,044)	(827)
531	Electric Transmission	Cooley	RE	A.0000610.002	Curry to Bailey 115kV New Line	(4,536)	(4,536)	(928)
532	Electric Transmission	Cooley	RE	A.0000610.027	Curry to Bailey 115kV NM Line	(4,545)	(4,545)	(929)
533	Electric Transmission	Cooley	RE	A.0000463.003	Market St. Substation	(5,055)	(5,055)	(1,034)
534	Electric Transmission	Cooley	RE	A.0000767.014	V-04 Circuit Removal	(5,549)	(5,549)	(1,135)
535	Electric Transmission	Cooley	SR	A.0000287.035	Potash #920 Breaker Relmnt	(6,108)	(6,108)	(1,249)
536	Electric Transmission	Cooley	RE	A.0000533.002	Nichols 115kV BFR - Dumas 19th	(7,652)	(7,652)	(1,565)
537	Electric Transmission	Cooley	GI	A.0000768.003	Floyd/Blanco Retermination-115	(7,789)	(7,789)	(1,593)
538	Electric Transmission	Cooley	RE	A.0000424.039	T38 WIP Re-Term. UJD 50924	(7,884)	(7,884)	(1,612)
539	Electric Transmission	Cooley	SR	A.0000287.036	Carlsbad C900 Breaker Rplmnt	(9,276)	(9,276)	(1,897)
540	Electric Transmission	Cooley	LI	A.0001076.001	Xcel Install 3 Way Switch	(9,390)	(9,390)	(1,920)
541	Electric Transmission	Cooley	RE	A.0000424.073	S Brush 115kV Sub Liv Cardinal	(9,857)	(9,857)	(2,016)
542	Electric Transmission	Cooley	RE	A.0000463.001	Portales 115kV Loop Line	(17,463)	(17,463)	(3,571)
543	Electric Transmission	Cooley	RE	A.0000533.006	Nichols 115kV BFR - East Plant	(18,145)	(18,145)	(3,711)
544	Electric Transmission	Cooley	RE	A.0000919.001	Happy Intg. auto upgrades Sub	(19,053)	(19,053)	(3,896)
545	Electric Transmission	Cooley	OT	A.0095288	E & S Elec Trans Subs SPS	(25,595)	(25,595)	(5,234)
546	Electric Transmission	Cooley	SR/LI	A.0000851.001	Pringle Substation Sub	(26,327)	(26,327)	(5,384)
547	Electric Transmission	Cooley	LI	A.0001156.001	Int 1 Way 115kV Switch Tap	(26,443)	(26,443)	(5,407)
548	Electric Transmission	Cooley	LI	A.0001097.002	Inst Z77 60kV Switch Reimb TOIF	(26,467)	(26,467)	(5,412)
549	Electric Transmission	Cooley	RE	A.0001312.004	Targa/Cardinal Recon 115kV Line	(29,330)	(29,330)	(5,998)
550	Electric Transmission	Cooley	SR	A.0000220.017	SPS 2015 NM S&E Sub	(31,196)	(31,196)	(6,379)
551	Electric Transmission	Cooley	RE	A.0000354.001	Crosby Co. 115kV Cap Bank Sub	(33,106)	(33,106)	(6,770)
552	Electric Transmission	Cooley	LI	A.0000711.002	LOA U06 Slack Spans Cust Portion	(39,132)	(39,132)	(8,002)
553	Electric Transmission	Cooley	RE	A.0000767.008	East Plant Relay Sub	(39,483)	(39,483)	(8,074)
554	Electric Transmission	Cooley	RE	A.0000215.012	Pleasant Hill to Roosevelt Co.	(45,306)	(45,306)	(9,265)
555	Electric Transmission	Cooley	LI	A.0000424.194	Pecos Dist Add/115kV Breaker a	(48,546)	(48,546)	(9,927)
556	Electric Transmission	Cooley	LI	A.0000553.001	Diamondback Lynegar TerminalS	(50,429)	(50,429)	(10,312)
557	Electric Transmission	Cooley	RE	A.0000367.002	Bowers 2nd Auto Sub	(51,121)	(51,121)	(12,454)
558	Electric Transmission	Cooley	RE	A.0000361.004	KC Substation Sub	(52,037)	(52,037)	(10,641)
559	Electric Transmission	Cooley	RE	A.0000603.001	Crosby County Transformer #1 Su	(58,784)	(58,784)	(12,021)
560	Electric Transmission	Cooley	RE	A.0000424.177	Hopi Breaker Install Pecos Ter	(59,865)	(59,865)	(12,242)
561	Electric Transmission	Cooley	RE	A.0000463.011	Kilgore-South Ponales ROW	(60,765)	(60,765)	(15,603)
562	Electric Transmission	Cooley	RE	A.0000361.001	KC Sub-Sulphur Springs 115kV T	(62,647)	(62,647)	(12,426)
563	Electric Transmission	Cooley	RE	A.0000407.004	Howard Substation	(70,153)	(70,153)	(12,811)
564	Electric Transmission	Cooley	LI	A.0001002.002	115kV N loving Sub Ter Updg Xcel Por	(72,600)	(72,600)	(14,346)
565	Electric Transmission	Cooley	OT	A.0001106.001	WIP/W38 Structure Relocate	(72,878)	(72,878)	(14,903)
566	Electric Transmission	Cooley	RE	A.0000407.002	Bowers Substation sub	(76,302)	(76,302)	(15,603)
567	Electric Transmission	Cooley	LI	A.0000634.001	Higg East Igh Side/Sub Portion	(80,057)	(80,057)	(16,371)
568	Electric Transmission	Cooley	RE	A.0000424.174	North Loving 115kV Bkr Ring Su	(82,511)	(82,511)	(16,873)
569	Electric Transmission	Cooley	SR	A.0000401.033	Potash Junction 115kV 4920	(87,662)	(87,662)	(17,926)
570	Electric Transmission	Cooley	RE	A.0000522.004	Chaves-Price-Capitan 115 kV Ca	(87,991)	(87,991)	(17,989)

Exhibit DG-7

Attachment LJW-2  
Page 14 of 25  
Case No. 19-00170-UT

Southwestern Public Service Company  
 Capital Additions  
 April 1, 2018 through March 31, 2019

Line No.	Asset Class	Witness	Project Category	WBS Level 2	Project Description (WBS Level 2 Description)	(E)	(F)	(G)
						Additions to Plant-in-Service (April 1, 2018 - March 31, 2019)	Total Company	Additions to Plant-in-Service (April 1, 2018 - March 31, 2019)
571	Electric Transmission	Cooley	RE	A.0000522.001	Capitan-Price 115 kV Line, Li PCA Terminal Upgrade Sub	(91,059)	\$ 247,247	(18,521)
572	Electric Transmission	Cooley	RE	A.0000424.028	Pleasant Hill 345/230kV NM Sub	(103,247)	\$ 21,113	(22,729)
573	Electric Transmission	Cooley	RE	A.0000215.002	Grassland XFM/R Sub	(111,148)	\$ 118,701	(24,273)
574	Electric Transmission	Cooley	RE	A.0000357.001	Cherry St Img Hastings-E.Pit	(124,356)	\$ 125,536	(25,330)
575	Electric Transmission	Cooley	RE	A.0000409.004	China Draw High Side Substatio	(125,536)	\$ 144,380	(25,671)
576	Electric Transmission	Cooley	RE	A.0000424.015	115/69 kV Mobile Sub, Sub	(144,380)	\$ 149,002	(25,325)
577	Electric Transmission	Cooley	SR	A.0000645.001	Ochiltree - BookenROW	(149,002)	\$ 171,541	(30,470)
578	Electric Transmission	Cooley	RE	A.0000646.004	Plainview City Exp, Cos, Sub	(171,541)	\$ 176,484	(35,079)
579	Electric Transmission	Cooley	RE	A.0000426.004	Dallam Co 230/115 kV sub	(176,484)	\$ 179,497	(36,706)
580	Electric Transmission	Cooley	RE	A.0000302.002	Drinkard 115 Cap Bank Sub	(197,508)	\$ 197,508	(40,389)
581	Electric Transmission	Cooley	SR	A.0000914.001	SPS Trans Switch Replmt Line	(209,175)	\$ 229,301	(42,775)
582	Electric Transmission	Cooley	EC/TI	A.0000153.001	Tuco to Mooreland (Woodward) R	(209,175)	\$ 230,393	(46,890)
583	Electric Transmission	Cooley	EC/TI	A.0000417.003	TUCC-A-Mooreland Woodward TX ROW 2017	(231,421)	\$ 231,421	(47,114)
584	Electric Transmission	Cooley	RE	A.0000417.015	Bowers - Howard ROW	(231,421)	\$ 238,840	(47,724)
585	Electric Transmission	Cooley	RE	A.0000407.001	Lynn Co. Dist. Load Conversion	(285,397)	\$ 285,397	(54,976)
586	Electric Transmission	Cooley	RE	A.0000350.002	Hitchland to Woodward 345 kV S	(320,517)	\$ 320,517	(65,543)
587	Electric Transmission	Cooley	EC/TI	A.0000244.002	Newhart Img Hart Ind-Lantoni I	(330,204)	\$ 330,204	(67,524)
588	Electric Transmission	Cooley	RE	A.0000421.006	Inst Temp Switch Reimb TO/F	(471,792)	\$ 471,792	(96,478)
589	Electric Transmission	Cooley	LI	A.0001126.001	Crosby-Blanco Retermination-11	(552,009)	\$ 552,009	(112,881)
590	Electric Transmission	Cooley	GI	A.0000768.002	115kV N loving Sub TO/F Lucid Porti	(704,828)	\$ 704,828	(144,132)
591	Electric Transmission	Cooley	LI	A.0001022.001	SPS SA&E 345kV Line TX 2016	(991,467)	\$ 991,467	(202,447)
592	Electric Transmission	Cooley	SR	A.0000303.046	GEN-2011-025 Fiber Wind Blanco	(1,064,782)	\$ 1,064,782	(214,059)
593	Electric Transmission	Cooley	GI	A.0000768.001	R27 Reconductor	(1,084,791)	\$ 1,084,791	(217,741)
594	Electric Transmission	Cooley	GI	A.0000105.001	V21_Qahada 115kV Reconductor	(1,092,475)	\$ 1,092,475	(223,402)
595	Electric Transmission	Cooley	RE	A.0000424.029	Eddy Co. 230/115 Xfm/H Upgra	(1,606,213)	\$ 1,606,213	(328,458)
596	Electric Transmission	Cooley	RE	A.0000890.001	K83 Line Capacity Work	(1,786,008)	\$ 1,786,008	(365,224)
597	Electric Transmission	Cooley	SR	A.0000427.011	Lost Draw Substation	(2,203,625)	\$ 2,203,625	(456,624)
598	Electric Transmission	Cooley	GI	A.0000350.001	Security Resilience Spae TR	(466,706)	\$ 466,706	(466,706)
599	Electric Transmission	Cooley	SR	A.0000776.002	Tuco 345 Traf Rplmnt Sub Portion	(2,292,270)	\$ 2,292,270	(52,501,979)
600	Electric Transmission	Cooley	GI	A.0000564.002	Needmore Substation	\$ 256,772,854	\$ 256,772,854	\$ 256,772,854
601	Electric Transmission	Cooley	GI	A.0000736.002		\$ 9,759,736	\$ 9,759,736	\$ 9,759,736
602	<b>Electric Transmission Total</b>					\$ 9,050,623	\$ 9,050,623	\$ 9,050,623
603	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0010017.001	TX - OH Rebuild Blanket	7,325,623		7,325,623
604	Electric Distribution	Meeks	New Business	A.0010002.001	NM - OH Extension Blanket	5,043,139		5,043,139
605	Electric Distribution	Meeks	Purchases	D.0005014.009	TX Electric Distribution Transforme	4,996,621		4,996,621
606	Electric Distribution	Meeks	New Business	A.0010001.001	TX - OH Extension Blanket	4,169,374		4,169,374
607	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0005522.130	Convert Soncy to 115/13.2kV 50	4,128,697		4,128,697
608	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0005533.001	TEXAS MAJOR STORM RECOVERY	3,798,784		3,798,784
609	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0010017.007	Install 115/12.47kV 14MV A substation	3,358,925		3,358,925
610	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0005522.370	NM - OH Rebuild Blanket	3,204,394		3,204,394
611	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0010018.001	NM Electric Distribution Transforme	2,954,609		2,954,609
612	Electric Distribution	Meeks	Purchases	D.0005014.011	TX - UG Extension Blanket			
613	Electric Distribution	Meeks	New Business	A.0010001.002				

Exhibit DG-7

Attachment LJW-2  
 Page 15 of 25  
 Case No. 19-00170-UT

# Exhibit DG-7

Attachment LJW-2

Page 16 of 25

Case No. 19-00170-UT

Southwestern Public Service Company  
Capital Additions  
April 1, 2018 through March 31, 2019

(A)	(B)	(C)	(D)	(E)	(F)	(G)	
Line No.	Asset Class	Witness	Project Category	WBS Level 2	Project Description (WBS Level 2 Description)	Additions to Plant-in-Service (April 1, 2018 - March 31, 2019) Total Company	Additions to Plant-in-Service (April 1, 2018 - March 31, 2019) NM Retail
614	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0005522.015	Output Substation 115-13.2kV 28MVA	2,945,627	-
615	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0005522.258	Convert Centre Street Replace	2,840,066	-
616	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0005522.211	Install New 34.5kV Source book	2,722,944	-
617	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0005521.004	Convert Curry Co. Interchange	2,439,579	2,439,579
618	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0010100.005	Tx N-Di Substation Equip Rep	2,339,009	-
619	Electric Distribution	Meeks	Outdoor/Area Lighting	D.0005014.028	TX-OH Street Light Rebuild Blanket	1,999,307	-
620	Electric Distribution	Meeks	Purchases	A.0010156.001	TX-Electric Meter Blanket	1,970,023	-
621	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0010002.002	Install Preston West Substation - L	1,726,698	-
622	Electric Distribution	Meeks	New Business	A.0005584.001	NM - UG Extension Blanket	1,605,710	-
623	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0000731.020	Convert 4kV Load out of RIAC East a	1,490,201	1,490,201
624	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0010018.007	Install Outpost Substation 115-13.2	1,445,465	-
625	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0005500.051	NM - Pole Blanket	1,433,712	1,433,712
626	Electric Distribution	Meeks	New Business	A.0010001.004	Cnunion Jal Orig Pmp Sln PME/OXY M.	1,095,058	1,095,058
627	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0010023.001	TX - OH Reinforcement Blanket	1,068,676	-
628	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0005521.200	NM - Subs Equipment Replace	1,033,451	-
629	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0010138.001	Land purchase for Western St Sub	873,726	873,726
630	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0010017.002	TX - UG Conversion/Rebuild Blanket	831,102	-
631	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0005517.024	Substation Land - New Mexico	775,292	-
632	Electric Distribution	Meeks	New Business	A.0010029.001	SEMARING ENERGY 5.7 MILE RECONDUCTO	674,045	-
633	Electric Distribution	Meeks	New Business	A.0010000.002	EUNICE/SAGE BRUSH 556 EXT	662,233	-
634	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0005521.085	Feeder breaker degradation - S	606,001	606,001
635	Electric Distribution	Meeks	New Business	A.0010060.005	JAL/GWS DEEP POSEIDON SWD/ RECON &	599,725	-
636	Electric Distribution	Meeks	Purchases	A.0005517.013	NM-Elec-Easement	581,119	-
637	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0010052.004	Reconductor Intrepid Potash Pond	570,765	570,765
638	Electric Distribution	Meeks	New Business	A.0010060.003	CIMAREX WHITE CITY PME	565,257	565,257
639	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0005584.002	NEW MEXICO MAJOR STORM RECOVERY	536,443	536,443
640	Electric Distribution	Meeks	New Business	A.0010002.004	NM - UG New Services Blanket	523,036	523,036
641	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0010076.001	JAL/JAL ORIGINATION PUMP/SPH RCND	482,572	482,572
642	Electric Distribution	Meeks	Purchases	D.0005014.030	NM-Electric Meter Blanket	476,927	476,927
643	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0005533.005	TX Mixed Work Adjustment	438,814	438,814
644	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0010123.004	Dammon Transformer Replacement	422,109	-
645	Electric Distribution	Meeks	New Business	A.0010060.006	Mesquite Services, LLC- Cypress SWD	411,441	-
646	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0010123.002	Repl Failed Kite Transfrnt 69/13.2	391,721	391,721
647	Electric Distribution	Meeks	New Business	A.0005500.047	JAL/SE SECCT24R31/OXY MESA VFR/RE	387,373	-
648	Electric Distribution	Meeks	Outdoor/Area Lighting	A.0010018.005	NM - OH Street Light Rebuild Blanket	384,087	384,087
649	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0005583.002	TEXAS POLE INSPECTIONS	364,543	364,543
650	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0005502.052	Install Market St 12.5kV Feeds	243,496	243,496
651	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0010017.003	TX - OH Services Renewal Blanket	228,205	-
652	Electric Distribution	Meeks	Purchases	A.0005517.015	TxN-Elec Easement	211,270	-
653	Electric Distribution	Meeks	New Business	A.0010002.003	TX - OH New Services Blanket	332,463	-
654	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0005583.002	TEXAS POLE INSPECTIONS	318,684	318,684
655	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0005502.052	Install Market St 12.5kV Feeds	243,496	243,496
656	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0010017.003	TX - OH Services Renewal Blanket	228,205	-
657	Electric Distribution	Meeks	Purchases			211,270	-

**Southwestern Public Service Company**  
**Capital Additions**  
**April 1, 2018 through March 31, 2019**

(A)	(B)	(C)	(D)	(E)	(F)	(G)
Line No.	Asset Class	Witness	Project Category	WBS Level 2	Project Description (WBS Level 2, Description)	Additions to Plant-in-Service (April 1, 2018 - March 31, 2019) Total Company
658	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0005517.025	Substation Land - TX	198,094
659	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0010010.001	NM - OH Relocation Blanket	190,629
660	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0005522.006	Replace Existing Substation Breaker	173,392
661	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0005521.086	ELR - Substation Relays - SPS	168,354
662	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0005508.186	Rebuild Plainview City 69/2.4kV	163,638
663	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0010018.003	NM - OH Services Renewal Blanket	161,682
664	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0010034.001	NM - OH Reinforcement Blanket	148,047
665	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0010009.001	TX - OH Relocation Blanket	147,304
666	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0010018.002	NM - UG Conversion/Rebuild Blanket	140,471
667	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0005584.006	NM Mixed Work Adjustment	138,150
668	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0010124.005	Replace Failed Union XTR	136,684
669	Electric Distribution	Meeks	Outdoor/Area Lighting	A.0010017.006	TX - UG Street Light Rebuild Blanket	131,369
670	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0000646.019	Convert Town of Booker to 34.5 Conv Portales So to 115/4.2kV	116,413
671	Electric Distribution	Meeks	Purchases	A.0005522.183	TxSElec Easement	109,620
672	Electric Distribution	Meeks	Outdoor/Area Lighting	A.0005517.017	NM - UG New Street Light Blanket	98,050
673	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0010022.006	Conv Market St to 11.5/12.5kV 2	96,395
674	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0005522.184	Install 2 12.47kV OH lines from Sie	90,453
675	Electric Distribution	Meeks	Outdoor/Area Lighting	A.0010001.005	TX - UG New Street Light Blanket	85,671
676	Electric Distribution	Meeks	Outdoor/Area Lighting	A.0010001.005	TX - OH New Street Light Blanket	68,800
677	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0005508.153	SPS-TX Convert Obsolete Vtg D	67,137
678	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0005521.087	ELR - Substation Regulators -	65,298
679	Electric Distribution	Meeks	Outdoor/Area Lighting	A.0010002.005	NM - OH New Street Light Blanket	63,109
680	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0000860.005	Conver Curry Co Interchange 60kV	62,606
681	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0010009.002	TX - UG Relocation Blanket	61,151
682	Electric Distribution	Meeks	Purchases	A.0005533.003	NM - UG Services Renewal Blanket	58,730
683	Electric Distribution	Meeks	New Business	A.0005505.009	Tx(0025) UG Services	55,062
684	Electric Distribution	Meeks	Purchases	A.0005584.004	SPS-NM CAPITALIZED ELECTRIC LOCATES	53,048
685	Electric Distribution	Meeks	Outdoor/Area Lighting	A.0005506.009	TXOH Street Lights-TX SENM	50,873
686	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0010017.004	TX - UG Services Renewal Blanket	46,841
687	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0010026.002	NM - FPIP Blanket	37,862
688	Electric Distribution	Meeks	Purchases	A.0005584.003	SPS-TX CAPITALIZED ELECTRIC LOCATES	36,209
689	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0005584.003	NEW MEXICO POLE INSPECTIONS	34,207
690	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0010025.001	TX - REVS Blanket	31,413
691	Electric Distribution	Meeks	Outdoor/Area Lighting	A.0005506.009	TXOH Street Lights-TX	28,906
692	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0005502.225	SENIM	26,407
693	Electric Distribution	Meeks	Outdoor/Area Lighting	A.0010018.006	NM - UG Street Light Rebuild Blanket	18,391
694	Electric Distribution	Meeks	New Business	A.0005501.116	AMARILLO/TIMES SQUARE VILLAGE I/BAC	18,298
695	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0005522.223	Conver Hereford 69/13.2kV to	18,248
696	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0005522.106	Conver Wade to 11.5/12.5kV &MVA	18,204
697	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0005508.179	Conver Town of Booker to 34.5	17,159
698	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0005522.218	Conver Livingston Ridge #1.69	13,916
699	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0005521.182	Conver Centre Street - Remova	13,854
700	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0005518.095	Sps-Poor Perf Fdr Replace Blkt	12,188
701	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0010025.002	TX - FPIP Blanket	10,363

## Exhibit DG-7

Attachment LJW-2  
 Page 17 of 25  
 Case No. 19-00170-UT

# Exhibit DG-7

Attachment LJW-2

Page 18 of 25

Case No. 19-00170-UT

**Southwestern Public Service Company  
Capital Additions  
April 1, 2018 through March 31, 2019**

(A)	(B)	(C)	(D)	(E)	(F)	(G)
Line No.	Asset Class	Witness	Project Category	WBS Level 2	Project Description (WBS Level 2 Description)	Additions to Plant-in- Service (April 1, 2018 - March 31, 2019) Total Company
702	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0005509.011	TXUG ConvarsRebuilds-TX	9,769
703	Electric Distribution	Meeks	New Business	A.0005505.007	NMUG Services-NM	9,137
704	Electric Distribution	Meeks	New Business	A.0005504.008	TXOH Services-TX	8,273
705	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0005502.232	Inst Muleshoe East 12.5/2.4 3-	-
706	Electric Distribution	Meeks	Outdoor Area Lighting	A.0005506.008	NMOH Street Lights-NM	7,147
707	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0005510.007	NMOH Relocations-NM	6,761
708	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0010033.002	TX - UG Reinforcement Blanket	6,687
709	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0010009.003	TX - UG Service Conversion Blanket	6,261
710	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0005521.202	Replace Substation Relays-NM	-
711	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0005511.011	NMUG Relocations-NM	4,573
712	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0005521.140	Potash #2 Replace Failed XFMR	3,353
713	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0005522.073	Reinf Price TI 69 to 115 kV 2	2,964
714	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0008680.004	Conver Curry Co. Interchange	2,917
715	Electric Distribution	Meeks	New Business	A.0005504.007	NMUG Services-NM	2,677
716	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0010010.002	NM - UG Relocation Blanket	2,344
717	Electric Distribution	Meeks	New Business	A.0005501.011	TXUG Extension-TX	2,044
718	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0005503.008	TXUG Reinforcements-TX	-
719	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0005511.012	TXUG Relocations-TX	1,825
720	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0005522.260	Reinforce Pringle Oil Field 10	-
721	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0005509.010	NMUG ConvarsRebuilds-NM	1,493
722	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0005510.021	Txn Blanket-Oh Relocations	1,341
723	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0005502.247	Install Sunset 13.2kV Feeders	1,246
724	Electric Distribution	Meeks	New Business	A.0005500.009	NMOH Extension-NM	-
725	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.1178942.2	Purch Land for Hig88 East Sub	894
726	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0005522.357	Install Ponderosa #1 115/25KV	542
727	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0005521.188	Order new system spare 115/12k	324
728	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0005508.031	Txn-(022) Oh Rebuilds	252
729	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0005518.013	Reliability Monitoring System	-
730	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0005508.101	Inspect/Replace Poles_Texas	159
731	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0005518.087	Reliability Monitoring System	-
732	Electric Distribution	Meeks	New Business	A.0005504.009	Txs-(023) Oh Services	3
733	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0005519.023	TX North-UG Service Conv	(1)
734	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0005584.005	SPS NM Targeted OH Rebuild - A	(119)
735	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0005510.008	TXOH Relocations-TX	(129)
736	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0005510.072	TX Pole Transfers	(144)
737	Electric Distribution	Meeks	New Business	A.0005505.011	0025 Blanket - New Mexico Ug S	(168)
738	Electric Distribution	Meeks	Purchases	A.0005516.033	Scrap Sale Credits-SPS	(191)
739	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0005521.011	Purchase 115/25KV 50 MVA reserve tr	(18)
740	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0005521.012	Replace North Hobbs 12 - 28MVA	(51)
741	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0005522.175	Construct Kilgore 15/4.3kV 14M	(664)
742	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0005522.263	Install New 115/12.5kV Banning	(710)
743	Electric Distribution	Meeks	New Business	A.0005500.024	Txs Blanket-Oh Extension	(883)
744	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0005508.007	NMOH Rebuilds-NM	(1,270)
745	Electric Distribution	Meeks	New Business	A.0005505.008	TXUG Services-TX	(1,670)
						(2,277)

# Exhibit DG-7

Attachment LJW-2

Page 19 of 25

Case No. 19-00170-UT

**Southwestern Public Service Company**  
**Capital Additions**  
**April 1, 2018 through March 31, 2019**

(A)	(B)	(C)	(D)	(E)	(F)	(G)
Line No.	Asset Class	Witness	Project Category	WBS Level 2	Project Description (WBS Level 2 Description)	Additions to Plant-in- Service (April 1, 2018 - March 31, 2019) Total Company
746	Electric Distribution	Meeks	Purchases	A.0005511.048	Capitalized Locating Costs-Ele Nm Blanket-Ug Conv/Vn/Rebuilds	(3,838)
747	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0005509.037	Nm Blanket-Ug Conv/Vn/Rebuilds	(6,945)
748	Electric Distribution	Meeks	New Business	A.0005500.025	NM Blanket-Oh Extension	(9,031)
749	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0005500.023	Tx Blank-Overhead Extensions	(12,170)
750	Electric Distribution	Meeks	New Business	A.0005502.009	TXOH Reinforcements-TX	(17,433)
751	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0005500.007	TXOH Extension-TX	(17,735)
752	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0005522.007	Wood Draw Pad Expansion	(21,958)
753	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0005522.105	Inst China Draw 69/12.5kV 28MV	(23,296)
754	Electric Distribution	Meeks	Outdoor/Area Lighting	A.0005507.006	NMUG Street Lights-NM	(42,601)
755	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0005522.177	Inst Camex 115/13.2kV 28MV A T3	(44,813)
756	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0005522.077	Convert Zodiac T1 69 to 115 kV	(61,323)
757	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0005522.178	Inst Higg East 115/12.5kV 28MV	(80,931)
758	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0005302.016	Conv Channing to 23/0.33kV 2-28	-
759	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0005522.127	Inst Battle Axe15/12.5kV 28MV	(107,731)
760	Electric Distribution	Meeks	New Business	A.0006062.010	Distribution CIAC TX Elec	(119,835)
761	Electric Distribution	Meeks	New Business	A.0005500.043	BUSHLAND/26511 N US HIGHWAY 287 N	(175,186)
762	Electric Distribution	Meeks	Distribution Line and Substation Capacity	A.0005502.231	Install Battle Axe 12.5kV Feed	(239,596)
763	Electric Distribution	Meeks	Distribution Line and Substation Reconstruction	A.0005508.008	TXOH Rebuilds-TX	(280,170)
764	Electric Distribution	Meeks	New Business	A.0006062.011	Distribution CIAC NM Elec	(1,668,842)
<b>765</b>	<b>Electric Distribution Total</b>				<b>\$ 100,309,251</b>	<b>\$ 35,334,399</b>
766	Electric General	Bick	Building & Infrastructure	D.0001813.061	Canyon Service Center - New	\$ 7,485,131
767	Electric General	Meeks	Purchases	A.0006056.213	NM-DIST Fleet New Unit Purchases	4,441,545
768	Electric General	Cooley	OT	A.0006056.224	Fleet New Unit El Trans TX	2,536,508
769	Electric General	Meeks	Purchases	A.0006059.006	TX-Dist Electric Tools and Equip	2,514,101
770	Electric General	Harkness	Aging Technology	D.0001839.827	Purch Eddy County MW Equip NM	697,050
771	Electric General	Cooley	OT	A.0001118.006	Lock and Key System TX	645,106
772	Electric General	Meeks	Purchases	A.0006039.016	TX-Dist Sub Tools and Equip	393,885
773	Electric General	Meeks	Purchases	A.0006056.214	NM-DIST Fleet New Unit Purchase El	372,051
774	Electric General	Harkness	Aging Technology	D.0001821.290	2018 Unplanned PC SPS	1,101,616
775	Electric General	Meeks	Purchases	A.0005549.009	A.0005549.009	205,824
776	Electric General	Cooley	OT	A.0000710.008	SPS-Dist Sub Security Comm	1,045,629
777	Electric General	Harkness	Cyber Security	D.0002000.008	A.0000710.008	290,281
778	Electric General	Cooley	Aging Technology	D.0001821.311	Purch CIP Appl SPS	273,380
779	Electric General	Cooley	OT	A.0005588.011	Moore Co 115kV RTU Rplmnt	958,469
780	Electric General	Cooley	RE	A.0000424.164	N Loving 34.5kV Sub Comms _UID 5	951,084
781	Electric General	Cooley	OT	A.0001118.007	Lock and Key System NM	264,035
782	Electric General	Cooley	SR	A.0000220.030	Amoco RTU Replacement	227,369
783	Electric General	Harkness	Aging Technology	D.0002016.017	Purch T&D MPLS - Unplanned	215,346
784	Electric General	Harkness	RE	D.0002021.004	N Moore Co 115kV RTU Rplmnt	212,927
785	Electric General	Cooley	OT	A.0000424.168	China Draw 34.5kV Sub Comms _UID	157,440
786	Electric General	Cooley	Purchases	A.0006059.063	SPS Sub Comm Tool Blanket	133,797
787	Electric General	Meeks	RE	A.0005549.010	NM-Dist Sub Communication Equi	126,623
788	Electric General	Cooley	RE	A.0005511.017	Car-Wolf Canisie Comm	125,127

Southwestern Public Service Company  
 Capital Additions  
 April 1, 2018 through March 31, 2019

Exhibit DG-7

Attachment LJW-2  
 Page 20 of 25  
 Case No. 19-00170-UT

Line No.	Asset Class	Witness	Project Category	WBS Level 2	Project Description (WBS Level 2 Description)	(E)	(F)	(G)
						Additions to Plant-in-Service (April 1, 2018 - March 31, 2019)	Total Company	NM Rebill
789	Electric General	Meeks	Purchases	A.0006059.007	NM:Dist Electric Tools and Equip	347,200		90,388
790	Electric General	Harkness	Aging Technology	D.0001783.021	Purch LMR Radio HW TX	321,210		89,172
791	Electric General	Cooley	RE	A.0000296.009	NE Hareford Comm	312,659		86,799
792	Electric General	Cooley	OT	A.0000594.004	TX Frame Relay Comm	302,571		83,998
793	Electric General	Cooley	OT	A.0000594.003	NM Frame Relay Comm	297,380		82,557
794	Electric General	Harkness	Aging Technology	D.0001821.307	2018 EMIS Infra Refresh SPS	289,475		80,362
795	Electric General	Bick	Security - Controls & Monitoring	D.0001781.049	790 Buchanan Security System	277,391		75,008
796	Electric General	Bick	Building & Infrastructure	D.0001834.039	Carlsbad Roof Seal-Safety System	272,224		75,573
797	Electric General	Harkness	Aging Technology	D.0001821.278	2018 T INFS Network Refresh S	257,063		71,364
798	Electric General	Cooley	RE	A.0001301.020	Roswell Ing New 11.5kV Terminal Com	252,009		69,961
799	Electric General	Cooley	GI	A.0000736.003	Needmore Communication	244,912		67,991
800	Electric General	Harkness	Enhance Capabilities	D.0001804.397	Purch Wireless HW SPS	239,605		66,518
801	Electric General	Cooley	RE	A.0000194.006	Cochran RTU, Comm	228,136		63,334
802	Electric General	Cooley	RE	A.0001310.008	Walkemeyer 345/115 Sub Comm	217,960		60,509
803	Electric General	Lytal	Reliability & Performance Enhancement	A.0003000.689	GMSOC-TX Lab Instruments	217,876		60,486
804	Electric General	Cooley	RE	A.0006296.007	New Centre St Comm	212,859		59,093
805	Electric General	Harkness	Aging Technology	D.0001839.148	2018 Storage Annual Refresh SP	207,751		57,675
806	Electric General	Harkness	Aging Technology	D.0002016.004	Purch T&D MPLS - Unplanned (2017) S	197,841		54,923
807	Electric General	Harkness	Aging Technology	D.0002014.001	Purch WAN HW SPS-BSPRJ0001170	197,774		54,905
808	Electric General	Cooley	OT	A.0006059.500	EPZ Mats NM	190,062		52,764
809	Electric General	Cooley	OT	A.0006059.499	EPZ Mats TX	185,713		51,557
810	Electric General	Cooley	RE	A.0000540.017	Atoka Comm Sub Portion Comm	181,320		50,337
811	Electric General	Harkness	Enhance Capabilities	D.0001804.396	Purch Wireless HW NM	175,180		48,632
812	Electric General	Cooley	SR	A.0000605.227	GSM/GC Purchase Vehicles	173,296		48,109
813	Electric General	Cooley	SR	A.0000499.017	PS ELR 11.5kV NM Comm	169,242		46,984
814	Electric General	Harkness	Enhance Capabilities	D.0001804.327	Purch Wireless HW SPS	167,034		46,371
815	Electric General	Harkness	Aging Technology	D.0001840.004	2017 Network Refresh SPS	164,421		45,646
816	Electric General	Cooley	OT	A.000795.003	SPS Sub Comm Network Group 1 C	163,179		45,301
817	Electric General	Cooley	GI	A.0001351.003	Roswell Comm	160,460		44,546
818	Electric General	Cooley	RE	A.0000658.007	Seagraves Comm	147,339		40,904
819	Electric General	Harkness	Aging Technology	D.0002014.002	Purch WAN HW NM	146,254		40,602
820	Electric General	Cooley	GI	A.0000350.004	Lost Draw Comm	143,270		39,774
821	Electric General	Cooley	RE	A.0001353.001	Reosevelt Comm	140,839		38,099
822	Electric General	Cooley	GI	A.0000902.002	TUCO RTU Addition Comm	135,542		37,629
823	Electric General	Cooley	OT	A.0000710.007	NM Physical Security Comm	132,175		36,694
824	Electric General	Harkness	Cyber Security	D.0001840.114	Purch Sec Camera HW TX	114,721		31,848
825	Electric General	Cooley	RE	A.0000658.006	Terry Co Comm	114,109		31,678
826	Electric General	Cooley	LI	A.0001008.004	Inst 220kV Sw Station Comm	111,870		31,057
827	Electric General	Meeks	Purchases	A.0005549.034	TX Frame Relay Replacement	111,566		30,972
828	Electric General	Cooley	OT	A.0006059.432	Tool Blanket TX Line	108,292		30,063
829	Electric General	Cooley	SR	A.0001067.002	Lubbock South Communication	103,192		28,647
830	Electric General	Lytal	Reliability & Performance Enhancement	A.0003000.684	TOL0.C - Purch Misc Tools	98,438		27,728
831	Electric General	Cooley	SR	A.0001067.003	Lubbock East Communication	97,429		27,048
832	Electric General	Lytal	Reliability & Performance Enhancement	A.0003000.668	HARRIC-Purch Plant Tools	95,600		26,540

Southwestern Public Service Company  
Capital Additions  
April 1, 2018 through March 31, 2019

Line No.	Asset Class	Witness	Project Category	WBS Level 2	Project Description (WBS Level 2 Description)	(E)	(F)	(G)
833	Electric General	Harkness	Aging Technology	D.0001821.538	Purch Mobile Handheld HW SPS	93,656	Additions to Plant-in-Service (April 1, 2018 - March 31, 2019) Total Company	26,000 NM Retail
834	Electric General	Cooley	RE	A.0000498.005	OCHOA Comm	92,896		25,789
835	Electric General	Cooley	SR	A.0000499.016	Line ELR SPS 2016 Comm	91,691		25,455
836	Electric General	Cooley	SR	A.0000153.003	SPS Trans Switch Comm	83,308		23,127
837	Electric General	Cooley	LI	A.0000844.003	Install Switch and Tap Comm	80,896		22,458
838	Electric General	Cooley	RE	A.0000494.003	Semiwire Xfmr East Comm	79,541		22,082
839	Electric General	Cooley	LI	A.0000424.073	W39 Inst Switch for Enterprise	71,768		19,374
840	Electric General	Bick	Building & Infrastructure	D.0001823.084	Misc Bldg - Electric - Dumas - Rout	65,419		18,161
841	Electric General	Cooley	RE	A.0001283.003	Business System Equip for Eng Acces	65,343		18,140
842	Electric General	Harkness	Aging Technology	D.0001821.537	2018 IT INF5 Network Ref HW NM	64,721		17,968
843	Electric General	Cooley	RE	A.0001272.002	Cargill 14.4 Mvar Cap Bank Comm	63,180		17,540
844	Electric General	Cooley	RE	A.0000424.043	OPIE 3 Hobbs 345kV Sub Comms U	62,076		17,233
845	Electric General	Cooley	OT	A.0006659.436	SPS Ops Engineering Tools	59,245		16,447
846	Electric General	Lytal	Reliability & Performance Enhancement	D.0003000.692	GMSOC-MNMR Instruments	56,118		15,579
847	Electric General	Cooley	RE	A.0000511.018	Carl-Wolf Wolfforth Comm	54,102		15,020
848	Electric General	Cooley	OT	A.0000588.001	SPS RTU EMS Upgrade	53,949		14,977
849	Electric General	Cooley	RE	A.0000290.008	Cunningham Ing Uppr Eddy Term Comm	53,801		14,936
850	Electric General	Bick	Building & Infrastructure	D.0001818.022	Amarillo Tower New Lease	51,606		14,327
851	Electric General	Harkness	Enhance Capabilities	D.0001804.325	Purch Wireless Hobbs NM SPS	51,522		14,303
852	Electric General	Lytal	Reliability & Performance Enhancement	A.0003000.691	GMSOC-TRA'C Tools	49,357		13,702
853	Electric General	Cooley	RE	A.0000194.007	Cochran Comm Equlp	49,254		13,674
854	Electric General	Lytal	Reliability & Performance Enhancement	A.0003000.429	JONOC-Rpl Milling Machine	48,276		13,402
855	Electric General	Cooley	RE	A.0000424.222	Quihada Communication	45,354		12,591
856	Electric General	Lytal	Reliability & Performance Enhancement	A.0001550.460	HAROC-Purchase PMI Analyzer	39,628		11,001
857	Electric General	Lytal	Reliability & Performance Enhancement	A.0003000.673	JONOC-Capital Tools	37,899		10,521
858	Electric General	Cooley	OT	A.0000656.223	Fleet New Units El Trans NM	36,470		10,125
859	Electric General	Lytal	Reliability & Performance Enhancement	A.0003000.677	PLXOC-Purch Misc Plant Tool	35,068		9,735
860	Electric General	Harkness	Aging Technology	D.0001839.406	Microwave Crossroads Towers SP	34,563		9,595
861	Electric General	Cooley	OT	A.0006059.437	SPS COM Tools (BU 8371)	34,545		9,390
862	Electric General	Lytal	Reliability & Performance Enhancement	A.0003000.674	MADOC-Purchase Cap Tools	34,414		9,354
863	Electric General	Cooley	RE	A.0000424.221	PCA Communication	33,396		9,271
864	Electric General	Bick	Tools & Equipment	A.0006059.489	Tools & Equipment - Electric - NM	32,469		9,014
865	Electric General	Harkness	Aging Technology	D.0001839.621	Purch Avaya Server HW SPS	32,451		9,009
866	Electric General	Lytal	Reliability & Performance Enhancement	A.0003000.693	GMSOC-PMO Equipment	28,270		7,848
867	Electric General	Cooley	SR/LI	A.0000851.002	Pringle Substation Comm	25,223		7,002
868	Electric General	Lytal	Reliability & Performance Enhancement	A.0003000.690	GMSOC-L&C Tools	23,823		6,614
869	Electric General	Cooley	LI	A.0000905.002	Install Switch and Tap Comm	22,101		6,136
870	Electric General	Cooley	RE	A.0002033.001	Portales Interchange Sub Comm	21,825		6,059
871	Electric General	Lytal	Reliability & Performance Enhancement	A.0003000.675	NICOC-Purch Plant Tools	21,541		5,980
872	Electric General	Cooley	OT	A.0006059.011	SPS CIP 5 Roosevelt Co NM Comm	21,412		5,944
873	Electric General	Cooley	RE	A.0000424.233	Hopi BK Inst pecos Term Sub Comm	21,368		5,932
874	Electric General	Bick	Building & Infrastructure	D.0001810.057	Amarillo NESC Evidence Storage Faci	21,098		5,857
875	Electric General	Cooley	OT	A.0006059.434	SPS Training Center Tools	18,804		5,220
876	Electric General	Harkness	Aging Technology	D.0001800.939	Purch Verint Server HW SPS	17,848		4,955

Exhibit DG-7

Attachment LJW-2  
Page 21 of 25  
Case No. 19-00170-UT

Southwestern Public Service Company  
Capital Additions  
April 1, 2018 through March 31, 2019

Exhibit DG-7

Attachment LJW-2  
Page 22 of 25  
Case No. 19-00170-UT

Line No.	Asset Class	Witness	Project Category	WBS Level 2	Project Description (WBS Level 2 Description)	(E)	(F)	(G)
						Additions to Plant-in-Service (April 1, 2018 - March 31, 2019) Total Company	Additions to Plant-in-Service (April 1, 2018 - March 31, 2019) NM Retail	Additions to Plant-in-Service (April 1, 2018 - March 31, 2019) NM Retail
877	Electric General	Harkness	Aging Technology	D 000216.018	Purch T&D MPLS - Unplanned (2017) O	17,683	4,909	4,909
878	Electric General	Meeks	Purchases	A 0005549.028	NM-Elec Dist Communication Equip	17,563	4,876	4,876
879	Electric General	Cooley	OT Purchases	A 0001118.009	Lock and Key System OK	17,284	4,798	4,798
880	Electric General	Meeks	RE	A.0005014.110	Remodel SPS Lubbock Dist Control Ce	16,427	4,560	4,560
881	Electric General	Cooley	OT	A.0000424.069	L Ridge 11.5kV Sub Comms - UID 50	13,979	3,881	3,881
882	Electric General	Cooley	Aging Technology	A.0000924.010	SPS CIP 5 Potter Co Comm	13,796	3,830	3,830
883	Electric General	Harkness	OT	D.0001839.370	Purch SPS Gold Elite Console H	13,782	3,826	3,826
884	Electric General	Cooley	OT	A.0000924.009	SPS CIP 5 Plant X Sta Comm	13,595	3,774	3,774
885	Electric General	Lyal	Reliability & Performance Enhancement	A.0003000.688	GMSOC-Training Tools	13,165	3,655	3,655
886	Electric General	Harkness	Enhance Capabilities	D.0002007.008	Purch Digital Signage HW SPS	12,390	3,440	3,440
887	Electric General	Meeks	Purchases	A.0006036.019	NM-DIST Fleet New Unit Purchase El	12,286	3,411	3,411
888	Electric General	Cooley	OT	A.0000598.010	Grassland RTU Replacement	11,139	3,092	3,092
889	Electric General	Meeks	Purchases	A.0005555.002	NM - Frame Relay Replacement	10,356	2,875	2,875
890	Electric General	Cooley	OT	A.0006059.081	Tools Sys Protection Comm Eng	9,332	2,591	2,591
891	Electric General	Harkness	Aging Technology	D.0001822.010	Purch Sub Frame Relay Equip SP	9,182	2,549	2,549
892	Electric General	Meeks	Purchases	A.0005014.076	SPS-Subs Furniture Blanket	8,831	2,452	2,452
893	Electric General	Harkness	Aging Technology	D.0001822.057	Purch Sub Frame BAU Sites TX SPS	8,784	2,439	2,439
894	Electric General	Cooley	OT	A.0005014.109	Gen Pit Ofc Furn TX	7,594	2,108	2,108
895	Electric General	Bick	Building & Infrastructure	D.0001806.086	Mechanical - Dumas - Routine	7,465	2,072	2,072
896	Electric General	Bick	Security - Controls & Monitoring	D.0001781.041	Security Projects - Electric -	6,739	1,871	1,871
897	Electric General	Cooley	SR	A.0000598.009	Tuco 115 House RTU Replacement Comm	6,509	1,807	1,807
898	Electric General	Cooley	RE	A.0000890.002	Eddy Co. Xlnr #1 Communication	5,939	1,649	1,649
899	Electric General	Harkness	Aging Technology	D.0001821.232	Purch Sub Frame Relay Equip NM	5,850	1,624	1,624
900	Electric General	Meeks	Purchases	A.0006039.105	NM-T Transportation Tools & Equi	5,480	1,521	1,521
901	Electric General	Cooley	RE	A.0000846.002	Denver City RTU Comm	5,171	1,436	1,436
902	Electric General	Harkness	Cyber Security	D.0001804.126	Purch Network Appl Camera Upgr SPS	4,412	1,225	1,225
903	Electric General	Cooley	OT	A.0005014.084	New Mexico Substation Furnitur	4,364	1,211	1,211
904	Electric General	Harkness	Aging Technology	D.0001821.232	2017 Unplanned PC Refresh SPS	4,179	1,160	1,160
905	Electric General	Cooley	LI	A.0000907.002	Kiser Distribution Add Comm	3,605	1,001	1,001
906	Electric General	Harkness	Aging Technology	D.0001797.009	Purch Sub Frame Relay OK SPS	3,395	942	942
907	Electric General	Cooley	GI	A.0000768.004	Blanco Comm	2,316	643	643
908	Electric General	Harkness	Aging Technology	D.0001783.010	Purch LMR HW SPS	2,278	633	633
909	Electric General	Harkness	Aging Technology	D.0001822.058	Purch Sub Frame BAU Sites NM SPS	2,142	595	595
910	Electric General	Cooley	RE	A.0000424.229	OPIE POTASH LIVINGSTON RIDGE RECOND	2,055	571	571
911	Electric General	Bick	Building & Infrastructure	D.0001810.035	Amarillo Tower - Structural	1,742	484	484
912	Electric General	Cooley	SR	A.0000220.029	SPS NM SEE Comm	1,731	481	481
913	Electric General	Cooley	OT	A.0000924.014	SPS CIP 5 Yorkum Co Comm	1,646	457	457
914	Electric General	Meeks	Purchases	A.0006056.010	TX-DIST Fleet New Unit Purchases	1,408	391	391
915	Electric General	Harkness	Aging Technology	D.0001840.019	2017 Network Ref NM	1,320	366	366
916	Electric General	Lyal	Reliability & Performance Enhancement	A.0003000.663	CHCOC-Cunningham Tools	1,318	366	366
917	Electric General	Harkness	Aging Technology	D.0001804.022	Purch Corp Network Core HW SP	1,318	365	365
918	Electric General	Cooley	RE	A.0000424.223	Hopi Comm	1,312	364	364
919	Electric General	Harkness	Aging Technology	D.0001839.675	Purch Roosevelt MW NM SPS	1,265	351	351
920	Electric General			D.0001828.004	Purch NS T&D Network Equip SPS	1,122		

Southwestern Public Service Company  
Capital Additions  
April 1, 2018 through March 31, 2019

Exhibit DG-7

Attachment LJW-2  
Page 23 of 25  
Case No. 19-00170-UT

Line No.	Asset Class	Witness	Project Category	WBS Level 2	Project Description (WBS Level 2 Description)	(D)	(E)	(F)	(G)
						Service (April 1, 2018 - March 31, 2019) Total Company	Additions to Plant-in-Service (April 1, 2018 - March 31, 2019) Total Company	Additions to Plant-in-Service (April 1, 2018 - March 31, 2019) NM Retail	
921	Electric General	Cooley	OT	A.0002048.003	Higg Inst New SCADA Radio Comm	969	269	256	
922	Electric General	Cooley	RE	A.0000574.007	Cooler Relay Mod. Sub COMM	923	815	226	
923	Electric General	Cooley	RE	A.0000906.001	Lynn Co RTU Replacement Comm	737	737	205	
924	Electric General	Cooley	RE	A.0000424.129	China Draw Sub Comm	600	167		
925	Electric General	Cooley	RE	A.0000424.074	Sage Brush 115kV Sub Commns _UID	508	141		
926	Electric General	Harkness	Aging Technology	D.0001703.009	Purch EMS DEMS Plat HW SPS	334	93		
927	Electric General	Harkness	Aging Technology	D.0001839.025	2016 IT INF5 Network Refresh S	264	73		
928	Electric General	Harkness	Aging Technology	D.0001821.401	2015 IT INF5 Refresh Communica	119	33		
929	Electric General	Cooley	RE	A.0000532.003	TPL BTR V31 Riverview Comm	76	21		
930	Electric General	Cooley	RE	A.0000424.018	Poash Junc 115/69 Xfrm UpgrC	76	21		
931	Electric General	Cooley	RE	A.0000424.130	North Loving RTU - comm	76	21		
932	Electric General	Bick	Building & Infrastructure	D.0001814.046	Electrical - Burger - Routine	71	20		
933	Electric General	Cooley	OT	11302945	Fleet New Units 2011 El Tran, SPS	65	18		
934	Electric General	Harkness	Aging Technology	D.0001822.001	Purch Corp Frame Relay HW SPS	25	7		
935	Electric General	Bick	Building & Infrastructure	D.0001806.080	Mechanical - Lubbock - Routine	3	1	1	
936	Electric General	Bick	Building & Infrastructure	D.0001806.001	Mechanical	1	0		
937	Electric General	Harkness	Aging Technology	D.0001839.679	Purch Net Core Rte Amarillo SPS	(5)	(1)		
938	Electric General	Cooley	OT	A.0005014.069	AC Unit 2015 for Subs	(24)	(7)		
939	Electric General	Harkness	Aging Technology	D.0001839.063	2015 IT INF5 Network Refresh S	(56)	(15)		
940	Electric General	Harkness	Aging Technology	D.0001797.010	Purch Sub Frame Relay KS SPS	(293)	(81)		
941	Electric General	Harkness	Aging Technology	D.0001821.185	2016 Unplanned PC Refresh SPS	(478)	(133)		
942	Electric General	Cooley	GI	A.0000706.002	Hitchland Firewheel Comm	(6,987)	(1,940)		
943	Electric General	Harkness	Aging Technology	D.0001821.208	2017 Planned PC SPS	(15,724)	(4,365)		
944	Electric General	Cooley	RE	A.0000421.052	Swisher Sub. Communications	(22,846)	(6,342)		
945	Electric General	Harkness	Cyber Security	D.0001839.832	Purch Net Sec HW SPS	(57,274)	(15,900)		
946	Electric General	Cooley	RE	A.0000352.016	Yoakum 230 kV Bus Rebld, Commu	(313,944)	(87,155)		
947	Electric General	Cooley	RE	A.0000424.041	OPIE 2 Kiowa 345kV Sub Commns U	(820,831)	(227,875)		
948	Electric General	<b>Total</b>				\$ 42,913,242	\$ 11,663,475		
949	Electric Intangible	Harkness	Aging Technology	D.0001805.004	Next Gen MSFT LIC SW SPS-10692	\$ 3,401,180	\$ 944,216		
950	Electric Intangible	Harkness	PTT	D.0001787.009	Customer Mgmt. SPS	2,932,094	813,991		
951	Electric Intangible	Harkness	Aging Technology	D.0001826.191	Enhanced Response Manage SW SPS	1,041,385	289,233		
952	Electric Intangible	Harkness	PTT	D.0001787.004	SAP Financial Mgmt SPS	966,479	268,308		
953	Electric Intangible	Harkness	Enhance Capabilities	D.0001839.391	Sharpoint 2013 Plat2 SW SPS	949,163	263,501		
954	Electric Intangible	Harkness	Aging Technology	D.0002002.907	NMS 1.1.2 Upgrade SW SPS-10669	759,942	210,971		
955	Electric Intangible	Harkness	Aging Technology	D.0001804.151	Interval Complex Billing SW SP	668,146	185,487		
956	Electric Intangible	Harkness	Enhance Capabilities	D.0001826.247	2015 RPAM Phase 3 Amort SW SPS	610,205	169,402		
957	Electric Intangible	Harkness	Aging Technology	D.0001796.018	Netw Tools Telecom Exp SW TX -106	560,993	155,740		
958	Electric Intangible	Harkness	Aging Technology	D.0001744.019	IrthNet Damage Prevent SW SPS	506,452	140,598		
959	Electric Intangible	Harkness	PTT	D.0002006.013	Microfocus SW SPS-10721	450,595	125,091		
960	Electric Intangible	Harkness	Aging Technology	D.0002003.010	2018 Oracle SW SPS-10701	409,078	113,566		
961	Electric Intangible	Harkness	Aging Technology	D.0002003.014	2019 Oracle SW SPS-10748	404,749	112,364		
962	Electric Intangible	Harkness	Aging Technology	D.0002097.007	UAST Plat SW SPS-10689	353,544	98,149		
963	Electric Intangible	Harkness	Cyber Security	D.00002099.007	Firewall Rule Mgmt SW SPS-10707	345,214	95,836		

# Exhibit DG-7

Attachment LJW-2

Page 24 of 25

Case No. 19-00170-UT

Southwestern Public Service Company  
Capital Additions  
April 1, 2018 through March 31, 2019

Line No.	Asset Class	Witness	Project Category	WBS Level 2	Project Description (WBS Level 2 Description)	(E)	(F)	(G)
964	Electric Intangible	Harkness	Cyber Security	D.0001771.007	Certicate Key Mgmt SW SPS	336,074	Additions to Plant-in-Service (April 1, 2018 - March 31, 2019)	Additions to Plant-in-Service (April 1, 2018 - March 31, 2019)
965	Electric Intangible	Harkness	Cyber Security	D.0001825.098	Advanced Endpoint SW SPS-10685	330,384	NM Retail	NM Retail
966	Electric Intangible	Harkness	Aging Technology	D.0002067.004	OSI Fin Agree SW SPS-10726	276,433		
967	Electric Intangible	Harkness	Aging Technology	D.0002020.014	SAP Cont Improve R13 SW SPS-10706	265,485		
968	Electric Intangible	Harkness	Aging Technology	D.0001826.161	Venin Workforce SW SPS	259,315		
969	Electric Intangible	Harkness	Enhance Capabilities	D.0002050.004	IT Service Request SW SPS-10699	246,023		
970	Electric Intangible	Harkness	PIT	D.0001726.058	Work and Asset Phase 1 SW SPS	245,902		
971	Electric Intangible	Harkness	Aging Technology	D.0002162.004	Microsoft Core Server SW SPS-10727	241,869		
972	Electric Intangible	Harkness	Aging Technology	D.0001839.379	RedSky e01 SW SPS	221,184		
973	Electric Intangible	Harkness	Cyber Security	D.0002058.004	CyberArk PAM SW SPS-10694	217,277		
974	Electric Intangible	Harkness	Cyber Security	D.0002001.014	Sailpoint Ph3 SW SPS-10717	211,607		
975	Electric Intangible	Harkness	Aging Technology	D.0002004.014	SAP Data Mart Ph2 SW SPS-10690	195,305		
976	Electric Intangible	Harkness	Aging Technology	D.0002066.004	Bus Obj Ref SW SPS-10658	170,644		
977	Electric Intangible	Harkness	Cyber Security	D.0002008.004	Ent DataBase Security Ph2 SW SPS-10	147,637		
978	Electric Intangible	Harkness	Enhance Capabilities	D.0001796.025	Network Tools Mgmt SW SPS-10700	141,841		
979	Electric Intangible	Harkness	Enhance Capabilities	D.0001792.176	Rational SW SPS-10715	123,015		
980	Electric Intangible	Harkness	Cyber Security	D.0001818.108	Emergency Mass SW SPS-10709	118,012		
981	Electric Intangible	Harkness	Aging Technology	D.0001839.851	RedSky Ph2 SW SPS Direct	74,307		
982	Electric Intangible	Harkness	Cyber Security	D.0002101.006	eGRCPhi3 SW SPS-10719	71,328		
983	Electric Intangible	Harkness	Aging Technology	D.0001839.613	CRSCM SW SPS-10644	30,556		
984	Electric Intangible	Harkness	Aging Technology	D.0001826.381	Mobile App Ph2 SW SPS-10695	25,338		
						7,034		

# Exhibit DG-7

Attachment LJW-2  
Page 25 of 25  
Case No. 19-00170-UT

**Southwestern Public Service Company**  
**Capital Additions**  
**April 1, 2018 through March 31, 2019**

(A)	(B)	(C)	(D)	(E)	(F)	(G)	
Line No.	Asset Class	Witness	Project Category	WBS Level 2	Project Description (WBS Level 2 Description)	Additions to Plant-in-Service (April 1, 2018 - March 31, 2019) Total Summary	Additions to Plant-in-Service (April 1, 2018 - March 31, 2019) NM Retail
985	Electric Intangible	Harkness	Cyber Security	D.0001747.008	Data Loss Ph2 SW SPS	21,882	6,075
986	Electric Intangible	Harkness	Aging Technology	D.0001747.008	Data Warehouse Env Ref SW SPS	21,105	5,859
987	Electric Intangible	Harkness	Aging Technology	D.0001770.020	Sec File Ph3 SW SPS-10716	21,023	5,836
988	Electric Intangible	Harkness	Enhance Capabilities	D.0002034.004	CEC-TCPA Do Not Call SW SPS-10703	20,746	5,759
989	Electric Intangible	Harkness	Cyber Security	D.0002182.004	Sharepoint RFP SW SPS-10739	17,090	4,744
990	Electric Intangible	Harkness	Aging Technology	D.0001818.090	SIEM Extension SW SPS-10679	10,188	2,628
991	Electric Intangible	Harkness	Aging Technology	D.0001770.014	Secure File Transfer Ph 2 SW SPS-10	8,826	2,450
992	Electric Intangible	Harkness	Cyber Security	D.0001804.365	eGRIC Security SW SPS-10660	4,399	1,221
993	Electric Intangible	Harkness	Cyber Security	D.0001804.376	eGRIC Security Ph2 SW SPS-10668	3,635	1,009
994	Electric Intangible	Harkness	Aging Technology	D.0001792.162	Informatica New Ver-10673 SW SPS	2,354	654
995	Electric Intangible	Harkness	Aging Technology	D.0001744.027	ITSM Ph4 SW SPS	1,282	356
996	Electric Intangible	Harkness	Aging Technology	D.0002004.004	SAP Data Mart SW SPS-10675	1,123	312
997	Electric Intangible	Harkness	Cyber Security	D.0001755.007	Identity & Access Mgmt Sailpoi	987	274
998	Electric Intangible	Harkness	Aging Technology	D.0001839.821	DMZ Airwatch SW SPS-10664	701	195
999	Electric Intangible	Harkness	Enhance Capabilities	D.0001804.369	Integrated Talent Ph4 SW SPS-10637	352	98
1000	Electric Intangible	Harkness	Aging Technology	D.0001792.152	XE COM Optimization Ph2 SW SPS-1066	315	88
1001	Electric Intangible	Harkness	Cyber Security	D.0001761.007	Database Security SW SPS	233	65
1002	Electric Intangible	Harkness	Cyber Security	D.0001839.642	Network Security Protect SW SPS-106	194	54
1003	Electric Intangible	Harkness	Enhance Capabilities	D.0001792.141	10634-eGERC NERC SW SPS	156	43
1004	Electric Intangible	Harkness	Cyber Security	D.0001818.077	Vulnerability NeXpose SW SPS-10665	114	32
1005	Electric Intangible	Cooley	OT	A.0002062.001	GIST-IV Computer Software SPS	56	16
1006	Electric Intangible	Harkness	Aging Technology	D.0001744.044	Teradici HW SW SPS	26	7
1007	Electric Intangible	Harkness	Enhance Capabilities	D.0001826.233	Solar Energy Grid SW SPS	4	1
1008	Electric Intangible	Harkness	Aging Technology	D.0001822.036	TD Ciena Network SW SPS-10642	3	1
1009	Electric Intangible	Harkness	Enhance Capabilities	D.0001763.014	ITSM Secure Ticket SW SPS-10676	1	0
1010	Electric Intangible	Harkness	Cyber Security	D.0001783.017	WebSense SW SPS-10670	(10)	(3)
1011	Electric Intangible	Harkness	Enhance Capabilities	D.0001783.018	GeoSpatial Integration SW SPS-10653	(43)	(12)
1012	Electric Intangible	Harkness	Aging Technology	D.0001743.007	Upgraded IEEE 5.3 to IEEE 8.1 SW	(59)	(16)
1013	Electric Intangible	Harkness	Enhance Capabilities	D.0001759.007	Fleet Focus SW SPS	(40)	(39)
1014	Electric Intangible	Harkness	Enhance Capabilities	D.0001839.635	VMware Private Cloud SW SPS-10647	(209)	(58)
1015	Electric Intangible	Harkness	Enhance Capabilities	D.0001804.306	Federated Records SW SPS-10640	(267)	(74)
1016	Electric Intangible	Harkness	Cyber Security	D.0001818.084	Vulnerability AppSpider SW SPS-1066	(442)	(123)
1017	Electric Intangible	Harkness	Aging Technology	D.0001826.064	Mobile Application Customer SW	(548)	(152)
1018	Electric Intangible	Harkness	Enhance Capabilities	D.0001815.043	Renewable Energy SW SPS-10649	(617)	(171)
1019	Electric Intangible	Harkness	Enhance Capabilities	D.0001826.241	SAP BI Suite SW SPS	(786)	(218)
1020	Electric Intangible	Harkness	Enhance Capabilities	D.0001741.007	Data Quality Tool SW SPS	(1,623)	(451)
1021	Electric Intangible	Harkness	Aging Technology	D.0002007.004	Digital Signage SW SPS-10671	(2,161)	(600)
1022	Electric Intangible	Harkness	Enhance Capabilities	D.0001767.007	Self Service and PAF SW SPS	(2,483)	(689)
1023	Electric Intangible	Harkness	Cyber Security	D.0001826.211	ITSA Pole Ph3 SW SPS	(2,570)	(713)
1024	Electric Intangible	Harkness	Cyber Security	D.0001754.007	Identity & Access Mgmt QAS SW	(2,738)	(760)
1025	Electric Intangible	Harkness	Cyber Security	D.0002001.007	SalPoint Extension SW SPS-10667	(60,483)	(16,791)
1026	Electric Intangible	<b>Total</b>				<b>\$ 18,371,298</b>	<b>\$ 510,149</b>
1027	<b>Grand Total</b>					<b>\$ 458,521,070</b>	<b>\$ 116,171,298</b>

**BEFORE THE NEW MEXICO PUBLIC REGULATION COMMISSION**

**IN THE MATTER OF SOUTHWESTERN )  
PUBLIC SERVICE COMPANY'S )  
APPLICATION 1) TO AMEND ITS )  
CERTIFICATES OF PUBLIC )  
CONVENIENCE AND NECESSITY TO )  
CONVERT HARRINGTON )  
GENERATION STATION FROM COAL )  
TO NATURAL GAS, 2) FOR )  
AUTHORIZATION TO ACCRUE )  
ALLOWANCE FOR FUNDS USED IN )  
CONSTRUCTION, AND 3) FOR OTHER )  
ASSOCIATED RELIEF )  
)**

**CASE NO. 21-00200-UT**

**SOUTHWESTERN PUBLIC SERVICE  
COMPANY,**

**APPLICANT.**

**SOUTHWESTERN PUBLIC SERVICE COMPANY'S RESPONSE  
TO SIERRA CLUB'S FIRST SET OF INTERROGATORIES AND  
REQUESTS FOR PRODUCTION OF DOCUMENTS**

Southwestern Public Service Company (“SPS”) hereby responds to and answers the Sierra Club (“SC”) First Set of Interrogatories and Requests for Production as set forth below.

**PRELIMINARY MATTERS-GENERAL OBJECTION**

SPS objects to the instructions and directions in SC’s First Set of Interrogatories and Requests for Production to the extent that SC improperly seeks to: (1) expand or establish more burdensome requirements for discovery than the requirements of the New Mexico Public Regulation Commission’s Rules and Procedures (i.e., 1.2.2.25 NMAC) and the New Mexico Rules of Civil Procedure for the District Courts (i.e., NMRA Rules 1-026 through 1-037); and (2) require disclosure of privileged communications and information pursuant to the attorney-client privilege

or disclosure of communications and information protected from discovery under the attorney work product doctrine. Subject to this general objection, SPS responds to SC's First Set of Interrogatories and expressly reserves all evidentiary objections concerning any of SPS's answers or related documents that SC may seek to offer into evidence at the hearing in this case. Relating to SC's discovery requests that seek disclosure of confidential/proprietary information, SPS will provide a copy of confidential/proprietary information to SC and other parties who sign the approved confidentiality agreement. Confidential/proprietary documents responsive to specific discovery requests have been identified with the designation "(CONF)."

**QUESTION NO. SC 1-5:**

For the Harrington units:

- a. Please produce any unit replacement studies done by the Company.
- b. Identify any transmission grid updates or changes that would be needed to allow for the retirement of any of the units.
- c. Produce any analysis or assessment of the need for the continued operations of each unit.
- d. Provide the remaining book value (plant balance) at the start of 2021.
- e. Identify the current undepreciated book value, and the expected undepreciated book value for each year of the remaining operation life of the unit.
- f. Produce any analysis or assessment of the impact that retirement of each unit would have on capacity adequacy, transmission grid stability, transmission grid support, voltage support, or transmission system reliability.

**RESPONSE:**

- a. Please refer to Exhibit SPS-SC 1-3(i)(CONF) and Exhibit SPS-SC 1-3(ii) for the unit replacement studies SPS conducted in 2021 and 2019, respectively.
- b. Transmission grid updates or changes will be studied and identified by the Southwest Power Pool, pursuant to Attachment AB "Generator Retirement Process" of the Open Access Tariff. During this process, Southwest Power Pool will perform a study to identify any updates or changes, if required, within a year of filing the retirement request. Retirement requests are required to be filed with Southwest Power Pool no less than one year from the expected retirement date. SPS does not conduct this process.
- c. Please refer to SPS's responses to subpart (a) and subpart (f).
- d. Please refer to Exhibit SPS-SC 1-5(d).
- e. Please refer to SPS's response to subpart (d).
- f. Please refer to subpart (a) and Exhibit SPS-SC 1-5(f)(CONF).

Preparers: Ben R. Elsey, Jarred Cooley, Sean Young  
Sponsors: Ben R. Elsey, William A. Grant



## Harrington Station Fuel Repowering System Impact Study

SPS Study #190311

Potter County, Texas

Xcel Energy Services, Inc.  
Transmission Planning, South

July 19, 2019

## Executive Summary

Transmission Planning has completed a study to assess reliability based impacts to the Southwestern Public Service Company (SPS) transmission system, as a result of the Harrington Station fuel repowering from coal to natural gas. The work completed was for both transient stability analysis and post transient stability, steady state power flow analysis. Contingencies assessed were taken from the list of events studied during the yearly North American Electric Reliability Corporation (NERC) TPL-001-4 analysis. These events were chosen due to the compliance obligations that SPS is required to meet during its yearly assessment.

The results of this study have determined several key factors that could result as concerns once the Harrington units are converted to natural gas fuel. Prior to outlining these concerns, it should be noted that the generation dispatch for the different model scenarios were developed based on an economic dispatch using the software tool PROMOD to reflect a market based dispatch. As such, new generation was added to these scenario models as part of the PROMOD dispatch without the required transmission system upgrades needed for interconnection, since the interconnection is being studied by the Southwest Power Pool (SPP). Therefore the validity of many of the impacts had to be carefully scrutinized.

Key notable concerns for this study include the dispatch of Harrington. It is concerning that the Harrington units did not make it into the economic dispatch used in the models for this study, leading us to believe that these units may not be dispatched when converted. As for impacts associated with outages, some of the key outages include those related to tie-line outages, which impact power imports into the SPS system. The outage of tie-lines was also identified as concern. Most impactful are the Category P3 outages for the EHV<sup>1</sup> transmission system. The outages of generators coupled with EHV outages of 345kV tie-lines, produced a large number of non-convergent results alluding to transmission system collapse due to the insufficiency of generation in the SPS area and import limitations caused by the outage of tie-lines. These types of violations mandate a Corrective Action Plan, per the requirements of the NERC TPL-001-4 reliability standard. Similar outages producing concerns are the combination of tie-line outages. During the outage of two EHV tie-lines (Category P6) and lines across the North-South interface and a tie-line, also produces a large number of non-convergent results. The violations produced by these types of outages will only become worse by the additional oil and gas growth in the southeast New Mexico as additional generation is retired.

As a result of the wide range of NERC TPL-001-4 disturbances assessed as part of the study, this study recommends the conversion of the Harrington units to synchronous condensers, in lieu of retiring the units. In addition, the MW capacity from the Harrington generation should be replaced and relocated to the south

<sup>1</sup> Extra High Voltage (>300kV)

west part of the SPS transmission system to serve the growing load pocket in the area. Equally important is the construction of a new 345kV transmission path from Potter County to Tolk Station, to alleviate flow-through across the Amarillo Metro HV<sup>2</sup> network and the North-South interface. This will provide an EHV transmission path from the Texas Panhandle during the outage of tie-lines south of the North-South interface. There is also a need for the addition of a second Potter 345/230kV transformer, due to high power-flows from the Texas Panhandle.



## Table of Contents

Executive Summary .....	2
Table of Contents.....	4
Introduction.....	5
Study Methodology.....	5
Modeling Assumptions.....	6
Contingency Events .....	6
Transmission Planning Observations/Concerns .....	18
Conclusions.....	19

## Introduction

The objective of this study is to assess impacts to the transmission system of Southwestern Public Service Company (SPS), for both system-intact and during contingency events consistent with the NERC TPL-001-4 reliability standard. The study is required to determine if the repowering of the Harrington Station from its present fuel source, coal, to its proposed fuel source, natural gas, will cause additional impacts to the transmission system of SPS.

It is Transmission Planning's understanding that the main driver for this fuel repowering is the Clean Air Act<sup>3</sup>, which was last amended in 1990, requires EPA to set National Ambient Air Quality Standards (40 CFR part 50) for pollutants considered harmful to public health and the environment. The Clean Air Act identifies two types of national ambient air quality standards. Primary standards provide public health protection, including protecting the health of "sensitive" populations such as asthmatics, children, and the elderly. Secondary standards provide public welfare protection, including protection against decreased visibility and damage to animals, crops, vegetation, and buildings.

The study considered options for the coal fired generators at Harrington station, as a result of a mandate from the Clean Air Act calling for the reduction of SO<sub>2</sub> emission required by the National Ambient Air Quality Requirement (NAAQS<sup>4</sup>). The scenario models developed for this study were developed with guidance from the Resource Planning group at Xcel Energy, in addition to assistance from the Regional Reliability Planning group, which provided the market based economic generation dispatches for the different scenario models. Details specific to the different scenario models used for this study are noted in the Modeling Assumptions section of this report.

## Study Methodology

The study analysis was performed using the Power Technologies, Inc. (PTI) Power System Simulator for Engineering (PSS<sup>TM</sup>E) program and contains a steady-state analysis using the AC Contingency Calculation (ACCC) with a Fixed Slope Decoupled Newton-Raphson (FDNS) solution. The study was conducted ensuring that current SPS/SPP/NERC criteria are fulfilled for voltage and thermal performance of the transmission system elements. As applicable, the criteria used for system intact conditions mandates that bus voltages must be maintained between 0.95 - 1.05 per-unit of their nominal voltage value and thermal system-intact conditions must not exceed their designated normal rating, or A-rating. During transmission system contingencies, bus voltages on the SPS transmission system are allowed to deviate between 0.90 - 1.05 per-

<sup>3</sup> <https://www.epa.gov/clean-air-act-overview>

<sup>4</sup> <https://www.epa.gov/criteria-air-pollutants/naaqs-table>

unit of their nominal voltage values and thermal loading on transmission system equipment cannot exceed 100% of the emergency B-rating.

Additionally as part of this study, the events specific to Table 1 of the NERC TPL-001-4 reliability standard are evaluated, and impacts associated with this standard are discussed and called-out in this report. Impacts specific to the fuel repowering of the generators are also discussed, along with concerns from Transmission Planning.

## **Modeling Assumptions**

The models used for this analysis were derived from the SPP 2019 ITPNT<sup>5</sup> Lubbock Power and Light (LPL) sensitivity models, where a portion of the LPL load is no longer in SPP. The transmission projects initially not added by SPP in the development of these ITP models were also added to these models. The transmission projects added were the Eddy – Kiowa 345kV line and China Draw – Phantom – Roadrunner 345kV lines, along with the 350 MW in southeast New Mexico. The significant differences considered as impacting to the various scenario models, is the generation dispatch specific to the season. The generator dispatch in each of the seasonal models comes from an economic dispatch, using PROMOD<sup>6</sup>. The PROMOD dispatch applied to each of the scenarios was provided by the Regional Planning Analytics group. The seasonal models created are the 2024 Light Load, 2024 Summer Peak and a 2024/25 Winter Peak.

The modeling assumptions for the Harrington generators in this study include fuel-repowering, generator conversion to synchronous condensers, and the addition of new gas fired generation to the SPS transmission system. The differences in the scenarios considered as part of this study are discussed below.

1. Retirement of all Harrington generation, without replacement of the MW capacity.
2. Harrington generators at the present location are repowered from coal to direct firing of the boiler with natural gas.
3. Repowering of two Harrington units to natural gas and replacing MW capacity at the Gaines Plant location in Andrews County, Texas.
4. Conversion of all three existing Harrington generators to synchronous condensers.
5. Retirement of all three Harrington Station generators by converting them to synchronous condensers and adding MW capacity at the Gaines Plant in Andrews County, Texas.

## **Contingency Events**

Power Flow contingency events considered as important for this study were chosen from Table 1 of the NERC reliability standard TPL-001-4. These events were selected for this study due the compliance obligations SPS

<sup>5</sup> Integrated Transmission Plan, Near Term

<sup>6</sup> ABB software

must meet for this reliability standard, and include a wide range of events from simple single-element type events, to those having a lower probability of occurring yet a much higher impact to the transmission system.

The events chosen include NERC TPL-001-4 Category P1 events consisting of single element outages. These events although only evaluate the outage of a single element, do not allow for the curtailment of non-sequential load for events taking place on the EHV and HV transmission elements. Category P2 events result in bus faults utilizing normal bus-differential clearing times to isolate the fault. Category P3 events are faults where the initial event is the outage of a generator, followed by an additional generator outage, or the outage of some other transmission system element. These other elements could include transformers, shunt devices, bus sections or transmission lines, including tie-lines to entities outside of the SPS legacy BA<sup>7</sup>. These events, similar to Category P1 events, do not allow for the curtailment of non-sequential load for events taking place on both the EHV and HV transmission system. The mechanical failures of breakers resulting in the inability of the breaker to isolate faults are evaluated under Category P4 events. These events are impactful since not all breakers on the SPS transmission system have breaker failure relaying, which can trigger a much larger system outage as a result of the time it takes for the remaining relays, local to the event, to recognize and isolate the fault. The Category P5 events analyze the failure of primary relaying on those transmission elements that do not have secondary or redundancy in the relaying. In the absence of secondary relaying fault isolation is left to the remaining uncoordinated relays, which at times cannot isolate the fault quickly enough, triggering a much larger than expected outage, and in some instances these faults are not isolated with the remaining relaying. Category P6 events, similar to the P3 events, are meant to consider the impact of outages on the transmission system due to the outage of two transmission elements, with the first event allowing for system adjustments prior to the second event. These Category P6 events were studied as an N-2 event (double contingency), disavowing system adjustments that are permitted for the first event and concentrating on a Corrective Action Plan (CAP) for the final state of the system following the outage of both elements. Finally Category P7 events consider the effects to the transmission system during the outage of two adjacent transmission circuits built on common transmission structures. Extreme events from the NERC Table 1 resulting in the loss of gas supply to some of the power plants were considered in this study.

Among the contingencies above, it should be noted that violations triggered by Category P1 events do not allow for the curtailment of load following the event. Violations from Category P3 events share the same fate and solutions to violations identified by both of these types of events require a CAP to mitigate the violations. As for the other type of event Categories, curtailment of load may be allowed; however for violations occurring on the EHV system these are not allowed and require a CAP.

<sup>7</sup> Balancing Authority

## NERC Category P1 Event Results

The 2024 Light Load scenario 1 model has all the Harrington units retired; this resulted in high imports (1750MW, 299MVar) on SPS tie lines to meet the generation deficiency. Consequently the critical contingency for Light Load scenario 1 steady state analysis is the loss of Tuco to OKU 345kV Tie line (with import of 400MW, 87Mvar), which resulted in non-convergence due to localized voltage collapse in the SPS area. 2024 Light Load scenario 2 and 3 which modeled the Harrington generation converted from coal to natural gas did not dispatch the Harrington units due to the economic generation dispatch used in these models (based on economics of fuel used for the generation), which resulted in the similar issues in scenario 2 and 3 as that of scenario 1 model for category P1 events. Whereas in 2024 Light Load scenario 4 model with all the Harrington units converted to synchronous condensers generated a combined reactive capability of at least 389 MVars providing voltage support to the SPS system resulted in mitigating the issues caused in 2024 Light Load scenario 1, 2 and 3 for the loss of Tuco to OKU 345kV Tie line.

Potter 345/230 transformer was found to be overloaded in all 2024 Light Load Scenario 1, 2, 3, 4 and 5 models due to high import on the SPS tie lines and can be mitigated by adding second Potter 345/230 transformer. Also in 2024 Light Load scenario 1, 2, 3, and 4 models thermal violation at Bushland – Deafsmith 230kV (K11) and Deafsmith –PlantX 230kV (K21) lines were observed due to the north to south flow to meet the load demand in the southern part of SPS system, which can be mitigated by upgrading transmission line terminals on K11 and K21 circuits or adding generation in southern part of SPS system (scenario 5).

2024 Winter Peak scenario 1, 2, 3, 4 and 5 models observed thermal violation at Potter 345/230 transformer and Spearman to Hansford 115kV (T87) line due to high import on the SPS tie lines and can be mitigated by adding second Potter 345/230 transformer and/or upgrading transmission terminal on T87 line.

It is also observed that by the addition of Potter to Pleasant Hill 345kV line or Potter to Tolk 345kV line to the system mitigates all the above mentioned P1 violations in 2024 Light Load and 2024 Winter Peak scenario models.

2024 Summer Peak scenario 1, 2 and 4 observed thermal violation at Allen to Lubbock South 115kV for the loss of Lubbock S to Wolfforth 230kV line. The violation is not related to Harrington generation retirement since turning on all the Harrington generation to full capacity, did not fix this thermal violation. This violation was mitigated in scenario 3 and scenario 5 models with the addition of Gaines generation of about 186MW and 700MW respectively.

The scenario 5 model has the addition of Gaines combined cycle generation (~700MW) to the system without modelling the transmission upgrades required for the generation interconnection. This resulted in thermal and voltage violation near generation interconnection location at Gaines, Hobbs and Andrews which are not related to Harrington generation retirement but due to the lack of transmission upgrades at generation interconnection.

### **Transient Stability P1 results:**

The 2024 Light Load scenario 1 model has all the Harrington units retired; this resulted in high imports on SPS tie lines to meet the generation deficiency. Consequently the critical contingencies for the Light Load scenario 1 transient stability analysis are the loss of Tuco to OKU 345kV or Tuco to Border 345kV Tie lines resulting in system instability generation at Hobbs, Tolk and Mustang losing synchronism and trip. 2024 Light Load scenario 2 and 3 which modeled the Harrington generation converted from coal to natural gas did not dispatch the Harrington units due to the economic generation dispatch used in these models (based on economics of fuel used for the generation), which resulted in the similar issues in scenario 2 and 3 as that of scenario 1 model for category P1 events.

In 2024 Light Load scenario 4 model with the conversion of all Harrington units to synchronous condensers and in 2024 Light Load scenario 5 model with the conversion of all Harrington units to synchronous condensers and addition of Gaines generation (700MW) provided voltage and inertia support to the SPS system resulted in mitigating the issues caused in 2024 Light Load scenario 1, 2 and 3 for the loss of the Tie lines.

It is also observed that by the addition of Potter to Pleasant Hill 345kV line or Potter to Tolk 345kV line to the system mitigates the P1 transient stability issues in 2024 Light Load scenario 1, 2 and 3 models.

Based on the steady state and transient stability results retiring or converting (scenario 1,2,3) all Harrington units to gas powered generation would result in steady state and transient stability issues in Light Load off peak season, since the gas units are not dispatched due to the economics of running the units in Light load. The ideal scenario would be to convert 1 or 2 Harrington units to gas powered generation and the remaining unit/s to synchronous condensers. Also, due to the huge load growth in South East New Mexico adding generation in South East New Mexico (preferably south of the SPS area) would help the SPS system. It is also observed that by the addition of Potter to Pleasant Hill 345kV line or Potter to Tolk 345kV line to the system mitigates P1 violations in 2024 Light Load and 2024 Winter Peak scenario models.

### **NERC Category P2 Event Results**

NERC TPL-001-4 Category P2 events that were assessed consisted of a single line-to-ground bus fault occurring on BES<sup>8</sup> substations having a straight bus or main and transfer bus design. A single line-to-ground bus fault at these substations results in the loss of the entire substation which could cause voltage violations and thermal overloads at other locations of the transmission system. There were 105 Category P2 events evaluated across five specific Harrington scenario models for both steady state and stability implications.

For the steady state analysis, with the exception of the Lubbock South 230 kV straight bus outage in the 2024 Summer Peak scenarios, all steady state violations were none persistent, meaning the violations did not occur across all of the scenarios and seasons. The greatest impact to the transmission system occurs in the scenario 1 model when all three Harrington units are retired. For these scenarios the transmission system experiences a deficiency in VAR<sup>9</sup> support and a greater occurrence of low bus voltages along with thermal overloads. The converse is also evident in scenarios 4 and 5, with Harrington going to synchronous condensers in scenario 4 and with the addition of new generation in southeast New Mexico in scenario 5. For these two scenarios, steady state violations occurred less frequently in comparison to the scenario 1 model.

Additionally, thermal violations are evident on the Lubbock South to Lubbock East 115kV line (V34) as a result of a bus fault outage of the Lubbock South 230 kV straight bus in the 2024 Summer Peak. This “persistence” implies that the dispatch during this season of the scenarios would cause a violation whether the Harrington generators were in-service or not. The violation can be mitigated by opening the 115kV line V34 from Lubbock South to Lubbock East.

For the Category P2 a stability analysis was conducted for all the aforementioned scenarios. The analysis determined that there were no unstable results indicating violations and no low bus voltage concerns that required a CAP.

The retirement of the Harrington units reduced the voltage and VAR support across the system. The addition of the synchronous condensers in scenarios 4 and 5 and the addition of generation in scenario 5 helped or eliminated many of the violations seen in scenarios 1, 2, and 3.

### **NERC Category P3 Event Results**

<sup>8</sup> Bulk Electric System

<sup>9</sup> Volt-Ampere Reactive (Reactive Power)

NERC TPL 001-4 Category P3 events (multiple contingency) consist of the initial condition of the loss of a generating unit (G-1), followed by system adjustments, which is then followed by the loss of one of the following; Generator (P31), Transmission Circuit (P32), Transformer (P33), or Shunt Device (P34).

The Harrington study models were developed in accordance with the study scope. The generation dispatches for the three load levels (2024 Summer Peak, 2024 Winter Peak, and 2024 Light Load) and five Scenarios studied were provided by the Regional Planning Analytics Group and consisted of economic dispatches determined by the PROMOD IV IV production cost model. As per the study scope, the transmission circuits utilized for P32 events consisted of all SPS 230kV and 345kV circuits including Tie-Lines, and all the 115kV circuits and Tie-Lines in the Amarillo zone part of SPS transmission system, where Harrington is located.

#### **Steady State P3 results:**

This analysis showed that the Category P3 contingencies placed a great strain on the SPS transmission system in this study. There were several issues and concerns contributing to this: The first was the initial state of the transmission system having the Harrington units off-line, this alone removes over 480 MVar's of Reactive Support from the SPS system. The second issue was the economic dispatches of the SPP RTO determined by the PROMOD IV IV model. These economic dispatches, particularly for 2024 Winter Peak Scenario cases and 2024 Light Load Scenario cases, seem to be importing more power into the SPS transmission system from the rest of the SPP RTO than has actually occurred in recent years. The 2024 Winter Peak Scenario loads were 5,350 MW. The PROMOD IV IV model determined economic dispatch had only 1,984 MW of non-wind/fossil fuel SPS generation on-line to serve this load. The 2024 Light Load Scenario loads were 3,796 MW. The PROMOD IV IV model determined economic dispatch only had 604 MW of non-wind/fossil fuel SPS generation on-line.

An additional concern is retirement of the three Harrington units could exacerbate the impact of a P3 contingency events by tripping up to two more generators, for a total of five SPS generators out-of-service. This can instantaneously cause the system to have to import a great deal of power, due to the loss of two additional generators or the loss of a Tie-Line in combination with a generator.

In addition P3 events also reduce the amount of reactive support on the system from tripping of generator(s), and from the loss of Tie-Lines that are providing reactive support. And in this study the amount of available Reactive Support for the transmission system is already diminished due to the Harrington units being off-line (They provide up to 400 MVar's of support.). Due to this there were a great many times the load flow case was not able to converge and find a solution after a P3 contingency event occurred.. This is referred to as a case being non-convergent, diverging, and also as a case

“Blowing up”. This can be indicative of system or voltage collapse due to lack of adequate reactive support, as well as dynamic/transient instability. This occurred two hundred fifty-eight (258) times in this study. This was consistent with number of P6 contingency events that had non-convergent solutions.

### **2024 Summer Peak**

The five Summer Peak Scenarios fared the best of the load levels studied in regards to cases converging after applying P3 contingencies. In the five 2024 Summer Peak Scenarios studied, only seven P3 contingencies resulted in non-convergent solutions. These were the loss of one Tolk unit followed by the loss of the other Tolk unit in Scenario 1, which can be easily resolved with the addition of a new Tolk–Potter 345kV line that also resolves a number of other issues, or by adding a 400 MVAr SVC at the Tuco 345kV substation. There were also five instances of non-convergence in Scenario 5 resulting from the outage of the Gaines Plant out-feed transmission line. This is easily resolved by adding another line from the combined cycle plant to a different part of the transmission system, perhaps to the Taylor or Legacy 115kV substations.

The most overloaded line in the five Summer Peak Scenarios was the Wheeler–Sweetwater 230kV Tie-Line for loss of a Tolk unit in combination with loss of the Potter 345/230kV transformer. This can also be mitigated by adding a new Tolk–Potter 345kV line or by installing a second 345/230kV transformer at the Potter substation. The addition of a second auto at Potter County can cause thermal overloads in the HV system as more renewables are added to the northern portion of the Panhandle of Texas, as power tries to flow into lower voltage networks. The second most overloaded line in the Summer Peak Scenarios was the Hansford–Spearman 115kV line also for the loss of a Tolk unit in combination with loss of the Potter 345/230kV transformer. Both of these overloads can be mitigated by adding a new Tolk–Potter 345kV line or by installing a second 345/230kV transformer at Potter.

### **2024 Winter Peak**

The five 2024 Winter Peak Scenarios had eighty-seven non-convergent results caused by P3 contingencies. Just over half of these were due to the loss of the Tuco–OKU 345 kV Tie-Line in combination with the loss of an SPS generator. These can be resolved by adding a new Tolk–Potter 345 kV line or by adding a 500 MVAr SVC at the Tuco 345 kV substation. The remaining non-convergent results can also be resolved with the addition of a new Tolk–Potter 345 kV line or by installing a 500 MVAr SVC at Tuco 345 kV substation.

The most overloaded element in the Winter Peak Scenarios was the Potter 345/230kV transformer for the loss Hobbs unit 3 and one of the Hitchland 230/115kV transformers. The second most overloaded

element is the Hansford-Spearman 115kV line for the loss of the Potter 345/230kV transformer in combination with Hobbs unit 3. Both overloads occur because they are primary import paths into the SPS transmission system from the north Texas Panhandle. These overloads can be resolved by adding a new Tolk–Potter 345kV line or by installing a second 345/230kV transformer at Potter. A benefit of a new Tolk–Potter 345k line that may be overlooked is that it provides an additional import path into the SPS transmission system.

### **2024 Light Load**

Not surprisingly, the five Light Load Scenarios had the highest number of convergence issues of the three load levels. This is primarily because of the economic dispatch used in these Scenarios, where the only non-wind units dispatched within the SPS transmission system is the Hobbs combined cycle plant, the Mustang units and the Blackhawk units. No other SPS fossil unit was on-line in any of the five Light Load Scenarios, except for the Tolk and Harrington units as synchronous condensers.

Accordingly SPS's rotational inertia and available reactive support were diminished in the Light Load Scenarios, lessening the SPS transmission system's capability to withstand disturbances, which directly contributed to the Light Load Scenarios having one hundred and sixty-four (164) P3 contingency events “Blow up” or be non-convergent. Though it should be noted this is only one specific economic dispatch. There are a number of variables that can easily cause more SPS NG units to be on-line during off-peak light load periods.

Similar to the Winter Peak Scenario results, just over half the one hundred sixty-four (164) P3 contingencies that “Blew up” or were non-convergent were due to the loss of the 345kV Tie-Lines into Tuco substation. Loss of either the Tuco–Border 345kV (**SPS–OGE**) or the Tuco–OKU 345kV (**SPS–AEP**) Tie-Lines tripped in combination with an SPS generator caused ninety two (92) non-convergent solutions. Consistent with the Winter Peak Scenario results these can be resolved by adding a new Tolk–Potter 345kV line, or by adding a 500 MVar SVC at the Tuco 345kV substation.

The Light Load Scenarios 1, 2, 3, and 4 had two additional significant contingencies. These were the loss of the Crossroads–Eddy County 345kV line or the Crossroads–Tolk 345kV line in combination with loss of a Hobbs, Mustang or Tolk unit. These can be resolved by installing a 200 MVar SVC at the Eddy County 345kV substation.

The most overloaded line in the Light Load Scenarios was the Bushland–Deaf Smith 230kV Line for loss of the Potter–Newhart 230kV line in combination with loss of the Sagamore Wind Farm. This can be mitigated by bringing one or more of the Mustang GT's on-line. The second most overloaded element in the Light Load Scenarios was the Potter 345/230kV transformer.

Overall the retirement of the Harrington plant and units had no adverse impacts on the local SPS transmission system in and around Amarillo where Harrington is located, with the exception of the Potter 345/230 kV transformer.

### NERC Category P4 Event Results

Steady state results for the Light Load scenarios 1, 2, 3 and 4 models show Category P4 contingencies violations for outages on the major SPS 345kV tie lines like the Tuco-Border 345kV line and the Tuco-Oklahoma 345kV line. This was due to scenarios 1, 2, 3 and 4 not dispatching generation at Harrington station and importing power across the tie-lines. Even in scenario 4, when Harrington units are operated as synchronous condenser these violations are still present. When Harrington units are operated as synchronous condensers (scenario 5) and with the addition of new generation at Gaines County Plant located in southeast New Mexico generating real power (MW), these contingencies do not produce violations in comparison to the other scenarios.

The Summer Peak scenario 1, 2, 3 and 4 have similar violations across all these scenarios. Scenario 5 had significantly more P4 violations than the other Summer Peak scenario because when the Harrington units were operated as synchronous condenser and new generation is added at the Gaines County Plant, the outage of the 230kV Hobbs Substation to the Gaines County Plant tap causes non-convergence issues. The non-convergence was caused by not enough transmission upgrades to support the generation added in S.E New Mexico.

The Winter Peak scenario 1, 2, 3 and 4 have similar violations across scenarios 1, 2, 3 and 4. As for scenario 5 models, it appears to have similar issues as observed in summer scenario 5. It needs to be noted that even though Harrington was converted to Gas, owing to the economic dispatch, no units at Harrington were running in scenario 2 and 3 Winter Peak models. With respect to generation dispatch, scenario(s) 1, 2 and 3 had zero MW dispatch at Harrington station. When the Harrington units are operated as synchronous condenser and a new generation unit added at Gaines Co (scenario 5), the outage of the 230kV Hobbs-Gaines Co line causes violations.

The combined cycle plant was added in S.E. New Mexico in scenario 5 without any associated transmission upgrades. This caused scenario 5 cases to have convergence issues (for the Summer Peak and Winter Peak models) for the loss of elements at Andrews Co/ Hobbs Generating Station. These issues are not related to Harrington plant retirement and should be treated as localized issues mainly due to non-addition of any transmission upgrade to support the generation that were added. The mitigation is to build a 345kV line from Hobbs-Andrews-Roadrunner solves convergence issues with the outage of the 230kV Hobbs- Gaines Co line.

Based on the results observed, it can be summarized that cases where Harrington is being dispatch as a gas plant and when it operates as synchronous condenser generating MVARs and providing voltage support have less system convergence issues. It also needs to be noted that building a new 345kV line between Potter Co-Tolk or Potter-Pleasant Hill sub helps mitigate most of the overloads issues (not all the issues) due to P4 contingencies for outages on the major SPS 345kV tie lines like the Tuco-Border 345kV line and the Tuco-Oklahoma 345kV line in Light Load.

For an extreme event for the loss of all three units at Hobbs substation causes system convergence issues in the Light Load and Winter Peak models. This is caused by not having enough generation to the south of the SPS system. To mitigate this issue the addition of generation is needed in south of the SPS system.

The transient stability results did not cause any concerns to the SPS transmission system in this study.

### **NERC Category P5 Event Results**

The power flow results for Category P5 events indicate the presence of violations as a result of these types of events. To resolve these violations, the addition of redundancy in the relaying, consistent with current company standards will be required. This may include replacing circuit breakers having single trip coils; typically old oil circuit breakers with breakers having dual trip coils in order to achieve full redundancy. The events and the violations produced among the different scenarios are most evident during periods of light load, one such violation of is the overloading of the Potter 345/230kV autotransformer. This violation is evident during system intact conditions, primarily due to the flow of power from the Hitchcock-Potter 345kV line towards the south via the high voltage network. Additional violations that produced which are also a cause for concern, are those emerging from P5 events associated with both bus and autotransformer outages at the Mustang Interchange and the Oasis Interchange. Some of these outages produce non-convergent results which could indicate local system collapse, while at Mustang these events could trigger the outage of Mustang generation. The Sunset 115kV substation bus outage is also the cause of low bus voltage conditions.

During Summer Peak loading conditions, the same events noted above during the light load conditions continue to cause concerns. However, due to the change in the generation dispatch additional events producing violations at Lamb County and South Georgia for bus and autotransformer outages cause thermal violations and low bus voltage conditions. At Deaf Smith Interchange, the 230kV circuit K11 event (Bushland-Deaf Smith) produces low bus voltages. Finally, a new violation which is the 230kV line from Hobbs to the Gaines Plant tap, going towards Andrews Interchange, overloads for outages associated with bus events at Johnson Draw, Taylor and West Hobbs.

Finally, during the Winter Peak scenarios, the same events and violations previously mentioned are evident and can be resolved with the addition of redundancy in the relaying, consistent with existing company standards.

It should be noted that these events which are triggering violations in this study have been previously identified as requiring relay upgrades as part the NERC TPL-001-4 reliability assessment. The one violation where a CAP has previously not been identified is the overload of the Potter 345/230kV autotransformer and shows up during multiple contingencies. The simple solution to this violation would be the addition of a second autotransformer at Potter County. However, a Potter-Tolk 345kV line also resolves the overload of the Potter 230/115kV autotransformer providing a 345kV path from the northern portion of the SPS transmission system during the outage of the tie-lines into Tuco Interchange resolving other NERC Category P-type TPL-001-4 violations. The 345kV line also provides a direct transmission path through the Amarillo area, minimizing the thermal impact on the underlying high voltage network through Amarillo.

### **NERC Category P6 Event Results**

Owing to the fact that NERC TPL 001-4 Category P6 events allow for Interruption of Firm Transmission Service and load curtailment as a mitigation, only power flow analysis was performed for Category P6 events to identify the types of contingencies causing power flow case convergence issues (i.e. localized voltage collapse).

The Light Load (high wind – low load) scenario 1, 2 and 3 scenarios had many convergence issues for the loss of combination(s) of SPS' major 345kV tie lines like Tuco-Border 345kV line, Tuco-Oklahoma 345kV line, etc. This was due to the fact that these two lines were importing a total of approximately 20-25% of entire SPS load prior to any outages. When the Harrington unit(s) are operated as synchronous condensers (scenario 4 and 5) or operated as a gas fired plant generating real power (MW), the same contingencies didn't seem to cause as many convergence issues. It should be noted that even though Harrington was converted to a gas fired plant, owing to the economic dispatch, no units at Harrington were dispatched as part of scenarios 2 and 3 for the Light Load models. With respect to generation dispatch, scenario(s) 1, 2 and 3 had zero MW at the Harrington station and the issues noticed in all of these models were very similar to one another.

Amongst the different Summer Peak scenario models, the Category P6 events did not exhibit significant differences, where the same contingencies caused similar violations. Since there were a considerable amount of new loads added to southeast New Mexico footprint, the scenario 5 model having a new

combustion turbine and combined cycle plant, appears to be the scenario producing the most favorable results, independent of what happens to Harrington.

The Winter Peak scenario models generally appear to have similar issues as those observed during the Light Load scenario models.. Additionally, as with the Light Load models, when the Harrington unit(s) were operated as synchronous condenser (scenario 4 and 5) or operated as gas fired plant generating real power (MW), these same contingencies didn't seem to cause as many convergence issues.

Based on the results observed, it can be summarized that repowering the Harrington units to natural gas or operating them as synchronous condensers for voltage support lessens system convergence issues. Additionally, building a new 345kV line from Potter County to Tolk Station helps mitigate most of the system convergence issues (not all the issues) due to the combination of major SPS 345kV tie-lines outages in Light Load and Winter Peak scenario models and in scenario 5 models converting the Hobbs to Gaines Plant to Andrews 230kV line to 345kV operation, followed by the addition of new 345kV line from Andrews to Road Runner helps mitigate most of the system convergence issues.

### **NERC Category P7 Event Results**

NERC TPL-001-4 Category P7 events that were assessed consisted of every two adjacent BES circuits on a common structure in the SPS system greater than 1 mile. A total of 67 events were evaluated for both steady-state and stability concerns. The evaluation of the steady-state results showed 5 violations while the stability results showed 0 violations. Steady-state violations were due to line overload issues.

The Light Load (high wind – low load) scenario 1, 2, 3 and 4 models had a line overload issue for 115kV line V04 Manhattan to Randall for the contingency of double circuit lines K19 Harrington to Randall County and K62 Nichols to Amarillo South. This overload issue may be resolved with LIDAR analysis for line V04 Manhattan to Randall County. Only scenario 1 had one line overload issue for line K21 Deaf Smith to Plant X for the contingency of double circuit lines K90 Potter County to Newhart and K91 Newhart to Plant X. This overload issue may be resolved by upgrading the wavetrap at Plant X. The scenario 5 model showed to be the best scenario since it had no issues.

The Summer Peak scenario 1, 2, 3, 4 and 5 models had a line overload issue for line V34 Lubbock East to Lubbock South for the contingency of double circuit lines K08 Lubbock South to Jones and K14 Lubbock South to Jones. This violation and contingency pair was also apparent in the 2024 Winter Peak case. Only scenario 1, 3 and 4 models had a line overload issue for the same line V34 Lubbock East to Lubbock South for a different contingency of double circuit lines K07 Tuco to Jones and K15 Lubbock East to Jones. Both line overload issues for line V34 Lubbock East to Lubbock South may be resolved by upgrading the limiting CTs at both Lubbock East and Lubbock South terminals. Only scenario 1 and 4

models had a line overload issue for line K10 Lubbock South to Wolfforth for the contingency of double circuit lines K07 Tuco Int. to Jones and K15 Lubbock East to Jones. The line overload issue for line K10 also appeared in scenario 1 and 4 models for the contingency of double circuit lines K07 Tuco Int. to Jones and T69 Lubbock East to Crosby. This issue may be resolved by analyzing LIDAR for line K10 Lubbock South to Wolfforth. Only scenario 3 had a line overload issue for line T01 Texas County to McMurry for the contingency of double circuit lines K76 Hitchland to Ochiltree and W10 Hitchland to Hansford. This issue may be resolved by upgrading CTs at the Texas County terminal.

The Winter Peak models showed similar issues found in the Summer Peak models. Scenarios 2 and 3 had the same line overload issue for line V34 Lubbock East to Lubbock South for the same contingency of double circuit lines K08 Lubbock South to Jones and K14 Lubbock South to Jones. This issue may be resolved by upgrading the limiting CTs at both Lubbock East and Lubbock South terminals. This violation and contingency pair was also apparent in the 2024 Summer Peak case. Scenarios 1, 4 and 5 had no violations.

Major P7 concerns from this study involved line overload issues. Resolutions for the line overload issues included fixing LIDAR issues and upgrading limiting elements such as terminals and wavetraps which exceeded either its facility or line ratings. LIDAR issues involved lines V04 Manhattan to Randall Co. and K10 Lubbock South to Wolfforth. CT upgrades involved Lubbock East and Lubbock South terminals for line V34 Lubbock East and Lubbock South and the Texas County terminal for line T01 Texas County to McMurry. Wavetrap upgrades involved Plant X for line K21 Deaf Smith to Plant X. The resolutions described above will mitigate line overload concerns for the Harrington Station area.

## **Transmission Planning Observations/Concerns**

This section of the report highlights observations or concerns that Transmission Planning believes are a critical part of the Harrington repowering. One observation is related to the PROMOD dispatch specifically how the Harrington station was dispatched when converted to natural gas. During the Light Load and Winter Peak scenarios, the Harrington generation was not shown as dispatched in these two seasons and could present concerns during the outage of tie lines, other generation or a combination of both. This could result in system collapse due to import limitations. This leads to the concern that the conversion of Harrington to natural gas could result in units that may not be dispatched during off peak seasons in an economic based dispatch.

Another observation worth mentioning is the addition of new generation within the SPS transmission system. The Gaines Plant in Andrews County, Texas was previously sited as a location for the addition of non-renewable resources to the SPS system. Although this location is in close proximity to the developing oil and

natural gas resources, Planning believes that the addition of new generation south of the New Mexico-Texas state line, south of China Draw and Roadrunner is a better location for the addition of a natural gas fired generator. The reason being that generation south of China Draw will provide counter-flow from the southern part of the SPS system alleviating transmission line loading from power flowing in from the north into the SE NM region. This generation can also provide a southern source, which today we do not have one. This southern source also serves as a good contingent plan when the Hobbs generation experiences a forced outage, preventing the curtailment of the developing oil and gas load pocket. Finally, with the development of oil and gas industry south of the New Mexico-Texas state line, in close proximity to this location, this SPS generation location has the potential to grow and serve as a good location for grid switchers between the SPP and the Electric Reliability Council of Texas (ERCOT) systems. Allowing for service to ERCOT load during periods when all the generation at this location is not needed in SPP and providing power to the ERCOT grid along its western boundary.

Planning also has a concern with the PROMOD dispatch, specifically the addition of new generating resources without the needed transmission system facilities that would have been identified as part of the SPP Generation Interconnection (GI) process. Some of these generators, to name a few, which were added to the models, include the Gaines Plant in Andrews County, Texas, the Sagamore Wind Farm and new generators at Plant X. Absent the transmission upgrades needed for both these facilities, contingencies simulated which triggered non-convergent results, may have been non-issues if these GI upgrades where added to the models.

Finally, the cost to operate the Harrington units as natural gas fire generators at a low MW output to produce VARs rather than MW should perhaps be compared to the cost of operating the generators as a synchronous condenser. If the cost comparison permits operating the Harrington units for VAR support, rather than as generators, perhaps the conversion of the generators to natural gas fire units is a better approach than simply converting them to

## **Conclusions**

The result of this study concludes that with the retirement of the MW capacity of the Harrington units, this will cause an increase of power imports into the SPS system during periods when wind resources are generating at a low output. It also shows that transient stability issues could develop if these units are retired without replacing these units with some other type of transmission system improvements to assist during transient stability excursions. The retirement of the Harrington generation will reduce the dynamic

performance of the SPS transmission system since these units contribute up to approximately 400 MVARs of dynamic reactive support, have high inertia values, and provides local MWs that does not have to flow across tie-lines for serving local load. The conversion of the Harrington generators to synchronous condensers reduces the inertia by 72%, retaining only 28% of the inertia that is present today at Harrington.

During periods of high-wind and low-load, wind resources in Texas Panhandle have a much higher probability of being dispatched, as part of an economic dispatch, causing high power flows through the Amarillo Metro area impacting the North-South interface. Since power from the north has to flow across the high-voltage network in the Amarillo Metro area, there is a need for a 345kV transmission path to bypass the Amarillo Metro and to alleviate flow-through across the North-South interface. Additionally, the need for this 345kV transmission path through the Amarillo metro area becomes more critical, especially during the forced outage of generation coupled with tie-line outages at Tuco Interchange, classified as a P3 type of event. The outage of SPS generation, without Harrington in the network, coupled with outages of 345kV transmission at Tuco Interchange, produces additional power flow from the Texas Panhandle across the North-South Interface triggering system collapse. NERC does not allow for the curtailment of load during this type of event and the TPL-001-4 reliability standard requires a CAP for violations triggered by these events.

The same can be said about Category P6 type events resulting in the outage of multiple tie-lines, specifically when one tie-line is out for maintenance and another is forced out of service. These types of EHV events, although allowing for the curtailment of load could result in NERC fines if cascading outages are evident and not addressed.

(In conclusion, if the Harrington generation is converted to natural gas but it is not dispatched, it is the same as retiring the generation. It should also be noted that a “best attempt” was made in trying to assess what happens if the Harrington generators are retired or converted to synchronous condensers. This is mainly due to the introduction of new generators on the SPS transmission system by the PROMOD dispatch, with no transmission system upgrades that would have been identified once the Generation Interconnection studies for these new generators are completed. Some of the many renewable energy plants and a combined cycle plant were added to these models without any transmission upgrade included the Sagamore Wind Farm, the Gaines Plant connecting to Andrews County, and generation at Plant X was also added. The addition of the Sagamore wind farm (522MW) at Crossroads substation caused multiple combination(s) of outages of Eddy-Crossroads 345kV line with other 230/345kV elements in that region to cause system convergence issues.

These issues were predominantly noticed in the Light Load scenarios 1, 2, 3 and 4. A combined cycle plant was also added in Andrews County Texas, for scenario 5, without any associated transmission upgrades. This caused scenario 5 contingency events to produce non-convergence results for the outage of the generator outlet facilities connecting to the Hobbs Generating Station to Andrews County 230kV transmission line, resulting in the islanding of the combine cycle plant. These issues are not related to Harrington plant retirement and should be treated as localized issues mainly due missing transmission upgrades required to support this generation.

## Recommendations

As a result of the wide range of NERC TPL-001-4 disturbances assessed as part of the study, this study recommends the conversion of the Harrington units to synchronous condensers, in lieu of retiring the units. In addition, the MW capacity from the Harrington generation should be replaced and relocated to the south west part of the SPS transmission system to serve the growing load pocket in the area. Equally important is the construction of a new 345kV transmission path from Potter County to Tolk Station, to alleviate flow-through across the Amarillo Metro HV network and the North-South interface. This will provide an EHV transmission path from the Texas Panhandle during the outage of tie-lines south of the North-South interface. There is also a need for the addition of a second Potter 345/230kV transformer, due to high power-flows from the Texas Panhandle.




Figure 1, Local Transmission System to Harrington Station

[ this page intentionally left blank ]

[ this page intentionally left blank ]