



Filing Receipt

Received - 2022-01-05 04:10:30 PM

Control Number - 52667

ItemNumber - 15

PUBLIC UTILITY COMMISSION of TEXAS PROJECT NO. 52667

FILING OF REPORT AND ATTESTATION REGARDING COMPLIANCE WITH HB 4150 FOR

FANNIN COUNTY ELECTRIC COOPERATIVE, INC.

MANDATE:

To comply with HB 4150, not later than January 14, 2022, each electric utility, municipally owned utility, or electric cooperative meeting the requirements of Section 6 of HB 4150 must file in Project No. 52667 a report with the following information:

- A declaration that each distribution line above 1 kilovolt or transmission line above 60 kilovolts owned by the utility that crosses a lake listed in PURA § 38.004(b) meets the applicable vertical clearance requirements established in Rule 232 of the NESC Standard ANSI (c)(2).
- The date on which the company verified each line's compliance with the applicable NESC Standard.
- For each utility that self-identified a line that did not meet vertical clearance requirements in an annual report filed in either Project 50596 or Project 51890, a declaration that each line identified in the annual report meets the NESC Standard.
- If a line over a lake listed in PURA § 38.004(b) does not meet the NESC Standard:
 - The name of line;
 - The name of lake and the county or counties in which the lake is located;
 - A narrative description of actions the utility will take to bring the line into compliance with the NESC Standard; and
 - The date by when the line will be brought into compliance.

Each affected utility must submit with the report an affidavit signed by an officer of the company who has direct responsibility for distribution or transmission service or construction attesting to the veracity of the information provided in the report.

REPORT:


- Fannin County Electric Cooperative, Inc. (FCEC) owns distribution lines above 1 kilovolt, over Lake Bonham, a lake listed in PURA § 38.004(b).
- These distribution lines over Lake Bonham meet the applicable vertical clearance requirements established in the current Rule 232 of the NESC Standard ANSI (c)(2).
- The vertical clearances of these distribution lines were verified on January 5, 2022.
- FCEC did not identify any violations in reports filed in Project No. 50596 or Project No 51890.

Affected Entity: Fannin County Electric Cooperative, Inc.

PROJECT NO. 52667

AFFIDAVIT

I swear or affirm that I have personal knowledge of the facts stated in this report or am relying on people with personal knowledge, that I am competent to testify to them, and that I have the authority to submit this report on behalf of the affected entity. I further swear or affirm that all statements made in this report are true, correct, and complete.



Signature

John Ed Shinpaugh

Printed Name

Job Title

GM/CEO

Job Title


Job Title

Fannin County Electric Cooperative, Inc.

Name of Affected Entity

Name of Affected Entity

Sworn and subscribed before me this 5th day of January, 2022
Month Year



Notary Public in and For the State of Texas.

My commission expires on 6/21/2023.

