

# **Filing Receipt**

Filing Date - 2024-03-07 03:59:25 PM

Control Number - 52667

Item Number - 175

#### PROJECT NO. 52667

FILING OF ATTESTATIONS	§	PUBLIC UTILITY COMMISSION
DEMONSTRATING COMPLIANCE	§	
WITH HB 4150	§	OF TEXAS

# PROGRESS REPORT OF DENTON COUNTY ELECTRIC COOPERATIVE, INC., D/B/A COSERV ELECTRIC

Denton County Electric Cooperative, Inc. d/b/a CoServ Electric files this progress report regarding compliance with Section 6 of House Bill 4150 ("HB 4150"), providing information regarding distribution lines on United States Army Corps of Engineers ("USACE") property that CoServ Electric identified as non-compliant in its report and attestation filed in this docket on January 14, 2022 ("Initial Report"). By letter dated March 4, 2022, the Division of Compliance and Enforcement ("DICE") of the Public Utility Commission of Texas ("Commission") requested a progress report and additional information to be filed on a monthly basis. This is CoServ Electric's progress report for March 2024, which is timely filed.

#### 1. Progress Report

In its last progress report, CoServ Electric identified two distribution line segments located in areas that could be suitable for a sailboat and remained non-compliant with the applicable clearance standards in Rule 232 of NESC Standard ANSI (c)(2) ("NESC Rule 232"). These two line segments remain in progress at Lake Lewisville, as described below.

#### 1. Status of engineering design, permitting, and reconstruction.

The status of the remaining distribution line segments is as follows:

- Lewisville 31A USACE has approved the location of new customer-owned meter
  pedestal and underground facilities to four existing boathouses and one security light.
  The customer is working to obtain easement rights to locate the customer's pedestal
  and associated facilities, which are not owned by CoServ Electric. Once the customer
  obtains easement rights and the pedestal is located, CoServ Electric will begin
  construction of new underground service to the customer and remove all existing
  overhead facilities from USACE property.
- Lewisville 34 Redesign for underground facilities completed and submitted to USACE for permit approval. Waiting on USACE approval to begin construction.

Further information is provided in Attachments A and B attached hereto.

Date: March 7, 2024 Respectfully submitted,

Carl R. Galant

State Bar No. 24050633

Travis Vickery

State Bar No. 00794790

McGinnis Lochridge LLP

1111 W. 6th Street, Bldg. B, Suite 400

OR. Cet


Austin, Texas 78703

Phone: (512) 495-6083 Fax: (512) 505-6383

cgalant@mcginnislaw.com

tvickery@mcginnislaw.com

#### ATTORNEYS FOR COSERV ELECTRIC



### ATTACHMENT & NESC - LAKE LEWISVILLE CLEARANCES ANALYSIS

New Job Code

## Finance Ensement Elevation Reference Pool Elevation

	Lake Lewisville	(05-2-1.42	SE #4191426					537.00	532.00*			
Lake Lewisville Crossing Number	Date Analyzed	ACTION NEEDED	WARNING FLAGS INSTALLED (EST.)	COSERV DESIGN COMPLETE	SURVEY	PERMIT SUBMITTED	PERMIT	COSERV CONSTRUCTION COMPLETE	NOTES	SUITABLE / NOT SUITABLE (ENGINEERING FIRM DETERMINATION)	CLEARANCE COMPLIANCE	LAKE ACRES AT CROSSING
tenissile 7	13/5/2021	None	Complete	Complete	N/A:	N/A:	N/A	Complete	Removed CoServ utilities from Army Corp of Engineers Howage Easement/Reference Pool	SHITABLE FOR SALBOAT	ж	4609.6
Levi ville 154	11/5/2021	None	Complete	Complete	R/A:	N/A	N/A	Complete	Removed Coborv utilities from Army Corp of Engineers Flowage Eastment/Reference Pool	SUITABLE FOR SAIGNOAT	YES	22291.6
Lewiwille 178	11/5/2021	None	Complete	Complete	N/A	N/A	N/A	Considera	Romoved Coberv utilities from Army Corp of Engineers Howage Lesement/Reference Pool	SUITABLE FOR SAUBOAT	YES	22291.6
Leniwille 31A	11/5/2021	Engineering Package Profinsinary - Electrician invitalling new More Pedestal and underground Service for Member	Complete	9/16/2022	N/A	14/3.	8/4		Design to remove Cuberv utilities from Jerny Corp of Engineers Hossage Learment/Reference Pool	SUITABLE FOR SALBOAT	NO	22291.6
teniwile 34	21/5/2022	Approval from USACE for Revised Overhead and Underground Design	Complete	Complete	Complete	Complete	USACE to imiles Revisions		Power time flevision flequined. To Resolve issues with 90' Concrete Poles and meet flegulatory Compliance we are conventing a section of Overhead to Uniference.	SUITABLE FOR SAUBOAT	NO	22291,6