



## **Filing Receipt**

**Filing Date - 2024-10-04 01:43:40 PM**

**Control Number - 52667**

**Item Number - 189**



## HB4150 Progress Report

<b>Date:</b>	September 30, 2024
<b>Line ID:</b>	<b>Lake Crossing-Line #1 is located off Pearl Street (377 Business)</b>
<b>Project / Compliance Status:</b>	The City, with the assistance of retained outside support, has determined that the line was in compliance status at the time of construction and that it is not subject to the current clearance requirements. See affidavit for research results, which updates and supersedes all prior attestations and reports.
▪ <b>Line Status</b>	See compliance status statement above
▪ <b>Permits</b>	See compliance status statement above
▪ <b>Mapping Information</b>	See compliance status statement above
▪ <b>Public Information Actions</b>	<ul style="list-style-type: none"> <li>▪ Post signage at appropriate locations (boat ramps; boat dock areas) to inform boaters and the general public about the clearance situation; Safety signage designed and ordered. <b>Safety signage installed</b></li> <li>▪ Post a notice on the City's website to inform the public about this situation and the location of the line;</li> <li>▪ City prepared and posted on April-4, a "power line notice" and news release with information on the status of the two lines on the City's website. The notice / news release provides the following: <ul style="list-style-type: none"> <li>○ Background information;</li> <li>○ Information on the steps the City is taking to address the situation;</li> <li>○ A project schedule;</li> <li>○ Contact information;</li> <li>○ Here is a link to the notice / news release. <a href="https://www.granbury.org/CivicAlerts.aspx?AID=939">https://www.granbury.org/CivicAlerts.aspx?AID=939</a></li> </ul> </li> <li>▪ Post information on City's social media platform(s) to inform the public about this situation and the location of the line. Social media notices will be posted by April 28<sup>th</sup></li> </ul>
▪ <b>Project Schedule</b>	▪ See compliance status statement above



## HB4150 Progress Report

<b>Date:</b>	September 30, 2024
<b>Line ID:</b>	<b>Lake Crossing-Line #2 is located in Brazos Harbor</b>
<b>Project / Compliance Status:</b>	The City, with the assistance of retained outside support, has not been able to determine that the line was in compliance status at the time of construction. See affidavit for research results, which updates and supersedes all prior attestations and reports.
▪ <b>Line Status</b>	No updates from the previous report
▪ <b>Permits</b>	No updates from the previous report
▪ <b>Mapping Information</b>	No updates from the previous report
▪ <b>Public Information Actions</b>	<ul style="list-style-type: none"> <li>▪ Post signage at appropriate locations (boat ramps; boat dock areas) to inform boaters and the general public about the clearance situation; Safety signage designed and ordered. <b>Safety signage installed.</b></li> <li>▪ Post a notice on the City's website to inform the public about this situation and the location of the line;</li> <li>▪ City prepared and posted on April-4, a "power line notice" and news release with information on the status of the two lines on the City's website. The notice / news release provides the following: <ul style="list-style-type: none"> <li>○ Background information;</li> <li>○ Information on the steps the City is taking to address the situation;</li> <li>○ A project schedule;</li> <li>○ Contact information.</li> <li>○ Here is a link to the notice / news release. <a href="https://www.granbury.org/CivicAlerts.aspx?AID=939">https://www.granbury.org/CivicAlerts.aspx?AID=939</a></li> </ul> </li> <li>▪ Post information on City's social media platform(s) to inform the public about this situation and the location of the line. Social media notices will be posted by April 28<sup>th</sup></li> </ul>
▪ <b>Other</b>	<ul style="list-style-type: none"> <li>▪ LiDAR data collection is complete.</li> <li>▪ Lake crossing design is complete. The line has been straightened out and the crossing is close to 90 degrees. The design is going to require one self-supported pole.</li> <li>▪ Currently coordinating with Geotechnical firms to have a soil boring done for the self-supported pole.</li> <li>▪ Engineering firm is working on the self-supporting pole design while waiting for geotechnical reports.</li> </ul>



## HB4150 Progress Report

<ul style="list-style-type: none"><li>▪ <b>Project Schedule</b></li></ul>	<ul style="list-style-type: none"><li>▪ Complete design of self-supported poles (date TBD).</li><li>▪ Prepare bid package and send out to qualified contractors (date TBD).</li></ul>
---	---