



## Filing Receipt

**Received - 2022-01-07 03:42:46 PM**

**Control Number - 52667**

**ItemNumber - 22**

**Jasper Newton Electric Cooperative, Inc.**

**Project No. 52667 Compliance Report**

---

**This report was prepared by Jasper Newton Electric Cooperative, Inc. (JNEC) to comply with PUCT Project No. 52667 regarding the filling of attestations Demonstrating Compliance with HB 4150.**

**Report Date** January 7, 2022  
**Entity** Jasper Newton Electric Cooperative, Inc.  
**ERCOT Entity Type** Distribution Service Provider  
**Lakes listed in PURA § 38.004(b)  
in JNEC Service area** B.A. Steinhagen  
Sam Rayburn  
**County of Lake and Distribution Line** Jasper and Angelina

Line Identifier	Lake	Compliance with NESC 232	Compliance Confirmation Date
P -635	B.A. Steinhagen	YES	October 2017
Z -924	Sam Rayburn	YES	October 2017
M -918	Sam Rayburn	YES	October 2017
M -903	Sam Rayburn	YES	October 2017

**PUBLIC UTILITY COMMISSION OF TEXAS PROJECT NO. 52667**  
**FILING OF ATTESTATION DEMONSTRATING COMPLIANCE WITH HB 4150**  
**AFFIDAVIT OF COOPERATIVE OFFICER FOR**  
**JASPER-NEWTON ELECTRIC COOPERATIVE**  
**FILED PURSUANT TO SECTION 6 HOUSE BILL 4150**


STATE OF TEXAS §

COUNTY OF JASPER §

BEFORE ME, the undersigned authority, on this day personally appeared, and who, after being duly sworn, stated on his or her oath he or she is entitled to make this Affidavit, and that the statements contained below are true and correct.

I, Aaron Crawford, swear or affirm that as an Electric Cooperative operating in the State of Texas and the Electric Reliability Council of Texas (ERCOT) and Midcontinent Independent System Operator (MISO) region, and control system, confirm the following:


- Jasper-Newton is a distribution electric cooperative headquartered in Kirbyville Texas.
- Jasper-Newton is responsible for inspecting and maintaining (1) distribution line that line that crosses a lake (B.A Steinhagen in Jasper County) listed in PURA § 38.004(b) ("Distribution Line").
- Jasper-Newton is responsible for inspecting and maintaining (3) distribution line that line that crosses a lake (Sam Rayburn in Angelina County) listed in PURA § 38.004(b) ("Distribution Line").
- In November of 2017, Jasper-Newton verified the Distribution Lines are in compliance with the vertical clearance requirements established in Rule 232 of the NESC Standard ANSI (c)(2).

 (signature of the Officer of the Cooperative)


Assistant General Manager -Operations

Jasper-Newton Electric Cooperative

Sworn and subscribed before me on this 7<sup>th</sup> day of January, 2022.



Notary Public in and for the State of Texas



Notary Seal