



Filing Receipt

Received - 2022-01-11 04:59:55 PM
Control Number - 52667
ItemNumber - 26

Affected Entity: South Plains Electric Cooperative, Inc.

PROJECT NO. 52667

- A declaration that each distribution line above 1 kilovolt or transmission line above 60 kilovolts owned by the utility that crosses a lake listed in PURA § 38.004(b) meets the applicable vertical clearance requirements established in Rule 232 of the NESC Standard ANSI (c)(2).
- The date on which the company verified each line's compliance with the applicable NESC Standard.

South Plains Electric Cooperative, Inc. owns a distribution line above 1 kilovolt that crosses Baylor Creek, a lake listed in PURA § 38.004(b). The line meets the applicable vertical clearance requirements established in Rule 232 of the NESC Standard ANSI (c)(2).

The line was verified in compliance with the applicable NESC Standard on April 8, 2021. The line was verified in compliance again on December 31, 2021.

Affected Entity: South Plains Electric Cooperative, Inc.

PROJECT NO. 52667

AFFIDAVIT

I swear or affirm that I have personal knowledge of the facts stated in the report or am relying on people with personal knowledge, that I am competent to testify to them, and that I have the authority to submit this report on behalf of the affected entity. I further swear or affirm that all statements made in this report are true, correct, and complete.

Ben Greene

Signature

Ben Greene

Printed Name

Manager of Risk Management

Job Title


South Plains Electric Cooperative

Name of Affected Entity

Sworn and subscribed before me this 11th day of January, 2022.

Month

Year



Jamey L. Phillips

Notary Public in and For the State of Texas

My commission expires on 04-27-2025