



Filing Receipt

Received - 2022-11-16 02:50:44 PM

Control Number - 53719

ItemNumber - 354

SOAH DOCKET NO. 473-22-04394
PUC DOCKET NO. 53719

APPLICATION OF ENTERGY	§	BEFORE THE STATE OFFICE
TEXAS, INC. FOR AUTHORITY TO	§	OF
CHANGE RATES	§	ADMINISTRATIVE HEARINGS

REBUTTAL TESTIMONY

OF

MELANIE L. TAYLOR

ON BEHALF OF

ENTERGY TEXAS, INC.

NOVEMBER 2022

ENTERGY TEXAS, INC.
REBUTTAL TESTIMONY OF MELANIE L. TAYLOR
SOAH DOCKET NO. 473-22-04394
PUC DOCKET NO. 53719

TABLE OF CONTENTS

	<u>Page</u>
I. Introduction and Purpose	1
II. Response to Intervenors	1
III. Conclusion	8

1

I. INTRODUCTION AND PURPOSE

2 Q1. PLEASE STATE YOUR NAME, BUSINESS ADDRESS, AND POSITION.

3 A. My name is Melanie L. Taylor. My business address is 2107 Research Forest
4 Drive, The Woodlands, Texas 77380. I am currently Vice President of Reliability
5 for Entergy Texas, Inc. (“ETI”).

6

7 Q2. ARE YOU THE SAME MELANIE L. TAYLOR WHO FILED DIRECT
8 TESTIMONY IN THIS CASE ON BEHALF OF ETI?

9 A. Yes.

10

11 Q3. WHAT IS THE PURPOSE OF YOUR REBUTTAL TESTIMONY?

12 A. I respond to issues raised by Evan D. Evans on behalf of the Office of Public Utility
13 Counsel (“OPUC”) and Mark E. Garrett on behalf of certain Cities.¹

14

15 **II. RESPONSE TO INTERVENORS**

16 Q4. CRITICIZING THE COMPANY’S AMS DEPLOYMENT, OPUC WITNESS
17 EVAN D. EVANS CLAIMS THAT ETI’S OUTAGE FREQUENCY AND
18 DURATION HAVE NOT SIGNIFICANTLY IMPROVED SINCE AMS
19 DEPLOYMENT BEGAN.² HOW DO YOU RESPOND?

¹ Cities include the Cities of Anahuac, Beaumont, Bridge City, Cleveland, Dayton, Groves, Houston, Huntsville, Liberty, Montgomery, Navasota, Nederland, Oak Ridge North, Orange, Pine Forest, Pinehurst, Port Arthur, Port Neches, Roman Forest, Rose City, Shenandoah, Silsbee, Sour Lake, Splendor, Vidor, West Orange, and Willis.

² Direct Testimony of Evan Evans at 17.

1 A. Mr. Evans's criticisms are premature given the timing of AMS deployment.
2 Mr. Evans's analysis begins with the 2018 Service Quality Report, which covers
3 calendar year 2018 reliability statistics, and ends with the 2021 Service Quality
4 report, which covers calendar year 2021 reliability statistics. ETI's advanced meter
5 mass deployment did not begin until March 2019, and it did not conclude until
6 March 2021. As ETI witness William Phillips, Jr. explained, optimization of the
7 communication network is continuing through 2022.³ Accordingly, it is too early
8 to evaluate whether the AMS deployment is having an impact on outage rates or
9 duration. In the interim, however, the AMS meters are providing faster and more
10 precise outage detection through their last-gasp feature, which alerts the
11 distribution operations center that the meter lost power, and crews are better able
12 to pinpoint outage locations, which can ultimately improve outage duration as well
13 as improved safety for the crews due to less scouting required to identify outage
14 locations.

15 Moreover, the deployment of AMS meters themselves would not be
16 expected to have a significant impact on outage statistics. In essence, meter failures
17 do not cause outages (a failed meter simply will not record usage). Rather, it is the
18 advanced metering system, including the communications network, that provides
19 the foundation for improved reliability. For example, as I explained in my direct
20 testimony, ETI has recently invested approximately \$23.5 million in distribution
21 automation ("DA") technology, which utilizes the communication network made

³ Direct Testimony of William Phillips, Jr. at 8.

1 up of the AMS meters and associated repeaters, access points, and backhaul
2 system.⁴ DA includes “smart” distribution devices, including reclosers, regulators,
3 and capacitors, that are equipped with electronic controls that enable the devices to
4 communicate with utility software, e.g., the new distribution management system
5 and updated outage management system, and perform real-time sensing and
6 reconfiguration of the distribution system. Together those systems are being
7 utilized to enable “self-healing networks,” which monitor the distribution system
8 for any outage conditions and automatically reconfigure the path of power to isolate
9 the outage to a minimum number of customers and restore power to all unaffected
10 customers in the surrounding area. As I described in my direct testimony, since
11 2019, ETI installed 45 new reclosers as part of automated load transfer systems,
12 resulting in 8,125 avoided customer interruptions over the 2020 through 2021 time
13 period.⁵ ETI plans to continue investing in those systems.

14 I also described in my direct testimony the Enterprise Asset Management
15 (“EAM”) system that was implemented in 2020.⁶ In addition to improving
16 workforce management, the EAM includes distribution assets tracking and
17 monitoring, that, together with the AMS backbone and DA infrastructure,
18 facilitates a more data-driven, proactive approach to making reliability
19 improvements by, for example, identifying devices for replacement before they fail.
20 Accordingly, through the maturation of the AMS foundational technology and the

⁴ Direct Testimony of Melanie Taylor (“Taylor Direct”) at 58.

⁵ Taylor Direct at 32.

⁶ Taylor Direct at 13, 67-68.

1 investment in new advanced technologies like DA and EAM, ETI's long term
2 reliability strategy is being enhanced to include more proactive and long-lasting
3 improvements that are expected to improve reliability and enhance the resiliency
4 of the distribution grid to extreme weather. Those results will take more time to
5 materialize, and it is premature to evaluate the effect of the not-yet-completed AMS
6 deployment on reliability.

7

8 Q5. DISCUSSING THE EFFECTIVENESS AND EFFICIENCY OF ETI'S
9 MANAGEMENT, CITIES WITNESS MARK E. GARRETT CRITICIZES THE
10 COMPANY'S OUTAGE FREQUENCY AND DURATION STATISTICS IN
11 2021 RELATIVE TO OTHER COMPANIES THAT MR. GARRETT SELECTED
12 FOR A BENCHMARKING ANALYSIS.⁷ HOW DO YOU RESPOND?

13 A. It is difficult to have a true comparison of reliability statistics among utilities due
14 to a number of variables. First, although SAIFI and SAIDI are industry standards,
15 there are differences in how they are measured. For example, some utilities use
16 Institute of Electrical and Electronics Engineers ("IEEE") Standards 1366-2012
17 ("IEEE 1366") to calculate and define SAIFI and SAIDI measurements, and IEEE
18 1366 contains a definition of Major Events that may be excluded from the
19 calculations. The threshold for Catastrophic Events discussed in IEEE 1366 also
20 varies by utility, and the exclusion or inclusion of these events have significant
21 effects on the IEEE's 2.5 Beta Method calculation and thresholds. The calculation

⁷ Direct Testimony of Mark Garrett at 82-83.

1 of Major Events as filed with the Public Utility Commission of Texas' ("PUCT")
2 rule 16 Tex. Admin. Code § 25.52 for Service Quality Reports defines excluded
3 days differently than the 2.5 Beta Method referenced in IEEE 1366. Moreover,
4 utilities have discretion on including or excluding certain types of outages in
5 reporting SAIFI and SAIDI, which can affect reported scores. An example of this
6 would be whether emergency or scheduled switching is included in the scores.
7 There are also variations in how weather cause categories are defined, which affects
8 whether certain weather outages are included or excluded in the scores.

9 Second, it is difficult to identify an accurate peer that operates under the
10 exact same parameters as ETI. For example, customer density, number of line
11 miles, weather patterns, geography, data gathering practices, load growth, and
12 customer count all can have a positive or negative reliability effect that varies
13 yearly. In fact, load growth and customer count have a direct correlation to the age
14 and type of infrastructure required to serve a utility's load reliably. Areas that have
15 experienced recent load and customer growth tend to have newer facilities and
16 modern construction standards that, from a reliability perspective, perform better
17 than areas that have seen a decline in customer count and have not had the benefit
18 of newer infrastructure.

19 Further, one of the primary contributors to higher SAIFI and SAIDI
20 performance that should be considered distinctly as to ETI is the geographical
21 characteristics that are common to ETI's service territory. Many of ETI's
22 customers are located in rural areas and tend to be spread out geographically.

1 Reliability scores tend to increase (lower scores are better) as population density
2 decreases due to longer feeders and the time required to locate faults and fewer
3 feeder interconnections, therefore impacting SAIDI. In addition, the cost of
4 improving and maintaining reliability is distributed across fewer customers as
5 opposed to utilities with increased population densities. SAIDI scores are also
6 negatively affected by the terrain in which ETI's customers reside. For example,
7 dense vegetation and tall trees are two of the common obstacles that tend to hinder
8 ETI's ability to quickly navigate the terrain when there is an outage in these
9 heavily-vegetated areas. As I explained in my direct testimony, ETI has also
10 implemented new safety measures that require more extensive deenergized work,
11 which also negatively affects SAIDI.

12 Weather is another common factor that contributes to higher SAIFI and
13 SAIDI scores. All utilities are vulnerable to weather-related events, although the
14 frequency and type of events may differ regionally. Texas, however, is subject to
15 both warm and cold weather events as opposed to one or the other. Examples
16 include severe thunderstorms, hurricanes, straight line winds, tornadoes, ice
17 storms, occasional snow, and extended periods of extreme heat and drought (and
18 occasionally extreme cold). ETI's territory is also located in an area with high
19 lightning activity, with some counties experiencing more than 150 events/km²/year
20 per Vaisala Global Lightning Density Maps (greater than 96 events is considered

1 high).⁸ The frequency and variety of these weather-related events negatively
2 affects ETI's SAIFI and SAIDI when compared to other utilities outside the region.

3 Mr. Garret did not provide any such comparative analysis between ETI and
4 the proxy group companies in his benchmarking data. Accordingly, drawing
5 conclusions about ETI's reliability performance from broad benchmarking
6 comparisons is of limited value. Instead, an evaluation of SAIFI and SAIDI from
7 year to year for ETI is a better way to evaluate ETI's reliability performance, which
8 is reported annually to the Commission in ETI's Service Quality Reports.

9
10 Q6. WHAT IS THE TREND IN ETI'S RELIABILITY PERFORMANCE?

11 A. I presented and explained ETI's long-term reliability performance (2010 through
12 2021) in my direct testimony at pages 14-21. In summary, ETI's SAIFI scores are
13 better than the PUCT-established target of 1.88 by an average margin of 45 basis
14 points (0.45). SAIDI missed the target by an average of 48 minutes, but I explained
15 how those SAIDI scores are largely the result of unusual weather events that does
16 not rise to the Major Event Day level (and thus excluded from most reliability
17 calculations) and uncontrollable outages, primarily trees falling from outside the
18 right-of-way,⁹ underground conductor "dig-ins" from third party contractors, and
19 public vehicles striking electric facilities. Next in my direct testimony, I described
20 the extensive efforts that the Company is undertaking to address reliability,

⁸ <https://interactive-lightning-map.vaisala.com/>.

⁹ See Figure 13 in Taylor Direct.

1 including building on the AMS foundation and associated grid modernization
2 activities.¹⁰ In short, not only has ETI exceeded the PUCT-established SAIFI target
3 for over a decade, it is fully committed to continued investment in reliability
4 enhancement using the AMS foundation and the latest technology. For example,
5 in 2020, ETI stood up a dedicated reliability group comprised of engineers whose
6 sole focus is to continuously, proactively and reactively, evaluate infrastructure
7 performance and execute ETI's proven reliability programs.

8

9

III. CONCLUSION

10 Q7. DOES THIS CONCLUDE YOUR REBUTTAL TESTIMONY?

11 A. Yes.

¹⁰ Taylor Direct at 21-39.

AFFIDAVIT OF MELANIE L. TAYLOR

THE STATE OF TEXAS)
)
COUNTY OF Montgomery)

This day, Melanie Taylor the affiant, appeared in person before me, a notary public, who knows the affiant to be the person whose signature appears below. The affiant stated under oath:

My name is Melanie L. Taylor. I am of legal age and a resident of the State of Texas. The foregoing testimony and exhibits offered by me are true and correct, and the opinions stated therein are, to the best of my knowledge and belief, accurate, true and correct.

Melanie L. Taylor
Melanie L. Taylor

SUBSCRIBED AND SWORN TO BEFORE ME, notary public, on this the 15 day of November 2022.

Donna W. Robert
Notary Public, State of Texas

My Commission expires:

