



Filing Receipt

Received - 2023-02-14 01:55:00 PM
Control Number - 54467
ItemNumber - 11

Service Quality Report
To The
Public Utility Commission of Texas
In Accordance With
Substantive Rule §25.81
2022 Reporting Year

AEP Texas

Project 54467

AEP Texas intends to file an addendum to its CY 2022 SQR as a supplemental filing.

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

System SAIFI	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced													
2022	1.257	0.111	0.098	0.093	0.165	0.119	0.094	0.082	0.135	0.078	0.092	0.086	0.103
Scheduled													
2022	0.522	0.013	0.007	0.008	0.011	0.012	0.009	0.007	0.413	0.013	0.014	0.009	0.008
Outside Causes													
2022	0.111	0.013	0.009	0.005	0.012	0.015	0.007	0.019	0.003	0.007	0.000	0.020	0.001
Major Events													
2022	0.069					0.066							0.003

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

System SAIDI		Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced														
2022		140.15	11.35	9.32	10.01	20.56	16.98	10.53	9.06	16.77	7.21	7.39	8.83	12.12
Scheduled														
2022		22.80	1.14	1.03	1.07	1.29	1.16	1.11	0.78	9.62	2.13	1.20	1.21	1.06
Outside Causes														
2022		10.68	0.80	1.49	0.44	0.98	1.96	1.78	1.11	0.23	0.35	0.08	1.39	0.08
Major Events														
2022		19.25					17.94							1.32

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

Total Number of Feeders

With 10 or more Customers

1304

Add or Delete Rows as Necessary

AEP Texas

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
1	62	RIO RICO	94SB8330	70	13.229
2	110	MINES ROAD	94LA7235	43	11.349
3	609	BERCLAIR	94CN990	26	9.115
4	508	RIO RICO	94SB5050	290	8.466
5	138	LULING - LCRA	94CN10	452	6.108
6	588	RAYMONDVILLE #2	94SB3170	766	6.052
7	270	RIO PECOS	97SA3835	103	5.990
8	83	GREGORY	94CS5900	120	5.983
9	774	MATHIS	94CS1410	472	5.881
10	346	PICACHO	94LA630	378	5.831
11	82	VERHALEN	97SA4460	70	5.729
12	86	GEORGE WEST	94CN1320	687	5.684
13	738	SONORA 138 SUB	97SA4810	876	5.535
14	479	ELSA	94SB700	1523	5.516
15	635	NORTH MERCEDES	94SB4860	1504	5.324
16	232	ODEM	94CS375	631	5.317
17	109	BAY CITY	94CN6670	1615	5.256
18	369	RANDADO	94LA8360	163	5.227
19	531	INGLESIDE CITY	94CS8050	1277	5.193
20	37	PLACEDO	94CN7980	425	5.174
21	454	LOS FRESNOS	94SB4315	1264	5.103
22	897	NORTH ALAMO	94SB4370	1628	5.060
23	629	POLK AVENUE	94SB4900	1915	5.058
24	772	NAVAL BASE	94CS7950	806	5.038
25	152	NORTH PADRE ISLAND	94CS720	1402	5.019
26	115	WEST HARLINGEN	94SB3720	1309	4.969
27	103	CHERRY CREEK TAP	97SA485	53	4.887
28	93	MOORE FIELD	94SB3120	151	4.675
29	767	ASHERTON	94LA4175	82	4.634
30	1076	HOLLY	94CS1220	3401	4.612
31	530	TAFT	94CS1260	200	4.555
32	991	SAN BENITO	94SB4135	1388	4.544
33	908	CLYDE	97AB1760	464	4.543
34	636	PORT ISABEL S.S.	94SB9295	2515	4.543
35	495	SOUTH PADRE ISLAND	94SB4695	1378	4.525
36	163	CAMPWOOD	94LA2610	1009	4.474
37	24	CHARLOTTE	94LA2780	33	4.455
38	129	ZAPATA	94LA8300	1613	4.449
39	65	GREGORY	94CS8560	255	4.439
40	187	FOSTER FIELD	94CN2550	66	4.409
41	989	PUEBLO	94LA95	1415	4.301
42	141	PIRATE	94CS3380	421	4.183

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
43	149	ELSA	94SB3520	1011	4.161
44	604	TUSCOLA	97AB3305	1234	4.160
45	54	PREMONT	94LA2730	199	4.146
46	741	WEIL TRACT (138/12KV)	94CS2520	83	4.133
47	536	PHARR	94SB1620	1243	4.132
48	18	OZONA	97SA4185	734	4.052
49	34	WEIL TRACT (138/12KV)	94CS5405	178	4.006
50	445	HALL ACRES ROAD	94SB5585	1623	3.996
51	649	NORTH VICTORIA	94CN7770	829	3.982
52	354	INGLESIDE CITY	94CS8060	2680	3.976
53	29	TATTON	94CN8490	293	3.959
54	809	ALICE	94LA1770	1657	3.898
55	670	WESMER	94SB4050	1954	3.880
56	920	SAND CRAB	94CN9235	386	3.852
57	1041	FT CHADBOURNE	97SA6515	92	3.826
58	84	SAN DIEGO	94LA2930	565	3.765
59	33	PRAIRIE PUMP	94CN1940	91	3.758
60	417	BAY CITY	94CN2700	1078	3.756
61	166	VALENTINE	97SA5590	208	3.726
62	612	HIGHWAY 9	94CS6760	1033	3.723
63	106	HIGHWAY 9	94CS6770	925	3.679
64	176	THREE RIVERS	94CN8430	194	3.634
65	540	PECOS VALLEY	97SA4080	237	3.633
66	301	FREISS RANCH	97SA4870	100	3.630
67	1179	PLASTERCO (MWEC)	97AB2720	117	3.590
68	233	MATHIS	94CS2870	870	3.582
69	618	MESQUITE	94SB3360	1023	3.580
70	439	RODD FIELD	94CS225	2913	3.560
71	533	CABANISS	94CS240	1408	3.546
72	541	JOURDANTON	94LA7880	593	3.528
73	191	CABANISS	94CS75	2243	3.527
74	523	SOUTHSIDE	94CS5335	1533	3.496
75	688	LIVE OAK	94CS1080	2555	3.470
76	90	NORTH MERCEDES	94SB3770	1844	3.450
77	9	O_CONNER	94CN390	200	3.430
78	1139	EAGLE PASS CITY	94LA2745	934	3.424
79		PECOS VALLEY	97SA9615	56	3.393
80	66	BLESSING	94CN8780	58	3.379
81	75	MORRIS STREET	94CS8820	1249	3.367
82		RAYMONDVILLE #2	94SB3250	28	3.357
83	57	SUNCHASE	94SB1150	1422	3.340
84	123	PARKER	94CN9010	21	3.333
85	153	PAWNEE (STEC OWNED)	94CN22202	197	3.330
86	400	HIGHWAY 9	94CS6720	1275	3.307
87	570	INGLESIDE CITY	94CS6040	429	3.277
88	594	ALPINE 12KV	97SA3875	105	3.276
89	61	ELSA	94SB3500	1332	3.264

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
90	202	EL CAMPO	94CN2800	841	3.262
91	314	CHARLOTTE	94LA2790	201	3.259
92	157	DILLEY	94LA3795	103	3.223
93	30	WEIL TRACT (138/12KV)	94CS1990	1369	3.221
94	488	MATHIS	94CS340	1418	3.207
95	627	PALMVIEW	94SB6790	2557	3.194
96	1005	HAWLEY	97AB4455	672	3.190
97	76	CLARKWOOD	94CS5525	627	3.190
98	117	BANQUETTE	94CS9000	462	3.171
99	63	ALAZAN	94CS620	179	3.162
100	135	HASKELL 12KV	97AB3495	826	3.155
101	55	MALONE	94CN7550	226	3.150
102	661	HARLINGEN SWITCH	94SB320	1686	3.133
103	836	GANADO	94CN5815	601	3.125
104	1014	JOURDANTON	94LA250	770	3.123
105	740	MORRIS STREET	94CS7625	513	3.111
106	180	PALMHURST	94SB3890	1864	3.106
107	1117	WEST MCALLEN	94SB4965	967	3.101
108	456	RIO BRAVO	94LA1130	1071	3.085
109	12	LOS FRESNOS	94SB5335	2708	3.078
110	951	LEARY LANE	94CN1430	1915	3.076
111	321	HIGHWAY 9	94CS7210	349	3.069
112	200	OZONA	97SA3810	1172	3.059
113	503	NORTH WESLACO	94SB4810	1522	3.034
114	1287	GOODLETT	97AB12205	48	3.021
115	113	PLACEDO	94CN7970	490	3.020
116	122	OZONA	97SA3555	157	3.006
117	814	LOS FRESNOS	94SB7270	2376	3.005
118	268	PAULANN	97SA6280	331	2.991
119	2	MCCAMEY	97SA2415	76	2.987
120	155	AB RAINEY CREEK	97AB4225	122	2.967
121	474	UNITEC	94LA3085	114	2.947
122	924	BEN FICKLIN	97SA14065	793	2.939
123	330	SEAWALL	94CS9325	1584	2.927
124	917	BISHOP	94CS2690	641	2.922
125	864	TAFT	94CS5230	832	2.912
126	425	NORTH MERCEDES	94SB3840	710	2.896
127	859	PHARR	94SB1625	1210	2.891
128	486	TYNAN	94CS1855	135	2.889
129	600	GANADO	94CN5795	489	2.869
130	1231	BALLINGER	97SA4375	1130	2.866
131	348	CROSS PLAINS	97AB2915	779	2.849
132	175	SAND CRAB	94CN8120	264	2.848
133	243	NORTH ALAMO	94SB3610	1999	2.845
134	381	UVALDE	94LA540	1969	2.843
135	306	WEST HARLINGEN	94SB3700	1876	2.838
136	286	HARLINGEN SWITCH	94SB4110	912	2.823

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
137	121	MAYO	94CS625	208	2.817
138	14	CRESTONIO	94LA270	641	2.813
139	183	HOLLY	94CS1480	1704	2.796
140	602	TATTON	94CS950	576	2.774
141	737	KNIPPA	94LA6535	22	2.773
142	177	DEL RIO CITY	94LA1930	1564	2.767
143	555	UVALDE	94LA6620	2158	2.747
144	150	GARWOOD CITY	94CN2570	145	2.745
145	440	FALFURRIAS	94LA5210	1177	2.743
146	95	PREMONT	94LA6570	809	2.739
147	35	CABANISS	94CS615	266	2.737
148	224	BEEVILLE	94CN8510	828	2.736
149	1087	MILO	94LA8365	2123	2.734
150	127	BAY CITY	94CN7480	380	2.732
151	401	RACHAL	94LA8145	376	2.726
152	342	WESLACO UNIT	94SB5970	2047	2.722
153	1093	GONZALES	97SA15390	1098	2.720
154	206	DEL RIO CITY	94LA430	2069	2.712
155	408	HEARN ROAD	94CS8990	1360	2.698
156	213	BEEVILLE	94CN8090	1386	2.698
157	603	PECAN BAYOU	97AB6815	2092	2.679
158	39	ZAPATA	94LA2710	1346	2.679
159	580	EAGLE LAKE	94CN310	740	2.673
160	466	PORTLAND	94CS9290	1790	2.665
161	621	FREER	94LA6320	162	2.660
162	161	MCCAMEY	97SA2830	97	2.639
163	211	RIO RICO	94SB8290	309	2.638
164	413	CHARLOTTE	94LA8120	240	2.625
165	43	INDIAN MESA	97SA2695	92	2.609
166	894	VICTORIA POWER PLANT	94CN1390	1092	2.604
167	100	MCKENZIE ROAD	94CS140	296	2.591
168	199	CALLICOATTE	94CS8785	1193	2.567
169	819	EL GATO	94SB910	2605	2.566
170	560	PUEBLO	94LA275	2910	2.554
171	414	DIMMIT	94LA4120	1277	2.546
172	882	PLEASANTON	94LA9505	1775	2.539
173	281	ARCADIA	94CS1440	1662	2.504
174	708	NORTH PADRE ISLAND	94CS7900	2346	2.496
175	709	SOUTHSIDE	94CS8025	1147	2.495
176	328	SKIDMORE	94CS380	159	2.491
177	329	SOUTH SANTA ROSA	94SB1235	648	2.489
178	520	HAINE DRIVE	94SB9690	633	2.483
179	249	CLARKWOOD	94CS7230	624	2.481
180	174	EAGLE LAKE	94CN9455	609	2.476
181	953	FASHING	94CN360	34	2.471
182	85	MAYBERRY	94SB3160	558	2.470
183	384	NORTH PADRE ISLAND	94CS5170	870	2.457

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
184	974	POLK AVENUE	94SB4190	1726	2.448
185	164	RIO BRAVO	94LA5	713	2.447
186	81	FOSTER FIELD	94CN8880	294	2.442
187	284	HIDALGO	94SB4845	1411	2.428
188	236	MATTHEWS	94CN1740	164	2.427
189	19	GREGORY	94CS5920	765	2.407
190	1047	BEEVILLE	94CN2380	219	2.402
191	993	NORTH VICTORIA	94CN7860	1510	2.397
192	753	FULTON	94CS440	2074	2.395
193	665	FULTON	94CS2020	3551	2.389
194	1277	STAFFORD HILL	94CN9955	85	2.388
195	923	MINES ROAD	94LA1600	1218	2.385
196	366	LOS FRESNOS	94SB2160	1863	2.382
197	958	PIRATE	94CS3490	378	2.376
198	573	LIVE OAK	94CS1070	2568	2.375
199	1004	AB SHELTON ST	97AB3660	638	2.353
200	370	YORKTOWN	94CN8380	780	2.349
201	97	RAYMONDVILLE #1	94SB630	792	2.348
202	22	FREER	94LA1500	201	2.348
203	238	ALICE	94LA2530	1502	2.339
204	15	MCELROY	97SA5165	95	2.326
205	491	EAGLE PASS CITY	94LA2770	2023	2.325
206	376	BISHOP	94CS7180	929	2.311
207	345	PORTLAND	94CS9370	2100	2.307
208	379	LAGUNA	94CS9590	2325	2.306
209		BULL MOOSE	94CS4185	20	2.300
210	730	GOODWIN	94SB4380	1668	2.299
211	107	WADSWORTH	94CN8630	669	2.299
212	1094	ABILENE PLANT	97AB1575	608	2.293
213	789	BEN FICKLIN	97SA6175	599	2.289
214	790	HOLLY	94CS7740	2209	2.283
215	415	AIRLINE	94CS7280	645	2.276
216	785	WOOLRIDGE	94CS1110	1650	2.272
217	543	AB ELM CREEK	97AB4745	902	2.272
218	367	KEMPER EXXON HUMBLE	97SA72103	26	2.269
219	218	ODEM	94CS385	567	2.257
220	197	WESMER	94SB4480	1136	2.254
221	297	CASA BLANCA	94CS55	871	2.247
222	1053	MCCOLL ROAD	94SB4790	2088	2.243
223	255	TURKEY	97AB3825	388	2.242
224	1130	COMSTOCK	94LA230	183	2.240
225	398	DEVINE	94LA7090	1070	2.240
226	909	SOUTH EAST EDINBURG	94SB4550	727	2.239
227	704	LEARY LANE	94CN1540	793	2.236
228	712	UVALDE	94LA5060	1288	2.227
229	761	ARCADIA	94CS6930	1480	2.216
230	632	WEST HARLINGEN	94SB4870	1072	2.203

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
231	344	YORKTOWN	94CN3130	492	2.203
232	96	PALACIOS	94CN8550	84	2.190
233	552	KEPLER	94CS2665	37	2.189
234	653	LAREDO PLANT	94LA8695	1551	2.188
235	89	WEST OSO	94CS9085	945	2.182
236	41	ALBANY	97AB2029	241	2.174
237	1090	TYNAN	94CS4010	46	2.174
238	623	GARWOOD CITY	94CN2560	201	2.169
239	733	BLACK CAT	94CN3175	495	2.166
240	162	ELDORADO	97SA1845	538	2.164
241	744	PHARR	94SB1640	1456	2.156
242	919	NORTH ALAMO	94SB3580	1023	2.150
243	182	VILLA CAVAZOS	94SB1980	1834	2.144
244	73	HOLLY	94CS7620	2703	2.141
245	1020	SILVER	97SA4295	15	2.133
246	1063	AB MCMURRY	97AB4350	707	2.130
247	1264	SWENSON	97AB136	31	2.129
248	88	AIRLINE	94CS5870	1008	2.129
249	862	POLK AVENUE	94SB4170	1466	2.124
250	613	VICTORIA POWER PLANT	94CN8170	842	2.122
251	272	CAUSEWAY	94SB9880	1229	2.112
252		HAISLEY	94CSTX_2_B	9	2.111
253	323	WEST MCALLEN	94SB6385	243	2.099
254	906	AB WALNUT ST	97AB3785	574	2.098
255	1017	POLK AVENUE	94SB4610	155	2.097
256	537	WESMER	94SB9705	938	2.088
257	697	MELVIN	97SA940	46	2.087
258	1140	CLARKWOOD	94CS7220	931	2.083
259	1146	AB MCMURRY	97AB4355	989	2.082
260	362	LA PRYOR	94LA570	171	2.082
261	1033	NORTH MCALLEN	94SB3830	1415	2.076
262	204	BEEVILLE	94CN1760	1838	2.065
263	289	CHILLICOTHE	97AB4525	119	2.059
264	70	COFFEE PORT	94SB1095	1080	2.058
265	105	BRUNI	94LA1120	266	2.056
266	49	STAMFORD PUMP	97AB3930	37	2.054
267	1132	CEDAR GAP (TEC)	97AB5445	506	2.053
268	209	PORT ISABEL S.S.	94SB3820	175	2.051
269	283	PALMVIEW	94SB3930	1163	2.050
270	943	RIO GRANDE CITY	94SB3230	2702	2.047
271	58	PAULANN	97SA6285	69	2.043
272	71	PAULANN	97SA6310	1086	2.041
273	643	VERNON CITY PLANT	97AB5770	94	2.032
274	32	SHROPSHIRE	94CN1240	73	2.027
275	513	PREMONT	94LA6610	834	2.019
276	735	SA MATHIS FIELD	97SA4790	194	2.010
277	40	SARAGOSA	97SA1590	49	2.000

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
278	143	VERHALEN	97SA4465	36	2.000
279	119	PORT ISABEL S.S.	94SB3760	782	1.986
280	186	RISING STAR	97AB5080	622	1.984
281	313	ASPHALT MINES	94LA500	43	1.977
282	403	SANTA ANNA	97SA3415	343	1.974
283	569	EOLA	97SA4950	211	1.972
284	778	ROBY	97AB3795	76	1.961
285	360	BEN FICKLIN	97SA6180	563	1.957
286	293	EAST HARRISON	94SB3950	788	1.952
287	1253	TRADE ZONE	94SB1935	41	1.951
288	595	CITRUS CITY	94SB5070	1022	1.938
289	509	OLMITO	94SB715	673	1.938
290	922	WESLACO UNIT	94SB7455	1235	1.925
291	471	MALONE	94CN7560	58	1.914
292	1028	RODD FIELD	94CS205	2184	1.900
293	515	SOUTHSIDE	94CS7995	1551	1.881
294	46	GREENLAKE	94CN2740	381	1.879
295	261	PORT ARANSAS	94CS990	2661	1.876
296	442	CLARKWOOD	94CS9570	1234	1.874
297	934	SOUTH PADRE ISLAND	94SB5850	1374	1.870
298	130	MCCAMEY	97SA2420	82	1.866
299	1101	CASA BLANCA	94CS5440	109	1.862
300	395	ELDORADO	97SA2880	354	1.853
301	137	VERHALEN	97SA14765	27	1.852
302	390	LA PRYOR	94LA580	334	1.847
303	136	WADSWORTH	94CN7660	1476	1.838
304	969	HIGHWAY 9	94CS6730	546	1.835
305	430	PALMHURST	94SB2530	2755	1.834
306	205	MAGNOLIA	94CN315	84	1.833
307	235	BIG OAK	94CN420	341	1.827
308	331	NORTH MCALLEN	94SB2980	1885	1.821
309	215	SOUTH SANTA ROSA	94SB1215	1717	1.818
310	450	ARCADIA	94CS8570	1448	1.791
311	701	SAN BENITO	94SB4945	1732	1.782
312		PROGRESO	94SB2545	90	1.778
313	254	SPUDDER FLAT	97SA4175	57	1.772
314	220	WESMER	94SB1850	485	1.765
315	189	PLEASANTON	94LA120	1233	1.756
316	769	SAND ROAD	97AB5195	254	1.748
317	128	SABINAL	94LA485	498	1.747
318	335	WESMER	94SB7760	1464	1.736
319	6	CONOCO-CHITTAM RANCH	94LA8580	26	1.731
320	165	BLESSING	94CN1030	285	1.723
321	996	BLACK CAT	94CN2960	2121	1.723
322	867	ROUNDTOP	97AB4490	54	1.722
323	528	ARANSAS PASS	94CS8280	619	1.704
324	829	MORRIS STREET	94CS2515	1017	1.699

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
325	455	CRYSTAL CITY	94LA8380	1340	1.683
326	565	CRESTONIO	94LA260	1780	1.682
327	214	PHARAOH	94CS1285	1776	1.682
328	436	HIDALGO	94SB3400	891	1.677
329	325	PECOS VALLEY	97SA4075	21	1.667
330	386	PEARSALL	94LA9905	435	1.667
331	140	NAVAL BASE	94CS9720	2657	1.657
332	340	PECAN BAYOU	97AB6810	467	1.655
333	742	MCCOLL ROAD	94SB4780	2021	1.651
334	104	CAUSEWAY	94SB4765	619	1.649
335	52	PALACIOS	94CN6830	838	1.635
336	998	SAN YGNACIO	94LA16060	539	1.635
337	766	EL GATO	94SB780	2161	1.628
338	850	BROOKHOLLOW	94CN7580	500	1.628
339	336	SOUTH SANTA ROSA	94SB1225	867	1.624
340	823	PICACHO	94LA1230	1052	1.620
341	728	KNIPPA	94LA6365	338	1.618
342	1	SANTA RITA	97SA1100	110	1.618
343	521	GOODWIN	94SB4390	413	1.613
344	257	BROWNSVILLE	94SB4290	492	1.612
345	633	SOUTH EAST EDINBURG	94SB6580	939	1.608
346	1203	SA SOUTHLAND HILLS	97SA5050	890	1.606
347	1060	HALL ACRES ROAD	94SB8870	2509	1.599
348	798	BEEVILLE	94CN300	1676	1.597
349	309	LEARY LANE	94CN7530	3171	1.595
350	854	STAMFORD	97AB2815	706	1.593
351	768	ZACATE CREEK	94LA2635	975	1.589
352	1221	WEST MCALLEN	94SB4815	568	1.588
353	492	MERKEL	97AB1895	709	1.585
354	409	SOUTHSIDE	94CS8055	848	1.574
355	683	KINGSVILLE	94CS1660	1981	1.573
356	221	FALFURRIAS	94LA2830	1529	1.573
357	156	OLMITO	94SB4275	818	1.568
358	1232	HEINES	94CS2185	1257	1.566
359	142	SOUTHSIDE	94CS7925	1160	1.554
360	871	HEIGHTS	94LA6820	1944	1.554
361	392	WOODSON OIL FIELD	97AB30	33	1.545
362	945	MAGRUDER	94CN7870	1262	1.545
363	771	DEVINE	94LA7100	1118	1.544
364	534	WEST OSO	94CS9090	1672	1.541
365	1009	DILLEY	94LA510	560	1.530
366	28	BRUNI	94LA5440	129	1.527
367	269	UVALDE	94LA550	746	1.525
368	302	VICTORIA POWER PLANT	94CN7600	164	1.524
369	616	NIXON	94CN3300	594	1.524
370	273	KEPLER	94CS1700	27	1.519
371	964	FT DAVIS	97SA4515	1013	1.512

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
372	247	TAFT	94CS1180	957	1.510
373	308	YORKTOWN	94CN8420	669	1.504
374	51	EAGLE PASS CITY	94LA450	886	1.498
375	262	BROWNSVILLE	94SB4280	325	1.495
376	1185	UNIVERSITY	94LA950	1737	1.492
377	231	ARCADIA	94CS1450	1638	1.491
378	985	FT CHADBOURNE	97SA6520	553	1.481
379	526	MAVERICK	94LA9680	843	1.480
380	396	FULTON	94CS3070	1589	1.480
381	1015	SA NORTH	97SA3115	586	1.478
382	350	LAGUNA	94CS9065	2373	1.476
383	167	CROSS PLAINS	97AB2920	552	1.475
384	333	SA LAKE DR	97SA6030	761	1.473
385	470	TUSCOLA	97AB3730	1215	1.472
386	606	WESLACO UNIT	94SB7630	2641	1.469
387	1069	HALL ACRES ROAD	94SB5465	1443	1.468
388	601	LOLITA	94CN6330	30	1.467
389	1285	PANTERA	94SB1765	881	1.464
390	655	VILLA CAVAZOS	94SB7615	1121	1.463
391	869	HARLINGEN SWITCH	94SB4230	1362	1.446
392	1175	ANNA STREET	94LA780	474	1.445
393	443	PALMHURST	94SB2820	1870	1.443
394	280	FLOMOT	97AB1852	75	1.440
395	695	CARRIZO SPRINGS	94LA750	599	1.439
396	506	CHOKE CANYON	94CN9255	367	1.439
397	111	PORT ARANSAS	94CS6940	1635	1.436
398	397	PARKER	94CN9260	126	1.429
399	590	HIGHWAY 9	94CS9830	133	1.429
400	192	ARANSAS PASS	94CS590	459	1.425
401	1207	BALLINGER	97SA4370	777	1.423
402	144	GARCENO	94SB2130	1821	1.422
403	657	KENEDY	94CN1970	567	1.420
404	967	WEST MCALLEN	94SB4505	1908	1.414
405	542	CARANCAHUA	94CN5870	472	1.411
406	675	BEEVILLE	94CN490	952	1.403
407	516	PUEBLO	94LA9870	1463	1.403
408	968	SA GRAPE CREEK	97SA5220	716	1.402
409	476	LYTLE	94LA2850	757	1.400
410	1166	EAST HARRISON	94SB3080	472	1.398
411	784	PIRATE	94CS3220	741	1.398
412	564	HARLINGEN SWITCH	94SB5350	965	1.390
413	168	SONORA 138 SUB	97SA4805	347	1.386
414	245	DEVINE	94LA8100	1647	1.386
415	801	MORRIS STREET	94CS5655	316	1.386
416	332	LULING - LCRA	94CN20	278	1.385
417	891	ABILENE PLANT	97AB1565	280	1.382
418	216	FULTON	94CS9050	1576	1.378

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
419	45	FREER	94LA5200	1013	1.376
420	337	PICACHO	94LA590	397	1.373
421	856	JUNCTION	97SA10805	816	1.366
422	936	ABILENE PLANT	97AB1570	959	1.357
423	586	WYLIE	97AB2665	1090	1.349
424	372	EDROY	94CS6980	195	1.344
425	469	STERLING CITY	97SA1445	381	1.341
426	131	PHARAOH	94CS5175	1284	1.339
427	525	WEST OSO	94CS9095	1659	1.339
428	1121	CHRISTOVAL	97SA6615	460	1.337
429	678	CLYDE	97AB3635	454	1.335
430	225	KINGSVILLE	94CS1130	2226	1.334
431	208	CONTINENTAL	94SB4880	69	1.333
432	808	THROCKMORTON	97AB2090	75	1.333
433	494	EL GATO	94SB720	2571	1.333
434	1082	SAND CRAB	94CN6800	1126	1.331
435	759	JOURDANTON	94LA5685	327	1.330
436	410	BAIRD	97AB5125	511	1.327
437	172	ELSA	94SB710	2369	1.324
438	1023	RIO BRAVO	94LA300	803	1.313
439	840	HIGHWAY 9	94CS7200	655	1.311
440	424	YOUNG	94SB5135	1288	1.309
441	729	POWELL FIELD	97SA2529	13	1.308
442	957	WASHINGTON STREET	94LA6525	2740	1.306
443	385	PLEASANTON	94LA9475	1367	1.306
444	802	BLACK CAT	94CN3000	1646	1.301
445	1165	ANSON REA (SEC)	97AB5215	259	1.301
446	584	GREGORY	94CS420	467	1.300
447	399	MOORE FIELD	94SB3960	2191	1.299
448	927	NORDHEIM	94CN3380	174	1.299
449	315	PHARAOH	94CS1365	684	1.298
450	217	RULE	97AB3396	440	1.295
451	290	THREE RIVERS	94CN5190	475	1.293
452	154	CAUSEWAY	94SB4795	390	1.292
453	841	SPUDDER FLAT	97SA4180	48	1.292
454	745	VALADEZ	94CS9890	1908	1.290
455	499	HEARN ROAD	94CS8980	1255	1.289
456	1003	RESACA	94SB8700	1125	1.284
457	713	DEL RIO CITY	94LA9850	1037	1.278
458	483	NAVAL BASE	94CS8540	1624	1.277
459	779	SHAFTER	97SA5110	47	1.277
460	754	CHRISTOVAL	97SA6620	655	1.276
461	78	WEST HARLINGEN	94SB3800	1423	1.276
462	634	WYLIE	97AB6340	779	1.275
463	929	HEARN ROAD	94CS9665	690	1.274
464	429	PALACIOS	94CN6840	1540	1.272
465	664	SAN BENITO	94SB3920	1651	1.270

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
466	815	AB MCMURRY	97AB3245	795	1.267
467	880	SHARYLAND	94SB6745	2320	1.265
468	696	BOBCAT HILLS	97SA6655	73	1.260
469		LA PRYOR	94LA1845	223	1.260
470	685	AB ONYX REA	97AB3260	148	1.257
471	355	CASA BLANCA	94CS1300	291	1.254
472	1114	WESLACO UNIT	94SB2195	1102	1.251
473	1058	AB ELM CREEK	97AB4775	886	1.248
474	835	THOMASTON	94CN9580	49	1.245
475	501	SOUTHSIDE	94CS7905	1828	1.243
476	452	LA PRYOR	94LA2440	194	1.242
477	226	RISING STAR	97AB5075	688	1.240
478	1012	AB VOGEL ST	97AB4560	1477	1.237
479	550	CHASE FIELD	94CN460	17	1.235
480	1122	CLYDE	97AB3630	438	1.235
481	356	CLOSNER	94SB4100	2086	1.233
482	538	NORTH VICTORIA	94CN6390	1510	1.232
483	559	MOCKINGBIRD	94CN370	49	1.224
484	1212	AB SHELTON ST	97AB4640	663	1.223
485	1092	AB OVER STREET 12KV	97AB1645	796	1.222
486	374	GOLIAD	94CN6540	1244	1.222
487	291	INDIAN MESA	97SA2690	146	1.219
488	775	SAN BENITO	94SB4030	1707	1.218
489	592	LANTANA	94CS7150	271	1.218
490	703	BEEVILLE	94CN2200	722	1.217
491	112	SINTON	94CS6860	1007	1.215
492	1048	SA GRAPE CREEK	97SA4700	749	1.215
493		PROGRESO	94SB2515	210	1.214
494	326	INGLESIDE CITY	94CS2495	273	1.212
495	575	READING	94LA1445	533	1.212
496	264	FALFURRIAS	94LA1080	463	1.212
497	830	HAINE DRIVE	94SB3490	1193	1.211
498	94	EAGLE PASS CITY	94LA2510	709	1.209
499	977	NORTH EDINBURG	94SB560	2199	1.209
500	672	RULE	97AB3378	106	1.208
501	889	PHARAOH	94CS5185	1244	1.207
502	1138	GONZALES	97SA14685	1328	1.207
503	114	SHROPSHIRE	94CN3575	34	1.206
504	240	LIVE OAK	94CS1090	299	1.204
505	237	UVALDE	94LA480	572	1.199
506	640	RIO GRANDE CITY	94SB3740	2390	1.196
507	102	SOUTHSIDE	94CS8045	970	1.193
508	992	AB RAINEY CREEK	97AB4550	988	1.192
509	201	BROOKHOLLOW	94CN8950	922	1.190
510	230	DEL RIO CITY	94LA420	2051	1.190
511	863	ROBSTOWN	94CS1650	354	1.189
512	970	SOUTH EAST EDINBURG	94SB5045	1783	1.189

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
513	1244	NORTH MCCAMEY	97SA6555	795	1.184
514	1096	THROCKMORTON	97AB3190	645	1.183
515	1135	AFTON	97AB2310	246	1.183
516	1149	SA LAKE DR	97SA5865	1062	1.183
517	1115	BROOKHOLLOW	94CN7190	280	1.182
518	1286	DONNA SKID	94SBTX_B	529	1.181
519	1106	SA SOUTHLAND HILLS	97SA5455	1428	1.179
520	118	HOLCOMB	94LA3025	371	1.178
521	219	HOLLY	94CS5820	903	1.177
522	581	KINGSVILLE	94CS1670	426	1.176
523	749	ANSON 12KV	97AB6635	414	1.174
524	1195	DUST DEVIL	94LA1495	2026	1.171
525	1059	MELVIN	97SA4955	82	1.171
526	546	LA GRULLA	94SB5005	1215	1.169
527	1073	EDNA	94CN5785	1258	1.169
528	978	CHILLICOTHE	97AB4530	506	1.168
529	751	LAREDO PLANT	94LA9305	1066	1.168
530	1072	GREGORY	94CS2420	913	1.166
531	941	CROSS PLAINS	97AB1795	434	1.166
532	1129	SA EMERSON ST	97SA4620	431	1.165
533	973	VICTORIA POWER PLANT	94CN8070	608	1.161
534	1282	MAYBERRY	94SB5340	39	1.154
535	393	SANTA ANNA	97SA3420	367	1.153
536	1046	RUSSEK STREET	97SA7705	1331	1.153
537	1220	AB SHELTON ST	97AB3045	550	1.149
538	437	MORRIS STREET	94CS7465	743	1.148
539	1042	AB OVER STREET 12KV	97AB1635	528	1.148
540	1180	WYLIE	97AB2675	820	1.148
541	1055	RESACA	94SB9975	561	1.146
542	311	NORTH MCALLEN	94SB5055	3319	1.145
543	72	THREE RIVERS	94CN5100	76	1.145
544	343	PUTNAM	97AB2129	201	1.144
545	352	CARRIZO SPRINGS	94LA910	872	1.142
546	990	AB OVER STREET 12KV	97AB1840	888	1.142
547	1159	AB EAST 12KV	97AB4820	1152	1.141
548	690	PUTNAM	97AB2131	123	1.138
549	912	NORDHEIM	94CN4275	80	1.138
550	705	CITRUS CITY	94SB6000	2373	1.135
551	710	MILO	94LA3070	1966	1.135
552	1208	ARANSAS PASS	94CS8270	412	1.133
553	746	MUNDAY	97AB6715	257	1.132
554	87	PHARR	94SB1645	1728	1.132
555	873	TWILIGHT TRAIL	97AB5855	257	1.128
556	1107	QUANAH	97AB3100	557	1.126
557	1089	ROTAN	97AB1860	686	1.125
558	1031	SARAGOSA	97SA14080	48	1.125
559	578	WINTERS	97SA2113	801	1.124

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
560	198	GOVERNMENT WELLS	94LA7240	229	1.122
561	1186	RANKIN	97SA6405	360	1.119
562	1120	SA NORTH	97SA3125	1387	1.119
563	527	BARNHART	97SA3725	135	1.119
564	7	WESMER	94SB6900	51	1.118
565	252	POLK AVENUE	94SB4740	1718	1.113
566	248	HAROLD	97AB3055	27	1.111
567	639	PECAN BAYOU	97AB530	18	1.111
568	173	GRAYBACK	97AB3315	46	1.109
569	965	TURKEY	97AB2980	333	1.108
570	170	ODEM	94CS2400	315	1.108
571	694	SANTO NINO	94LA75	1515	1.108
572	489	BEN FICKLIN	97SA6185	755	1.106
573	994	AB MCMURRY	97AB4360	1100	1.105
574	796	SEAWALL	94CS9450	299	1.104
575	207	PORT ARANSAS	94CS1000	1611	1.101
576	605	HASKELL 12KV	97AB3770	459	1.098
577	23	BONNIEVIEW	94CS8020	544	1.097
578	463	KLEBERG	94CS6410	247	1.097
579	423	HOLLY	94CS9675	1776	1.096
580	700	MCCOLL ROAD	94SB4910	335	1.096
581	124	VALENTINE	97SA6325	550	1.095
582	407	HIDALGO	94SB3680	334	1.093
583	959	MAYBERRY	94SB1790	1090	1.092
584	987	AB ELM CREEK	97AB1815	388	1.090
585	1134	PANTERA	94SB1315	1921	1.090
586	805	YOUNG	94SB7145	1810	1.090
587	1161	AB OVER STREET 12KV	97AB3140	686	1.087
588	1182	ANSON 12KV	97AB6630	718	1.086
589	1250	MORRIS STREET	94CSBLACK	82	1.085
590	178	EDROY	94CS6990	294	1.085
591	378	ELDORADO	97SA5310	189	1.085
592	1001	SA GRAPE CREEK	97SA5365	857	1.084
593	1213	SAND CRAB	94CN8390	532	1.083
594	1080	NORTH MCALLEN	94SB2750	3182	1.082
595	529	KNOX CITY	97AB3390	380	1.082
596	316	DARST	94CN1265	75	1.080
597	1191	UNITEC	94LA4715	40	1.075
598	229	BROWNSVILLE	94SB3050	2010	1.075
599	1038	ABILENE PLANT	97AB1735	84	1.071
600	420	WOODSBORO	94CS8330	298	1.070
601	812	AB EAST 12KV	97AB5760	215	1.070
602	885	HAINE DRIVE	94SB8065	1368	1.069
603	545	DIMMIT	94LA5545	549	1.069
604	734	JOURDANTON	94LA8725	30	1.067
605	1099	RUSSEK STREET	97SA250	143	1.063
606	158	GOLIAD	94CN8220	1056	1.063

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
607	692	AB SHELTON ST	97AB3040	179	1.061
608	1209	AB COUNTRY CLUB	97AB4730	542	1.061
609	1124	ROBY	97AB2276	333	1.054
610	1102	AIRLINE	94CS8890	526	1.053
611	843	DEL MAR	94LA7930	1981	1.053
612	549	HAINE DRIVE	94SB9700	1166	1.050
613	1064	GATEWAY	94LA3595	1503	1.044
614	490	PLEASANTON	94LA2080	1742	1.040
615	1234	AB ELM CREEK	97AB1820	100	1.040
616	1265	HAMLIN SHELL	97AB6330	26	1.038
617	427	CITRUS CITY	94SB3470	1776	1.038
618	855	VERNON	97AB1520	723	1.037
619	890	AB WALNUT ST	97AB3445	56	1.036
620	36	BLACK BAYOU	94CN1120	371	1.035
621	68	STAFFORD HILL	94CN1550	144	1.035
622	1260	VICTORIA POWER PLANT	94CNVGREEN	29	1.034
623	662	AB SHELTON ST	97AB3435	295	1.031
624		BULL MOOSE	94CS5875	66	1.030
625		DARST	94CN1610	66	1.030
626	1136	HEIGHTS	94LA2390	1722	1.030
627	938	YOUNG	94SB3310	1873	1.025
628	1254	MORRIS STREET	94CSYELLOW	44	1.023
629	171	SABINAL	94LA200	443	1.023
630	1054	MCCOLL ROAD	94SB5485	1077	1.019
631	511	ROWENA	97SA4480	231	1.017
632	896	MINES ROAD	94LA4275	252	1.016
633	271	KARNES CITY	94CN2315	1026	1.015
634	1201	HASKELL 12KV	97AB5240	650	1.014
635	1271	MORRIS STREET	94CSRED	148	1.014
636	441	MUSTANG ISLAND	94CS8510	516	1.010
637	1222	AB COUNTRY CLUB	97AB4725	230	1.009
638	1278	MORRIS STREET	94CSGREEN	235	1.009
639	1243	KENEDY S.S.	94CN8320	142	1.007
640	715	WEST MCALLEN	94SB4595	1190	1.006
641	911	DEL MAR	94LA490	797	1.003
642	496	TRENT	97AB2850	25	1.000
643	16	MESA VIEW	97SA7045	93	1.000
644	1043	MCKENZIE ROAD	94CS150	26	1.000
645	1103	AFTON	97AB2355	45	1.000
646	1255	VICTORIA POWER PLANT	94CNVRED	44	1.000
647	1259	VICTORIA POWER PLANT	94CNVBROWN	16	1.000
648	756	SA COKE ST	97SA3905	653	1.000
649	341	PETTUS	94CN8210	346	0.994
650	946	EL GATO	94SB890	3108	0.989
651	31	AFTON	97AB2225	54	0.981
652	1118	DEL MAR	94LA3440	1807	0.979
653	997	CEDAR GAP (TEC)	97AB4115	972	0.971

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
654	303	NORTH PADRE ISLAND	94CS1010	2394	0.964
655	50	HAROLD	97AB1495	25	0.960
656	1095	JOSLIN POWER PLANT	94CN8720	24	0.958
657	193	MCCAMEY	97SA2855	508	0.957
658	1022	ALPINE 12KV	97SA3160	1642	0.952
659	17	RANDADO	94LA8350	136	0.949
660	1274	MORRIS STREET	94CSBROWN	67	0.940
661	1145	MAYBERRY	94SB5770	924	0.938
662	451	BENTSEN	94SBSH115	342	0.930
663	53	CONTINENTAL	94SB3650	14	0.929
664	776	RUNGE	94CN3250	273	0.927
665	619	RODD FIELD	94CS1730	2211	0.923
666	1100	TWILIGHT TRAIL	97AB11500	1050	0.915
667	656	IRAAN	97SA2050	389	0.900
668	196	BRACKETTVILLE	94LA8460	1201	0.899
669	275	WOOLRIDGE	94CS1170	439	0.897
670	21	BAY CITY	94CN5960	402	0.893
671	418	SOUTHSIDE	94CS8035	1086	0.891
672	931	HEIGHTS	94LA9400	1470	0.887
673	900	POLK AVENUE	94SB4180	1298	0.883
674	212	HARLINGEN SWITCH	94SB4090	2347	0.883
675	1210	SOUTH MCALLEN	94SB5065	175	0.880
676	699	ARANSAS PASS	94CS1250	661	0.879
677	181	FREER	94LA2900	164	0.866
678	453	CRYSTAL CITY	94LA1425	1193	0.865
679	620	KLEBERG	94CS1560	1472	0.861
680	1226	SOUTH EAST EDINBURG	94SB4015	448	0.857
681	282	COTULLA	94LA460	502	0.857
682	677	SOUTH SANTA ROSA	94SB7485	1235	0.840
683	304	POINT COMFORT	94CN6060	369	0.840
684	412	RAYMONDVILLE #1	94SB3130	307	0.837
685	276	BANQUETTE	94CS130	231	0.835
686	1155	MATADOR	97AB3030	217	0.834
687	299	WEST MCALLEN	94SB4555	1619	0.832
688	126	CAMPWOOD	94LA3430	123	0.829
689	642	MESQUITE	94SB2900	948	0.814
690	913	PRIMERA	94SB6085	1462	0.814
691	810	MERTZON (CVEC)	97SA2905	592	0.806
692	353	SOUTH MISSION	94SB3620	2110	0.801
693	961	IRAAN	97SA2055	135	0.800
694	504	ARCADIA	94CS1400	443	0.797
695	428	BLESSING	94CN8790	761	0.794
696	838	REFUGIO	94CN1210	190	0.789
697	553	AIRLINE	94CS8370	274	0.788
698	816	TYNAN	94CS4000	27	0.778
699	1126	THREE RIVERS	94CN2010	313	0.767
700	263	ESCONDIDO	94LA3350	2283	0.761

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
701	932	ALAZAN	94CS2740	36	0.750
702	788	AIRLINE	94CS8260	1421	0.742
703	757	SOUTH SANTA ROSA	94SB1240	1704	0.738
704	731	AB HARTFORD ST	97AB3815	1114	0.732
705	684	ROCKPORT	94CS5930	944	0.730
706	444	ARCADIA	94CS1460	2455	0.730
707	460	STADIUM	94LA7810	1324	0.723
708	307	MATHIS	94CS1420	911	0.719
709	557	AMISTAD DAM	94LA5450	782	0.706
710	587	AB OIL MILL	97AB2780	747	0.700
711	673	NORTH VICTORIA	94CN7430	1685	0.694
712	256	MORRIS STREET	94CS8830	1512	0.692
713	1081	HAMILTON ROAD	94LA9655	1323	0.688
714	1067	CHILDRESS 69	97AB1800	543	0.685
715	327	MORRIS STREET	94CS8715	1587	0.679
716	1176	STADIUM	94LA7800	686	0.678
717	645	MAGRUDER	94CN6690	756	0.677
718	813	NORTH VICTORIA	94CN1580	1049	0.677
719	203	COFFEE PORT	94SB1090	1257	0.671
720	169	ARMSTRONG	94CS6050	85	0.671
721	833	LEARY LANE	94CN1890	1625	0.668
722	721	BRADY	97SA5015	201	0.667
723	918	KITTIE WEST	94CN3760	240	0.667
724	963	CITRUS CITY	94SB7985	1211	0.666
725	349	PREMONT	94LA2720	776	0.664
726	658	SANTO NINO	94LA515	1174	0.659
727	258	HAINE DRIVE	94SB270	1172	0.656
728	1019	GATEWAY	94LA390	3743	0.656
729	274	SUN VALLEY	97SA4300	69	0.652
730	179	GREENLAKE	94CN2760	1189	0.646
731	69	PORTLAND	94CS6505	1826	0.634
732	160	CABANISS	94CS80	98	0.633
733	222	RAYMONDVILLE #2	94SB3240	919	0.632
734	628	GREENLAKE	94CN2750	73	0.630
735	139	PETTUS	94CN1020	456	0.629
736	228	EAST HARRISON	94SB3190	1489	0.626
737	983	CHILDRESS 69	97AB1480	303	0.614
738	223	BUENA VISTA	94LA8965	919	0.614
739	1187	HIGHLAND	97SA6370	270	0.611
740	510	HAMILTON ROAD	94LA9665	1258	0.607
741	484	HALL ACRES ROAD	94SB3670	1292	0.603
742	1164	YOUNG	94SB4435	826	0.603
743	811	JUNCTION	97SA10795	811	0.602
744	383	PHARAOH	94CS1185	1414	0.601
745	826	ROCKPORT	94CS5130	566	0.601
746	954	AIRLINE	94CS9030	403	0.598
747	250	ALPINE 12KV	97SA6825	1806	0.596

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
748	671	RUNGE	94CN4465	361	0.596
749	448	NIXON	94CN2025	539	0.596
750	846	HARLINGEN	94SB370	1236	0.595
751	253	RIO GRANDE CITY	94SB3220	1420	0.593
752	930	MAGRUDER	94CN7690	542	0.592
753	870	GATEWAY	94LA350	2017	0.591
754	472	PEARSALL	94LA7050	581	0.585
755	702	HOMEPORT	94CS4665	429	0.580
756	566	SINTON	94CS1750	266	0.579
757	679	JOURDANTON	94LA880	1121	0.577
758	979	EAST HARRISON	94SB3030	678	0.572
759	799	AIRLINE	94CS9605	713	0.565
760	893	DEL RIO CITY	94LA440	1115	0.552
761	296	SAND CRAB	94CN6735	1321	0.551
762	1216	TRUSCOTT	97AB3845	31	0.548
763	98	BRUNI	94LA1100	602	0.548
764	1154	VERNON	97AB3340	534	0.547
765	519	WESLACO UNIT	94SB8610	1194	0.545
766	722	KLEIMANN	94CN565	582	0.545
767	227	LAS CRUSES	94LA7325	2761	0.541
768	375	HALL ACRES ROAD	94SB3460	3201	0.541
769	597	COTULLA	94LA610	727	0.541
770	797	FRIO	94LA2270	990	0.536
771	351	PALMVIEW	94SB9685	2957	0.533
772	831	FRIO	94LA1815	1069	0.529
773	419	ASHERTON	94LA5495	597	0.528
774	949	ANNA STREET	94LA900	2843	0.526
775	507	KENEDY S.S.	94CN8340	307	0.524
776	644	JOURDANTON	94LA5695	323	0.523
777	498	CRESTONIO	94LA6660	790	0.520
778	750	NIXON	94CN6630	645	0.519
779	60	GOVERNMENT WELLS	94LA6800	230	0.513
780	755	PORTLAND	94CS9270	1810	0.511
781	358	GEORGE WEST	94CN730	907	0.507
782	67	EAGLE LAKE	94CN320	629	0.506
783	720	PORT ISABEL S.S.	94SB4070	283	0.505
784	585	SAN DIEGO	94LA2880	1335	0.496
785	676	SAN DIEGO	94LA2890	1019	0.495
786	318	MOCKINGBIRD	94CN400	1015	0.491
787	874	SANTO NINO	94LA70	3113	0.485
788	706	CASA BLANCA	94CS4170	1158	0.485
789	47	BANDERA ELECTRIC (LEAKEY)	94LAL30	271	0.480
790	190	VILLA CAVAZOS	94SB5680	1983	0.478
791	1016	ALPINE 12KV	97SA3155	1357	0.477
792	1174	AB MCMURRY	97AB3240	766	0.477
793	698	EAGLE PASS CITY	94LA7060	871	0.476
794	477	ALBANY	97AB3540	635	0.476

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
795	554	CRYSTAL CITY	94LA7425	444	0.475
796	394	HOLLY	94CS1370	1886	0.475
797	693	SHARYLAND	94SB5105	2042	0.472
798	674	EAST HARRISON	94SB4310	1205	0.469
799	611	WEST MCALLEN	94SB4515	867	0.463
800	558	HEARN ROAD	94CS2220	1731	0.460
801	5	CARANCAHUA	94CN1875	59	0.458
802	1177	CHILDRESS 20TH ST	97AB5720	186	0.457
803	845	VERNON	97AB4275	593	0.455
804	1085	DEL RIO CITY	94LA9790	2357	0.454
805	591	SOUTHSIDE	94CS7955	1067	0.450
806	422	WINTERS	97SA3765	824	0.441
807	607	CHARLOTTE	94LA1960	506	0.439
808	770	ASPR CONTINENTAL	97AB4800	32	0.438
809	914	READING	94LA1275	78	0.436
810	108	NORTH VICTORIA	94CN7440	1643	0.435
811	827	CHOKE CANYON	94CN5390	412	0.434
812	686	SOUTHSIDE	94CS8005	744	0.434
813	828	SHEFFIELD	97SA6430	209	0.431
814	1281	MAYBERRY	94SB6450	28	0.429
815	576	REFUGIO	94CN1040	161	0.429
816	1184	BRONTE AMBASSADOR	97SA6650	14	0.429
817	1040	HEIGHTS	94LA2450	2042	0.426
818	780	EL CAMPO	94CN7710	1074	0.426
819	391	RUSSEK STREET	97SA11370	200	0.425
820	791	EAST HARRISON	94SB4360	1769	0.424
821	38	SUNCHASE	94SB1155	1433	0.424
822	277	HIGHWAY 9	94CS6780	754	0.422
823	763	STADIUM	94LA8540	1695	0.418
824	1119	MILO	94LA5020	113	0.416
825	485	BUENA VISTA	94LA9385	892	0.415
826	760	WEST MCALLEN	94SB4535	3068	0.415
827	339	NORTH EDINBURG	94SB3570	1051	0.414
828	184	ARCADIA	94CS1360	1539	0.409
829	617	MILO	94LA6940	467	0.407
830	892	RESACA	94SB7110	1730	0.405
831	648	EL CAMPO	94CN2860	1517	0.403
832	48	DARST	94CN1845	184	0.402
833	547	AB VOGEL ST	97AB4410	764	0.402
834	363	CLARKWOOD	94CS7610	105	0.400
835	404	STADIUM	94LA7490	1307	0.399
836	480	BROOKHOLLOW	94CN8960	595	0.398
837	426	MORAN	97AB2108	304	0.398
838	1086	REFUGIO	94CN1170	864	0.397
839	582	GRETA	94CN7890	235	0.396
840	650	CATARINA	94LA2380	187	0.396
841	487	BAY CITY	94CN2050	329	0.395

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
842	320	MAGRUDER	94CN245	1248	0.395
843	1024	BUENA VISTA	94LA9035	2048	0.395
844	493	CITRUS CITY	94SB9775	1599	0.393
845	517	REFUGIO	94CN5120	726	0.391
846	868	NORTH EDINBURG	94SB4240	1151	0.391
847	133	ARCADIA	94CS5030	1578	0.388
848	736	ODEM	94CS5575	80	0.388
849	926	NORTH VICTORIA	94CN2240	746	0.387
850	25	BLACK CAT	94CN4525	114	0.386
851	1189	TWILIGHT TRAIL	97AB3150	724	0.384
852	120	PALMVIEW	94SB7595	3225	0.382
853	652	ANNA STREET	94LA2250	1557	0.379
854	285	HALL ACRES ROAD	94SB4895	882	0.379
855	458	AB DYESS 2	97AB6335	352	0.378
856	334	LA GRULLA	94SB5110	1030	0.378
857	777	AB ELM CREEK	97AB5045	384	0.378
858	464	NORTH VICTORIA	94CN1470	481	0.376
859	752	FALFURRIAS	94LA1070	937	0.376
860	960	SA WALNUT ST	97SA3925	894	0.371
861	853	WAGGONER	97AB5900	27	0.370
862	377	WEAVER ROAD	94CN1910	27	0.370
863	1197	WYLIE	97AB6495	362	0.370
864	765	AB ELMDALE	97AB4085	46	0.370
865	259	WESLACO UNIT	94SB9805	2269	0.369
866	1006	LAREDO PLANT	94LA8505	1053	0.366
867	1056	SPUR	97AB5170	383	0.366
868	405	KLEBERG	94CS6000	1408	0.365
869	762	GARCENO	94SB2165	1973	0.364
870	726	FULTON	94CS6070	1817	0.364
871	416	OLMITO	94SB905	1677	0.363
872	834	SA SOUTH	97SA2595	1070	0.363
873	1143	AB SHELTON ST	97AB3050	649	0.361
874	42	MEDIO CREEK	94CN1380	810	0.360
875	438	PANTERA	94SB1105	580	0.360
876	1116	HEINES	94CS7875	1951	0.360
877	101	MOORE FIELD	94SB3110	720	0.360
878	895	CABANISS	94CS820	1304	0.359
879	56	SINTON	94CS360	335	0.358
880	1034	AB RAINEY CREEK	97AB4220	219	0.356
881	295	HARLINGEN	94SB360	2434	0.355
882	1109	COLLEGE HILLS	97SA5520	432	0.354
883	64	BIG WELLS	94LA1570	430	0.353
884	266	MCKENZIE ROAD	94CS330	2406	0.352
885	505	HOLLY	94CS1950	838	0.351
886	680	WESLACO UNIT	94SB8195	1667	0.349
887	431	ARCADIA	94CS5020	1544	0.348
888	10	DUNE FIELD (N CRANE)	97SA3885	69	0.348

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
889	842	ELSA	94SB690	2419	0.347
890		RAYMONDVILLE #2	94SB1280	989	0.346
891	373	CARRIZO SPRINGS	94LA370	550	0.342
892	1078	SA WALNUT ST	97SA3920	901	0.337
893	571	VERNON	97AB1750	246	0.337
894	669	CABANISS	94CS710	175	0.337
895	716	HARLINGEN	94SB660	1270	0.337
896	92	SOUTH PADRE ISLAND	94SB6440	2590	0.336
897	242	GARCENO	94SB2135	1543	0.331
898	615	DILLEY	94LA6400	873	0.329
899	905	MERKEL	97AB1890	575	0.329
900	947	AB SHELTON ST	97AB3060	1584	0.328
901	459	LAREDO PLANT	94LA8565	1440	0.327
902	462	BAY CITY	94CN1110	1237	0.327
903	747	PUEBLO	94LA130	1764	0.327
904	27	MARKHAM	94CN6440	470	0.326
905	1279	ESPY WELLS	97SA50207	31	0.323
906	574	MOCKINGBIRD	94CN305	329	0.322
907	260	WEAVER ROAD	94CN1900	63	0.317
908	849	HALL ACRES ROAD	94SB9595	1588	0.317
909	481	ANNA STREET	94LA850	1559	0.317
910	1108	MCCOLL ROAD	94SB1655	1513	0.312
911	792	AB CANYON ROCK	97AB5030	699	0.310
912	512	NORTH MCALLEN	94SB5060	2634	0.310
913	593	HOLCOMB	94LA2240	458	0.310
914	660	ALICE	94LA1780	510	0.310
915	310	PONDER KENNEDY	97SA50208	13	0.308
916	844	HEIGHTS	94LA2100	1991	0.305
917	556	YOUNG	94SB6140	2536	0.304
918	901	MARFA	97SA1905	1155	0.304
919	77	CONTINENTAL	94SB4080	66	0.303
920	146	TANKERSLY (CVEC)	97SA5265	381	0.302
921	388	LAREDO PLANT	94LA8745	767	0.301
922	4	BAY CITY	94CN6450	164	0.299
923	631	AIRLINE	94CS9390	1352	0.297
924	1137	PANTERA	94SB1915	1195	0.297
925	935	SEAWALL	94CS9420	818	0.296
926	1018	THREE RIVERS	94CN2580	119	0.294
927	821	SHARYLAND	94SB2150	895	0.293
928	937	EL CAMPO	94CN7260	537	0.292
929	1125	ZACATE CREEK	94LA2675	1216	0.291
930	807	CRYSTAL CITY	94LA2170	747	0.290
931	598	CARRIZO SPRINGS	94LA860	31	0.290
932	861	EL CAMPO	94CN5745	941	0.290
933	1168	SA EMERSON ST	97SA4625	421	0.290
934	800	SA EMERSON ST	97SA4860	233	0.288
935	1002	POLK AVENUE	94SB4520	1068	0.287

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
936	981	MUNDAY REA (BKEC)	97AB2015	21	0.286
937	1000	SA LAKE DR	97SA5880	735	0.286
938	1171	QUANAH	97AB100	89	0.281
939	524	SOUTH MISSION	94SB3590	556	0.279
940	380	SKIDMORE	94CS600	365	0.277
941	848	AB OIL MILL	97AB3900	690	0.275
942	278	MORAN	97AB2107	208	0.274
943	781	KARNES CITY	94CN2325	665	0.274
944	748	SAND ROAD	97AB5655	622	0.273
945	482	VALADEZ	94CS3140	1977	0.273
946	1070	AB CANYON ROCK	97AB5035	823	0.272
947	365	HAMILTON ROAD	94LA9645	298	0.272
948	434	MILO	94LA3060	129	0.271
949	265	EDNA	94CN5775	509	0.269
950	579	SA JACKSON ST	97SA4265	799	0.269
951	1061	CHILDRESS 69	97AB4865	777	0.269
952	551	ESCONDIDO	94LA5730	2759	0.269
953	663	AIRLINE	94CS6970	1401	0.266
954	185	RACHAL	94LA6595	339	0.265
955	1039	COLLEGE HILLS	97SA6145	981	0.265
956	1035	LEARY LANE	94CN6175	2483	0.264
957	1079	SA JACKSON ST	97SA4260	654	0.261
958	447	RIO GRANDE CITY	94SB3210	1991	0.260
959	783	MAGRUDER	94CN6700	1374	0.258
960	907	SHARYLAND	94SB5635	2311	0.258
961	402	KINGSVILLE	94CS1140	1134	0.257
962	502	SAN BENITO	94SB3910	680	0.257
963	1218	CHILDRESS 20TH ST	97AB5725	680	0.256
964	577	YELLOW JACKET	97SA5505	539	0.254
965	241	PALMHURST	94SB2525	2328	0.253
966	986	COLLEGE HILLS	97SA4840	218	0.252
967	116	TANKERSLY (CVEC)	97SA5260	479	0.251
968	1008	SA COKE ST	97SA4910	1783	0.246
969	539	EL CAMPO	94CN6370	776	0.245
970	288	ALICE	94LA2540	963	0.244
971	1172	WASHINGTON STREET	94LA7015	1545	0.244
972	1141	WASHINGTON STREET	94LA6355	949	0.243
973	727	AILEEN	97AB4605	429	0.242
974	251	ROMA	94SB3070	904	0.242
975	298	RANKIN	97SA5735	187	0.241
976	899	TAYLOR	94SB5H111	711	0.241
977	421	CLARKWOOD	94CS2170	795	0.239
978	188	ZAPATA	94LA7330	1375	0.239
979	1156	SONORA	97SA2045	202	0.238
980	666	YELLOW JACKET	97SA7935	810	0.236
981	980	CISCO	97AB7400	833	0.235
982	921	VERNON	97AB5000	247	0.235

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
983	881	AB OIL MILL	97AB3895	133	0.233
984	563	SA SOUTH	97SA3995	795	0.233
985	955	LANTANA	94CS4095	195	0.231
986	1224	ROARING SPRINGS	97AB2065	217	0.230
987	1098	AB COUNTRY CLUB	97AB4735	122	0.230
988		PROGRESO	94SB2495	1696	0.229
989	1013	LA GRULLA	94SB4120	1532	0.228
990	723	KITTIE WEST	94CN3765	323	0.226
991	707	STADIUM	94LA6950	427	0.225
992	267	CLOSNER	94SB2945	1101	0.223
993	795	RODD FIELD	94CS245	705	0.221
994	1194	LAREDO PLANT	94LA8705	172	0.221
995	3	SANTA RITA	97SA1105	68	0.221
996	1111	LEARY LANE	94CN6005	1386	0.220
997	786	SOUTH MCALLEN	94SB3790	1468	0.218
998	1036	KENEDY	94CN6270	546	0.218
999	567	RAYMONDVILLE #1	94SB800	740	0.218
1000	475	PALMHURST	94SB1300	2280	0.216
1001	646	SOUTH MISSION	94SB5215	1241	0.216
1002	1097	RODD FIELD	94CS3010	2068	0.216
1003	1045	WASHINGTON STREET	94LA2350	3052	0.215
1004	1037	ARANSAS PASS	94CS9130	460	0.215
1005	847	MILO	94LA3065	28	0.214
1006	11	RAYMONDVILLE #2	94SB5875	28	0.214
1007	91	PORT ARANSAS	94CS3030	955	0.214
1008	382	PALMHURST	94SB2535	3048	0.214
1009	1026	MERTZON (CVEC)	97SA1530	338	0.213
1010	668	QUANAH	97AB1830	627	0.211
1011	852	MORRIS STREET	94CS8840	637	0.210
1012	44	SAN DIEGO	94LA1980	628	0.210
1013	758	AB MCMURRY	97AB4510	816	0.208
1014	903	EAGLE PASS CITY	94LA2650	1384	0.205
1015	1066	AB MCMURRY	97AB3235	781	0.204
1016	858	SAND ROAD	97AB5290	819	0.203
1017	711	BUSH KNOB	97AB5200	303	0.201
1018	357	MAGRUDER	94CN6680	701	0.201
1019	806	AB OIL MILL	97AB2785	274	0.201
1020	74	MARKHAM	94CN5550	20	0.200
1021	1235	PAINT ROCK	97SA5235	140	0.200
1022	568	UVALDE	94LA9770	516	0.200
1023	1169	SA AVENUE N	97SA1730	830	0.198
1024	714	KINGSVILLE	94CS1350	396	0.197
1025	1151	CLOSNER	94SB6430	1028	0.196
1026	654	AB COUNTRY CLUB	97AB4855	964	0.195
1027	999	READING	94LA1385	1354	0.194
1028	782	ZAPATA	94LA8290	988	0.193
1029	1229	MAYO	94CS500	26	0.192

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
1030	1223	VALADEZ	94CS8800	1690	0.192
1031	1245	AB REBECCA LANE	97AB5555	1268	0.192
1032	682	GOODWIN	94SB3530	335	0.191
1033	915	TRADE ZONE	94SB2060	513	0.191
1034	1084	SA WALNUT ST	97SA4635	1549	0.189
1035	793	AB VOGEL ST	97AB4650	809	0.188
1036	950	SOUTH PADRE ISLAND	94SB4675	197	0.188
1037	1198	SAN BENITO	94SB3860	258	0.186
1038	865	GILA	94CS7840	770	0.184
1039	514	QUANAH	97AB3975	214	0.182
1040	1131	UNIVERSITY	94LA465	931	0.182
1041	234	SARAGOSA	97SA1552	780	0.181
1042	824	STAMFORD	97AB4565	786	0.179
1043	195	GOODWIN	94SB4625	2302	0.178
1044	1217	UNIVERSITY	94LA920	909	0.177
1045	589	PRIMERA	94SB7020	1484	0.177
1046	312	TRENT	97AB4245	183	0.175
1047	387	MESQUITE	94SB8340	759	0.174
1048	1128	HEIGHTS	94LA6810	2122	0.173
1049	976	SANTO NINO	94LA80	1904	0.173
1050	364	MUSTANG ISLAND	94CS9470	790	0.172
1051	876	SOUTH MISSION	94SB4650	1010	0.171
1052	1065	CISCO	97AB9715	1023	0.170
1053	371	RAYMONDVILLE #1	94SB620	667	0.169
1054	614	KLEIMANN	94CN425	612	0.168
1055	956	HIGHLAND	97SA6385	1356	0.168
1056	359	BIG WELLS	94LA2630	30	0.167
1057	1256	DUST DEVIL	94LA1380	42	0.167
1058	1104	ROARING SPRINGS	97AB6155	30	0.167
1059	610	TATTON	94CS8200	1225	0.167
1060	59	GILA	94CS350	308	0.166
1061	982	ARANSAS PASS	94CS650	1192	0.165
1062	1240	COLLEGE HILLS	97SA4845	600	0.165
1063	659	NORTH MCALLEN	94SB9660	2183	0.164
1064	1160	TWILIGHT TRAIL	97AB4290	1202	0.164
1065	244	SOUTH MCALLEN	94SB3850	1362	0.164
1066	544	KLEBERG	94CS280	1328	0.163
1067	134	ALBANY	97AB3655	625	0.163
1068	818	SAND ROAD	97AB5295	537	0.162
1069	8	SONORA ATLANTIC (SWTEC)	97SA4415	31	0.161
1070	898	FT DAVIS	97SA3345	539	0.160
1071	1032	COTULLA	94LA90	1058	0.157
1072	866	WASHINGTON STREET	94LA2360	204	0.157
1073	1057	STAMFORD	97AB6255	434	0.157
1074	435	ROCKPORT	94CS5940	64	0.156
1075	457	KLEBERG	94CS8140	643	0.154
1076	822	CROWELL	97AB3490	176	0.153

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
1077	194	ROCKSPRINGS	94LA2600	368	0.152
1078	1236	SPUR	97AB300	204	0.152
1079	1214	SA WALNUT ST	97SA3910	145	0.152
1080	1158	BENJAMIN (BEPC)	97AB5680	165	0.152
1081	99	STAMFORD	97AB2835	100	0.150
1082	1050	RANKIN	97SA6400	60	0.150
1083	532	WOOLRIDGE	94CS1120	1636	0.150
1084	717	SOUTH EAST EDINBURG	94SB4570	1902	0.148
1085	995	VERNON CITY PLANT	97AB5775	813	0.148
1086	583	DEL MAR	94LA10	1746	0.147
1087		DUST DEVIL	94LA1810	478	0.146
1088	317	GILA	94CS345	69	0.145
1089	1147	AB WALNUT ST	97AB3110	658	0.144
1090	667	ENCINAL	94LA2160	231	0.143
1091	305	PEARSALL	94LA5580	854	0.143
1092	910	SHARYLAND	94SB2020	2814	0.141
1093	817	KLEBERG	94CS9395	1261	0.140
1094	638	SA AVENUE N	97SA1695	1525	0.140
1095	132	GOVERNMENT WELLS	94LA7250	566	0.140
1096	719	SOUTH MISSION	94SB3940	877	0.139
1097	125	MIDWAY LANE	97SA3440	58	0.138
1098	1075	AB VOGEL ST	97AB4405	597	0.137
1099	468	AIRLINE	94CS7390	2330	0.137
1100	596	HAMLIN	97AB3270	893	0.137
1101	210	CLYDE	97AB1755	132	0.136
1102	625	SOUTH MISSION	94SB3980	1937	0.136
1103	1011	MCCOLL ROAD	94SB4400	1288	0.134
1104	473	LA GRULLA	94SB3045	1211	0.132
1105	518	POWELL FIELD	97SA2528	23	0.130
1106	820	SHARYLAND	94SB2035	853	0.130
1107	147	MUNDAY	97AB3365	390	0.128
1108	743	PRIMERA	94SB5705	1260	0.128
1109	368	EDNA	94CN5765	1257	0.126
1110	1010	BAIRD	97AB5120	568	0.125
1111	975	TEX/NEW MEX PIPELINE	97SA9045	16	0.125
1112	561	NORTH MCALLEN	94SB9640	1535	0.124
1113	1133	BALLINGER	97SA4395	534	0.124
1114	972	WASHINGTON STREET	94LA2470	481	0.123
1115	389	AB MAPLE ST	97AB5750	474	0.122
1116	1211	MAYBERRY	94SB3010	347	0.121
1117	279	ROCKPORT	94CS5950	555	0.121
1118	883	SA CONCHO	97SA1705	928	0.121
1119	1074	ROCHESTER	97AB3295	208	0.120
1120	1190	SIERRA VISTA	94LA9900	2515	0.119
1121	925	KARNES CITY	94CN2340	786	0.118
1122	324	VALADEZ	94CS2500	2570	0.118
1123	739	MCCOLL ROAD	94SB2810	2287	0.116

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
1124	1049	SA EMERSON ST	97SA4630	1236	0.116
1125	887	LA GRULLA	94SB6150	1735	0.115
1126	988	BRONTE	97SA3590	194	0.113
1127	300	KNOX CITY	97AB3300	459	0.113
1128	1269	BARNHART	97SA590	18	0.111
1129	787	AB HARTFORD ST	97AB3690	172	0.110
1130	1205	SA SOUTHLAND HILLS	97SA5055	857	0.110
1131	497	NORTH MCALLEN	94SB4995	2486	0.109
1132	837	ROMA	94SB3060	1619	0.107
1133	411	AB RAINEY CREEK	97AB4270	1422	0.107
1134	928	ARANSAS PASS	94CS660	723	0.107
1135	1029	POLK AVENUE	94SB4600	160	0.106
1136	879	SA NORTH	97SA3120	1136	0.106
1137	80	PERKINS PROTHO	97SA3180	19	0.105
1138	599	EAST HARRISON	94SB4620	776	0.104
1139	888	QUANAH	97AB3530	328	0.104
1140	773	ASPERMONT	97AB1070	329	0.103
1141	1150	AILEEN	97AB6435	852	0.102
1142	724	ASPERMONT	97AB3380	395	0.101
1143	322	GOODWIN	94SB7380	2094	0.101
1144	1283	KIRKLAND	97AB3545	30	0.100
1145	548	SA NORTH	97SA3130	231	0.100
1146	239	DEL MAR	94LA220	1470	0.099
1147	1157	PADUCAH CITY	97AB1930	574	0.099
1148	647	SINTON	94CS180	232	0.099
1149	624	HARLINGEN	94SB380	263	0.099
1150	1183	SOUTH MCALLEN	94SB3935	508	0.098
1151	626	SA CONCHO	97SA3325	295	0.098
1152	1230	SA SOUTH	97SA3500	562	0.098
1153	572	AB ELM CREEK	97AB4780	553	0.098
1154	449	ABILENE PLANT	97AB1910	246	0.098
1155	1152	PADUCAH CITY	97AB1935	289	0.097
1156	966	NORTH WESLACO	94SB4830	531	0.096
1157	630	SA SOUTH	97SA4255	866	0.096
1158	1030	AB SHELTON ST	97AB3145	1051	0.095
1159	1021	CISCO	97AB1020	479	0.094
1160	26	RODD FIELD	94CS2190	96	0.094
1161	1083	TWILIGHT TRAIL	97AB4285	1146	0.093
1162	1200	BRONTE	97SA3560	229	0.092
1163	940	JOSLIN POWER PLANT	94CN7915	11	0.091
1164	1051	ZACATE CREEK	94LA2665	1727	0.091
1165	839	CISCO	97AB6530	538	0.089
1166	1170	AB ELM CREEK	97AB1810	831	0.088
1167	875	AB REBECCA LANE	97AB6915	1020	0.087
1168	287	ALBANY	97AB3640	335	0.087
1169	902	AB CANYON ROCK	97AB5025	58	0.086
1170	1202	SA MATHIS FIELD	97SA5100	316	0.085

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
1171	886	EDITH HUMBLE	97SA6170	83	0.084
1172	294	JAYTON	97AB6125	353	0.082
1173	1192	SOUTHSIDE	94CS5345	403	0.082
1174	292	ESCONDIDO	94LA1510	739	0.081
1175	500	AB MAPLE ST	97AB4070	1070	0.080
1176	446	KNOX CITY	97AB3985	25	0.080
1177	1071	SA JACKSON ST	97SA4685	1442	0.080
1178	319	PALMVIEW	94SB9680	1066	0.080
1179	1110	AB DYESS 1	97AB1775	881	0.079
1180	803	NORTH EDINBURG	94SB3810	1535	0.079
1181	1113	ROBERT LEE	97SA4120	549	0.078
1182	1127	DEL MAR	94LA2120	1346	0.078
1183	1142	SA AVENUE N	97SA1655	494	0.075
1184	687	ALICE	94LA1790	454	0.075
1185	725	PAISANO	97SAPAISAN	161	0.075
1186	1288	STEAMBOAT	97AB12515	68	0.074
1187	1239	HEINES	94CS8480	150	0.073
1188	681	ROBERT LEE	97SA4125	274	0.073
1189	1251	BENTSEN	94SBSH215	55	0.073
1190	948	MARFA	97SA1900	822	0.072
1191	641	ASHLAND	94SBSH301	14	0.071
1192	851	SA JACKSON ST	97SA4690	1122	0.071
1193	1163	CROWELL	97AB3980	471	0.070
1194	732	PEACOCK	97AB1375	43	0.070
1195	361	HEIGHTS	94LA9080	694	0.069
1196	962	PHARR	94SB1650	898	0.069
1197	1196	AB EAST 12KV	97AB4830	1020	0.068
1198	562	SIERRA VISTA	94LA8205	1236	0.066
1199	79	GATEWAY	94LA5055	1893	0.064
1200	1233	SA WALNUT ST	97SA3915	722	0.064
1201	522	SA CONCHO	97SA1700	553	0.063
1202	347	CAUSEWAY	94SB4775	1069	0.062
1203	1027	KENEDY S.S.	94CN6750	65	0.062
1204	1148	RAYMONDVILLE #2	94SB4160	347	0.061
1205	622	GARCENO	94SB5490	1459	0.060
1206	952	EDEN	97SA3195	533	0.060
1207	1228	SA SOUTH	97SA4795	1504	0.060
1208	1193	SIERRA VISTA	94LA7170	1455	0.058
1209	1007	AB EAST 12KV	97AB4825	416	0.058
1210	1242	TRADE ZONE	94SB2220	70	0.057
1211	1237	AB ELM CREEK	97AB1825	214	0.056
1212	718	SHARYLAND	94SB2010	1165	0.056
1213	1252	UNITEC	94LA5895	36	0.056
1214	884	ABILENE PLANT	97AB1740	18	0.056
1215	465	MILES	97SA4670	395	0.053
1216	338	ANNA STREET	94LA5780	661	0.053
1217	794	CLOSNER	94SB7505	764	0.052

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
1218	1105	MORRIS STREET	94CS8850	411	0.051
1219	764	SA CONCHO	97SA1715	294	0.051
1220	689	VALERA HUMBLE	97SA7015	79	0.051
1221	804	AB REBECCA LANE	97AB2710	262	0.050
1222	1091	SPUR	97AB260	162	0.049
1223	1247	LAS CRUSES	94LA9865	448	0.049
1224	1227	RANKIN	97SA7425	123	0.049
1225	1276	BRYANTS RANCH	97SA205	21	0.048
1226	1162	AB REBECCA LANE	97AB5550	716	0.047
1227	1112	NEW BLUFFS	97SA7280	1581	0.047
1228	944	MUNDAY	97AB2080	506	0.047
1229	1206	SANTO NINO	94LA695	1606	0.047
1230	1167	SIERRA VISTA	94LA7360	1713	0.047
1231	1215	SA SOUTHLAND HILLS	97SA5860	1193	0.045
1232	1173	AB ONYX REA	97AB3255	23	0.043
1233	1178	HIGHLAND	97SA6375	295	0.041
1234	877	AB HARTFORD ST	97AB3685	370	0.041
1235	651	ABILENE PLANT	97AB1915	50	0.040
1236	145	HEINES	94CS3515	1307	0.040
1237	478	AB ELMDALE	97AB4520	283	0.039
1238	1225	CHILDRESS 69	97AB2800	342	0.038
1239	872	AB HARTFORD ST	97AB3820	927	0.036
1240	1257	SA CONCHO	97SA1725	29	0.034
1241	1144	FLOMOT	97AB81335	29	0.034
1242	691	ROCKSPRINGS	94LA8040	332	0.033
1243	1219	HAMLIN	97AB3775	246	0.033
1244	878	AIRLINE	94CS7270	1034	0.032
1245	608	ROTAN	97AB1865	193	0.031
1246	916	TALPA ATLANTIC	97SA5180	65	0.031
1247	1241	TAYLOR	94SBSH112	989	0.030
1248		SONORA	97SAT000E2	498	0.030
1249		LA PRYOR	94LA1835	266	0.030
1250	406	HAINE DRIVE	94SB9240	34	0.029
1251	1272	CROCKETT HEIGHTS	97SA73703	69	0.029
1252	904	MATADOR	97AB3090	315	0.029
1253	1044	ALPINE 12KV	97SA6820	775	0.028
1254	1062	BRONTE	97SA4160	226	0.027
1255	857	SA JACKSON ST	97SA4695	561	0.025
1256	637	ROCHESTER	97AB3290	82	0.024
1257	1199	COLLEGE HILLS	97SA4835	499	0.024
1258	1248	RUSSEK STREET	97SA12295	292	0.024
1259	984	SA SOUTH	97SA3990	757	0.024
1260	1188	WEINERT	97AB6490	129	0.023
1261	1077	SA AVENUE N	97SA1975	320	0.022
1262	1153	SANTO NINO	94LA645	840	0.021
1263	1284	TAYLOR	94SBSH114	626	0.021
1264	1052	SOUTH MCALLEN	94SB3640	205	0.020

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
1265	461	HIGHLAND	97SA6380	478	0.019
1266	1088	EAST HARRISON	94SB3000	548	0.018
1267	971	COTULLA	94LA110	55	0.018
1268	159	ESCONDIDO	94LA2035	444	0.018
1269		QUINTANA	94CNT001Y8	58	0.017
1270	535	AB MAPLE ST	97AB5755	1220	0.016
1271	1204	PAINT ROCK	97SA1110	64	0.016
1272	151	UNIVERSITY	94LA305	759	0.014
1273	1123	EDEN	97SA1780	232	0.013
1274	1025	ESCONDIDO	94LA3775	234	0.013
1275	1268	COLLEGE HILLS	97SA5515	201	0.010
1276		MINES ROAD	94LA3745	2114	0.009
1277	832	SA JACKSON ST	97SA4250	336	0.009
1278	1273	ABILENE PLANT	97AB3175	122	0.008
1279	433	SIERRA VISTA	94LA3540	1154	0.008
1280		STERLING CITY	97SA11040	544	0.007
1281	939	NEW BLUFFS	97SA9110	818	0.006
1282	1289	MILES	97SA11330	171	0.006
1283	467	SA COKE ST	97SA4915	176	0.006
1284	148	IRAAN	97SA4305	251	0.004
1285	1181	NEW BLUFFS	97SA3005	314	0.003
1286	1249	BENTSEN	94SBSH211	375	0.003
1287	825	UNIVERSITY	94LA930	92	0.000
1288	1258	WASHINGTON STREET	94LA2330	60	0.000
1289		MINES ROAD	94LA8770	310	0.000
1290	1068	LAS CRUSES	94LA8530	80	0.000
1291	1267	VICTORIA POWER PLANT	94CNNETVIC	88	0.000
1292	1270	WASHINGTON STREET	94LANETLAR	163	0.000
1293	1280	WASHINGTON STREET	94LA6890	19	0.000
1294	1266	WASHINGTON STREET	94LA2310	46	0.000
1295	1262	MORRIS STREET	94CSNET CC	317	0.000
1296	1238	KENEDY	94CN1960	69	0.000
1297	1261	WASHINGTON STREET	94LA2320	34	0.000
1298	1263	AB WALNUT ST	97AB3250	11	0.000
1299	860	SANTA RITA	97SA1135	10	0.000
1300	246	GIRARD	97AB6260	43	0.000
1301	1246	AILEEN	97AB4600	270	0.000
1302	933	SANTA RITA	97SA1140	11	0.000
1303	432	ASPR CONTINENTAL	97AB3830	27	0.000
1304	1275	ABILENE INDUSTRIAL PARK	97AB6600	12	0.000

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
--------------------	--------------------	---------------------------	-----------------------	---------------------	------------------

Feeders from last year that are not in this year's list

2021 Ranking	Substation Identification	Feeder ID	Reason not in 2022
13	MASTERSON FIELD	97SA800	Count is now less than 10
20	HOEFFS ROAD	97SA15680	Count is now less than 10
942	RIO PECOS	97SA513	Count is now less than 10

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

Total Number of Feeders

With 10 or more Customers

1304

Add or Delete Rows as Necessary

AEP Texas

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
1	47	RIO RICO	94SB8330	70	4,330.2
2	90	MINES ROAD	94LA7235	43	2,704.5
3	778	BERCLAIR	94CN990	26	2,308.2
4	368	MATHIS	94CS1410	472	1,655.6
5	147	RAYMONDVILLE #2	94SB3170	766	1,438.8
6	71	RIO RICO	94SB5050	290	1,321.2
7	180	LULING - LCRA	94CN10	452	1,267.8
8	121	CHERRY CREEK TAP	97SA485	53	1,261.3
9	474	RANDADO	94LA8360	163	1,256.8
10	176	PECOS VALLEY	97SA4080	237	1,225.8
11	280	MALONE	94CN7550	226	1,202.3
12	133	VERHALEN	97SA4460	70	1,158.8
13	833	TRENT	97AB2850	25	1,054.3
14	171	TAFT	94CS1260	200	996.2
15	685	FREER	94LA1500	201	983.4
16	272	BLESSING	94CN8780	58	978.3
17	311	TWILIGHT TRAIL	97AB11500	1,050	916.1
18	734	CHARLOTTE	94LA2780	33	915.5
19	404	SARAGOSA	97SA14080	48	908.8
20	40	RIO PECOS	97SA3835	103	901.3
21	290	KEMPER EXXON HUMBLE	97SA72103	26	877.3
22	874	THREE RIVERS	94CN8430	194	873.6
23	631	TATTON	94CS950	576	850.9
24	313	TATTON	94CN8490	293	842.4
25	172	PROGRESO	94SB2545	90	841.5
26	84	MCELROY	97SA5165	95	837.1
27	55	CHILLICOTHE	97AB4525	119	834.3
28	321	SAND CRAB	94CN9235	386	810.4
29	923	PECOS VALLEY	97SA9615	56	796.9
30	1083	SAN BENITO	94SB4135	1,388	794.8
31	680	MCCAMEY	97SA2415	76	777.8
32	948	GREGORY	94CS5900	120	769.0
33	853	PREMONT	94LA6570	809	767.0
34	757	OZONA	97SA3555	157	755.5
35	183	ALPINE 12KV	97SA3875	105	750.4
36	337	SPUDDER FLAT	97SA4180	48	743.0
37	32	NORTH ALAMO	94SB4370	1,628	737.2
38	77	CRESTONIO	94LA270	641	732.6
39	17	GREENLAKE	94CN2740	381	704.2
40	49	MCCAMEY	97SA2830	97	703.5
41	946	GOODLETT	97AB12205	48	698.0
42	198	BRUNI	94LA5440	129	693.0
43	83	SAN DIEGO	94LA2930	565	682.8
44	704	SAND ROAD	97AB5195	254	676.9

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
45	143	TYNAN	94CS1855	135	671.9
46	782	ASHERTON	94LA4175	82	669.9
47	451	PECOS VALLEY	97SA4075	21	668.6
48	35	TYNAN	94CS4010	46	667.5
49	26	BAY CITY	94CN6670	1,615	664.2
50	441	ALAZAN	94CS620	179	652.1
51	726	NAVAL BASE	94CS7950	806	647.0
52	264	BRUNI	94LA1120	266	639.8
53	36	MATHIS	94CS340	1,418	632.1
54	731	INGLESIDE CITY	94CS8050	1,277	629.4
55	460	PREMONT	94LA2730	199	628.3
56	920	SAND CRAB	94CN8120	264	620.5
57	1143	BULL MOOSE	94CS4185	20	612.2
58	64	WADSWORTH	94CN8630	669	609.1
59	57	CABANISS	94CS615	266	605.3
60	698	KEPLER	94CS2665	37	605.0
61	190	CLARKWOOD	94CS5525	627	598.7
62	718	WEIL TRACT (138/12KV)	94CS1990	1,369	595.6
63	130	FT CHADBOURNE	97SA6515	92	592.3
64	276	GANADO	94CN5795	489	583.5
65	135	SPUDDER FLAT	97SA4175	57	582.6
66	237	PUEBLO	94LA95	1,415	575.2
67	1140	ARCADIA	94CS1440	1,662	573.1
68	209	CHILLICOTHE	97AB4530	506	572.9
69	688	FASHING	94CN360	34	557.8
70	323	WEST OSO	94CS9085	945	555.0
71	550	PORT ISABEL S.S.	94SB9295	2,515	549.1
72	463	GEORGE WEST	94CN1320	687	548.3
73	236	HIGHWAY 9	94CS6760	1,033	547.1
74	446	ELSA	94SB700	1,523	540.8
75	818	ZAPATA	94LA8300	1,613	537.5
76	13	OZONA	97SA4185	734	521.0
77	7	OZONA	97SA3810	1,172	520.7
78	1137	CAMPWOOD	94LA2610	1,009	520.6
79		INGLESIDE CITY	94CS6040	429	517.4
80	78	CONOCO-CHITTAM RANCH	94LA8580	26	516.9
81	61	NORTH PADRE ISLAND	94CS720	1,402	514.2
82		ALICE	94LA1770	1,657	510.6
83	22	ROBY	97AB3795	76	507.6
84	542	UNITEC	94LA3085	114	503.7
85	126	RIO BRAVO	94LA1130	1,071	503.3
86	346	GOVERNMENT WELLS	94LA7240	229	503.2
87	736	RAYMONDVILLE #2	94SB3250	28	503.2
88	693	SHROPSHIRE	94CN1240	73	501.6
89	70	LA PRYOR	94LA570	171	500.2
90	59	PLACEDO	94CN7970	490	485.8
91	671	SARAGOSA	97SA1590	49	483.0
92	166	ODEM	94CS385	567	477.9
93	33	STAFFORD HILL	94CN9955	85	476.0

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
94	429	NORTH MERCEDES	94SB3840	710	467.0
95	795	FOSTER FIELD	94CN2550	66	465.1
96	1026	CALLICOATTE	94CS8785	1,193	463.2
97	50	RIO BRAVO	94LA5	713	461.7
98	43	WEIL TRACT (138/12KV)	94CS2520	83	461.6
99	56	EAGLE LAKE	94CN9455	609	460.3
100	255	THREE RIVERS	94CN5100	76	460.0
101	116	NORTH PADRE ISLAND	94CS5170	870	459.3
102	804	PLASTERCO (MWEC)	97AB2720	117	457.1
103	900	O_CONNER	94CN390	200	449.9
104	954	MOORE FIELD	94SB3120	151	446.9
105	186	CASA BLANCA	94CS5440	109	446.4
106	72	SAN YGNACIO	94LA16060	539	445.4
107	1105	MAYBERRY	94SB3160	558	443.5
108	326	KNIPPA	94LA6535	22	438.1
109	2	PARKER	94CN9010	21	435.6
110	886	POLK AVENUE	94SB4170	1,466	435.3
111	251	BLACK CAT	94CN3175	495	433.1
112	363	GREGORY	94CS5920	765	432.6
113	87	FREISS RANCH	97SA4870	100	429.9
114	1287	ROUNDTOP	97AB4490	54	426.1
115	136	MESQUITE	94SB3360	1,023	423.3
116	274	HOLLY	94CS1220	3,401	422.1
117	820	POLK AVENUE	94SB4900	1,915	420.7
118	278	DILLEY	94LA3795	103	413.7
119	112	MALONE	94CN7560	58	412.4
120	131	GARWOOD CITY	94CN2560	201	412.4
121	707	ELSA	94SB3520	1,011	411.2
122	1015	FALFURRIAS	94LA5210	1,177	407.8
123	482	BLESSING	94CN1030	285	406.7
124	902	COMSTOCK	94LA230	183	404.9
125	945	PLACEDO	94CN7980	425	404.2
126	86	PRAIRIE PUMP	94CN1940	91	403.7
127	892	PORT ARANSAS	94CS6940	1,635	403.6
128	894	WEIL TRACT (138/12KV)	94CS5405	178	403.5
129	737	ROBY	97AB2276	333	401.6
130	1225	SHROPSHIRE	94CN3575	34	399.8
131	156	PUTNAM	97AB2129	201	396.5
132	333	HAROLD	97AB3055	27	389.4
133	98	TAFT	94CS5230	832	385.3
134	320	MAYO	94CS625	208	384.5
135	165	YORKTOWN	94CN3130	492	383.2
136	107	WADSWORTH	94CN7660	1,476	382.5
137	89	FULTON	94CS2020	3,551	381.3
138	14	PORTLAND	94CS9290	1,790	380.7
139	151	POWELL FIELD	97SA2529	13	380.3
140	729	ALBANY	97AB2029	241	379.6
141	733	MELVIN	97SA940	46	378.0
142	341	SAN BENITO	94SB4945	1,732	375.3

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
143	351	STAMFORD	97AB2815	706	374.6
144	103	SINTON	94CS6860	1,007	371.7
145	310	RACHAL	94LA8145	376	371.4
146	261	ELSA	94SB3500	1,332	371.0
147	191	MATHIS	94CS2870	870	369.0
148	92	AB RAINEY CREEK	97AB4225	122	368.0
149	1009	SOUTH PADRE ISLAND	94SB4695	1,378	366.5
150	62	CONTINENTAL	94SB4880	69	365.0
151	761	PAWNEE (STEC OWNED)	94CN22202	197	364.4
152	141	GREGORY	94CS8560	255	362.8
153	1067	MATTHEWS	94CN1740	164	362.5
154	517	HIGHWAY 9	94CS6770	925	361.1
155	189	ALICE	94LA2530	1,502	361.0
156	74	FREER	94LA6320	162	361.0
157	489	DEL RIO CITY	94LA1930	1,564	359.9
158	375	HALL ACRES ROAD	94SB5585	1,623	359.2
159	759	LEARY LANE	94CN1430	1,915	358.9
160	324	WEST HARLINGEN	94SB3720	1,309	358.2
161	705	MCKENZIE ROAD	94CS140	296	356.5
162	41	HEARN ROAD	94CS8990	1,360	356.2
163	44	HOLLY	94CS1480	1,704	354.6
164	455	SOUTHSIDE	94CS5335	1,533	353.4
165	352	BAY CITY	94CN7480	380	352.9
166	746	BAY CITY	94CN2700	1,078	352.7
167	239	BULL MOOSE	94CS5875	66	352.4
168	138	LOS FRESNOS	94SB7270	2,376	350.8
169	862	DEL RIO CITY	94LA430	2,069	349.7
170	660	LA PRYOR	94LA1845	223	349.7
171	308	NORTH MERCEDES	94SB4860	1,504	345.6
172	821	ODEM	94CS375	631	343.3
173	294	TUSCOLA	97AB3305	1,234	341.3
174	514	ARANSAS PASS	94CS590	459	340.9
175	785	PHARR	94SB1620	1,243	338.9
176	427	VALENTINE	97SA5590	208	338.0
177	388	EL CAMPO	94CN2800	841	337.6
178	740	ELSA	94SB710	2,369	337.5
179	227	BANQUETTE	94CS9000	462	335.0
180	307	HIGHWAY 9	94CS7210	349	334.3
181	959	HAROLD	97AB1495	25	333.4
182	124	PICACHO	94LA630	378	332.4
183	212	LOS FRESNOS	94SB2160	1,863	331.8
184	932	EDROY	94CS6990	294	331.2
185	222	HIDALGO	94SB4845	1,411	331.0
186	168	LIVE OAK	94CS1080	2,555	329.1
187	317	PALACIOS	94CN6830	838	328.3
188	390	LOS FRESNOS	94SB4315	1,264	327.4
189	4	PUEBLO	94LA275	2,910	326.8
190	1097	EAGLE PASS CITY	94LA2745	934	326.8
191	993	SONORA 138 SUB	97SA4810	876	326.8

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
192	910	BARNHART	97SA3725	135	325.4
193	710	WEST HARLINGEN	94SB3700	1,876	324.4
194	1277	ZAPATA	94LA2710	1,346	324.1
195	528	PALMVIEW	94SB6790	2,557	323.4
196	76	CHARLOTTE	94LA2790	201	323.1
197	1019	VILLA CAVAZOS	94SB7615	1,121	321.6
198	712	MORRIS STREET	94CS8820	1,249	319.6
199	506	SANTA ANNA	97SA3415	343	317.1
200	492	ARANSAS PASS	94CS8280	619	315.4
201	370	RANDADO	94LA8350	136	315.2
202	23	INDIAN MESA	97SA2695	92	314.7
203	182	FALFURRIAS	94LA2830	1,529	313.7
204	27	PREMONT	94LA6610	834	312.4
205	435	PORT ISABEL S.S.	94SB3760	782	311.5
206	291	EAGLE PASS CITY	94LA2770	2,023	310.9
207	531	PALACIOS	94CN8550	84	309.2
208	364	RODD FIELD	94CS225	2,913	306.4
209		SOUTHSIDE	94CS7925	1,160	303.8
210	501	MATHIS	94CS1420	911	303.6
211	249	PIRATE	94CS3380	421	303.4
212	1012	EOLA	97SA4950	211	301.3
213	883	VICTORIA POWER PLANT	94CN1390	1,092	301.2
214	979	CLARKWOOD	94CS7230	624	300.6
215	91	MAGNOLIA	94CN315	84	299.4
216	532	LYTLE	94LA2850	757	298.9
217	267	RAYMONDVILLE #1	94SB630	792	298.6
218	754	INGLESIDE CITY	94CS8060	2,680	293.3
219	184	PORTLAND	94CS9370	2,100	291.0
220	65	CAUSEWAY	94SB4765	619	290.6
221	231	EDROY	94CS6980	195	289.3
222	1014	ASPHALT MINES	94LA500	43	285.8
223	302	PALMHURST	94SB3890	1,864	281.2
224	1120	MINES ROAD	94LA1600	1,218	278.7
225	681	LEARY LANE	94CN1540	793	278.1
226	929	CROSS PLAINS	97AB2920	552	277.8
227	770	BRADY	97SA5015	201	276.1
228	366	PARKER	94CN9260	126	275.9
229	807	COFFEE PORT	94SB1095	1,080	275.6
230	419	WOODSON OIL FIELD	97AB30	33	275.0
231	406	SUNCHASE	94SB1150	1,422	275.0
232	169	VALENTINE	97SA6325	550	274.6
233	521	LOLITA	94CN6330	30	274.2
234	342	PALMHURST	94SB2820	1,870	273.7
235	58	NORTH VICTORIA	94CN7770	829	273.4
236	51	PUEBLO	94LA9870	1,463	272.9
237	1096	LULING - LCRA	94CN20	278	271.6
238	732	EAGLE PASS CITY	94LA450	886	270.4
239	891	DARST	94CN1265	75	269.5
240	226	HALL ACRES ROAD	94SB5465	1,443	268.6

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
241	601	HIDALGO	94SB3400	891	265.8
242	592	MCCAMEY	97SA2420	82	265.5
243	285	PORT ARANSAS	94CS990	2,661	264.9
244	12	PORT ISABEL S.S.	94SB3820	175	264.8
245	1068	SEAWALL	94CS9325	1,584	263.6
246	985	BRUNI	94LA1100	602	262.3
247	1264	GARWOOD CITY	94CN2570	145	261.9
248	299	THREE RIVERS	94CN5190	475	261.6
249	510	ARCADIA	94CS1450	1,638	259.8
250	498	TRADE ZONE	94SB1935	41	259.5
251	93	SOUTHSIDE	94CS7995	1,551	259.4
252		HAISLEY	94CSTX_2_B	9	258.6
253	396	SOUTH PADRE ISLAND	94SB5850	1,374	258.5
254	871	INDIAN MESA	97SA2690	146	257.9
255	950	VERNON CITY PLANT	97AB5770	94	257.8
256	275	MELVIN	97SA4955	82	253.9
257	603	ARCADIA	94CS6930	1,480	253.6
258	1116	NAVAL BASE	94CS9720	2,657	253.2
259	1166	GANADO	94CN5815	601	252.5
260	692	PICACHO	94LA590	397	252.1
261	1042	SKIDMORE	94CS380	159	251.6
262	81	NORTH ALAMO	94SB3610	1,999	251.4
263	768	OLMITO	94SB715	673	250.7
264	28	WOODSBORO	94CS8330	298	250.4
265	530	ELDORADO	97SA1845	538	250.0
266	293	PLEASANTON	94LA9505	1,775	249.0
267	1128	BRACKETTVILLE	94LA8460	1,201	249.0
268	449	KEPLER	94CS1700	27	248.3
269	304	SWENSON	97AB136	31	248.2
270	998	BEN FICKLIN	97SA6185	755	244.0
271	192	RIO RICO	94SB8290	309	243.4
272	273	RIO BRAVO	94LA300	803	242.0
273	645	WOOLRIDGE	94CS1170	439	241.6
274	10	LA PRYOR	94LA580	334	240.6
275	750	MERTZON (CVEC)	97SA2905	592	240.5
276	906	BLACK CAT	94CN3000	1,646	240.0
277	104	PIRATE	94CS3490	378	238.6
278	373	GOLIAD	94CN6540	1,244	238.2
279	125	LIVE OAK	94CS1090	299	236.8
280	338	CASA BLANCA	94CS55	871	236.4
281	462	GONZALES	97SA15390	1,098	235.5
282	260	SABINAL	94LA485	498	235.1
283	812	BOBCAT HILLS	97SA6655	73	235.1
284	864	BEN FICKLIN	97SA14065	793	234.5
285	377	SOUTH SANTA ROSA	94SB1235	648	232.9
286	122	SOUTHSIDE	94CS8055	848	232.5
287	1253	BLACK CAT	94CN2960	2,121	230.5
288	656	FLOMOT	97AB1852	75	230.0
289	422	FALFURRIAS	94LA1080	463	229.1

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
290	913	CABANISS	94CS75	2,243	228.5
291	661	HOLCOMB	94LA3025	371	228.3
292	752	AB ELM CREEK	97AB1820	100	226.7
293	686	WESLACO UNIT	94SB7630	2,641	226.7
294	38	MORRIS STREET	94CS5655	316	226.4
295	224	DEL RIO CITY	94LA420	2,051	225.6
296	367	NORTH VICTORIA	94CN7860	1,510	225.3
297	919	MAGRUDER	94CN7870	1,262	225.2
298	79	WESMER	94SB4480	1,136	223.1
299	1146	CRESTONIO	94LA260	1,780	222.5
300	491	NORTH MERCEDES	94SB3770	1,844	221.8
301	113	CAUSEWAY	94SB9880	1,229	219.8
302	214	DUNE FIELD (N CRANE)	97SA3885	69	218.6
303	208	NORTH PADRE ISLAND	94CS7900	2,346	218.5
304	584	LOS FRESNOS	94SB5335	2,708	215.7
305	394	WESMER	94SB1850	485	214.9
306	146	RISING STAR	97AB5080	622	214.6
307	242	RESACA	94SB9975	561	214.5
308	653	FULTON	94CS440	2,074	214.4
309	119	HASKELL 12KV	97AB3495	826	214.0
310	548	JOSLIN POWER PLANT	94CN8720	24	213.5
311	742	WOOLRIDGE	94CS1110	1,650	212.8
312		MAVERICK	94LA9680	843	212.6
313	560	MOCKINGBIRD	94CN370	49	212.3
314	67	EAST HARRISON	94SB3080	472	212.2
315	39	HIDALGO	94SB3680	334	210.7
316	559	BIG OAK	94CN420	341	210.1
317	69	FREER	94LA2900	164	208.5
318	187	THOMASTON	94CN9580	49	206.2
319	34	NORTH ALAMO	94SB3580	1,023	204.6
320	329	SOUTHSIDE	94CS8045	970	203.0
321	885	MAYBERRY	94SB5770	924	201.9
322	895	FOSTER FIELD	94CN8880	294	200.7
323	534	TURKEY	97AB2980	333	200.4
324	865	NORTH PADRE ISLAND	94CS1010	2,394	200.4
325	306	CITRUS CITY	94SB5070	1,022	200.1
326	708	GOODWIN	94SB4390	413	199.9
327	243	WESLACO UNIT	94SB5970	2,047	199.8
328	387	WEST OSO	94CS9090	1,672	199.0
329	382	BLESSING	94CN8790	761	198.9
330	423	CARANCAHUA	94CN5870	472	198.6
331	54	HARLINGEN SWITCH	94SB320	1,686	197.7
332	129	ARCADIA	94CS8570	1,448	197.2
333	476	IRAAN	97SA2055	135	197.0
334	15	BROOKHOLLOW	94CN7580	500	195.7
335	105	PROGRESO	94SB2515	210	195.3
336	563	OLMITO	94SB4275	818	195.3
337	205	SAN BENITO	94SB3920	1,651	195.2
338	806	CHOKE CANYON	94CN9255	367	194.3

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
339	181	GREENLAKE	94CN2750	73	193.1
340	912	POLK AVENUE	94SB4610	155	193.1
341	855	SOUTH SANTA ROSA	94SB1215	1,717	193.0
342	241	PAULANN	97SA6285	69	192.8
343	385	PHARAOH	94CS1285	1,776	192.6
344	109	SHAFTER	97SA5110	47	192.4
345	694	FREER	94LA5200	1,013	192.1
346	1223	DARST	94CN1610	66	191.2
347	1053	EL GATO	94SB780	2,161	190.5
348	849	RUNGE	94CN3250	273	189.6
349	206	SOUTHSIDE	94CS8025	1,147	188.7
350	763	VERNON	97AB4275	593	186.8
351	484	EL GATO	94SB910	2,605	186.6
352	1219	HIGHLAND	97SA6370	270	185.9
353	537	NIXON	94CN3300	594	185.6
354	354	WEST MCALLEN	94SB4815	568	185.5
355	219	CRYSTAL CITY	94LA1425	1,193	185.0
356	428	UNIVERSITY	94LA950	1,737	184.6
357	150	HOLLY	94CS7740	2,209	183.9
358	1229	CHARLOTTE	94LA8120	240	183.4
359	101	EAGLE PASS CITY	94LA2510	709	183.4
360	852	HEARN ROAD	94CS8980	1,255	182.5
361	487	NORTH MCALLEN	94SB3830	1,415	181.8
362	882	HAINE DRIVE	94SB9690	633	180.4
363	518	EAGLE LAKE	94CN310	740	180.2
364	651	CHASE FIELD	94CN460	17	180.2
365	1002	HAWLEY	97AB4455	672	180.1
366	384	BROWNSVILLE	94SB3050	2,010	179.4
367	82	PLEASANTON	94LA2080	1,742	179.2
368	322	VALADEZ	94CS9890	1,908	179.1
369	723	PALMVIEW	94SB3930	1,163	178.9
370	289	CONTINENTAL	94SB4080	66	178.7
371	989	WESMER	94SB9705	938	178.5
372	331	BIG WELLS	94LA1570	430	178.3
373	402	BISHOP	94CS7180	929	177.4
374	16	VILLA CAVAZOS	94SB1980	1,834	177.3
375	325	PLEASANTON	94LA9475	1,367	177.2
376	1217	HIGHWAY 9	94CS6720	1,275	176.7
377	127	AB SHELTON ST	97AB3435	295	175.8
378	991	HIGHWAY 9	94CS6730	546	175.4
379	717	HAINE DRIVE	94SB9700	1,166	175.1
380	539	KNIPPA	94LA6365	338	174.8
381	1062	EAST HARRISON	94SB3950	788	174.4
382	400	NORTH WESLACO	94SB4810	1,522	174.2
383	173	THREE RIVERS	94CN2010	313	174.0
384	614	PALMHURST	94SB2530	2,755	173.7
385	381	MILO	94LA3070	1,966	173.0
386	595	HAMLIN SHELL	97AB6330	26	172.7
387	1107	PALACIOS	94CN6840	1,540	172.0

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
388	836	PUTNAM	97AB2131	123	172.0
389	1285	DILLEY	94LA510	560	170.1
390	827	VICTORIA POWER PLANT	94CN7600	164	169.9
391	901	ABILENE PLANT	97AB1575	608	169.8
392	1160	TRUSCOTT	97AB3845	31	169.0
393	527	WAGGONER	97AB5900	27	168.9
394	343	HARLINGEN SWITCH	94SB4230	1,362	167.2
395	765	SA MATHIS FIELD	97SA4790	194	166.3
396	675	JOURDANTON	94LA250	770	166.3
397	292	MERKEL	97AB1895	709	165.7
398	305	GATEWAY	94LA3595	1,503	165.6
399	774	BONNIEVIEW	94CS8020	544	165.6
400	356	ELDORADO	97SA2880	354	165.2
401	1191	MAYBERRY	94SB5340	39	164.7
402	161	GRAYBACK	97AB3315	46	164.7
403	232	BEEVILLE	94CN8090	1,386	164.6
404	499	PAULANN	97SA6280	331	164.0
405	751	MCCOLL ROAD	94SB4910	335	163.8
406	687	HARLINGEN SWITCH	94SB4090	2,347	163.7
407	840	KNOX CITY	97AB3390	380	163.6
408	682	BEEVILLE	94CN1760	1,838	163.1
409	642	CHRISTOVAL	97SA6615	460	163.0
410	1113	CLARKWOOD	94CS9570	1,234	162.8
411	213	POLK AVENUE	94SB4180	1,298	162.7
412	556	ALPINE 12KV	97SA3160	1,642	162.1
413	202	SA NORTH	97SA3125	1,387	161.9
414	269	WEST MCALLEN	94SB6385	243	161.1
415	496	BENTSEN	94BSBH115	342	160.9
416	634	STERLING CITY	97SA1445	381	160.5
417	677	PHARR	94SB1640	1,456	160.2
418	178	CROSS PLAINS	97AB1795	434	159.1
419	210	CABANISS	94CS240	1,408	157.8
420	440	GOODWIN	94SB4380	1,668	157.1
421	839	MORRIS STREET	94CS7465	743	157.1
422	602	WESLACO UNIT	94SB7455	1,235	156.7
423	188	RISING STAR	97AB5075	688	156.1
424	689	POLK AVENUE	94SB4190	1,726	155.4
425	220	RIO GRANDE CITY	94SB3230	2,702	155.3
426	96	GREENLAKE	94CN2760	1,189	155.0
427	509	FT CHADBOURNE	97SA6520	553	154.8
428	1082	MORRIS STREET	94CS2515	1,017	154.8
429	438	PLEASANTON	94LA120	1,233	154.0
430	300	TAFT	94CS1180	957	153.9
431	409	UVALDE	94LA540	1,969	153.2
432	1007	STADIUM	94LA7800	686	152.8
433	228	DEVINE	94LA7090	1,070	152.4
434	1194	SOUTH SANTA ROSA	94SB1225	867	152.2
435	424	BISHOP	94CS2690	641	152.1
436	695	BROWNSVILLE	94SB4290	492	151.6

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
437	357	HARLINGEN SWITCH	94SB4110	912	150.6
438	1071	CLYDE	97AB1760	464	150.5
439	905	SILVER	97SA4295	15	150.3
440	468	SAND CRAB	94CN6800	1,126	149.4
441	970	LAGUNA	94CS9590	2,325	149.4
442	968	MESA VIEW	97SA7045	93	147.7
443	328	BEEVILLE	94CN8510	828	147.6
444	464	JUNCTION	97SA10805	816	147.1
445	1156	CITRUS CITY	94SB3470	1,776	146.6
446	279	CROSS PLAINS	97AB2915	779	146.6
447	658	MUSTANG ISLAND	94CS8510	516	146.4
448	925	LIVE OAK	94CS1070	2,568	145.8
449	408	THROCKMORTON	97AB2090	75	144.8
450	106	SOUTH EAST EDINBURG	94SB4550	727	144.7
451	376	FRIO	94LA2270	990	144.6
452	29	VICTORIA POWER PLANT	94CN8170	842	144.5
453	1134	PHARR	94SB1625	1,210	144.2
454	665	UVALDE	94LA6620	2,158	144.0
455	170	ALPINE 12KV	97SA3155	1,357	143.6
456	813	PICACHO	94LA1230	1,052	143.3
457	571	HOLLY	94CS7620	2,703	142.9
458	309	PORT ARANSAS	94CS1000	1,611	142.6
459	792	WEST MCALLEN	94SB4505	1,908	141.2
460	469	RUSSEK STREET	97SA250	143	140.5
461	240	ROBSTOWN	94CS1650	354	140.4
462	199	BROWNSVILLE	94SB4280	325	139.9
463	1003	SOUTH SANTA ROSA	94SB7485	1,235	139.0
464	344	NORDHEIM	94CN3380	174	138.9
465	666	WESMER	94SB4050	1,954	138.6
466	801	LAREDO PLANT	94LA8695	1,551	138.5
467	1000	SANTO NINO	94LA515	1,174	138.4
468	834	CARRIZO SPRINGS	94LA910	872	138.4
469		MCCOLL ROAD	94SB4780	2,021	137.8
470	604	CRYSTAL CITY	94LA8380	1,340	137.5
471	643	STADIUM	94LA7810	1,324	137.4
472	1001	NORTH MCALLEN	94SB2980	1,885	137.2
473	1005	DEVINE	94LA8100	1,647	136.5
474	1030	CAMPWOOD	94LA3430	123	136.5
475	719	SONORA 138 SUB	97SA4805	347	135.8
476	669	DEVINE	94LA7100	1,118	135.5
477	163	BAIRD	97AB5125	511	134.4
478	859	AIRLINE	94CS7280	645	134.0
479	728	SAN BENITO	94SB4030	1,707	133.9
480	1125	MCCOLL ROAD	94SB4790	2,088	133.9
481	519	BEEVILLE	94CN300	1,676	132.4
482	652	LAGUNA	94CS9065	2,373	132.1
483	605	TYNAN	94CS4000	27	131.7
484	1211	PHARAOH	94CS5185	1,244	131.6
485	1047	HALL ACRES ROAD	94SB8870	2,509	131.5

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
486	569	SOUTHSIDE	94CS8035	1,086	131.3
487	314	SINTON	94CS1750	266	130.7
488	775	RODD FIELD	94CS205	2,184	130.5
489	691	BAY CITY	94CN5960	402	129.8
490	797	BLACK BAYOU	94CN1120	371	129.0
491	145	CLYDE	97AB3635	454	128.6
492	594	HAINE DRIVE	94SB8065	1,368	127.4
493		MATADOR	97AB3030	217	126.6
494	271	JOURDANTON	94LA7880	593	126.0
495	722	MUNDAY	97AB6715	257	125.7
496	644	KARNES CITY	94CN2315	1,026	125.5
497	713	CAUSEWAY	94SB4795	390	125.3
498	110	PANTERA	94SB1315	1,921	124.6
499	977	MAGRUDER	94CN7690	542	124.1
500	235	MORRIS STREET	94CS8715	1,587	123.8
501	869	DIMMIT	94LA4120	1,277	123.1
502	1147	AMISTAD DAM	94LA5450	782	123.0
503	715	HIGHWAY 9	94CS9830	133	122.2
504	413	EL GATO	94SB720	2,571	122.1
505	21	SA NORTH	97SA3115	586	121.9
506	789	CHRISTOVAL	97SA6620	655	121.2
507	200	HEINES	94CS7875	1,951	120.6
508	971	HOLLY	94CS9675	1,776	120.2
509	132	POINT COMFORT	94CN6060	369	120.1
510	194	PECAN BAYOU	97AB6815	2,092	120.1
511	967	RUSSEK STREET	97SA7705	1,331	119.7
512	962	PETTUS	94CN1020	456	119.5
513	1239	MORRIS STREET	94CSBLACK	82	119.4
514	1090	BUENA VISTA	94LA9035	2,048	119.3
515	1139	FULTON	94CS3070	1,589	119.0
516	1138	ARMSTRONG	94CS6050	85	118.7
517	1112	YORKTOWN	94CN8420	669	118.5
518	1286	TUSCOLA	97AB3730	1,215	118.4
519	1136	KINGSVILLE	94CS1660	1,981	118.2
520	270	ANSON 12KV	97AB6635	414	117.5
521	369	MCCAMEY	97SA2855	508	117.4
522	662	GOLIAD	94CN8220	1,056	116.7
523	606	AB ELM CREEK	97AB4745	902	116.0
524	1204	PORTLAND	94CS6505	1,826	115.8
525	507	VILLA CAVAZOS	94SB5680	1,983	115.6
526	796	GARCENO	94SB2130	1,821	115.5
527	1095	EL GATO	94SB890	3,108	115.3
528	922	KINGSVILLE	94CS1130	2,226	115.2
529	764	MCKENZIE ROAD	94CS150	26	115.2
530	1119	SA GRAPE CREEK	97SA5220	716	114.6
531	931	ROCKPORT	94CS5930	944	114.6
532	1178	BANQUETTE	94CS130	231	114.4
533	934	ARCADIA	94CS1400	443	114.2
534	1282	NORTH VICTORIA	94CN7430	1,685	114.2

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
535	248	ARANSAS PASS	94CS650	1,192	113.8
536	1024	AB ONYX REA	97AB3260	148	113.8
537	1206	SA SOUTHLAND HILLS	97SA5455	1,428	113.6
538	19	AB SHELTON ST	97AB3660	638	113.1
539	1016	BUENA VISTA	94LA8965	919	113.0
540	1195	CHARLOTTE	94LA1960	506	112.8
541	973	MORRIS STREET	94CSYELLOW	44	112.5
542	420	EAST HARRISON	94SB4310	1,205	112.4
543	193	MORRIS STREET	94CSGREEN	235	112.3
544	395	FT DAVIS	97SA4515	1,013	111.5
545	520	ABILENE PLANT	97AB1570	959	111.4
546	555	MORRIS STREET	94CSRED	148	111.1
547	1049	KENEDY S.S.	94CN8340	307	110.0
548	766	KITTIE WEST	94CN3760	240	109.9
549	943	LA PRYOR	94LA2440	194	109.8
550	846	NAVAL BASE	94CS8540	1,624	109.4
551	552	AFTON	97AB2310	246	109.3
552	1224	COTULLA	94LA460	502	108.7
553	454	MORRIS STREET	94CS7625	513	108.7
554	196	SOUTH MISSION	94SB3620	2,110	108.3
555	873	ANSON 12KV	97AB6630	718	108.1
556	1088	GOVERNMENT WELLS	94LA6800	230	107.9
557	1029	UNITEC	94LA4715	40	107.9
558	1148	KINGSVILLE	94CS1670	426	107.9
559	558	AIRLINE	94CS9605	713	107.6
560	578	HASKELL 12KV	97AB3770	459	107.5
561	1142	KLEBERG	94CS1560	1,472	107.4
562	1094	MILO	94LA8365	2,123	107.3
563	600	SOUTHSIDE	94CS7905	1,828	107.1
564	1	SA LAKE DR	97SA6030	761	106.9
565	564	REFUGIO	94CN1210	190	106.7
566	697	BANDERA ELECTRIC (LEAKEY)	94LAL30	271	106.6
567	598	FULTON	94CS9050	1,576	106.1
568	120	SOUTH MCALLEN	94SB5065	175	105.9
569	1031	DEL RIO CITY	94LA9850	1,037	104.5
570	207	BEN FICKLIN	97SA6175	599	104.2
571	397	AIRLINE	94CS8260	1,421	104.0
572	622	HARLINGEN SWITCH	94SB5350	965	103.7
573	940	HEIGHTS	94LA6820	1,944	103.7
574	904	WEST OSO	94CS9095	1,659	103.6
575	566	HAINE DRIVE	94SB3490	1,193	103.5
576	477	MORRIS STREET	94CSBROWN	67	103.4
577	73	HASKELL 12KV	97AB5240	650	103.3
578	650	EAGLE LAKE	94CN320	629	103.3
579	177	ARCADIA	94CS1460	2,455	103.3
580	493	AFTON	97AB2355	45	103.0
581	100	AIRLINE	94CS5870	1,008	102.9
582	295	BUENA VISTA	94LA9385	892	102.8
583	1017	RODD FIELD	94CS1730	2,211	102.8

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
584	1010	WEST HARLINGEN	94SB3800	1,423	102.2
585	1077	PAULANN	97SA6310	1,086	102.2
586	916	NIXON	94CN2025	539	102.1
587	1196	LAREDO PLANT	94LA8505	1,053	101.5
588	1135	AFTON	97AB2225	54	101.0
589	1250	TURKEY	97AB3825	388	100.6
590	217	HAMILTON ROAD	94LA9665	1,258	100.4
591	450	LEARY LANE	94CN7530	3,171	100.2
592	508	MAYBERRY	94SB6450	28	99.8
593	1209	VICTORIA POWER PLANT	94CNVGREEN	29	99.4
594	969	SOUTHSIDE	94CS7955	1,067	99.2
595	565	RACHAL	94LA6595	339	99.0
596	247	RULE	97AB3396	440	99.0
597	1158	RULE	97AB3378	106	98.8
598	162	THROCKMORTON	97AB3190	645	98.6
599	641	DEL RIO CITY	94LA4440	1,115	98.6
600	632	COFFEE PORT	94SB1090	1,257	97.9
601	513	ARANSAS PASS	94CS8270	412	97.5
602	512	LANTANA	94CS7150	271	97.5
603	461	ARANSAS PASS	94CS1250	661	97.4
604	941	HEARN ROAD	94CS9665	690	96.9
605	1133	SABINAL	94LA200	443	96.8
606	95	AB ELM CREEK	97AB4775	886	96.8
607	586	NORTH VICTORIA	94CN6390	1,510	96.7
608	1190	GATEWAY	94LA390	3,743	96.7
609	1164	SOUTH SANTA ROSA	94SB1240	1,704	96.5
610	1157	SANTA RITA	97SA1100	110	96.3
611	1074	CITRUS CITY	94SB6000	2,373	96.3
612	257	DEL RIO CITY	94LA9790	2,357	96.2
613	1060	REFUGIO	94CN1040	161	95.3
614	353	WEST HARLINGEN	94SB4870	1,072	95.2
615	1240	WEAVER ROAD	94CN1900	63	94.9
616	1265	JOURDANTON	94LA880	1,121	94.8
617	589	DEL MAR	94LA490	797	94.7
618	963	EAST HARRISON	94SB3190	1,489	93.8
619	1174	PEARSALL	94LA9905	435	93.3
620	6	ANNA STREET	94LA780	474	93.3
621	80	SUN VALLEY	97SA4300	69	93.3
622	1260	ESCONDIDO	94LA3350	2,283	93.0
623	623	UVALDE	94LA480	572	92.8
624		DEL MAR	94LA3440	1,807	92.8
625		BROOKHOLLOW	94CN7190	280	92.3
626	1043	WEST MCALLEN	94SB4555	1,619	92.2
627	983	HAINE DRIVE	94SB270	1,172	91.9
628	1254	ASHERTON	94LA5495	597	91.5
629	155	SAN DIEGO	94LA2890	1,019	91.0
630	1102	AB SHELTON ST	97AB4640	663	90.7
631	283	WESLACO UNIT	94SB2195	1,102	90.1
632	887	HALL ACRES ROAD	94SB3670	1,292	89.9

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
633	238	BALLINGER	97SA4375	1,130	89.7
634	1198	WEST MCALLEN	94SB4595	1,190	89.7
635	1271	READING	94LA1275	78	89.7
636	640	ALBANY	97AB3540	635	88.8
637	1238	ALAZAN	94CS2740	36	88.2
638	1278	GRETA	94CN7890	235	87.5
639	1241	PHARAOH	94CS5175	1,284	87.3
640	960	AB EAST 12KV	97AB4820	1,152	87.3
641	830	ABILENE PLANT	97AB1565	280	86.9
642	608	PANTERA	94SB1105	580	86.5
643	115	PHARAOH	94CS1185	1,414	86.4
644	1048	RAYMONDVILLE #1	94SB3130	307	86.4
645	1197	AIRLINE	94CS8370	274	85.7
646	1255	NORTH MCCAMEY	97SA6555	795	85.4
647	1259	CASA BLANCA	94CS1300	291	85.2
648	511	DONNA SKID	94SBTX_B	529	85.0
649	391	PHARAOH	94CS1365	684	84.9
650	935	COTULLA	94LA610	727	84.5
651	153	PORTLAND	94CS9270	1,810	84.2
652	1170	VICTORIA POWER PLANT	94CN8070	608	84.2
653	1045	PIRATE	94CS3220	741	84.0
654	403	CLARKWOOD	94CS7610	105	84.0
655	638	CARRIZO SPRINGS	94LA750	599	83.9
656	1080	MORRIS STREET	94CS8830	1,512	83.9
657	185	JOURDANTON	94LA5685	327	83.8
658	1050	PORT ISABEL S.S.	94SB4070	283	83.3
659	63	RIO GRANDE CITY	94SB3220	1,420	83.3
660	1274	NIXON	94CN6630	645	83.2
661	1203	MUNDAY REA (BKEC)	97AB2015	21	83.0
662	609	MOORE FIELD	94SB3110	720	83.0
663	312	ROTAN	97AB1860	686	82.3
664	899	JUNCTION	97SA10795	811	82.3
665	448	UVALDE	94LA5060	1,288	81.8
666	1177	WYLIE	97AB2665	1,090	81.7
667	828	LA GRULLA	94SB5005	1,215	80.7
668	211	HAMILTON ROAD	94LA9655	1,323	80.4
669	215	AB COUNTRY CLUB	97AB4735	122	80.4
670	9	RESACA	94SB8700	1,125	80.1
671	684	VICTORIA POWER PLANT	94CNVRED	44	80.0
672	810	VICTORIA POWER PLANT	94CNVBROWN	16	80.0
673	503	NORTH VICTORIA	94CN1580	1,049	79.6
674	31	LEARY LANE	94CN1890	1,625	79.4
675	1182	NORTH MCALLEN	94SB5055	3,319	79.1
676	756	EAGLE PASS CITY	94LA7060	871	78.5
677	360	SEAWALL	94CS9450	299	77.8
678	646	ZACATE CREEK	94LA2635	975	77.6
679	748	PETTUS	94CN8210	346	77.5
680	1218	ANNA STREET	94LA2250	1,557	77.0
681	287	POLK AVENUE	94SB4740	1,718	76.9

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
682	495	YORKTOWN	94CN8380	780	76.6
683	703	BROOKHOLLOW	94CN8950	922	76.3
684	760	WINTERS	97SA3765	824	76.2
685	374	STAMFORD PUMP	97AB3930	37	75.7
686	1127	KLEIMANN	94CN565	582	75.2
687	149	MAYBERRY	94SB1790	1,090	74.8
688	298	PECAN BAYOU	97AB6810	467	74.7
689	803	MOCKINGBIRD	94CN400	1,015	74.5
690	1085	AB SHELTON ST	97AB3040	179	73.5
691	486	ROCKPORT	94CS5130	566	73.5
692	457	MOCKINGBIRD	94CN305	329	73.2
693	915	CLARKWOOD	94CS7220	931	73.1
694	458	MEDIO CREEK	94CN1380	810	72.9
695	316	BROOKHOLLOW	94CN8960	595	72.8
696	872	MORAN	97AB2108	304	72.8
697	433	WEST MCALLEN	94SB4965	967	72.6
698	825	CONTINENTAL	94SB3650	14	72.5
699	1162	AB WALNUT ST	97AB3445	56	72.4
700	244	WASHINGTON STREET	94LA6525	2,740	72.2
701	980	CATARINA	94LA2380	187	71.9
702	546	KLEBERG	94CS8140	643	71.9
703	378	BEEVILLE	94CN2380	219	71.7
704	405	EL CAMPO	94CN7710	1,074	71.2
705	880	READING	94LA1445	533	71.2
706	702	GARCENO	94SB2135	1,543	71.0
707	636	BLACK CAT	94CN4525	114	70.9
708	303	CRYSTAL CITY	94LA7425	444	70.6
709	670	AB HARTFORD ST	97AB3815	1,114	70.5
710	383	MOORE FIELD	94SB3960	2,191	70.5
711	673	PRIMERA	94SB6085	1,462	70.5
712	319	AB OVER STREET 12KV	97AB1840	888	70.3
713	1004	RUNGE	94CN4465	361	70.3
714	918	AB VOGEL ST	97AB4410	764	70.1
715	327	ANNA STREET	94LA900	2,843	69.8
716	1159	ROWENA	97SA4480	231	69.7
717	442	BEEVILLE	94CN2200	722	69.6
718	817	IRAAN	97SA2050	389	69.0
719	152	AB OVER STREET 12KV	97AB3140	686	68.9
720	426	SOUTH EAST EDINBURG	94SB6580	939	68.8
721	772	HOMEPORT	94CS4665	429	68.8
722	992	ARCADIA	94CS1360	1,539	68.8
723	898	AB MCMURRY	97AB4350	707	68.2
724	958	PEARSALL	94LA7050	581	68.2
725	453	ARCADIA	94CS5020	1,544	68.0
726	829	MORAN	97AB2107	208	67.8
727	432	SUNCHASE	94SB1155	1,433	67.7
728	847	MAGRUDER	94CN245	1,248	67.6
729	425	SOUTH PADRE ISLAND	94SB6440	2,590	67.5
730	335	AB SHELTON ST	97AB3045	550	67.3

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
731	102	UVALDE	94LA550	746	67.1
732	626	NORTH MCALLEN	94SB2750	3,182	66.9
733	590	YOUNG	94SB5135	1,288	66.8
734	268	HIGHWAY 9	94CS6780	754	66.7
735	345	GEORGE WEST	94CN730	907	66.4
736	99	AB OVER STREET 12KV	97AB1635	528	66.3
737	907	HEINES	94CS2185	1,257	66.1
738	179	HIGHWAY 9	94CS7200	655	66.0
739	1207	PHARR	94SB1645	1,728	66.0
740	389	CRESTONIO	94LA6660	790	66.0
741	154	VERNON	97AB1520	723	65.9
742	1179	SA GRAPE CREEK	97SA5365	857	65.7
743	921	LAREDO PLANT	94LA8705	172	65.5
744	223	YELLOW JACKET	97SA5505	539	65.5
745	955	WESLACO UNIT	94SB8610	1,194	65.4
746	863	STAFFORD HILL	94CN1550	144	65.1
747	164	SEAWALL	94CS9420	818	65.1
748	630	BRONTE AMBASSADOR	97SA6650	14	64.8
749	234	SAN DIEGO	94LA1980	628	64.5
750	914	WESMER	94SB7760	1,464	64.5
751	140	TAYLOR	94BSBH111	711	64.3
752	938	STADIUM	94LA7490	1,307	64.3
753	947	CITRUS CITY	94SB7985	1,211	64.2
754	195	AB OVER STREET 12KV	97AB1645	796	63.7
755	809	YOUNG	94SB4435	826	63.3
756	683	MILO	94LA3065	28	63.2
757	831	HOLCOMB	94LA2240	458	63.1
758	937	SOUTH EAST EDINBURG	94SB5045	1,783	63.1
759	767	AB MCMURRY	97AB4360	1,100	62.9
760	888	CHOKE CANYON	94CN5390	412	62.6
761	619	SAN DIEGO	94LA2880	1,335	62.2
762	1221	ELDORADO	97SA5310	189	61.9
763	580	REFUGIO	94CN5120	726	61.8
764	1152	NORTH EDINBURG	94SB560	2,199	61.7
765	108	ODEM	94CS2400	315	61.3
766	897	SA EMERSON ST	97SA4620	431	61.2
767	414	CEDAR GAP (TEC)	97AB4115	972	61.0
768	167	WEAVER ROAD	94CN1910	27	60.4
769	596	RESACA	94SB7110	1,730	59.9
770	893	CITRUS CITY	94SB9775	1,599	59.5
771	418	COLLEGE HILLS	97SA5520	432	59.4
772	793	BEN FICKLIN	97SA6180	563	59.3
773	709	THREE RIVERS	94CN2580	119	59.3
774	896	RIO GRANDE CITY	94SB3740	2,390	59.3
775	725	SANTA RITA	97SA1105	68	58.8
776	657	PREMONT	94LA2720	776	58.5
777	664	ARCADIA	94CS5030	1,578	58.1
778	777	STADIUM	94LA8540	1,695	58.1
779	339	EDNA	94CN5785	1,258	58.1

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
780	456	HARLINGEN	94SB370	1,236	57.9
781	478	AB MCMURRY	97AB3245	795	57.6
782	160	BEEVILLE	94CN490	952	57.3
783	824	PANTERA	94SB1765	881	57.1
784	676	NORDHEIM	94CN4275	80	56.9
785	727	FALFURRIAS	94LA1070	937	56.7
786	480	CLOSNER	94SB4100	2,086	56.7
787	616	RAYMONDVILLE #2	94SB3240	919	56.6
788	282	AB MCMURRY	97AB3240	766	56.1
789	75	WEST MCALLEN	94SB4515	867	56.0
790	97	RUSSEK STREET	97SA11370	200	56.0
791	1013	CHILDRESS 20TH ST	97AB5720	186	55.9
792	1176	CARANCAHUA	94CN1875	59	55.7
793	787	HEARN ROAD	94CS2220	1,731	55.5
794	543	FRIO	94LA1815	1,069	55.1
795	436	CABANISS	94CS820	1,304	55.0
796	470	DARST	94CN1845	184	54.9
797	549	KLEBERG	94CS6410	247	54.5
798	738	GONZALES	97SA14685	1,328	54.4
799	667	LAREDO PLANT	94LA8565	1,440	54.3
800	805	SINTON	94CS360	335	54.0
801	348	RAYMONDVILLE #2	94SB1280	989	53.9
802	1020	SOUTHSIDE	94CS8005	744	53.6
803	786	MAGRUDER	94CN6690	756	53.6
804	1034	ABILENE PLANT	97AB1735	84	53.2
805	576	PECAN BAYOU	97AB530	18	53.2
806	417	JOURDANTON	94LA8725	30	53.0
807	837	INGLESIDE CITY	94CS2495	273	53.0
808	843	BAY CITY	94CN1110	1,237	52.9
809	911	CARRIZO SPRINGS	94LA370	550	52.9
810	20	MILO	94LA5020	113	52.8
811	841	CASA BLANCA	94CS4170	1,158	52.6
812	781	GATEWAY	94LA350	2,017	52.4
813	952	ASPR CONTINENTAL	97AB4800	32	52.2
814	1281	LA GRULLA	94SB5110	1,030	52.1
815	411	WESMER	94SB6900	51	52.1
816	1059	HALL ACRES ROAD	94SB3460	3,201	51.7
817	1023	CABANISS	94CS80	98	51.7
818	860	YOUNG	94SB3310	1,873	51.6
819	591	EL CAMPO	94CN7260	537	51.4
820	822	OLMITO	94SB905	1,677	51.3
821	24	AB RAINEY CREEK	97AB4220	219	51.2
822	297	BENTSEN	94BSBH215	55	51.1
823	858	NORTH EDINBURG	94SB3570	1,051	51.1
824	1008	KENEDY	94CN1970	567	50.9
825	701	PALMVIEW	94SB9685	2,957	50.8
826	336	HOLLY	94CS1370	1,886	50.4
827	674	EAST HARRISON	94SB3030	678	50.3
828	439	MCCOLL ROAD	94SB1655	1,513	49.9

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
829	618	CEDAR GAP (TEC)	97AB5445	506	49.9
830	879	MILO	94LA3060	129	49.7
831	716	AB MCMURRY	97AB4355	989	49.6
832	142	SA WALNUT ST	97SA3920	901	49.5
833	431	SAN BENITO	94SB3860	258	49.5
834	246	MCCOLL ROAD	94SB5485	1,077	49.3
835	744	KITTIE WEST	94CN3765	323	49.3
836	315	AB CANYON ROCK	97AB5030	699	49.2
837	721	PANTERA	94SB1915	1,195	49.0
838	1081	BARNHART	97SA590	18	48.9
839	799	SA GRAPE CREEK	97SA4700	749	48.8
840	857	AB COUNTRY CLUB	97AB4730	542	48.8
841	739	EL CAMPO	94CN2860	1,517	48.6
842	471	HEIGHTS	94LA2450	2,042	48.3
843	1021	HOLLY	94CS1950	838	47.9
844	37	HALL ACRES ROAD	94SB9595	1,588	47.5
845	535	AB ELM CREEK	97AB5045	384	47.4
846	939	VERHALEN	97SA4465	36	47.2
847	410	AIRLINE	94CS6970	1,401	47.2
848	655	SAND CRAB	94CN6735	1,321	47.0
849	909	CLYDE	97AB3630	438	46.9
850	175	CRYSTAL CITY	94LA2170	747	46.9
851	1173	ARANSAS PASS	94CS9130	460	46.5
852	45	AIRLINE	94CS8890	526	46.3
853	585	GREGORY	94CS420	467	46.2
854	30	SANTO NINO	94LA75	1,515	46.0
855	318	ODEM	94CS5575	80	45.9
856	288	ENCINAL	94LA2160	231	45.9
857	444	ALPINE 12KV	97SA6825	1,806	45.9
858	617	MARKHAM	94CN6440	470	45.8
859	753	NORTH VICTORIA	94CN7440	1,643	45.8
860	842	SARAGOSA	97SA1552	780	45.5
861	771	SHARYLAND	94SB6745	2,320	45.1
862	536	PALMVIEW	94SB7595	3,225	45.1
863	1193	SHEFFIELD	97SA6430	209	44.7
864	502	MCKENZIE ROAD	94CS330	2,406	44.7
865	68	SKIDMORE	94CS600	365	44.5
866	1108	ALICE	94LA1780	510	44.5
867	1055	AIRLINE	94CS9030	403	44.4
868	647	PONDER KENNEDY	97SA50208	13	44.4
869	811	ELSA	94SB690	2,419	44.4
870	845	CABANISS	94CS710	175	44.3
871	459	SHARYLAND	94SB5105	2,042	44.3
872	575	MINES ROAD	94LA4275	252	44.2
873	1098	CHILDRESS 69	97AB1480	303	43.9
874	11	AB REBECCA LANE	97AB5555	1,268	43.6
875	430	PROGRESO	94SB2495	1,696	43.1
876	1153	GREGORY	94CS2420	913	42.9
877	66	LEARY LANE	94CN6005	1,386	42.8

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
878	917	WESLACO UNIT	94SB8195	1,667	42.7
879	386	LAREDO PLANT	94LA9305	1,066	42.6
880	1032	SA COKE ST	97SA3905	653	42.6
881	137	COLLEGE HILLS	97SA6145	981	42.5
882	1118	RANKIN	97SA5735	187	42.3
883	139	STAMFORD	97AB2835	100	42.2
884	359	EAGLE PASS CITY	94LA2650	1,384	42.1
885	94	ESCONDIDO	94LA5730	2,759	42.0
886	412	SOUTH PADRE ISLAND	94SB4675	197	41.8
887	649	BALLINGER	97SA4370	777	41.8
888	229	AB OIL MILL	97AB2780	747	41.7
889	823	MERKEL	97AB1890	575	41.7
890		PUEBLO	94LA130	1,764	41.6
891	434	KLEIMANN	94CN425	612	41.6
892	581	SA SOUTH	97SA2595	1,070	41.3
893	573	AB SHELTON ST	97AB3050	649	41.0
894	1044	MESQUITE	94SB2900	948	40.8
895	816	KLEBERG	94CS6000	1,408	40.8
896	134	SPUR	97AB5170	383	40.7
897	340	PALMHURST	94SB2535	3,048	40.6
898	779	QUANAH	97AB3100	557	40.4
899	930	SAND CRAB	94CN8390	532	40.1
900	876	WEST MCALLEN	94SB4535	3,068	40.0
901	679	FULTON	94CS6070	1,817	39.7
902	398	SANTA ANNA	97SA3420	367	39.4
903	844	ANNA STREET	94LA850	1,559	39.4
904	8	GARCENO	94SB2165	1,973	39.4
905	1279	MILO	94LA6940	467	39.4
906	788	YOUNG	94SB7145	1,810	39.3
907	157	HOLLY	94CS5820	903	39.3
908	637	EAST HARRISON	94SB4360	1,769	39.2
909	350	AB ELM CREEK	97AB1815	388	39.1
910	1167	HARLINGEN	94SB360	2,434	39.0
911	416	GOVERNMENT WELLS	94LA7250	566	38.8
912	332	AB SHELTON ST	97AB3060	1,584	38.7
913	735	ROCKPORT	94CS5940	64	38.5
914	347	CARRIZO SPRINGS	94LA860	31	38.4
915	949	PALMHURST	94SB2525	2,328	38.1
916	936	MIDWAY LANE	97SA3440	58	38.1
917	483	NORTH MCALLEN	94SB5060	2,634	38.0
918	769	SA JACKSON ST	97SA4265	799	38.0
919	362	VALADEZ	94CS3140	1,977	37.9
920	250	AB CANYON ROCK	97AB5035	823	37.9
921	88	SA SOUTHLAND HILLS	97SA5050	890	37.7
922	3	ANSON REA (SEC)	97AB5215	259	37.6
923	780	TANKERSLY (CVEC)	97SA5265	381	37.5
924	1154	VERHALEN	97SA14765	27	37.0
925	957	POWELL FIELD	97SA2528	23	36.8
926	1061	AB OIL MILL	97AB3900	690	35.8

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
927	838	TANKERSLY (CVEC)	97SA5260	479	35.8
928	890	AB DYESS 2	97AB6335	352	35.8
929	1122	BAY CITY	94CN2050	329	35.8
930	877	AB ONYX REA	97AB3255	23	35.4
931	678	LAS CRUSES	94LA7325	2,761	35.3
932	870	NORTH EDINBURG	94SB4240	1,151	34.9
933	1129	NORTH VICTORIA	94CN1470	481	34.8
934	927	SOUTH EAST EDINBURG	94SB4015	448	34.6
935	944	ESPY WELLS	97SA50207	31	34.6
936	1058	KARNES CITY	94CN2325	665	34.5
937	996	WYLIE	97AB6340	779	34.4
938	1184	TRENT	97AB4245	183	34.4
939	663	WESLACO UNIT	94SB9805	2,269	34.3
940	540	VERNON	97AB3340	534	34.1
941	561	MAGRUDER	94CN6680	701	34.1
942	624	YELLOW JACKET	97SA7935	810	33.9
943	798	SOUTH MISSION	94SB3590	556	33.7
944	500	EL CAMPO	94CN5745	941	33.7
945	714	TWILIGHT TRAIL	97AB5855	257	33.7
946	1063	AILEEN	97AB4605	429	33.4
947	443	SHARYLAND	94SB2150	895	32.9
948	371	BUSH KNOB	97AB5200	303	32.9
949	233	RODD FIELD	94CS3010	2,068	32.5
950	579	WYLIE	97AB2675	820	32.3
951	978	BIG WELLS	94LA2630	30	32.2
952	597	HEIGHTS	94LA2100	1,991	32.1
953	407	SHARYLAND	94SB5635	2,311	31.7
954	286	AB WALNUT ST	97AB3785	574	31.7
955	593	SANTO NINO	94LA70	3,113	31.6
956	1018	HALL ACRES ROAD	94SB4895	882	31.6
957	1171	SONORA	97SA2045	202	31.5
958	372	LA GRULLA	94SB4120	1,532	31.3
959	881	QUANAH	97AB1830	627	31.3
960	903	ZAPATA	94LA7330	1,375	31.3
961	466	MORRIS STREET	94CS8840	637	31.2
962	472	WASHINGTON STREET	94LA6355	949	31.2
963	1149	YOUNG	94SB6140	2,536	31.1
964	465	ROCKSPRINGS	94LA2600	368	31.1
965	203	MAGRUDER	94CN6700	1,374	31.1
966	964	ASHLAND	94SB3H301	14	30.9
967	174	CHILDRESS 69	97AB1800	543	30.7
968	1011	GILA	94CS7840	770	30.6
969	252	RAYMONDVILLE #2	94SB5875	28	30.5
970	473	WASHINGTON STREET	94LA7015	1,545	30.5
971	1186	AB RAINEY CREEK	97AB4550	988	30.4
972	1106	DUST DEVIL	94LA1380	42	30.3
973	961	POLK AVENUE	94SB4520	1,068	30.3
974	259	AIRLINE	94CS9390	1,352	30.3
975	415	AB EAST 12KV	97AB5760	215	30.1

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
976	749	JOURDANTON	94LA5695	323	30.1
977	277	CLARKWOOD	94CS2170	795	30.0
978	380	LEARY LANE	94CN6175	2,483	29.9
979	1072	NORTH VICTORIA	94CN2240	746	29.8
980	538	SAN BENITO	94SB3910	680	29.6
981	832	WYLIE	97AB6495	362	29.5
982	861	MERTZON (CVEC)	97SA1530	338	29.3
983	504	UNIVERSITY	94LA465	931	29.0
984	854	VERNON	97AB1750	246	28.9
985	951	WASHINGTON STREET	94LA2360	204	28.8
986	1188	HARLINGEN	94SB660	1,270	28.6
987	1175	SA WALNUT ST	97SA3925	894	28.4
988		QUANAH	97AB100	89	28.2
989	1084	AB VOGEL ST	97AB4560	1,477	28.1
990	850	REFUGIO	94CN1170	864	28.0
991	784	MUSTANG ISLAND	94CS9470	790	28.0
992	204	DUST DEVIL	94LA1495	2,026	27.3
993	621	RANKIN	97SA6405	360	27.1
994	1038	RAYMONDVILLE #1	94SB800	740	27.1
995	117	HEIGHTS	94LA9400	1,470	27.0
996	1103	EDITH HUMBLE	97SA6170	83	27.0
997	884	AB ELMDALE	97AB4085	46	26.9
998	981	GILA	94CS345	69	26.8
999	379	TWILIGHT TRAIL	97AB3150	724	26.7
1000	221	DEL MAR	94LA2120	1,346	26.7
1001	392	BAY CITY	94CN6450	164	26.7
1002	1131	TATTON	94CS8200	1,225	26.7
1003	990	EL CAMPO	94CN6370	776	26.6
1004	1052	MARKHAM	94CN5550	20	26.6
1005	639	PALMHURST	94SB1300	2,280	26.2
1006	5	DUST DEVIL	94LA1810	478	26.1
1007	114	DEL MAR	94LA7930	1,981	26.1
1008	266	AB COUNTRY CLUB	97AB4725	230	25.8
1009	1051	ALICE	94LA2540	963	25.8
1010	696	BRONTE	97SA3590	194	25.8
1011	826	KENEDY S.S.	94CN8320	142	25.8
1012	25	SA LAKE DR	97SA5865	1,062	25.8
1013	361	STADIUM	94LA6950	427	25.7
1014	984	SOUTH MISSION	94SB3940	877	25.6
1015	1025	AB MCMURRY	97AB3235	781	25.6
1016	574	MAYO	94CS500	26	25.6
1017	953	ZACATE CREEK	94LA2675	1,216	25.5
1018	334	PORT ARANSAS	94CS3030	955	25.4
1019	572	SOUTH MISSION	94SB5215	1,241	25.2
1020	46	HEIGHTS	94LA2390	1,722	24.8
1021	1227	BENJAMIN (BEPC)	97AB5680	165	24.8
1022	577	CLOSNER	94SB2945	1,101	24.6
1023	1115	WASHINGTON STREET	94LA2350	3,052	24.5
1024	524	KENEDY	94CN6270	546	24.5

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
1025	1165	CLOSNR	94SB6430	1,028	24.4
1026	447	DILLEY	94LA6400	873	24.2
1027	568	RANKIN	97SA6400	60	24.1
1028	1121	LA GRULLA	94SB6150	1,735	24.1
1029	1212	SHARYLAND	94SB2035	853	24.0
1030	1233	SOUTH MISSION	94SB3980	1,937	23.9
1031	1248	PRIMERA	94SB7020	1,484	23.9
1032	942	ROMA	94SB3070	904	23.9
1033	755	RIO GRANDE CITY	94SB3210	1,991	23.5
1034	1037	HAMILTON ROAD	94LA9645	298	23.4
1035	659	CHILDRESS 69	97AB4865	777	23.3
1036	1099	WINTERS	97SA2113	801	23.3
1037	1151	MESQUITE	94SB8340	759	23.0
1038	1035	SA EMERSON ST	97SA4625	421	22.6
1039	724	MAYBERRY	94SB3010	347	22.5
1040	1185	SPUR	97AB300	204	22.4
1041	762	ROARING SPRINGS	97AB2065	217	22.4
1042	522	SOUTH MCALLEN	94SB3790	1,468	22.3
1043	281	SA SOUTH	97SA3995	795	22.3
1044	1228	KINGSVILLE	94CS1350	396	22.3
1045	730	TRADE ZONE	94SB2060	513	22.0
1046	633	VALADEZ	94CS8800	1,690	21.7
1047	218	PAINT ROCK	97SA5235	140	21.6
1048	1066	SONORA ATLANTIC (SWTEC)	97SA4415	31	21.5
1049	974	POLK AVENUE	94SB4600	160	21.4
1050	254	LANTANA	94CS4095	195	21.2
1051	975	LAREDO PLANT	94LA8745	767	21.1
1052	997	KINGSVILLE	94CS1140	1,134	21.0
1053	488	SA NORTH	97SA3130	231	20.9
1054	819	SA MATHIS FIELD	97SA5100	316	20.9
1055	814	COTULLA	94LA90	1,058	20.8
1056	783	LA GRULLA	94SB3045	1,211	20.8
1057	1256	GOODWIN	94SB3530	335	20.8
1058	1111	SIERRA VISTA	94LA9900	2,515	20.5
1059	758	DIMMIT	94LA5545	549	20.4
1060	48	SA LAKE DR	97SA5880	735	20.4
1061	1033	SA JACKSON ST	97SA4260	654	20.4
1062	1242	SOUTH EAST EDINBURG	94SB4570	1,902	20.4
1063	245	ZAPATA	94LA8290	988	20.4
1064	1126	NORTH MCALLEN	94SB9660	2,183	20.4
1065	144	SA EMERSON ST	97SA4860	233	20.2
1066	216	CAUSEWAY	94SB4775	1,069	20.2
1067	85	TWILIGHT TRAIL	97AB4290	1,202	20.1
1068	526	SAND ROAD	97AB5655	622	20.0
1069	42	AB MAPLE ST	97AB5750	474	19.9
1070	976	AB OIL MILL	97AB3895	133	19.8
1071	1069	BALLINGER	97SA4395	534	19.8
1072	924	UNIVERSITY	94LA920	909	19.7
1073	1054	SOUTH MCALLEN	94SB3850	1,362	19.7

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
1074	253	AB MCMURRY	97AB4510	816	19.6
1075	926	FT DAVIS	97SA3345	539	19.6
1076	544	SA COKE ST	97SA4910	1,783	19.3
1077	529	DEL MAR	94LA10	1,746	19.1
1078	1236	AB REBECCA LANE	97AB6915	1,020	19.1
1079	1192	MCCOLL ROAD	94SB4400	1,288	19.0
1080	1130	RAYMONDVILLE #1	94SB620	667	19.0
1081	18	STEAMBOAT	97AB12515	68	19.0
1082	1070	SOUTH MISSION	94SB4650	1,010	18.9
1083	358	BRYANTS RANCH	97SA205	21	18.9
1084	815	AILEEN	97AB6435	852	18.8
1085	533	CISCO	97AB7400	833	18.6
1086	256	HIGHLAND	97SA6375	295	18.4
1087		AIRLINE	94CS7390	2,330	18.3
1088	201	QUANAH	97AB3975	214	18.3
1089	1168	MARFA	97SA1905	1,155	18.3
1090	802	SA AVENUE N	97SA1730	830	18.2
1091	355	HEIGHTS	94LA6810	2,122	17.8
1092	481	UVALDE	94LA9770	516	17.8
1093	889	READING	94LA1385	1,354	17.7
1094	494	SINTON	94CS180	232	17.6
1095	148	MCCOLL ROAD	94SB2810	2,287	17.6
1096	516	DEL MAR	94LA220	1,470	17.4
1097	330	VERNON	97AB5000	247	17.4
1098	1041	RODD FIELD	94CS245	705	17.3
1099	554	ESCONDIDO	94LA1510	739	17.3
1100	497	MUNDAY	97AB3365	390	17.1
1101	587	SIERRA VISTA	94LA8205	1,236	17.0
1102	851	COLLEGE HILLS	97SA4840	218	16.9
1103	1092	ROARING SPRINGS	97AB6155	30	16.9
1104	523	WASHINGTON STREET	94LA2470	481	16.9
1105	790	GILA	94CS350	308	16.8
1106	475	STAMFORD	97AB4565	786	16.8
1107	479	EDNA	94CN5775	509	16.7
1108	745	AB EAST 12KV	97AB4825	416	16.7
1109	467	PHARR	94SB1650	898	16.7
1110	1022	SA SOUTH	97SA4255	866	16.7
1111	1027	ARANSAS PASS	94CS660	723	16.6
1112	230	AB WALNUT ST	97AB3110	658	16.6
1113	1132	AB VOGEL ST	97AB4405	597	16.5
1114	525	ROBERT LEE	97SA4125	274	16.4
1115	421	KNOX CITY	97AB3300	459	16.3
1116	1216	AB ELM CREEK	97AB4780	553	16.2
1117	158	HARLINGEN	94SB380	263	16.2
1118	987	ABILENE PLANT	97AB1910	246	16.2
1119	1064	KLEBERG	94CS280	1,328	16.1
1120	1205	AB RAINEY CREEK	97AB4270	1,422	16.1
1121	966	KLEBERG	94CS9395	1,261	16.1
1122	776	KARNES CITY	94CN2340	786	16.0

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
1123	800	AB OIL MILL	97AB2785	274	16.0
1124	1040	AB MAPLE ST	97AB4070	1,070	15.9
1125	982	CHILDRESS 20TH ST	97AB5725	680	15.7
1126	868	SANTO NINO	94LA80	1,904	15.5
1127	263	HIGHLAND	97SA6385	1,356	15.5
1128	1269	UNITEC	94LA5895	36	15.4
1129	547	SA CONCHO	97SA3325	295	15.2
1130	1220	SHARYLAND	94SB2020	2,814	15.2
1131	654	AB COUNTRY CLUB	97AB4855	964	14.9
1132	965	SAND ROAD	97AB5290	819	14.8
1133	485	NORTH MCALLEN	94SB9640	1,535	14.7
1134	956	GOODWIN	94SB4625	2,302	14.6
1135	1078	PEARSALL	94LA5580	854	14.4
1136	551	ROCKPORT	94CS5950	555	14.2
1137	159	SIERRA VISTA	94LA7170	1,455	14.0
1138	490	AB DYESS 1	97AB1775	881	14.0
1139	562	AB VOGEL ST	97AB4650	809	13.9
1140	570	CLYDE	97AB1755	132	13.8
1141	1163	VALADEZ	94CS2500	2,570	13.8
1142	541	CISCO	97AB9715	1,023	13.6
1143	515	ALBANY	97AB3655	625	13.3
1144	1283	CROWELL	97AB3490	176	13.2
1145	545	SA CONCHO	97SA1705	928	13.2
1146	225	EDNA	94CN5765	1,257	12.9
1147	1006	GOODWIN	94SB7380	2,094	12.8
1148	741	SA AVENUE N	97SA1695	1,525	12.5
1149	747	ROCHESTER	97AB3295	208	12.2
1150	1181	NORTH WESLACO	94SB4830	531	12.1
1151	567	SOUTHSIDE	94CS5345	403	12.1
1152	1213	VERNON CITY PLANT	97AB5775	813	12.0
1153	123	SA SOUTHLAND HILLS	97SA5055	857	12.0
1154	258	SA WALNUT ST	97SA4635	1,549	11.6
1155	1046	PRIMERA	94SB5705	1,260	11.6
1156	848	SA WALNUT ST	97SA3910	145	11.4
1157	401	STAMFORD	97AB6255	434	11.4
1158	612	WOOLRIDGE	94CS1120	1,636	11.3
1159	1039	SAND ROAD	97AB5295	537	11.2
1160	52	ALICE	94LA1790	454	10.9
1161	610	ASPERMONT	97AB1070	329	10.9
1162	1161	ALBANY	97AB3640	335	10.8
1163	1110	ROMA	94SB3060	1,619	10.6
1164	1104	CISCO	97AB1020	479	10.6
1165	700	SOUTH MCALLEN	94SB3935	508	10.0
1166	1145	EDEN	97SA3195	533	9.9
1167	582	GATEWAY	94LA5055	1,893	9.8
1168	437	COLLEGE HILLS	97SA4845	600	9.7
1169	599	SPUR	97AB260	162	9.6
1170	1200	BAIRD	97AB5120	568	9.6
1171	835	SA JACKSON ST	97SA4685	1,442	9.5

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
1172	265	NORTH EDINBURG	94SB3810	1,535	9.5
1173	1079	ASPERMONT	97AB3380	395	9.5
1174	262	NORTH MCALLEN	94SB4995	2,486	9.4
1175	672	SA CONCHO	97SA1700	553	9.1
1176	627	HEINES	94CS8480	150	8.9
1177	1114	SA NORTH	97SA3120	1,136	8.5
1178	505	AB SHELTON ST	97AB3145	1,051	8.4
1179	1109	JOSLIN POWER PLANT	94CN7915	11	8.2
1180	988	BRONTE	97SA3560	229	8.0
1181	1144	SA AVENUE N	97SA1655	494	7.9
1182	1087	HAMLIN	97AB3270	893	7.8
1183	1155	AB ELM CREEK	97AB1810	831	7.7
1184	743	MUNDAY	97AB2080	506	7.7
1185	690	KIRKLAND	97AB3545	30	7.7
1186	1288	PADUCAH CITY	97AB1935	289	7.6
1187	1243	PERKINS PROTHO	97SA3180	19	7.6
1188	808	SA JACKSON ST	97SA4690	1,122	7.6
1189	1251	QUANAH	97AB3530	328	7.6
1190	794	EAST HARRISON	94SB4620	776	7.6
1191	791	PADUCAH CITY	97AB1930	574	7.3
1192	878	CLOSNER	94SB7505	764	7.2
1193	1117	PEACOCK	97AB1375	43	7.0
1194	866	SA EMERSON ST	97SA4630	1,236	6.9
1195	393	MARFA	97SA1900	822	6.9
1196	1076	SA CONCHO	97SA1725	29	6.8
1197	1201	KENEDY S.S.	94CN6750	65	6.7
1198	583	SA WALNUT ST	97SA3915	722	6.7
1199	588	HEINES	94CS3515	1,307	6.6
1200	1232	PALMVIEW	94SB9680	1,066	6.6
1201	611	TRADE ZONE	94SB2220	70	6.5
1202	284	SA SOUTH	97SA3500	562	6.5
1203	1123	AB EAST 12KV	97AB4830	1,020	6.5
1204	1187	ROBERT LEE	97SA4120	549	6.4
1205	711	RANKIN	97SA7425	123	6.4
1206	1075	GARCENO	94SB5490	1,459	6.2
1207	1189	SANTO NINO	94LA695	1,606	6.1
1208	1150	SA SOUTHLAND HILLS	97SA5860	1,193	6.1
1209	908	HEIGHTS	94LA9080	694	6.1
1210	1235	PAISANO	97SAPAISAN	161	6.1
1211	1231	ROCHESTER	97AB3290	82	6.0
1212	452	ROCKSPRINGS	94LA8040	332	5.9
1213	1252	SHARYLAND	94SB2010	1,165	5.9
1214	720	ZACATE CREEK	94LA2665	1,727	5.7
1215	111	JAYTON	97AB6125	353	5.7
1216	699	CISCO	97AB6530	538	5.5
1217	553	CROWELL	97AB3980	471	5.5
1218	1057	AIRLINE	94CS7270	1,034	5.4
1219	668	LAS CRUSES	94LA9865	448	5.4
1220	620	TAYLOR	94SBSH114	626	5.3

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
1221	613	SOUTH MCALLEN	94SB3640	205	5.3
1222	1208	AB HARTFORD ST	97AB3690	172	5.3
1223	1244	SA SOUTH	97SA4795	1,504	5.2
1224	1226	MILES	97SA4670	395	5.2
1225	1276	RODD FIELD	94CS2190	96	5.2
1226	1141	HIGHLAND	97SA6380	478	5.2
1227	1172	MORRIS STREET	94CS8850	411	5.1
1228	1028	TWILIGHT TRAIL	97AB4285	1,146	5.0
1229	1222	ABILENE PLANT	97AB1740	18	4.9
1230	1101	NEW BLUFFS	97SA7280	1,581	4.9
1231	1214	LA PRYOR	94LA1835	266	4.8
1232	1210	AB HARTFORD ST	97AB3820	927	4.8
1233	1180	AB CANYON ROCK	97AB5025	58	4.6
1234	628	AB REBECCA LANE	97AB2710	262	4.6
1235	1093	ROTAN	97AB1865	193	4.5
1236	296	KNOX CITY	97AB3985	25	4.5
1237	349	SIERRA VISTA	94LA7360	1,713	4.2
1238	1169	RAYMONDVILLE #2	94SB4160	347	4.2
1239	615	HAMLIN	97AB3775	246	4.2
1240	1257	ANNA STREET	94LA5780	661	4.2
1241	995	ABILENE PLANT	97AB1915	50	4.2
1242	1056	AB ELM CREEK	97AB1825	214	4.2
1243	1202	SANTO NINO	94LA645	840	4.1
1244	875	AB REBECCA LANE	97AB5550	716	4.0
1245	365	QUINTANA	94CNT001Y8	58	3.7
1246	933	AB ELMDALE	97AB4520	283	3.6
1247	1245	AB HARTFORD ST	97AB3685	370	3.5
1248		MATADOR	97AB3090	315	3.4
1249		CHILDRESS 69	97AB2800	342	3.4
1250	445	VALERA HUMBLE	97SA7015	79	3.4
1251	1272	ALPINE 12KV	97SA6820	775	3.3
1252	972	COLLEGE HILLS	97SA5515	201	3.3
1253	1073	SA SOUTH	97SA3990	757	3.0
1254	999	CROCKETT HEIGHTS	97SA73703	69	2.9
1255	1065	SA CONCHO	97SA1715	294	2.8
1256	706	ESCONDIDO	94LA3775	234	2.7
1257	1230	COLLEGE HILLS	97SA4835	499	2.7
1258	1247	TEX/NEW MEX PIPELINE	97SA9045	16	2.4
1259	557	SONORA	97SAT000E2	498	2.3
1260	1124	AB MAPLE ST	97AB5755	1,220	2.3
1261	1183	TAYLOR	94SBSH112	989	2.2
1262	1215	COTULLA	94LA110	55	2.1
1263	1284	SA JACKSON ST	97SA4695	561	2.1
1264	629	FLOMOT	97AB81335	29	2.1
1265	928	ESCONDIDO	94LA2035	444	2.0
1266	1036	HAINE DRIVE	94SB9240	34	1.9
1267	1086	RUSSEK STREET	97SA12295	292	1.8
1268	197	TALPA ATLANTIC	97SA5180	65	1.7
1269		EAST HARRISON	94SB3000	548	1.6

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
1270	118	STERLING CITY	97SA11040	544	1.5
1271	1199	EDEN	97SA1780	232	1.3
1272	399	MINES ROAD	94LA3745	2,114	1.3
1273	1100	UNIVERSITY	94LA305	759	1.0
1274	986	SA AVENUE N	97SA1975	320	1.0
1275	1268	PAINT ROCK	97SA1110	64	1.0
1276		BRONTE	97SA4160	226	0.9
1277	301	SIERRA VISTA	94LA3540	1,154	0.6
1278	1273	IRAAN	97SA4305	251	0.6
1279	607	WEINERT	97AB6490	129	0.6
1280		MILES	97SA11330	171	0.6
1281	1089	SA JACKSON ST	97SA4250	336	0.4
1282	1289	ABILENE PLANT	97AB3175	122	0.3
1283	648	SA COKE ST	97SA4915	176	0.3
1284	53	BENTSEN	94SBSH211	375	0.2
1285	1237	NEW BLUFFS	97SA3005	314	0.1
1286	1249	NEW BLUFFS	97SA9110	818	0.1
1287	773	UNIVERSITY	94LA930	92	0.0
1288	1258	WASHINGTON STREET	94LA2330	60	0.0
1289		MINES ROAD	94LA8770	310	0.0
1290	856	LAS CRUSES	94LA8530	80	0.0
1291	1267	VICTORIA POWER PLANT	94CNNETVIC	88	0.0
1292	1270	WASHINGTON STREET	94LANETLAR	163	0.0
1293	1280	WASHINGTON STREET	94LA6890	19	0.0
1294	1266	WASHINGTON STREET	94LA2310	46	0.0
1295	1262	MORRIS STREET	94CSNET CC	317	0.0
1296	1234	KENEDY	94CN1960	69	0.0
1297	1261	WASHINGTON STREET	94LA2320	34	0.0
1298	1263	AB WALNUT ST	97AB3250	11	0.0
1299	994	SANTA RITA	97SA1135	10	0.0
1300	128	GIRARD	97AB6260	43	0.0
1301	1246	AILEEN	97AB4600	270	0.0
1302	867	SANTA RITA	97SA1140	11	0.0
1303	635	ASPR CONTINENTAL	97AB3830	27	0.0
1304	1275	ABILENE INDUSTRIAL PARK	97AB6600	12	0.0

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
---------------------------	---------------------------	----------------------------------	------------------------------	----------------------------	-------------------------

Feeders from last year that are not in this year's list

2021 Ranking	Substation Identification	Feeder ID	Reason not in 2022
13	MASTERSON FIELD	97SA800	Count is now less than 10
20	HOEFFS ROAD	97SA15680	Count is now less than 10
942	RIO PECOS	97SA513	Count is now less than 10

Service Quality Report to the Public Utility Commission of Texas

AEP Texas

INTERRUPTION CAUSES

Provide the percentage of interruptions attributable to each cause.

2022 Reporting Year

Causes of Forced Interruptions	Percentage
Utility-Owned Equipment	52.50%
Weather (including lightning)	14.69%
Vegetation	14.69%
Unknown	8.74%
Animals and Birds	5.69%
People (including cars and farm eqpt)	2.42%
Other	0.00%

The following files are not convertible:

2023 AEP-TX SQR 02092023.xls

Please see the ZIP file for this Filing on the PUC Interchange in order to access these files.

Contact centralrecords@puc.texas.gov if you have any questions.