



Filing Receipt

Received - 2023-02-14 02:15:03 PM
Control Number - 54467
ItemNumber - 13



Thomas J. Yamin, P.E.
Director
Regulatory Transmission and Planning

February 14, 2023

Filing Clerk
Public Utility Commission of Texas
1701 N Congress
P.O. Box 13326
Austin, TX 78711-3326

RE: PUCT Project No. 54467 – 2021 Electric System Service Quality Report pursuant to Substantive Rules §25.52, §25.81, §25.343

Attached is a copy of Oncor Electric Delivery Company's Service Quality Report pursuant to Substantive Rule §25.81, dated February 14, 2023. Additionally, pursuant to Substantive Rule §25.343, in the reporting year of 2022, there was a single instance where Oncor Electric Delivery Company provided competitive energy services to a customer in an emergency situation.

Oncor provided two station post insulators components to support maintenance and repair of failed equipment during an emergency event due to the facility's inability to obtain material within a reasonable timeframe to support the emergency situation.

If you have any questions or require further information, please contact me at 682.270.6305.

Sincerely,

A handwritten signature in black ink that reads "Thomas J. Yamin". The signature is written in a cursive, flowing style.

Thomas J. Yamin, P.E.
Director

Service Quality Report
To The
Public Utility Commission of Texas
In Accordance With
Substantive Rule §25.81
2022 Reporting Year

Oncor Electric Delivery

Project 54467

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

System SAIFI	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced													
2022	0.78	0.07	0.06	0.08	0.07	0.05	0.07	0.09	0.06	0.05	0.07	0.06	0.06
Scheduled													
2022	0.04	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.00	0.00	0.00
Outside Causes													
2022	0.06	0.00	0.01	0.00	0.00	0.00	0.01	0.00	0.01	0.00	0.01	0.00	0.01
Major Events													
2022	0.84	0.02	0.05	0.04	0.08	0.15	0.08	0.03	0.12	0.10	0.09	0.02	0.08

Note: Due to rounding, the sum of monthly values may not match yearly totals.

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

System SAIDI	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced													
2022	67.45	5.16	4.05	6.34	6.56	4.75	6.83	7.52	6.37	4.19	5.57	5.58	4.55
Scheduled													
2022	2.35	0.19	0.13	0.23	0.16	0.11	0.18	0.34	0.16	0.20	0.24	0.22	0.19
Outside Causes													
2022	2.13	0.07	0.12	0.03	0.17	0.11	0.27	0.36	0.43	0.13	0.27	0.09	0.09
Major Events													
2022	164.45	2.68	8.93	11.09	19.30	28.50	10.96	3.67	17.01	29.53	15.50	3.59	13.70

Note: Due to rounding, the sum of monthly values may not match yearly totals.

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

Total Number of Feeders

With 10 or more Customers

3,238

Add or Delete Rows as Necessary

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
1	5	MKNSW	2601	1,182	28.12
2	N/A	TYEST	1505	684	11.74
3	N/A	BLAKE	1711	281	10.77
4	264	HNTNG	1307	1,584	9.62
5	437	KYSTN	1011	114	8.75
6	134	DGLAS	2401	818	7.64
7	1118	CDCRK	1201	1,345	7.26
8	755	BSPSW	0822	254	6.94
9	1367	JDKNS	0822	32	6.78
10	3068	PCOMM	3314	864	6.64
11	2143	CRNRD	0007	778	6.42
12	881	QNLAN	1202	431	6.38
13	474	TYRSW	1703	402	6.31
14	344	GASLD	4211	88	6.28
15	1770	NCSFA	1706	1,169	6.24
16	169	CSHNG	1201	940	6.19
17	2844	LTVSB	5451	1,138	6.04
18	1920	WICKT	0431	188	6.01
19	24	FRNKS	1202	100	5.97
20	N/A	BLAKE	1721	46	5.96
21	452	TYWST	2012	1,773	5.91
22	995	DPCRK	1832	310	5.56
23	42	MNHNS	1922	94	5.44
24	61	MKNKY	1251	4,310	5.40
25	2548	THRNE	0001	712	5.35
26	10	RGLRW	0004	81	5.11
27	349	GLSCK	2411	201	5.05
28	408	BRLND	7921	931	5.02
29	3001	BRKTN	1202	139	4.96
30	406	NIPAK	1001	134	4.92
31	130	TAYLR	1202	2,056	4.88
32	114	CLNSE	4203	1,284	4.85
33	162	ECTHP	4911	1,373	4.85
34	2124	JDKNS	0821	31	4.84
35	351	CRNTH	2401	2,774	4.82
36	658	KMPSO	2400	990	4.82
37	2748	TIODE	9622	1,137	4.77
38	1139	BULDG	1109	130	4.76
39	113	BLAGG	3912	1,050	4.64
40	3083	IRVRS	4413	1,711	4.64
41	156	CRNAT	4121	54	4.56
42	46	ALCAT	1211	26	4.54
43	1484	MKNSW	2603	1,270	4.51

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
44	15	HNTNG	1301	1,519	4.47
45	557	BRKNR	1221	1,152	4.45
46	1159	WMRLD	0004	1,583	4.33
47	2712	HKBRY	1106	1,872	4.31
48	31	IRVNR	1553	1,658	4.30
49	2270	OAKHL	3062	2,456	4.25
50	22	CNTRY	2831	1,650	4.22
51	2664	LKTMS	2412	38	4.21
52	142	DUBLN	2214	723	4.16
53	2489	WSTHL	3652	3,200	4.12
54	443	TRPMN	4094	629	4.05
55	7	RSKMN	3057	1,181	4.02
56	885	ALKLK	4222	43	4.00
57	2636	TIODE	9621	229	3.93
58	486	LKTMS	2411	147	3.87
59	2546	JREST	2102	1,148	3.84
60	N/A	MMILL	3941	349	3.84
61	67	LOMAL	0011	1,127	3.79
62	1589	MRLNS	4003	918	3.77
63	289	HOLND	1901	1,166	3.76
64	417	STNVL	1206	2,803	3.76
65	1228	TYLNE	1605	675	3.76
66	781	DOLEY	8011	56	3.75
67	1190	RYLTY	1411	111	3.74
68	509	KLBRG	0002	1,456	3.71
69	384	TEGMN	3038	1,671	3.71
70	3051	MIDNT	3712	5,100	3.66
71	1878	LIGSW	1621	51	3.63
72	101	RDRSE	2607	6,000	3.61
73	2374	SHAMP	0004	1,171	3.59
74	1146	NCNTH	1806	893	3.57
75	238	MCWHT	3511	3,424	3.52
76	2543	LDRAW	6623	172	3.48
77	159	CNI45	2402	785	3.47
78	45	CRKET	2402	1,696	3.45
79	86	CRKET	2403	2,819	3.45
80	2307	VANSB	1501	890	3.44
81	2032	PSHIL	1603	1,861	3.41
82	3003	GAMMA	2203	1,237	3.36
83	44	DHIDE	2821	99	3.33
84	1348	BARNW	4523	99	3.31
85	1464	NCSTH	1501	801	3.30
86	352	TEGMN	3040	774	3.29
87	1198	PLKST	0007	2,296	3.28
88	2422	JUDCT	0001	1,799	3.26
89	123	DIALV	3911	1,129	3.23
90	931	COYNW	8122	83	3.18
91	1301	ALNSW	2651	2,986	3.17

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
92	247	MLKF2	1201	926	3.17
93	655	RCHHL	0332	1,692	3.17
94	145	MNWLW	1403	1,000	3.15
95	299	TSLVL	4008	2,228	3.13
96	48	BRIRV	6911	3,044	3.12
97	2055	MCTYE	1721	586	3.12
98	107	WLWSP	1201	623	3.12
99	1415	ATHNW	1401	909	3.11
100	2161	MRDCK	0001	1,818	3.10
101	2545	DENDR	0005	478	3.09
102	461	MEXIA	4023	646	3.09
103	40	SWAN2	1803	1,389	3.09
104	996	IOWPK	0821	767	3.06
105	2597	NPKWY	0005	863	3.06
106	1862	HLSBR	1204	574	3.05
107	398	MNHNS	1911	1,508	3.05
108	2231	EDWDS	5931	678	3.03
109	544	MESQW	1803	2,143	3.02
110	1373	NECSP	2401	635	3.01
111	252	CUMBY	1201	794	2.99
112	2155	MESQT	1302	1,633	2.99
113	186	WXHCH	1202	2,448	2.99
114	3049	TYLGE	1314	1,113	2.98
115	1923	KEENE	1503	876	2.97
116	965	TAYLR	1201	1,865	2.95
117	734	AMMFG	5621	592	2.94
118	891	BRNSO	1807	251	2.93
119	1594	WNRTH	1417	1,691	2.93
120	108	CLMET	0003	901	2.92
121	993	PLKST	0004	1,373	2.92
122	41	CRNES	2711	112	2.91
123	2375	TXHRV	1621	100	2.91
124	1015	ALNTH	2854	795	2.88
125	1942	MRTSP	1502	923	2.88
126	990	JKWST	4178	476	2.85
127	623	SWTWR	1341	251	2.85
128	316	VLYRN	2951	2,233	2.83
129	441	ALPHA	0015	1,251	2.82
130	2758	HKBRY	1115	17	2.82
131	1781	IRVBL	2503	1,921	2.82
132	1840	HURST	1811	1,263	2.77
133	924	RWALE	3322	2,307	2.77
134	1369	TRPMN	4001	806	2.76
135	1192	CHRNO	1203	442	2.75
136	918	EMPCT	0004	1,151	2.75
137	1088	GRSLK	1104	640	2.75
138	1126	TYSTH	1209	817	2.74
139	35	CHILK	7711	15	2.73

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
140	2795	MRDCK	0004	852	2.73
141	375	TROYS	1014	1,448	2.73
142	2612	WDGWD	1592	1,090	2.73
143	2606	LKHLD	0002	1,527	2.72
144	1883	BKWVWF	0521	460	2.71
145	20	CHRNA	1201	538	2.71
146	200	CNANG	1804	194	2.71
147	1204	FKLCY	5121	37	2.70
148	211	CNANG	1806	2,632	2.69
149	193	STANT	1323	419	2.69
150	365	TYEST	1501	1,910	2.69
151	1492	CNLRD	2106	319	2.68
152	1669	SMPST	0003	1,092	2.68
153	2	TMPLE	1201	2,464	2.68
154	1324	BSPSW	0851	530	2.66
155	136	RYSSW	2803	3,307	2.65
156	1175	CMINO	1203	1,824	2.64
157	N/A	OWLHL	7713	47	2.64
158	2998	AMLIA	0006	79	2.63
159	1825	ANDRD	0921	75	2.63
160	2445	THRDN	1901	692	2.62
161	1321	CRSGL	1301	154	2.61
162	3045	TYLNW	1914	1,120	2.61
163	170	PRFTW	4222	5,054	2.60
164	97	FRMBR	1804	198	2.59
165	323	CNEXP	0003	1,412	2.57
166	2364	CNTRY	2814	1,116	2.57
167	419	THRDN	1921	1,215	2.57
168	1215	BAYLC	1201	136	2.56
169	735	CSHNG	1202	72	2.56
170	2046	MSLSW	0005	868	2.56
171	418	BLISS	9411	333	2.55
172	1160	KLBRG	0003	1,695	2.55
173	1104	BRIRV	6921	2,438	2.54
174	1018	CTFLD	9911	2,121	2.54
175	2017	WTAUG	4652	803	2.54
176	1051	GNSVE	1603	1,776	2.53
177	1468	HLSBR	1202	1,266	2.53
178	1368	HUDSN	1601	1,015	2.53
179	350	TYOMN	1409	1,789	2.53
180	610	ALKLK	4211	67	2.52
181	2721	GAVSW	0002	1,260	2.52
182	1026	NCNTH	1802	1,320	2.51
183	1076	PLSTN	1003	1,663	2.51
184	1360	BRNWD	1206	1,395	2.50
185	205	HLTOM	2442	1,099	2.50
186	181	OVRTN	4015	632	2.50
187	370	HLSES	0522	1,736	2.48

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
188	792	IVANS	1612	1,084	2.47
189	1289	MNWLE	1701	772	2.47
190	2090	BOWEN	3132	1,811	2.46
191	886	HRSMO	1957	2,462	2.46
192	794	CTYVW	2222	1,434	2.45
193	118	SCYEN	0005	1,679	2.45
194	2426	HKBRY	1113	442	2.44
195	877	PRNTH	1404	1,564	2.43
196	1474	SCURY	1921	91	2.43
197	232	TYLNE	1607	762	2.43
198	270	CRLSP	1703	271	2.42
199	2310	HLSES	0511	1,940	2.42
200	1306	AIRPK	8411	819	2.41
201	71	BUFLO	2601	1,619	2.41
202	66	NCSTH	1503	966	2.41
203	1060	FORSN	5632	253	2.40
204	1733	HUDSN	1604	974	2.40
205	407	AZLES	2121	3,197	2.39
206	1163	BOWEN	3192	1,269	2.39
207	333	ELMAR	3222	28	2.39
208	147	OTTOJ	3059	1,116	2.39
209	1341	PFFRD	3472	1,292	2.39
210	244	LVBRD	0003	271	2.38
211	2202	MSTLT	1084	1,267	2.38
212	2475	RNKSW	5413	37	2.38
213	203	NCSFA	1704	1,424	2.37
214	199	TRLNW	1203	720	2.37
215	651	ALPHA	0013	454	2.36
216	795	PPARK	1801	1,318	2.36
217	2137	RTHGB	1411	700	2.36
218	1243	WXHCH	1201	1,765	2.36
219	1476	ARMST	0010	819	2.35
220	2637	IVANS	1621	66	2.35
221	2227	MRLNS	4002	408	2.35
222	483	PLSTN	1002	1,246	2.35
223	378	SCYEN	0004	1,357	2.35
224	1384	TLRWT	2203	789	2.35
225	756	FHLSW	1311	1,704	2.34
226	3089	ALCAT	1222	36	2.33
227	1191	MLDR2	1605	228	2.33
228	216	RICES	0208	818	2.33
229	602	RWALE	3321	1,484	2.33
230	696	RYLTY	1431	45	2.33
231	2587	ELMAR	3221	35	2.31
232	687	BRLSN	2052	3,484	2.30
233	1014	BNBRK	4113	3,922	2.29
234	2172	BRNAV	0732	827	2.28
235	91	CDMIL	2401	1,436	2.27

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
236	1273	HMTRD	0002	1,719	2.27
237	1609	JKSNR	4107	328	2.27
238	34	ORANS	1501	955	2.27
239	1170	WGROB	8411	3,558	2.27
240	6	ALNSW	2654	1,979	2.25
241	2105	ELGIN	1003	3,435	2.25
242	2488	SSPNE	1405	501	2.25
243	2549	ADMDS	6521	2,118	2.24
244	2903	DENDR	0003	2,255	2.23
245	1518	RCHHL	0342	1,016	2.23
246	1345	STHRL	0004	1,396	2.23
247	2119	RDOAK	1301	1,347	2.22
248	23	SHSTH	1303	902	2.22
249	106	MESTE	1204	1,829	2.21
250	2343	ODESW	5932	542	2.21
251	1889	BRLSN	2013	1,108	2.20
252	1424	CMINO	1204	584	2.20
253	1483	JUDCT	0007	527	2.20
254	1619	TMPLE	1206	713	2.20
255	1562	DCVSO	1107	1,115	2.19
256	1678	HMTRD	0003	429	2.19
257	2527	MDWPK	9241	2,201	2.19
258	2419	SLAKE	8312	3,393	2.19
259	1875	CGRSW	9821	29	2.17
260	973	DCDAM	2001	860	2.17
261	1575	FLGRV	4711	197	2.17
262	105	HKBRY	1111	29	2.17
263	95	NCWDN	1121	46	2.17
264	1798	COLNY	2403	2,897	2.16
265	1311	CRSGL	1306	693	2.16
266	1610	KLBRG	0004	1,724	2.16
267	1786	OAKHL	3021	2,062	2.16
268	325	MCGRG	0775	1,162	2.15
269	2617	PRSTN	0008	769	2.15
270	3055	BRIRV	6922	3,404	2.14
271	844	LUFKN	1206	1,744	2.14
272	1724	OKCLS	0004	1,573	2.14
273	129	MDLNW	1532	2,052	2.13
274	1864	SHNRW	1614	1,405	2.13
275	168	IRVNR	1551	1,366	2.12
276	1475	WSTHL	3642	2,334	2.12
277	185	LUTHR	2106	70	2.11
278	409	BDFWD	8932	1,715	2.10
279	883	MKNNY	1202	1,945	2.10
280	1362	ALVRD	1501	1,234	2.09
281	2495	ARLNG	1261	1,363	2.09
282	298	HUTCH	1502	232	2.09
283	511	TRIRA	6221	572	2.09

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
284	2248	WNTHW	1121	751	2.09
285	645	CDCSW	0005	2,295	2.08
286	710	CHROW	0005	188	2.08
287	2370	CKRHL	0008	1,829	2.08
288	447	PCUST	2004	1,216	2.08
289	2985	RECCR	0001	223	2.08
290	89	GRLND	1604	2,004	2.07
291	972	ALLNC	6411	50	2.06
292	450	DEALY	0001	3,909	2.06
293	1950	GRSLK	1103	721	2.06
294	2480	FHLSW	1361	1,544	2.05
295	1213	HUBRD	1402	1,068	2.05
296	2595	LVBRD	0002	513	2.05
297	911	WSTHL	3613	3,464	2.05
298	2715	BRIRV	6912	846	2.04
299	57	CNI45	1202	855	2.03
300	848	PRSTN	0001	873	2.03
301	2816	WHITE	3532	2,156	2.03
302	2743	MDLNE	0172	386	2.02
303	1000	MLKF2	1203	1,284	2.02
304	526	PCUST	2006	1,620	2.02
305	956	ELKTN	2506	549	2.01
306	555	HNTNG	1306	1,165	2.01
307	2835	RRSTH	1704	3,970	2.01
308	1877	DCATR	1204	764	2.00
309	N/A	KIMBL	5013	1,387	2.00
310	2602	MRNFD	2311	60	2.00
311	1391	GORMN	0411	571	1.99
312	358	FRMBR	1802	1,145	1.98
313	989	LFEST	1905	1,886	1.98
314	3037	BNDRA	0006	689	1.97
315	1254	GRPTT	9921	599	1.97
316	1210	HISKY	8821	155	1.97
317	2975	RECCR	0005	161	1.97
318	769	WALST	0010	2,220	1.97
319	2461	EULSO	9112	1,100	1.96
320	1482	WSOTH	1019	836	1.96
321	1211	YARBR	5011	25	1.96
322	1453	BNTDR	0002	1,858	1.95
323	1850	GLNHV	3953	1,359	1.94
324	3126	GRVPT	7522	47	1.94
325	573	LVOAK	1601	1,225	1.94
326	1992	ALPHA	0009	71	1.93
327	1466	CHROW	0007	82	1.93
328	1481	HDWLK	3003	1,004	1.93
329	368	MDRAW	8211	120	1.93
330	202	WMRLD	0005	1,618	1.93
331	569	KRNCH	9021	13	1.92

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
332	2608	MCKMY	0812	2,031	1.92
333	13	MNFLD	2672	2,557	1.92
334	1003	JKSES	3029	828	1.91
335	448	LTFRD	3021	944	1.91
336	257	LVBRD	0008	1,843	1.91
337	1402	MEXIA	4008	723	1.91
338	362	MSLMN	4007	436	1.91
339	2261	CRTLD	4732	3,110	1.90
340	1865	CGRSW	9811	64	1.89
341	1615	CNTRY	2811	2,872	1.89
342	1624	CNTRY	2823	1,888	1.89
343	1179	GLNHV	3942	792	1.89
344	2038	OKCLS	0005	261	1.89
345	2604	WCOLO	1320	1,461	1.89
346	2561	WOVER	6162	1,097	1.89
347	1284	ALLEN	2406	3,042	1.88
348	2529	BRKNR	1211	121	1.88
349	121	CLKVL	1202	1,237	1.88
350	2544	DEALY	0002	1,740	1.88
351	561	SMFLD	2392	1,051	1.87
352	253	WNDRC	0252	948	1.87
353	1629	WEAST	0621	298	1.86
354	851	CKRHL	0001	399	1.85
355	2583	CRNRD	0001	740	1.85
356	234	IRLBJ	3233	2,283	1.85
357	2821	NCRST	2203	498	1.85
358	916	PJPTR	3242	79	1.85
359	2392	SMFLD	2341	998	1.85
360	2556	WCOLO	1316	2,084	1.85
361	638	CMINO	1201	788	1.84
362	332	LEMON	0006	730	1.84
363	2568	BSPRW	2532	1,585	1.83
364	2503	CDHIL	1805	621	1.83
365	1097	RECCR	0002	90	1.83
366	83	STAUG	0004	1,086	1.83
367	994	BRTL	1402	152	1.82
368	971	GODLY	1601	832	1.82
369	1169	IRVGS	1902	1,492	1.82
370	1538	IRVHF	2305	1,483	1.82
371	2031	DAVST	0006	1,415	1.81
372	1150	DELTA	1702	490	1.81
373	1461	IRVND	1201	989	1.81
374	1469	ATHNW	1404	1,483	1.80
375	2784	BLUEA	2105	116	1.80
376	1738	COMSO	1405	813	1.80
377	2569	GRPVN	8223	2,087	1.80
378	172	LFEST	1904	1,418	1.80
379	1024	WCITY	2402	688	1.80

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
380	249	DIBOL	1505	1,439	1.79
381	2794	LWSNR	2232	2,544	1.79
382	N/A	OILML	3622	921	1.79
383	192	RDOAK	1302	2,679	1.79
384	2910	LIGSW	1604	725	1.78
385	326	BNEST	3111	2,860	1.77
386	3022	JUDCT	0002	1,383	1.77
387	259	KEYSB	2621	13	1.77
388	16	MSTNG	2611	137	1.77
389	2356	CRSWS	1403	2,473	1.76
390	473	LNDAL	2203	2,628	1.76
391	1246	CPRCV	1403	2,134	1.75
392	2663	ELKTN	2502	1,819	1.75
393	424	FINKS	1802	871	1.75
394	52	JREST	2101	2,324	1.75
395	889	PRNTH	1405	1,061	1.75
396	427	RWALL	1203	3,312	1.75
397	260	TMNTH	1603	118	1.75
398	1657	WWDWY	2015	1,274	1.75
399	1114	KEENE	1501	1,697	1.74
400	2900	SHNRW	1601	584	1.74
401	1400	SSPNE	1401	820	1.74
402	1613	ALNSW	2653	3,380	1.73
403	104	GYVLM	8611	15	1.73
404	73	SBEAN	6022	49	1.73
405	78	FRNKS	4168	1,003	1.72
406	3015	HORNE	1921	318	1.72
407	1456	MESQT	1304	627	1.72
408	1822	ANARN	1911	14	1.71
409	1002	BRGPR	1103	1,005	1.71
410	2675	DEALY	0004	1,262	1.71
411	2191	MURPH	2755	3,460	1.71
412	2444	RYLTY	1421	389	1.71
413	2262	EDDYS	0712	1,180	1.70
414	2449	PBELL	4831	1,231	1.70
415	498	SGOVL	1401	1,922	1.70
416	1826	CDCSW	0008	751	1.69
417	126	RWALL	1202	2,866	1.69
418	863	CNTRY	2833	1,253	1.68
419	791	GSMTH	1721	50	1.68
420	246	HLTOM	2421	1,682	1.68
421	650	HNTNG	1305	1,259	1.68
422	2084	CHYNE	9122	36	1.67
423	1157	COLDG	4047	425	1.67
424	2319	FRMBR	1806	450	1.67
425	1107	FRFWS	3001	1,873	1.66
426	1451	MSLSW	0001	850	1.66
427	1525	QNLAN	1201	891	1.66

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
428	444	CNTRY	2851	1,529	1.65
429	1361	CRSGL	1302	1,524	1.65
430	779	RCHRD	1204	1,141	1.64
431	213	SGOVL	1403	2,549	1.64
432	1020	SHPWK	5713	107	1.64
433	233	EUSTC	2402	859	1.63
434	2841	LMBLN	0001	2,039	1.63
435	1623	RSKMN	3053	506	1.63
436	1120	GNSVL	1205	943	1.62
437	1522	HLTOM	2452	1,823	1.62
438	2182	LNCST	1602	1,592	1.62
439	681	MEANS	4421	45	1.62
440	3166	PTENN	2356	13	1.62
441	1167	SCYEN	0003	1,277	1.62
442	2407	MESQW	1804	1,346	1.61
443	94	MKNSW	2602	2,717	1.61
444	1375	ODESA	0251	1,368	1.61
445	2280	DPCRK	1831	1,440	1.60
446	661	EULSO	9111	1,961	1.60
447	711	RHOME	2402	1,569	1.60
448	N/A	BATLE	4111	1,291	1.59
449	617	CRNTH	2402	1,422	1.59
450	1046	DESHR	1204	1,253	1.59
451	386	HMTRD	0004	1,063	1.59
452	235	LNGLK	1604	471	1.59
453	151	CDHCR	2050	817	1.58
454	2067	CMTSW	0977	270	1.58
455	72	CRSWS	1401	1,102	1.58
456	98	GRPVN	8212	4,151	1.58
457	49	MRVLY	2311	378	1.58
458	2087	MSHLN	0008	688	1.58
459	3074	ALPHA	0011	1,153	1.57
460	675	CLKVL	1201	434	1.57
461	998	JKSNR	4111	484	1.57
462	1201	PLOWB	2911	326	1.57
463	1679	SSPSW	1604	1,313	1.57
464	1977	TYBLR	2805	2,279	1.57
465	263	MASON	3412	137	1.56
466	109	PRFTW	4221	1,408	1.56
467	709	BONHM	1206	2,258	1.54
468	2325	CLYVL	9313	2,066	1.54
469	434	CSHNG	1204	325	1.54
470	2984	KLNSO	4512	2,546	1.54
471	1079	SSPNG	1204	1,076	1.54
472	1035	BRTRD	7312	2,334	1.53
473	4	ELMAR	3232	77	1.53
474	214	FLGRV	4721	271	1.53
475	905	MCDMT	2532	1,986	1.53

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
476	2538	WFALS	0184	926	1.53
477	2131	WXHCH	1204	1,974	1.53
478	2251	CMTSW	0957	1,214	1.52
479	12	ECTHP	4921	797	1.52
480	207	HORNE	1931	947	1.52
481	1779	HSKAV	0001	1,099	1.52
482	596	LUFGN	1205	1,328	1.52
483	1956	THORN	6812	113	1.52
484	2198	ADISN	1608	370	1.51
485	2061	CDHIL	1801	1,145	1.51
486	893	PKRVL	1053	1,360	1.51
487	1315	PLSTN	1001	1,954	1.51
488	690	TSLVL	4002	3,065	1.51
489	2688	WHTRK	0001	2,838	1.51
490	2007	DESHR	1201	989	1.50
491	1116	SMPST	0002	1,523	1.50
492	2184	WHITE	3531	1,887	1.50
493	898	PRFTW	4211	4,575	1.49
494	2518	ROANW	9511	1,962	1.49
495	2787	MSHLN	0007	733	1.48
496	2399	MSLMN	4131	143	1.48
497	2355	WNRTH	1421	1,384	1.48
498	670	EGFRD	0005	1,073	1.47
499	2139	FINKS	1803	1,539	1.47
500	1660	GVFTW	1801	752	1.47
501	2123	HUDSN	1602	1,739	1.47
502	96	PLSTH	1302	1,007	1.47
503	866	RDOAK	1304	2,060	1.47
504	1435	STNVL	1201	2,595	1.47
505	663	TYOMN	1408	1,350	1.47
506	2869	HLTOM	2411	1,516	1.46
507	1638	IRVGS	1908	940	1.46
508	1425	LEMON	0009	1,098	1.46
509	188	PLOWB	2921	549	1.46
510	901	WXNTH	2306	3,248	1.46
511	1459	KLNTF	1806	1,190	1.45
512	1423	TIODE	9611	479	1.45
513	393	WWDWY	2024	1,466	1.45
514	229	IRVNR	1501	1,132	1.44
515	79	SBEAN	6021	25	1.44
516	1437	BRLSN	2023	1,911	1.43
517	2638	KNLTR	0003	625	1.43
518	1357	KRUMS	1203	853	1.43
519	1418	NCNTH	1801	2,571	1.43
520	2322	NCWDN	1111	876	1.43
521	381	SWDTN	1611	1,527	1.43
522	1514	BAKKE	6921	2,227	1.42
523	460	BOWEN	3151	1,931	1.42

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
524	2230	CRLFR	2159	1,614	1.42
525	2185	CRTLD	4731	3,233	1.42
526	1094	FSCRK	6721	1,706	1.42
527	2266	HNYGR	2401	615	1.42
528	582	KIMBL	5022	915	1.42
529	38	LUFKN	1208	1,783	1.42
530	1521	GASLD	4221	64	1.41
531	158	GNSVE	1602	1,730	1.41
532	380	JKSNR	4109	652	1.41
533	2171	LKWOD	7411	629	1.41
534	1205	OTTOJ	3060	17	1.41
535	2121	TMPNW	1105	881	1.41
536	969	ALLNC	6422	45	1.40
537	562	BLSRA	1601	544	1.40
538	2562	CDCSW	0003	769	1.40
539	383	MDLNE	0142	529	1.40
540	1066	LTLRV	1701	1,161	1.39
541	1598	MESWE	3621	828	1.39
542	1554	RCHRD	1202	817	1.39
543	2703	VLRYN	2954	2,747	1.39
544	2043	BELLS	1201	634	1.38
545	2667	LWRDR	0002	1,021	1.38
546	178	PLSTN	1004	1,605	1.38
547	N/A	TYRSW	1702	1,036	1.38
548	1283	CLYVL	9322	2,202	1.37
549	627	DALLW	0003	695	1.37
550	1344	ELGIN	1002	3,052	1.37
551	1922	FRSTN	1602	1,395	1.37
552	1620	GRHWY	5511	2,412	1.37
553	266	HNRTA	0321	977	1.37
554	2045	KLRPR	9012	2,556	1.37
555	466	RWALS	1852	3,027	1.37
556	2634	PRKRW	3392	176	1.36
557	1510	WMMMR	2703	1,146	1.36
558	2284	MLFRD	2101	1,531	1.35
559	394	VANSB	1502	1,753	1.35
560	2291	WNDCR	0241	667	1.35
561	2450	ALPHA	0016	1,986	1.34
562	354	CPLND	1101	1,260	1.34
563	137	EDDYS	0710	686	1.34
564	166	MCTYE	1711	1,758	1.34
565	2733	OKLND	0002	1,381	1.34
566	2402	WDGWD	1512	820	1.34
567	745	WSMWS	9811	5,906	1.34
568	2225	BNBOR	1203	356	1.33
569	1477	BRKTN	1201	486	1.33
570	2115	CRLTN	1452	3,435	1.33
571	1186	DCVSO	1105	1,676	1.33

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
572	1359	DENAV	0631	1,786	1.33
573	1288	HDWLK	3005	1,301	1.33
574	2246	OKLND	0004	1,580	1.33
575	1455	RKCRK	6111	4,634	1.33
576	2969	WDGWD	1552	304	1.33
577	1224	CPRCV	1404	2,223	1.32
578	496	ENNIS	1906	2,342	1.32
579	1355	GRAHM	0721	1,246	1.32
580	2456	GRFRD	1002	410	1.32
581	2418	MESQT	1301	1,429	1.32
582	936	RWDHV	1907	904	1.32
583	377	SIKES	2421	2,082	1.32
584	2935	TMPSE	1503	523	1.32
585	2726	WESTS	1602	928	1.32
586	1564	BDFWD	8922	2,015	1.31
587	1646	BRNAV	0711	1,670	1.31
588	2060	BRNAV	0741	2,055	1.31
589	723	CDCSW	0007	1,053	1.31
590	294	COPEL	3056	1,924	1.31
591	1664	EULES	8711	2,044	1.31
592	1184	MKNYY	1253	163	1.31
593	2195	OKCLS	0008	1,555	1.31
594	2329	PGSTH	7011	52	1.31
595	1067	RWALE	3326	1,183	1.31
596	1450	SHRSW	6621	1,816	1.31
597	1112	WHTRK	0005	729	1.31
598	2710	ALPHA	0007	1,477	1.30
599	708	MAYFD	5522	3,471	1.30
600	N/A	MDLNW	1554	1,192	1.30
601	1498	MNWLL	1204	298	1.30
602	494	MSTNG	2621	54	1.30
603	1135	TRNTY	7521	1,187	1.30
604	760	CURIE	7212	980	1.29
605	75	HHSTH	1502	2,296	1.29
606	912	MDLNW	1521	1,826	1.29
607	1867	RDLML	2512	1,225	1.29
608	2359	TMPLE	1202	1,372	1.29
609	2440	WALST	0011	756	1.29
610	639	CRSWS	1402	1,013	1.28
611	3145	MIDNT	3711	2,501	1.28
612	237	SHAMP	0007	732	1.28
613	612	SWTWR	1321	139	1.28
614	1029	TRPMN	4023	431	1.28
615	728	WFALS	0153	1,147	1.28
616	283	BSPRG	1902	2,535	1.27
617	1244	CANTN	1303	963	1.27
618	746	CDCSW	0002	2,455	1.27
619	312	CRWLY	7021	4,118	1.27

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
620	355	ENNIS	1903	1,593	1.27
621	2222	GRPVN	8213	299	1.27
622	1372	HNYGR	2403	641	1.27
623	1445	IRVGS	1906	735	1.27
624	1723	IRVNG	1402	1,149	1.27
625	27	MESTE	1208	996	1.27
626	2136	MSLSW	0008	175	1.27
627	1377	RDLML	2561	1,009	1.27
628	541	REYST	4118	779	1.27
629	1991	RSPCK	2102	1,566	1.27
630	1641	ARPMN	4147	651	1.26
631	458	ENTOH	0005	1,245	1.26
632	825	GMINI	5812	1,268	1.26
633	647	KIMBL	5012	1,109	1.26
634	2301	PARIS	1206	1,039	1.26
635	221	PGSTH	7012	227	1.26
636	189	STANT	1312	365	1.26
637	2896	BKWST	0004	1,085	1.25
638	2883	CKRHL	0003	497	1.25
639	2327	HKBRY	1102	1,709	1.25
640	1386	JNKNS	0003	919	1.25
641	676	MSLSW	0004	401	1.25
642	641	PLSTH	1304	1,340	1.25
643	621	SHAMP	0003	1,767	1.25
644	2128	TYLNE	1623	942	1.25
645	2376	WALST	0004	79	1.25
646	2273	WITTS	1703	1,040	1.25
647	2856	BSPRG	1904	1,670	1.24
648	2071	COMSO	1403	459	1.24
649	2095	CRLJL	1508	337	1.24
650	1178	DNISN	1206	1,009	1.24
651	2040	ELCTR	1211	271	1.24
652	2746	EMPCT	0007	98	1.24
653	1119	ENSSO	2004	1,387	1.24
654	2798	GSMTH	1731	37	1.24
655	2747	HUTTO	2721	5,894	1.24
656	148	LUTHR	2105	71	1.24
657	1984	MSLMN	4009	251	1.24
658	926	PFLGV	2001	5,378	1.24
659	2657	WALST	0002	45	1.24
660	954	COLNY	2404	1,935	1.23
661	231	FSHSW	2111	347	1.23
662	1651	GVODS	3041	1,466	1.23
663	589	MDTHS	1002	1,162	1.23
664	1439	TYWST	2003	345	1.23
665	1928	BLTLN	0003	605	1.22
666	1054	CRLJL	1505	1,145	1.22
667	360	DNIWS	1602	1,064	1.22

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
668	2540	FSTVW	0006	1,223	1.22
669	752	GAVSW	0009	1,022	1.22
670	984	GSTHW	1614	872	1.22
671	1269	ITALY	2103	366	1.22
672	1622	MCGRG	0776	294	1.22
673	1802	MESQN	1503	1,834	1.22
674	2623	PWEST	1311	1,305	1.22
675	592	CNI45	2401	564	1.21
676	1697	ODNTH	2035	690	1.21
677	1405	POOLV	5811	460	1.21
678	141	TERSO	2501	192	1.21
679	2718	WITTS	1701	1,306	1.21
680	1714	CMTSW	0936	522	1.20
681	2530	EDGCF	2262	1,043	1.20
682	1537	GRSMN	4029	976	1.20
683	585	HOWRD	3911	25	1.20
684	1686	LKMNT	0003	570	1.20
685	1916	PRCRK	0003	1,943	1.20
686	2400	PRNTH	1401	1,317	1.20
687	1370	WGROB	8422	2,454	1.20
688	2522	ALLEN	2402	919	1.19
689	1718	CRLTN	1405	1,249	1.19
690	32	PAULN	2503	808	1.19
691	2353	PRSTN	0004	675	1.19
692	572	RWDHV	1901	930	1.19
693	2192	ARLNG	1232	1,262	1.18
694	1145	CANTN	1301	1,406	1.18
695	1552	FRSTN	1604	401	1.18
696	119	ITALY	2101	313	1.18
697	2085	KLNPS	1101	2,461	1.18
698	702	MRTNS	1501	536	1.18
699	1008	SMFLD	2381	856	1.18
700	273	SSPNE	1403	1,242	1.18
701	37	WALST	0001	719	1.18
702	662	CMPWI	0002	1,777	1.17
703	835	CRLCC	2703	627	1.17
704	516	DHIDE	2811	29	1.17
705	575	DNISN	1204	1,438	1.17
706	124	EULES	8723	5,155	1.17
707	2862	FARON	4062	1,148	1.17
708	3079	FLMSO	3712	952	1.17
709	1904	GSTHW	1623	2,488	1.17
710	1985	HRSHD	5821	127	1.17
711	2864	HUTCH	1505	212	1.17
712	854	MAPLE	0006	2,590	1.17
713	554	MKNGB	5321	480	1.17
714	1337	NCDSW	3811	1,507	1.17
715	540	PLKST	0008	1,692	1.17

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
716	2949	WALST	0013	377	1.17
717	1138	CDMIL	1201	825	1.16
718	2267	DALWT	2982	1,337	1.16
719	3059	FRNKF	0006	1,720	1.16
720	2328	LMESA	1512	1,770	1.16
721	2700	PALRD	2205	480	1.16
722	914	SHAMP	0001	1,044	1.16
723	76	TRLWD	7721	3,140	1.16
724	2091	BRNSY	1231	68	1.15
725	629	BRNWD	1205	1,139	1.15
726	1946	FHLSW	1372	1,561	1.15
727	1695	SWTWR	1362	436	1.15
728	2330	WLSPT	1001	2,103	1.15
729	1058	WMRLD	0003	503	1.15
730	2662	CNLRD	2107	262	1.14
731	2189	EDGCF	2272	1,074	1.14
732	N/A	GUNSO	9931	316	1.14
733	3009	HLTOM	2461	851	1.14
734	2996	HMPHL	2742	857	1.14
735	1898	HUDSN	1603	1,530	1.14
736	1963	IRVBL	2504	1,607	1.14
737	3132	IRVVV	2852	173	1.14
738	308	MAYFD	5521	1,987	1.14
739	487	MRDCK	0003	854	1.14
740	1888	PPARK	1806	848	1.14
741	1272	SHLMT	1801	309	1.14
742	611	ALPHA	0010	533	1.13
743	117	BAGWL	1202	46	1.13
744	286	BARRY	1802	358	1.13
745	2199	BBTWN	1501	2,131	1.13
746	2485	CLBNR	1402	2,036	1.13
747	2944	CRNRD	0006	352	1.13
748	1164	FHLSW	1321	433	1.13
749	1317	HSKAV	0004	1,366	1.13
750	1716	LKMNT	0008	1,214	1.13
751	19	MNFLD	2682	2,685	1.13
752	3149	MRSDO	9622	3,644	1.13
753	2210	MYPTX	2401	364	1.13
754	693	NCSFA	1702	1,298	1.13
755	1943	OAKHL	3072	2,624	1.13
756	301	PTENN	2351	1,567	1.13
757	2238	PWEST	1302	988	1.13
758	2082	RRNES	2404	2,347	1.13
759	2088	SMFLD	2333	1,071	1.13
760	1494	TATSP	4312	2,556	1.13
761	2968	WATSN	5372	1,338	1.13
762	503	WEAST	0618	849	1.13
763	642	ADMDS	6511	467	1.12

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
764	90	AZLES	2122	2,377	1.12
765	2066	BBTWN	1504	2,100	1.12
766	920	FSCRK	6732	2,375	1.12
767	442	LFEST	1902	1,100	1.12
768	803	MSLSW	0007	403	1.12
769	2373	PFFRD	3421	853	1.12
770	2430	TYEST	1511	877	1.12
771	1322	BDFWD	8921	684	1.11
772	1777	BOWEN	3181	770	1.11
773	829	COLNY	2401	762	1.11
774	212	TYLNW	1910	739	1.11
775	506	CKRHL	0006	51	1.10
776	14	DALLW	0001	1,118	1.10
777	165	GATOR	6421	21	1.10
778	714	GLNHV	3931	1,334	1.10
779	686	GNSVN	1403	306	1.10
780	749	MDWCK	0008	1,258	1.10
781	N/A	NADAM	2102	10	1.10
782	1590	PALRD	2206	1,554	1.10
783	2765	ARMST	0005	1,515	1.09
784	21	BLMND	3223	491	1.09
785	2013	FLAND	1312	136	1.09
786	1962	FRNKF	0005	1,105	1.09
787	1365	LWRDR	0004	806	1.09
788	N/A	MDDTN	4341	825	1.09
789	736	MESQW	1801	2,105	1.09
790	N/A	MLFRD	2153	11	1.09
791	2361	ROWLT	1102	1,173	1.09
792	N/A	WILLO	7822	23	1.09
793	1551	ALDTU	9412	1,154	1.08
794	457	BEALS	9521	204	1.08
795	3040	COLNY	2405	1,697	1.08
796	1876	CRLUD	1304	1,950	1.08
797	2309	DALLW	0007	1,532	1.08
798	2492	GLNHV	3973	1,567	1.08
799	305	GMINI	5821	2,067	1.08
800	N/A	GRADY	2108	40	1.08
801	2432	LEMON	0001	2,326	1.08
802	1318	MESQT	1308	1,875	1.08
803	1330	NLNVL	2003	762	1.08
804	1918	PCOIT	1024	2,363	1.08
805	313	RRNES	2405	4,748	1.08
806	3183	TMNTH	1607	12	1.08
807	2094	TRLNW	1204	584	1.08
808	2386	WTAUG	4612	1,297	1.08
809	840	CKRHL	0002	435	1.07
810	1548	CNEXP	0002	1,171	1.07
811	2914	ELZCK	4921	3,279	1.07

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
812	1593	FSTVW	0007	1,582	1.07
813	2264	GRADY	2107	165	1.07
814	1326	LOMAL	0012	753	1.07
815	673	LWSNR	2242	1,620	1.07
816	892	MAPLE	0002	1,290	1.07
817	778	PNTIS	0252	652	1.07
818	1543	ROWLT	1105	1,601	1.07
819	154	RSNHT	1142	1,200	1.07
820	3064	ALNTH	2832	1,183	1.06
821	2659	BRHLW	7622	1,092	1.06
822	1140	DNISN	1203	1,822	1.06
823	1945	ELGIN	1001	633	1.06
824	819	EULTB	5712	1,838	1.06
825	2776	FHLSW	1332	574	1.06
826	1300	FINKS	1801	1,827	1.06
827	39	IRVNR	1557	3,218	1.06
828	2921	LSCOL	2138	2,944	1.06
829	3023	ROWLT	1106	1,351	1.06
830	578	VLARN	2953	2,659	1.06
831	1278	WDGWD	1541	1,146	1.06
832	2153	ALPHA	0003	874	1.05
833	1960	CRLTR	2053	1,750	1.05
834	664	CRTLD	4712	1,185	1.05
835	2872	FRMBR	1808	686	1.05
836	2825	HKBRY	1103	395	1.05
837	783	ROLTR	2921	2,504	1.05
838	937	SCSES	1201	279	1.05
839	3018	WEAST	0627	256	1.05
840	456	WMRNR	0001	210	1.05
841	369	WSMWS	9821	1,464	1.05
842	930	BLKST	1752	1,460	1.04
843	64	CDHCR	2054	1,556	1.04
844	738	CLMET	0002	1,749	1.04
845	3099	COTRD	0004	104	1.04
846	987	GVFTW	1802	1,113	1.04
847	2799	HMPHL	2781	388	1.04
848	2134	HRSMD	1955	2,128	1.04
849	3016	MESQW	1805	85	1.04
850	890	PROAD	0008	1,232	1.04
851	1010	RSNHT	1152	1,052	1.04
852	58	TYLGE	1311	882	1.04
853	2395	WEAST	0615	465	1.04
854	3188	WMMMR	2708	24	1.04
855	N/A	WXHCH	1206	539	1.04
856	2477	CDHIL	1613	2,690	1.03
857	2179	CMINO	1202	1,034	1.03
858	2110	EMPCT	0001	33	1.03
859	2909	FRMBG	1751	815	1.03

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
860	340	HRSMD	1907	3,081	1.03
861	2820	LOMAL	0007	159	1.03
862	2801	TYSTH	1208	251	1.03
863	1013	WSOTH	1017	1,769	1.03
864	2249	ALLNC	6421	52	1.02
865	763	BAKKE	6911	326	1.02
866	1027	BNTDR	0001	1,500	1.02
867	1101	CMINO	1205	1,095	1.02
868	2868	CRLTR	2001	2,499	1.02
869	1419	DALWT	2911	346	1.02
870	1065	PCOIT	1022	2,122	1.02
871	2843	RRSTH	1707	641	1.02
872	2953	WTAUG	4651	765	1.02
873	775	ALKLK	4212	162	1.01
874	2790	CHROW	0006	95	1.01
875	3098	COTRD	0001	341	1.01
876	2437	DAVST	0001	595	1.01
877	2336	FARON	4021	273	1.01
878	2939	JKSNR	4105	88	1.01
879	2942	PRKRW	3372	670	1.01
880	2287	PRKWY	1532	2,319	1.01
881	N/A	PWEST	1305	373	1.01
882	1431	RECCR	0004	67	1.01
883	2933	RSPCK	2133	2,243	1.01
884	822	STAUG	0001	719	1.01
885	428	ALLNC	6412	2,254	1.00
886	209	AMLIA	0007	66	1.00
887	2378	BLMED	1617	349	1.00
888	2516	BRTRD	7321	2,770	1.00
889	2478	CNTRD	0003	1,404	1.00
890	774	CRNRD	0005	351	1.00
891	747	CRWLY	7022	4,188	1.00
892	93	FORSW	2015	751	1.00
893	1833	HLSBR	1203	1,808	1.00
894	2983	IRLBJ	3222	1,038	1.00
895	152	IRVNR	1508	2,049	1.00
896	3054	LFSTH	1405	207	1.00
897	1092	LFSTH	1408	2,362	1.00
898	2618	WALST	0008	12	1.00
899	400	WXNTH	2308	2,083	1.00
900	348	CMPST	0003	222	0.99
901	2200	CRLFR	2157	2,462	0.99
902	132	DAVST	0008	99	0.99
903	855	MSLSW	0002	1,076	0.99
904	153	RRWES	1623	2,685	0.99
905	3180	STAGE	3811	4,788	0.99
906	N/A	STAGE	3821	4,112	0.99
907	2049	STERT	2706	1,196	0.99

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
908	2641	SYCRK	4511	1,895	0.99
909	604	BLMND	3252	1,096	0.98
910	2298	BNDRA	0011	413	0.98
911	1968	BRELN	7911	222	0.98
912	741	DALLW	0005	123	0.98
913	3122	FRMNT	0005	82	0.98
914	317	HNTNG	1302	43	0.98
915	2181	HSKAV	0006	876	0.98
916	964	LSCOL	2114	247	0.98
917	1380	NSMFD	4201	372	0.98
918	161	TRNDD	1201	488	0.98
919	1036	DGNST	0001	307	0.97
920	336	DIBOL	1506	575	0.97
921	194	MDWCK	0005	1,038	0.97
922	1851	MURPH	2752	1,212	0.97
923	2156	PRKWY	1521	2,446	0.97
924	2701	SANSM	3921	1,574	0.97
925	2113	SYCRK	4512	4,848	0.97
926	372	ESTLD	3621	1,581	0.96
927	560	HLTOM	2431	1,313	0.96
928	845	MCWHT	3522	3,016	0.96
929	2972	MDLNW	1511	840	0.96
930	598	MRSDO	9621	1,944	0.96
931	1031	RRNES	2402	2,118	0.96
932	387	ALDTU	9422	3,107	0.95
933	62	CAMRN	1203	1,288	0.95
934	1659	CHSPG	2412	2,831	0.95
935	347	ELZCK	4922	19	0.95
936	3013	FRMNT	0007	966	0.95
937	N/A	KNEDL	6352	2,821	0.95
938	2234	WKATY	1718	1,766	0.95
939	2642	ARLNG	1271	2,266	0.94
940	2892	ENTOH	0002	1,452	0.94
941	2531	FATES	3003	2,230	0.94
942	1143	HSKAV	0008	808	0.94
943	1259	LFSTH	1407	1,866	0.94
944	3	THSES	2402	948	0.94
945	469	WRIDG	3053	2,804	0.94
946	620	CNTRD	0002	1,469	0.93
947	3134	JKREA	1201	29	0.93
948	3142	MDAIR	2921	126	0.93
949	550	WATCO	2602	2,553	0.93
950	1239	FRNKS	1201	415	0.92
951	138	LMBLN	0004	53	0.92
952	2183	MABNK	2402	1,152	0.92
953	1295	NCDSW	3813	450	0.92
954	1354	RANGR	4321	817	0.92
955	927	RWALS	1853	2,538	0.92

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
956	793	THRNE	0004	752	0.92
957	601	WHOUS	4128	375	0.92
958	991	WTAUG	4631	1,152	0.92
959	982	BNBOR	1202	857	0.91
960	2438	DCATR	1201	1,388	0.91
961	1214	DNISN	1205	1,654	0.91
962	411	EMMAS	4022	54	0.91
963	1871	GRLWS	1706	296	0.91
964	2015	HLSES	0561	1,825	0.91
965	112	RYSSW	2804	2,757	0.91
966	3088	AIRPK	8422	29	0.90
967	908	LVBRD	0004	1,183	0.90
968	2976	RWDHV	1903	1,248	0.90
969	3184	TMPSE	1501	649	0.90
970	3017	TMPSE	1512	429	0.90
971	1	VENSW	2601	1,198	0.90
972	3094	BRHLW	7641	54	0.89
973	2592	BRHLW	7642	1,002	0.89
974	85	BRNSY	1221	45	0.89
975	1209	DNCNV	1901	905	0.89
976	646	EDGCF	2211	2,106	0.89
977	3153	NCSTH	1505	19	0.89
978	2352	PCUST	2010	2,267	0.89
979	390	RKDLN	1401	925	0.89
980	2401	WNDRC	0221	595	0.89
981	2487	HURST	1872	2,217	0.88
982	2037	INAIR	1423	735	0.88
983	1349	MESWE	3611	1,869	0.88
984	961	SBEAN	6011	52	0.88
985	776	AZLES	2111	2,504	0.87
986	497	AZLES	2112	1,836	0.87
987	2832	ITSCA	1702	242	0.87
988	1818	MIDWY	0611	126	0.87
989	1207	WHOUS	4122	1,770	0.87
990	1926	WITTS	1705	1,728	0.87
991	1268	BNEST	3121	6,464	0.86
992	957	JSHUA	1302	1,434	0.86
993	288	MDDTN	4331	1,215	0.86
994	932	RGFTW	6841	29	0.86
995	50	CRISP	1501	295	0.85
996	1909	DUPUY	1219	945	0.85
997	1601	FRMBG	1702	61	0.85
998	925	MAPOI	1201	163	0.85
999	1783	MEXIA	4011	1,063	0.85
1000	1310	MNRVA	1301	760	0.85
1001	191	MRNFD	2331	41	0.85
1002	143	CRKET	2401	152	0.84
1003	1839	DLEON	0111	852	0.84

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
1004	648	DNIWS	1601	1,132	0.84
1005	3078	FATES	3001	2,369	0.84
1006	1676	FERIS	1103	1,391	0.84
1007	871	IRVNR	1559	2,633	0.84
1008	903	MAYFD	5511	2,723	0.84
1009	2190	MDWCK	0001	799	0.84
1010	563	REYST	4129	539	0.84
1011	1342	SWDTN	1631	1,570	0.84
1012	1687	EZACH	0001	996	0.83
1013	1528	FRFWS	3002	862	0.83
1014	215	KLBRG	0001	1,935	0.83
1015	1515	LNDAL	2204	564	0.83
1016	1235	RRSTH	1708	4,395	0.83
1017	751	WALST	0015	918	0.83
1018	1219	WEAST	0617	1,424	0.83
1019	1742	WHITE	3511	1,308	0.83
1020	440	WICKT	0411	117	0.83
1021	1766	WRTHM	5012	327	0.83
1022	1760	BNBRK	4111	2,907	0.82
1023	545	CNTRY	2822	2,825	0.82
1024	1407	DENAV	0622	913	0.82
1025	522	ECTHM	3311	1,625	0.82
1026	597	EDGWD	1102	979	0.82
1027	127	GRDNE	9211	499	0.82
1028	607	HKHTS	1601	1,540	0.82
1029	899	HSKAV	0003	1,558	0.82
1030	1757	IRVBL	2505	503	0.82
1031	1292	MNSTR	1201	687	0.82
1032	1296	PLSTH	1301	918	0.82
1033	30	SBEAN	6012	85	0.82
1034	2591	WFALS	0124	159	0.82
1035	1725	BLKST	1762	1,021	0.81
1036	2396	BRCRK	6524	809	0.81
1037	3041	CRNSO	3911	535	0.81
1038	445	LVOAK	1602	1,121	0.81
1039	311	TROYS	1013	1,137	0.81
1040	2098	WELRD	0006	710	0.81
1041	1505	WOVER	6142	2,114	0.81
1042	1884	CLBNR	1411	618	0.80
1043	492	COPEL	3051	915	0.80
1044	423	MCKMY	0822	1,425	0.80
1045	139	NCSTH	1506	101	0.80
1046	2074	PLANO	1104	1,572	0.80
1047	1964	PLGRV	0001	1,200	0.80
1048	490	CLCTY	1021	740	0.79
1049	282	ELKTN	2508	1,206	0.79
1050	1454	PLSTN	1005	1,911	0.79
1051	1339	RBNSN	2504	1,794	0.79

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
1052	1320	RKDLE	1302	1,162	0.79
1053	1568	WMMMR	2707	1,572	0.79
1054	306	ARTHR	0462	214	0.78
1055	1599	ATHNW	1402	557	0.78
1056	1258	CLBWS	8112	1,722	0.78
1057	1550	HURST	1822	1,577	0.78
1058	547	OVRTN	4037	98	0.78
1059	2501	WMMMR	2702	1,884	0.78
1060	1062	COMSO	1401	668	0.77
1061	1185	CRNTH	2405	4,384	0.77
1062	N/A	ELKHR	1502	215	0.77
1063	2311	LTVSB	5432	2,075	0.77
1064	1379	MEXIA	4007	460	0.77
1065	2167	MOSSW	4632	1,058	0.77
1066	2524	ODNTH	2073	2,841	0.77
1067	1316	CLBRN	1204	1,331	0.76
1068	29	FLINT	3211	1,966	0.76
1069	2550	FSCRK	6724	1,403	0.76
1070	652	MABNK	2404	1,671	0.76
1071	1680	RCHLD	2101	756	0.76
1072	2334	RNDRK	1503	3,936	0.76
1073	3173	RSPCK	2103	176	0.76
1074	1637	WGROB	8412	1,091	0.76
1075	482	BNBRK	4121	1,433	0.75
1076	198	HUTTO	2742	3,189	0.75
1077	975	IOWPK	0811	827	0.75
1078	310	MCDMT	2554	2,447	0.75
1079	364	MRTSP	1504	722	0.75
1080	2019	ODNTH	2024	1,513	0.75
1081	967	PEGAS	2312	239	0.75
1082	59	RKCRK	6112	1,605	0.75
1083	1761	DAVST	0007	534	0.74
1084	1536	DCATR	1202	1,820	0.74
1085	54	LSCOL	2116	122	0.74
1086	3147	MNWLL	1201	27	0.74
1087	1032	PGSTH	7021	38	0.74
1088	2822	TYLGE	1313	2,151	0.74
1089	1231	WHTRK	0006	1,381	0.74
1090	3014	HMPHL	2733	223	0.73
1091	2916	IRVNR	1510	704	0.73
1092	618	KILEN	1205	1,410	0.73
1093	523	KLELM	2205	3,488	0.73
1094	1639	PKRMX	4703	3,276	0.73
1095	1156	POWEL	2706	268	0.73
1096	2212	RRSTH	1705	4,400	0.73
1097	1307	GDPRW	9611	1,335	0.72
1098	1389	GLSCN	6211	101	0.72
1099	1981	LOMAL	0001	716	0.72

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
1100	2439	PLKST	0001	651	0.72
1101	396	CWIND	6311	31	0.71
1102	2428	LKWOD	7442	731	0.71
1103	2520	PRKWY	1511	1,355	0.71
1104	1957	RDOAK	1303	1,774	0.71
1105	357	ARPMN	4149	347	0.70
1106	1630	ATHNS	1203	1,111	0.70
1107	2490	BAKKE	6912	1,534	0.70
1108	1433	DAVIS	3743	133	0.70
1109	1740	HILCR	7321	2,473	0.70
1110	371	MOSSW	4612	1,800	0.70
1111	759	REAST	1502	1,456	0.70
1112	1153	SHMNE	1401	1,290	0.70
1113	753	TATSP	4322	2,587	0.70
1114	2294	THORN	6821	1,499	0.70
1115	2295	WBOSE	1103	1,033	0.70
1116	1487	BLMED	1621	628	0.69
1117	465	HUTCH	1501	1,374	0.69
1118	1541	IOWPK	0831	1,118	0.69
1119	379	MCKMY	0821	2,015	0.69
1120	261	CPLSO	4322	322	0.68
1121	706	CRLUD	1307	284	0.68
1122	1090	DALWT	2991	1,221	0.68
1123	3081	GLNHV	3992	2,506	0.68
1124	330	KFMNW	1201	1,059	0.68
1125	2382	MTLDA	0003	1,935	0.68
1126	1327	TMPNW	1104	1,953	0.68
1127	2611	TYRSW	1701	1,448	0.68
1128	1128	BLTSW	3212	2,599	0.67
1129	1416	DPCRK	1821	1,619	0.67
1130	963	KNLTR	0011	1,864	0.67
1131	1953	MESTE	1202	951	0.67
1132	1611	PBELL	4821	161	0.67
1133	320	RSNHT	1131	2,610	0.67
1134	277	TSLVL	4001	1,468	0.67
1135	1671	WXNTH	2305	434	0.67
1136	1406	DCVSO	1106	1,230	0.66
1137	2751	FRMBG	1705	277	0.66
1138	489	IRVBL	2507	911	0.66
1139	1064	LFSTH	1406	1,734	0.66
1140	1149	LNCST	1605	847	0.66
1141	2464	MURPH	2754	2,681	0.66
1142	2628	PARIS	1204	1,134	0.66
1143	1529	RTHGB	1421	1,574	0.66
1144	1523	BRNWD	1203	904	0.65
1145	806	CLBWS	8121	711	0.65
1146	77	JNDAY	3311	770	0.65
1147	163	LMESA	2813	119	0.65

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
1148	1533	MDTHN	1701	1,944	0.65
1149	1429	MESQW	1808	1,343	0.65
1150	1331	NPKWY	0010	3,021	0.65
1151	240	PREST	1604	1,487	0.65
1152	1711	TMSTH	1402	1,694	0.65
1153	1340	TRNTY	7511	1,428	0.65
1154	430	WINKS	0531	37	0.65
1155	1001	WSANG	2802	638	0.65
1156	1217	WTHRF	2001	1,302	0.65
1157	1208	CDHCR	2055	1,325	0.64
1158	3070	DEALY	0003	655	0.64
1159	1971	FLAND	1311	120	0.64
1160	704	HUTCH	1503	767	0.64
1161	1728	LKBLT	2107	1,204	0.64
1162	1801	LNCST	1604	657	0.64
1163	2609	MKNSW	1603	1,928	0.64
1164	2588	OAKCK	2211	36	0.64
1165	784	PCUST	2009	2,268	0.64
1166	787	STAUG	0008	2,099	0.64
1167	606	WWDWY	2020	1,369	0.64
1168	1063	CDCSW	0001	277	0.63
1169	1982	CHALK	0911	63	0.63
1170	1788	DAVST	0005	1,874	0.63
1171	2351	EDWDS	5921	16	0.63
1172	671	ELCTR	1221	92	0.63
1173	1398	ENNIS	1904	1,299	0.63
1174	1134	MNWLL	1203	901	0.63
1175	401	RRSTH	1703	3,860	0.63
1176	2414	WATCO	2605	5,501	0.63
1177	2625	WNRTH	1416	733	0.63
1178	1264	BKBNT	1832	188	0.62
1179	2150	BSPRW	2511	1,019	0.62
1180	1936	ENTOH	0003	13	0.62
1181	2180	HKHTS	1605	1,482	0.62
1182	2354	RRSTH	1706	3,131	0.62
1183	894	WSTON	3201	1,417	0.62
1184	479	BNBOR	1201	867	0.61
1185	1908	BNDRA	0004	730	0.61
1186	1108	BRCRK	6522	2,258	0.61
1187	65	COMRC	1203	725	0.61
1188	1260	FORSW	2025	675	0.61
1189	265	MDDTN	4312	405	0.61
1190	988	MDLNE	0112	481	0.61
1191	2003	MDTHS	1001	1,875	0.61
1192	2889	RWALS	1854	566	0.61
1193	2289	SHRSW	6631	1,289	0.61
1194	581	SSPNG	1201	939	0.61
1195	1808	VANAL	2412	1,958	0.61

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
1196	2247	VLARN	2957	500	0.61
1197	978	WINKS	0521	44	0.61
1198	157	WMRLD	0007	1,702	0.61
1199	1385	BLTLN	0005	891	0.60
1200	429	BRGPR	1102	1,649	0.60
1201	241	CRKET	2405	321	0.60
1202	2371	HORNE	1934	1,648	0.60
1203	2526	KNOTT	5221	62	0.60
1204	1647	LNDAL	2202	1,499	0.60
1205	3144	MESTE	1201	25	0.60
1206	N/A	OILML	3611	773	0.60
1207	1642	ROBNW	1503	1,777	0.60
1208	N/A	TLRWT	2223	161	0.60
1209	811	VENSW	2602	157	0.60
1210	2157	WTAUG	4643	999	0.60
1211	1832	BLAGG	3911	603	0.59
1212	1524	DCVSO	1103	1,857	0.59
1213	1366	DCVSO	1104	1,371	0.59
1214	1181	FSCRK	6713	3,862	0.59
1215	1413	KLNTF	1804	1,001	0.59
1216	1336	MLDR2	1601	423	0.59
1217	1854	RNDRK	1509	1,417	0.59
1218	1668	SHNRW	1608	1,487	0.59
1219	692	SWDTN	1621	708	0.59
1220	1689	BEAST	4090	1,105	0.58
1221	116	DIBOL	1507	561	0.58
1222	2062	DNISN	1201	1,519	0.58
1223	3072	LEMON	0002	985	0.58
1224	2682	LENSW	0321	69	0.58
1225	2918	SYCRK	4521	3,534	0.58
1226	1859	ANDNR	2222	126	0.57
1227	1526	BNMAG	1202	687	0.57
1228	2051	BSPSW	0841	702	0.57
1229	1245	COVEE	3405	1,443	0.57
1230	1309	CRSCN	1203	2,021	0.57
1231	983	ECTOR	1201	398	0.57
1232	N/A	ELKHR	1501	781	0.57
1233	552	GRLRD	0002	1,150	0.57
1234	248	GRLRD	0004	1,534	0.57
1235	N/A	LFKHL	2102	2,536	0.57
1236	977	LNGLK	1602	653	0.57
1237	190	LOVNG	2512	42	0.57
1238	2582	WWDWD	3631	316	0.57
1239	2614	ARTHR	0422	1,074	0.56
1240	799	ATHNS	1201	1,038	0.56
1241	2279	CMPBW	2102	742	0.56
1242	1903	CMPWI	0005	1,639	0.56
1243	1574	FARON	4041	1,001	0.56

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
1244	279	HKHTS	1602	1,036	0.56
1245	1479	KLNCC	1703	1,808	0.56
1246	631	KRUMS	1204	1,922	0.56
1247	2112	PSHIL	1602	1,095	0.56
1248	1252	REYST	4040	570	0.56
1249	1277	RNDRK	1501	782	0.56
1250	1530	WESTS	1601	1,124	0.56
1251	1187	WTHRF	2002	1,451	0.56
1252	217	ALVDO	1902	1,205	0.55
1253	1672	CLBRN	1201	1,829	0.55
1254	1506	DALWT	2931	1,595	0.55
1255	1334	FHLSW	1351	1,229	0.55
1256	864	FRMBR	1807	848	0.55
1257	992	FSTVW	0001	796	0.55
1258	426	JKWST	4033	790	0.55
1259	2417	JUDCT	0004	218	0.55
1260	2100	KFMSO	1301	828	0.55
1261	N/A	LKCRS	4211	1,520	0.55
1262	206	LMESA	1522	1,389	0.55
1263	2684	MLKF2	1202	462	0.55
1264	2943	RDRSE	2601	3,778	0.55
1265	1682	RKDLE	1301	1,224	0.55
1266	1787	SPRDL	4821	1,351	0.55
1267	2020	THRNE	0003	2,009	0.55
1268	1976	TIODE	9632	447	0.55
1269	1571	WDGWD	1581	613	0.55
1270	2385	WEBBS	8624	2,388	0.55
1271	2217	ARMST	0006	1,868	0.54
1272	314	CMPWI	0001	1,975	0.54
1273	1587	CPRCV	1401	1,870	0.54
1274	99	CTFLD	9921	935	0.54
1275	949	HUDSN	1605	1,583	0.54
1276	1891	MESQN	1502	1,207	0.54
1277	N/A	PSHIL	1607	1,155	0.54
1278	2599	TMPNW	1101	2,421	0.54
1279	1019	TMSTH	1408	766	0.54
1280	144	BRELN	7921	634	0.53
1281	2410	CLLVL	0003	1,666	0.53
1282	3050	DGNST	0004	1,455	0.53
1283	2265	GRPVN	8222	2,342	0.53
1284	51	KRGRV	2401	51	0.53
1285	2888	LUFKN	1204	75	0.53
1286	2457	MESQN	1504	1,358	0.53
1287	2714	PCUST	2012	1,830	0.53
1288	47	PPARK	1803	1,057	0.53
1289	827	RCLNS	1405	638	0.53
1290	171	RRNES	2401	2,592	0.53
1291	1045	WMRLD	0008	1,591	0.53

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
1292	2377	ADISN	1601	1,025	0.52
1293	1440	ATHNS	1202	790	0.52
1294	25	CRNES	2712	63	0.52
1295	356	JEWET	1204	1,335	0.52
1296	1363	JKSBR	1402	1,375	0.52
1297	970	MDFRM	2111	77	0.52
1298	600	PREST	1602	1,691	0.52
1299	2033	SPRDL	4812	1,211	0.52
1300	43	TMPLE	1205	2,687	0.52
1301	1874	AYERS	4421	1,545	0.51
1302	584	CMINO	1206	1,110	0.51
1303	2742	GRDPR	0891	2,439	0.51
1304	1939	LEMON	0011	1,375	0.51
1305	3047	LIGSW	1623	801	0.51
1306	1047	LKBLT	2103	2,311	0.51
1307	2135	LOMAL	0006	1,404	0.51
1308	2683	MDLNW	1513	3,055	0.51
1309	2777	MKNKY	1203	1,184	0.51
1310	1041	TYLER	1005	1,717	0.51
1311	2027	WCOLO	1315	1,692	0.51
1312	660	WMRLD	0006	619	0.51
1313	2176	AMMFG	5611	815	0.50
1314	2028	BLKRV	8311	46	0.50
1315	976	BONHM	1204	885	0.50
1316	1496	DNINR	1404	196	0.50
1317	587	FINKS	1804	2,447	0.50
1318	N/A	GUNSO	9912	24	0.50
1319	1828	NCRST	2201	2,025	0.50
1320	1604	OAKHL	3041	1,106	0.50
1321	632	PKRVL	1051	4,179	0.50
1322	712	TYBLR	2808	1,295	0.50
1323	2782	WATSN	5352	1,895	0.50
1324	1662	WOVER	6122	1,765	0.50
1325	945	BKWST	0007	1,758	0.49
1326	87	BLISS	9421	263	0.49
1327	2785	COLNY	2402	2,421	0.49
1328	2420	FSHSW	2121	1,761	0.49
1329	1265	IRASB	3211	274	0.49
1330	2878	IRLBJ	3212	3,606	0.49
1331	2511	MKNKY	1201	1,326	0.49
1332	1404	PKRVL	1052	4,218	0.49
1333	1223	PLSTH	1305	531	0.49
1334	539	ALLEN	2403	2,778	0.48
1335	1396	BLSRA	1602	163	0.48
1336	504	CRNDL	2401	523	0.48
1337	2994	FRMBG	1706	66	0.48
1338	2235	KLNTF	1801	1,121	0.48
1339	867	WHTRK	0002	1,425	0.48

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
1340	1212	WOVER	6151	1,738	0.48
1341	1698	WSOTH	1020	1,193	0.48
1342	698	CDHIL	1802	1,941	0.47
1343	1382	DNCNV	1902	1,056	0.47
1344	1719	FRMBG	1703	30	0.47
1345	830	GNSVL	1213	780	0.47
1346	2080	GRLND	1606	975	0.47
1347	807	JACKR	7621	354	0.47
1348	559	KRGRV	2405	2,748	0.47
1349	1427	LFEST	1901	1,526	0.47
1350	122	LFKHL	2103	447	0.47
1351	1441	LKBLT	2101	1,603	0.47
1352	258	MNWLL	1207	2,288	0.47
1353	1931	MSHLN	0006	1,098	0.47
1354	1012	NYLDV	1201	712	0.47
1355	1409	WNDWD	3611	499	0.47
1356	1137	ALPHA	0006	293	0.46
1357	1925	DESHR	1203	1,448	0.46
1358	1447	EULSO	9122	1,340	0.46
1359	824	FRNKF	0002	930	0.46
1360	665	GODRD	8122	1,062	0.46
1361	2293	GODRD	8142	814	0.46
1362	2571	LIPAN	1303	330	0.46
1363	966	MDLNW	1541	2,149	0.46
1364	1708	NCRST	2204	1,961	0.46
1365	2063	ODESA	0261	439	0.46
1366	1502	PCOIT	1007	778	0.46
1367	2807	TNSCL	1104	211	0.46
1368	1820	WRBND	2311	1,450	0.46
1369	1893	WSOTH	1021	2,178	0.46
1370	551	ANASE	1903	3,673	0.45
1371	527	ARTHR	0431	496	0.45
1372	733	EZACH	0004	1,165	0.45
1373	2224	MDTHS	1004	1,796	0.45
1374	1762	MLDR2	1603	560	0.45
1375	1879	MNWLL	1206	1,183	0.45
1376	2564	PNTGO	7111	745	0.45
1377	1279	RDLML	2552	288	0.45
1378	814	ROANW	9521	3,058	0.45
1379	1595	BRNWD	1202	448	0.44
1380	1699	CRLTN	1401	822	0.44
1381	2757	CRLTR	2004	241	0.44
1382	2885	ENTOH	0007	1,012	0.44
1383	3031	GAVSW	0010	494	0.44
1384	1151	IRVNE	1309	590	0.44
1385	2805	LWSNR	2212	1,502	0.44
1386	507	MDWCK	0007	1,081	0.44
1387	1633	PCOIT	1001	1,116	0.44

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
1388	2216	PLKST	0002	893	0.44
1389	1048	SMPST	0004	1,757	0.44
1390	633	SPRDL	4831	1,323	0.44
1391	2865	VENSW	2604	27	0.44
1392	1868	WRBND	2312	1,484	0.44
1393	2323	ALPHA	0008	1,230	0.43
1394	1830	BDFRD	8821	913	0.43
1395	2126	CMBTP	1201	277	0.43
1396	1414	CRSCN	1201	815	0.43
1397	1573	CRYVE	3011	306	0.43
1398	1256	DNINR	1403	1,269	0.43
1399	3046	FRMNT	0002	651	0.43
1400	1480	FSCRK	6711	3,773	0.43
1401	70	GDPRW	9621	1,685	0.43
1402	319	INDIA	2501	803	0.43
1403	1559	IRVGS	1904	983	0.43
1404	1232	KNEDL	6313	2,482	0.43
1405	2627	MOSSW	4621	1,997	0.43
1406	2408	NLNVL	2001	561	0.43
1407	493	OAKHL	3031	644	0.43
1408	1077	PWEST	1301	1,263	0.43
1409	2228	TATSP	4323	2,498	0.43
1410	1291	TYEST	1503	1,067	0.43
1411	2240	WHTRK	0008	1,792	0.43
1412	2515	BRNAV	0723	1,363	0.42
1413	1861	EDDYS	0425	430	0.42
1414	1028	HLTOM	2482	1,063	0.42
1415	1983	HURST	1861	1,846	0.42
1416	1449	IRVNG	1406	1,280	0.42
1417	2186	IRVNG	1407	1,468	0.42
1418	183	JSHUA	1301	1,132	0.42
1419	17	MABNK	2401	2,462	0.42
1420	1773	PALRD	2203	1,121	0.42
1421	816	SGOVL	1405	1,505	0.42
1422	1109	SMFLD	2313	2,132	0.42
1423	839	STAUG	0007	1,205	0.42
1424	1805	TMSTH	1405	530	0.42
1425	1084	WXNTH	2303	2,281	0.42
1426	1144	BONHM	1202	762	0.41
1427	74	BRNWD	1204	1,051	0.41
1428	1182	CADDO	0911	466	0.41
1429	1527	CKRHL	0004	432	0.41
1430	1772	DNCNV	1903	1,208	0.41
1431	1352	GNSVL	1203	1,652	0.41
1432	1100	GRLTC	3803	1,172	0.41
1433	2877	HOLDY	0911	738	0.41
1434	2473	IRVVV	2853	3,910	0.41
1435	227	MNWLW	1401	1,563	0.41

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
1436	2474	ODESA	0252	792	0.41
1437	2581	WEBBS	8622	1,743	0.41
1438	1670	WTAUG	4613	1,853	0.41
1439	1795	ALDTU	9421	1,171	0.40
1440	N/A	BHILL	1921	68	0.40
1441	2586	BLMED	1622	1,029	0.40
1442	1581	CLBNR	1404	1,344	0.40
1443	2647	CNTRY	2862	746	0.40
1444	1785	DESPR	1405	915	0.40
1445	1654	EDGCF	2231	451	0.40
1446	558	GSTHW	1644	954	0.40
1447	1996	LNCST	1603	1,943	0.40
1448	1417	MCWHT	3512	1,475	0.40
1449	1293	MTLDA	0001	2,455	0.40
1450	N/A	MTLDA	0005	1,779	0.40
1451	841	RBNSN	2501	2,058	0.40
1452	849	SMFLD	2352	610	0.40
1453	895	WNTHW	1116	677	0.40
1454	1852	ADISN	1604	1,159	0.39
1455	2783	BARNW	4522	99	0.39
1456	219	CDHCR	2052	1,504	0.39
1457	404	CLKVL	1203	596	0.39
1458	1715	DESPR	1407	944	0.39
1459	2631	EULSO	9131	1,993	0.39
1460	605	LNDAL	2201	2,163	0.39
1461	549	LUFKN	1202	1,116	0.39
1462	1700	RCHRD	1208	1,010	0.39
1463	1986	RNDRK	1505	1,322	0.39
1464	1636	RNDRK	1507	2,919	0.39
1465	1829	SCURY	1911	141	0.39
1466	677	SLAKE	8321	1,205	0.39
1467	2175	STNVL	1203	2,557	0.39
1468	2025	ARLNG	1213	1,329	0.38
1469	3093	BLMND	3272	16	0.38
1470	1129	COMSO	1402	954	0.38
1471	1203	CRLTN	1407	1,550	0.38
1472	574	DAVIS	3711	678	0.38
1473	2103	DEALY	0005	1,412	0.38
1474	239	GODRD	8131	896	0.38
1475	1517	HMTRD	0001	1,000	0.38
1476	1124	HOLDY	0921	1,166	0.38
1477	754	HURST	1831	1,468	0.38
1478	838	INAIR	1442	129	0.38
1479	1912	IRVHF	2302	1,409	0.38
1480	1095	LKHLD	0004	1,272	0.38
1481	1364	MAYFD	5524	2,753	0.38
1482	1519	MRKLY	0811	113	0.38
1483	2056	PCOIT	1003	1,504	0.38

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
1484	1434	PREST	1601	1,250	0.38
1485	2806	RCHHL	0374	564	0.38
1486	2362	STAUG	0002	1,401	0.38
1487	534	TAYLR	1204	2,042	0.38
1488	1241	TRNTH	1502	620	0.38
1489	1176	TRNTY	7551	1,591	0.38
1490	538	TYEST	1508	677	0.38
1491	796	WALST	0017	971	0.38
1492	2866	WATSN	5342	2,108	0.38
1493	463	WGROB	8421	5,039	0.38
1494	1194	WHITE	3512	1,660	0.38
1495	453	ACRLY	1721	57	0.37
1496	1591	BDFRD	8831	873	0.37
1497	1570	BOWEN	3171	1,690	0.37
1498	1202	COMRC	1201	1,005	0.37
1499	2673	CRLJL	1504	1,313	0.37
1500	1426	CRLUD	1305	1,716	0.37
1501	588	DESPR	1402	1,357	0.37
1502	2425	DUVAL	0452	1,590	0.37
1503	729	ENSSO	2002	1,589	0.37
1504	488	FARON	4011	622	0.37
1505	324	GAVSW	0006	795	0.37
1506	2605	GRMES	0521	558	0.37
1507	1308	HRSMD	1951	4,432	0.37
1508	2737	KRUMS	1202	881	0.37
1509	887	LFSTH	1404	497	0.37
1510	1727	MESFR	2102	681	0.37
1511	285	MIDNT	3721	3,632	0.37
1512	721	PFFRD	3482	1,103	0.37
1513	2008	RCLNS	1406	527	0.37
1514	1741	RSNHT	1171	2,423	0.37
1515	2749	TYOMN	1401	782	0.37
1516	1882	VALVW	1802	491	0.37
1517	329	WEBBS	8623	3,339	0.37
1518	2431	WOVER	6131	2,466	0.37
1519	531	ATHNW	1403	2,206	0.36
1520	1183	CLBRN	1202	1,096	0.36
1521	1271	CRLJL	1503	751	0.36
1522	125	CRLTN	1406	1,201	0.36
1523	576	CRSCN	1206	1,573	0.36
1524	2194	ECTHM	3322	2,297	0.36
1525	321	HOWRD	3921	25	0.36
1526	2404	HSKAV	0002	1,918	0.36
1527	2946	IRVNG	1403	529	0.36
1528	2023	LWSNR	2231	799	0.36
1529	2496	PERIN	1511	704	0.36
1530	2391	PLKST	0005	1,376	0.36
1531	2512	PNTGO	7121	1,493	0.36

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
1532	1648	RCHHL	0311	975	0.36
1533	2483	RENSW	3124	2,185	0.36
1534	3170	RNGMG	8421	11	0.36
1535	1892	RSPCK	2108	955	0.36
1536	1627	SHMNE	1403	1,018	0.36
1537	500	TMPLE	1204	1,084	0.36
1538	2680	TYLNE	1613	481	0.36
1539	N/A	TYRSW	1704	1,360	0.36
1540	2619	WCOLO	1318	1,694	0.36
1541	135	WHTRK	0007	1,268	0.36
1542	2065	WDCR	0211	1,309	0.36
1543	2255	WWDWD	3641	1,478	0.36
1544	622	WXHCH	1203	1,387	0.36
1545	1493	ADISN	1603	199	0.35
1546	1759	ALPHA	0001	713	0.35
1547	28	AYERS	4411	1,376	0.35
1548	2229	BDFWD	8941	1,238	0.35
1549	1713	CDHIL	1623	2,413	0.35
1550	416	CMPBW	2101	376	0.35
1551	1952	CRANE	0321	23	0.35
1552	180	CRWLY	7011	362	0.35
1553	2244	EULES	8712	1,071	0.35
1554	2584	GRLRD	0001	1,805	0.35
1555	703	LKWOD	7432	1,633	0.35
1556	773	LWRDR	0001	1,171	0.35
1557	2245	MESFR	2103	428	0.35
1558	777	MESQN	1505	1,453	0.35
1559	2342	MESTE	1211	1,200	0.35
1560	2458	ODESW	5922	2,488	0.35
1561	2117	PARIS	1201	1,101	0.35
1562	802	RSNHT	1162	1,620	0.35
1563	1688	SGOVL	1402	948	0.35
1564	817	SHNRW	1612	933	0.35
1565	2149	SHRSW	6611	1,238	0.35
1566	2977	STNVL	1205	448	0.35
1567	1206	SUNNY	2301	789	0.35
1568	1747	TYBLR	2811	1,348	0.35
1569	1350	TYLER	1001	1,149	0.35
1570	2004	TYSTH	1201	1,515	0.35
1571	420	WEBBS	8631	3,424	0.35
1572	1040	WTAUG	4623	733	0.35
1573	1442	ADISN	1605	1,323	0.34
1574	2719	ATNRN	3421	707	0.34
1575	1098	BLTON	1805	1,584	0.34
1576	367	BRCRK	6513	1,315	0.34
1577	1586	BRNCH	1421	64	0.34
1578	1896	BSPRG	1905	1,622	0.34
1579	1227	BSPSW	0832	1,033	0.34

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
1580	399	DNISN	1202	950	0.34
1581	389	FERIS	1101	989	0.34
1582	546	GRSMN	3027	385	0.34
1583	1973	KILEN	1202	1,763	0.34
1584	1748	KLNCC	1702	3,904	0.34
1585	223	KNLTR	0006	1,733	0.34
1586	1230	MDWCK	0006	1,007	0.34
1587	1775	MKNGB	5312	834	0.34
1588	2899	MKNGB	5331	1,096	0.34
1589	958	MNFLD	2621	2,886	0.34
1590	2269	MNHNS	1912	491	0.34
1591	1880	NHNSW	0007	583	0.34
1592	439	NPKWY	0006	4,912	0.34
1593	2506	ODESW	5912	293	0.34
1594	1313	PARIS	1202	1,269	0.34
1595	1251	PCOIT	1004	731	0.34
1596	68	POYNR	1201	356	0.34
1597	2465	PWEST	1303	1,539	0.34
1598	790	RBNSN	2502	1,358	0.34
1599	529	RRSTH	1701	4,553	0.34
1600	2580	SHDYG	7842	704	0.34
1601	644	SSPNG	1205	1,282	0.34
1602	502	TMPTV	2405	520	0.34
1603	684	TRIRA	6222	1,032	0.34
1604	2651	WRIDG	3054	2,458	0.34
1605	2154	ANDNR	2211	1,148	0.33
1606	1495	AZLES	2123	2,744	0.33
1607	1044	BNMNW	1102	556	0.33
1608	1831	BOWEN	3112	903	0.33
1609	1655	CLYVL	9311	2,239	0.33
1610	1038	COPEL	3055	2,154	0.33
1611	1500	DAVST	0004	1,733	0.33
1612	1933	EDGCF	2241	968	0.33
1613	1073	EULES	8732	640	0.33
1614	1460	EUSTC	2401	1,942	0.33
1615	2320	GODRD	8112	1,443	0.33
1616	1905	GSTHW	1624	2,273	0.33
1617	1465	HORNE	1923	1,465	0.33
1618	1444	IRVNG	1405	1,162	0.33
1619	943	JEWET	1202	777	0.33
1620	1127	LAVON	1404	958	0.33
1621	1266	LRENA	2901	1,024	0.33
1622	2860	LVBRD	0005	1,280	0.33
1623	501	PFFRD	3441	1,197	0.33
1624	570	RSKMN	3046	1,147	0.33
1625	1312	WATCO	2603	1,474	0.33
1626	1563	WEBBS	8614	2,525	0.33
1627	459	ANDRD	0931	98	0.32

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
1628	942	ARMST	0007	126	0.32
1629	951	BDFRD	8822	1,050	0.32
1630	1017	BMTWN	1611	1,925	0.32
1631	224	BRHLW	7621	2,466	0.32
1632	84	BRLSN	2041	2,079	0.32
1633	422	CLCTY	1011	939	0.32
1634	947	DGNST	0008	130	0.32
1635	1102	DNCNV	1906	413	0.32
1636	726	DUVAL	0414	734	0.32
1637	1142	EDGCF	2213	3,185	0.32
1638	3114	EDGCF	2224	133	0.32
1639	1401	GPLND	1201	487	0.32
1640	N/A	GUNSO	9911	299	0.32
1641	1732	HLTOM	2472	1,851	0.32
1642	1542	IRVGS	1905	753	0.32
1643	2232	ITSCA	1701	822	0.32
1644	907	JKWST	4035	95	0.32
1645	567	LGVST	8521	2,134	0.32
1646	N/A	LKBRN	2402	2,099	0.32
1647	331	LKHLD	0008	1,457	0.32
1648	1746	MEXIA	4012	1,120	0.32
1649	436	PCUST	2005	2,047	0.32
1650	1234	PRNTH	1406	983	0.32
1651	1789	SWAN2	1801	598	0.32
1652	1661	TATSP	4321	1,505	0.32
1653	1959	TRNTH	1501	1,885	0.32
1654	1544	TYLER	1002	788	0.32
1655	1110	WMRLD	0002	1,578	0.32
1656	2514	ATHNW	1405	914	0.31
1657	861	BDFWD	8931	1,732	0.31
1658	1006	BEAST	4084	898	0.31
1659	1025	BLTLN	0001	721	0.31
1660	1397	BNBRK	4123	1,414	0.31
1661	2314	BRNSO	1808	724	0.31
1662	2660	BRYAN	0005	1,897	0.31
1663	N/A	CHYNE	9132	26	0.31
1664	2348	COPEL	3053	2,787	0.31
1665	1799	CRLJL	1506	1,943	0.31
1666	2292	EDGWD	1101	680	0.31
1667	2304	IRVND	1205	212	0.31
1668	2535	IRVVV	2801	2,751	0.31
1669	N/A	LOYLK	1903	471	0.31
1670	537	LTFRD	3011	961	0.31
1671	2236	LUFKN	1203	649	0.31
1672	740	MDLNW	1594	1,647	0.31
1673	2093	MDTHN	1703	1,057	0.31
1674	1974	MDWPK	9231	2,421	0.31
1675	2024	MKNNY	1254	859	0.31

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
1676	1089	NHNSW	0001	477	0.31
1677	1262	PAYNE	1202	1,710	0.31
1678	1919	RANGR	4311	958	0.31
1679	837	RCHHL	0384	729	0.31
1680	2754	RDLML	2591	1,577	0.31
1681	2890	RWDHV	1908	2,433	0.31
1682	2039	SSPNG	1203	1,413	0.31
1683	2696	TYEST	1509	393	0.31
1684	543	TYLER	1006	2,033	0.31
1685	2073	TYSTH	1202	1,054	0.31
1686	1039	WTHRE	2101	770	0.31
1687	284	BLMND	3241	247	0.30
1688	1756	BLTSW	3203	1,408	0.30
1689	1709	BNBRK	4112	2,617	0.30
1690	2138	BOWIE	0621	10	0.30
1691	1033	BRLSN	2051	3,004	0.30
1692	2451	CDCSW	0006	1,429	0.30
1693	2006	CNTRY	2824	3,057	0.30
1694	2469	DUPUY	1211	1,014	0.30
1695	2111	GVODS	3011	2,354	0.30
1696	491	KLNPS	1102	1,960	0.30
1697	2209	MEXIA	4040	871	0.30
1698	1975	PCUST	2003	1,025	0.30
1699	82	PNTIS	0221	2,301	0.30
1700	2169	POOLV	5821	1,105	0.30
1701	1499	RCHRD	1201	1,438	0.30
1702	N/A	RRWES	1613	4,283	0.30
1703	2413	TYWST	2013	1,041	0.30
1704	2204	WDGWD	1572	1,484	0.30
1705	1796	ARTHR	0472	1,345	0.29
1706	1057	BANGS	1201	1,597	0.29
1707	1961	BDFRD	8842	1,458	0.29
1708	1858	BLTLN	0002	884	0.29
1709	2005	BLTON	1806	1,071	0.29
1710	1771	BRCRK	6514	584	0.29
1711	910	CLBNR	1407	277	0.29
1712	1995	CTYVW	2221	1,857	0.29
1713	2460	DALLW	0006	2,075	0.29
1714	405	DAVIS	3721	1,321	0.29
1715	941	DCVSO	1101	1,483	0.29
1716	1989	EULTB	5721	1,634	0.29
1717	667	FRMBR	1801	1,246	0.29
1718	3080	FRNKF	0008	774	0.29
1719	1221	FROKS	0002	1,758	0.29
1720	767	GNSVL	1223	1,286	0.29
1721	2299	GRHWY	5512	3,596	0.29
1722	2390	GRMES	0512	1,203	0.29
1723	1597	KERNS	2401	549	0.29

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
1724	1735	MDESA	4512	712	0.29
1725	2254	MURPH	2753	1,055	0.29
1726	1730	NCNTH	1808	801	0.29
1727	1605	PKRVL	1054	2,764	0.29
1728	1823	PRMED	4403	2,651	0.29
1729	2165	PRNTH	1403	21	0.29
1730	2555	RDLML	2571	364	0.29
1731	2259	RSPVY	1703	954	0.29
1732	1319	SBEND	0611	160	0.29
1733	1899	SPRDL	4811	2,030	0.29
1734	195	SPRTN	1801	2,115	0.29
1735	804	STAUG	0006	1,840	0.29
1736	530	TMNTH	1605	1,917	0.29
1737	1649	TYOMN	1405	1,717	0.29
1738	1856	TYSTH	1206	1,275	0.29
1739	1949	WHITE	3521	1,725	0.29
1740	1023	BKBNT	1821	1,134	0.28
1741	1503	BNBRK	4122	2,837	0.28
1742	1220	BONHM	1210	1,226	0.28
1743	2824	CLBNR	1406	108	0.28
1744	1653	CRLJL	1501	1,466	0.28
1745	1358	ENNIS	1902	1,594	0.28
1746	2044	EULES	8722	2,146	0.28
1747	1566	EULES	8731	1,462	0.28
1748	1612	GRLRD	0003	654	0.28
1749	2427	HMPHL	2772	329	0.28
1750	782	IRVNG	1401	1,646	0.28
1751	1171	KLRPR	9021	1,469	0.28
1752	1681	MEXIA	4024	376	0.28
1753	2802	MKNGB	5311	371	0.28
1754	3148	MRSDO	9612	2,352	0.28
1755	1841	RDLML	2532	1,989	0.28
1756	2443	RSPVY	1702	539	0.28
1757	1815	TMNTH	1602	478	0.28
1758	2575	TRLWD	7711	2,896	0.28
1759	626	TYEST	1507	634	0.28
1760	1819	WATSN	5382	1,743	0.28
1761	1085	WEBBS	8613	2,452	0.28
1762	1907	WNDWD	3621	2,218	0.28
1763	435	ALVDO	1901	1,812	0.27
1764	2079	DAVIS	3741	1,644	0.27
1765	472	DESPR	1406	959	0.27
1766	2768	FROKS	0007	1,522	0.27
1767	2769	FSTVW	0002	142	0.27
1768	1222	GRNGR	1801	948	0.27
1769	N/A	GUNSO	9922	910	0.27
1770	801	IRVNR	1506	2,991	0.27
1771	896	LUFKN	1201	1,376	0.27

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
1772	1652	LWRDR	0003	1,670	0.27
1773	2558	MCKMY	0811	1,779	0.27
1774	2707	MKNSO	3613	3,329	0.27
1775	251	OKCLS	0003	1,538	0.27
1776	1814	ROANW	9512	2,311	0.27
1777	1545	SCYEN	0001	1,807	0.27
1778	1030	SHLMT	1802	567	0.27
1779	1539	SIKES	2422	1,195	0.27
1780	1947	STANT	1332	1,217	0.27
1781	2058	TLRWT	2201	2,143	0.27
1782	593	TRLWD	7712	3,414	0.27
1783	2494	VGCRK	8041	1,031	0.27
1784	1257	WHOUS	4121	2,297	0.27
1785	1438	ABRRD	0002	1,396	0.26
1786	2347	ADISN	1602	226	0.26
1787	3090	ALKLK	4221	27	0.26
1788	1614	ARLNG	1292	1,581	0.26
1789	1226	BLMND	3231	1,252	0.26
1790	659	BRNSO	1806	2,336	0.26
1791	1752	BRNSY	1211	50	0.26
1792	2278	CAMRN	1201	1,001	0.26
1793	565	CHROW	0001	126	0.26
1794	1592	CLBRN	1203	1,600	0.26
1795	2173	CNTRY	2842	1,157	0.26
1796	2132	CRKSD	3105	868	0.26
1797	2504	CRLFR	2152	3,581	0.26
1798	1625	DUBLN	1360	1,157	0.26
1799	713	DUVAL	0462	1,106	0.26
1800	2220	FARON	4072	1,557	0.26
1801	268	FSCRK	6723	4,540	0.26
1802	1911	HKHTS	1606	2,082	0.26
1803	724	HLSES	0553	2,129	0.26
1804	2648	HMPHL	2721	1,067	0.26
1805	1617	HORNE	1911	1,804	0.26
1806	700	HORNE	1933	1,282	0.26
1807	637	KIMBL	5021	2,388	0.26
1808	1602	KLNPS	1104	1,434	0.26
1809	1473	KLNTF	1805	1,376	0.26
1810	1583	LKMNT	0007	1,527	0.26
1811	938	MDAIR	2911	387	0.26
1812	1411	ODESA	0242	127	0.26
1813	N/A	OILML	3621	652	0.26
1814	3156	PARIS	1205	23	0.26
1815	2358	PPARK	1807	1,025	0.26
1816	1585	PRMED	4404	1,156	0.26
1817	980	RCHRD	1203	839	0.26
1818	2669	RGFTW	6822	31	0.26
1819	1567	SCYEN	0002	2,027	0.26

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
1820	518	SSPNE	1404	74	0.26
1821	2936	TRLNW	1201	1,262	0.26
1822	1021	ABRRD	0005	1,538	0.25
1823	382	ARCTY	1311	412	0.25
1824	1643	BEALS	9511	118	0.25
1825	2029	BLTON	1802	1,666	0.25
1826	2593	BRYAN	0004	2,826	0.25
1827	536	CLMET	0001	1,288	0.25
1828	2491	CNEXP	0004	659	0.25
1829	1816	CNTRY	2813	3,094	0.25
1830	1086	CRLTN	1454	446	0.25
1831	1994	CRNTH	2404	2,540	0.25
1832	1674	CRTLD	4721	3,057	0.25
1833	2326	CTYVW	2212	155	0.25
1834	2214	DAVIS	3731	753	0.25
1835	1281	DELTA	1701	1,135	0.25
1836	2689	DESPR	1401	1,879	0.25
1837	1556	ECTHP	4931	421	0.25
1838	391	ENSSO	2001	235	0.25
1839	269	FRMBR	1805	765	0.25
1840	432	HDWLK	3001	1,044	0.25
1841	N/A	JACKR	7622	1,444	0.25
1842	397	JKSBR	1401	740	0.25
1843	2752	LOMAL	0013	1,058	0.25
1844	1845	MESQT	1307	659	0.25
1845	553	MLFRD	2103	1,011	0.25
1846	1758	MNWLL	1205	449	0.25
1847	2693	NPKWY	0014	6,073	0.25
1848	225	OVRTN	4019	674	0.25
1849	884	PTENN	2358	1,430	0.25
1850	2882	REGST	0003	1,672	0.25
1851	339	RWALE	3324	1,995	0.25
1852	1071	SALSW	3001	1,044	0.25
1853	697	SLBLF	1201	137	0.25
1854	1489	SMFLD	2343	730	0.25
1855	36	SWDTN	1641	1,546	0.25
1856	1329	TRNTY	7541	696	0.25
1857	765	WDGWD	1531	1,502	0.25
1858	1780	WHITE	3522	1,841	0.25
1859	865	ARCTY	1321	901	0.24
1860	267	ARTHR	0441	1,870	0.24
1861	944	BLMND	3282	96	0.24
1862	2735	BOWEN	3161	1,559	0.24
1863	2643	BRLSN	2062	815	0.24
1864	1897	CMINO	1207	712	0.24
1865	1684	CMPST	0001	421	0.24
1866	986	CRISP	1502	982	0.24
1867	2379	CRNTH	2403	3,273	0.24

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
1868	2523	DAVIS	3752	505	0.24
1869	1970	DENAV	0621	915	0.24
1870	2219	DESPR	1403	1,842	0.24
1871	2122	DNCNV	1904	1,482	0.24
1872	2690	ENTOH	0001	867	0.24
1873	3030	FORSW	2053	2,541	0.24
1874	388	GRAHM	0711	1,648	0.24
1875	1704	GRHWY	5522	1,794	0.24
1876	748	GSMTH	1742	29	0.24
1877	2022	HHSTH	1504	2,705	0.24
1878	1803	HKHTS	1607	971	0.24
1879	1553	IRVGS	1903	986	0.24
1880	80	KMASB	1721	86	0.24
1881	2300	MNWLL	1202	699	0.24
1882	1165	PAYNE	1205	1,311	0.24
1883	683	PCUST	2008	693	0.24
1884	2874	PLANO	1101	409	0.24
1885	2573	PSHIL	1604	465	0.24
1886	2723	PWEST	1304	1,683	0.24
1887	1834	RCHHL	0321	1,723	0.24
1888	455	RICES	0206	829	0.24
1889	1764	ROUGH	7422	21	0.24
1890	668	RSKMN	3078	140	0.24
1891	467	SANSM	3912	3,877	0.24
1892	2290	SMFLD	2322	41	0.24
1893	2702	TMSTH	1404	1,336	0.24
1894	1978	WALST	0005	246	0.24
1895	2109	WEAST	0620	2,023	0.24
1896	1914	WFALS	0193	2,227	0.24
1897	2750	WINKS	0511	747	0.24
1898	1253	WWDWY	2022	1,084	0.24
1899	1351	ADISN	1607	1,233	0.23
1900	1531	ALNSW	2652	3,677	0.23
1901	2525	ARLNG	1212	119	0.23
1902	2076	ARLNG	1282	842	0.23
1903	1569	BLMED	1620	1,604	0.23
1904	579	BOWEN	3122	1,270	0.23
1905	2077	BRNCH	1411	554	0.23
1906	882	CLCRK	1011	205	0.23
1907	2411	CMTSW	0946	868	0.23
1908	1412	CMTSW	0973	1,617	0.23
1909	2281	CMTSW	0987	404	0.23
1910	1261	CRLTN	1404	278	0.23
1911	1302	DFWNW	2405	13	0.23
1912	1478	EMMAS	4012	60	0.23
1913	1934	FHLSW	1342	2,472	0.23
1914	1673	FROKS	0003	647	0.23
1915	1532	GPLND	1202	600	0.23

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
1916	902	GRLND	1605	1,685	0.23
1917	2542	GRMES	0511	1,219	0.23
1918	2133	HORNE	1924	968	0.23
1919	1174	IRVNE	1303	1,750	0.23
1920	1546	IRVNE	1304	656	0.23
1921	N/A	LTVSB	5481	1,291	0.23
1922	69	MESQN	1501	1,801	0.23
1923	635	MESQW	1807	1,503	0.23
1924	2650	NPKWY	0012	2,244	0.23
1925	1430	OAKHL	3082	1,488	0.23
1926	N/A	OWLHL	7723	13	0.23
1927	935	PCUST	2011	1,450	0.23
1928	2616	PLKST	0006	840	0.23
1929	3085	PRSPR	4703	1,447	0.23
1930	2730	PSHIL	1605	136	0.23
1931	2196	RBNSN	2503	1,082	0.23
1932	904	REAST	1507	109	0.23
1933	2708	REYST	4051	1,153	0.23
1934	175	RHOME	2401	1,208	0.23
1935	1491	RNDRK	1504	990	0.23
1936	2423	ROWLT	1101	1,280	0.23
1937	403	SFTLK	4021	31	0.23
1938	1987	SHNRW	1610	461	0.23
1939	1656	SHSTH	1301	2,330	0.23
1940	1305	SPRDL	4841	962	0.23
1941	303	TMPTV	2404	1,765	0.23
1942	1774	WDGWD	1591	1,133	0.23
1943	853	ALLEN	2404	2,174	0.22
1944	1555	AMMFG	5631	1,575	0.22
1945	619	ARMST	0008	245	0.22
1946	1168	BBTWN	1502	1,985	0.22
1947	111	BEAST	4082	513	0.22
1948	3011	BNDRA	0009	594	0.22
1949	228	BSPRG	1903	1,368	0.22
1950	N/A	CANTN	1304	826	0.22
1951	1091	COYNW	8151	46	0.22
1952	1200	CPLSO	4312	1,836	0.22
1953	60	CRANE	0331	1,227	0.22
1954	1881	CRLTR	2003	1,354	0.22
1955	2452	CRTLD	4711	3,230	0.22
1956	2068	DAVIS	3772	1,723	0.22
1957	1123	DENAV	0611	846	0.22
1958	510	DNIWS	1603	1,401	0.22
1959	256	EMPCT	0003	1,308	0.22
1960	630	EULSO	9132	2,201	0.22
1961	505	EZACH	0008	1,529	0.22
1962	1497	HKHTS	1603	1,039	0.22
1963	960	HLSES	0542	768	0.22

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
1964	1894	HMPHL	2743	1,130	0.22
1965	915	HURST	1882	1,931	0.22
1966	1863	IRVGS	1901	1,395	0.22
1967	2116	KILEN	1203	793	0.22
1968	1782	KILEN	1204	1,648	0.22
1969	421	KLNPS	1103	2,347	0.22
1970	2870	KLRPR	9011	2,889	0.22
1971	2621	LKBLT	2104	964	0.22
1972	2759	MESQT	1306	998	0.22
1973	831	MKNSW	1601	1,807	0.22
1974	1267	MKNSW	1602	900	0.22
1975	464	OAKHL	3011	2,653	0.22
1976	1731	ODNTH	2015	590	0.22
1977	1249	PCOIT	1008	1,308	0.22
1978	2108	PLANO	1102	144	0.22
1979	2654	PNTGO	7122	878	0.22
1980	2694	RCHHL	0353	1,722	0.22
1981	2145	RDLML	2581	1,237	0.22
1982	2338	SCATR	2501	935	0.22
1983	981	TATSP	4313	1,600	0.22
1984	2470	TRNTH	1503	2,064	0.22
1985	1154	TYLNW	1912	1,059	0.22
1986	1180	TYWST	2001	1,010	0.22
1987	1835	WDGWD	1513	940	0.22
1988	2277	WELRD	0008	1,131	0.22
1989	304	WHITE	3542	1,646	0.22
1990	1332	WICKT	0421	225	0.22
1991	2147	WTAUG	4611	1,384	0.22
1992	3020	WTAUG	4632	1,343	0.22
1993	2907	ZEPHR	2404	203	0.22
1994	1572	AIRPK	8421	447	0.21
1995	476	ALVRD	1504	170	0.21
1996	879	ARLNG	1223	1,943	0.21
1997	1721	ARMST	0001	272	0.21
1998	2369	BNDRA	0007	491	0.21
1999	1106	BRCRK	6543	1,767	0.21
2000	2838	BSPRW	2542	565	0.21
2001	1565	CANTN	1302	1,439	0.21
2002	1093	CLYVL	9312	1,311	0.21
2003	2644	CLYVL	9321	831	0.21
2004	250	CPRCV	1407	2,221	0.21
2005	2218	CRANE	0311	834	0.21
2006	1155	CRTLD	4742	915	0.21
2007	2357	ECTHM	3321	1,554	0.21
2008	210	EDGCF	2223	4,107	0.21
2009	2736	JUDCT	0008	159	0.21
2010	1806	KNOTT	5211	89	0.21
2011	2481	LKHLD	0003	1,353	0.21

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
2012	2649	LKMNT	0005	688	0.21
2013	1009	LUFKN	1207	52	0.21
2014	1603	MAPLE	0004	482	0.21
2015	1886	MDESA	4531	1,824	0.21
2016	2002	MDLNW	1552	1,032	0.21
2017	946	MRDCK	0002	1,714	0.21
2018	302	PTENN	2352	2,475	0.21
2019	174	RCHHL	0363	972	0.21
2020	1561	RDRSE	2604	4,917	0.21
2021	1848	RGFTW	6813	33	0.21
2022	2127	RWDHV	1902	966	0.21
2023	164	SGOVL	1404	1,786	0.21
2024	722	SHMNE	1409	934	0.21
2025	128	SNDHL	3811	43	0.21
2026	2335	SSPNE	1402	72	0.21
2027	717	STAUG	0003	1,618	0.21
2028	1628	SYCRK	4522	3,168	0.21
2029	1811	TATSP	4311	1,883	0.21
2030	846	THRNE	0002	1,741	0.21
2031	599	TMNTH	1606	14	0.21
2032	1121	TMSTH	1401	1,843	0.21
2033	2197	TMSTH	1403	1,590	0.21
2034	115	TRLWD	7722	2,350	0.21
2035	1860	WNDWD	3662	899	0.21
2036	2083	WNRTH	1419	322	0.21
2037	2263	WNTHW	1119	1,325	0.21
2038	685	BDFWD	8912	1,010	0.20
2039	1578	BLKST	1742	1,780	0.20
2040	528	BLTSW	3201	2,812	0.20
2041	1797	BRCRK	6511	1,562	0.20
2042	826	BRCRK	6533	1,909	0.20
2043	1993	BRHLW	7611	1,635	0.20
2044	1915	BRLSN	2033	1,694	0.20
2045	718	BRNAV	0753	1,291	0.20
2046	1516	BRNWD	1201	1,717	0.20
2047	2681	CNEXP	0006	1,383	0.20
2048	1932	COVEE	3403	1,594	0.20
2049	2455	CRKSD	3101	1,466	0.20
2050	1767	CRLUD	1303	908	0.20
2051	431	CRYVE	3021	1,332	0.20
2052	1901	DAVST	0003	1,809	0.20
2053	737	DNCNV	1905	1,323	0.20
2054	1507	DPCRK	1822	1,344	0.20
2055	649	DUVAL	0434	2,738	0.20
2056	1999	EULTB	5731	677	0.20
2057	2601	GAVSW	0007	1,526	0.20
2058	2059	GLNHV	3911	95	0.20
2059	1472	GVGLF	9601	61	0.20

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
2060	179	INAIR	1411	1,981	0.20
2061	402	IRVNE	1306	1,491	0.20
2062	33	JUDCT	0003	1,922	0.20
2063	2519	KFMNW	1202	1,033	0.20
2064	2594	KNEDL	6314	2,142	0.20
2065	2729	LOMAL	0009	1,023	0.20
2066	395	MAYFD	5533	5,335	0.20
2067	2442	MEXIA	3015	114	0.20
2068	571	MSHLN	0003	530	0.20
2069	1847	NSTAR	2011	545	0.20
2070	1172	ODESW	5221	1,255	0.20
2071	764	ODNTH	2033	702	0.20
2072	1285	PFLGV	2004	3,474	0.20
2073	1105	PKRMX	4701	2,930	0.20
2074	287	PRFTW	4212	2,017	0.20
2075	1452	PTENN	2354	556	0.20
2076	2453	REAST	1506	1,203	0.20
2077	1965	RRNES	2403	3,376	0.20
2078	2508	SCHRD	0001	1,431	0.20
2079	1432	SGOVL	1406	976	0.20
2080	744	STAUG	0005	1,248	0.20
2081	2187	TMPLE	1203	127	0.20
2082	694	TYEST	1506	525	0.20
2083	1640	WCITY	2401	957	0.20
2084	2567	WELRD	0001	1,210	0.20
2085	2075	WNDWD	3682	791	0.20
2086	1751	WRBND	2321	1,565	0.20
2087	2658	ARMST	0003	363	0.19
2088	N/A	BUFLO	2602	5,123	0.19
2089	2509	CMPWI	0003	659	0.19
2090	470	CRLJL	1502	399	0.19
2091	1607	CRLJL	1507	961	0.19
2092	1980	CRSCN	1204	665	0.19
2093	309	DALWT	2921	321	0.19
2094	1705	DCVSO	1102	695	0.19
2095	1838	FLINT	3212	3,803	0.19
2096	92	FSTVW	0008	380	0.19
2097	359	GLNHV	3983	1,737	0.19
2098	2226	GNSVN	1401	32	0.19
2099	2500	GVODS	3072	2,292	0.19
2100	2042	HRSMD	1905	2,806	0.19
2101	280	HSKAV	0007	81	0.19
2102	955	HUTTO	2711	4,535	0.19
2103	1734	IRVND	1202	1,504	0.19
2104	2879	IRVNR	1507	1,606	0.19
2105	1448	KILEN	1201	1,956	0.19
2106	2151	LIGSW	1602	1,160	0.19
2107	2000	LKCRS	4231	1,311	0.19

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
2108	1557	LNCST	1601	1,229	0.19
2109	1037	MCGRG	1902	1,360	0.19
2110	1113	MKNNY	1205	507	0.19
2111	1558	MRTSP	1501	733	0.19
2112	410	MSHLN	0002	1,589	0.19
2113	2536	NAVCO	0001	31	0.19
2114	2800	NNTWK	0006	955	0.19
2115	730	OKCLS	0007	656	0.19
2116	3157	PAULN	2502	240	0.19
2117	1314	PFFRD	3431	577	0.19
2118	2306	PFLGV	2007	1,676	0.19
2119	N/A	PGSTH	7031	27	0.19
2120	2553	PRKWY	1561	1,807	0.19
2121	1299	ROWLT	1107	520	0.19
2122	2679	RSNHT	1181	2,492	0.19
2123	1944	RWALL	1204	1,105	0.19
2124	1606	SANDS	1101	21	0.19
2125	2034	SCHRD	0008	80	0.19
2126	2528	SHRSW	6622	1,538	0.19
2127	1810	SPRDL	4822	1,242	0.19
2128	2498	STNVL	1207	1,169	0.19
2129	2140	WCOLO	1319	2,090	0.19
2130	873	WMRLD	0001	229	0.19
2131	2613	ARLNG	1222	96	0.18
2132	1195	ARPCM	4169	11	0.18
2133	499	CHICG	1402	495	0.18
2134	1395	CHNDW	1203	874	0.18
2135	2018	CMTSW	0922	1,617	0.18
2136	1616	CPRCV	1405	1,580	0.18
2137	343	CPRCV	1406	1,296	0.18
2138	2030	CRLTN	1453	298	0.18
2139	2929	CRLTR	2005	677	0.18
2140	2308	CRLTR	2052	1,562	0.18
2141	2213	DALWT	2962	1,088	0.18
2142	1233	DCDAM	2002	1,095	0.18
2143	1588	DWSON	3121	28	0.18
2144	2318	FLMSO	3716	1,698	0.18
2145	1701	GLNHV	3963	1,574	0.18
2146	149	GMINI	5811	3,857	0.18
2147	2448	GVODS	3031	1,384	0.18
2148	2585	IRLBJ	3231	3,023	0.18
2149	1078	JNDAY	3321	4,739	0.18
2150	1691	KLNPS	1105	1,604	0.18
2151	2653	KNEDL	6323	4,036	0.18
2152	1694	LAVON	1451	1,044	0.18
2153	2713	MCDMT	2553	2,281	0.18
2154	1665	MDRAW	8221	45	0.18
2155	742	MESTE	1205	1,642	0.18

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
2156	2233	MESTE	1213	1,004	0.18
2157	857	MNWLE	1702	1,510	0.18
2158	615	MYPRL	1803	654	0.18
2159	2163	ODNTH	2044	2,053	0.18
2160	1744	PCOIT	1006	1,041	0.18
2161	1720	PCUST	2001	574	0.18
2162	813	PLANO	1103	1,872	0.18
2163	1376	PRKRW	3362	1,087	0.18
2164	2655	PRMED	4402	869	0.18
2165	262	PSHIL	1601	1,183	0.18
2166	2678	RCHRD	1206	704	0.18
2167	1512	RCHRD	1207	1,554	0.18
2168	1873	RCLNS	1407	1,402	0.18
2169	2656	SHMNE	1407	788	0.18
2170	2828	SMFLD	2323	614	0.18
2171	1849	SMOUR	0721	22	0.18
2172	520	TRNDD	1202	572	0.18
2173	2429	TXHRV	1611	17	0.18
2174	548	VESTS	3111	11	0.18
2175	858	VLRYN	2955	4,762	0.18
2176	2409	WEAST	0629	1,633	0.18
2177	485	WNTHW	1120	1,043	0.18
2178	204	WTAUG	4633	1,066	0.18
2179	2837	ALLEN	2408	3,660	0.17
2180	2159	ARLNG	1251	558	0.17
2181	805	BKWST	0002	1,732	0.17
2182	477	BNTDR	0003	591	0.17
2183	1410	BRCRK	6512	1,824	0.17
2184	1979	CAMRN	1202	1,465	0.17
2185	1294	CHNDW	1201	1,426	0.17
2186	1644	CMNCH	1401	1,237	0.17
2187	1870	CNEXP	0007	770	0.17
2188	1462	DAVIS	3782	1,362	0.17
2189	2099	EULES	8713	1,708	0.17
2190	413	FKLCY	5111	63	0.17
2191	917	FRMNT	0009	933	0.17
2192	1082	GSMTH	1732	30	0.17
2193	2001	GVODS	3062	2,674	0.17
2194	1467	HKHTS	1604	1,240	0.17
2195	1690	HNRTA	0311	1,093	0.17
2196	1951	HORNE	1943	1,900	0.17
2197	521	IRVGS	1907	982	0.17
2198	1910	IRVNG	1404	1,436	0.17
2199	1022	IRVNR	1505	1,310	0.17
2200	1935	KLNCC	1701	2,375	0.17
2201	2926	KNEDL	6324	3,478	0.17
2202	1710	LAVON	1406	1,561	0.17
2203	614	LFSTH	1402	1,199	0.17

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
2204	1917	LKBLT	2105	1,281	0.17
2205	624	LKHLD	0001	1,774	0.17
2206	2676	LOMAL	0008	454	0.17
2207	1743	LOVNG	2521	18	0.17
2208	643	MDAIR	2912	1,174	0.17
2209	974	MDAIR	2922	512	0.17
2210	786	MESQW	1802	1,086	0.17
2211	2201	MKNGB	5352	2,182	0.17
2212	952	NNTWK	0004	2,016	0.17
2213	564	ODNTH	2013	1,610	0.17
2214	2779	PAULN	2501	2,082	0.17
2215	1056	PLKST	0003	1,307	0.17
2216	2207	PNTGO	7112	748	0.17
2217	1736	PREST	1603	1,531	0.17
2218	1955	RCHHL	0344	1,257	0.17
2219	2755	ROLTR	2922	2,950	0.17
2220	1383	RSNHT	1122	2,088	0.17
2221	716	RWDHV	1905	1,125	0.17
2222	2346	STNVL	1204	914	0.17
2223	1457	SUNNY	2303	1,003	0.17
2224	2590	TAYLR	1203	1,330	0.17
2225	1540	TYLGE	1308	1,567	0.17
2226	1152	WLSPT	1002	661	0.17
2227	449	WSTHL	3631	3,916	0.17
2228	725	BDFRD	8841	813	0.16
2229	1043	BKBNT	1811	718	0.16
2230	2160	BLKST	1771	1,702	0.16
2231	2793	BRNAV	0774	208	0.16
2232	1335	CHICW	1302	240	0.16
2233	508	CHROW	0004	259	0.16
2234	2645	CMPWI	0004	1,048	0.16
2235	2041	COTRD	0006	612	0.16
2236	3076	COTRD	0008	1,179	0.16
2237	906	CRLTR	2051	3,907	0.16
2238	843	CRNRD	0002	373	0.16
2239	1600	CRTLD	4723	2,348	0.16
2240	2349	CTYVW	2211	1,528	0.16
2241	1053	DCATR	1203	1,091	0.16
2242	688	DUVAL	0483	2,693	0.16
2243	2863	FRSCW	3703	3,114	0.16
2244	278	FSTVW	0004	2,246	0.16
2245	374	GLNHV	3922	736	0.16
2246	634	GRVPT	7512	324	0.16
2247	1902	HKHTS	1608	1,339	0.16
2248	535	INWRD	0001	1,048	0.16
2249	1645	IRVND	1204	1,345	0.16
2250	820	JREST	2103	2,815	0.16
2251	679	LIPAN	1301	573	0.16

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
2252	862	LOVNG	2511	31	0.16
2253	2607	LWSNR	2221	942	0.16
2254	2372	MDTHS	1003	1,040	0.16
2255	1276	MKNSO	3614	8,805	0.16
2256	2941	MSHLN	0004	1,304	0.16
2257	63	MSLSW	0006	86	0.16
2258	3067	NNTWK	0002	1,133	0.16
2259	300	ODESA	0212	575	0.16
2260	2047	ODNTH	2053	2,187	0.16
2261	2722	PAYNE	1213	1,582	0.16
2262	88	PPARK	1805	990	0.16
2263	1990	PRMED	4401	2,566	0.16
2264	2686	PRSTN	0003	2,962	0.16
2265	3168	REAST	1509	144	0.16
2266	N/A	RNDER	2403	3,815	0.16
2267	2780	RSPCK	2141	19	0.16
2268	1692	SALSW	3003	759	0.16
2269	878	SCYEN	0006	1,216	0.16
2270	366	SHAMP	0002	2,073	0.16
2271	1240	STHRL	0001	620	0.16
2272	2010	TYBLR	2804	2,434	0.16
2273	2070	WDGWD	1522	1,452	0.16
2274	2957	WSOTH	1022	2,248	0.16
2275	2367	WTAUG	4622	1,014	0.16
2276	2958	ADMDS	6532	283	0.15
2277	2897	BLTLN	0004	612	0.15
2278	2577	BLTON	1801	849	0.15
2279	1148	CMEXP	1601	286	0.15
2280	847	CMTSW	0983	1,380	0.15
2281	1969	DALRK	1305	1,206	0.15
2282	2275	DUVAL	0473	1,966	0.15
2283	870	ESTLD	3611	1,572	0.15
2284	1809	EZACH	0005	538	0.15
2285	934	FRMBG	1750	404	0.15
2286	2394	GODRD	8151	801	0.15
2287	1844	HHSTH	1501	2,872	0.15
2288	N/A	HRSKD	5831	27	0.15
2289	1693	IRVND	1203	436	0.15
2290	1081	IRVNG	1408	1,058	0.15
2291	1403	JACKR	7631	246	0.15
2292	2911	LOMAL	0003	1,058	0.15
2293	2845	MDESA	4521	1,473	0.15
2294	1297	MDWCK	0003	1,866	0.15
2295	720	MESQN	1507	708	0.15
2296	653	MESQT	1305	1,151	0.15
2297	140	MNFLD	2611	2,528	0.15
2298	580	MNWLW	1402	1,577	0.15
2299	3151	MSTLT	1011	62	0.15

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
2300	2152	PCOIT	1002	733	0.15
2301	1717	PCUST	2007	1,392	0.15
2302	3161	PLHWY	3701	498	0.15
2303	2565	PNTIS	0241	386	0.15
2304	669	RDLML	2521	1,013	0.15
2305	2174	REAST	1501	317	0.15
2306	1520	RENSW	3121	1,963	0.15
2307	2466	TMSTH	1406	1,166	0.15
2308	1755	TYBLR	2802	1,023	0.15
2309	3036	TYBLR	2806	202	0.15
2310	1282	WALST	0009	880	0.15
2311	2871	WATCO	2604	798	0.15
2312	2285	WCOLO	1317	1,268	0.15
2313	471	WFALS	0133	1,695	0.15
2314	1130	WHTRK	0004	1,149	0.15
2315	2035	WNDKR	0232	953	0.15
2316	438	WSOTH	1018	1,086	0.15
2317	2158	WXNTH	2301	1,307	0.15
2318	1199	ALNTH	2853	3,039	0.14
2319	568	ANDNR	2242	304	0.14
2320	2170	ARTHR	0481	1,263	0.14
2321	1501	BDFRD	8811	1,693	0.14
2322	1712	BLKST	1711	2,071	0.14
2323	1726	BLKST	1781	1,954	0.14
2324	2012	BRCRK	6521	1,437	0.14
2325	1189	BRCRK	6523	881	0.14
2326	940	BRYAN	0006	2,005	0.14
2327	682	CKRHL	0005	1,232	0.14
2328	2727	CMHBL	8121	59	0.14
2329	2315	CMTSW	0927	619	0.14
2330	1236	COPEL	3052	2,610	0.14
2331	566	CRLTN	1403	207	0.14
2332	392	CRLTR	2002	1,457	0.14
2333	1390	DENAV	0632	923	0.14
2334	1791	FARON	4031	1,149	0.14
2335	2053	FARON	4052	1,671	0.14
2336	608	GAVSW	0005	1,520	0.14
2337	3021	GODRD	8141	842	0.14
2338	102	GRLWS	1704	183	0.14
2339	1286	LFKHL	2101	167	0.14
2340	1547	MDTHN	1702	1,963	0.14
2341	N/A	MNFLD	2613	3,154	0.14
2342	1328	MTLDA	0004	1,832	0.14
2343	2162	OAKHL	3052	798	0.14
2344	2107	OKLND	0003	1,515	0.14
2345	1298	PARIS	1203	955	0.14
2346	2069	PFFRD	3462	1,816	0.14
2347	2639	PRKRW	3311	1,153	0.14

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
2348	245	PUMPR	6731	518	0.14
2349	1750	PWEST	1312	2,007	0.14
2350	2566	REAST	1503	600	0.14
2351	616	RWALS	1851	1,577	0.14
2352	1683	SHDYG	7822	532	0.14
2353	2146	TYBLR	2803	801	0.14
2354	1099	WELRD	0007	438	0.14
2355	1900	WTAUG	4621	943	0.14
2356	2992	WTAUG	4641	577	0.14
2357	1988	WXNTH	2304	933	0.14
2358	2403	ADMDS	6542	1,234	0.13
2359	103	ALLEN	2410	2,430	0.13
2360	1428	ALPHA	0002	1,256	0.13
2361	2913	ARTHR	0411	741	0.13
2362	1117	BRGPR	1101	632	0.13
2363	2303	BRNSO	1801	1,645	0.13
2364	1173	BRTRD	7311	1,720	0.13
2365	2036	CDCSW	0004	1,442	0.13
2366	2661	CKRHL	0007	68	0.13
2367	2823	CLBNR	1401	23	0.13
2368	1050	CLNSE	4201	319	0.13
2369	295	CNTRD	0001	2,061	0.13
2370	2720	CRLTR	2007	1,504	0.13
2371	2674	DALRK	1303	1,370	0.13
2372	2393	DALRK	1307	627	0.13
2373	2078	DALRK	1354	1,962	0.13
2374	2350	DALWT	2992	404	0.13
2375	815	DESPR	1404	565	0.13
2376	2178	DNINR	1401	83	0.13
2377	2705	EDGCF	2282	1,057	0.13
2378	628	ELMGV	3653	2,309	0.13
2379	636	ENSSO	2003	638	0.13
2380	2129	EULES	8724	2,446	0.13
2381	2021	EZACH	0002	1,414	0.13
2382	939	FRMNT	0006	972	0.13
2383	1703	FRMNT	0013	2,466	0.13
2384	2950	FROKS	0008	1,514	0.13
2385	757	GAVSW	0001	1,541	0.13
2386	657	GNSVL	1204	512	0.13
2387	2711	GODRD	8161	1,051	0.13
2388	480	GRLND	1603	313	0.13
2389	1371	GRPVN	8231	415	0.13
2390	N/A	GUNSO	9941	407	0.13
2391	1769	HORNE	1914	1,071	0.13
2392	699	HORNE	1922	1,624	0.13
2393	1420	HUBRD	1401	980	0.13
2394	1685	INAIR	1421	16	0.13
2395	1042	KNAPP	4021	32	0.13

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
2396	2321	LIGSW	1607	1,376	0.13
2397	743	LKHLD	0006	741	0.13
2398	2223	LOMAL	0010	1,506	0.13
2399	2101	MDLNW	1564	1,279	0.13
2400	1490	MESFR	2101	2,036	0.13
2401	N/A	MMILL	3911	46	0.13
2402	208	MRSDO	9611	3,506	0.13
2403	1216	MRTNS	1502	547	0.13
2404	2615	ODESA	0231	576	0.13
2405	481	OKLND	0001	1,490	0.13
2406	2097	PFFRD	3411	324	0.13
2407	2716	PLHWY	3703	15	0.13
2408	1754	RCHRD	1205	1,039	0.13
2409	276	RECCR	0003	200	0.13
2410	3044	RENSW	3122	1,643	0.13
2411	3169	RGLRW	0006	31	0.13
2412	1486	RNDRK	1508	2,151	0.13
2413	1303	ROGRS	1301	839	0.13
2414	2537	ROLTR	2912	2,437	0.13
2415	2624	ROWLT	1104	1,486	0.13
2416	2598	RSPVY	1704	1,400	0.13
2417	2876	RVRFT	0004	120	0.13
2418	1846	SALDS	3311	627	0.13
2419	1513	SMPST	0001	2,079	0.13
2420	809	SSPNG	1202	1,251	0.13
2421	1166	SYCRK	4532	1,213	0.13
2422	1855	TMPTV	2402	5,117	0.13
2423	N/A	TYLER	1003	1,079	0.13
2424	2436	TYOMN	1402	1,597	0.13
2425	1824	TYOMN	1410	1,549	0.13
2426	2272	WEAST	0616	842	0.13
2427	2381	WELCH	4911	23	0.13
2428	1161	WITTS	1702	871	0.13
2429	2600	WNRTH	1420	1,179	0.13
2430	2089	WSANG	2801	1,338	0.13
2431	1666	ANDNR	2252	266	0.12
2432	2250	BDFRD	8812	757	0.12
2433	533	BRNAV	0784	1,940	0.12
2434	2789	BSPRW	2521	582	0.12
2435	275	BULDG	1102	74	0.12
2436	1812	CDHIL	1804	1,458	0.12
2437	1696	CLBRN	1206	1,669	0.12
2438	654	CLCTY	1031	1,137	0.12
2439	462	CRNTH	2406	1,973	0.12
2440	1488	CRTLD	4724	3,195	0.12
2441	2791	CRWLY	7012	4,377	0.12
2442	2740	DALRK	1326	2,797	0.12
2443	2388	DFWSE	2712	49	0.12

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
2444	2441	EGFRD	0002	26	0.12
2445	1274	ELKTN	2504	435	0.12
2446	1582	FRMBG	1701	99	0.12
2447	373	FSTVW	0003	1,908	0.12
2448	2026	GRSMN	4028	710	0.12
2449	2534	IRLBJ	3221	1,082	0.12
2450	3005	IRVNE	1310	917	0.12
2451	415	LMESA	1561	1,397	0.12
2452	923	LOMAL	0004	142	0.12
2453	2842	MDLNE	0121	735	0.12
2454	2389	MDWPK	9211	1,319	0.12
2455	2297	MESTE	1206	1,287	0.12
2456	2365	MKNGB	5342	1,302	0.12
2457	2106	MNHNS	1921	1,513	0.12
2458	1096	MSHLN	0001	1,069	0.12
2459	2547	MURPH	2751	2,368	0.12
2460	2206	NHNSW	0004	552	0.12
2461	2677	ODNTH	2025	1,175	0.12
2462	1887	PAYNE	1203	880	0.12
2463	672	PFLGV	2005	4,481	0.12
2464	N/A	PNKNY	1811	274	0.12
2465	666	RGLRW	0005	50	0.12
2466	1618	RSPVY	1701	1,332	0.12
2467	524	RYSSW	2802	3,572	0.12
2468	1577	SALDS	3321	678	0.12
2469	1247	SHNRW	1609	1,868	0.12
2470	888	TYLER	1004	181	0.12
2471	2725	TYSTH	1203	430	0.12
2472	1534	VLYRN	2952	3,571	0.12
2473	2064	WELRD	0003	417	0.12
2474	2471	WELRD	0004	748	0.12
2475	2260	WTAUG	4642	1,332	0.12
2476	968	ALPHA	0014	1,002	0.11
2477	1857	BDFRD	8832	1,012	0.11
2478	1967	BLKST	1721	1,022	0.11
2479	1131	BLTON	1803	997	0.11
2480	1929	BSPRG	1901	689	0.11
2481	2467	CHSPG	2401	1,826	0.11
2482	2803	CNEXP	0001	269	0.11
2483	2104	CRKSD	3103	942	0.11
2484	2316	DAVST	0002	783	0.11
2485	3117	EXPKY	8122	57	0.11
2486	2831	FRMNT	0010	2,601	0.11
2487	2014	GLSCN	6221	18	0.11
2488	800	HLSBR	1201	1,207	0.11
2489	2096	IRLBJ	3211	2,684	0.11
2490	315	IRVNR	1555	550	0.11
2491	242	IRVVV	2802	1,066	0.11

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
2492	N/A	LKCRS	4241	1,735	0.11
2493	334	MASON	3422	18	0.11
2494	1356	MDESA	4541	1,448	0.11
2495	1346	MDLNE	0132	122	0.11
2496	2333	MDLNW	1531	1,651	0.11
2497	322	MDWCK	0004	1,744	0.11
2498	2622	MESTE	1209	1,445	0.11
2499	517	MKNNY	1252	1,245	0.11
2500	222	MSTLT	1054	621	0.11
2501	656	PALRD	2201	792	0.11
2502	2203	PALRD	2207	1,266	0.11
2503	243	PCUST	2002	798	0.11
2504	2243	PFFRD	3452	874	0.11
2505	1626	RNDRK	1506	1,750	0.11
2506	2923	ROWLT	1103	1,090	0.11
2507	3174	RVRFT	0001	28	0.11
2508	2952	SCHRD	0003	386	0.11
2509	1463	SHNRW	1611	1,005	0.11
2510	2934	SHRSW	6612	1,945	0.11
2511	3177	SLTLK	3511	19	0.11
2512	1737	SPRTN	1802	1,043	0.11
2513	772	TYOMN	1411	303	0.11
2514	880	VGCRK	8011	1,729	0.11
2515	2384	VGCRK	8021	217	0.11
2516	519	WBROK	3021	35	0.11
2517	2670	WEBBS	8611	2,704	0.11
2518	1948	WELRD	0002	744	0.11
2519	1436	WNRTH	1418	1,800	0.11
2520	1843	WNTHW	1118	1,521	0.11
2521	1869	ALNTH	2844	1,908	0.10
2522	2902	ALNTH	2851	2,528	0.10
2523	1745	ANDNR	2231	1,133	0.10
2524	1966	AYERS	4431	1,595	0.10
2525	1162	BMTWN	1621	1,432	0.10
2526	2539	BNMNW	1101	207	0.10
2527	2324	BNTDR	0004	1,933	0.10
2528	N/A	BRHLW	7613	1,145	0.10
2529	3075	BRHLW	7623	1,550	0.10
2530	1072	BRNAV	0762	2,433	0.10
2531	2188	CMNCH	1402	1,152	0.10
2532	2857	CNTRD	0004	1,083	0.10
2533	412	CPLSO	4311	96	0.10
2534	701	CRLFR	2156	1,327	0.10
2535	1485	CRNDL	2403	1,058	0.10
2536	1827	CRSCN	1205	767	0.10
2537	196	CRTLD	4722	4,557	0.10
2538	1677	DAVIS	3733	962	0.10
2539	2745	EDGCF	2221	888	0.10

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
2540	2479	ELMGV	3651	2,585	0.10
2541	1675	ENNIS	1901	363	0.10
2542	2148	FARON	4082	995	0.10
2543	1074	FLMSO	3714	2,047	0.10
2544	182	FORSW	2051	2,354	0.10
2545	1080	FRMBR	1803	3,590	0.10
2546	2541	GDNVL	1202	68	0.10
2547	11	GRSMN	3071	333	0.10
2548	2851	HKBRY	1104	122	0.10
2549	1408	HSKAV	0005	1,367	0.10
2550	2839	IRVND	1208	172	0.10
2551	542	KLNSO	4501	2,955	0.10
2552	921	KLNSO	4502	3,452	0.10
2553	N/A	KLNSO	4522	2,022	0.10
2554	1913	LAVON	1402	161	0.10
2555	N/A	LKBRN	2401	755	0.10
2556	2276	LKHLD	0005	1,368	0.10
2557	719	MCGHR	2003	1,314	0.10
2558	1263	MDLNE	0131	3,005	0.10
2559	1729	MESQT	1303	842	0.10
2560	2596	MESQW	1806	742	0.10
2561	640	MESTE	1207	947	0.10
2562	2505	MESTE	1215	1,539	0.10
2563	2552	MNSTR	1202	286	0.10
2564	2792	MTLDA	0002	1,885	0.10
2565	2125	NHNSW	0006	696	0.10
2566	120	NLNVL	2002	2,881	0.10
2567	1421	OKCLS	0006	1,696	0.10
2568	3158	PBELL	4841	1,711	0.10
2569	812	PFFRD	3492	285	0.10
2570	758	PLGRV	0003	618	0.10
2571	2875	PRHLL	2402	58	0.10
2572	2589	PRKRW	3321	166	0.10
2573	2912	PRKWY	1552	566	0.10
2574	2827	PRSTN	0002	1,338	0.10
2575	2271	RGLRW	0008	40	0.10
2576	N/A	RNDER	2401	231	0.10
2577	1147	SANSM	3923	4,584	0.10
2578	2847	SHDYG	7821	91	0.10
2579	2435	SHRSW	6641	1,020	0.10
2580	3181	STERT	2702	21	0.10
2581	2574	TMPNW	1106	1,239	0.10
2582	933	TNPON	0001	69	0.10
2583	788	WALNT	0001	1,427	0.10
2584	2302	WATSN	5331	1,127	0.10
2585	2576	WFALS	0114	415	0.10
2586	2011	WFALS	0174	1,203	0.10
2587	859	WMRLD	0009	31	0.10

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
2588	2274	WNDCR	0262	222	0.10
2589	2671	WXNTH	2302	1,768	0.10
2590	2313	ARMST	0009	1,172	0.09
2591	1248	ARTHR	0492	54	0.09
2592	1323	BLTLN	0007	779	0.09
2593	1287	BRHLW	7631	648	0.09
2594	2767	BULDG	1108	864	0.09
2595	1836	CDHCR	2053	279	0.09
2596	818	CHROW	0002	105	0.09
2597	197	CPRCV	1402	2,388	0.09
2598	2424	CRNSO	3913	1,879	0.09
2599	290	DALRK	1358	3,103	0.09
2600	2797	DAVIS	3713	981	0.09
2601	2317	DESHR	1206	2,334	0.09
2602	2397	DLEON	0131	744	0.09
2603	N/A	ELKTN	2505	901	0.09
2604	1667	ENTOH	0004	1,288	0.09
2605	2741	FRNKF	0004	1,602	0.09
2606	2421	GORMN	0421	350	0.09
2607	220	GRPTT	9911	1,184	0.09
2608	N/A	GUNSO	9932	881	0.09
2609	2762	JUDCT	0006	2,563	0.09
2610	2840	KERNS	2402	397	0.09
2611	1576	KLNTF	1802	835	0.09
2612	577	KNLTR	0008	1,415	0.09
2613	1938	LAVON	1401	1,741	0.09
2614	226	LAVON	1453	2,268	0.09
2615	2016	LIGSW	1603	2,525	0.09
2616	2947	LKWOD	7421	44	0.09
2617	2557	LMBLN	0003	187	0.09
2618	731	LMBLN	0005	701	0.09
2619	2668	MESFR	2105	1,019	0.09
2620	1055	MEXIA	3016	312	0.09
2621	586	MKNGB	5322	2,487	0.09
2622	2434	NPKWY	0009	1,297	0.09
2623	3007	PLANO	1105	65	0.09
2624	1509	PLGRV	0002	2,420	0.09
2625	2050	PPARK	1802	598	0.09
2626	345	PSHIL	1608	2,174	0.09
2627	3167	PWEST	1309	54	0.09
2628	2102	RDRSE	2603	2,842	0.09
2629	900	RENTL	2204	1,665	0.09
2630	2081	ROBNW	1501	400	0.09
2631	2048	SANSM	3922	1,620	0.09
2632	446	SCHRD	0007	1,419	0.09
2633	705	SCYEN	0007	907	0.09
2634	1958	TRLNW	2401	23	0.09
2635	2901	TRNTH	1504	848	0.09

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
2636	1895	VLARN	2959	1,178	0.09
2637	834	WBOSE	1102	373	0.09
2638	1122	WEBBS	8621	3,012	0.09
2639	695	WWDWD	3652	1,023	0.09
2640	1927	WRTHM	5004	231	0.09
2641	2141	ABRRD	0003	354	0.08
2642	2997	ABRRD	0008	2,423	0.08
2643	2959	ALLEN	2401	3,657	0.08
2644	2861	BLMED	1618	26	0.08
2645	1034	BLMND	3213	3,636	0.08
2646	2368	BNDRA	0002	447	0.08
2647	3096	BRYAN	0008	12	0.08
2648	18	CLMET	0004	1,240	0.08
2649	425	CRLFR	2158	3,470	0.08
2650	2699	DALRK	1309	905	0.08
2651	2205	DCDAM	2003	1,374	0.08
2652	56	ELMAR	3212	37	0.08
2653	271	FRFWS	3004	849	0.08
2654	2915	FRMNT	0008	1,657	0.08
2655	81	FSCRK	6712	2,802	0.08
2656	761	FSTVW	0005	1,769	0.08
2657	2296	GODRD	8132	2,146	0.08
2658	2257	IRVND	1206	114	0.08
2659	1650	IRVVV	2851	2,987	0.08
2660	3137	KIMBL	5011	193	0.08
2661	868	LGVST	8511	780	0.08
2662	376	LKMNT	0002	1,005	0.08
2663	2433	LOMAL	0016	658	0.08
2664	1125	MDLNW	1573	1,046	0.08
2665	2215	MEANS	4411	37	0.08
2666	2626	MESFR	2104	181	0.08
2667	1353	MIDWY	0621	12	0.08
2668	2398	MOSSW	4611	1,051	0.08
2669	1954	MSTLT	1063	1,308	0.08
2670	272	OKCLS	0001	725	0.08
2671	2507	PPARK	1808	596	0.08
2672	2211	PRKRW	3331	826	0.08
2673	N/A	PRSPR	4701	1,708	0.08
2674	860	PWEST	1307	958	0.08
2675	1763	RCLNS	1408	120	0.08
2676	2744	RRNES	2407	3,859	0.08
2677	798	RSPCK	2106	370	0.08
2678	2120	RSPCK	2131	61	0.08
2679	2695	RWDHV	1904	511	0.08
2680	3175	SACRC	5521	119	0.08
2681	591	SHAMP	0006	1,137	0.08
2682	1237	SMFLD	2311	1,645	0.08
2683	1765	SMFLD	2391	295	0.08

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
2684	750	SMPST	0006	847	0.08
2685	1059	WATSN	5361	2,645	0.08
2686	2239	WDGWD	1523	302	0.08
2687	2672	ABBOT	1902	122	0.07
2688	2256	AIRPK	8432	966	0.07
2689	2775	BEAST	4088	156	0.07
2690	1458	BKBNT	1842	596	0.07
2691	2796	BLKST	1732	1,735	0.07
2692	2756	BNDRA	0003	738	0.07
2693	2925	BNDRA	0005	1,267	0.07
2694	201	BRHLW	7612	714	0.07
2695	184	BSPSW	0812	263	0.07
2696	293	CLLVL	0001	531	0.07
2697	2387	CLYVL	9323	1,432	0.07
2698	1817	COMRC	1204	633	0.07
2699	2332	CRLTN	1402	1,069	0.07
2700	2340	CRNRD	0004	597	0.07
2701	2072	CRSCN	1202	637	0.07
2702	1136	DALLW	0004	1,444	0.07
2703	525	DALWT	2941	310	0.07
2704	2486	DESPR	1408	1,955	0.07
2705	150	ELZCK	4911	41	0.07
2706	928	ENTOH	0006	1,955	0.07
2707	2886	EXPKY	8142	29	0.07
2708	2144	EZACH	0003	1,282	0.07
2709	307	EZACH	0007	1,599	0.07
2710	1596	FRMBG	1707	448	0.07
2711	1739	FRMNT	0001	865	0.07
2712	2416	FRNKF	0001	968	0.07
2713	1930	FROKS	0005	1,423	0.07
2714	2208	FROKS	0006	989	0.07
2715	913	GAVSW	0004	851	0.07
2716	3032	GSTHW	1616	153	0.07
2717	2873	GVODS	3052	664	0.07
2718	2646	HKBRY	1105	198	0.07
2719	3131	INAIR	1414	2,625	0.07
2720	1188	KMASB	1711	295	0.07
2721	2578	KNLTR	0001	2,205	0.07
2722	2242	KNLTR	0005	2,393	0.07
2723	2168	LMESA	1531	625	0.07
2724	1753	LOMAL	0002	524	0.07
2725	3138	LSCOL	2142	15	0.07
2726	3140	LTVSB	5422	15	0.07
2727	2922	LWSNR	2211	1,646	0.07
2728	2283	LWSNR	2241	1,093	0.07
2729	2893	MCDMT	2531	2,453	0.07
2730	1632	MDWPK	9221	964	0.07
2731	3006	MORHD	4105	950	0.07

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
2732	155	MSLSW	0003	178	0.07
2733	832	PALRD	2204	696	0.07
2734	274	PRSTN	0006	769	0.07
2735	337	RDRSE	2602	6,507	0.07
2736	512	RECCR	0006	468	0.07
2737	3172	RSNHT	1111	350	0.07
2738	2009	RVRFT	0002	339	0.07
2739	2635	RYSSW	2801	2,042	0.07
2740	1634	SHDYG	7841	346	0.07
2741	2967	SMFLD	2372	641	0.07
2742	2833	SORCY	0004	597	0.07
2743	N/A	THORN	6822	441	0.07
2744	1238	TYLGE	1316	2,972	0.07
2745	2855	WXHCH	1205	649	0.07
2746	1663	WXHNW	2903	949	0.07
2747	346	ANASE	1901	1,244	0.06
2748	2513	ARLNG	1241	625	0.06
2749	2919	BDFWD	8911	940	0.06
2750	2502	BLMND	3262	141	0.06
2751	2057	BLUEA	2104	17	0.06
2752	2472	BRTRD	7322	1,353	0.06
2753	475	BRYAN	0001	18	0.06
2754	2697	CDHIL	1614	1,323	0.06
2755	361	CHYNE	9111	17	0.06
2756	2849	CLLVL	0004	51	0.06
2757	2666	COLNY	2406	844	0.06
2758	1255	CRSGL	1303	115	0.06
2759	2698	CURIE	7221	919	0.06
2760	2241	EGFRD	0004	1,871	0.06
2761	1325	EULTB	5711	2,402	0.06
2762	1177	EXPKY	8112	18	0.06
2763	1921	EXPKY	8121	17	0.06
2764	353	GAVSW	0003	50	0.06
2765	1007	GAVSW	0011	210	0.06
2766	707	GRVPT	7521	170	0.06
2767	1133	HHSTH	1503	2,351	0.06
2768	2804	HKBRY	1107	1,009	0.06
2769	2956	HORNE	1912	1,806	0.06
2770	468	HORNE	1913	1,571	0.06
2771	3060	HUTTO	2723	3,846	0.06
2772	2570	IRVNR	1552	82	0.06
2773	55	JACKR	7611	1,616	0.06
2774	318	JACKR	7612	1,259	0.06
2775	1937	JNKNS	0004	332	0.06
2776	2732	KLELM	2201	2,517	0.06
2777	2380	LIGSW	1608	389	0.06
2778	2859	LKMNT	0004	2,210	0.06
2779	2406	LOMAL	0014	581	0.06

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
2780	1508	MCHSN	1201	250	0.06
2781	1070	MDDTN	4321	1,140	0.06
2782	2517	MSTLT	1032	18	0.06
2783	514	MURPH	2756	3,889	0.06
2784	2817	NPKWY	0011	4,163	0.06
2785	2493	ODESA	0221	759	0.06
2786	929	PCOIT	1025	3,245	0.06
2787	1061	PJPTR	3211	130	0.06
2788	1218	PLGRV	0004	794	0.06
2789	2809	PNTIS	0282	2,075	0.06
2790	2312	PROAD	0007	247	0.06
2791	2521	REAST	1504	1,319	0.06
2792	338	REAST	1505	1,685	0.06
2793	296	RGLRW	0003	93	0.06
2794	2895	RNKSW	5412	33	0.06
2795	1304	SALSW	3004	1,578	0.06
2796	762	SHDYG	7812	130	0.06
2797	133	TERSO	2503	1,511	0.06
2798	53	THRNE	0008	2,240	0.06
2799	1842	TMPNW	1102	685	0.06
2800	146	TYBLR	2801	1,238	0.06
2801	495	TYWST	2002	518	0.06
2802	2177	TYWST	2004	1,022	0.06
2803	2446	WALNT	0005	1,039	0.06
2804	1381	WBROK	3011	184	0.06
2805	2924	WFALS	0163	349	0.06
2806	1393	WILLO	7821	17	0.06
2807	3187	WMMMR	2706	32	0.06
2808	2476	WMRNR	0002	429	0.06
2809	1702	WNDWD	3672	241	0.06
2810	433	WRBND	2322	933	0.06
2811	2774	WSTHL	3621	1,367	0.06
2812	2484	ALLEN	2405	20	0.05
2813	1052	BAKKE	6922	1,727	0.05
2814	962	BKWST	0005	944	0.05
2815	1584	BLMGR	1901	277	0.05
2816	2331	BRNSO	1805	790	0.05
2817	2114	CDHCR	2051	2,129	0.05
2818	9	CHICC	1701	55	0.05
2819	1707	CHROW	0003	153	0.05
2820	1087	DPCRK	1842	1,369	0.05
2821	3029	DUPUY	1220	209	0.05
2822	768	EGFRD	0001	1,815	0.05
2823	3042	ELKTN	2503	1,116	0.05
2824	2979	FHLSW	1382	121	0.05
2825	2510	FRMNT	0004	2,044	0.05
2826	2813	GSTHW	1626	21	0.05
2827	2931	HKBRY	1109	551	0.05

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
2828	254	INAIR	1432	2,513	0.05
2829	2405	IRVVV	2804	1,047	0.05
2830	N/A	KNEDL	6362	2,940	0.05
2831	478	LAVON	1454	3,179	0.05
2832	2282	LKBLT	2102	1,898	0.05
2833	3139	LTMAN	1511	66	0.05
2834	2086	MDLNW	1582	1,540	0.05
2835	1784	MKNSO	3612	1,956	0.05
2836	N/A	MNFLD	2623	2,330	0.05
2837	167	MRTNS	1503	393	0.05
2838	2932	MSTLT	1021	1,154	0.05
2839	1242	MTLDA	0007	2,489	0.05
2840	2685	NHNSW	0008	595	0.05
2841	1075	PCOIT	1005	1,099	0.05
2842	1924	PRKWY	1542	543	0.05
2843	2554	PROAD	0002	866	0.05
2844	2834	PROAD	0003	1,112	0.05
2845	1906	PROAD	0004	1,003	0.05
2846	2974	PWEST	1306	710	0.05
2847	959	PWEST	1308	859	0.05
2848	1141	RCLNS	1401	103	0.05
2849	3062	SCHRD	0006	519	0.05
2850	3178	SMFLD	2362	63	0.05
2851	2345	STERT	2701	40	0.05
2852	1225	THRNE	0005	1,336	0.05
2853	N/A	TRGLE	1107	73	0.05
2854	856	TYLGE	1306	666	0.05
2855	2829	VENSW	2603	1,007	0.05
2856	810	WEBBS	8633	2,836	0.05
2857	590	WHTRK	0003	1,280	0.05
2858	3186	WMMMR	2704	19	0.05
2859	691	WRIDG	3055	2,259	0.05
2860	766	ABRRD	0004	880	0.04
2861	771	ALDTU	9411	1,041	0.04
2862	1197	ARTHR	0452	635	0.04
2863	1443	BARNW	4513	28	0.04
2864	1115	BLTLN	0006	923	0.04
2865	2363	BOWEN	3142	1,268	0.04
2866	N/A	BRYAN	0003	24	0.04
2867	1941	BRYAN	0007	593	0.04
2868	828	CLBWS	8111	1,614	0.04
2869	2193	CMTSW	0916	575	0.04
2870	874	CMTSW	0966	130	0.04
2871	2961	COMRC	1202	50	0.04
2872	3103	CRLUD	1301	24	0.04
2873	2850	CRLUD	1306	25	0.04
2874	680	CURIE	7211	849	0.04
2875	3012	CURIE	7231	1,061	0.04

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
2876	2499	DALLW	0002	67	0.04
2877	2962	DALWT	2972	256	0.04
2878	1722	DAVIS	3723	344	0.04
2879	2963	DAVIS	3762	52	0.04
2880	1579	DENDR	0008	126	0.04
2881	3105	DFWNW	2403	23	0.04
2882	2341	EULSO	9121	106	0.04
2883	1422	EZACH	0006	1,359	0.04
2884	2954	FRNKF	0003	1,141	0.04
2885	2054	FROKS	0001	1,366	0.04
2886	2337	FRSCW	3701	2,221	0.04
2887	3124	GAMMA	2201	72	0.04
2888	2786	GRAHM	0713	381	0.04
2889	1768	GSTHW	1646	1,175	0.04
2890	N/A	GUNSO	9921	720	0.04
2891	2771	HMPHL	2723	54	0.04
2892	1706	HMPHL	2762	1,357	0.04
2893	2633	HMPHL	2791	26	0.04
2894	3004	HURST	1841	1,381	0.04
2895	2951	HURST	1852	1,739	0.04
2896	3082	IRVRS	4411	980	0.04
2897	1392	LAVON	1452	2,172	0.04
2898	797	LGVST	8522	1,459	0.04
2899	1621	LKHLD	0007	1,334	0.04
2900	236	MAPLE	0001	1,056	0.04
2901	2482	MCDMT	2552	724	0.04
2902	2917	MDLNE	0151	317	0.04
2903	2253	MESQN	1508	1,742	0.04
2904	1793	MESTE	1203	184	0.04
2905	850	MTLDA	0006	2,589	0.04
2906	2130	MYPRL	1801	192	0.04
2907	2237	NHNSW	0003	736	0.04
2908	1347	PFLGV	2002	2,409	0.04
2909	1049	PJPTR	3221	46	0.04
2910	2973	PRKRW	3382	293	0.04
2911	689	PTENN	2353	968	0.04
2912	3087	RCLNS	1402	880	0.04
2913	2366	RCLNS	1404	721	0.04
2914	2603	RSPCK	2104	2,639	0.04
2915	2764	RSPCK	2107	913	0.04
2916	3052	SCHRD	0002	292	0.04
2917	2772	SCHRD	0004	1,872	0.04
2918	385	SHAMP	0005	2,014	0.04
2919	1069	SHNRW	1607	603	0.04
2920	2724	SHSTH	1305	559	0.04
2921	2166	SMPST	0005	428	0.04
2922	2560	SORCY	0003	846	0.04
2923	919	STERT	2703	743	0.04

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
2924	2854	STNVL	1202	48	0.04
2925	2986	TMSTH	1407	262	0.04
2926	1778	TYLNE	1624	213	0.04
2927	454	VESTS	3121	25	0.04
2928	2687	VGCRK	8031	1,802	0.04
2929	131	WALNT	0004	1,470	0.04
2930	2818	WDGWD	1561	1,490	0.04
2931	1270	WEBBS	8612	4,111	0.04
2932	869	WFALS	0143	200	0.04
2933	1275	WRIDG	3056	812	0.04
2934	3019	WRTHM	5017	161	0.04
2935	727	ABRRD	0001	2,394	0.03
2936	2760	ABRRD	0006	474	0.03
2937	2454	ALPHA	0004	60	0.03
2938	2810	ARMST	0004	1,205	0.03
2939	3010	ARMST	0011	781	0.03
2940	3008	ARMST	0012	1,777	0.03
2941	2766	BLMED	1619	610	0.03
2942	3026	BLMGR	1902	187	0.03
2943	2960	BNDRA	0001	870	0.03
2944	739	CHROW	0008	36	0.03
2945	2811	CLLVL	0006	1,443	0.03
2946	2459	CPLSO	4321	188	0.03
2947	2468	CRTLD	4734	821	0.03
2948	N/A	CYOTE	2154	250	0.03
2949	3056	DALWT	2952	658	0.03
2950	327	DENDR	0006	38	0.03
2951	2704	DESHR	1202	1,616	0.03
2952	2964	DUPUY	1216	265	0.03
2953	2908	DUPUY	1217	102	0.03
2954	2812	DUPUY	1222	198	0.03
2955	N/A	EDGCF	2214	408	0.03
2956	2052	ELKTN	2501	867	0.03
2957	2630	EMPCT	0002	106	0.03
2958	2987	EULSO	9141	92	0.03
2959	3119	EXPKY	8141	34	0.03
2960	2904	FRMBR	1853	66	0.03
2961	2982	FROKS	0004	115	0.03
2962	2858	FSCRK	6714	2,231	0.03
2963	1608	IRVBL	2501	381	0.03
2964	909	IRVBL	2502	184	0.03
2965	2692	KLELM	2202	1,398	0.03
2966	2852	KLELM	2204	442	0.03
2967	852	KLNCC	1704	341	0.03
2968	2808	KNLTR	0009	861	0.03
2969	N/A	LKCRS	4222	2,070	0.03
2970	100	LOMAL	0015	169	0.03
2971	3141	LVBRD	0001	40	0.03

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
2972	335	MCGHR	2004	31	0.03
2973	3146	MKNNY	1204	38	0.03
2974	291	MSHLN	0005	496	0.03
2975	2258	NPKWY	0008	860	0.03
2976	2753	PALRD	2208	1,014	0.03
2977	N/A	PEGAS	2322	33	0.03
2978	2927	PLANO	1106	560	0.03
2979	897	PLSTH	1303	573	0.03
2980	2360	PRKRW	3341	293	0.03
2981	2164	PRKRW	3352	1,569	0.03
2982	N/A	RKCRK	6122	3,578	0.03
2983	2928	ROBNW	1505	1,054	0.03
2984	2344	RWDHV	1906	642	0.03
2985	2853	SHMNE	1405	850	0.03
2986	2738	SORCY	0001	2,780	0.03
2987	3179	SORCY	0002	66	0.03
2988	789	STHRL	0007	295	0.03
2989	297	TMNTH	1601	31	0.03
2990	N/A	TRGLE	1109	191	0.03
2991	2709	WALNT	0008	875	0.03
2992	1068	WOVER	6111	1,450	0.03
2993	1158	ACRLY	1711	171	0.02
2994	2142	AMLIA	0008	139	0.02
2995	2739	ARMST	0002	2,042	0.02
2996	341	ATNRN	3412	4,211	0.02
2997	1940	BLMND	3221	111	0.02
2998	N/A	BUFLO	2604	58	0.02
2999	2938	CNEXP	0005	463	0.02
3000	2620	COPEL	3054	1,314	0.02
3001	3028	CRLTR	2054	111	0.02
3002	780	CRLUD	1302	165	0.02
3003	N/A	CTRLA	1924	97	0.02
3004	1290	CURIE	7222	1,032	0.02
3005	2894	DENAV	0612	60	0.02
3006	2930	DGNST	0005	515	0.02
3007	770	EDGCF	2252	389	0.02
3008	2884	ENNIS	1905	56	0.02
3009	3121	FRMBG	1708	45	0.02
3010	821	FRMNT	0003	1,147	0.02
3011	2221	FRNKF	0007	1,883	0.02
3012	N/A	GDPRW	9631	125	0.02
3013	2905	GRHWY	5521	2,243	0.02
3014	2761	GSTHW	1613	52	0.02
3015	2995	HKBRY	1101	746	0.02
3016	1446	HUTTO	2713	3,025	0.02
3017	1998	IRVHF	2303	90	0.02
3018	2728	IRVNE	1305	244	0.02
3019	715	JKSES	3028	324	0.02

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
3020	3066	JNKNS	0006	696	0.02
3021	2462	KRUMS	1201	533	0.02
3022	1193	LKMNT	0001	203	0.02
3023	2898	MAYFD	5531	1,642	0.02
3024	2778	MSTLT	1042	875	0.02
3025	2989	NHNSW	0002	410	0.02
3026	2383	NHNSW	0005	488	0.02
3027	3073	NNTWK	0008	1,902	0.02
3028	2881	ODESW	5211	2,239	0.02
3029	1196	PAYNE	1223	133	0.02
3030	833	PCOMM	3311	44	0.02
3031	2305	PFLGV	2003	4,060	0.02
3032	1387	PJPTR	3212	48	0.02
3033	1280	PNTIS	0272	854	0.02
3034	2990	PROAD	0005	124	0.02
3035	2788	ROLTR	2911	1,818	0.02
3036	1804	RWALL	1201	1,485	0.02
3037	2497	SANSM	3913	2,043	0.02
3038	1083	SHDYG	7811	404	0.02
3039	2906	SHDYG	7831	101	0.02
3040	1103	THORN	6811	136	0.02
3041	2991	TRLSW	1202	64	0.02
3042	N/A	TYLER	1007	112	0.02
3043	872	VANAL	1201	657	0.02
3044	2339	WEAST	0619	1,162	0.02
3045	3025	WEBBS	8634	1,644	0.02
3046	1821	ABBOT	1901	112	0.01
3047	2993	ALNTH	2842	2,716	0.01
3048	2652	ALPHA	0005	123	0.01
3049	594	ATNRN	3432	3,581	0.01
3050	674	BARRY	1801	94	0.01
3051	3027	BLTON	1804	475	0.01
3052	1658	BNDRA	0013	387	0.01
3053	1333	BUFLO	2603	1,298	0.01
3054	1338	CMPST	0004	1,774	0.01
3055	2970	CNEXP	0008	287	0.01
3056	875	COTRD	0003	112	0.01
3057	1535	CRLCC	2704	544	0.01
3058	187	CRLTN	1408	126	0.01
3059	255	CRLTN	1451	146	0.01
3060	2945	CURIE	7241	798	0.01
3061	3038	DCATR	1205	119	0.01
3062	3039	DFWSE	2710	107	0.01
3063	363	DGNST	0002	465	0.01
3064	3057	DGNST	0007	526	0.01
3065	N/A	DWIND	2201	75	0.01
3066	836	EMPCT	0005	71	0.01
3067	3077	EULES	8714	978	0.01

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
3068	3065	FLMSO	3711	2,544	0.01
3069	678	FRMBG	1753	702	0.01
3070	176	FRMNT	0011	1,168	0.01
3071	3058	FRMNT	0014	788	0.01
3072	1853	GAVSW	0008	86	0.01
3073	2563	GAVSW	0012	829	0.01
3074	2887	GRLTC	3801	929	0.01
3075	2706	GRPVN	8211	147	0.01
3076	3129	GVODS	3021	2,050	0.01
3077	2955	HKBRY	1117	145	0.01
3078	2632	HMPHL	2711	1,166	0.01
3079	2920	HMPHL	2713	777	0.01
3080	2533	HMPHL	2752	422	0.01
3081	2971	HMPHL	2792	676	0.01
3082	3033	HORNE	1932	2,439	0.01
3083	2691	HRSMD	1953	1,181	0.01
3084	3135	JNKNS	0001	249	0.01
3085	2966	KLNTF	1803	1,052	0.01
3086	2763	LEMON	0004	792	0.01
3087	N/A	LKCRS	4212	1,879	0.01
3088	2988	LOMAL	0005	405	0.01
3089	2092	LSCOL	2140	1,384	0.01
3090	1580	MABNK	2403	168	0.01
3091	342	MCDMT	2542	471	0.01
3092	N/A	MDDTN	4332	218	0.01
3093	842	MDLNE	0161	218	0.01
3094	3143	MESQN	1506	78	0.01
3095	N/A	MMILL	3912	94	0.01
3096	2880	MSTLT	1073	172	0.01
3097	3061	PCOIT	1023	411	0.01
3098	2579	PEGAS	2311	68	0.01
3099	3160	PLANO	1108	483	0.01
3100	2412	PNTIS	0211	328	0.01
3101	1374	PPARK	1804	350	0.01
3102	3048	PROAD	0009	141	0.01
3103	3165	PSHIL	1613	566	0.01
3104	950	PTENN	2355	179	0.01
3105	1635	RCHHL	0394	234	0.01
3106	808	REGST	0004	953	0.01
3107	N/A	REGST	0010	126	0.01
3108	110	RGLRW	0002	215	0.01
3109	1794	RRSTH	1702	1,791	0.01
3110	2846	RSPCK	2132	76	0.01
3111	1250	RVRFT	0003	1,273	0.01
3112	2781	SANSM	3911	2,071	0.01
3113	1132	SYCRK	4531	3,654	0.01
3114	2836	WALNT	0002	1,246	0.01
3115	3024	WEAST	0628	267	0.01

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
3116	3063	WHITE	3541	950	0.01
3117	3069	WMRNR	0003	931	0.01
3118	N/A	WXHCH	1208	277	0.01
3119	3091	ALPHA	0012	10	0.00
3120	2867	AMLIA	0003	27	0.00
3121	979	AMLIA	0005	18	0.00
3122	N/A	APPLE	2511	97	0.00
3123	N/A	APPLE	2521	463	0.00
3124	3092	ARLNG	1291	87	0.00
3125	281	ATNRN	3411	3,035	0.00
3126	785	ATNRN	3431	2,093	0.00
3127	2629	BKWST	0001	390	0.00
3128	2999	BKWST	0006	146	0.00
3129	N/A	BLAIN	3511	42	0.00
3130	2734	BLMND	3211	16	0.00
3131	N/A	BNMAG	1201	249	0.00
3132	3095	BRNSO	1804	14	0.00
3133	3002	BRYAN	0002	219	0.00
3134	160	CMPST	0002	1,733	0.00
3135	999	COTRD	0005	231	0.00
3136	3100	COTRD	0007	177	0.00
3137	3101	CRLFR	2153	471	0.00
3138	3102	CRLTR	2006	54	0.00
3139	1837	DENAV	0641	38	0.00
3140	1470	DENDR	0009	66	0.00
3141	2447	DESHR	1208	462	0.00
3142	3104	DFWNW	2402	11	0.00
3143	3106	DFWNW	2408	30	0.00
3144	3107	DFWSE	2713	18	0.00
3145	3108	DFWSE	2715	10	0.00
3146	1016	DFWSW	2322	32	0.00
3147	2819	DFWSW	2323	42	0.00
3148	3109	DFWSW	2325	14	0.00
3149	3111	DGNST	0003	1,424	0.00
3150	3071	DGNST	0006	447	0.00
3151	3112	DNINR	1402	393	0.00
3152	1511	DUPUY	1218	38	0.00
3153	3113	DUPUY	1221	32	0.00
3154	N/A	DUVAL	7711	1,071	0.00
3155	N/A	DUVAL	7712	1,661	0.00
3156	1388	ECTHM	3312	19	0.00
3157	3115	ENSSE	3011	12	0.00
3158	3043	ENTOH	0008	266	0.00
3159	3116	EXPKY	8111	11	0.00
3160	3118	EXPKY	8131	17	0.00
3161	N/A	FLRTN	3711	55	0.00
3162	N/A	FLRTN	3721	124	0.00
3163	3120	FORSN	5611	10	0.00

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
3164	414	FRMBG	1704	30	0.00
3165	2980	FRMNT	0012	543	0.00
3166	3123	FRMNT	0015	234	0.00
3167	N/A	GODRD	8171	839	0.00
3168	3125	GRLTC	3805	11	0.00
3169	2770	GSTHW	1615	34	0.00
3170	3127	GSTHW	1625	47	0.00
3171	3128	GSTHW	1634	15	0.00
3172	N/A	GSTHW	1635	18	0.00
3173	2551	GSTHW	1636	38	0.00
3174	3130	HORNE	1944	712	0.00
3175	1549	INWRD	0002	1,193	0.00
3176	N/A	IRVNE	1311	1,428	0.00
3177	3133	IRVVV	2854	17	0.00
3178	N/A	JDKNS	0812	35	0.00
3179	3136	JNKNS	0002	640	0.00
3180	2965	JNKNS	0005	669	0.00
3181	948	JNKNS	0008	839	0.00
3182	N/A	KNEDL	6322	3,964	0.00
3183	922	KNLTR	0004	1,373	0.00
3184	2252	KNLTR	0007	13	0.00
3185	1005	LEMON	0008	1,005	0.00
3186	N/A	LKCRS	4232	229	0.00
3187	1885	LMBLN	0008	121	0.00
3188	218	LMESA	2833	22	0.00
3189	N/A	LOYLK	1901	724	0.00
3190	2268	LSCOL	2135	719	0.00
3191	3084	LSCOL	2137	808	0.00
3192	3034	LSCOL	2148	1,866	0.00
3193	3035	MAPLE	0008	215	0.00
3194	997	MCDMT	2551	3,214	0.00
3195	2814	MDDTN	4322	18	0.00
3196	N/A	MDLNW	1544	1,295	0.00
3197	N/A	MSTNG	2921	53	0.00
3198	3152	NCRST	2202	34	0.00
3199	2572	NCSTH	1504	66	0.00
3200	613	NOLNW	2111	23	0.00
3201	3154	NPKWY	0007	159	0.00
3202	N/A	OILML	3612	15	0.00
3203	1004	PJPTR	3222	190	0.00
3204	3159	PJPTR	3231	28	0.00
3205	3162	PNTIS	0231	15	0.00
3206	484	PRCRK	0001	73	0.00
3207	2118	PRCRK	0002	2,503	0.00
3208	2826	PRCRK	0004	1,146	0.00
3209	3163	PROAD	0001	125	0.00
3210	2640	PROAD	0006	137	0.00
3211	1471	PRSTN	0005	1,077	0.00

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
3212	1997	PTENN	2357	1,214	0.00
3213	3086	PWEST	1310	1,138	0.00
3214	2288	RDRSE	2605	1,015	0.00
3215	N/A	RENTL	2201	34	0.00
3216	1776	RGLRW	0001	42	0.00
3217	2815	ROANW	9522	82	0.00
3218	3171	ROLTR	2913	1,989	0.00
3219	1807	RRWES	1603	11	0.00
3220	328	RSPCK	2105	1,075	0.00
3221	N/A	SBANA	2011	202	0.00
3222	N/A	SBANA	2021	259	0.00
3223	2610	SFTLK	4011	36	0.00
3224	2948	SHDYG	7832	793	0.00
3225	3176	SHSTH	1302	22	0.00
3226	N/A	SIKES	2432	2,003	0.00
3227	N/A	SMCRK	2611	361	0.00
3228	3053	SMPST	0008	456	0.00
3229	2717	STERT	2704	15	0.00
3230	3182	STERT	2705	13	0.00
3231	2891	TMNTH	1604	493	0.00
3232	2773	TMPNW	1103	1,114	0.00
3233	3185	VLRYN	2958	347	0.00
3234	1504	WALST	0007	27	0.00
3235	2830	WITTS	1704	27	0.00
3236	2978	WMMMR	2705	1,235	0.00
3237	2981	WMRNR	0004	373	0.00
3238	N/A	WXOCF	1402	13	0.00

2021's customer count was used due to feeder reconfiguration:

BLISS9411
 BLISS9421
 FHLSW1332
 HUDSN1603
 IRVHF2305
 KLBRG0003
 MCGHR2003
 MDLNW1521
 MDLNW1532
 MNFLD2672
 ODESW5922
 RKCRK6111
 SHNRW1601
 SMPST0003
 SYCRK4512
 TMNTH1603
 TXHRV1621
 TYEST1501

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
-------------------------------	-------------------------------	--------------------------------------	----------------------------------	--------------------------------	-----------------------------

WHITE3532

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

Total Number of Feeders

With 10 or more Customers

3,238

Add or Delete Rows as Necessary

Oncor Electric Delivery

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
1	N/A	BLAKE	1711	281	3,402.23
2	14	KYSTN	1011	114	2,255.38
3	114	MKNSW	2601	1,182	2,198.58
4	N/A	BLAKE	1721	46	1,744.56
5	2028	JDKNS	0821	31	1,624.61
6	58	DOLEY	8011	56	1,565.21
7	67	MEANS	4421	45	1,549.98
8	1890	LDRAW	6623	172	1,509.00
9	34	KRNCH	9021	13	1,473.17
10	29	ALCAT	1211	26	1,226.41
11	90	DGLAS	2401	818	1,216.69
12	85	CSHNG	1201	940	1,182.38
13	504	BULDG	1109	130	1,170.21
14	1081	QNLAN	1202	431	1,158.62
15	1991	ANARN	1911	14	1,109.88
16	1195	WICKT	0431	188	1,070.96
17	22	CRNES	2711	112	1,058.03
18	147	TYRSW	1703	402	1,045.64
19	3092	ALCAT	1222	36	992.74
20	1968	DPCRK	1832	310	991.26
21	2627	LKTMS	2412	38	988.82
22	2501	YARBR	5011	25	984.15
23	62	GASLD	4211	88	977.57
24	106	PGSTH	7012	227	940.39
25	658	HNTNG	1307	1,584	905.88
26	N/A	OWLHL	7713	47	881.42
27	46	MNHNS	1922	94	854.70
28	2	ELMAR	3222	28	849.67
29	98	CWIND	6311	31	835.09
30	2838	TIODE	9622	1,137	827.54
31	1471	NCSFA	1706	1,169	791.53
32	28	RSKMN	3057	1,181	759.13
33	3129	GRVPT	7522	47	741.39
34	30	MDRAW	8211	120	738.32
35	17	FRNKS	1202	100	728.04
36	821	ESTLD	3621	1,581	691.94
37	2245	ANDRD	0921	75	665.48
38	1427	VANSB	1501	890	657.62
39	788	NCNTH	1806	893	656.90
40	2399	JREST	2102	1,148	623.50
41	336	RYLTY	1431	45	611.48
42	2150	PGSTH	7011	52	608.23
43	2613	THRNE	0001	712	607.42

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
44	9	SBEAN	6022	49	596.98
45	458	CMINO	1203	1,824	593.80
46	16	DHIDE	2821	99	592.08
47	2284	WDGWD	1592	1,090	590.88
48	N/A	MMILL	3941	349	579.91
49	2866	BLUEA	2105	116	579.89
50	103	NIPAK	1001	134	570.90
51	100	CSHNG	1202	72	564.86
52	287	TYWST	2012	1,773	550.80
53	44	BLAGG	3912	1,050	546.69
54	1512	SCURY	1921	91	535.46
55	132	CLNSE	4203	1,284	518.69
56	887	NECSP	2401	635	513.39
57	464	TRIRA	6221	572	503.86
58	2922	TYLNW	1914	1,120	501.19
59	372	WNDCR	0252	948	499.83
60	285	SBEAN	6011	52	497.91
61	796	ALKLK	4222	43	494.33
62	246	LEMON	0006	730	479.53
63	1450	NCSTH	1501	801	477.17
64	1089	IVANS	1612	1,084	471.28
65	635	BSPSW	0822	254	468.01
66	12	CRNAT	4121	54	466.16
67	20	HNTNG	1301	1,519	463.70
68	172	GLSCK	2411	201	458.10
69	27	NCWDN	1121	46	456.72
70	2746	COYNW	8122	83	452.91
71	349	BRTLTL	1402	152	451.45
72	2069	HRSHD	5821	127	446.93
73	1416	GORMN	0411	571	446.53
74	167	WLWSP	1201	623	441.11
75	8	CHILK	7711	15	440.68
76	346	FKLCY	5121	37	435.67
77	1144	CDCRK	1201	1,345	433.87
78	1775	DHIDE	2811	29	430.71
79	1031	MNHNS	1911	1,508	427.18
80	1331	FRMBG	1703	30	418.75
81	84	CSHNG	1204	325	418.15
82	2062	WMRLD	0004	1,583	416.63
83	117	DIALV	3911	1,129	411.21
84	2222	MRTSP	1502	923	410.75
85	2999	BRKTN	1202	139	410.49
86	156	MDFRM	2111	77	410.38
87	360	MLKF2	1201	926	404.56
88	980	TAYLR	1201	1,865	402.62
89	284	JDKNS	0822	32	396.50
90	506	TRPMN	4094	629	394.88
91	1266	CMTSW	0977	270	390.92

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
92	2724	HKBRY	1106	1,872	386.53
93	323	TSLVL	4008	2,228	386.51
94	1952	LIGSW	1621	51	383.90
95	25	CRLSP	1703	271	383.68
96	587	TYOMN	1408	1,350	382.42
97	71	PLOWB	2911	326	378.23
98	2360	OAKHL	3062	2,456	370.35
99	105	RGLRW	0004	81	369.61
100	1026	CRNRD	0007	778	368.21
101	13	CHRNO	1201	538	367.28
102	1350	MEXIA	4008	723	363.16
103	180	TYOMN	1409	1,789	353.70
104	304	SWTWR	1341	251	350.41
105	N/A	TYEST	1505	684	348.57
106	121	SWAN2	1803	1,389	347.42
107	785	BOWEN	3192	1,269	346.88
108	145	RYLTY	1411	111	343.23
109	23	SBEAN	6021	25	340.19
110	3047	PCOMM	3314	864	337.27
111	368	GRSLK	1104	640	337.21
112	1140	CMINO	1204	584	336.92
113	1863	GRSLK	1103	721	335.59
114	774	RDRSE	2607	6,000	335.00
115	3183	TMNTH	1607	12	332.54
116	242	BNEST	3111	2,860	331.63
117	1248	MKNSW	2603	1,270	330.01
118	296	FORSN	5632	253	326.44
119	326	MRTNS	1501	536	326.17
120	3050	MIDNT	3712	5,100	323.53
121	2450	FLGRV	4711	197	323.20
122	735	DCDAM	2001	860	321.57
123	1988	TIODE	9621	229	320.75
124	935	BRLND	7921	931	314.56
125	51	TYLNW	1910	739	312.85
126	705	TYLNE	1605	675	310.81
127	1575	COLNY	2403	2,897	310.00
128	1088	LFEST	1905	1,886	309.62
129	1039	HISKY	8821	155	308.23
130	61	LMESA	2813	119	307.68
131	454	CHRNO	1203	442	307.20
132	1157	CNLRD	2106	319	305.65
133	2465	MCKMY	0812	2,031	305.07
134	223	LKTMS	2411	147	304.06
135	681	BAKKE	6911	326	303.63
136	870	IOWPK	0821	767	302.53
137	203	HOLND	1901	1,166	302.43
138	2628	LWRDR	0002	1,021	290.99
139	2331	HLSES	0511	1,940	290.86

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
140	2907	LTVSB	5451	1,138	290.84
141	2316	OAKCK	2211	36	290.00
142	2608	CMTSW	0957	1,214	287.09
143	582	JKSES	3029	828	286.77
144	1036	JUDCT	0007	527	286.51
145	1417	HDWLK	3003	1,004	286.38
146	906	MRLNS	4003	918	285.92
147	3009	GAMMA	2203	1,237	283.34
148	208	TAYLR	1202	2,056	280.60
149	596	FRMBR	1802	1,145	279.01
150	60	MKNNY	1251	4,310	278.60
151	2407	FINKS	1803	1,539	278.42
152	124	CNTRY	2831	1,650	278.19
153	908	LUTHR	2105	71	277.38
154	606	HKBRY	1111	29	276.58
155	1458	COMSO	1405	813	276.35
156	1216	RSKMN	3053	506	275.26
157	1588	GVFTW	1801	752	272.57
158	509	BARNW	4523	99	271.98
159	2091	NCWDN	1111	876	271.67
160	291	CRKET	2402	1,696	269.77
161	91	CNI45	1202	855	269.13
162	2085	TRPMN	4001	806	268.21
163	1578	OKCLS	0005	261	267.35
164	643	ELMAR	3221	35	266.75
165	193	CUMBY	1201	794	265.57
166	2676	CNLRD	2107	262	264.63
167	N/A	NADAM	2102	10	263.92
168	88	BLISS	9421	263	263.72
169	749	RANGR	4321	817	263.20
170	1514	CRSGL	1301	154	260.44
171	1025	WCITY	2402	688	260.04
172	31	NCSTH	1503	966	258.39
173	2610	CLBNR	1411	618	256.98
174	1808	WALST	0008	12	256.49
175	1423	FHLSW	1321	433	253.61
176	6	MSTNG	2611	137	252.47
177	70	PLOWB	2921	549	250.21
178	1301	BDFWD	8932	1,715	250.03
179	1020	BRKNR	1221	1,152	249.25
180	626	REYST	4118	779	248.94
181	535	VLARN	2951	2,233	246.88
182	1396	RWALS	1852	3,027	246.52
183	760	MEXIA	4023	646	246.26
184	159	ECTHM	3311	1,625	245.75
185	361	CRNTH	2401	2,774	244.64
186	476	TYLNE	1607	762	244.14
187	1733	MESQN	1503	1,834	244.10

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
188	107	MRNFD	2331	41	242.95
189	3073	IRVRS	4413	1,711	242.73
190	252	TEGMN	3038	1,671	241.92
191	1569	GODLY	1601	832	241.55
192	129	CNANG	1806	2,632	240.44
193	68	WINKS	0521	44	238.68
194	1712	TYWST	2003	345	238.43
195	1452	RWALE	3322	2,307	238.17
196	237	SGOVL	1403	2,549	236.54
197	177	MNWLW	1403	1,000	234.08
198	988	HUDSN	1604	974	233.54
199	1397	MESQT	1308	1,875	230.22
200	790	JKWST	4178	476	229.27
201	1057	BAYLC	1201	136	229.12
202	373	BLISS	9411	333	228.83
203	43	ALNSW	2654	1,979	227.74
204	1705	THORN	6812	113	227.52
205	331	SCSES	1201	279	226.98
206	1650	DALWT	2911	346	226.71
207	50	ALKLK	4212	162	225.83
208	1639	ALNSW	2653	3,380	225.63
209	601	ALKLK	4211	67	224.92
210	2823	HOLDY	0911	738	224.82
211	766	PLKST	0007	2,296	224.61
212	93	MASON	3412	137	224.15
213	1644	ALPHA	0013	454	223.04
214	2235	RNKSW	5413	37	222.92
215	380	SWTWR	1321	139	222.25
216	757	GLNHV	3942	792	221.93
217	1855	CRLJL	1508	337	221.74
218	1513	CNEXP	0003	1,412	221.41
219	699	ELKTN	2506	549	221.15
220	2931	CRNSO	3911	535	220.56
221	N/A	WXHCH	1206	539	220.30
222	437	MNFLD	2672	2,557	220.16
223	974	PCUST	2004	1,216	219.28
224	2842	LENSW	0321	69	219.22
225	430	CTFLD	9911	2,121	219.06
226	1547	ALNSW	2651	2,986	218.94
227	345	IRVNR	1551	1,366	218.39
228	268	THRDN	1921	1,215	218.13
229	123	ECTHP	4921	797	218.05
230	911	KMP SO	2400	990	216.61
231	397	FRMBR	1804	198	215.98
232	732	ALNTH	2854	795	214.96
233	2528	RTHGB	1411	700	214.79
234	2097	HKBRY	1115	17	214.69
235	1898	EDWDS	5931	678	214.54

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
236	394	TMNTH	1603	118	214.21
237	213	NCSFA	1704	1,424	213.79
238	133	CLKVL	1201	434	213.37
239	2308	BNBOR	1203	356	213.16
240	89	MCGRG	0775	1,162	210.43
241	2415	ADMDS	6521	2,118	210.24
242	2430	ODESW	5932	542	209.55
243	479	TRNDD	1201	488	209.11
244	770	MDWCK	0005	1,038	208.73
245	187	WICKT	0411	117	208.70
246	1501	HUDSN	1601	1,015	208.68
247	440	GSMTH	1721	50	207.40
248	768	TEGMN	3040	774	207.23
249	2180	CDHIL	1801	1,145	206.62
250	2919	KLNSO	4512	2,546	205.64
251	2372	SLAKE	8312	3,393	204.71
252	329	MRVLY	2311	378	204.60
253	150	JKSNR	4111	484	204.44
254	550	LVOAK	1601	1,225	204.27
255	227	DIBOL	1506	575	203.95
256	21	SBEAN	6012	85	203.58
257	3147	MIDNT	3711	2,501	203.47
258	2704	PBELL	4831	1,231	203.34
259	442	LUFKN	1206	1,744	203.01
260	1172	QNLAN	1201	891	202.05
261	1309	MKNNY	1202	1,945	202.02
262	2619	FHLSW	1332	574	201.84
263	376	HUTCH	1502	232	201.67
264	2732	ALPHA	0016	1,986	199.57
265	862	TMSTH	1408	766	199.43
266	365	CRNTH	2402	1,422	199.40
267	947	BKWFF	0521	460	199.01
268	1164	OVRTN	4037	98	198.49
269	712	CLMET	0003	901	197.92
270	839	TYSTH	1209	817	197.37
271	1072	MNWLE	1701	772	197.36
272	N/A	BATLE	4111	1,291	197.25
273	332	BARRY	1802	358	196.70
274	200	BUFLO	2601	1,619	196.33
275	63	CNI45	2402	785	196.32
276	328	NCSTH	1506	101	196.09
277	400	NLNVL	2003	762	195.96
278	1053	AIRPK	8411	819	195.86
279	954	OTTOJ	3060	17	194.25
280	1517	ARMST	0010	819	194.21
281	1498	ATHNW	1404	1,483	194.18
282	127	TYLGE	1311	882	194.05
283	1394	SMFLD	2381	856	193.30

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
284	2108	PSHIL	1603	1,861	192.15
285	64	CRKET	2405	321	191.03
286	1659	CHYNE	9122	36	191.01
287	1462	SWDTN	1631	1,570	190.75
288	1604	ELCTR	1211	271	190.73
289	1507	WXHCH	1201	1,765	190.17
290	338	TROYS	1014	1,448	189.68
291	265	GYVLM	8611	15	189.63
292	709	HMTRD	0002	1,719	189.42
293	3188	WMMMR	2708	24	189.23
294	65	FRNKS	4168	1,003	187.55
295	2868	FRMBG	1705	277	187.48
296	2860	MRDCK	0004	852	185.42
297	2228	SSPNE	1405	501	184.61
298	2925	RWDHV	1903	1,248	184.40
299	405	LVOAK	1602	1,121	184.19
300	589	SCYEN	0003	1,277	184.19
301	269	KLBRG	0002	1,456	184.12
302	500	NCNTH	1802	1,320	184.02
303	168	KIMBL	5022	915	183.80
304	2106	IRVBL	2503	1,921	183.04
305	503	SMPST	0003	1,092	182.63
306	263	WINKS	0531	37	182.50
307	312	PLKST	0004	1,373	182.46
308	2441	SHAMP	0004	1,171	182.40
309	1747	PFFRD	3472	1,292	182.27
310	2217	MESQT	1302	1,633	181.55
311	2148	HLSBR	1204	574	181.50
312	2592	DENDR	0005	478	181.23
313	670	RWALL	1202	2,866	180.62
314	2739	NCRST	2203	498	180.59
315	2714	GSMTH	1731	37	180.22
316	1189	LNCST	1604	657	180.15
317	141	RYSSW	2803	3,307	179.73
318	474	GVFTW	1802	1,113	179.16
319	1572	IRVHF	2305	1,483	178.55
320	1667	PKRVL	1053	1,360	178.43
321	137	HNTNG	1302	43	178.15
322	313	WSMWS	9821	1,464	177.43
323	863	FRNKS	1201	415	177.27
324	2511	FHLSW	1361	1,544	176.82
325	1084	GLSCN	6211	101	176.76
326	2649	FSTVW	0006	1,223	176.54
327	2478	JUDCT	0001	1,799	176.28
328	205	BRIRV	6911	3,044	176.07
329	1724	CGRSW	9811	64	175.81
330	480	PRNTH	1405	1,061	175.51
331	455	MCWHT	3511	3,424	175.24

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
332	491	LNGLK	1604	471	175.02
333	94	GRDNE	9211	499	174.87
334	955	WNRTH	1417	1,691	174.84
335	2179	LMESA	1512	1,770	174.69
336	282	PRNTH	1404	1,564	174.39
337	1969	CDHIL	1805	621	173.21
338	1506	GRPTT	9921	599	173.01
339	578	BRIRV	6921	2,438	172.52
340	2270	RYLTY	1421	389	172.39
341	419	CDHCR	2050	817	172.23
342	217	IRVNR	1553	1,658	172.05
343	782	TRPMN	4023	431	171.93
344	1015	CNTRY	2823	1,888	171.65
345	283	DIBOL	1505	1,439	171.51
346	1297	IRASB	3211	274	171.16
347	783	KLBRG	0003	1,695	169.96
348	142	CDMIL	2401	1,436	169.67
349	118	CAMRN	1203	1,288	169.63
350	4	ELMAR	3232	77	169.12
351	1766	LKMNT	0008	1,214	168.76
352	131	EUSTC	2402	859	168.51
353	695	JKSNR	4109	652	168.46
354	1503	BLKRV	8311	46	168.31
355	1085	BNTDR	0002	1,858	166.83
356	1755	BLMED	1621	628	166.63
357	912	CRWLY	7021	4,118	166.27
358	511	WOVER	6151	1,738	166.07
359	2577	THRDN	1901	692	166.06
360	258	LFEST	1904	1,418	165.76
361	2321	SHNRW	1614	1,405	165.38
362	515	ECTHP	4911	1,373	165.26
363	3010	BKWST	0004	1,085	165.21
364	119	BLMND	3223	491	165.10
365	392	PLSTN	1002	1,246	165.03
366	2123	MYPTX	2401	364	164.96
367	197	OVRTN	4015	632	164.17
368	N/A	MDLNW	1554	1,192	163.85
369	3013	JUDCT	0002	1,383	162.94
370	32	KEYSB	2621	13	162.90
371	2345	WEAST	0621	298	162.82
372	909	GNSVE	1603	1,776	162.75
373	293	RICES	0208	818	162.49
374	1631	ATHNW	1401	909	161.90
375	1014	LUFKN	1205	1,328	161.85
376	108	ARPMN	4149	347	161.74
377	2409	IVANS	1621	66	161.64
378	1982	BOWEN	3132	1,811	161.55
379	1536	MEXIA	4011	1,063	161.19

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
380	2911	MESQW	1805	85	160.79
381	553	DELTA	1702	490	160.53
382	N/A	ELKHR	1502	215	160.45
383	298	CRKET	2403	2,819	159.19
384	402	HDWLK	3005	1,301	159.13
385	2261	HUTCH	1505	212	157.97
386	1868	MNSTR	1201	687	157.95
387	1242	SHLMT	1801	309	157.63
388	37	LUTHR	2106	70	156.36
389	2216	FRMBR	1806	450	156.17
390	1780	GRAHM	0721	1,246	155.93
391	324	ELCTR	1221	92	155.85
392	1420	HURST	1822	1,577	155.11
393	938	MOSSW	4612	1,800	154.87
394	641	ELGIN	1002	3,052	154.47
395	2127	TMPLE	1202	1,372	153.99
396	N/A	MLFRD	2153	11	152.76
397	1665	EDDYS	0425	430	152.51
398	1046	NCDSW	3811	1,507	152.04
399	3003	TMPSE	1512	429	152.02
400	1681	BRGPR	1103	1,005	151.78
401	1002	RRWES	1623	2,685	151.40
402	2257	LIPAN	1303	330	151.15
403	333	FHLSW	1311	1,704	151.12
404	2580	ALPHA	0007	1,477	150.56
405	2030	CRLTR	2004	241	149.61
406	81	SCYEN	0005	1,679	149.48
407	1810	LKBLT	2107	1,204	149.47
408	1058	WSOTH	1020	1,193	149.19
409	1984	HKBRY	1113	442	149.05
410	2683	KNOTT	5221	62	148.79
411	2933	RECCR	0001	223	148.75
412	359	GRLRD	0004	1,534	148.32
413	358	CDCSW	0007	1,053	147.93
414	225	BNBOR	1201	867	147.05
415	2055	WDGWD	1512	820	146.85
416	2387	SHPWK	5713	107	146.73
417	1626	PRKRW	3392	176	146.71
418	628	MESQW	1803	2,143	146.10
419	317	LVBRD	0003	271	145.45
420	618	MSLMN	4007	436	145.42
421	933	KRUMS	1203	853	145.19
422	466	BNMAG	1202	687	145.15
423	1971	WSTHL	3652	3,200	145.10
424	255	MNFLD	2682	2,685	144.99
425	1393	RCHHL	0332	1,692	144.94
426	2653	ROANW	9511	1,962	144.54
427	2190	DAVST	0006	1,415	144.31

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
428	229	RDOAK	1304	2,060	144.31
429	3091	AIRPK	8422	29	143.66
430	2349	SMFLD	2333	1,071	143.39
431	586	BRELN	7921	634	143.04
432	1034	CTYVW	2222	1,434	142.81
433	432	HMTRD	0004	1,063	142.56
434	166	CMINO	1201	788	142.46
435	144	MAYFD	5521	1,987	142.41
436	N/A	KIMBL	5013	1,387	142.17
437	2493	BRKNR	1211	121	142.11
438	927	SSPNG	1204	1,076	141.84
439	2048	WTAUG	4643	999	141.50
440	231	SHSTH	1303	902	141.46
441	201	BLSRA	1601	544	141.02
442	1653	PGSTH	7021	38	140.96
443	568	SGOVL	1401	1,922	140.56
444	1090	MAYFD	5522	3,471	140.32
445	577	ALDTU	9422	3,107	140.13
446	1461	HKHTS	1601	1,540	139.75
447	N/A	MDDTN	4341	825	139.14
448	309	LOMAL	0011	1,127	139.07
449	824	FRFWS	3001	1,873	138.53
450	1215	WSTHL	3613	3,464	138.42
451	1591	BSPSW	0851	530	137.99
452	2389	WNTHW	1121	751	137.86
453	1096	MLKF2	1203	1,284	137.50
454	522	LNDAL	2203	2,628	137.45
455	112	PRFTW	4221	1,408	137.38
456	2005	EDWDS	5921	16	137.10
457	280	HORNE	1931	947	136.53
458	2991	JKSNR	4105	88	136.20
459	244	RSNHT	1142	1,200	136.11
460	675	JSHUA	1302	1,434	135.89
461	134	FLINT	3211	1,966	135.87
462	387	WMRLD	0003	503	135.67
463	1779	HNYGR	2401	615	135.57
464	2174	PRSTN	0001	873	135.44
465	279	ALLNC	6422	45	134.66
466	1911	OKCLS	0004	1,573	134.60
467	1548	EULTB	5712	1,838	134.44
468	341	MDLNE	0112	481	134.44
469	627	SHAMP	0007	732	134.29
470	532	STAUG	0007	1,205	134.01
471	57	THSES	2402	948	133.90
472	1142	PPARK	1801	1,318	133.60
473	218	SCYEN	0004	1,357	133.31
474	2271	BBTWN	1501	2,131	133.09
475	2299	MSLSW	0008	175	132.97

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
476	1970	KEENE	1503	876	132.85
477	856	RCHHL	0342	1,016	132.61
478	447	HLTOM	2421	1,682	132.48
479	3015	HORNE	1921	318	132.29
480	910	HOWRD	3911	25	132.16
481	1264	PJPTR	3242	79	131.67
482	1510	BRNAV	0732	827	131.61
483	691	CNI45	2401	564	131.59
484	1410	AYERS	4421	1,545	131.40
485	634	CPRCV	1403	2,134	131.36
486	1104	SBEND	0611	160	131.07
487	877	CDCSW	0001	277	130.99
488	2662	WCOLO	1316	2,084	130.91
489	2203	BRHLW	7642	1,002	130.74
490	1571	WDGWD	1581	613	130.04
491	2635	OKLND	0002	1,381	129.84
492	2420	DEALY	0002	1,740	129.61
493	347	PAULN	2503	808	129.56
494	1087	POOLV	5811	460	129.51
495	2769	WEAST	0627	256	129.02
496	716	CDCSW	0002	2,455	128.58
497	1610	MURPH	2755	3,460	128.45
498	533	OTTOJ	3059	1,116	128.03
499	1943	GLNHV	3953	1,359	128.02
500	210	LTFRD	3021	944	128.00
501	1751	HSKAV	0001	1,099	127.72
502	3077	ALNTH	2832	1,183	127.68
503	3072	MRSDO	9622	3,644	127.51
504	371	CDCSW	0005	2,295	127.49
505	425	PLSTH	1304	1,340	127.43
506	2246	MSLMN	4131	143	127.00
507	835	NCSFA	1702	1,298	126.97
508	1929	HRSMD	1957	2,462	126.85
509	822	SHRSW	6621	1,816	126.72
510	1281	CLBRN	1204	1,331	126.69
511	439	GNSVE	1602	1,730	126.60
512	1811	GRLWS	1706	296	126.60
513	1207	SCURY	1911	141	126.55
514	801	MIDWY	0611	126	126.54
515	249	CLKVL	1202	1,237	126.53
516	160	TSLVL	4001	1,468	126.45
517	2304	LTVSB	5432	2,075	126.44
518	794	GNSVN	1403	306	126.43
519	2369	HSKAV	0006	876	126.24
520	939	KLNTF	1806	1,190	126.24
521	663	EDGCF	2211	2,106	126.05
522	195	RECCR	0002	90	125.67
523	2672	WFALS	0124	159	125.60

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
524	973	ALVRD	1501	1,234	125.56
525	2466	MSTLT	1084	1,267	125.19
526	1278	MOSSW	4632	1,058	125.08
527	2185	CRSWS	1403	2,473	125.01
528	915	PCUST	2006	1,620	125.01
529	2886	HLTOM	2411	1,516	124.85
530	860	STNVL	1206	2,803	124.80
531	493	AMMFG	5621	592	124.52
532	1119	EGFRD	0005	1,073	124.48
533	1149	IRVGS	1906	735	124.41
534	2744	EULSO	9112	1,100	124.38
535	564	GMINI	5812	1,268	124.32
536	1221	EZACH	0004	1,165	124.10
537	1996	EDGWD	1101	680	123.77
538	1457	ELGIN	1001	633	123.75
539	1407	HLSES	0522	1,736	123.68
540	2583	KNLTR	0003	625	123.61
541	2594	WOVER	6162	1,097	123.60
542	2652	ODESA	0252	792	123.43
543	2445	ODESW	5922	2,488	122.96
544	983	CLYVL	9322	2,202	122.45
545	1816	RCHRD	1202	817	122.17
546	300	HNRTA	0321	977	122.15
547	2082	ATHNW	1402	557	121.80
548	1185	PLSTN	1003	1,663	121.28
549	465	PLSTN	1004	1,605	121.27
550	2323	WEBBS	8624	2,388	121.09
551	1201	LNDAL	2202	1,499	121.06
552	111	JREST	2101	2,324	120.84
553	510	HLTOM	2431	1,313	120.72
554	1873	GNSVL	1205	943	120.70
555	2629	CRNRD	0001	740	120.58
556	1409	HMTRD	0003	429	120.41
557	297	DALLW	0001	1,118	120.11
558	152	LUFKN	1208	1,783	120.09
559	1174	MNRVA	1301	760	119.95
560	428	WWDWY	2024	1,466	119.90
561	1200	CRSWS	1402	1,013	119.64
562	584	NCDSW	3813	450	119.64
563	482	EDDYS	0710	686	119.43
564	429	MKNGB	5321	480	119.17
565	2980	AMLIA	0006	79	118.49
566	1723	MNWLL	1204	298	118.28
567	N/A	TYRSW	1702	1,036	117.96
568	903	MCKMY	0822	1,425	117.93
569	1391	PLSTN	1001	1,954	117.74
570	1980	WLSPT	1001	2,103	117.74
571	1564	BNBRK	4111	2,907	117.68

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
572	1740	PLGRV	0001	1,200	117.68
573	3037	BNDRA	0006	689	117.56
574	1987	BSPRW	2511	1,019	117.49
575	2355	MSLSW	0005	868	117.29
576	1788	DCATR	1204	764	117.22
577	2670	LKHLD	0002	1,527	117.08
578	1595	RSPCK	2102	1,566	116.98
579	803	WALST	0010	2,220	116.78
580	547	IRVGS	1902	1,492	116.53
581	844	ODESA	0251	1,368	116.46
582	838	IOWPK	0811	827	116.01
583	15	ACRLY	1721	57	115.91
584	953	RWALL	1203	3,312	115.89
585	2585	ODESW	5912	293	115.79
586	1341	ROWLT	1105	1,601	115.49
587	907	PLSTH	1301	918	115.37
588	668	BLTSW	3212	2,599	115.22
589	657	MESTE	1204	1,829	115.06
590	960	LFSTH	1407	1,866	115.01
591	122	ARCTY	1311	412	114.87
592	575	PEGAS	2312	239	114.25
593	306	LFEST	1902	1,100	114.06
594	834	FARON	4041	1,001	114.00
595	403	MSLSW	0004	401	113.93
596	55	PLSTH	1302	1,007	113.90
597	573	STAUG	0001	719	113.82
598	3040	HLTOM	2461	851	113.26
599	310	JACKR	7621	354	113.26
600	2206	GRPVN	8213	299	113.08
601	527	FSHSW	2111	347	112.99
602	2133	PALRD	2205	480	112.72
603	362	PRFTW	4222	5,054	112.70
604	542	RDOAK	1302	2,679	112.57
605	2869	WNDWD	3631	316	112.24
606	170	STANT	1312	365	112.03
607	1745	WSOTH	1019	836	111.90
608	69	LOVNG	2512	42	111.56
609	918	LEMON	0009	1,098	111.37
610	2959	ENTOH	0007	1,012	111.25
611	759	MSLMN	4009	251	111.04
612	931	RKDLE	1302	1,162	110.81
613	1592	WSTHL	3642	2,334	110.81
614	677	CKRHL	0006	51	110.59
615	921	CURIE	7212	980	110.46
616	1672	ARLNG	1213	1,329	110.45
617	1795	BRLSN	2023	1,911	110.27
618	501	BRLSN	2052	3,484	109.50
619	257	TERSO	2501	192	109.43

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
620	519	WSOTH	1017	1,769	109.39
621	1229	DNCNV	1901	905	109.20
622	1114	DCVSO	1104	1,371	109.17
623	2176	FRNKF	0005	1,105	109.02
624	2904	LOMAL	0007	159	108.49
625	2975	WATSN	5372	1,338	108.37
626	1353	RDLML	2512	1,225	108.36
627	809	BLMND	3252	1,096	108.35
628	1879	BRLSN	2013	1,108	108.21
629	1412	HURST	1811	1,263	107.97
630	1365	CGRSW	9821	29	107.90
631	3036	TYLGE	1314	1,113	107.59
632	461	DAVST	0008	99	107.52
633	848	WATCO	2602	2,553	107.42
634	1091	MCKMY	0821	2,015	107.38
635	672	HNTNG	1305	1,259	107.24
636	842	LFSTH	1406	1,734	107.00
637	460	STANT	1323	419	106.87
638	671	MCTYE	1711	1,758	106.79
639	2032	HUDSN	1602	1,739	106.75
640	1697	GSTHW	1614	872	106.32
641	1438	FRFWS	3002	862	106.27
642	1891	HLSBR	1202	1,266	106.27
643	47	CNANG	1804	194	106.19
644	1070	TYLER	1005	1,717	106.03
645	2461	MNHNS	1912	491	106.01
646	2125	DUPUY	1219	945	105.62
647	640	PNTIS	0252	652	105.51
648	682	CANTN	1301	1,406	105.46
649	1359	SSPNE	1401	820	105.45
650	1817	CDCSW	0008	751	105.32
651	1707	WALST	0011	756	105.15
652	629	TYEST	1501	1,910	105.13
653	2105	ALPHA	0003	874	104.89
654	619	FRSTN	1604	401	104.84
655	2956	SHNRW	1601	584	104.84
656	2044	MRDCK	0001	1,818	104.80
657	292	CDHCR	2052	1,504	104.79
658	1288	DNISN	1203	1,822	104.74
659	254	CNTRY	2822	2,825	104.69
660	3097	BRHLW	7641	54	104.57
661	26	INAIR	1442	129	104.13
662	570	WRIDG	3053	2,804	103.96
663	1105	MESWE	3621	828	103.47
664	19	EMMAS	4022	54	103.32
665	3017	CHROW	0006	95	103.07
666	1258	MRSDO	9621	1,944	102.92
667	1021	KNLTR	0011	1,864	102.82

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
668	1770	ELGIN	1003	3,435	102.48
669	594	ENNIS	1903	1,593	102.19
670	1275	KNEDL	6313	2,482	102.19
671	649	WDGWD	1541	1,146	102.08
672	1961	WWDWY	2015	1,274	101.99
673	N/A	GRADY	2108	40	101.91
674	1550	BELLS	1201	634	101.88
675	1990	WHITE	3531	1,887	101.84
676	1699	WGROB	8411	3,558	101.50
677	755	NCNTH	1801	2,571	101.44
678	2687	ARLNG	1261	1,363	101.43
679	3134	IRVVV	2852	173	101.37
680	481	HSKAV	0008	808	101.30
681	1954	STNVL	1201	2,595	101.23
682	797	AZLES	2112	1,836	101.10
683	1392	MCTYE	1721	586	100.98
684	833	KEENE	1501	1,697	100.97
685	1385	EULES	8711	2,044	100.76
686	149	BRNSY	1221	45	100.24
687	934	COVEE	3405	1,443	100.18
688	247	CMINO	1206	1,110	100.15
689	1197	DCVSO	1103	1,857	99.95
690	2969	WTAUG	4651	765	99.89
691	2374	RRSTH	1707	641	99.71
692	56	DUBLN	2214	723	99.62
693	2885	RRSTH	1704	3,970	99.62
694	620	GNSVL	1213	780	99.51
695	1963	CRLFR	2157	2,462	99.48
696	1883	CMPWI	0005	1,639	99.28
697	3136	JKREA	1201	29	99.01
698	1404	ARPMN	4147	651	98.95
699	410	FINKS	1802	871	98.90
700	540	ALPHA	0015	1,251	98.82
701	1915	VENSW	2602	157	98.81
702	1077	DGNST	0001	307	98.79
703	1443	GRSMN	4029	976	98.68
704	450	HNYGR	2403	641	98.53
705	3167	PTENN	2356	13	98.49
706	N/A	BHILL	1921	68	98.45
707	1351	SMFLD	2392	1,051	98.17
708	1066	BNDRA	0004	730	97.75
709	1673	GPLND	1201	487	97.73
710	1884	IRVBL	2505	503	97.72
711	1843	WXHCH	1204	1,974	97.66
712	520	PFLGV	2001	5,378	97.61
713	827	TATSP	4312	2,556	97.48
714	2068	RRSTH	1706	3,131	97.41
715	1439	DNCNV	1903	1,208	97.34

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
716	1307	MESQT	1304	627	96.58
717	1718	OAKHL	3041	1,106	96.48
718	572	MCDMT	2532	1,986	96.17
719	2883	WDGWD	1552	304	95.90
720	483	BOWEN	3151	1,931	95.88
721	1541	TYEST	1511	877	95.84
722	1700	BRNWD	1205	1,139	95.70
723	563	KIMBL	5012	1,109	95.61
724	2530	PCUST	2012	1,830	95.61
725	1921	VANAL	2412	1,958	95.57
726	1508	BBTWN	1504	2,100	95.56
727	1976	PBELL	4821	161	95.44
728	2164	SHDYG	7842	704	95.21
729	897	CRSGL	1306	693	95.07
730	879	COLDG	4047	425	94.76
731	1895	RDLML	2561	1,009	94.62
732	417	MLDR2	1605	228	94.59
733	2397	GRFRD	1002	410	94.56
734	765	WMRNR	0001	210	94.33
735	2677	MLKF2	1202	462	94.22
736	1112	ANDNR	2222	126	94.04
737	1469	DALLW	0005	123	94.04
738	3026	BRIRV	6922	3,404	93.69
739	1419	HUBRD	1402	1,068	93.60
740	245	MDLNW	1532	2,052	93.49
741	1902	WGROB	8422	2,454	93.47
742	1289	SIKES	2421	2,082	93.34
743	204	LFSTH	1408	2,362	93.28
744	153	ORANS	1501	955	93.10
745	1874	PCOIT	1022	2,122	93.10
746	1706	DESHR	1203	1,448	93.04
747	1251	ALLEN	2406	3,042	92.91
748	597	DCVSO	1106	1,230	92.88
749	36	KRGRV	2401	51	92.88
750	767	IRVNR	1501	1,132	92.70
751	655	HNTNG	1306	1,165	92.65
752	3032	LSCOL	2138	2,944	92.58
753	3064	RECCR	0005	161	92.57
754	1136	IRVNG	1402	1,149	92.43
755	696	CDMIL	1201	825	92.24
756	2578	ROWLT	1102	1,173	92.18
757	2434	BAKKE	6912	1,534	92.07
758	2351	WMMMR	2702	1,884	91.84
759	2659	MSLSW	0007	403	91.77
760	2236	BLKST	1752	1,460	91.72
761	348	JEWET	1204	1,335	91.70
762	1647	LKWOD	7411	629	91.69
763	N/A	JACKR	7622	1,444	91.67

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
764	2359	KRUMS	1202	881	91.47
765	1919	DNIWS	1601	1,132	91.36
766	2417	COMSO	1403	459	91.25
767	581	ENSSO	2001	235	91.14
768	919	RWALE	3321	1,484	90.93
769	1318	WHOUS	4122	1,770	90.85
770	2745	VLARN	2954	2,747	90.78
771	2786	TYOMN	1401	782	90.61
772	957	GDPRW	9611	1,335	90.51
773	395	CHROW	0001	126	90.37
774	2456	RRSTH	1705	4,400	90.29
775	1904	HKBRY	1102	1,709	90.26
776	52	CRISP	1501	295	90.23
777	2717	ITSCA	1702	242	90.22
778	2000	GSTHW	1623	2,488	90.21
779	1459	HHSTH	1502	2,296	90.19
780	1628	HUTCH	1503	767	89.98
781	1276	GRLRD	0003	654	89.86
782	1960	PCOIT	1024	2,363	89.80
783	2562	MESQW	1804	1,346	89.76
784	3125	FRMNT	0005	82	89.61
785	1907	CMINO	1205	1,095	89.60
786	2336	WCOLO	1320	1,461	89.53
787	2136	BLMED	1617	349	89.48
788	872	PCUST	2009	2,268	89.37
789	471	DESHR	1204	1,253	89.23
790	2516	MDWCK	0001	799	89.21
791	370	ALVDO	1902	1,205	89.09
792	1615	WRBND	2312	1,484	88.83
793	1240	DCVSO	1107	1,115	88.81
794	2211	NPKWY	0005	863	88.80
795	452	AZLES	2121	3,197	88.79
796	2561	ODNTH	2073	2,841	88.75
797	1363	WOVER	6142	2,114	88.75
798	2487	ARLNG	1232	1,262	88.66
799	2362	CNTRY	2833	1,253	88.64
800	2398	BRIRV	6912	846	88.43
801	236	CPLSO	4322	322	88.43
802	708	BRNCH	1421	64	88.41
803	484	RWDHV	1901	930	88.41
804	1973	CNTRY	2814	1,116	88.40
805	968	CPRCV	1404	2,223	88.33
806	188	CMPBW	2101	376	88.30
807	2090	TMPNW	1104	1,953	88.27
808	2317	WNRTH	1421	1,384	88.27
809	1401	HLTOM	2442	1,099	88.18
810	1069	TLRWT	2203	789	88.18
811	2552	SMFLD	2341	998	88.07

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
812	1454	BNBRK	4113	3,922	87.98
813	148	CRKET	2401	152	87.95
814	185	DFWNW	2405	13	87.93
815	1999	MSHLN	0008	688	87.92
816	2377	ARLNG	1271	2,266	87.89
817	612	CRLJL	1505	1,145	87.73
818	337	DEALY	0001	3,909	87.56
819	2574	WKATY	1718	1,766	87.55
820	817	FINKS	1804	2,447	87.36
821	1467	RSNHT	1171	2,423	87.32
822	179	CRLCC	2703	627	87.27
823	1636	FERIS	1103	1,391	87.07
824	800	TSLVL	4002	3,065	86.99
825	2128	TYBLR	2805	2,279	86.86
826	1975	MLDR2	1603	560	86.72
827	2266	KLRPR	9012	2,556	86.68
828	2101	FRMBG	1702	61	86.63
829	82	GODRD	8131	896	86.62
830	386	VANSB	1502	1,753	86.47
831	3102	COTRD	0004	104	86.37
832	1473	DNISN	1205	1,654	86.35
833	1552	FSCRK	6721	1,706	85.98
834	1853	MLFRD	2101	1,531	85.90
835	1152	BRNSO	1807	251	85.88
836	232	CPLND	1101	1,260	85.88
837	697	CNTRY	2851	1,529	85.85
838	411	ITALY	2103	366	85.60
839	2388	MURPH	2754	2,681	85.54
840	1191	MCWHT	3512	1,475	85.51
841	1048	DALLW	0003	695	85.42
842	574	WEAST	0617	1,424	85.24
843	854	HLTOM	2452	1,823	85.16
844	2924	GAVSW	0002	1,260	85.11
845	1055	GASLD	4221	64	84.92
846	1145	MDWCK	0008	1,258	84.72
847	2726	PWEST	1311	1,305	84.70
848	2352	TXHRV	1621	100	84.63
849	412	CADDO	0911	466	84.56
850	1533	CLBWS	8112	1,722	84.56
851	1277	DAVIS	3743	133	84.54
852	2897	RDLML	2591	1,577	84.46
853	997	CRWLY	7011	362	84.26
854	1998	WRTHM	5012	327	83.98
855	275	RWALE	3326	1,183	83.89
856	1376	PFFRD	3482	1,103	83.87
857	747	WHTRK	0005	729	83.72
858	1847	PCOIT	1003	1,504	83.70
859	1993	JKSNR	4107	328	83.58

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
860	136	TMPTV	2405	520	83.58
861	1554	BRNSY	1231	68	83.47
862	883	DALWT	2931	1,595	83.43
863	1683	BDFWD	8922	2,015	83.23
864	3154	NCSTH	1505	19	83.23
865	2204	PARIS	1206	1,039	83.05
866	3082	FLMSO	3712	952	83.02
867	189	ELKTN	2508	1,206	82.88
868	1064	TATSP	4322	2,587	82.76
869	1880	MCGRG	0776	294	82.73
870	2709	LVBRD	0002	513	82.55
871	389	TRLWD	7721	3,140	82.40
872	2878	MSHLN	0007	733	82.32
873	2447	BSPRW	2532	1,585	82.26
874	N/A	LKBRN	2402	2,099	82.13
875	1839	LOMAL	0001	716	82.10
876	965	CRYVE	3011	306	82.08
877	2371	ADISN	1608	370	81.99
878	39	KMASB	1721	86	81.85
879	702	CRSGL	1302	1,524	81.81
880	1603	BAKKE	6921	2,227	81.76
881	1767	PWEST	1302	988	81.66
882	3005	LIGSW	1623	801	81.53
883	761	MRKLY	0811	113	81.34
884	1944	SSPSW	1604	1,313	81.25
885	1107	IRVHF	2302	1,409	81.01
886	2376	MRNFD	2311	60	81.01
887	2720	PRKRW	3372	670	80.99
888	951	WMRLD	0008	1,591	80.90
889	1831	RHOME	2402	1,569	80.83
890	N/A	WILLO	7822	23	80.57
891	2457	CDHIL	1613	2,690	80.48
892	75	POYNR	1201	356	80.19
893	981	ATHNS	1201	1,038	79.89
894	591	LNGLK	1602	653	79.68
895	53	CRSWS	1401	1,102	79.67
896	963	CDHIL	1623	2,413	79.65
897	2050	LKWOD	7442	731	79.65
898	1652	CLYVL	9311	2,239	79.63
899	2721	RWALS	1854	566	79.63
900	2072	IRVNG	1407	1,468	79.49
901	2543	PRKWY	1511	1,355	79.40
902	2757	EMPCT	0004	1,151	78.93
903	1502	CRLTN	1405	1,249	78.75
904	2293	ODNTH	2024	1,513	78.73
905	2367	CRLFR	2159	1,614	78.41
906	826	MDWCK	0007	1,081	78.32
907	1758	FINKS	1801	1,827	78.26

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
908	441	IRVNR	1508	2,049	78.18
909	165	AYERS	4411	1,376	78.15
910	364	JKWST	4033	790	78.11
911	1234	WMRLD	0005	1,618	77.98
912	2571	CDCSW	0003	769	77.86
913	769	GRSMN	3027	385	77.83
914	608	CRTLD	4712	1,185	77.75
915	2517	CRLTR	2001	2,499	77.74
916	2378	THORN	6821	1,499	77.69
917	1124	ENSSO	2004	1,387	77.47
918	N/A	OILML	3622	921	77.47
919	2232	PROAD	0008	1,232	77.41
920	1909	MSLSW	0001	850	77.36
921	556	COPEL	3051	915	77.32
922	1491	GAVSW	0009	1,022	77.31
923	2047	GRADY	2107	165	77.25
924	1737	MKNKY	1254	859	77.00
925	2288	PCUST	2010	2,267	77.00
926	238	STAUG	0004	1,086	76.98
927	1366	CNEXP	0002	1,171	76.74
928	2908	ROWLT	1106	1,351	76.66
929	462	LVBRD	0008	1,843	76.51
930	1370	DNISN	1206	1,009	76.49
931	211	GRLND	1604	2,004	76.46
932	1769	WOVER	6122	1,765	76.23
933	2182	GRHWY	5511	2,412	75.96
934	3063	SCHRD	0006	519	75.94
935	2559	CRLTN	1452	3,435	75.90
936	N/A	PSHIL	1607	1,155	75.87
937	1171	RKDLE	1301	1,224	75.80
938	2834	ARMST	0005	1,515	75.70
939	1243	SMOUR	0721	22	75.68
940	2563	PRKWY	1532	2,319	75.53
941	853	DCVSO	1105	1,676	75.46
942	109	RKCRK	6112	1,605	75.41
943	948	TRIRA	6222	1,032	75.37
944	2443	MDLNE	0172	386	75.32
945	2703	PRSTN	0008	769	75.30
946	321	WXHCH	1202	2,448	75.30
947	2913	ELZCK	4921	3,279	75.29
948	1434	LFEST	1901	1,526	75.24
949	2498	DCATR	1201	1,388	75.19
950	2525	GNSVN	1401	32	75.19
951	396	ANASE	1903	3,673	75.18
952	639	PREST	1602	1,691	75.08
953	1761	EDGCF	2272	1,074	75.00
954	664	IRLBJ	3233	2,283	74.98
955	2073	MDTHS	1004	1,796	74.97

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
956	1972	WEAST	0615	465	74.94
957	2277	CLYVL	9313	2,066	74.77
958	867	GODRD	8122	1,062	74.67
959	1193	HSKAV	0003	1,558	74.66
960	513	STAUG	0006	1,840	74.54
961	546	MDTHS	1002	1,162	74.51
962	45	COMRC	1203	725	74.50
963	1688	LKMNT	0003	570	74.47
964	798	WTAUG	4631	1,152	74.47
965	808	PKRVL	1051	4,179	74.24
966	264	BEALS	9521	204	74.13
967	1611	FORSW	2025	675	74.03
968	2007	EULSO	9111	1,961	73.98
969	1222	BDFRD	8831	873	73.85
970	1906	FHLSW	1372	1,561	73.78
971	104	BRCKR	6513	1,315	73.66
972	1373	JKSBR	1402	1,375	73.59
973	996	REYST	4040	570	73.52
974	1655	RDOAK	1301	1,347	73.48
975	1885	CMINO	1202	1,034	73.43
976	207	HUTCH	1501	1,374	73.26
977	1807	HLSBR	1203	1,808	73.23
978	220	MDDTN	4331	1,215	73.23
979	3018	COLNY	2405	1,697	73.17
980	48	CTFLD	9921	935	73.08
981	199	MKNSW	2602	2,717	73.00
982	2410	EMPCT	0001	33	72.98
983	2259	VLRYN	2957	500	72.97
984	2705	GRMES	0521	558	72.84
985	1388	LSCOL	2114	247	72.79
986	2075	OAKHL	3072	2,624	72.78
987	2870	FRMBG	1751	815	72.72
988	2481	WFALS	0184	926	72.54
989	849	CRLUD	1307	284	72.43
990	1314	TYEST	1503	1,067	72.31
991	1570	FRSTN	1602	1,395	72.28
992	2269	BNDRA	0011	413	72.27
993	2675	MKNNY	1203	1,184	72.26
994	1357	RCHLD	2101	756	72.26
995	2163	MABNK	2402	1,152	72.25
996	557	ARTHR	0462	214	72.21
997	1716	PKRVL	1052	4,218	72.07
998	890	FSTVW	0001	796	71.99
999	1007	INDIA	2501	803	71.94
1000	2063	LEMON	0001	2,326	71.78
1001	861	REYST	4129	539	71.62
1002	731	DNISN	1204	1,438	71.61
1003	2682	SYCRK	4511	1,895	71.58

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
1004	521	BONHM	1206	2,258	71.53
1005	674	CLCTY	1021	740	71.46
1006	1994	WNDCR	0221	595	71.41
1007	895	MESTE	1208	996	71.35
1008	2647	MESQN	1504	1,358	71.22
1009	135	MABNK	2401	2,462	71.10
1010	592	CHSPG	2412	2,831	70.94
1011	1597	CRANE	0311	834	70.87
1012	689	ADMDS	6511	467	70.78
1013	2474	ELKTN	2502	1,819	70.68
1014	2237	CKRHL	0002	435	70.54
1015	2679	SANSM	3921	1,574	70.44
1016	1602	TMSTH	1402	1,694	70.26
1017	289	JNDAY	3311	770	70.18
1018	1555	RSKMN	3046	1,147	70.14
1019	1774	SWDTN	1621	708	69.99
1020	2690	LMBLN	0001	2,039	69.95
1021	719	JEWET	1202	777	69.91
1022	2442	BKWST	0007	1,758	69.88
1023	320	CRISP	1502	982	69.83
1024	162	HURST	1831	1,468	69.80
1025	2319	WTAUG	4652	803	69.78
1026	N/A	OILML	3611	773	69.76
1027	894	IRVNG	1405	1,162	69.75
1028	1380	ENNIS	1904	1,299	69.67
1029	2286	CMPBW	2102	742	69.52
1030	1199	THRNE	0004	752	69.43
1031	959	MAYFD	5524	2,753	69.28
1032	659	CHROW	0005	188	69.09
1033	115	PNTIS	0221	2,301	69.06
1034	3016	WALST	0013	377	69.06
1035	1760	BDFRD	8821	913	68.91
1036	1146	SWAN2	1801	598	68.85
1037	886	RRNES	2405	4,748	68.82
1038	1283	RWDHV	1907	904	68.79
1039	1882	WESTS	1601	1,124	68.78
1040	404	GSTHW	1644	954	68.50
1041	1316	CNTRY	2811	2,872	68.41
1042	1024	PLSTN	1005	1,911	68.34
1043	N/A	GUNSO	9911	299	68.02
1044	630	SWDTN	1611	1,527	68.01
1045	1047	BRNSY	1211	50	67.88
1046	2054	FLAND	1312	136	67.88
1047	2645	PLKST	0001	651	67.87
1048	2009	ITSCA	1701	822	67.82
1049	616	WXNTH	2303	2,281	67.73
1050	609	DESPR	1406	959	67.69
1051	1028	LOMAL	0012	753	67.64

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
1052	791	WFALS	0153	1,147	67.52
1053	35	MASON	3422	18	67.50
1054	1524	BRNWD	1203	904	67.49
1055	1538	WXHCH	1203	1,387	67.47
1056	2202	WELRD	0006	710	67.45
1057	1985	EDDYS	0712	1,180	67.43
1058	2431	DPCRK	1831	1,440	67.42
1059	11	LTFRD	3011	961	67.39
1060	1071	MAPLE	0006	2,590	67.28
1061	1886	GVOVS	3041	1,466	67.17
1062	319	GSMTH	1742	29	67.16
1063	377	DNCNV	1902	1,056	66.89
1064	1912	STERT	2706	1,196	66.73
1065	1018	LWRDR	0004	806	66.70
1066	2093	HSKAV	0004	1,366	66.66
1067	2700	PFFRD	3421	853	66.59
1068	720	AMLIA	0007	66	66.58
1069	1433	NCRST	2201	2,025	66.36
1070	1298	RCHRD	1208	1,010	66.18
1071	271	IRVBL	2507	911	66.15
1072	1627	DESPR	1407	944	65.98
1073	2752	LWSNR	2212	1,502	65.94
1074	1228	BNBOR	1202	857	65.79
1075	418	COYNW	8151	46	65.78
1076	1483	WTHRF	2002	1,451	65.72
1077	952	BLSRA	1602	163	65.67
1078	660	MAPOI	1201	163	65.54
1079	1905	TYSTH	1202	1,054	65.47
1080	1173	CMPWI	0001	1,975	65.45
1081	234	DIBOL	1507	561	65.45
1082	2843	RSPCK	2133	2,243	65.20
1083	2655	CNTRY	2862	746	65.11
1084	1739	SSPNG	1201	939	65.03
1085	3079	FRMBG	1706	66	64.93
1086	1920	THRNE	0003	2,009	64.90
1087	2576	GRPVN	8223	2,087	64.67
1088	1649	MURPH	2752	1,212	64.67
1089	2568	FSHSW	2121	1,761	64.61
1090	621	LWRDR	0001	1,171	64.59
1091	3149	MNWLL	1201	27	64.56
1092	1094	BRELN	7911	222	64.51
1093	41	TMPLE	1201	2,464	64.43
1094	2045	STNVL	1203	2,557	64.41
1095	1693	SHAMP	0001	1,044	64.35
1096	343	BNTDR	0001	1,500	64.34
1097	1429	SGOVL	1402	948	64.34
1098	2934	DENDR	0003	2,255	64.32
1099	434	PPARK	1803	1,057	64.27

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
1100	496	TIODE	9611	479	64.27
1101	1942	CHALK	0911	63	64.24
1102	1475	CRANE	0321	23	64.24
1103	2178	GODRD	8112	1,443	64.22
1104	1573	ARMST	0001	272	64.21
1105	1153	BRKTN	1201	486	64.19
1106	N/A	HRSHD	5831	27	64.19
1107	2130	RSNHT	1152	1,052	64.11
1108	2634	PNTGO	7111	745	64.04
1109	1408	WTHRF	2001	1,302	64.03
1110	2135	SHRSW	6631	1,289	63.99
1111	2711	COLNY	2402	2,421	63.97
1112	1261	CRLTN	1401	822	63.94
1113	2147	LNCST	1602	1,592	63.93
1114	2877	LIGSW	1604	725	63.84
1115	2324	ECTHM	3321	1,554	63.79
1116	2546	MOSSW	4621	1,997	63.78
1117	468	PREST	1604	1,487	63.69
1118	1244	RCLNS	1405	638	63.67
1119	1041	RWALS	1853	2,538	63.50
1120	N/A	LFKHL	2102	2,536	63.45
1121	1493	SMFLD	2313	2,132	63.39
1122	367	AZLES	2122	2,377	63.35
1123	1360	NSMFD	4201	372	63.04
1124	3174	RSPCK	2103	176	63.00
1125	1217	TIODE	9632	447	62.88
1126	1781	WDGWD	1572	1,484	62.82
1127	2479	WHTRK	0001	2,838	62.71
1128	2218	STAUG	0002	1,401	62.61
1129	385	GRVPT	7512	324	62.56
1130	351	KLELM	2205	3,488	62.54
1131	2884	FRMBR	1808	686	62.51
1132	518	WALST	0017	971	62.48
1133	989	MEXIA	4007	460	62.44
1134	2361	ALDTU	9412	1,154	62.37
1135	825	FHLSW	1351	1,229	62.16
1136	1584	WTAUG	4623	733	62.07
1137	1060	WWDWY	2020	1,369	62.00
1138	2626	DAVST	0007	534	61.97
1139	502	LKWOD	7432	1,633	61.93
1140	1466	LVBRD	0004	1,183	61.81
1141	216	FORSW	2015	751	61.64
1142	517	SSPNE	1403	1,242	61.45
1143	N/A	GUNSO	9931	316	61.38
1144	1361	SMPST	0002	1,523	61.11
1145	2654	BRNWD	1206	1,395	61.05
1146	1009	ALPHA	0009	71	61.01
1147	2065	LIGSW	1602	1,160	61.00

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
1148	2312	INAIR	1423	735	60.93
1149	446	FSCRK	6732	2,375	60.88
1150	624	RKDLN	1401	925	60.83
1151	1632	DAVST	0004	1,733	60.82
1152	175	EULES	8723	5,155	60.82
1153	2229	FARON	4021	273	60.82
1154	850	VLRYN	2953	2,659	60.75
1155	1110	BKBNT	1832	188	60.67
1156	330	HKHTS	1602	1,036	60.54
1157	738	PRFTW	4211	4,575	60.53
1158	3044	GLNHV	3992	2,506	60.40
1159	1978	CNEXP	0004	659	60.39
1160	2214	MKNNY	1201	1,326	60.09
1161	1809	SPRDL	4821	1,351	60.01
1162	1488	RECCR	0004	67	59.92
1163	472	DCVSO	1101	1,483	59.88
1164	1924	RRNES	2404	2,347	59.83
1165	2605	DPCRK	1821	1,619	59.79
1166	228	TYEST	1508	677	59.57
1167	1043	GLNHV	3931	1,334	59.46
1168	415	BRGPR	1102	1,649	59.42
1169	1238	IRVNR	1559	2,633	59.20
1170	2735	IRLBJ	3222	1,038	59.14
1171	164	LMESA	1522	1,389	59.13
1172	173	RSNHT	1162	1,620	59.12
1173	1181	KLBRG	0004	1,724	59.10
1174	7	ANDRD	0931	98	59.05
1175	1711	BLKST	1762	1,021	59.03
1176	736	NNTWK	0004	2,016	59.03
1177	1717	INAIR	1421	16	58.98
1178	2966	HMPHL	2733	223	58.94
1179	2429	SSPNE	1402	72	58.71
1180	2107	GRPVN	8222	2,342	58.40
1181	354	HOLDY	0921	1,166	58.21
1182	356	ALLNC	6412	2,254	58.20
1183	943	WSANG	2802	638	58.07
1184	1169	CANTN	1303	963	57.99
1185	913	SHLMT	1802	567	57.97
1186	1141	BLTLN	0005	891	57.88
1187	1180	ROLTR	2921	2,504	57.83
1188	2643	CKRHL	0008	1,829	57.82
1189	1746	DAVIS	3741	1,644	57.77
1190	1334	RCHRD	1204	1,141	57.70
1191	1815	TYLNE	1623	942	57.66
1192	2622	ARMST	0006	1,868	57.60
1193	163	HUTTO	2742	3,189	57.59
1194	1076	MNWLL	1203	901	57.59
1195	2223	CTYVW	2211	1,528	57.47

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
1196	1496	BRNCH	1411	554	57.45
1197	2630	EULSO	9131	1,993	57.41
1198	638	TRNTY	7521	1,187	57.38
1199	1332	RBNSN	2504	1,794	57.29
1200	80	CRNES	2712	63	57.28
1201	1476	RDLML	2552	288	57.28
1202	2334	TYRSW	1701	1,448	57.04
1203	1870	CNTRD	0003	1,404	57.00
1204	2754	ADMDS	6532	283	56.99
1205	698	SPRDL	4831	1,323	56.83
1206	194	WMRLD	0007	1,702	56.83
1207	684	GRPVN	8212	4,151	56.79
1208	1583	BLTLN	0003	605	56.68
1209	2611	DESPR	1401	1,879	56.65
1210	3035	DGNST	0004	1,455	56.58
1211	1710	IRVNE	1304	656	56.58
1212	1685	CDCSW	0006	1,429	56.53
1213	820	ENNIS	1902	1,594	56.49
1214	1923	CMBTP	1201	277	56.47
1215	813	CRSCN	1203	2,021	56.47
1216	889	IRVNG	1406	1,280	56.39
1217	726	SALSW	3001	1,044	56.29
1218	843	AZLES	2111	2,504	56.21
1219	1176	BMTWN	1611	1,925	56.13
1220	1519	TMNTH	1602	478	56.13
1221	543	CRLTN	1406	1,201	55.94
1222	2775	DGNST	0008	130	55.94
1223	240	MSTNG	2621	54	55.93
1224	1083	PALRD	2206	1,554	55.87
1225	995	IOWPK	0831	1,118	55.85
1226	2306	DNISN	1201	1,519	55.67
1227	1914	MRLNS	4002	408	55.67
1228	1744	RDOAK	1303	1,774	55.66
1229	2973	LUFKN	1204	75	55.50
1230	3068	ALPHA	0011	1,153	55.40
1231	327	RYSSW	2804	2,757	55.35
1232	1529	KFMSSO	1301	828	55.27
1233	314	MDDTN	4312	405	55.24
1234	2553	RRNES	2402	2,118	55.21
1235	2512	DUVAL	0452	1,590	55.07
1236	2051	ECTHM	3322	2,297	55.06
1237	342	DUVAL	0483	2,693	54.96
1238	2194	DAVST	0001	595	54.93
1239	580	CLBWS	8121	711	54.78
1240	1280	TMPNW	1105	881	54.74
1241	209	LMBLN	0004	53	54.72
1242	558	ENNIS	1906	2,342	54.69
1243	1235	MRTSP	1504	722	54.69