



Filing Receipt

Filing Date - 2023-06-09 12:14:35 PM

Control Number - 54467

Item Number - 16

Service Quality Report
To The
Public Utility Commission of Texas
In Accordance With
Substantive Rule §25.81
2022 Reporting Year
Corrected

AEP Texas Inc.

Project 54467

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

System SAIFI		Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced														
2022		1.257	0.111	0.098	0.093	0.165	0.119	0.094	0.082	0.135	0.078	0.092	0.086	0.103
Scheduled														
2022		0.522	0.013	0.007	0.008	0.011	0.012	0.009	0.007	0.413	0.013	0.014	0.009	0.008
Outside Causes														
2022		0.111	0.013	0.009	0.005	0.012	0.015	0.007	0.019	0.003	0.007	0.000	0.020	0.001
Major Events														
2022		0.069					0.066							0.003

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

System SAIDI	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced													
2022	140.15	11.35	9.32	10.01	20.56	16.98	10.53	9.06	16.77	7.21	7.39	8.83	12.12
Scheduled													
2022	22.80	1.14	1.03	1.07	1.29	1.16	1.11	0.78	9.62	2.13	1.20	1.21	1.06
Outside Causes													
2022	10.68	0.80	1.49	0.44	0.98	1.96	1.78	1.11	0.23	0.35	0.08	1.39	0.08
Major Events													
2022	19.25					17.94							1.32

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

Total Number of Feeders

With 10 or more Customers

1304

Add or Delete Rows as Necessary

AEP Texas Inc.

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
1	47	RIO RICO	94SB8330	70	13.229
2	90	MINES ROAD	94LA7235	43	11.349
3	778	BERCLAIR	94CN990	26	9.115
4	368	RIO RICO	94SB5050	290	8.466
5	147	LULING - LCRA	94CN10	452	6.108
6	71	RAYMONDVILLE #2	94SB3170	766	6.052
7	180	RIO PECOS	97SA3835	103	5.990
8	121	GREGORY	94CS5900	120	5.983
9	474	MATHIS	94CS1410	472	5.881
10	176	PICACHO	94LA630	378	5.831
11	280	VERHALEN	97SA4460	70	5.729
12	133	GEORGE WEST	94CN1320	687	5.684
13	833	SONORA 138 SUB	97SA4810	876	5.535
14	171	ELSA	94SB700	1523	5.516
15	685	NORTH MERCEDES	94SB4860	1504	5.324
16	272	ODEM	94CS375	631	5.317
17	311	BAY CITY	94CN6670	1615	5.256
18	734	RANDADO	94LA8360	163	5.227
19	404	INGLESIDE CITY	94CS8050	1277	5.193
20	40	PLACEDO	94CN7980	425	5.174
21	290	LOS FRESNOS	94SB4315	1264	5.103
22	874	NORTH ALAMO	94SB4370	1628	5.060
23	631	POLK AVENUE	94SB4900	1915	5.058
24	313	NAVAL BASE	94CS7950	806	5.038
25	172	NORTH PADRE ISLAND	94CS720	1402	5.019
26	84	WEST HARLINGEN	94SB3720	1309	4.969
27	55	CHERRY CREEK TAP	97SA485	53	4.887
28	321	MOORE FIELD	94SB3120	151	4.675
29	923	ASHERTON	94LA4175	82	4.634
30	1083	HOLLY	94CS1220	3401	4.612
31	680	TAFT	94CS1260	200	4.555
32	948	SAN BENITO	94SB4135	1388	4.544
33	853	CLYDE	97AB1760	464	4.543
34	757	PORT ISABEL S.S.	94SB9295	2515	4.543
35	183	SOUTH PADRE ISLAND	94SB4695	1378	4.525
36	337	CAMPWOOD	94LA2610	1009	4.474
37	32	CHARLOTTE	94LA2780	33	4.455
38	77	ZAPATA	94LA8300	1613	4.449
39	17	GREGORY	94CS8560	255	4.439
40	49	FOSTER FIELD	94CN2550	66	4.409
41	946	PUEBLO	94LA95	1415	4.301
42	198	PIRATE	94CS3380	421	4.183

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
43	83	ELSA	94SB3520	1011	4.161
44	704	TUSCOLA	97AB3305	1234	4.160
45	143	PREMONT	94LA2730	199	4.146
46	782	WEIL TRACT (138/12KV)	94CS2520	83	4.133
47	451	PHARR	94SB1620	1243	4.132
48	35	OZONA	97SA4185	734	4.052
49	26	WEIL TRACT (138/12KV)	94CS5405	178	4.006
50	441	HALL ACRES ROAD	94SB5585	1623	3.996
51	726	NORTH VICTORIA	94CN7770	829	3.982
52	264	INGLESIDE CITY	94CS8060	2680	3.976
53	36	TATTON	94CN8490	293	3.959
54	731	ALICE	94LA1770	1657	3.898
55	460	WESMER	94SB4050	1954	3.880
56	920	SAND CRAB	94CN9235	386	3.852
57	1143	FT CHADBOURNE	97SA6515	92	3.826
58	64	SAN DIEGO	94LA2930	565	3.765
59	57	PRAIRIE PUMP	94CN1940	91	3.758
60	698	BAY CITY	94CN2700	1078	3.756
61	190	VALENTINE	97SA5590	208	3.726
62	718	HIGHWAY 9	94CS6760	1033	3.723
63	130	HIGHWAY 9	94CS6770	925	3.679
64	276	THREE RIVERS	94CN8430	194	3.634
65	135	PECOS VALLEY	97SA4080	237	3.633
66	237	FREISS RANCH	97SA4870	100	3.630
67	1140	PLASTERCO (MWEC)	97AB2720	117	3.590
68	209	MATHIS	94CS2870	870	3.582
69	688	MESQUITE	94SB3360	1023	3.580
70	323	RODD FIELD	94CS225	2913	3.560
71	550	CABANISS	94CS240	1408	3.546
72	463	JOURDANTON	94LA7880	593	3.528
73	236	CABANISS	94CS75	2243	3.527
74	446	SOUTHSIDE	94CS5335	1533	3.496
75	818	LIVE OAK	94CS1080	2555	3.470
76	13	NORTH MERCEDES	94SB3770	1844	3.450
77	7	O CONNER	94CN390	200	3.430
78	1137	EAGLE PASS CITY	94LA2745	934	3.424
79	NA	PECOS VALLEY	97SA9615	56	3.393
80	78	BLESSING	94CN8780	58	3.379
81	61	MORRIS STREET	94CS8820	1249	3.367
82	0	RAYMONDVILLE #2	94SB3250	28	3.357
83	22	SUNCHASE	94SB1150	1422	3.340
84	542	PARKER	94CN9010	21	3.333
85	126	PAWNEE (STEC OWNED)	94CN22202	197	3.330
86	346	HIGHWAY 9	94CS6720	1275	3.307
87	736	INGLESIDE CITY	94CS6040	429	3.277
88	693	ALPINE 12KV	97SA3875	105	3.276
89	70	ELSA	94SB3500	1332	3.264

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
90	59	EL CAMPO	94CN2800	841	3.262
91	671	CHARLOTTE	94LA2790	201	3.259
92	166	DILLEY	94LA3795	103	3.223
93	33	WEIL TRACT (138/12KV)	94CS1990	1369	3.221
94	429	MATHIS	94CS340	1418	3.207
95	795	PALMVIEW	94SB6790	2557	3.194
96	1026	HAWLEY	97AB4455	672	3.190
97	50	CLARKWOOD	94CS5525	627	3.190
98	43	BANQUETTE	94CS9000	462	3.171
99	56	ALAZAN	94CS620	179	3.162
100	255	HASKELL 12KV	97AB3495	826	3.155
101	116	MALONE	94CN7550	226	3.150
102	804	HARLINGEN SWITCH	94SB320	1686	3.133
103	900	GANADO	94CN5815	601	3.125
104	954	JOURDANTON	94LA250	770	3.123
105	186	MORRIS STREET	94CS7625	513	3.111
106	72	PALMHURST	94SB3890	1864	3.106
107	1105	WEST MCALLEN	94SB4965	967	3.101
108	326	RIO BRAVO	94LA1130	1071	3.085
109	2	LOS FRESNOS	94SB5335	2708	3.078
110	886	LEARY LANE	94CN1430	1915	3.076
111	251	HIGHWAY 9	94CS7210	349	3.069
112	363	OZONA	97SA3810	1172	3.059
113	87	NORTH WESLACO	94SB4810	1522	3.034
114	1287	GOODLETT	97AB12205	48	3.021
115	136	PLACEDO	94CN7970	490	3.020
116	274	OZONA	97SA3555	157	3.006
117	820	LOS FRESNOS	94SB7270	2376	3.005
118	278	PAULANN	97SA6280	331	2.991
119	112	MCCAMEY	97SA2415	76	2.987
120	131	AB RAINEY CREEK	97AB4225	122	2.967
121	707	UNITEC	94LA3085	114	2.947
122	1015	BEN FICKLIN	97SA14065	793	2.939
123	482	SEAWALL	94CS9325	1584	2.927
124	902	BISHOP	94CS2690	641	2.922
125	945	TAFT	94CS5230	832	2.912
126	86	NORTH MERCEDES	94SB3840	710	2.896
127	892	PHARR	94SB1625	1210	2.891
128	894	TYNAN	94CS1855	135	2.889
129	737	GANADO	94CN5795	489	2.869
130	1225	BALLINGER	97SA4375	1130	2.866
131	156	CROSS PLAINS	97AB2915	779	2.849
132	333	SAND CRAB	94CN8120	264	2.848
133	98	NORTH ALAMO	94SB3610	1999	2.845
134	320	UVALDE	94LA540	1969	2.843
135	165	WEST HARLINGEN	94SB3700	1876	2.838
136	107	HARLINGEN SWITCH	94SB4110	912	2.823

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
137	89	MAYO	94CS625	208	2.817
138	14	CRESTONIO	94LA270	641	2.813
139	151	HOLLY	94CS1480	1704	2.796
140	729	TATTON	94CS950	576	2.774
141	733	KNIPPA	94LA6535	22	2.773
142	341	DEL RIO CITY	94LA1930	1564	2.767
143	351	UVALDE	94LA6620	2158	2.747
144	103	GARWOOD CITY	94CN2570	145	2.745
145	310	FALFURRIAS	94LA5210	1177	2.743
146	261	PREMONT	94LA6570	809	2.739
147	191	CABANISS	94CS615	266	2.737
148	92	BEEVILLE	94CN8510	828	2.736
149	1009	MILO	94LA8365	2123	2.734
150	62	BAY CITY	94CN7480	380	2.732
151	761	RACHAL	94LA8145	376	2.726
152	141	WESLACO UNIT	94SB5970	2047	2.722
153	1067	GONZALES	97SA15390	1098	2.720
154	517	DEL RIO CITY	94LA430	2069	2.712
155	189	HEARN ROAD	94CS8990	1360	2.698
156	74	BEEVILLE	94CN8090	1386	2.698
157	489	PECAN BAYOU	97AB6815	2092	2.679
158	375	ZAPATA	94LA2710	1346	2.679
159	759	EAGLE LAKE	94CN310	740	2.673
160	324	PORTLAND	94CS9290	1790	2.665
161	705	FREER	94LA6320	162	2.660
162	41	MCCAMEY	97SA2830	97	2.639
163	44	RIO RICO	94SB8290	309	2.638
164	455	CHARLOTTE	94LA8120	240	2.625
165	352	INDIAN MESA	97SA2695	92	2.609
166	746	VICTORIA POWER PLANT	94CN1390	1092	2.604
167	239	MCKENZIE ROAD	94CS140	296	2.591
168	138	CALLICOATTE	94CS8785	1193	2.567
169	862	EL GATO	94SB910	2605	2.566
170	660	PUEBLO	94LA275	2910	2.554
171	308	DIMMIT	94LA4120	1277	2.546
172	821	PLEASANTON	94LA9505	1775	2.539
173	294	ARCADIA	94CS1440	1662	2.504
174	514	NORTH PADRE ISLAND	94CS7900	2346	2.496
175	785	SOUTHSIDE	94CS8025	1147	2.495
176	427	SKIDMORE	94CS380	159	2.491
177	388	SOUTH SANTA ROSA	94SB1235	648	2.489
178	740	HAINE DRIVE	94SB9690	633	2.483
179	227	CLARKWOOD	94CS7230	624	2.481
180	307	EAGLE LAKE	94CN9455	609	2.476
181	959	FASHING	94CN360	34	2.471
182	124	MAYBERRY	94SB3160	558	2.470
183	212	NORTH PADRE ISLAND	94CS5170	870	2.457

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
184	932	POLK AVENUE	94SB4190	1726	2.448
185	222	RIO BRAVO	94LA5	713	2.447
186	168	FOSTER FIELD	94CN8880	294	2.442
187	317	HIDALGO	94SB4845	1411	2.428
188	390	MATTHEWS	94CN1740	164	2.427
189	4	GREGORY	94CS5920	765	2.407
190	1097	BEEVILLE	94CN2380	219	2.402
191	993	NORTH VICTORIA	94CN7860	1510	2.397
192	910	FULTON	94CS440	2074	2.395
193	710	FULTON	94CS2020	3551	2.389
194	1277	STAFFORD HILL	94CN9955	85	2.388
195	528	MINES ROAD	94LA1600	1218	2.385
196	76	LOS FRESNOS	94SB2160	1863	2.382
197	1019	PIRATE	94CS3490	378	2.376
198	712	LIVE OAK	94CS1070	2568	2.375
199	506	AB SHELTON ST	97AB3660	638	2.353
200	492	YORKTOWN	94CN8380	780	2.349
201	370	RAYMONDVILLE #1	94SB630	792	2.348
202	23	FREER	94LA1500	201	2.348
203	182	ALICE	94LA2530	1502	2.339
204	27	MCELROY	97SA5165	95	2.326
205	435	EAGLE PASS CITY	94LA2770	2023	2.325
206	291	BISHOP	94CS7180	929	2.311
207	531	PORTLAND	94CS9370	2100	2.307
208	364	LAGUNA	94CS9590	2325	2.306
209	NA	BULL MOOSE	94CS4185	20	2.300
210	501	GOODWIN	94SB4380	1668	2.299
211	249	WADSWORTH	94CN8630	669	2.299
212	1012	ABILENE PLANT	97AB1575	608	2.293
213	883	BEN FICKLIN	97SA6175	599	2.289
214	979	HOLLY	94CS7740	2209	2.283
215	91	AIRLINE	94CS7280	645	2.276
216	532	WOOLRIDGE	94CS1110	1650	2.272
217	267	AB ELM CREEK	97AB4745	902	2.272
218	754	KEMPER EXXON HUMBLE	97SA72103	26	2.269
219	184	ODEM	94CS385	567	2.257
220	65	WESMER	94SB4480	1136	2.254
221	231	CASA BLANCA	94CS55	871	2.247
222	1014	MCCOLL ROAD	94SB4790	2088	2.243
223	302	TURKEY	97AB3825	388	2.242
224	1120	COMSTOCK	94LA230	183	2.240
225	681	DEVINE	94LA7090	1070	2.240
226	929	SOUTH EAST EDINBURG	94SB4550	727	2.239
227	770	LEARY LANE	94CN1540	793	2.236
228	366	UVALDE	94LA5060	1288	2.227
229	807	ARCADIA	94CS6930	1480	2.216
230	419	WEST HARLINGEN	94SB4870	1072	2.203

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
231	406	YORKTOWN	94CN3130	492	2.203
232	169	PALACIOS	94CN8550	84	2.190
233	521	KEPLER	94CS2665	37	2.189
234	342	LAREDO PLANT	94LA8695	1551	2.188
235	58	WEST OSO	94CS9085	945	2.182
236	51	ALBANY	97AB2029	241	2.174
237	1096	TYNAN	94CS4010	46	2.174
238	732	GARWOOD CITY	94CN2560	201	2.169
239	891	BLACK CAT	94CN3175	495	2.166
240	226	ELDORADO	97SA1845	538	2.164
241	601	PHARR	94SB1640	1456	2.156
242	592	NORTH ALAMO	94SB3580	1023	2.150
243	285	VILLA CAVAZOS	94SB1980	1834	2.144
244	12	HOLLY	94CS7620	2703	2.141
245	1068	SILVER	97SA4295	15	2.133
246	985	AB MCMURRY	97AB4350	707	2.130
247	1264	SWENSON	97AB136	31	2.129
248	299	AIRLINE	94CS5870	1008	2.129
249	510	POLK AVENUE	94SB4170	1466	2.124
250	498	VICTORIA POWER PLANT	94CN8170	842	2.122
251	93	CAUSEWAY	94SB9880	1229	2.112
252	NA	HAISLEY	94CSTX_2_B	9	2.111
253	396	WEST MCALLEN	94SB6385	243	2.099
254	871	AB WALNUT ST	97AB3785	574	2.098
255	950	POLK AVENUE	94SB4610	155	2.097
256	275	WESMER	94SB9705	938	2.088
257	603	MELVIN	97SA940	46	2.087
258	1116	CLARKWOOD	94CS7220	931	2.083
259	1166	AB MCMURRY	97AB4355	989	2.082
260	692	LA PRYOR	94LA570	171	2.082
261	1042	NORTH MCALLEN	94SB3830	1415	2.076
262	81	BEEVILLE	94CN1760	1838	2.065
263	768	CHILLICOTHE	97AB4525	119	2.059
264	28	COFFEE PORT	94SB1095	1080	2.058
265	530	BRUNI	94LA1120	266	2.056
266	293	STAMFORD PUMP	97AB3930	37	2.054
267	1128	CEDAR GAP (TEC)	97AB5445	506	2.053
268	449	PORT ISABEL S.S.	94SB3820	175	2.051
269	304	PALMVIEW	94SB3930	1163	2.050
270	998	RIO GRANDE CITY	94SB3230	2702	2.047
271	192	PAULANN	97SA6285	69	2.043
272	273	PAULANN	97SA6310	1086	2.041
273	645	VERNON CITY PLANT	97AB5770	94	2.032
274	10	SHROPSHIRE	94CN1240	73	2.027
275	750	PREMONT	94LA6610	834	2.019
276	906	SA MATHIS FIELD	97SA4790	194	2.010
277	104	SARAGOSA	97SA1590	49	2.000

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
278	373	VERHALEN	97SA4465	36	2.000
279	125	PORT ISABEL S.S.	94SB3760	782	1.986
280	338	RISING STAR	97AB5080	622	1.984
281	462	ASPHALT MINES	94LA500	43	1.977
282	260	SANTA ANNA	97SA3415	343	1.974
283	812	EOLA	97SA4950	211	1.972
284	864	ROBY	97AB3795	76	1.961
285	377	BEN FICKLIN	97SA6180	563	1.957
286	122	EAST HARRISON	94SB3950	788	1.952
287	1253	TRADE ZONE	94SB1935	41	1.951
288	656	CITRUS CITY	94SB5070	1022	1.938
289	422	OLMITO	94SB715	673	1.938
290	913	WESLACO UNIT	94SB7455	1235	1.925
291	661	MALONE	94CN7560	58	1.914
292	752	RODD FIELD	94CS205	2184	1.900
293	686	SOUTHSIDE	94CS7995	1551	1.881
294	38	GREENLAKE	94CN2740	381	1.879
295	224	PORT ARANSAS	94CS990	2661	1.876
296	367	CLARKWOOD	94CS9570	1234	1.874
297	919	SOUTH PADRE ISLAND	94SB5850	1374	1.870
298	79	MCCAMEY	97SA2420	82	1.866
299	1146	CASA BLANCA	94CS5440	109	1.862
300	491	ELDORADO	97SA2880	354	1.853
301	113	VERHALEN	97SA14765	27	1.852
302	214	LA PRYOR	94LA580	334	1.847
303	208	WADSWORTH	94CN7660	1476	1.838
304	584	HIGHWAY 9	94CS6730	546	1.835
305	394	PALMHURST	94SB2530	2755	1.834
306	146	MAGNOLIA	94CN315	84	1.833
307	242	BIG OAK	94CN420	341	1.827
308	653	NORTH MCALLEN	94SB2980	1885	1.821
309	119	SOUTH SANTA ROSA	94SB1215	1717	1.818
310	548	ARCADIA	94CS8570	1448	1.791
311	742	SAN BENITO	94SB4945	1732	1.782
312	NA	PROGRESO	94SB2545	90	1.778
313	560	SPUDDER FLAT	97SA4175	57	1.772
314	67	WESMER	94SB1850	485	1.765
315	39	PLEASANTON	94LA120	1233	1.756
316	559	SAND ROAD	97AB5195	254	1.748
317	69	SABINAL	94LA485	498	1.747
318	187	WESMER	94SB7760	1464	1.736
319	34	CONOCO-CHITTAM RANCH	94LA8580	26	1.731
320	329	BLESSING	94CN1030	285	1.723
321	885	BLACK CAT	94CN2960	2121	1.723
322	895	ROUNDTOP	97AB4490	54	1.722
323	534	ARANSAS PASS	94CS8280	619	1.704
324	865	MORRIS STREET	94CS2515	1017	1.699

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
325	306	CRYSTAL CITY	94LA8380	1340	1.683
326	708	CRESTONIO	94LA260	1780	1.682
327	243	PHARAOH	94CS1285	1776	1.682
328	387	HIDALGO	94SB3400	891	1.677
329	382	PECOS VALLEY	97SA4075	21	1.667
330	423	PEARSALL	94LA9905	435	1.667
331	54	NAVAL BASE	94CS9720	2657	1.657
332	129	PECAN BAYOU	97AB6810	467	1.655
333	476	MCCOLL ROAD	94SB4780	2021	1.651
334	15	CAUSEWAY	94SB4765	619	1.649
335	105	PALACIOS	94CN6830	838	1.635
336	563	SAN YGNACIO	94LA16060	539	1.635
337	205	EL GATO	94SB780	2161	1.628
338	806	BROOKHOLLOW	94CN7580	500	1.628
339	181	SOUTH SANTA ROSA	94SB1225	867	1.624
340	912	PICACHO	94LA1230	1052	1.620
341	855	KNIPPA	94LA6365	338	1.618
342	241	SANTA RITA	97SA1100	110	1.618
343	385	GOODWIN	94SB4390	413	1.613
344	109	BROWNSVILLE	94SB4290	492	1.612
345	694	SOUTH EAST EDINBURG	94SB6580	939	1.608
346	1223	SA SOUTHLAND HILLS	97SA5050	890	1.606
347	1053	HALL ACRES ROAD	94SB8870	2509	1.599
348	849	BEEVILLE	94CN300	1676	1.597
349	206	LEARY LANE	94CN7530	3171	1.595
350	763	STAMFORD	97AB2815	706	1.593
351	484	ZACATE CREEK	94LA2635	975	1.589
352	1219	WEST MCALLEN	94SB4815	568	1.588
353	537	MERKEL	97AB1895	709	1.585
354	354	SOUTHSIDE	94CS8055	848	1.574
355	219	KINGSVILLE	94CS1660	1981	1.573
356	428	FALFURRIAS	94LA2830	1529	1.573
357	150	OLMITO	94SB4275	818	1.568
358	1229	HEINES	94CS2185	1257	1.566
359	101	SOUTHSIDE	94CS7925	1160	1.554
360	852	HEIGHTS	94LA6820	1944	1.554
361	487	WOODSON OIL FIELD	97AB30	33	1.545
362	882	MAGRUDER	94CN7870	1262	1.545
363	518	DEVINE	94LA7100	1118	1.544
364	651	WEST OSO	94CS9090	1672	1.541
365	1002	DILLEY	94LA510	560	1.530
366	384	BRUNI	94LA5440	129	1.527
367	82	UVALDE	94LA550	746	1.525
368	322	VICTORIA POWER PLANT	94CN7600	164	1.524
369	723	NIXON	94CN3300	594	1.524
370	289	KEPLER	94CS1700	27	1.519
371	989	FT DAVIS	97SA4515	1013	1.512

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
372	331	TAFT	94CS1180	957	1.510
373	402	YORKTOWN	94CN8420	669	1.504
374	16	EAGLE PASS CITY	94LA450	886	1.498
375	325	BROWNSVILLE	94SB4280	325	1.495
376	1217	UNIVERSITY	94LA950	1737	1.492
377	127	ARCADIA	94CS1450	1638	1.491
378	991	FT CHADBOURNE	97SA6520	553	1.481
379	717	MAVERICK	94LA9680	843	1.480
380	539	FULTON	94CS3070	1589	1.480
381	1062	SA NORTH	97SA3115	586	1.478
382	400	LAGUNA	94CS9065	2373	1.476
383	173	CROSS PLAINS	97AB2920	552	1.475
384	614	SA LAKE DR	97SA6030	761	1.473
385	381	TUSCOLA	97AB3730	1215	1.472
386	595	WESLACO UNIT	94SB7630	2641	1.469
387	1107	HALL ACRES ROAD	94SB5465	1443	1.468
388	836	LOLITA	94CN6330	30	1.467
389	1285	PANTERA	94SB1765	881	1.464
390	827	VILLA CAVAZOS	94SB7615	1121	1.463
391	901	HARLINGEN SWITCH	94SB4230	1362	1.446
392	1160	ANNA STREET	94LA780	474	1.445
393	527	PALMHURST	94SB2820	1870	1.443
394	343	FLOMOT	97AB1852	75	1.440
395	765	CARRIZO SPRINGS	94LA750	599	1.439
396	675	CHOKE CANYON	94CN9255	367	1.439
397	292	PORT ARANSAS	94CS6940	1635	1.436
398	305	PARKER	94CN9260	126	1.429
399	774	HIGHWAY 9	94CS9830	133	1.429
400	356	ARANSAS PASS	94CS590	459	1.425
401	1191	BALLINGER	97SA4370	777	1.423
402	161	GARCENO	94SB2130	1821	1.422
403	232	KENEDY	94CN1970	567	1.420
404	499	WEST MCALLEN	94SB4505	1908	1.414
405	751	CARANCAHUA	94CN5870	472	1.411
406	687	BEEVILLE	94CN490	952	1.403
407	840	PUEBLO	94LA9870	1463	1.403
408	682	SA GRAPE CREEK	97SA5220	716	1.402
409	642	LYTLE	94LA2850	757	1.400
410	1113	EAST HARRISON	94SB3080	472	1.398
411	213	PIRATE	94CS3220	741	1.398
412	556	HARLINGEN SWITCH	94SB5350	965	1.390
413	202	SONORA 138 SUB	97SA4805	347	1.386
414	269	DEVINE	94LA8100	1647	1.386
415	496	MORRIS STREET	94CS5655	316	1.386
416	634	LULING - LCRA	94CN20	278	1.385
417	677	ABILENE PLANT	97AB1565	280	1.382
418	178	FULTON	94CS9050	1576	1.378

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
419	210	FREER	94LA5200	1013	1.376
420	440	PICACHO	94LA590	397	1.373
421	839	JUNCTION	97SA10805	816	1.366
422	602	ABILENE PLANT	97AB1570	959	1.357
423	188	WYLIE	97AB2665	1090	1.349
424	689	EDROY	94CS6980	195	1.344
425	220	STERLING CITY	97SA1445	381	1.341
426	96	PHARAOH	94CS5175	1284	1.339
427	509	WEST OSO	94CS9095	1659	1.339
428	1082	CHRISTOVAL	97SA6615	460	1.337
429	438	CLYDE	97AB3635	454	1.335
430	300	KINGSVILLE	94CS1130	2226	1.334
431	409	CONTINENTAL	94SB4880	69	1.333
432	1007	THROCKMORTON	97AB2090	75	1.333
433	228	EL GATO	94SB720	2571	1.333
434	1194	SAND CRAB	94CN6800	1126	1.331
435	424	JOURDANTON	94LA5685	327	1.330
436	695	BAIRD	97AB5125	511	1.327
437	357	ELSA	94SB710	2369	1.324
438	1071	RIO BRAVO	94LA300	803	1.313
439	905	HIGHWAY 9	94CS7200	655	1.311
440	468	YOUNG	94SB5135	1288	1.309
441	970	POWELL FIELD	97SA2529	13	1.308
442	968	WASHINGTON STREET	94LA6525	2740	1.306
443	328	PLEASANTON	94LA9475	1367	1.306
444	464	BLACK CAT	94CN3000	1646	1.301
445	1156	ANSON REA (SEC)	97AB5215	259	1.301
446	279	GREGORY	94CS420	467	1.300
447	658	MOORE FIELD	94SB3960	2191	1.299
448	925	NORDHEIM	94CN3380	174	1.299
449	408	PHARAOH	94CS1365	684	1.298
450	106	RULE	97AB3396	440	1.295
451	376	THREE RIVERS	94CN5190	475	1.293
452	29	CAUSEWAY	94SB4795	390	1.292
453	1134	SPUDDER FLAT	97SA4180	48	1.292
454	665	VALADEZ	94CS9890	1908	1.290
455	170	HEARN ROAD	94CS8980	1255	1.289
456	813	RESACA	94SB8700	1125	1.284
457	571	DEL RIO CITY	94LA9850	1037	1.278
458	309	NAVAL BASE	94CS8540	1624	1.277
459	792	SHAFTER	97SA5110	47	1.277
460	469	CHRISTOVAL	97SA6620	655	1.276
461	240	WEST HARLINGEN	94SB3800	1423	1.276
462	199	WYLIE	97AB6340	779	1.275
463	1003	HEARN ROAD	94CS9665	690	1.274
464	344	PALACIOS	94CN6840	1540	1.272
465	666	SAN BENITO	94SB3920	1651	1.270

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
466	801	AB MCMURRY	97AB3245	795	1.267
467	1000	SHARYLAND	94SB6745	2320	1.265
468	834	BOBCAT HILLS	97SA6655	73	1.260
469	NA	LA PRYOR	94LA1845	223	1.260
470	604	AB ONYX REA	97AB3260	148	1.257
471	643	CASA BLANCA	94CS1300	291	1.254
472	1001	WESLACO UNIT	94SB2195	1102	1.251
473	1005	AB ELM CREEK	97AB4775	886	1.248
474	1030	THOMASTON	94CN9580	49	1.245
475	719	SOUTHSIDE	94CS7905	1828	1.243
476	669	LA PRYOR	94LA2440	194	1.242
477	163	RISING STAR	97AB5075	688	1.240
478	859	AB VOGEL ST	97AB4560	1477	1.237
479	728	CHASE FIELD	94CN460	17	1.235
480	1125	CLYDE	97AB3630	438	1.235
481	519	CLOSNER	94SB4100	2086	1.233
482	652	NORTH VICTORIA	94CN6390	1510	1.232
483	605	MOCKINGBIRD	94CN370	49	1.224
484	1211	AB SHELTON ST	97AB4640	663	1.223
485	1047	AB OVER STREET 12KV	97AB1645	796	1.222
486	569	GOLIAD	94CN6540	1244	1.222
487	314	INDIAN MESA	97SA2690	146	1.219
488	775	SAN BENITO	94SB4030	1707	1.218
489	691	LANTANA	94CS7150	271	1.218
490	797	BEEVILLE	94CN2200	722	1.217
491	145	SINTON	94CS6860	1007	1.215
492	594	SA GRAPE CREEK	97SA4700	749	1.215
493	NA	PROGRESO	94SB2515	210	1.214
494	271	INGLESIDE CITY	94CS2495	273	1.212
495	722	READING	94LA1445	533	1.212
496	644	FALFURRIAS	94LA1080	463	1.212
497	713	HAINE DRIVE	94SB3490	1193	1.211
498	110	EAGLE PASS CITY	94LA2510	709	1.209
499	977	NORTH EDINBURG	94SB560	2199	1.209
500	235	RULE	97AB3378	106	1.208
501	869	PHARAOH	94CS5185	1244	1.207
502	1147	GONZALES	97SA14685	1328	1.207
503	715	SHROPSHIRE	94CN3575	34	1.206
504	413	LIVE OAK	94CS1090	299	1.204
505	21	UVALDE	94LA480	572	1.199
506	789	RIO GRANDE CITY	94SB3740	2390	1.196
507	200	SOUTHSIDE	94CS8045	970	1.193
508	971	AB RAINEY CREEK	97AB4550	988	1.192
509	132	BROOKHOLLOW	94CN8950	922	1.190
510	194	DEL RIO CITY	94LA420	2051	1.190
511	967	ROBSTOWN	94CS1650	354	1.189
512	962	SOUTH EAST EDINBURG	94SB5045	1783	1.189

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
513	1239	NORTH MCCAMEY	97SA6555	795	1.184
514	1090	THROCKMORTON	97AB3190	645	1.183
515	1139	AFTON	97AB2310	246	1.183
516	1138	SA LAKE DR	97SA5865	1062	1.183
517	1112	BROOKHOLLOW	94CN7190	280	1.182
518	1286	DONNA SKID	94SBTX_B	529	1.181
519	1136	SA SOUTHLAND HILLS	97SA5455	1428	1.179
520	270	HOLCOMB	94LA3025	371	1.178
521	369	HOLLY	94CS5820	903	1.177
522	662	KINGSVILLE	94CS1670	426	1.176
523	606	ANSON 12KV	97AB6635	414	1.174
524	1204	DUST DEVIL	94LA1495	2026	1.171
525	507	MELVIN	97SA4955	82	1.171
526	796	LA GRULLA	94SB5005	1215	1.169
527	1095	EDNA	94CN5785	1258	1.169
528	922	CHILLICOTHE	97AB4530	506	1.168
529	764	LAREDO PLANT	94LA9305	1066	1.168
530	1119	GREGORY	94CS2420	913	1.166
531	931	CROSS PLAINS	97AB1795	434	1.166
532	1178	SA EMERSON ST	97SA4620	431	1.165
533	934	VICTORIA POWER PLANT	94CN8070	608	1.161
534	1282	MAYBERRY	94SB5340	39	1.154
535	248	SANTA ANNA	97SA3420	367	1.153
536	1024	RUSSEK STREET	97SA7705	1331	1.153
537	1206	AB SHELTON ST	97AB3045	550	1.149
538	19	MORRIS STREET	94CS7465	743	1.148
539	1016	AB OVER STREET 12KV	97AB1635	528	1.148
540	1195	WYLIE	97AB2675	820	1.148
541	973	RESACA	94SB9975	561	1.146
542	420	NORTH MCALLEN	94SB5055	3319	1.145
543	193	THREE RIVERS	94CN5100	76	1.145
544	395	PUTNAM	97AB2129	201	1.144
545	520	CARRIZO SPRINGS	94LA910	872	1.142
546	555	AB OVER STREET 12KV	97AB1840	888	1.142
547	1049	AB EAST 12KV	97AB4820	1152	1.141
548	766	PUTNAM	97AB2131	123	1.138
549	943	NORDHEIM	94CN4275	80	1.138
550	846	CITRUS CITY	94SB6000	2373	1.135
551	552	MILO	94LA3070	1966	1.135
552	1224	ARANSAS PASS	94CS8270	412	1.133
553	454	MUNDAY	97AB6715	257	1.132
554	196	PHARR	94SB1645	1728	1.132
555	873	TWILIGHT TRAIL	97AB5855	257	1.128
556	1088	QUANAH	97AB3100	557	1.126
557	1029	ROTAN	97AB1860	686	1.125
558	1148	SARAGOSA	97SA14080	48	1.125
559	558	WINTERS	97SA2113	801	1.124

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
560	578	GOVERNMENT WELLS	94LA7240	229	1.122
561	1142	RANKIN	97SA6405	360	1.119
562	1094	SA NORTH	97SA3125	1387	1.119
563	600	BARNHART	97SA3725	135	1.119
564	1	WESMER	94SB6900	51	1.118
565	564	POLK AVENUE	94SB4740	1718	1.113
566	697	HAROLD	97AB3055	27	1.111
567	598	PECAN BAYOU	97AB530	18	1.111
568	120	GRAYBACK	97AB3315	46	1.109
569	1031	TURKEY	97AB2980	333	1.108
570	207	ODEM	94CS2400	315	1.108
571	397	SANTO NINO	94LA75	1515	1.108
572	622	BEN FICKLIN	97SA6185	755	1.106
573	940	AB MCMURRY	97AB4360	1100	1.105
574	904	SEAWALL	94CS9450	299	1.104
575	566	PORT ARANSAS	94CS1000	1611	1.101
576	477	HASKELL 12KV	97AB3770	459	1.098
577	73	BONNIEVIEW	94CS8020	544	1.097
578	650	KLEBERG	94CS6410	247	1.097
579	177	HOLLY	94CS9675	1776	1.096
580	493	MCCOLL ROAD	94SB4910	335	1.096
581	100	VALENTINE	97SA6325	550	1.095
582	295	HIDALGO	94SB3680	334	1.093
583	1017	MAYBERRY	94SB1790	1090	1.092
584	1010	AB ELM CREEK	97AB1815	388	1.090
585	1077	PANTERA	94SB1315	1921	1.090
586	916	YOUNG	94SB7145	1810	1.090
587	1196	AB OVER STREET 12KV	97AB3140	686	1.087
588	1135	ANSON 12KV	97AB6630	718	1.086
589	1250	MORRIS STREET	94CSBLACK	82	1.085
590	217	EDROY	94CS6990	294	1.085
591	450	ELDORADO	97SA5310	189	1.085
592	508	SA GRAPE CREEK	97SA5365	857	1.084
593	1209	SAND CRAB	94CN8390	532	1.083
594	969	NORTH MCALLEN	94SB2750	3182	1.082
595	565	KNOX CITY	97AB3390	380	1.082
596	247	DARST	94CN1265	75	1.080
597	1158	UNITEC	94LA4715	40	1.075
598	162	BROWNSVILLE	94SB3050	2010	1.075
599	641	ABILENE PLANT	97AB1735	84	1.071
600	632	WOODSBORO	94CS8330	298	1.070
601	513	AB EAST 12KV	97AB5760	215	1.070
602	512	HAINE DRIVE	94SB8065	1368	1.069
603	461	DIMMIT	94LA5545	549	1.069
604	941	JOURDANTON	94LA8725	30	1.067
605	1133	RUSSEK STREET	97SA250	143	1.063
606	95	GOLIAD	94CN8220	1056	1.063

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
607	586	AB SHELTON ST	97AB3040	179	1.061
608	1190	AB COUNTRY CLUB	97AB4730	542	1.061
609	1164	ROBY	97AB2276	333	1.054
610	1157	AIRLINE	94CS8890	526	1.053
611	1074	DEL MAR	94LA7930	1981	1.053
612	257	HAINE DRIVE	94SB9700	1166	1.050
613	1060	GATEWAY	94LA3595	1503	1.044
614	353	PLEASANTON	94LA2080	1742	1.040
615	1240	AB ELM CREEK	97AB1820	100	1.040
616	1265	HAMLIN SHELL	97AB6330	26	1.038
617	589	CITRUS CITY	94SB3470	1776	1.038
618	963	VERNON	97AB1520	723	1.037
619	1174	AB WALNUT ST	97AB3445	56	1.036
620	6	BLACK BAYOU	94CN1120	371	1.035
621	80	STAFFORD HILL	94CN1550	144	1.035
622	1260	VICTORIA POWER PLANT	94CNVGREEN	29	1.034
623	623	AB SHELTON ST	97AB3435	295	1.031
624	NA	BULL MOOSE	94CS5875	66	1.030
625	NA	DARST	94CN1610	66	1.030
626	1043	HEIGHTS	94LA2390	1722	1.030
627	983	YOUNG	94SB3310	1873	1.025
628	1254	MORRIS STREET	94CSYELLOW	44	1.023
629	155	SABINAL	94LA200	443	1.023
630	1102	MCCOLL ROAD	94SB5485	1077	1.019
631	283	ROWENA	97SA4480	231	1.017
632	887	MINES ROAD	94LA4275	252	1.016
633	238	KARNES CITY	94CN2315	1026	1.015
634	1198	HASKELL 12KV	97AB5240	650	1.014
635	1271	MORRIS STREET	94CSRED	148	1.014
636	640	MUSTANG ISLAND	94CS8510	516	1.010
637	1238	AB COUNTRY CLUB	97AB4725	230	1.009
638	1278	MORRIS STREET	94CSGREEN	235	1.009
639	1241	KENEDY S.S.	94CN8320	142	1.007
640	960	WEST MCALLEN	94SB4595	1190	1.006
641	830	DEL MAR	94LA490	797	1.003
642	608	TRENT	97AB2850	25	1.000
643	115	MESA VIEW	97SA7045	93	1.000
644	1048	MCKENZIE ROAD	94CS150	26	1.000
645	1197	AFTON	97AB2355	45	1.000
646	1255	VICTORIA POWER PLANT	94CNVRED	44	1.000
647	1259	VICTORIA POWER PLANT	94CNVBROWN	16	1.000
648	511	SA COKE ST	97SA3905	653	1.000
649	391	PETTUS	94CN8210	346	0.994
650	935	EL GATO	94SB890	3108	0.989
651	153	AFTON	97AB2225	54	0.981
652	1170	DEL MAR	94LA3440	1807	0.979
653	1045	CEDAR GAP (TEC)	97AB4115	972	0.971

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
654	403	NORTH PADRE ISLAND	94CS1010	2394	0.964
655	638	HAROLD	97AB1495	25	0.960
656	1080	JOSLIN POWER PLANT	94CN8720	24	0.958
657	185	MCCAMEY	97SA2855	508	0.957
658	1050	ALPINE 12KV	97SA3160	1642	0.952
659	63	RANDADO	94LA8350	136	0.949
660	1274	MORRIS STREET	94CSBROWN	67	0.940
661	1203	MAYBERRY	94SB5770	924	0.938
662	609	BENTSEN	94SBSH115	342	0.930
663	312	CONTINENTAL	94SB3650	14	0.929
664	899	RUNGE	94CN3250	273	0.927
665	448	RODD FIELD	94CS1730	2211	0.923
666	1177	TWILIGHT TRAIL	97AB11500	1050	0.915
667	828	IRAAN	97SA2050	389	0.900
668	211	BRACKETTVILLE	94LA8460	1201	0.899
669	215	WOOLRIDGE	94CS1170	439	0.897
670	9	BAY CITY	94CN5960	402	0.893
671	684	SOUTHSIDE	94CS8035	1086	0.891
672	810	HEIGHTS	94LA9400	1470	0.887
673	503	POLK AVENUE	94SB4180	1298	0.883
674	31	HARLINGEN SWITCH	94SB4090	2347	0.883
675	1182	SOUTH MCALLEN	94SB5065	175	0.880
676	756	ARANSAS PASS	94CS1250	661	0.879
677	360	FREER	94LA2900	164	0.866
678	646	CRYSTAL CITY	94LA1425	1193	0.865
679	748	KLEBERG	94CS1560	1472	0.861
680	1218	SOUTH EAST EDINBURG	94SB4015	448	0.857
681	287	COTULLA	94LA460	502	0.857
682	495	SOUTH SANTA ROSA	94SB7485	1235	0.840
683	703	POINT COMFORT	94CN6060	369	0.840
684	760	RAYMONDVILLE #1	94SB3130	307	0.837
685	374	BANQUETTE	94CS130	231	0.835
686	1127	MATADOR	97AB3030	217	0.834
687	149	WEST MCALLEN	94SB4555	1619	0.832
688	298	CAMPWOOD	94LA3430	123	0.829
689	803	MESQUITE	94SB2900	948	0.814
690	1085	PRIMERA	94SB6085	1462	0.814
691	486	MERTZON (CVEC)	97SA2905	592	0.806
692	457	SOUTH MISSION	94SB3620	2110	0.801
693	915	IRAAN	97SA2055	135	0.800
694	458	ARCADIA	94CS1400	443	0.797
695	316	BLESSING	94CN8790	761	0.794
696	872	REFUGIO	94CN1210	190	0.789
697	433	AIRLINE	94CS8370	274	0.788
698	825	TYNAN	94CS4000	27	0.778
699	1162	THREE RIVERS	94CN2010	313	0.767
700	244	ESCONDIDO	94LA3350	2283	0.761

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
701	980	ALAZAN	94CS2740	36	0.750
702	546	AIRLINE	94CS8260	1421	0.742
703	378	SOUTH SANTA ROSA	94SB1240	1704	0.738
704	405	AB HARTFORD ST	97AB3815	1114	0.732
705	880	ROCKPORT	94CS5930	944	0.730
706	702	ARCADIA	94CS1460	2455	0.730
707	636	STADIUM	94LA7810	1324	0.723
708	303	MATHIS	94CS1420	911	0.719
709	670	AMISTAD DAM	94LA5450	782	0.706
710	383	AB OIL MILL	97AB2780	747	0.700
711	673	NORTH VICTORIA	94CN7430	1685	0.694
712	319	MORRIS STREET	94CS8830	1512	0.692
713	1004	HAMILTON ROAD	94LA9655	1323	0.688
714	918	CHILDRESS 69	97AB1800	543	0.685
715	327	MORRIS STREET	94CS8715	1587	0.679
716	1159	STADIUM	94LA7800	686	0.678
717	442	MAGRUDER	94CN6690	756	0.677
718	817	NORTH VICTORIA	94CN1580	1049	0.677
719	152	COFFEE PORT	94SB1090	1257	0.671
720	426	ARMSTRONG	94CS6050	85	0.671
721	772	LEARY LANE	94CN1890	1625	0.668
722	992	BRADY	97SA5015	201	0.667
723	898	KITTIE WEST	94CN3760	240	0.667
724	958	CITRUS CITY	94SB7985	1211	0.666
725	453	PREMONT	94LA2720	776	0.664
726	829	SANTO NINO	94LA515	1174	0.659
727	432	HAINE DRIVE	94SB270	1172	0.656
728	847	GATEWAY	94LA390	3743	0.656
729	425	SUN VALLEY	97SA4300	69	0.652
730	335	GREENLAKE	94CN2760	1189	0.646
731	102	PORTLAND	94CS6505	1826	0.634
732	626	CABANISS	94CS80	98	0.633
733	590	RAYMONDVILLE #2	94SB3240	919	0.632
734	268	GREENLAKE	94CN2750	73	0.630
735	345	PETTUS	94CN1020	456	0.629
736	99	EAST HARRISON	94SB3190	1489	0.626
737	907	CHILDRESS 69	97AB1480	303	0.614
738	179	BUENA VISTA	94LA8965	919	0.614
739	1207	HIGHLAND	97SA6370	270	0.611
740	389	HAMILTON ROAD	94LA9665	1258	0.607
741	154	HALL ACRES ROAD	94SB3670	1292	0.603
742	1179	YOUNG	94SB4435	826	0.603
743	921	JUNCTION	97SA10795	811	0.602
744	223	PHARAOH	94CS1185	1414	0.601
745	955	ROCKPORT	94CS5130	566	0.601
746	863	AIRLINE	94CS9030	403	0.598
747	164	ALPINE 12KV	97SA6825	1806	0.596

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
748	630	RUNGE	94CN4465	361	0.596
749	234	NIXON	94CN2025	539	0.596
750	914	HARLINGEN	94SB370	1236	0.595
751	140	RIO GRANDE CITY	94SB3220	1420	0.593
752	938	MAGRUDER	94CN7690	542	0.592
753	947	GATEWAY	94LA350	2017	0.591
754	195	PEARSALL	94LA7050	581	0.585
755	809	HOMEPORT	94CS4665	429	0.580
756	683	SINTON	94CS1750	266	0.579
757	831	JOURDANTON	94LA880	1121	0.577
758	937	EAST HARRISON	94SB3030	678	0.572
759	767	AIRLINE	94CS9605	713	0.565
760	888	DEL RIO CITY	94LA440	1115	0.552
761	619	SAND CRAB	94CN6735	1321	0.551
762	1221	TRUSCOTT	97AB3845	31	0.548
763	580	BRUNI	94LA1100	602	0.548
764	1152	VERNON	97AB3340	534	0.547
765	108	WESLACO UNIT	94SB8610	1194	0.545
766	897	KLEIMANN	94CN565	582	0.545
767	414	LAS CRUSES	94LA7325	2761	0.541
768	167	HALL ACRES ROAD	94SB3460	3201	0.541
769	596	COTULLA	94LA610	727	0.541
770	893	FRIO	94LA2270	990	0.536
771	418	PALMVIEW	94SB9685	2957	0.533
772	793	FRIO	94LA1815	1069	0.529
773	709	ASHERTON	94LA5495	597	0.528
774	896	ANNA STREET	94LA900	2843	0.526
775	725	KENEDY S.S.	94CN8340	307	0.524
776	657	JOURDANTON	94LA5695	323	0.523
777	664	CRESTONIO	94LA6660	790	0.520
778	777	NIXON	94CN6630	645	0.519
779	339	GOVERNMENT WELLS	94LA6800	230	0.513
780	456	PORTLAND	94CS9270	1810	0.511
781	478	GEORGE WEST	94CN730	907	0.507
782	160	EAGLE LAKE	94CN320	629	0.506
783	824	PORT ISABEL S.S.	94SB4070	283	0.505
784	676	SAN DIEGO	94LA2880	1335	0.496
785	727	SAN DIEGO	94LA2890	1019	0.495
786	480	MOCKINGBIRD	94CN400	1015	0.491
787	616	SANTO NINO	94LA70	3113	0.485
788	282	CASA BLANCA	94CS4170	1158	0.485
789	75	BANDERA ELECTRIC (LEAKEY)	94LAL30	271	0.480
790	97	VILLA CAVAZOS	94SB5680	1983	0.478
791	1013	ALPINE 12KV	97SA3155	1357	0.477
792	1176	AB MCMURRY	97AB3240	766	0.477
793	787	EAGLE PASS CITY	94LA7060	871	0.476
794	543	ALBANY	97AB3540	635	0.476

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
795	436	CRYSTAL CITY	94LA7425	444	0.475
796	470	HOLLY	94CS1370	1886	0.475
797	549	SHARYLAND	94SB5105	2042	0.472
798	738	EAST HARRISON	94SB4310	1205	0.469
799	667	WEST MCALLEN	94SB4515	867	0.463
800	805	HEARN ROAD	94CS2220	1731	0.460
801	348	CARANCAHUA	94CN1875	59	0.458
802	1020	CHILDRESS 20TH ST	97AB5720	186	0.457
803	786	VERNON	97AB4275	593	0.455
804	1034	DEL RIO CITY	94LA9790	2357	0.454
805	576	SOUTHSIDE	94CS7955	1067	0.450
806	417	WINTERS	97SA3765	824	0.441
807	837	CHARLOTTE	94LA1960	506	0.439
808	843	ASPR CONTINENTAL	97AB4800	32	0.438
809	911	READING	94LA1275	78	0.436
810	20	NORTH VICTORIA	94CN7440	1643	0.435
811	841	CHOKE CANYON	94CN5390	412	0.434
812	781	SOUTHSIDE	94CS8005	744	0.434
813	952	SHEFFIELD	97SA6430	209	0.431
814	1281	MAYBERRY	94SB6450	28	0.429
815	411	REFUGIO	94CN1040	161	0.429
816	1059	BRONTE AMBASSADOR	97SA6650	14	0.429
817	1023	HEIGHTS	94LA2450	2042	0.426
818	860	EL CAMPO	94CN7710	1074	0.426
819	591	RUSSEK STREET	97SA11370	200	0.425
820	822	EAST HARRISON	94SB4360	1769	0.424
821	24	SUNCHASE	94SB1155	1433	0.424
822	297	HIGHWAY 9	94CS6780	754	0.422
823	858	STADIUM	94LA8540	1695	0.418
824	1008	MILO	94LA5020	113	0.416
825	701	BUENA VISTA	94LA9385	892	0.415
826	336	WEST MCALLEN	94SB4535	3068	0.415
827	674	NORTH EDINBURG	94SB3570	1051	0.414
828	439	ARCADIA	94CS1360	1539	0.409
829	618	MILO	94LA6940	467	0.407
830	879	RESACA	94SB7110	1730	0.405
831	716	EL CAMPO	94CN2860	1517	0.403
832	142	DARST	94CN1845	184	0.402
833	431	AB VOGEL ST	97AB4410	764	0.402
834	246	CLARKWOOD	94CS7610	105	0.400
835	744	STADIUM	94LA7490	1307	0.399
836	315	BROOKHOLLOW	94CN8960	595	0.398
837	721	MORAN	97AB2108	304	0.398
838	1081	REFUGIO	94CN1170	864	0.397
839	799	GRETA	94CN7890	235	0.396
840	857	CATARINA	94LA2380	187	0.396
841	739	BAY CITY	94CN2050	329	0.395

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
842	471	MAGRUDER	94CN245	1248	0.395
843	1021	BUENA VISTA	94LA9035	2048	0.395
844	37	CITRUS CITY	94SB9775	1599	0.393
845	535	REFUGIO	94CN5120	726	0.391
846	939	NORTH EDINBURG	94SB4240	1151	0.391
847	410	ARCADIA	94CS5030	1578	0.388
848	655	ODEM	94CS5575	80	0.388
849	909	NORTH VICTORIA	94CN2240	746	0.387
850	175	BLACK CAT	94CN4525	114	0.386
851	1173	TWILIGHT TRAIL	97AB3150	724	0.384
852	45	PALMVIEW	94SB7595	3225	0.382
853	585	ANNA STREET	94LA2250	1557	0.379
854	30	HALL ACRES ROAD	94SB4895	882	0.379
855	318	AB DYESS 2	97AB6335	352	0.378
856	288	LA GRULLA	94SB5110	1030	0.378
857	444	AB ELM CREEK	97AB5045	384	0.378
858	617	NORTH VICTORIA	94CN1470	481	0.376
859	753	FALFURRIAS	94LA1070	937	0.376
860	842	SA WALNUT ST	97SA3925	894	0.371
861	771	WAGGONER	97AB5900	27	0.370
862	536	WEAVER ROAD	94CN1910	27	0.370
863	1193	WYLIE	97AB6495	362	0.370
864	502	AB ELMDALE	97AB4085	46	0.370
865	68	WESLACO UNIT	94SB9805	2269	0.369
866	1108	LAREDO PLANT	94LA8505	1053	0.366
867	1055	SPUR	97AB5170	383	0.366
868	647	KLEBERG	94CS6000	1408	0.365
869	811	GARCENO	94SB2165	1973	0.364
870	845	FULTON	94CS6070	1817	0.364
871	459	OLMITO	94SB905	1677	0.363
872	575	SA SOUTH	97SA2595	1070	0.363
873	1098	AB SHELTON ST	97AB3050	649	0.361
874	11	MEDIO CREEK	94CN1380	810	0.360
875	430	PANTERA	94SB1105	580	0.360
876	1153	HEINES	94CS7875	1951	0.360
877	66	MOORE FIELD	94SB3110	720	0.360
878	917	CABANISS	94CS820	1304	0.359
879	386	SINTON	94CS360	335	0.358
880	1032	AB RAINEY CREEK	97AB4220	219	0.356
881	137	HARLINGEN	94SB360	2434	0.355
882	1118	COLLEGE HILLS	97SA5520	432	0.354
883	139	BIG WELLS	94LA1570	430	0.353
884	359	MCKENZIE ROAD	94CS330	2406	0.352
885	94	HOLLY	94CS1950	838	0.351
886	412	WESLACO UNIT	94SB8195	1667	0.349
887	649	ARCADIA	94CS5020	1544	0.348
888	229	DUNE FIELD (N CRANE)	97SA3885	69	0.348

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
889	823	ELSA	94SB690	2419	0.347
890	0	RAYMONDVILLE #2	94SB1280	989	0.346
891	434	CARRIZO SPRINGS	94LA370	550	0.342
892	581	SA WALNUT ST	97SA3920	901	0.337
893	573	VERNON	97AB1750	246	0.337
894	1044	CABANISS	94CS710	175	0.337
895	816	HARLINGEN	94SB660	1270	0.337
896	134	SOUTH PADRE ISLAND	94SB6440	2590	0.336
897	340	GARCENO	94SB2135	1543	0.331
898	779	DILLEY	94LA6400	873	0.329
899	930	MERKEL	97AB1890	575	0.329
900	876	AB SHELTON ST	97AB3060	1584	0.328
901	679	LAREDO PLANT	94LA8565	1440	0.327
902	398	BAY CITY	94CN1110	1237	0.327
903	844	PUEBLO	94LA130	1764	0.327
904	8	MARKHAM	94CN6440	470	0.326
905	1279	ESPY WELLS	97SA50207	31	0.323
906	788	MOCKINGBIRD	94CN305	329	0.322
907	157	WEAVER ROAD	94CN1900	63	0.317
908	637	HALL ACRES ROAD	94SB9595	1588	0.317
909	350	ANNA STREET	94LA850	1559	0.317
910	1167	MCCOLL ROAD	94SB1655	1513	0.312
911	416	AB CANYON ROCK	97AB5030	699	0.310
912	332	NORTH MCALLEN	94SB5060	2634	0.310
913	735	HOLCOMB	94LA2240	458	0.310
914	347	ALICE	94LA1780	510	0.310
915	949	PONDER KENNEDY	97SA50208	13	0.308
916	936	HEIGHTS	94LA2100	1991	0.305
917	483	YOUNG	94SB6140	2536	0.304
918	769	MARFA	97SA1905	1155	0.304
919	362	CONTINENTAL	94SB4080	66	0.303
920	250	TANKERSLY (CVEC)	97SA5265	381	0.302
921	88	LAREDO PLANT	94LA8745	767	0.301
922	3	BAY CITY	94CN6450	164	0.299
923	780	AIRLINE	94CS9390	1352	0.297
924	1154	PANTERA	94SB1915	1195	0.297
925	957	SEAWALL	94CS9420	818	0.296
926	1061	THREE RIVERS	94CN2580	119	0.294
927	838	SHARYLAND	94SB2150	895	0.293
928	890	EL CAMPO	94CN7260	537	0.292
929	1122	ZACATE CREEK	94LA2675	1216	0.291
930	877	CRYSTAL CITY	94LA2170	747	0.290
931	678	CARRIZO SPRINGS	94LA860	31	0.290
932	870	EL CAMPO	94CN5745	941	0.290
933	1129	SA EMERSON ST	97SA4625	421	0.290
934	927	SA EMERSON ST	97SA4860	233	0.288
935	944	POLK AVENUE	94SB4520	1068	0.287

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
936	1058	MUNDAY REA (BKEC)	97AB2015	21	0.286
937	996	SA LAKE DR	97SA5880	735	0.286
938	1184	QUANAH	97AB100	89	0.281
939	663	SOUTH MISSION	94SB3590	556	0.279
940	540	SKIDMORE	94CS600	365	0.277
941	561	AB OIL MILL	97AB3900	690	0.275
942	624	MORAN	97AB2107	208	0.274
943	798	KARNES CITY	94CN2325	665	0.274
944	500	SAND ROAD	97AB5655	622	0.273
945	714	VALADEZ	94CS3140	1977	0.273
946	1063	AB CANYON ROCK	97AB5035	823	0.272
947	443	HAMILTON ROAD	94LA9645	298	0.272
948	371	MILO	94LA3060	129	0.271
949	233	EDNA	94CN5775	509	0.269
950	579	SA JACKSON ST	97SA4265	799	0.269
951	978	CHILDRESS 69	97AB4865	777	0.269
952	597	ESCONDIDO	94LA5730	2759	0.269
953	407	AIRLINE	94CS6970	1401	0.266
954	286	RACHAL	94LA6595	339	0.265
955	593	COLLEGE HILLS	97SA6145	981	0.265
956	1018	LEARY LANE	94CN6175	2483	0.264
957	1171	SA JACKSON ST	97SA4260	654	0.261
958	372	RIO GRANDE CITY	94SB3210	1991	0.260
959	881	MAGRUDER	94CN6700	1374	0.258
960	903	SHARYLAND	94SB5635	2311	0.258
961	466	KINGSVILLE	94CS1140	1134	0.257
962	472	SAN BENITO	94SB3910	680	0.257
963	1149	CHILDRESS 20TH ST	97AB5725	680	0.256
964	465	YELLOW JACKET	97SA5505	539	0.254
965	203	PALMHURST	94SB2525	2328	0.253
966	964	COLLEGE HILLS	97SA4840	218	0.252
967	174	TANKERSLY (CVEC)	97SA5260	479	0.251
968	1011	SA COKE ST	97SA4910	1783	0.246
969	252	EL CAMPO	94CN6370	776	0.245
970	473	ALICE	94LA2540	963	0.244
971	1186	WASHINGTON STREET	94LA7015	1545	0.244
972	1106	WASHINGTON STREET	94LA6355	949	0.243
973	961	AILEEN	97AB4605	429	0.242
974	259	ROMA	94SB3070	904	0.242
975	415	RANKIN	97SA5735	187	0.241
976	749	TAYLOR	94SBSH111	711	0.241
977	277	CLARKWOOD	94CS2170	795	0.239
978	380	ZAPATA	94LA7330	1375	0.239
979	1072	SONORA	97SA2045	202	0.238
980	538	YELLOW JACKET	97SA7935	810	0.236
981	832	CISCO	97AB7400	833	0.235
982	861	VERNON	97AB5000	247	0.235

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
983	504	AB OIL MILL	97AB3895	133	0.233
984	854	SA SOUTH	97SA3995	795	0.233
985	951	LANTANA	94CS4095	195	0.231
986	1188	ROARING SPRINGS	97AB2065	217	0.230
987	1175	AB COUNTRY CLUB	97AB4735	122	0.230
988	NA	PROGRESO	94SB2495	1696	0.229
989	1084	LA GRULLA	94SB4120	1532	0.228
990	850	KITTIE WEST	94CN3765	323	0.226
991	784	STADIUM	94LA6950	427	0.225
992	204	CLOSNER	94SB2945	1101	0.223
993	621	RODD FIELD	94CS245	705	0.221
994	1038	LAREDO PLANT	94LA8705	172	0.221
995	117	SANTA RITA	97SA1105	68	0.221
996	1103	LEARY LANE	94CN6005	1386	0.220
997	884	SOUTH MCALLEN	94SB3790	1468	0.218
998	981	KENEDY	94CN6270	546	0.218
999	379	RAYMONDVILLE #1	94SB800	740	0.218
1000	221	PALMHURST	94SB1300	2280	0.216
1001	392	SOUTH MISSION	94SB5215	1241	0.216
1002	1131	RODD FIELD	94CS3010	2068	0.216
1003	990	WASHINGTON STREET	94LA2350	3052	0.215
1004	1052	ARANSAS PASS	94CS9130	460	0.215
1005	639	MILO	94LA3065	28	0.214
1006	5	RAYMONDVILLE #2	94SB5875	28	0.214
1007	114	PORT ARANSAS	94CS3030	955	0.214
1008	266	PALMHURST	94SB2535	3048	0.214
1009	1051	MERTZON (CVEC)	97SA1530	338	0.213
1010	696	QUANAH	97AB1830	627	0.211
1011	826	MORRIS STREET	94CS8840	637	0.210
1012	25	SAN DIEGO	94LA1980	628	0.210
1013	361	AB MCMURRY	97AB4510	816	0.208
1014	984	EAGLE PASS CITY	94LA2650	1384	0.205
1015	1025	AB MCMURRY	97AB3235	781	0.204
1016	574	SAND ROAD	97AB5290	819	0.203
1017	953	BUSH KNOB	97AB5200	303	0.201
1018	334	MAGRUDER	94CN6680	701	0.201
1019	572	AB OIL MILL	97AB2785	274	0.201
1020	46	MARKHAM	94CN5550	20	0.200
1021	1227	PAINT ROCK	97SA5235	140	0.200
1022	577	UVALDE	94LA9770	516	0.200
1023	1115	SA AVENUE N	97SA1730	830	0.198
1024	524	KINGSVILLE	94CS1350	396	0.197
1025	1165	CLOSNER	94SB6430	1028	0.196
1026	447	AB COUNTRY CLUB	97AB4855	964	0.195
1027	568	READING	94LA1385	1354	0.194
1028	1121	ZAPATA	94LA8290	988	0.193
1029	1212	MAYO	94CS500	26	0.192

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
1030	1233	VALADEZ	94CS8800	1690	0.192
1031	1248	AB REBECCA LANE	97AB5555	1268	0.192
1032	942	GOODWIN	94SB3530	335	0.191
1033	755	TRADE ZONE	94SB2060	513	0.191
1034	1037	SA WALNUT ST	97SA4635	1549	0.189
1035	659	AB VOGEL ST	97AB4650	809	0.188
1036	1099	SOUTH PADRE ISLAND	94SB4675	197	0.188
1037	1151	SAN BENITO	94SB3860	258	0.186
1038	1035	GILA	94CS7840	770	0.184
1039	724	QUANAH	97AB3975	214	0.182
1040	1185	UNIVERSITY	94LA465	931	0.182
1041	762	SARAGOSA	97SA1552	780	0.181
1042	522	STAMFORD	97AB4565	786	0.179
1043	281	GOODWIN	94SB4625	2302	0.178
1044	1228	UNIVERSITY	94LA920	909	0.177
1045	730	PRIMERA	94SB7020	1484	0.177
1046	633	TRENT	97AB4245	183	0.175
1047	218	MESQUITE	94SB8340	759	0.174
1048	1066	HEIGHTS	94LA6810	2122	0.173
1049	974	SANTO NINO	94LA80	1904	0.173
1050	254	MUSTANG ISLAND	94CS9470	790	0.172
1051	975	SOUTH MISSION	94SB4650	1010	0.171
1052	997	CISCO	97AB9715	1023	0.170
1053	488	RAYMONDVILLE #1	94SB620	667	0.169
1054	819	KLEIMANN	94CN425	612	0.168
1055	814	HIGHLAND	97SA6385	1356	0.168
1056	783	BIG WELLS	94LA2630	30	0.167
1057	1256	DUST DEVIL	94LA1380	42	0.167
1058	1111	ROARING SPRINGS	97AB6155	30	0.167
1059	758	TATTON	94CS8200	1225	0.167
1060	48	GILA	94CS350	308	0.166
1061	1033	ARANSAS PASS	94CS650	1192	0.165
1062	1242	COLLEGE HILLS	97SA4845	600	0.165
1063	245	NORTH MCALLEN	94SB9660	2183	0.164
1064	1126	TWILIGHT TRAIL	97AB4290	1202	0.164
1065	144	SOUTH MCALLEN	94SB3850	1362	0.164
1066	216	KLEBERG	94CS280	1328	0.163
1067	85	ALBANY	97AB3655	625	0.163
1068	526	SAND ROAD	97AB5295	537	0.162
1069	42	SONORA ATLANTIC (SWTEC)	97SA4415	31	0.161
1070	976	FT DAVIS	97SA3345	539	0.160
1071	1069	COTULLA	94LA90	1058	0.157
1072	924	WASHINGTON STREET	94LA2360	204	0.157
1073	1054	STAMFORD	97AB6255	434	0.157
1074	253	ROCKPORT	94CS5940	64	0.156
1075	926	KLEBERG	94CS8140	643	0.154
1076	544	CROWELL	97AB3490	176	0.153

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
1077	529	ROCKSPRINGS	94LA2600	368	0.152
1078	1236	SPUR	97AB300	204	0.152
1079	1192	SA WALNUT ST	97SA3910	145	0.152
1080	1130	BENJAMIN (BEPC)	97AB5680	165	0.152
1081	18	STAMFORD	97AB2835	100	0.150
1082	1070	RANKIN	97SA6400	60	0.150
1083	358	WOOLRIDGE	94CS1120	1636	0.150
1084	815	SOUTH EAST EDINBURG	94SB4570	1902	0.148
1085	533	VERNON CITY PLANT	97AB5775	813	0.148
1086	256	DEL MAR	94LA10	1746	0.147
1087	NA	DUST DEVIL	94LA1810	478	0.146
1088	201	GILA	94CS345	69	0.145
1089	1168	AB WALNUT ST	97AB3110	658	0.144
1090	802	ENCINAL	94LA2160	231	0.143
1091	355	PEARSALL	94LA5580	854	0.143
1092	481	SHARYLAND	94SB2020	2814	0.141
1093	889	KLEBERG	94CS9395	1261	0.140
1094	494	SA AVENUE N	97SA1695	1525	0.140
1095	148	GOVERNMENT WELLS	94LA7250	566	0.140
1096	516	SOUTH MISSION	94SB3940	877	0.139
1097	330	MIDWAY LANE	97SA3440	58	0.138
1098	1041	AB VOGEL ST	97AB4405	597	0.137
1099	554	AIRLINE	94CS7390	2330	0.137
1100	497	HAMLIN	97AB3270	893	0.137
1101	587	CLYDE	97AB1755	132	0.136
1102	851	SOUTH MISSION	94SB3980	1937	0.136
1103	1092	MCCOLL ROAD	94SB4400	1288	0.134
1104	523	LA GRULLA	94SB3045	1211	0.132
1105	790	POWELL FIELD	97SA2528	23	0.130
1106	475	SHARYLAND	94SB2035	853	0.130
1107	479	MUNDAY	97AB3365	390	0.128
1108	745	PRIMERA	94SB5705	1260	0.128
1109	467	EDNA	94CN5765	1257	0.126
1110	1022	BAIRD	97AB5120	568	0.125
1111	1027	TEX/NEW MEX PIPELINE	97SA9045	16	0.125
1112	230	NORTH MCALLEN	94SB9640	1535	0.124
1113	1132	BALLINGER	97SA4395	534	0.124
1114	525	WASHINGTON STREET	94LA2470	481	0.123
1115	421	AB MAPLE ST	97AB5750	474	0.122
1116	1216	MAYBERRY	94SB3010	347	0.121
1117	158	ROCKPORT	94CS5950	555	0.121
1118	987	SA CONCHO	97SA1705	928	0.121
1119	1064	ROCHESTER	97AB3295	208	0.120
1120	1205	SIERRA VISTA	94LA9900	2515	0.119
1121	966	KARNES CITY	94CN2340	786	0.118
1122	776	VALADEZ	94CS2500	2570	0.118
1123	800	MCCOLL ROAD	94SB2810	2287	0.116

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
1124	1040	SA EMERSON ST	97SA4630	1236	0.116
1125	982	LA GRULLA	94SB6150	1735	0.115
1126	868	BRONTE	97SA3590	194	0.113
1127	263	KNOX CITY	97AB3300	459	0.113
1128	1269	BARNHART	97SA590	18	0.111
1129	547	AB HARTFORD ST	97AB3690	172	0.110
1130	1220	SA SOUTHLAND HILLS	97SA5055	857	0.110
1131	654	NORTH MCALLEN	94SB4995	2486	0.109
1132	965	ROMA	94SB3060	1619	0.107
1133	485	AB RAINEY CREEK	97AB4270	1422	0.107
1134	956	ARANSAS PASS	94CS660	723	0.107
1135	1078	POLK AVENUE	94SB4600	160	0.106
1136	551	SA NORTH	97SA3120	1136	0.106
1137	159	PERKINS PROTHO	97SA3180	19	0.105
1138	490	EAST HARRISON	94SB4620	776	0.104
1139	562	QUANAH	97AB3530	328	0.104
1140	570	ASPERMONT	97AB1070	329	0.103
1141	1163	AILEEN	97AB6435	852	0.102
1142	541	ASPERMONT	97AB3380	395	0.101
1143	515	GOODWIN	94SB7380	2094	0.101
1144	1283	KIRKLAND	97AB3545	30	0.100
1145	545	SA NORTH	97SA3130	231	0.100
1146	225	DEL MAR	94LA220	1470	0.099
1147	1006	PADUCAH CITY	97AB1930	574	0.099
1148	741	SINTON	94CS180	232	0.099
1149	747	HARLINGEN	94SB380	263	0.099
1150	1181	SOUTH MCALLEN	94SB3935	508	0.098
1151	567	SA CONCHO	97SA3325	295	0.098
1152	1213	SA SOUTH	97SA3500	562	0.098
1153	123	AB ELM CREEK	97AB4780	553	0.098
1154	258	ABILENE PLANT	97AB1910	246	0.098
1155	1046	PADUCAH CITY	97AB1935	289	0.097
1156	848	NORTH WESLACO	94SB4830	531	0.096
1157	401	SA SOUTH	97SA4255	866	0.096
1158	612	AB SHELTON ST	97AB3145	1051	0.095
1159	1039	CISCO	97AB1020	479	0.094
1160	52	RODD FIELD	94CS2190	96	0.094
1161	610	TWILIGHT TRAIL	97AB4285	1146	0.093
1162	1161	BRONTE	97SA3560	229	0.092
1163	1110	JOSLIN POWER PLANT	94CN7915	11	0.091
1164	1104	ZACATE CREEK	94LA2665	1727	0.091
1165	700	CISCO	97AB6530	538	0.089
1166	1145	AB ELM CREEK	97AB1810	831	0.088
1167	582	AB REBECCA LANE	97AB6915	1020	0.087
1168	437	ALBANY	97AB3640	335	0.087
1169	599	AB CANYON ROCK	97AB5025	58	0.086
1170	1200	SA MATHIS FIELD	97SA5100	316	0.085

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
1171	835	EDITH HUMBLE	97SA6170	83	0.084
1172	265	JAYTON	97AB6125	353	0.082
1173	1079	SOUTHSIDE	94CS5345	403	0.082
1174	262	ESCONDIDO	94LA1510	739	0.081
1175	672	AB MAPLE ST	97AB4070	1070	0.080
1176	627	KNOX CITY	97AB3985	25	0.080
1177	1114	SA JACKSON ST	97SA4685	1442	0.080
1178	505	PALMVIEW	94SB9680	1066	0.080
1179	1109	AB DYESS 1	97AB1775	881	0.079
1180	988	NORTH EDINBURG	94SB3810	1535	0.079
1181	1144	ROBERT LEE	97SA4120	549	0.078
1182	1087	DEL MAR	94LA2120	1346	0.078
1183	1155	SA AVENUE N	97SA1655	494	0.075
1184	743	ALICE	94LA1790	454	0.075
1185	690	PAISANO	97SAPAISAN	161	0.075
1186	1288	STEAMBOAT	97AB12515	68	0.074
1187	1243	HEINES	94CS8480	150	0.073
1188	808	ROBERT LEE	97SA4125	274	0.073
1189	1251	BENTSEN	94SBSH215	55	0.073
1190	794	MARFA	97SA1900	822	0.072
1191	791	ASHLAND	94SBSH301	14	0.071
1192	878	SA JACKSON ST	97SA4690	1122	0.071
1193	1117	CROWELL	97AB3980	471	0.070
1194	866	PEACOCK	97AB1375	43	0.070
1195	393	HEIGHTS	94LA9080	694	0.069
1196	1076	PHARR	94SB1650	898	0.069
1197	1201	AB EAST 12KV	97AB4830	1020	0.068
1198	583	SIERRA VISTA	94LA8205	1236	0.066
1199	588	GATEWAY	94LA5055	1893	0.064
1200	1232	SA WALNUT ST	97SA3915	722	0.064
1201	611	SA CONCHO	97SA1700	553	0.063
1202	284	CAUSEWAY	94SB4775	1069	0.062
1203	1123	KENEDY S.S.	94CN6750	65	0.062
1204	1187	RAYMONDVILLE #2	94SB4160	347	0.061
1205	711	GARCENO	94SB5490	1459	0.060
1206	1075	EDEN	97SA3195	533	0.060
1207	1189	SA SOUTH	97SA4795	1504	0.060
1208	1150	SIERRA VISTA	94LA7170	1455	0.058
1209	908	AB EAST 12KV	97AB4825	416	0.058
1210	1235	TRADE ZONE	94SB2220	70	0.057
1211	1231	AB ELM CREEK	97AB1825	214	0.056
1212	452	SHARYLAND	94SB2010	1165	0.056
1213	1252	UNITEC	94LA5895	36	0.056
1214	720	ABILENE PLANT	97AB1740	18	0.056
1215	111	MILES	97SA4670	395	0.053
1216	699	ANNA STREET	94LA5780	661	0.053
1217	553	CLOSNER	94SB7505	764	0.052

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
1218	1057	MORRIS STREET	94CS8850	411	0.051
1219	668	SA CONCHO	97SA1715	294	0.051
1220	620	VALERA HUMBLE	97SA7015	79	0.051
1221	613	AB REBECCA LANE	97AB2710	262	0.050
1222	1208	SPUR	97AB260	162	0.049
1223	1244	LAS CRUSES	94LA9865	448	0.049
1224	1226	RANKIN	97SA7425	123	0.049
1225	1276	BRYANTS RANCH	97SA205	21	0.048
1226	1141	AB REBECCA LANE	97AB5550	716	0.047
1227	1172	NEW BLUFFS	97SA7280	1581	0.047
1228	1028	MUNDAY	97AB2080	506	0.047
1229	1222	SANTO NINO	94LA695	1606	0.047
1230	1101	SIERRA VISTA	94LA7360	1713	0.047
1231	1214	SA SOUTHLAND HILLS	97SA5860	1193	0.045
1232	1210	AB ONYX REA	97AB3255	23	0.043
1233	1180	HIGHLAND	97SA6375	295	0.041
1234	628	AB HARTFORD ST	97AB3685	370	0.041
1235	1093	ABILENE PLANT	97AB1915	50	0.040
1236	296	HEINES	94CS3515	1307	0.040
1237	349	AB ELMDALE	97AB4520	283	0.039
1238	1169	CHILDRESS 69	97AB2800	342	0.038
1239	615	AB HARTFORD ST	97AB3820	927	0.036
1240	1257	SA CONCHO	97SA1725	29	0.034
1241	995	FLOMOT	97AB81335	29	0.034
1242	1056	ROCKSPRINGS	94LA8040	332	0.033
1243	1202	HAMLIN	97AB3775	246	0.033
1244	875	AIRLINE	94CS7270	1034	0.032
1245	365	ROTAN	97AB1865	193	0.031
1246	933	TALPA ATLANTIC	97SA5180	65	0.031
1247	1245	TAYLOR	94SBSH112	989	0.030
1248	NA	SONORA	97SAT000E2	498	0.030
1249	NA	LA PRYOR	94LA1835	266	0.030
1250	445	HAINE DRIVE	94SB9240	34	0.029
1251	1272	CROCKETT HEIGHTS	97SA73703	69	0.029
1252	972	MATADOR	97AB3090	315	0.029
1253	1073	ALPINE 12KV	97SA6820	775	0.028
1254	999	BRONTE	97SA4160	226	0.027
1255	1065	SA JACKSON ST	97SA4695	561	0.025
1256	706	ROCHESTER	97AB3290	82	0.024
1257	1230	COLLEGE HILLS	97SA4835	499	0.024
1258	1247	RUSSEK STREET	97SA12295	292	0.024
1259	557	SA SOUTH	97SA3990	757	0.024
1260	1124	WEINERT	97AB6490	129	0.023
1261	1183	SA AVENUE N	97SA1975	320	0.022
1262	1215	SANTO NINO	94LA645	840	0.021
1263	1284	TAYLOR	94SBSH114	626	0.021
1264	629	SOUTH MCALLEN	94SB3640	205	0.020

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
1265	928	HIGHLAND	97SA6380	478	0.019
1266	1036	EAST HARRISON	94SB3000	548	0.018
1267	1086	COTULLA	94LA110	55	0.018
1268	197	ESCONDIDO	94LA2035	444	0.018
1269	NA	QUINTANA	94CNT001Y8	58	0.017
1270	118	AB MAPLE ST	97AB5755	1220	0.016
1271	1199	PAINT ROCK	97SA1110	64	0.016
1272	399	UNIVERSITY	94LA305	759	0.014
1273	1100	EDEN	97SA1780	232	0.013
1274	986	ESCONDIDO	94LA3775	234	0.013
1275	1268	COLLEGE HILLS	97SA5515	201	0.010
1276	NA	MINES ROAD	94LA3745	2114	0.009
1277	301	SA JACKSON ST	97SA4250	336	0.009
1278	1273	ABILENE PLANT	97AB3175	122	0.008
1279	607	SIERRA VISTA	94LA3540	1154	0.008
1280	NA	STERLING CITY	97SA11040	544	0.007
1281	1089	NEW BLUFFS	97SA9110	818	0.006
1282	1289	MILES	97SA11330	171	0.006
1283	648	SA COKE ST	97SA4915	176	0.006
1284	53	IRAAN	97SA4305	251	0.004
1285	1237	NEW BLUFFS	97SA3005	314	0.003
1286	1249	BENTSEN	94SBSH211	375	0.003
1287	773	UNIVERSITY	94LA930	92	0.000
1288	1258	WASHINGTON STREET	94LA2330	60	0.000
1289	NA	MINES ROAD	94LA8770	310	0.000
1290	856	LAS CRUSES	94LA8530	80	0.000
1291	1267	VICTORIA POWER PLANT	94CNNETVIC	88	0.000
1292	1270	WASHINGTON STREET	94LANETLAR	163	0.000
1293	1280	WASHINGTON STREET	94LA6890	19	0.000
1294	1266	WASHINGTON STREET	94LA2310	46	0.000
1295	1262	MORRIS STREET	94CSNET CC	317	0.000
1296	1234	KENEDY	94CN1960	69	0.000
1297	1261	WASHINGTON STREET	94LA2320	34	0.000
1298	1263	AB WALNUT ST	97AB3250	11	0.000
1299	994	SANTA RITA	97SA1135	10	0.000
1300	128	GIRARD	97AB6260	43	0.000
1301	1246	AILEEN	97AB4600	270	0.000
1302	867	SANTA RITA	97SA1140	11	0.000
1303	635	ASPR CONTINENTAL	97AB3830	27	0.000
1304	1275	ABILENE INDUSTRIAL PARK	97AB6600	12	0.000

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
---------------------------	---------------------------	----------------------------------	------------------------------	----------------------------	-------------------------

Feeders from last year that are not in this year's list

2021 Ranking	Substation Identification	Feeder ID	Reason not in 2022
60	MASTERSON FIELD	97SA800	Count is now less than 10
625	HOEFFS ROAD	97SA15680	Count is now less than 10
1091	RIO PECOS	97SA513	Count is now less than 10

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

Total Number of Feeders

With 10 or more Customers

1304

Add or Delete Rows as Necessary

AEP Texas Inc.

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
1	62	RIO RICO	94SB8330	70	4,330.2
2	110	MINES ROAD	94LA7235	43	2,704.5
3	609	BERCLAIR	94CN990	26	2,308.2
4	774	MATHIS	94CS1410	472	1,655.6
5	588	RAYMONDVILLE #2	94SB3170	766	1,438.8
6	508	RIO RICO	94SB5050	290	1,321.2
7	138	LULING - LCRA	94CN10	452	1,267.8
8	103	CHERRY CREEK TAP	97SA485	53	1,261.3
9	369	RANDADO	94LA8360	163	1,256.8
10	540	PECOS VALLEY	97SA4080	237	1,225.8
11	55	MALONE	94CN7550	226	1,202.3
12	82	VERHALEN	97SA4460	70	1,158.8
13	496	TRENT	97AB2850	25	1,054.3
14	530	TAFT	94CS1260	200	996.2
15	22	FREER	94LA1500	201	983.4
16	66	BLESSING	94CN8780	58	978.3
17	1100	TWILIGHT TRAIL	97AB11500	1,050	916.1
18	24	CHARLOTTE	94LA2780	33	915.5
19	1031	SARAGOSA	97SA14080	48	908.8
20	270	RIO PECOS	97SA3835	103	901.3
21	367	KEMPER EXXON HUMBLE	97SA72103	26	877.3
22	176	THREE RIVERS	94CN8430	194	873.6
23	602	TATTON	94CS950	576	850.9
24	29	TATTON	94CN8490	293	842.4
25	NA	PROGRESO	94SB2545	90	841.5
26	15	MCELROY	97SA5165	95	837.1
27	289	CHILLICOTHE	97AB4525	119	834.3
28	920	SAND CRAB	94CN9235	386	810.4
29	NA	PECOS VALLEY	97SA9615	56	796.9
30	991	SAN BENITO	94SB4135	1,388	794.8
31	2	MCCAMEY	97SA2415	76	777.8
32	83	GREGORY	94CS5900	120	769.0
33	95	PREMONT	94LA6570	809	767.0
34	122	OZONA	97SA3555	157	755.5
35	594	ALPINE 12KV	97SA3875	105	750.4
36	841	SPUDDER FLAT	97SA4180	48	743.0
37	897	NORTH ALAMO	94SB4370	1,628	737.2
38	14	CRESTONIO	94LA270	641	732.6
39	46	GREENLAKE	94CN2740	381	704.2
40	161	MCCAMEY	97SA2830	97	703.5
41	1287	GOODLETT	97AB12205	48	698.0
42	28	BRUNI	94LA5440	129	693.0
43	84	SAN DIEGO	94LA2930	565	682.8
44	769	SAND ROAD	97AB5195	254	676.9

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
45	486	TYNAN	94CS1855	135	671.9
46	767	ASHERTON	94LA4175	82	669.9
47	325	PECOS VALLEY	97SA4075	21	668.6
48	1090	TYNAN	94CS4010	46	667.5
49	109	BAY CITY	94CN6670	1,615	664.2
50	63	ALAZAN	94CS620	179	652.1
51	772	NAVAL BASE	94CS7950	806	647.0
52	105	BRUNI	94LA1120	266	639.8
53	488	MATHIS	94CS340	1,418	632.1
54	531	INGLESIDE CITY	94CS8050	1,277	629.4
55	54	PREMONT	94LA2730	199	628.3
56	175	SAND CRAB	94CN8120	264	620.5
57	NA	BULL MOOSE	94CS4185	20	612.2
58	107	WADSWORTH	94CN8630	669	609.1
59	35	CABANISS	94CS615	266	605.3
60	552	KEPLER	94CS2665	37	605.0
61	76	CLARKWOOD	94CS5525	627	598.7
62	30	WEIL TRACT (138/12KV)	94CS1990	1,369	595.6
63	1041	FT CHADBOURNE	97SA6515	92	592.3
64	600	GANADO	94CN5795	489	583.5
65	254	SPUDDER FLAT	97SA4175	57	582.6
66	989	PUEBLO	94LA95	1,415	575.2
67	281	ARCADIA	94CS1440	1,662	573.1
68	978	CHILLICOTHE	97AB4530	506	572.9
69	953	FASHING	94CN360	34	557.8
70	89	WEST OSO	94CS9085	945	555.0
71	636	PORT ISABEL S.S.	94SB9295	2,515	549.1
72	86	GEORGE WEST	94CN1320	687	548.3
73	612	HIGHWAY 9	94CS6760	1,033	547.1
74	479	ELSA	94SB700	1,523	540.8
75	129	ZAPATA	94LA8300	1,613	537.5
76	18	OZONA	97SA4185	734	521.0
77	200	OZONA	97SA3810	1,172	520.7
78	163	CAMPWOOD	94LA2610	1,009	520.6
79	570	INGLESIDE CITY	94CS6040	429	517.4
80	6	CONOCO-CHITTAM RANCH	94LA8580	26	516.9
81	152	NORTH PADRE ISLAND	94CS720	1,402	514.2
82	809	ALICE	94LA1770	1,657	510.6
83	778	ROBY	97AB3795	76	507.6
84	474	UNITEC	94LA3085	114	503.7
85	456	RIO BRAVO	94LA1130	1,071	503.3
86	198	GOVERNMENT WELLS	94LA7240	229	503.2
87	0	RAYMONDVILLE #2	94SB3250	28	503.2
88	32	SHROPSHIRE	94CN1240	73	501.6
89	362	LA PRYOR	94LA570	171	500.2
90	113	PLACEDO	94CN7970	490	485.8
91	40	SARAGOSA	97SA1590	49	483.0
92	218	ODEM	94CS385	567	477.9
93	1277	STAFFORD HILL	94CN9955	85	476.0

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
94	425	NORTH MERCEDES	94SB3840	710	467.0
95	187	FOSTER FIELD	94CN2550	66	465.1
96	199	CALLICOATTE	94CS8785	1,193	463.2
97	164	RIO BRAVO	94LA5	713	461.7
98	741	WEIL TRACT (138/12KV)	94CS2520	83	461.6
99	174	EAGLE LAKE	94CN9455	609	460.3
100	72	THREE RIVERS	94CN5100	76	460.0
101	384	NORTH PADRE ISLAND	94CS5170	870	459.3
102	1179	PLASTERCO (MWEC)	97AB2720	117	457.1
103	9	O CONNER	94CN390	200	449.9
104	93	MOORE FIELD	94SB3120	151	446.9
105	1101	CASA BLANCA	94CS5440	109	446.4
106	998	SAN YGNACIO	94LA16060	539	445.4
107	85	MAYBERRY	94SB3160	558	443.5
108	737	KNIPPA	94LA6535	22	438.1
109	123	PARKER	94CN9010	21	435.6
110	862	POLK AVENUE	94SB4170	1,466	435.3
111	733	BLACK CAT	94CN3175	495	433.1
112	19	GREGORY	94CS5920	765	432.6
113	301	FREISS RANCH	97SA4870	100	429.9
114	867	ROUNDTOP	97AB4490	54	426.1
115	618	MESQUITE	94SB3360	1,023	423.3
116	1076	HOLLY	94CS1220	3,401	422.1
117	629	POLK AVENUE	94SB4900	1,915	420.7
118	157	DILLEY	94LA3795	103	413.7
119	471	MALONE	94CN7560	58	412.4
120	623	GARWOOD CITY	94CN2560	201	412.4
121	149	ELSA	94SB3520	1,011	411.2
122	440	FALFURRIAS	94LA5210	1,177	407.8
123	165	BLESSING	94CN1030	285	406.7
124	1130	COMSTOCK	94LA230	183	404.9
125	37	PLACEDO	94CN7980	425	404.2
126	33	PRAIRIE PUMP	94CN1940	91	403.7
127	111	PORT ARANSAS	94CS6940	1,635	403.6
128	34	WEIL TRACT (138/12KV)	94CS5405	178	403.5
129	1124	ROBY	97AB2276	333	401.6
130	114	SHROPSHIRE	94CN3575	34	399.8
131	343	PUTNAM	97AB2129	201	396.5
132	248	HAROLD	97AB3055	27	389.4
133	864	TAFT	94CS5230	832	385.3
134	121	MAYO	94CS625	208	384.5
135	344	YORKTOWN	94CN3130	492	383.2
136	136	WADSWORTH	94CN7660	1,476	382.5
137	665	FULTON	94CS2020	3,551	381.3
138	466	PORTLAND	94CS9290	1,790	380.7
139	729	POWELL FIELD	97SA2529	13	380.3
140	41	ALBANY	97AB2029	241	379.6
141	697	MELVIN	97SA940	46	378.0
142	701	SAN BENITO	94SB4945	1,732	375.3

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
143	854	STAMFORD	97AB2815	706	374.6
144	112	SINTON	94CS6860	1,007	371.7
145	401	RACHAL	94LA8145	376	371.4
146	61	ELSA	94SB3500	1,332	371.0
147	233	MATHIS	94CS2870	870	369.0
148	155	AB RAINEY CREEK	97AB4225	122	368.0
149	495	SOUTH PADRE ISLAND	94SB4695	1,378	366.5
150	208	CONTINENTAL	94SB4880	69	365.0
151	153	PAWNEE (STEC OWNED)	94CN22202	197	364.4
152	65	GREGORY	94CS8560	255	362.8
153	236	MATTHEWS	94CN1740	164	362.5
154	106	HIGHWAY 9	94CS6770	925	361.1
155	238	ALICE	94LA2530	1,502	361.0
156	621	FREER	94LA6320	162	361.0
157	177	DEL RIO CITY	94LA1930	1,564	359.9
158	445	HALL ACRES ROAD	94SB5585	1,623	359.2
159	951	LEARY LANE	94CN1430	1,915	358.9
160	115	WEST HARLINGEN	94SB3720	1,309	358.2
161	100	MCKENZIE ROAD	94CS140	296	356.5
162	408	HEARN ROAD	94CS8990	1,360	356.2
163	183	HOLLY	94CS1480	1,704	354.6
164	523	SOUTHSIDE	94CS5335	1,533	353.4
165	127	BAY CITY	94CN7480	380	352.9
166	417	BAY CITY	94CN2700	1,078	352.7
167	NA	BULL MOOSE	94CS5875	66	352.4
168	814	LOS FRESNOS	94SB7270	2,376	350.8
169	206	DEL RIO CITY	94LA430	2,069	349.7
170	NA	LA PRYOR	94LA1845	223	349.7
171	635	NORTH MERCEDES	94SB4860	1,504	345.6
172	232	ODEM	94CS375	631	343.3
173	604	TUSCOLA	97AB3305	1,234	341.3
174	192	ARANSAS PASS	94CS590	459	340.9
175	536	PHARR	94SB1620	1,243	338.9
176	166	VALENTINE	97SA5590	208	338.0
177	202	EL CAMPO	94CN2800	841	337.6
178	172	ELSA	94SB710	2,369	337.5
179	117	BANQUETTE	94CS9000	462	335.0
180	321	HIGHWAY 9	94CS7210	349	334.3
181	50	HAROLD	97AB1495	25	333.4
182	346	PICACHO	94LA630	378	332.4
183	366	LOS FRESNOS	94SB2160	1,863	331.8
184	178	EDROY	94CS6990	294	331.2
185	284	HIDALGO	94SB4845	1,411	331.0
186	688	LIVE OAK	94CS1080	2,555	329.1
187	52	PALACIOS	94CN6830	838	328.3
188	454	LOS FRESNOS	94SB4315	1,264	327.4
189	560	PUEBLO	94LA275	2,910	326.8
190	1139	EAGLE PASS CITY	94LA2745	934	326.8
191	738	SONORA 138 SUB	97SA4810	876	326.8

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
192	527	BARNHART	97SA3725	135	325.4
193	306	WEST HARLINGEN	94SB3700	1,876	324.4
194	39	ZAPATA	94LA2710	1,346	324.1
195	627	PALMVIEW	94SB6790	2,557	323.4
196	314	CHARLOTTE	94LA2790	201	323.1
197	655	VILLA CAVAZOS	94SB7615	1,121	321.6
198	75	MORRIS STREET	94CS8820	1,249	319.6
199	403	SANTA ANNA	97SA3415	343	317.1
200	528	ARANSAS PASS	94CS8280	619	315.4
201	17	RANDADO	94LA8350	136	315.2
202	43	INDIAN MESA	97SA2695	92	314.7
203	221	FALFURRIAS	94LA2830	1,529	313.7
204	513	PREMONT	94LA6610	834	312.4
205	119	PORT ISABEL S.S.	94SB3760	782	311.5
206	491	EAGLE PASS CITY	94LA2770	2,023	310.9
207	96	PALACIOS	94CN8550	84	309.2
208	439	RODD FIELD	94CS225	2,913	306.4
209	142	SOUTHSIDE	94CS7925	1,160	303.8
210	307	MATHIS	94CS1420	911	303.6
211	141	PIRATE	94CS3380	421	303.4
212	569	EOLA	97SA4950	211	301.3
213	894	VICTORIA POWER PLANT	94CN1390	1,092	301.2
214	249	CLARKWOOD	94CS7230	624	300.6
215	205	MAGNOLIA	94CN315	84	299.4
216	476	LYTLE	94LA2850	757	298.9
217	97	RAYMONDVILLE #1	94SB630	792	298.6
218	354	INGLESIDE CITY	94CS8060	2,680	293.3
219	345	PORTLAND	94CS9370	2,100	291.0
220	104	CAUSEWAY	94SB4765	619	290.6
221	372	EDROY	94CS6980	195	289.3
222	313	ASPHALT MINES	94LA500	43	285.8
223	180	PALMHURST	94SB3890	1,864	281.2
224	923	MINES ROAD	94LA1600	1,218	278.7
225	704	LEARY LANE	94CN1540	793	278.1
226	167	CROSS PLAINS	97AB2920	552	277.8
227	721	BRADY	97SA5015	201	276.1
228	397	PARKER	94CN9260	126	275.9
229	70	COFFEE PORT	94SB1095	1,080	275.6
230	392	WOODSON OIL FIELD	97AB30	33	275.0
231	57	SUNCHASE	94SB1150	1,422	275.0
232	124	VALENTINE	97SA6325	550	274.6
233	601	LOLITA	94CN6330	30	274.2
234	443	PALMHURST	94SB2820	1,870	273.7
235	649	NORTH VICTORIA	94CN7770	829	273.4
236	516	PUEBLO	94LA9870	1,463	272.9
237	332	LULING - LCRA	94CN20	278	271.6
238	51	EAGLE PASS CITY	94LA450	886	270.4
239	316	DARST	94CN1265	75	269.5
240	1069	HALL ACRES ROAD	94SB5465	1,443	268.6

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
241	436	HIDALGO	94SB3400	891	265.8
242	130	MCCAMEY	97SA2420	82	265.5
243	261	PORT ARANSAS	94CS990	2,661	264.9
244	209	PORT ISABEL S.S.	94SB3820	175	264.8
245	330	SEAWALL	94CS9325	1,584	263.6
246	98	BRUNI	94LA1100	602	262.3
247	150	GARWOOD CITY	94CN2570	145	261.9
248	290	THREE RIVERS	94CN5190	475	261.6
249	231	ARCADIA	94CS1450	1,638	259.8
250	1253	TRADE ZONE	94SB1935	41	259.5
251	515	SOUTHSIDE	94CS7995	1,551	259.4
252	NA	HAISLEY	94CSTX_2_B	9	258.6
253	934	SOUTH PADRE ISLAND	94SB5850	1,374	258.5
254	291	INDIAN MESA	97SA2690	146	257.9
255	643	VERNON CITY PLANT	97AB5770	94	257.8
256	1059	MELVIN	97SA4955	82	253.9
257	761	ARCADIA	94CS6930	1,480	253.6
258	140	NAVAL BASE	94CS9720	2,657	253.2
259	836	GANADO	94CN5815	601	252.5
260	337	PICACHO	94LA590	397	252.1
261	328	SKIDMORE	94CS380	159	251.6
262	243	NORTH ALAMO	94SB3610	1,999	251.4
263	509	OLMITO	94SB715	673	250.7
264	420	WOODSBORO	94CS8330	298	250.4
265	162	ELDORADO	97SA1845	538	250.0
266	882	PLEASANTON	94LA9505	1,775	249.0
267	196	BRACKETTVILLE	94LA8460	1,201	249.0
268	273	KEPLER	94CS1700	27	248.3
269	1264	SWENSON	97AB136	31	248.2
270	489	BEN FICKLIN	97SA6185	755	244.0
271	211	RIO RICO	94SB8290	309	243.4
272	1023	RIO BRAVO	94LA300	803	242.0
273	275	WOOLRIDGE	94CS1170	439	241.6
274	390	LA PRYOR	94LA580	334	240.6
275	810	MERTZON (CVEC)	97SA2905	592	240.5
276	802	BLACK CAT	94CN3000	1,646	240.0
277	958	PIRATE	94CS3490	378	238.6
278	374	GOLIAD	94CN6540	1,244	238.2
279	240	LIVE OAK	94CS1090	299	236.8
280	297	CASA BLANCA	94CS55	871	236.4
281	1093	GONZALES	97SA15390	1,098	235.5
282	128	SABINAL	94LA485	498	235.1
283	696	BOBCAT HILLS	97SA6655	73	235.1
284	924	BEN FICKLIN	97SA14065	793	234.5
285	329	SOUTH SANTA ROSA	94SB1235	648	232.9
286	409	SOUTHSIDE	94CS8055	848	232.5
287	996	BLACK CAT	94CN2960	2,121	230.5
288	280	FLOMOT	97AB1852	75	230.0
289	264	FALFURRIAS	94LA1080	463	229.1

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
290	191	CABANISS	94CS75	2,243	228.5
291	118	HOLCOMB	94LA3025	371	228.3
292	1234	AB ELM CREEK	97AB1820	100	226.7
293	606	WESLACO UNIT	94SB7630	2,641	226.7
294	801	MORRIS STREET	94CS5655	316	226.4
295	230	DEL RIO CITY	94LA420	2,051	225.6
296	993	NORTH VICTORIA	94CN7860	1,510	225.3
297	945	MAGRUDER	94CN7870	1,262	225.2
298	197	WESMER	94SB4480	1,136	223.1
299	565	CRESTONIO	94LA260	1,780	222.5
300	90	NORTH MERCEDES	94SB3770	1,844	221.8
301	272	CAUSEWAY	94SB9880	1,229	219.8
302	10	DUNE FIELD (N CRANE)	97SA3885	69	218.6
303	708	NORTH PADRE ISLAND	94CS7900	2,346	218.5
304	12	LOS FRESNOS	94SB5335	2,708	215.7
305	220	WESMER	94SB1850	485	214.9
306	186	RISING STAR	97AB5080	622	214.6
307	1055	RESACA	94SB9975	561	214.5
308	753	FULTON	94CS440	2,074	214.4
309	135	HASKELL 12KV	97AB3495	826	214.0
310	1095	JOSLIN POWER PLANT	94CN8720	24	213.5
311	785	WOOLRIDGE	94CS1110	1,650	212.8
312	526	MAVERICK	94LA9680	843	212.6
313	559	MOCKINGBIRD	94CN370	49	212.3
314	1166	EAST HARRISON	94SB3080	472	212.2
315	407	HIDALGO	94SB3680	334	210.7
316	235	BIG OAK	94CN420	341	210.1
317	181	FREER	94LA2900	164	208.5
318	835	THOMASTON	94CN9580	49	206.2
319	919	NORTH ALAMO	94SB3580	1,023	204.6
320	102	SOUTHSIDE	94CS8045	970	203.0
321	1145	MAYBERRY	94SB5770	924	201.9
322	81	FOSTER FIELD	94CN8880	294	200.7
323	965	TURKEY	97AB2980	333	200.4
324	303	NORTH PADRE ISLAND	94CS1010	2,394	200.4
325	595	CITRUS CITY	94SB5070	1,022	200.1
326	521	GOODWIN	94SB4390	413	199.9
327	342	WESLACO UNIT	94SB5970	2,047	199.8
328	534	WEST OSO	94CS9090	1,672	199.0
329	428	BLESSING	94CN8790	761	198.9
330	542	CARANCAHUA	94CN5870	472	198.6
331	661	HARLINGEN SWITCH	94SB320	1,686	197.7
332	450	ARCADIA	94CS8570	1,448	197.2
333	961	IRAAN	97SA2055	135	197.0
334	850	BROOKHOLLOW	94CN7580	500	195.7
335	NA	PROGRESO	94SB2515	210	195.3
336	156	OLMITO	94SB4275	818	195.3
337	664	SAN BENITO	94SB3920	1,651	195.2
338	506	CHOKE CANYON	94CN9255	367	194.3

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
339	628	GREENLAKE	94CN2750	73	193.1
340	1017	POLK AVENUE	94SB4610	155	193.1
341	215	SOUTH SANTA ROSA	94SB1215	1,717	193.0
342	58	PAULANN	97SA6285	69	192.8
343	214	PHARAOH	94CS1285	1,776	192.6
344	779	SHAFTER	97SA5110	47	192.4
345	45	FREER	94LA5200	1,013	192.1
346	NA	DARST	94CN1610	66	191.2
347	766	EL GATO	94SB780	2,161	190.5
348	776	RUNGE	94CN3250	273	189.6
349	709	SOUTHSIDE	94CS8025	1,147	188.7
350	845	VERNON	97AB4275	593	186.8
351	819	EL GATO	94SB910	2,605	186.6
352	1187	HIGHLAND	97SA6370	270	185.9
353	616	NIXON	94CN3300	594	185.6
354	1221	WEST MCALLEN	94SB4815	568	185.5
355	453	CRYSTAL CITY	94LA1425	1,193	185.0
356	1185	UNIVERSITY	94LA950	1,737	184.6
357	790	HOLLY	94CS7740	2,209	183.9
358	413	CHARLOTTE	94LA8120	240	183.4
359	94	EAGLE PASS CITY	94LA2510	709	183.4
360	499	HEARN ROAD	94CS8980	1,255	182.5
361	1033	NORTH MCALLEN	94SB3830	1,415	181.8
362	520	HAINE DRIVE	94SB9690	633	180.4
363	580	EAGLE LAKE	94CN310	740	180.2
364	550	CHASE FIELD	94CN460	17	180.2
365	1005	HAWLEY	97AB4455	672	180.1
366	229	BROWNSVILLE	94SB3050	2,010	179.4
367	490	PLEASANTON	94LA2080	1,742	179.2
368	745	VALADEZ	94CS9890	1,908	179.1
369	283	PALMVIEW	94SB3930	1,163	178.9
370	77	CONTINENTAL	94SB4080	66	178.7
371	537	WESMER	94SB9705	938	178.5
372	64	BIG WELLS	94LA1570	430	178.3
373	376	BISHOP	94CS7180	929	177.4
374	182	VILLA CAVAZOS	94SB1980	1,834	177.3
375	385	PLEASANTON	94LA9475	1,367	177.2
376	400	HIGHWAY 9	94CS6720	1,275	176.7
377	662	AB SHELTON ST	97AB3435	295	175.8
378	969	HIGHWAY 9	94CS6730	546	175.4
379	549	HAINE DRIVE	94SB9700	1,166	175.1
380	728	KNIPPA	94LA6365	338	174.8
381	293	EAST HARRISON	94SB3950	788	174.4
382	503	NORTH WESLACO	94SB4810	1,522	174.2
383	1126	THREE RIVERS	94CN2010	313	174.0
384	430	PALMHURST	94SB2530	2,755	173.7
385	710	MILO	94LA3070	1,966	173.0
386	1265	HAMLIN SHELL	97AB6330	26	172.7
387	429	PALACIOS	94CN6840	1,540	172.0

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
388	690	PUTNAM	97AB2131	123	172.0
389	1009	DILLEY	94LA510	560	170.1
390	302	VICTORIA POWER PLANT	94CN7600	164	169.9
391	1094	ABILENE PLANT	97AB1575	608	169.8
392	1216	TRUSCOTT	97AB3845	31	169.0
393	853	WAGGONER	97AB5900	27	168.9
394	869	HARLINGEN SWITCH	94SB4230	1,362	167.2
395	735	SA MATHIS FIELD	97SA4790	194	166.3
396	1014	JOURDANTON	94LA250	770	166.3
397	492	MERKEL	97AB1895	709	165.7
398	1064	GATEWAY	94LA3595	1,503	165.6
399	23	BONNIEVIEW	94CS8020	544	165.6
400	395	ELDORADO	97SA2880	354	165.2
401	1282	MAYBERRY	94SB5340	39	164.7
402	173	GRAYBACK	97AB3315	46	164.7
403	213	BEEVILLE	94CN8090	1,386	164.6
404	268	PAULANN	97SA6280	331	164.0
405	700	MCCOLL ROAD	94SB4910	335	163.8
406	212	HARLINGEN SWITCH	94SB4090	2,347	163.7
407	529	KNOX CITY	97AB3390	380	163.6
408	204	BEEVILLE	94CN1760	1,838	163.1
409	1121	CHRISTOVAL	97SA6615	460	163.0
410	442	CLARKWOOD	94CS9570	1,234	162.8
411	900	POLK AVENUE	94SB4180	1,298	162.7
412	1022	ALPINE 12KV	97SA3160	1,642	162.1
413	1120	SA NORTH	97SA3125	1,387	161.9
414	323	WEST MCALLEN	94SB6385	243	161.1
415	451	BENTSEN	94SBSH115	342	160.9
416	469	STERLING CITY	97SA1445	381	160.5
417	744	PHARR	94SB1640	1,456	160.2
418	941	CROSS PLAINS	97AB1795	434	159.1
419	533	CABANISS	94CS240	1,408	157.8
420	730	GOODWIN	94SB4380	1,668	157.1
421	437	MORRIS STREET	94CS7465	743	157.1
422	922	WESLACO UNIT	94SB7455	1,235	156.7
423	226	RISING STAR	97AB5075	688	156.1
424	974	POLK AVENUE	94SB4190	1,726	155.4
425	943	RIO GRANDE CITY	94SB3230	2,702	155.3
426	179	GREENLAKE	94CN2760	1,189	155.0
427	985	FT CHADBOURNE	97SA6520	553	154.8
428	829	MORRIS STREET	94CS2515	1,017	154.8
429	189	PLEASANTON	94LA120	1,233	154.0
430	247	TAFT	94CS1180	957	153.9
431	381	UVALDE	94LA540	1,969	153.2
432	1176	STADIUM	94LA7800	686	152.8
433	398	DEVINE	94LA7090	1,070	152.4
434	336	SOUTH SANTA ROSA	94SB1225	867	152.2
435	917	BISHOP	94CS2690	641	152.1
436	257	BROWNSVILLE	94SB4290	492	151.6

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
437	286	HARLINGEN SWITCH	94SB4110	912	150.6
438	908	CLYDE	97AB1760	464	150.5
439	1020	SILVER	97SA4295	15	150.3
440	1082	SAND CRAB	94CN6800	1,126	149.4
441	379	LAGUNA	94CS9590	2,325	149.4
442	16	MESA VIEW	97SA7045	93	147.7
443	224	BEEVILLE	94CN8510	828	147.6
444	856	JUNCTION	97SA10805	816	147.1
445	427	CITRUS CITY	94SB3470	1,776	146.6
446	348	CROSS PLAINS	97AB2915	779	146.6
447	441	MUSTANG ISLAND	94CS8510	516	146.4
448	573	LIVE OAK	94CS1070	2,568	145.8
449	808	THROCKMORTON	97AB2090	75	144.8
450	909	SOUTH EAST EDINBURG	94SB4550	727	144.7
451	797	FRIO	94LA2270	990	144.6
452	613	VICTORIA POWER PLANT	94CN8170	842	144.5
453	859	PHARR	94SB1625	1,210	144.2
454	555	UVALDE	94LA6620	2,158	144.0
455	1016	ALPINE 12KV	97SA3155	1,357	143.6
456	823	PICACHO	94LA1230	1,052	143.3
457	73	HOLLY	94CS7620	2,703	142.9
458	207	PORT ARANSAS	94CS1000	1,611	142.6
459	967	WEST MCALLEN	94SB4505	1,908	141.2
460	1099	RUSSEK STREET	97SA250	143	140.5
461	863	ROBSTOWN	94CS1650	354	140.4
462	262	BROWNSVILLE	94SB4280	325	139.9
463	677	SOUTH SANTA ROSA	94SB7485	1,235	139.0
464	927	NORDHEIM	94CN3380	174	138.9
465	670	WESMER	94SB4050	1,954	138.6
466	653	LAREDO PLANT	94LA8695	1,551	138.5
467	658	SANTO NINO	94LA515	1,174	138.4
468	352	CARRIZO SPRINGS	94LA910	872	138.4
469	742	MCCOLL ROAD	94SB4780	2,021	137.8
470	455	CRYSTAL CITY	94LA8380	1,340	137.5
471	460	STADIUM	94LA7810	1,324	137.4
472	331	NORTH MCALLEN	94SB2980	1,885	137.2
473	245	DEVINE	94LA8100	1,647	136.5
474	126	CAMPWOOD	94LA3430	123	136.5
475	168	SONORA 138 SUB	97SA4805	347	135.8
476	771	DEVINE	94LA7100	1,118	135.5
477	410	BAIRD	97AB5125	511	134.4
478	415	AIRLINE	94CS7280	645	134.0
479	775	SAN BENITO	94SB4030	1,707	133.9
480	1053	MCCOLL ROAD	94SB4790	2,088	133.9
481	798	BEEVILLE	94CN300	1,676	132.4
482	350	LAGUNA	94CS9065	2,373	132.1
483	816	TYNAN	94CS4000	27	131.7
484	889	PHARAOH	94CS5185	1,244	131.6
485	1060	HALL ACRES ROAD	94SB8870	2,509	131.5

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
486	418	SOUTHSIDE	94CS8035	1,086	131.3
487	566	SINTON	94CS1750	266	130.7
488	1028	RODD FIELD	94CS205	2,184	130.5
489	21	BAY CITY	94CN5960	402	129.8
490	36	BLACK BAYOU	94CN1120	371	129.0
491	678	CLYDE	97AB3635	454	128.6
492	885	HAINE DRIVE	94SB8065	1,368	127.4
493	1155	MATADOR	97AB3030	217	126.6
494	541	JOURDANTON	94LA7880	593	126.0
495	746	MUNDAY	97AB6715	257	125.7
496	271	KARNES CITY	94CN2315	1,026	125.5
497	154	CAUSEWAY	94SB4795	390	125.3
498	1134	PANTERA	94SB1315	1,921	124.6
499	930	MAGRUDER	94CN7690	542	124.1
500	327	MORRIS STREET	94CS8715	1,587	123.8
501	414	DIMMIT	94LA4120	1,277	123.1
502	557	AMISTAD DAM	94LA5450	782	123.0
503	590	HIGHWAY 9	94CS9830	133	122.2
504	494	EL GATO	94SB720	2,571	122.1
505	1015	SA NORTH	97SA3115	586	121.9
506	754	CHRISTOVAL	97SA6620	655	121.2
507	1116	HEINES	94CS7875	1,951	120.6
508	423	HOLLY	94CS9675	1,776	120.2
509	304	POINT COMFORT	94CN6060	369	120.1
510	603	PECAN BAYOU	97AB6815	2,092	120.1
511	1046	RUSSEK STREET	97SA7705	1,331	119.7
512	139	PETTUS	94CN1020	456	119.5
513	1250	MORRIS STREET	94CSBLACK	82	119.4
514	1024	BUENA VISTA	94LA9035	2,048	119.3
515	396	FULTON	94CS3070	1,589	119.0
516	169	ARMSTRONG	94CS6050	85	118.7
517	308	YORKTOWN	94CN8420	669	118.5
518	470	TUSCOLA	97AB3730	1,215	118.4
519	683	KINGSVILLE	94CS1660	1,981	118.2
520	749	ANSON 12KV	97AB6635	414	117.5
521	193	MCCAMEY	97SA2855	508	117.4
522	158	GOLIAD	94CN8220	1,056	116.7
523	543	AB ELM CREEK	97AB4745	902	116.0
524	69	PORTLAND	94CS6505	1,826	115.8
525	190	VILLA CAVAZOS	94SB5680	1,983	115.6
526	144	GARCENO	94SB2130	1,821	115.5
527	946	EL GATO	94SB890	3,108	115.3
528	225	KINGSVILLE	94CS1130	2,226	115.2
529	1043	MCKENZIE ROAD	94CS150	26	115.2
530	968	SA GRAPE CREEK	97SA5220	716	114.6
531	684	ROCKPORT	94CS5930	944	114.6
532	276	BANQUETTE	94CS130	231	114.4
533	504	ARCADIA	94CS1400	443	114.2
534	673	NORTH VICTORIA	94CN7430	1,685	114.2

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
535	982	ARANSAS PASS	94CS650	1,192	113.8
536	685	AB ONYX REA	97AB3260	148	113.8
537	1106	SA SOUTHLAND HILLS	97SA5455	1,428	113.6
538	1004	AB SHELTON ST	97AB3660	638	113.1
539	223	BUENA VISTA	94LA8965	919	113.0
540	607	CHARLOTTE	94LA1960	506	112.8
541	1254	MORRIS STREET	94CSYELLOW	44	112.5
542	674	EAST HARRISON	94SB4310	1,205	112.4
543	1278	MORRIS STREET	94CSGREEN	235	112.3
544	964	FT DAVIS	97SA4515	1,013	111.5
545	936	ABILENE PLANT	97AB1570	959	111.4
546	1271	MORRIS STREET	94CSRED	148	111.1
547	507	KENEDY S.S.	94CN8340	307	110.0
548	918	KITTIE WEST	94CN3760	240	109.9
549	452	LA PRYOR	94LA2440	194	109.8
550	483	NAVAL BASE	94CS8540	1,624	109.4
551	1135	AFTON	97AB2310	246	109.3
552	282	COTULLA	94LA460	502	108.7
553	740	MORRIS STREET	94CS7625	513	108.7
554	353	SOUTH MISSION	94SB3620	2,110	108.3
555	1182	ANSON 12KV	97AB6630	718	108.1
556	60	GOVERNMENT WELLS	94LA6800	230	107.9
557	1191	UNITEC	94LA4715	40	107.9
558	581	KINGSVILLE	94CS1670	426	107.9
559	799	AIRLINE	94CS9605	713	107.6
560	605	HASKELL 12KV	97AB3770	459	107.5
561	620	KLEBERG	94CS1560	1,472	107.4
562	1087	MILO	94LA8365	2,123	107.3
563	501	SOUTHSIDE	94CS7905	1,828	107.1
564	333	SA LAKE DR	97SA6030	761	106.9
565	838	REFUGIO	94CN1210	190	106.7
566	47	BANDERA ELECTRIC (LEAKEY)	94LAL30	271	106.6
567	216	FULTON	94CS9050	1,576	106.1
568	1210	SOUTH MCALLEN	94SB5065	175	105.9
569	713	DEL RIO CITY	94LA9850	1,037	104.5
570	789	BEN FICKLIN	97SA6175	599	104.2
571	788	AIRLINE	94CS8260	1,421	104.0
572	564	HARLINGEN SWITCH	94SB5350	965	103.7
573	871	HEIGHTS	94LA6820	1,944	103.7
574	525	WEST OSO	94CS9095	1,659	103.6
575	830	HAINE DRIVE	94SB3490	1,193	103.5
576	1274	MORRIS STREET	94CSBROWN	67	103.4
577	1201	HASKELL 12KV	97AB5240	650	103.3
578	67	EAGLE LAKE	94CN320	629	103.3
579	444	ARCADIA	94CS1460	2,455	103.3
580	1103	AFTON	97AB2355	45	103.0
581	88	AIRLINE	94CS5870	1,008	102.9
582	485	BUENA VISTA	94LA9385	892	102.8
583	619	RODD FIELD	94CS1730	2,211	102.8

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
584	78	WEST HARLINGEN	94SB3800	1,423	102.2
585	71	PAULANN	97SA6310	1,086	102.2
586	448	NIXON	94CN2025	539	102.1
587	1006	LAREDO PLANT	94LA8505	1,053	101.5
588	31	AFTON	97AB2225	54	101.0
589	255	TURKEY	97AB3825	388	100.6
590	510	HAMILTON ROAD	94LA9665	1,258	100.4
591	309	LEARY LANE	94CN7530	3,171	100.2
592	1281	MAYBERRY	94SB6450	28	99.8
593	1260	VICTORIA POWER PLANT	94CNVGREEN	29	99.4
594	591	SOUTHSIDE	94CS7955	1,067	99.2
595	185	RACHAL	94LA6595	339	99.0
596	217	RULE	97AB3396	440	99.0
597	672	RULE	97AB3378	106	98.8
598	1096	THROCKMORTON	97AB3190	645	98.6
599	893	DEL RIO CITY	94LA440	1,115	98.6
600	203	COFFEE PORT	94SB1090	1,257	97.9
601	1208	ARANSAS PASS	94CS8270	412	97.5
602	592	LANTANA	94CS7150	271	97.5
603	699	ARANSAS PASS	94CS1250	661	97.4
604	929	HEARN ROAD	94CS9665	690	96.9
605	171	SABINAL	94LA200	443	96.8
606	1058	AB ELM CREEK	97AB4775	886	96.8
607	538	NORTH VICTORIA	94CN6390	1,510	96.7
608	1019	GATEWAY	94LA390	3,743	96.7
609	757	SOUTH SANTA ROSA	94SB1240	1,704	96.5
610	1	SANTA RITA	97SA1100	110	96.3
611	705	CITRUS CITY	94SB6000	2,373	96.3
612	1085	DEL RIO CITY	94LA9790	2,357	96.2
613	576	REFUGIO	94CN1040	161	95.3
614	632	WEST HARLINGEN	94SB4870	1,072	95.2
615	260	WEAVER ROAD	94CN1900	63	94.9
616	679	JOURDANTON	94LA880	1,121	94.8
617	911	DEL MAR	94LA490	797	94.7
618	228	EAST HARRISON	94SB3190	1,489	93.8
619	386	PEARSALL	94LA9905	435	93.3
620	1175	ANNA STREET	94LA780	474	93.3
621	274	SUN VALLEY	97SA4300	69	93.3
622	263	ESCONDIDO	94LA3350	2,283	93.0
623	237	UVALDE	94LA480	572	92.8
624	1118	DEL MAR	94LA3440	1,807	92.8
625	1115	BROOKHOLLOW	94CN7190	280	92.3
626	299	WEST MCALLEN	94SB4555	1,619	92.2
627	258	HAINE DRIVE	94SB270	1,172	91.9
628	419	ASHERTON	94LA5495	597	91.5
629	676	SAN DIEGO	94LA2890	1,019	91.0
630	1212	AB SHELTON ST	97AB4640	663	90.7
631	1114	WESLACO UNIT	94SB2195	1,102	90.1
632	484	HALL ACRES ROAD	94SB3670	1,292	89.9

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
633	1231	BALLINGER	97SA4375	1,130	89.7
634	715	WEST MCALLEN	94SB4595	1,190	89.7
635	914	READING	94LA1275	78	89.7
636	477	ALBANY	97AB3540	635	88.8
637	932	ALAZAN	94CS2740	36	88.2
638	582	GRETA	94CN7890	235	87.5
639	131	PHARAOH	94CS5175	1,284	87.3
640	1159	AB EAST 12KV	97AB4820	1,152	87.3
641	891	ABILENE PLANT	97AB1565	280	86.9
642	438	PANTERA	94SB1105	580	86.5
643	383	PHARAOH	94CS1185	1,414	86.4
644	412	RAYMONDVILLE #1	94SB3130	307	86.4
645	553	AIRLINE	94CS8370	274	85.7
646	1244	NORTH MCCAMEY	97SA6555	795	85.4
647	355	CASA BLANCA	94CS1300	291	85.2
648	1286	DONNA SKID	94SBTX_B	529	85.0
649	315	PHARAOH	94CS1365	684	84.9
650	597	COTULLA	94LA610	727	84.5
651	755	PORTLAND	94CS9270	1,810	84.2
652	973	VICTORIA POWER PLANT	94CN8070	608	84.2
653	784	PIRATE	94CS3220	741	84.0
654	363	CLARKWOOD	94CS7610	105	84.0
655	695	CARRIZO SPRINGS	94LA750	599	83.9
656	256	MORRIS STREET	94CS8830	1,512	83.9
657	759	JOURDANTON	94LA5685	327	83.8
658	720	PORT ISABEL S.S.	94SB4070	283	83.3
659	253	RIO GRANDE CITY	94SB3220	1,420	83.3
660	750	NIXON	94CN6630	645	83.2
661	981	MUNDAY REA (BKEC)	97AB2015	21	83.0
662	101	MOORE FIELD	94SB3110	720	83.0
663	1089	ROTAN	97AB1860	686	82.3
664	811	JUNCTION	97SA10795	811	82.3
665	712	UVALDE	94LA5060	1,288	81.8
666	586	WYLIE	97AB2665	1,090	81.7
667	546	LA GRULLA	94SB5005	1,215	80.7
668	1081	HAMILTON ROAD	94LA9655	1,323	80.4
669	1098	AB COUNTRY CLUB	97AB4735	122	80.4
670	1003	RESACA	94SB8700	1,125	80.1
671	1255	VICTORIA POWER PLANT	94CNVRED	44	80.0
672	1259	VICTORIA POWER PLANT	94CNVBROWN	16	80.0
673	813	NORTH VICTORIA	94CN1580	1,049	79.6
674	833	LEARY LANE	94CN1890	1,625	79.4
675	311	NORTH MCALLEN	94SB5055	3,319	79.1
676	698	EAGLE PASS CITY	94LA7060	871	78.5
677	796	SEAWALL	94CS9450	299	77.8
678	768	ZACATE CREEK	94LA2635	975	77.6
679	341	PETTUS	94CN8210	346	77.5
680	652	ANNA STREET	94LA2250	1,557	77.0
681	252	POLK AVENUE	94SB4740	1,718	76.9

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
682	370	YORKTOWN	94CN8380	780	76.6
683	201	BROOKHOLLOW	94CN8950	922	76.3
684	422	WINTERS	97SA3765	824	76.2
685	49	STAMFORD PUMP	97AB3930	37	75.7
686	722	KLEIMANN	94CN565	582	75.2
687	959	MAYBERRY	94SB1790	1,090	74.8
688	340	PECAN BAYOU	97AB6810	467	74.7
689	318	MOCKINGBIRD	94CN400	1,015	74.5
690	692	AB SHELTON ST	97AB3040	179	73.5
691	826	ROCKPORT	94CS5130	566	73.5
692	574	MOCKINGBIRD	94CN305	329	73.2
693	1140	CLARKWOOD	94CS7220	931	73.1
694	42	MEDIO CREEK	94CN1380	810	72.9
695	480	BROOKHOLLOW	94CN8960	595	72.8
696	426	MORAN	97AB2108	304	72.8
697	1117	WEST MCALLEN	94SB4965	967	72.6
698	53	CONTINENTAL	94SB3650	14	72.5
699	890	AB WALNUT ST	97AB3445	56	72.4
700	957	WASHINGTON STREET	94LA6525	2,740	72.2
701	650	CATARINA	94LA2380	187	71.9
702	457	KLEBERG	94CS8140	643	71.9
703	1047	BEEVILLE	94CN2380	219	71.7
704	780	EL CAMPO	94CN7710	1,074	71.2
705	575	READING	94LA1445	533	71.2
706	242	GARCENO	94SB2135	1,543	71.0
707	25	BLACK CAT	94CN4525	114	70.9
708	554	CRYSTAL CITY	94LA7425	444	70.6
709	731	AB HARTFORD ST	97AB3815	1,114	70.5
710	399	MOORE FIELD	94SB3960	2,191	70.5
711	913	PRIMERA	94SB6085	1,462	70.5
712	990	AB OVER STREET 12KV	97AB1840	888	70.3
713	671	RUNGE	94CN4465	361	70.3
714	547	AB VOGEL ST	97AB4410	764	70.1
715	949	ANNA STREET	94LA900	2,843	69.8
716	511	ROWENA	97SA4480	231	69.7
717	703	BEEVILLE	94CN2200	722	69.6
718	656	IRAAN	97SA2050	389	69.0
719	1161	AB OVER STREET 12KV	97AB3140	686	68.9
720	633	SOUTH EAST EDINBURG	94SB6580	939	68.8
721	702	HOMEPORT	94CS4665	429	68.8
722	184	ARCADIA	94CS1360	1,539	68.8
723	1063	AB MCMURRY	97AB4350	707	68.2
724	472	PEARSALL	94LA7050	581	68.2
725	431	ARCADIA	94CS5020	1,544	68.0
726	278	MORAN	97AB2107	208	67.8
727	38	SUNCHASE	94SB1155	1,433	67.7
728	320	MAGRUDER	94CN245	1,248	67.6
729	92	SOUTH PADRE ISLAND	94SB6440	2,590	67.5
730	1220	AB SHELTON ST	97AB3045	550	67.3

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
731	269	UVALDE	94LA550	746	67.1
732	1080	NORTH MCALLEN	94SB2750	3,182	66.9
733	424	YOUNG	94SB5135	1,288	66.8
734	277	HIGHWAY 9	94CS6780	754	66.7
735	358	GEORGE WEST	94CN730	907	66.4
736	1042	AB OVER STREET 12KV	97AB1635	528	66.3
737	1232	HEINES	94CS2185	1,257	66.1
738	840	HIGHWAY 9	94CS7200	655	66.0
739	87	PHARR	94SB1645	1,728	66.0
740	498	CRESTONIO	94LA6660	790	66.0
741	855	VERNON	97AB1520	723	65.9
742	1001	SA GRAPE CREEK	97SA5365	857	65.7
743	1194	LAREDO PLANT	94LA8705	172	65.5
744	577	YELLOW JACKET	97SA5505	539	65.5
745	519	WESLACO UNIT	94SB8610	1,194	65.4
746	68	STAFFORD HILL	94CN1550	144	65.1
747	935	SEAWALL	94CS9420	818	65.1
748	1184	BRONTE AMBASSADOR	97SA6650	14	64.8
749	44	SAN DIEGO	94LA1980	628	64.5
750	335	WESMER	94SB7760	1,464	64.5
751	899	TAYLOR	94SBSH111	711	64.3
752	404	STADIUM	94LA7490	1,307	64.3
753	963	CITRUS CITY	94SB7985	1,211	64.2
754	1092	AB OVER STREET 12KV	97AB1645	796	63.7
755	1164	YOUNG	94SB4435	826	63.3
756	847	MILO	94LA3065	28	63.2
757	593	HOLCOMB	94LA2240	458	63.1
758	970	SOUTH EAST EDINBURG	94SB5045	1,783	63.1
759	994	AB MCMURRY	97AB4360	1,100	62.9
760	827	CHOKE CANYON	94CN5390	412	62.6
761	585	SAN DIEGO	94LA2880	1,335	62.2
762	378	ELDORADO	97SA5310	189	61.9
763	517	REFUGIO	94CN5120	726	61.8
764	977	NORTH EDINBURG	94SB560	2,199	61.7
765	170	ODEM	94CS2400	315	61.3
766	1129	SA EMERSON ST	97SA4620	431	61.2
767	997	CEDAR GAP (TEC)	97AB4115	972	61.0
768	377	WEAVER ROAD	94CN1910	27	60.4
769	892	RESACA	94SB7110	1,730	59.9
770	493	CITRUS CITY	94SB9775	1,599	59.5
771	1109	COLLEGE HILLS	97SA5520	432	59.4
772	360	BEN FICKLIN	97SA6180	563	59.3
773	1018	THREE RIVERS	94CN2580	119	59.3
774	640	RIO GRANDE CITY	94SB3740	2,390	59.3
775	3	SANTA RITA	97SA1105	68	58.8
776	349	PREMONT	94LA2720	776	58.5
777	133	ARCADIA	94CS5030	1,578	58.1
778	763	STADIUM	94LA8540	1,695	58.1
779	1073	EDNA	94CN5785	1,258	58.1

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
780	846	HARLINGEN	94SB370	1,236	57.9
781	815	AB MCMURRY	97AB3245	795	57.6
782	675	BEEVILLE	94CN490	952	57.3
783	1285	PANTERA	94SB1765	881	57.1
784	912	NORDHEIM	94CN4275	80	56.9
785	752	FALFURRIAS	94LA1070	937	56.7
786	356	CLOSNER	94SB4100	2,086	56.7
787	222	RAYMONDVILLE #2	94SB3240	919	56.6
788	1174	AB MCMURRY	97AB3240	766	56.1
789	611	WEST MCALLEN	94SB4515	867	56.0
790	391	RUSSEK STREET	97SA11370	200	56.0
791	1177	CHILDRESS 20TH ST	97AB5720	186	55.9
792	5	CARANCAHUA	94CN1875	59	55.7
793	558	HEARN ROAD	94CS2220	1,731	55.5
794	831	FRIO	94LA1815	1,069	55.1
795	895	CABANISS	94CS820	1,304	55.0
796	48	DARST	94CN1845	184	54.9
797	463	KLEBERG	94CS6410	247	54.5
798	1138	GONZALES	97SA14685	1,328	54.4
799	459	LAREDO PLANT	94LA8565	1,440	54.3
800	56	SINTON	94CS360	335	54.0
801	0	RAYMONDVILLE #2	94SB1280	989	53.9
802	686	SOUTHSIDE	94CS8005	744	53.6
803	645	MAGRUDER	94CN6690	756	53.6
804	1038	ABILENE PLANT	97AB1735	84	53.2
805	639	PECAN BAYOU	97AB530	18	53.2
806	734	JOURDANTON	94LA8725	30	53.0
807	326	INGLESIDE CITY	94CS2495	273	53.0
808	462	BAY CITY	94CN1110	1,237	52.9
809	373	CARRIZO SPRINGS	94LA370	550	52.9
810	1119	MILO	94LA5020	113	52.8
811	706	CASA BLANCA	94CS4170	1,158	52.6
812	870	GATEWAY	94LA350	2,017	52.4
813	770	ASPR CONTINENTAL	97AB4800	32	52.2
814	334	LA GRULLA	94SB5110	1,030	52.1
815	7	WESMER	94SB6900	51	52.1
816	375	HALL ACRES ROAD	94SB3460	3,201	51.7
817	160	CABANISS	94CS80	98	51.7
818	938	YOUNG	94SB3310	1,873	51.6
819	937	EL CAMPO	94CN7260	537	51.4
820	416	OLMITO	94SB905	1,677	51.3
821	1034	AB RAINEY CREEK	97AB4220	219	51.2
822	1251	BENTSEN	94SBH215	55	51.1
823	339	NORTH EDINBURG	94SB3570	1,051	51.1
824	657	KENEDY	94CN1970	567	50.9
825	351	PALMVIEW	94SB9685	2,957	50.8
826	394	HOLLY	94CS1370	1,886	50.4
827	979	EAST HARRISON	94SB3030	678	50.3
828	1108	MCCOLL ROAD	94SB1655	1,513	49.9

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
829	1132	CEDAR GAP (TEC)	97AB5445	506	49.9
830	434	MILO	94LA3060	129	49.7
831	1146	AB MCMURRY	97AB4355	989	49.6
832	1078	SA WALNUT ST	97SA3920	901	49.5
833	1198	SAN BENITO	94SB3860	258	49.5
834	1054	MCCOLL ROAD	94SB5485	1,077	49.3
835	723	KITTIE WEST	94CN3765	323	49.3
836	792	AB CANYON ROCK	97AB5030	699	49.2
837	1137	PANTERA	94SB1915	1,195	49.0
838	1269	BARNHART	97SA590	18	48.9
839	1048	SA GRAPE CREEK	97SA4700	749	48.8
840	1209	AB COUNTRY CLUB	97AB4730	542	48.8
841	648	EL CAMPO	94CN2860	1,517	48.6
842	1040	HEIGHTS	94LA2450	2,042	48.3
843	505	HOLLY	94CS1950	838	47.9
844	849	HALL ACRES ROAD	94SB9595	1,588	47.5
845	777	AB ELM CREEK	97AB5045	384	47.4
846	143	VERHALEN	97SA4465	36	47.2
847	663	AIRLINE	94CS6970	1,401	47.2
848	296	SAND CRAB	94CN6735	1,321	47.0
849	1122	CLYDE	97AB3630	438	46.9
850	807	CRYSTAL CITY	94LA2170	747	46.9
851	1037	ARANSAS PASS	94CS9130	460	46.5
852	1102	AIRLINE	94CS8890	526	46.3
853	584	GREGORY	94CS420	467	46.2
854	694	SANTO NINO	94LA75	1,515	46.0
855	736	ODEM	94CS5575	80	45.9
856	667	ENCINAL	94LA2160	231	45.9
857	250	ALPINE 12KV	97SA6825	1,806	45.9
858	27	MARKHAM	94CN6440	470	45.8
859	108	NORTH VICTORIA	94CN7440	1,643	45.8
860	234	SARAGOSA	97SA1552	780	45.5
861	880	SHARYLAND	94SB6745	2,320	45.1
862	120	PALMVIEW	94SB7595	3,225	45.1
863	828	SHEFFIELD	97SA6430	209	44.7
864	266	MCKENZIE ROAD	94CS330	2,406	44.7
865	380	SKIDMORE	94CS600	365	44.5
866	660	ALICE	94LA1780	510	44.5
867	954	AIRLINE	94CS9030	403	44.4
868	310	PONDER KENNEDY	97SA50208	13	44.4
869	842	ELSA	94SB690	2,419	44.4
870	669	CABANISS	94CS710	175	44.3
871	693	SHARYLAND	94SB5105	2,042	44.3
872	896	MINES ROAD	94LA4275	252	44.2
873	983	CHILDRESS 69	97AB1480	303	43.9
874	1245	AB REBECCA LANE	97AB5555	1,268	43.6
875	NA	PROGRESO	94SB2495	1,696	43.1
876	1072	GREGORY	94CS2420	913	42.9
877	1111	LEARY LANE	94CN6005	1,386	42.8

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
878	680	WESLACO UNIT	94SB8195	1,667	42.7
879	751	LAREDO PLANT	94LA9305	1,066	42.6
880	756	SA COKE ST	97SA3905	653	42.6
881	1039	COLLEGE HILLS	97SA6145	981	42.5
882	298	RANKIN	97SA5735	187	42.3
883	99	STAMFORD	97AB2835	100	42.2
884	903	EAGLE PASS CITY	94LA2650	1,384	42.1
885	551	ESCONDIDO	94LA5730	2,759	42.0
886	950	SOUTH PADRE ISLAND	94SB4675	197	41.8
887	1207	BALLINGER	97SA4370	777	41.8
888	587	AB OIL MILL	97AB2780	747	41.7
889	905	MERKEL	97AB1890	575	41.7
890	747	PUEBLO	94LA130	1,764	41.6
891	614	KLEIMANN	94CN425	612	41.6
892	834	SA SOUTH	97SA2595	1,070	41.3
893	1143	AB SHELTON ST	97AB3050	649	41.0
894	642	MESQUITE	94SB2900	948	40.8
895	405	KLEBERG	94CS6000	1,408	40.8
896	1056	SPUR	97AB5170	383	40.7
897	382	PALMHURST	94SB2535	3,048	40.6
898	1107	QUANAH	97AB3100	557	40.4
899	1213	SAND CRAB	94CN8390	532	40.1
900	760	WEST MCALLEN	94SB4535	3,068	40.0
901	726	FULTON	94CS6070	1,817	39.7
902	393	SANTA ANNA	97SA3420	367	39.4
903	481	ANNA STREET	94LA850	1,559	39.4
904	762	GARCENO	94SB2165	1,973	39.4
905	617	MILO	94LA6940	467	39.4
906	805	YOUNG	94SB7145	1,810	39.3
907	219	HOLLY	94CS5820	903	39.3
908	791	EAST HARRISON	94SB4360	1,769	39.2
909	987	AB ELM CREEK	97AB1815	388	39.1
910	295	HARLINGEN	94SB360	2,434	39.0
911	132	GOVERNMENT WELLS	94LA7250	566	38.8
912	947	AB SHELTON ST	97AB3060	1,584	38.7
913	435	ROCKPORT	94CS5940	64	38.5
914	598	CARRIZO SPRINGS	94LA860	31	38.4
915	241	PALMHURST	94SB2525	2,328	38.1
916	125	MIDWAY LANE	97SA3440	58	38.1
917	512	NORTH MCALLEN	94SB5060	2,634	38.0
918	579	SA JACKSON ST	97SA4265	799	38.0
919	482	VALADEZ	94CS3140	1,977	37.9
920	1070	AB CANYON ROCK	97AB5035	823	37.9
921	1203	SA SOUTHLAND HILLS	97SA5050	890	37.7
922	1165	ANSON REA (SEC)	97AB5215	259	37.6
923	146	TANKERSLY (CVEC)	97SA5265	381	37.5
924	137	VERHALEN	97SA14765	27	37.0
925	518	POWELL FIELD	97SA2528	23	36.8
926	848	AB OIL MILL	97AB3900	690	35.8

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
927	116	TANKERSLY (CVEC)	97SA5260	479	35.8
928	458	AB DYESS 2	97AB6335	352	35.8
929	487	BAY CITY	94CN2050	329	35.8
930	1173	AB ONYX REA	97AB3255	23	35.4
931	227	LAS CRUSES	94LA7325	2,761	35.3
932	868	NORTH EDINBURG	94SB4240	1,151	34.9
933	464	NORTH VICTORIA	94CN1470	481	34.8
934	1226	SOUTH EAST EDINBURG	94SB4015	448	34.6
935	1279	ESPY WELLS	97SA50207	31	34.6
936	781	KARNES CITY	94CN2325	665	34.5
937	634	WYLIE	97AB6340	779	34.4
938	312	TRENT	97AB4245	183	34.4
939	259	WESLACO UNIT	94SB9805	2,269	34.3
940	1154	VERNON	97AB3340	534	34.1
941	357	MAGRUDER	94CN6680	701	34.1
942	666	YELLOW JACKET	97SA7935	810	33.9
943	524	SOUTH MISSION	94SB3590	556	33.7
944	861	EL CAMPO	94CN5745	941	33.7
945	873	TWILIGHT TRAIL	97AB5855	257	33.7
946	727	AILEEN	97AB4605	429	33.4
947	821	SHARYLAND	94SB2150	895	32.9
948	711	BUSH KNOB	97AB5200	303	32.9
949	1097	RODD FIELD	94CS3010	2,068	32.5
950	1180	WYLIE	97AB2675	820	32.3
951	359	BIG WELLS	94LA2630	30	32.2
952	844	HEIGHTS	94LA2100	1,991	32.1
953	907	SHARYLAND	94SB5635	2,311	31.7
954	906	AB WALNUT ST	97AB3785	574	31.7
955	874	SANTO NINO	94LA70	3,113	31.6
956	285	HALL ACRES ROAD	94SB4895	882	31.6
957	1156	SONORA	97SA2045	202	31.5
958	1013	LA GRULLA	94SB4120	1,532	31.3
959	668	QUANAH	97AB1830	627	31.3
960	188	ZAPATA	94LA7330	1,375	31.3
961	852	MORRIS STREET	94CS8840	637	31.2
962	1141	WASHINGTON STREET	94LA6355	949	31.2
963	556	YOUNG	94SB6140	2,536	31.1
964	194	ROCKSPRINGS	94LA2600	368	31.1
965	783	MAGRUDER	94CN6700	1,374	31.1
966	641	ASHLAND	94SB5H301	14	30.9
967	1067	CHILDRESS 69	97AB1800	543	30.7
968	865	GILA	94CS7840	770	30.6
969	11	RAYMONDVILLE #2	94SB5875	28	30.5
970	1172	WASHINGTON STREET	94LA7015	1,545	30.5
971	992	AB RAINEY CREEK	97AB4550	988	30.4
972	1256	DUST DEVIL	94LA1380	42	30.3
973	1002	POLK AVENUE	94SB4520	1,068	30.3
974	631	AIRLINE	94CS9390	1,352	30.3
975	812	AB EAST 12KV	97AB5760	215	30.1

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
976	644	JOURDANTON	94LA5695	323	30.1
977	421	CLARKWOOD	94CS2170	795	30.0
978	1035	LEARY LANE	94CN6175	2,483	29.9
979	926	NORTH VICTORIA	94CN2240	746	29.8
980	502	SAN BENITO	94SB3910	680	29.6
981	1197	WYLIE	97AB6495	362	29.5
982	1026	MERTZON (CVEC)	97SA1530	338	29.3
983	1131	UNIVERSITY	94LA465	931	29.0
984	571	VERNON	97AB1750	246	28.9
985	866	WASHINGTON STREET	94LA2360	204	28.8
986	716	HARLINGEN	94SB660	1,270	28.6
987	960	SA WALNUT ST	97SA3925	894	28.4
988	1171	QUANAH	97AB100	89	28.2
989	1012	AB VOGEL ST	97AB4560	1,477	28.1
990	1086	REFUGIO	94CN1170	864	28.0
991	364	MUSTANG ISLAND	94CS9470	790	28.0
992	1195	DUST DEVIL	94LA1495	2,026	27.3
993	1186	RANKIN	97SA6405	360	27.1
994	567	RAYMONDVILLE #1	94SB800	740	27.1
995	931	HEIGHTS	94LA9400	1,470	27.0
996	886	EDITH HUMBLE	97SA6170	83	27.0
997	765	AB ELMDALE	97AB4085	46	26.9
998	317	GILA	94CS345	69	26.8
999	1189	TWILIGHT TRAIL	97AB3150	724	26.7
1000	1127	DEL MAR	94LA2120	1,346	26.7
1001	4	BAY CITY	94CN6450	164	26.7
1002	610	TATTON	94CS8200	1,225	26.7
1003	539	EL CAMPO	94CN6370	776	26.6
1004	74	MARKHAM	94CN5550	20	26.6
1005	475	PALMHURST	94SB1300	2,280	26.2
1006	NA	DUST DEVIL	94LA1810	478	26.1
1007	843	DEL MAR	94LA7930	1,981	26.1
1008	1222	AB COUNTRY CLUB	97AB4725	230	25.8
1009	288	ALICE	94LA2540	963	25.8
1010	988	BRONTE	97SA3590	194	25.8
1011	1243	KENEDY S.S.	94CN8320	142	25.8
1012	1149	SA LAKE DR	97SA5865	1,062	25.8
1013	707	STADIUM	94LA6950	427	25.7
1014	719	SOUTH MISSION	94SB3940	877	25.6
1015	1066	AB MCMURRY	97AB3235	781	25.6
1016	1229	MAYO	94CS500	26	25.6
1017	1125	ZACATE CREEK	94LA2675	1,216	25.5
1018	91	PORT ARANSAS	94CS3030	955	25.4
1019	646	SOUTH MISSION	94SB5215	1,241	25.2
1020	1136	HEIGHTS	94LA2390	1,722	24.8
1021	1158	BENJAMIN (BEPC)	97AB5680	165	24.8
1022	267	CLOSER	94SB2945	1,101	24.6
1023	1045	WASHINGTON STREET	94LA2350	3,052	24.5
1024	1036	KENEDY	94CN6270	546	24.5

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
1025	1151	CLOSER	94SB6430	1,028	24.4
1026	615	DILLEY	94LA6400	873	24.2
1027	1050	RANKIN	97SA6400	60	24.1
1028	887	LA GRULLA	94SB6150	1,735	24.1
1029	820	SHARYLAND	94SB2035	853	24.0
1030	625	SOUTH MISSION	94SB3980	1,937	23.9
1031	589	PRIMERA	94SB7020	1,484	23.9
1032	251	ROMA	94SB3070	904	23.9
1033	447	RIO GRANDE CITY	94SB3210	1,991	23.5
1034	365	HAMILTON ROAD	94LA9645	298	23.4
1035	1061	CHILDRESS 69	97AB4865	777	23.3
1036	578	WINTERS	97SA2113	801	23.3
1037	387	MESQUITE	94SB8340	759	23.0
1038	1168	SA EMERSON ST	97SA4625	421	22.6
1039	1211	MAYBERRY	94SB3010	347	22.5
1040	1236	SPUR	97AB300	204	22.4
1041	1224	ROARING SPRINGS	97AB2065	217	22.4
1042	786	SOUTH MCALLEN	94SB3790	1,468	22.3
1043	563	SA SOUTH	97SA3995	795	22.3
1044	714	KINGSVILLE	94CS1350	396	22.3
1045	915	TRADE ZONE	94SB2060	513	22.0
1046	1223	VALADEZ	94CS8800	1,690	21.7
1047	1235	PAINT ROCK	97SA5235	140	21.6
1048	8	SONORA ATLANTIC (SWTEC)	97SA4415	31	21.5
1049	1029	POLK AVENUE	94SB4600	160	21.4
1050	955	LANTANA	94CS4095	195	21.2
1051	388	LAREDO PLANT	94LA8745	767	21.1
1052	402	KINGSVILLE	94CS1140	1,134	21.0
1053	548	SA NORTH	97SA3130	231	20.9
1054	1202	SA MATHIS FIELD	97SA5100	316	20.9
1055	1032	COTULLA	94LA90	1,058	20.8
1056	473	LA GRULLA	94SB3045	1,211	20.8
1057	682	GOODWIN	94SB3530	335	20.8
1058	1190	SIERRA VISTA	94LA9900	2,515	20.5
1059	545	DIMMIT	94LA5545	549	20.4
1060	1000	SA LAKE DR	97SA5880	735	20.4
1061	1079	SA JACKSON ST	97SA4260	654	20.4
1062	717	SOUTH EAST EDINBURG	94SB4570	1,902	20.4
1063	782	ZAPATA	94LA8290	988	20.4
1064	659	NORTH MCALLEN	94SB9660	2,183	20.4
1065	800	SA EMERSON ST	97SA4860	233	20.2
1066	347	CAUSEWAY	94SB4775	1,069	20.2
1067	1160	TWILIGHT TRAIL	97AB4290	1,202	20.1
1068	748	SAND ROAD	97AB5655	622	20.0
1069	389	AB MAPLE ST	97AB5750	474	19.9
1070	881	AB OIL MILL	97AB3895	133	19.8
1071	1133	BALLINGER	97SA4395	534	19.8
1072	1217	UNIVERSITY	94LA920	909	19.7
1073	244	SOUTH MCALLEN	94SB3850	1,362	19.7

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
1074	758	AB MCMURRY	97AB4510	816	19.6
1075	898	FT DAVIS	97SA3345	539	19.6
1076	1008	SA COKE ST	97SA4910	1,783	19.3
1077	583	DEL MAR	94LA10	1,746	19.1
1078	875	AB REBECCA LANE	97AB6915	1,020	19.1
1079	1011	MCCOLL ROAD	94SB4400	1,288	19.0
1080	371	RAYMONDVILLE #1	94SB620	667	19.0
1081	1288	STEAMBOAT	97AB12515	68	19.0
1082	876	SOUTH MISSION	94SB4650	1,010	18.9
1083	1276	BRYANTS RANCH	97SA205	21	18.9
1084	1150	AILEEN	97AB6435	852	18.8
1085	980	CISCO	97AB7400	833	18.6
1086	1178	HIGHLAND	97SA6375	295	18.4
1087	468	AIRLINE	94CS7390	2,330	18.3
1088	514	QUANAH	97AB3975	214	18.3
1089	901	MARFA	97SA1905	1,155	18.3
1090	1169	SA AVENUE N	97SA1730	830	18.2
1091	1128	HEIGHTS	94LA6810	2,122	17.8
1092	568	UVALDE	94LA9770	516	17.8
1093	999	READING	94LA1385	1,354	17.7
1094	647	SINTON	94CS180	232	17.6
1095	739	MCCOLL ROAD	94SB2810	2,287	17.6
1096	239	DEL MAR	94LA220	1,470	17.4
1097	921	VERNON	97AB5000	247	17.4
1098	795	RODD FIELD	94CS245	705	17.3
1099	292	ESCONDIDO	94LA1510	739	17.3
1100	147	MUNDAY	97AB3365	390	17.1
1101	562	SIERRA VISTA	94LA8205	1,236	17.0
1102	986	COLLEGE HILLS	97SA4840	218	16.9
1103	1104	ROARING SPRINGS	97AB6155	30	16.9
1104	972	WASHINGTON STREET	94LA2470	481	16.9
1105	59	GILA	94CS350	308	16.8
1106	824	STAMFORD	97AB4565	786	16.8
1107	265	EDNA	94CN5775	509	16.7
1108	1007	AB EAST 12KV	97AB4825	416	16.7
1109	962	PHARR	94SB1650	898	16.7
1110	630	SA SOUTH	97SA4255	866	16.7
1111	928	ARANSAS PASS	94CS660	723	16.6
1112	1147	AB WALNUT ST	97AB3110	658	16.6
1113	1075	AB VOGEL ST	97AB4405	597	16.5
1114	681	ROBERT LEE	97SA4125	274	16.4
1115	300	KNOX CITY	97AB3300	459	16.3
1116	572	AB ELM CREEK	97AB4780	553	16.2
1117	624	HARLINGEN	94SB380	263	16.2
1118	449	ABILENE PLANT	97AB1910	246	16.2
1119	544	KLEBERG	94CS280	1,328	16.1
1120	411	AB RAINEY CREEK	97AB4270	1,422	16.1
1121	817	KLEBERG	94CS9395	1,261	16.1
1122	925	KARNES CITY	94CN2340	786	16.0

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
1123	806	AB OIL MILL	97AB2785	274	16.0
1124	500	AB MAPLE ST	97AB4070	1,070	15.9
1125	1218	CHILDRESS 20TH ST	97AB5725	680	15.7
1126	976	SANTO NINO	94LA80	1,904	15.5
1127	956	HIGHLAND	97SA6385	1,356	15.5
1128	1252	UNITEC	94LA5895	36	15.4
1129	626	SA CONCHO	97SA3325	295	15.2
1130	910	SHARYLAND	94SB2020	2,814	15.2
1131	654	AB COUNTRY CLUB	97AB4855	964	14.9
1132	858	SAND ROAD	97AB5290	819	14.8
1133	561	NORTH MCALLEN	94SB9640	1,535	14.7
1134	195	GOODWIN	94SB4625	2,302	14.6
1135	305	PEARSALL	94LA5580	854	14.4
1136	279	ROCKPORT	94CS5950	555	14.2
1137	1193	SIERRA VISTA	94LA7170	1,455	14.0
1138	1110	AB DYESS 1	97AB1775	881	14.0
1139	793	AB VOGEL ST	97AB4650	809	13.9
1140	210	CLYDE	97AB1755	132	13.8
1141	324	VALADEZ	94CS2500	2,570	13.8
1142	1065	CISCO	97AB9715	1,023	13.6
1143	134	ALBANY	97AB3655	625	13.3
1144	822	CROWELL	97AB3490	176	13.2
1145	883	SA CONCHO	97SA1705	928	13.2
1146	368	EDNA	94CN5765	1,257	12.9
1147	322	GOODWIN	94SB7380	2,094	12.8
1148	638	SA AVENUE N	97SA1695	1,525	12.5
1149	1074	ROCHESTER	97AB3295	208	12.2
1150	966	NORTH WESLACO	94SB4830	531	12.1
1151	1192	SOUTHSIDE	94CS5345	403	12.1
1152	995	VERNON CITY PLANT	97AB5775	813	12.0
1153	1205	SA SOUTHLAND HILLS	97SA5055	857	12.0
1154	1084	SA WALNUT ST	97SA4635	1,549	11.6
1155	743	PRIMERA	94SB5705	1,260	11.6
1156	1214	SA WALNUT ST	97SA3910	145	11.4
1157	1057	STAMFORD	97AB6255	434	11.4
1158	532	WOOLRIDGE	94CS1120	1,636	11.3
1159	818	SAND ROAD	97AB5295	537	11.2
1160	687	ALICE	94LA1790	454	10.9
1161	773	ASPERMONT	97AB1070	329	10.9
1162	287	ALBANY	97AB3640	335	10.8
1163	837	ROMA	94SB3060	1,619	10.6
1164	1021	CISCO	97AB1020	479	10.6
1165	1183	SOUTH MCALLEN	94SB3935	508	10.0
1166	952	EDEN	97SA3195	533	9.9
1167	79	GATEWAY	94LA5055	1,893	9.8
1168	1240	COLLEGE HILLS	97SA4845	600	9.7
1169	1091	SPUR	97AB260	162	9.6
1170	1010	BAIRD	97AB5120	568	9.6
1171	1071	SA JACKSON ST	97SA4685	1,442	9.5

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
1172	803	NORTH EDINBURG	94SB3810	1,535	9.5
1173	724	ASPERMONT	97AB3380	395	9.5
1174	497	NORTH MCALLEN	94SB4995	2,486	9.4
1175	522	SA CONCHO	97SA1700	553	9.1
1176	1239	HEINES	94CS8480	150	8.9
1177	879	SA NORTH	97SA3120	1,136	8.5
1178	1030	AB SHELTON ST	97AB3145	1,051	8.4
1179	940	JOSLIN POWER PLANT	94CN7915	11	8.2
1180	1200	BRONTE	97SA3560	229	8.0
1181	1142	SA AVENUE N	97SA1655	494	7.9
1182	596	HAMLIN	97AB3270	893	7.8
1183	1170	AB ELM CREEK	97AB1810	831	7.7
1184	944	MUNDAY	97AB2080	506	7.7
1185	1283	KIRKLAND	97AB3545	30	7.7
1186	1152	PADUCAH CITY	97AB1935	289	7.6
1187	80	PERKINS PROTHO	97SA3180	19	7.6
1188	851	SA JACKSON ST	97SA4690	1,122	7.6
1189	888	QUANAH	97AB3530	328	7.6
1190	599	EAST HARRISON	94SB4620	776	7.6
1191	1157	PADUCAH CITY	97AB1930	574	7.3
1192	794	CLOSNER	94SB7505	764	7.2
1193	732	PEACOCK	97AB1375	43	7.0
1194	1049	SA EMERSON ST	97SA4630	1,236	6.9
1195	948	MARFA	97SA1900	822	6.9
1196	1257	SA CONCHO	97SA1725	29	6.8
1197	1027	KENEDY S.S.	94CN6750	65	6.7
1198	1233	SA WALNUT ST	97SA3915	722	6.7
1199	145	HEINES	94CS3515	1,307	6.6
1200	319	PALMVIEW	94SB9680	1,066	6.6
1201	1242	TRADE ZONE	94SB2220	70	6.5
1202	1230	SA SOUTH	97SA3500	562	6.5
1203	1196	AB EAST 12KV	97AB4830	1,020	6.5
1204	1113	ROBERT LEE	97SA4120	549	6.4
1205	1227	RANKIN	97SA7425	123	6.4
1206	622	GARCENO	94SB5490	1,459	6.2
1207	1206	SANTO NINO	94LA695	1,606	6.1
1208	1215	SA SOUTHLAND HILLS	97SA5860	1,193	6.1
1209	361	HEIGHTS	94LA9080	694	6.1
1210	725	PAISANO	97SAPAISAN	161	6.1
1211	637	ROCHESTER	97AB3290	82	6.0
1212	691	ROCKSPRINGS	94LA8040	332	5.9
1213	718	SHARYLAND	94SB2010	1,165	5.9
1214	1051	ZACATE CREEK	94LA2665	1,727	5.7
1215	294	JAYTON	97AB6125	353	5.7
1216	839	CISCO	97AB6530	538	5.5
1217	1163	CROWELL	97AB3980	471	5.5
1218	878	AIRLINE	94CS7270	1,034	5.4
1219	1247	LAS CRUSES	94LA9865	448	5.4
1220	1284	TAYLOR	94SBSH114	626	5.3

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
1221	1052	SOUTH MCALLEN	94SB3640	205	5.3
1222	787	AB HARTFORD ST	97AB3690	172	5.3
1223	1228	SA SOUTH	97SA4795	1,504	5.2
1224	465	MILES	97SA4670	395	5.2
1225	26	RODD FIELD	94CS2190	96	5.2
1226	461	HIGHLAND	97SA6380	478	5.2
1227	1105	MORRIS STREET	94CS8850	411	5.1
1228	1083	TWILIGHT TRAIL	97AB4285	1,146	5.0
1229	884	ABILENE PLANT	97AB1740	18	4.9
1230	1112	NEW BLUFFS	97SA7280	1,581	4.9
1231	NA	LA PRYOR	94LA1835	266	4.8
1232	872	AB HARTFORD ST	97AB3820	927	4.8
1233	902	AB CANYON ROCK	97AB5025	58	4.6
1234	804	AB REBECCA LANE	97AB2710	262	4.6
1235	608	ROTAN	97AB1865	193	4.5
1236	446	KNOX CITY	97AB3985	25	4.5
1237	1167	SIERRA VISTA	94LA7360	1,713	4.2
1238	1148	RAYMONDVILLE #2	94SB4160	347	4.2
1239	1219	HAMLIN	97AB3775	246	4.2
1240	338	ANNA STREET	94LA5780	661	4.2
1241	651	ABILENE PLANT	97AB1915	50	4.2
1242	1237	AB ELM CREEK	97AB1825	214	4.2
1243	1153	SANTO NINO	94LA645	840	4.1
1244	1162	AB REBECCA LANE	97AB5550	716	4.0
1245	NA	QUINTANA	94CNT001Y8	58	3.7
1246	478	AB ELMDALE	97AB4520	283	3.6
1247	877	AB HARTFORD ST	97AB3685	370	3.5
1248	904	MATADOR	97AB3090	315	3.4
1249	1225	CHILDRESS 69	97AB2800	342	3.4
1250	689	VALERA HUMBLE	97SA7015	79	3.4
1251	1044	ALPINE 12KV	97SA6820	775	3.3
1252	1268	COLLEGE HILLS	97SA5515	201	3.3
1253	984	SA SOUTH	97SA3990	757	3.0
1254	1272	CROCKETT HEIGHTS	97SA73703	69	2.9
1255	764	SA CONCHO	97SA1715	294	2.8
1256	1025	ESCONDIDO	94LA3775	234	2.7
1257	1199	COLLEGE HILLS	97SA4835	499	2.7
1258	975	TEX/NEW MEX PIPELINE	97SA9045	16	2.4
1259	NA	SONORA	97SAT000E2	498	2.3
1260	535	AB MAPLE ST	97AB5755	1,220	2.3
1261	1241	TAYLOR	94SBSH112	989	2.2
1262	971	COTULLA	94LA110	55	2.1
1263	857	SA JACKSON ST	97SA4695	561	2.1
1264	1144	FLOMOT	97AB81335	29	2.1
1265	159	ESCONDIDO	94LA2035	444	2.0
1266	406	HAINE DRIVE	94SB9240	34	1.9
1267	1248	RUSSEK STREET	97SA12295	292	1.8
1268	916	TALPA ATLANTIC	97SA5180	65	1.7
1269	1088	EAST HARRISON	94SB3000	548	1.6

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
1270	NA	STERLING CITY	97SA11040	544	1.5
1271	1123	EDEN	97SA1780	232	1.3
1272	NA	MINES ROAD	94LA3745	2,114	1.3
1273	151	UNIVERSITY	94LA305	759	1.0
1274	1077	SA AVENUE N	97SA1975	320	1.0
1275	1204	PAINT ROCK	97SA1110	64	1.0
1276	1062	BRONTE	97SA4160	226	0.9
1277	433	SIERRA VISTA	94LA3540	1,154	0.6
1278	148	IRAAN	97SA4305	251	0.6
1279	1188	WEINERT	97AB6490	129	0.6
1280	1289	MILES	97SA11330	171	0.6
1281	832	SA JACKSON ST	97SA4250	336	0.4
1282	1273	ABILENE PLANT	97AB3175	122	0.3
1283	467	SA COKE ST	97SA4915	176	0.3
1284	1249	BENTSEN	94SBSH211	375	0.2
1285	1181	NEW BLUFFS	97SA3005	314	0.1
1286	939	NEW BLUFFS	97SA9110	818	0.1
1287	825	UNIVERSITY	94LA930	92	0.0
1288	1258	WASHINGTON STREET	94LA2330	60	0.0
1289	NA	MINES ROAD	94LA8770	310	0.0
1290	1068	LAS CRUSES	94LA8530	80	0.0
1291	1267	VICTORIA POWER PLANT	94CNNETVIC	88	0.0
1292	1270	WASHINGTON STREET	94LANETLAR	163	0.0
1293	1280	WASHINGTON STREET	94LA6890	19	0.0
1294	1266	WASHINGTON STREET	94LA2310	46	0.0
1295	1262	MORRIS STREET	94CSNET CC	317	0.0
1296	1238	KENEDY	94CN1960	69	0.0
1297	1261	WASHINGTON STREET	94LA2320	34	0.0
1298	1263	AB WALNUT ST	97AB3250	11	0.0
1299	860	SANTA RITA	97SA1135	10	0.0
1300	246	GIRARD	97AB6260	43	0.0
1301	1246	AILEEN	97AB4600	270	0.0
1302	933	SANTA RITA	97SA1140	11	0.0
1303	432	ASPR CONTINENTAL	97AB3830	27	0.0
1304	1275	ABILENE INDUSTRIAL PARK	97AB6600	12	0.0

Feeders from last year that are not in this year's list

2021 Ranking	Substation Identification	Feeder ID	Reason not in 2022
13	MASTERTON FIELD	97SA800	Count is now less than 10
20	HOEFFS ROAD	97SA15680	Count is now less than 10

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
	942	RIO PECOS	97SA513	Count is now less than 10	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

INTERRUPTION CAUSES

Provide the percentage of interruptions attributable to each cause.

2022 Reporting Year

Causes of Forced Interruptions	Percentage
Utility-Owned Equipment	52.50%
Weather (including lightning)	14.69%
Vegetation	14.69%
Unknown	8.74%
Animals and Birds	5.69%
People (including cars and farm eqpt)	2.42%
Other	0.00%

The following files are not convertible:

2023 AEP-TX SQR 06022023 (2021 Rank
Correction).xls

Please see the ZIP file for this Filing on the PUC Interchange in order to
access these files.

Contact centralrecords@puc.texas.gov if you have any questions.