



Filing Receipt

Received - 2023-02-14 01:01:45 PM

Control Number - 54467

ItemNumber - 9

Service Quality Report
To The
Public Utility Commission of Texas
In Accordance With
Substantive Rule §25.81
2022 Reporting Year

Project 54467

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

System SAIFI	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced													
2022	1.732	0.112	0.081	0.128	0.135	0.226	0.105	0.132	0.207	0.130	0.145	0.130	0.201
Scheduled													
2022	0.413	0.055	0.039	0.033	0.042	0.046	0.046	0.024	0.025	0.025	0.017	0.029	0.032
Outside Causes													
2022	0.074	0.004	0.000	0.003	0.007	0.014	0.005	0.000	0.010	0.012	0.000	0.003	0.015
Major Events													
2022	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

System SAIDI	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced													
2022	274.6	16.0	9.8	23.0	21.0	32.0	14.9	19.4	29.0	15.5	24.5	20.5	49.0
Scheduled													
2022	68.5	7.2	6.4	6.5	10.1	7.4	5.8	3.4	4.5	5.1	3.2	4.2	4.7
Outside Causes													
2022	9.4	0.3	0.0	0.4	0.7	1.4	0.8	0.0	1.4	0.4	0.1	0.1	3.7
Major Events													
2022	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

Total Number of Feeders

With 10 or more Customers

410

Add or Delete Rows as Necessary

Entergy Texas, Inc.

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
1	114	PEE DEE	806PD	3113	10.231
2	127	STILSON	733SN	85	9.329
3	43	PEE DEE	809PD	1672	8.968
4	2	CRYSTAL	566CR	1926	7.965
5	48	RIVTRIN	269RV	3017	7.047
6	333	CORDREY	326CO	1217	7.016
7	51	CALVERT	6CAL	1668	6.547
8	99	CLEVELAND - TX	426CV	3060	6.466
9	388	MAYHAW	671MA	123	6.35
10	166	CHINA	92CHI	669	6.215
11	65	HEIGHTS	362HT	137	6.19
12	4	CHEEK	166CH	376	5.771
13	18	KICKAPOO	251KP	1355	5.156
14	1	FORT WORTH	567FT	524	4.927
15	156	SPLENDORA	309SP	2328	4.912
16	68	HUNTSVILLE	600HU	2312	4.829
17	146	STOWELL	233ST	703	4.804
18	42	APOLLO	320AP	2211	4.722
19	219	CROCKETT	61CRK	99	4.636
20	316	CORRIGAN BULK	239CR	496	4.48
21	47	WARREN	506WR	1356	4.463
22	341	ORANGE	352ON	1225	4.422
23	237	TRANSCO	48TCO	220	4.418
24	194	OILLA	345OI	1521	4.402
25	35	LOEB	18LOB	554	4.338
26	110	BROOKS CREEK	270BC	54	4.333
27	16	WARREN	592WR	2278	4.129
28	208	METRO	719ME	1826	4.095
29	120	CORDREY	324CO	1647	4.075
30	9	STILSON	731SN	52	3.981
31	130	DAYTON BULK	725DY	1578	3.894
32	40	TAMINA	317TA	818	3.888
33	64	MCDONALD	477MD	2056	3.859
34	262	DAISETTA	744DA	695	3.847
35	8	ELIZABETH	122EL	739	3.839
36	300	Alden Bridge	770AL	1924	3.817
37	274	SOUR LAKE	104SL	434	3.797
38	23	CORRIGAN BULK	238CR	611	3.655
39	63	NECHES	193NE	1436	3.63
40	258	BENTWATER	520BW	2349	3.63
41	27	WEST END	86WED	504	3.589
42	10	CROCKETT	63CRK	610	3.575
43	14	JOHNSTOWN	345JT	2025	3.562
44	385	METRO	716ME	33	3.545
45	93	DAISETTA	743DA	370	3.422
46	272	WOODVILLE - TX	594WD	1195	3.417
47	322	WALDEN	560WD	757	3.387

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
48	347	LAKEVIEW	81LAV	1270	3.359
49	112	GEORGIA	670GE	989	3.343
50	188	DOUCETTE	570DC	1146	3.343
51	364	METRO	724ME	1194	3.267
52	255	WINFREE	341WN	747	3.265
53	397	PORT NECHES	45PTN	1034	3.248
54	7	JOHNSTOWN	544JT	3024	3.247
55	278	SPURLOCK	98SPU	729	3.218
56	107	WALDEN	564WD	2852	3.207
57	170	LACON	538LA	1483	3.206
58	298	STONEGATE	92STG	2023	3.2
59	46	TEMCO	628TE	411	3.182
60	213	FRONT STREET	307FR	491	3.173
61	34	ECHO	70ECH	1697	3.169
62	122	CALVERT	4CAL	2188	3.154
63	101	VIRGINIA	130VI	1186	3.153
64	245	RIVTRIN	268RV	2652	3.146
65	257	HANKAMER	206HA	698	3.089
66	159	WEST END	82WED	488	3.078
67	20	CLEVELAND - TX	425CV	4247	3.077
68	55	CLEVELAND - TX	405CV	832	3.03
69	190	WEST END	88WED	888	3.021
70	335	WYNTEX	633WT	875	2.958
71	106	BRIDGE CITY	362BD	1201	2.954
72	293	HANKAMER	207HA	777	2.945
73	228	METRO	722ME	1235	2.943
74	160	GRIMES	982GR	762	2.896
75	116	HEIGHTS	364HT	2625	2.896
76	22	MAGNOLIA AMES	711MG	814	2.828
77	77	HEIGHTS	363HT	1601	2.818
78	331	CROWDER	102CD	1767	2.808
79	118	HEIGHTS	365HT	664	2.783
80	45	PARKWAY	350PW	995	2.767
81	71	TAMINA	598TA	886	2.761
82	311	LACON	540LA	1414	2.753
83	251	NEW CANEY	337NC	849	2.753
84	222	LOVELLS LAKE	142LV	389	2.74
85	378	TAMINA	316TA	1086	2.731
86	29	RAYWOOD	74RAY	1109	2.726
87	227	ADAMS BAYOU	331AD	196	2.719
88	305	KOLBS	36KOL	1358	2.714
89	80	LACON	537LA	2266	2.696
90	384	CONROE BULK	576CN	1698	2.683
91	15	APOLLO	321AP	1949	2.609
92	73	NAVASOTA	969NA	1132	2.6
93	133	BAYSHORE	213BA	1783	2.563
94	291	HANKS	23HKS	1394	2.555
95	186	ECHO	71ECH	735	2.554
96	342	ORANGE	351ON	573	2.543
97	70	Alden Bridge	771AL	2158	2.524
98	69	GOSLIN	704GL	1680	2.515

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
99	66	ECHO	73ECH	784	2.497
100	302	KOUNTZE	453KT	725	2.462
101	132	SHEAWILL	536SH	1413	2.461
102	309	SILSBEE	461SI	1098	2.426
103	273	LOEB	17LOB	989	2.419
104	290	AMELIA BULK	181AM	2467	2.417
105	104	LINDBERGH	41LNB	1744	2.368
106	92	DOUCETTE	569DC	857	2.326
107	83	KOLBS	37KOL	719	2.281
108	266	GOSLIN	702GL	1651	2.26
109	207	NAVASOTA	905NA	2356	2.25
110	124	SOUR LAKE	105SL	1268	2.17
111	220	BEVIL	154BE	2728	2.163
112	231	MERLIN	374MR	560	2.161
113	145	GRIMES	981GR	325	2.105
114	113	HARDIN	35HDN	831	2.09
115	371	CONROE BULK	504CN	238	2.063
116	253	KOUNTZE BULK	432KT	898	2.052
117	323	SPLENDORA	307SP	1715	2.044
118	117	ECHO	72ECH	498	2.022
119	348	LONGMIRE	581LM	2973	2.019
120	281	OAK RIDGE - TX	744OK	3057	2.017
121	140	NORTH END	21NOE	1867	2.013
122	72	MAPLE	90MPL	334	2.006
123	395	WEST END	87WED	71	2
124	269	ELIZABETH	120EL	1357	1.999
125	201	PEE DEE	808PD	948	1.991
126	115	ELIZABETH	123EL	2621	1.97
127	287	RAYWOOD	73RAY	463	1.963
128	121	LOVELLS LAKE	141LV	730	1.942
129	21	CRYSTAL	567CR	1321	1.935
130	289	TAMINA	599TA	460	1.933
131	173	GOSLIN	709GL	3600	1.933
132	279	LILLARD	490LI	281	1.915
133	206	CONROE BULK	572CN	1438	1.911
134	174	MCDONALD	479MD	776	1.89
135	404	JIROU	77JRU	601	1.864
136	78	WYNTEX	634WT	1317	1.838
137	59	HEARNE	26HRN	551	1.829
138	413	HIGH ISLAND	228HI	5115	1.819
139	303	FORT WORTH	7FTW	1869	1.817
140	67	Alden Bridge	763AL	1436	1.815
141	223	PLANTATION - TX	546PL	866	1.809
142	31	MCLEWIS	380MC	2429	1.8
143	277	FLETCHER	456FL	834	1.781
144	74	CEDAR	698CE	21	1.762
145	38	OAK RIDGE - TX	743OK	1376	1.754
146	252	EGYPT	552EP	2098	1.748
147	292	MCLEWIS	381MC	1225	1.747
148	102	NEW CANEY	335NC	2581	1.733

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
149	N/A	NECHES	194NE	11	1.727
150	36	GROVES-EGSI	59GRO	1747	1.712
151	185	KOLBS	35KOL	1065	1.69
152	267	EGYPT	551EP	2605	1.686
153	315	WALDEN	562WD	353	1.683
154	226	NEW CANEY	334NC	6732	1.68
155	358	KOUNTZE	452KT	398	1.666
156	148	VIDOR	162VD	1859	1.661
157	85	BRIDGE CITY	361BD	1130	1.651
158	24	PORT ACRES SUB	67PTA	599	1.636
159	387	Alden Bridge	765AL	722	1.627
160	183	SILSBEE	462SI	799	1.622
161	345	GOSLIN	706GL	1701	1.614
162	249	SILSBEE	463SI	777	1.609
163	11	NECHES	197NE	139	1.604
164	3	FORT WORTH	99FTW	713	1.604
165	224	FLETCHER	457FL	1514	1.601
166	13	BEVIL	155BE	3960	1.593
167	98	VIRGINIA	129VI	568	1.592
168	299	METRO	718ME	2058	1.572
169	328	FOREST	759FO	441	1.571
170	321	HUNTSVILLE	611HU	1533	1.558
171	163	CORDREY	325CO	1560	1.558
172	54	HUNTSVILLE	607HU	3987	1.549
173	217	ROSEDALE - TX	153RS	767	1.541
174	39	BRIDGE CITY	360BD	1149	1.529
175	79	CONROE BULK	577CN	1956	1.526
176	356	PORT ACRES BULK	70PAS	764	1.526
177	372	MCHALE	113MC	618	1.515
178	62	YANKEE DOODLE	22YAN	2053	1.509
179	182	FOREST	750FO	660	1.505
180	232	LUMBERTON	441LU	4587	1.497
181	50	OAK RIDGE - TX	741OK	829	1.497
182	326	WEST ORANGE	393WO	1066	1.471
183	86	DAYTON BULK	726DY	1573	1.44
184	75	HUMPHREY - TX	107HM	868	1.435
185	177	BENTWATER	521BW	2102	1.426
186	261	GOSLIN	707GL	2989	1.416
187	200	MCHALE	111MC	656	1.398
188	242	CROWDER	105CD	1262	1.376
189	178	NEW CANEY	336NC	4915	1.371
190	125	PANSY	184PS	439	1.355
191	138	EASTGATE	781EG	1121	1.34
192	402	CONAIR	515CN	831	1.339
193	229	NORTH SILSBEE	472NS	328	1.338
194	37	CHEEK	159CH	548	1.332
195	57	JOHNSTOWN	343JT	1554	1.324
196	334	CHEEK	165CH	120	1.3
197	82	DOUCETTE	568DC	584	1.298
198	153	RAYWOOD	75RAY	184	1.288

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
199	100	HIGH ISLAND	226HI	106	1.283
200	142	BRIARCLIFF	30BRC	2408	1.278
201	89	METRO	723ME	1245	1.277
202	312	HANKS	25HKS	920	1.273
203	367	CONAIR	516CN	308	1.263
204	134	HUNTSVILLE	610HU	1793	1.261
205	171	DAYTON BULK	724DY	2257	1.249
206	162	LACON	539LA	2157	1.238
207	256	BATSON	53BAT	918	1.235
208	84	FOREST	753FO	1400	1.211
209	131	ELIZABETH	121EL	1463	1.201
210	268	DOBBIN	920DO	1970	1.196
211	129	GRIMES	883GR	903	1.182
212	149	VIDOR	161VD	577	1.177
213	250	NORTH SILSBEE	471NS	1120	1.176
214	202	GOSLIN	708GL	2226	1.169
215	391	TRAVIS	11TRV	26	1.154
216	403	Alden Bridge	764AL	1257	1.154
217	238	WINFREE	340WN	483	1.149
218	198	TANGLEWOOD	137TG	1506	1.141
219	337	METRO	721ME	692	1.136
220	215	LINCOLN	16LCN	290	1.134
221	379	ADAMS BAYOU	332AD	532	1.128
222	295	FORT WORTH	12FTW	1432	1.118
223	276	WALDEN	563WD	1975	1.114
224	176	GOSLIN	705GL	1631	1.111
225	369	HAMPTON	157HA	11	1.091
226	141	PLANTATION - TX	545PL	1122	1.084
227	205	MEMORIAL	281ML	832	1.078
228	136	CLEVELAND - TX	406CV	1826	1.076
229	307	CROWDER	104CD	1674	1.069
230	210	WINSHIRE	241WS	1080	1.067
231	97	CLEVELAND - TX	404CV	1880	1.064
232	41	PORT ACRES SUB	68PTA	1272	1.061
233	90	NEW CANEY	304NC	1864	1.04
234	179	LINDBERGH	40LNB	1592	1.033
235	354	STONEGATE	91STG	1387	1.025
236	394	KOUNTZE BULK	435KT	50	1.02
237	5	CRYSTAL	570CR	1193	1.008
238	49	METRO	720ME	549	1.002
239	407	TRAVIS	8TRV	23	1
240	383	YANKEE DOODLE	25YAN	176	1
241	196	HEIGHTS	360HT	287	0.993
242	187	TANGLEWOOD	134TG	2237	0.99
243	313	FRONT STREET	310FR	543	0.972
244	175	VIDOR	163VD	1685	0.969
245	329	CORDREY	327CO	949	0.944
246	284	STOWELL	232ST	1165	0.943
247	244	CONAIR	511CN	1631	0.941
248	254	ROSEDALE - TX	150RS	125	0.936

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
249	259	VIWAY	682VI	1702	0.9
250	167	BRIARCLIFF	32BRC	1289	0.891
251	144	PANSY	185PS	1333	0.873
252	212	MCHALE	110MC	1033	0.861
253	168	ROSEDALE - TX	151RS	1279	0.857
254	233	VIRGINIA	132VI	591	0.854
255	332	CENTRAL	133CE	1611	0.845
256	297	HAMPTON	158HA	1126	0.839
257	157	HANKS	22HKS	1113	0.819
258	241	ROSEDALE - TX	152RS	748	0.817
259	105	MCHALE	112MC	818	0.796
260	95	WOODVILLE - TX	593WD	716	0.796
261	30	WINFREE	342WN	1209	0.773
262	193	LINDBERGH	43LNB	781	0.771
263	128	CONROE BULK	574CN	2370	0.768
264	58	DAYTON BULK	723DY	1090	0.764
265	214	NEW CANEY	338NC	1494	0.764
266	366	GROVES-EGSI	63GRO	1313	0.763
267	88	TYRRELL	37TYR	496	0.758
268	26	BENTWATER	522BW	736	0.751
269	164	VIWAY	681VI	897	0.745
270	240	CROCKETT	65CRK	551	0.733
271	408	WEST END	80WED	269	0.732
272	318	TANGLEWOOD	135TG	675	0.721
273	301	CROWDER	103CD	1450	0.717
274	365	SOMERVILLE	126SO	846	0.68
275	239	CHINA	93CHI	1300	0.675
276	60	CALDWELL INDUSTRIAL	138CI	741	0.675
277	172	MERLIN	375MR	864	0.663
278	306	CONROE BULK	505CN	1278	0.656
279	204	BRIARCLIFF	31BRC	864	0.648
280	340	APRIL	591AP	1667	0.636
281	151	CHEEK	160CH	712	0.633
282	230	BEVIL	156BE	624	0.625
283	288	NAVASOTA	904NA	1514	0.589
284	320	MCDONALD	476MD	1114	0.585
285	169	APRIL	590AP	1597	0.58
286	324	SOUTH LIBERTY	714SL	115	0.574
287	184	PANORAMA	525PA	1439	0.573
288	181	DOBBIN	519DO	2110	0.569
289	280	CONAIR	512CN	1234	0.567
290	296	BRIDGE CITY	363BD	2201	0.563
291	310	DAYTON BULK	727DY	791	0.555
292	161	HUNTSVILLE	608HU	3428	0.555
293	350	CENTRAL	130CE	737	0.554
294	265	VIRGINIA	131VI	1364	0.548
295	243	SARATOGA	761SA	434	0.544
296	123	BAYSHORE	212BA	48	0.542
297	216	JIROU	75JRU	60	0.533
298	139	GOSLIN	703GL	1647	0.532

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
299	126	LONGMIRE	584LM	1416	0.53
300	248	LONGMIRE	582LM	1441	0.523
301	53	FEDERAL	801FE	262	0.523
302	32	WESTSIDE	112WS	379	0.522
303	361	STONEGATE	90STG	1041	0.509
304	327	HANKS	24HKS	815	0.508
305	103	GOREE	682GR	1670	0.505
306	195	SOMERVILLE	127SO	492	0.502
307	294	CLEVELAND - TX	403CV	1501	0.491
308	155	OAK RIDGE - TX	740OK	1294	0.488
309	381	SHEAWILL	535SH	692	0.464
310	234	WEST ORANGE	392WO	691	0.463
311	325	WEST END	85WED	514	0.455
312	264	MEMORIAL	280ML	944	0.454
313	285	VIDOR	164VD	781	0.452
314	143	MANCHESTER	67MAN	973	0.445
315	339	WINSHIRE	240WS	959	0.443
316	304	BAYOU FANNETT	250BY	324	0.438
317	353	BAYSHORE	211BA	1061	0.437
318	108	EGYPT	550EP	1102	0.432
319	135	TEMCO	627TE	934	0.418
320	189	ORANGE	350ON	939	0.417
321	94	MCLEWIS	382MC	851	0.405
322	344	MCDONALD	478MD	628	0.404
323	336	FOREST	751FO	3131	0.383
324	271	CONROE BULK	506CN	2161	0.378
325	158	WYNTEX	632WT	889	0.376
326	260	AMELIA BULK	180AM	1422	0.368
327	359	GROVES-EGSI	62GRO	1562	0.358
328	191	CONROE BULK	507CN	2214	0.352
329	180	OAK RIDGE - TX	745OK	527	0.351
330	19	AMELIA BULK	182AM	1232	0.348
331	380	NORTH END	29NOE	342	0.333
332	314	CONROE BULK	573CN	15	0.333
333	343	FOREST	752FO	357	0.325
334	137	APRIL	592AP	1133	0.322
335	165	JOHNSTOWN	342JT	736	0.322
336	25	PORT NECHES	46PTN	1300	0.318
337	392	YANKEE DOODLE	24YAN	236	0.305
338	152	NORTH END	28NOE	172	0.291
339	209	PARKWAY	782PW	352	0.284
340	154	LONGMIRE	580LM	2397	0.283
341	399	HIGH ISLAND	227HI	220	0.268
342	76	HUMPHREY - TX	106HM	1051	0.261
343	91	STOWELL	231ST	1038	0.257
344	28	CONAIR	513CN	1708	0.254
345	393	JIROU	76JRU	170	0.253
346	109	Alden Bridge	762AL	5161	0.247
347	263	CROCKETT	195CR	971	0.243
348	355	LAKEVIEW	80LAV	686	0.236

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
349	275	MANCHESTER	66MAN	2080	0.235
350	319	METRO	717ME	222	0.23
351	360	CONAIR	514CN	1217	0.223
352	377	FOREST	754FO	1488	0.214
353	247	CROCKETT	64CRK	1011	0.207
354	338	DAISETTA	741DA	253	0.202
355	368	LINCOLN	15LCN	293	0.201
356	56	KOLBS	34KOL	1064	0.197
357	351	FRONT STREET	308FR	360	0.194
358	81	GROVES-EGSI	61GRO	949	0.191
359	6	PORT ACRES SUB	69PTA	724	0.191
360	150	TANGLEWOOD	136TG	622	0.183
361	33	LONGMIRE	583LM	1806	0.162
362	17	WESTSIDE	111WS	327	0.147
363	235	MAYHAW	673MA	1860	0.141
364	61	ADAMS BAYOU	330AD	154	0.136
365	236	TRAVIS	13TRV	39	0.128
366	119	YANKEE DOODLE	23YAN	542	0.125
367	411	FLATLAND	530CM	32	0.125
368	225	Alden Bridge	767AL	2776	0.119
369	386	OAK RIDGE - TX	742OK	238	0.118
370	349	BRIARCLIFF	33BRC	301	0.116
371	221	Alden Bridge	768AL	1531	0.11
372	357	Alden Bridge	769AL	1148	0.105
373	362	MANCHESTER	65MAN	58	0.103
374	409	FLATLAND	528CM	30	0.1
375	N/A	INDEPENDENCE - TX	945ID	10	0.1
376	389	TESCO	36TSC	80	0.1
377	374	FOREST	758FO	308	0.094
378	352	CROCKETT	198CR	220	0.091
379	12	TRAVIS	14TRV	11	0.091
380	390	HUMPHREY - TX	108HM	46	0.087
381	382	NORTH END	26NOE	301	0.086
382	203	Alden Bridge	766AL	1665	0.082
383	44	FOREST	755FO	1375	0.081
384	192	WESTSIDE	113WS	273	0.077
385	96	NEW CANEY	333NC	3908	0.075
386	283	CENTRAL	132CE	1821	0.074
387	346	STONEGATE	93STG	2070	0.074
388	376	SPURLOCK	99SPU	782	0.073
389	197	JIROU	78JRU	300	0.07
390	52	HEARNE	28HRN	30	0.067
391	363	SPLENDORA	308SP	4128	0.066
392	286	LINDBERGH	42LNB	311	0.061
393	370	MAPLE	91MPL	204	0.059
394	270	PARKDALE	176PR	706	0.057
395	111	GOREE	681GR	656	0.05
396	401	CONROE BULK	575CN	894	0.041
397	330	CENTRAL	131CE	979	0.04
398	400	PARKWAY	351PW	586	0.039

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2022 SAIFI Ranking	2021 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIFI Value
399	87	GOSLIN	701GL	876	0.035
400	373	PARKDALE	171PR	694	0.023
401	375	CROCKETT	60CRK	205	0.015
402	199	GOSLIN	710GL	952	0.007
403	398	NORTH END	27NOE	56	0
404	405	PARKDALE	172PR	24	0
405	406	TRAVIS	6TRV	26	0
406	308	TYRRELL	38TYR	50	0
407	410	FLATLAND	529CM	23	0
408	412	SPEEDWAY	917SW	50	0
409	246	FOREST	757FO	290	0
410	396	METRO	715ME	38	0

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

Total Number of Feeders

With 10 or more Customers

410

Add or Delete Rows as Necessary

Entergy Texas, Inc.

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
1	73	STILSON	733SN	85	2541.8
2	26	HEIGHTS	362HT	137	2104.8
3	34	PEE DEE	809PD	1672	1941.3
4	95	PEE DEE	806PD	3113	1559.6
5	5	CRYSTAL	566CR	1926	1241.6
6	63	CLEVELAND - TX	426CV	3060	1232.8
7	372	MAYHAW	671MA	123	1179.9
8	1	FORT WORTH	567FT	524	1170
9	44	RIVTRIN	269RV	3017	1132.6
10	176	TRANSCO	48TCO	220	1046.1
11	15	CHEEK	166CH	376	978.5
12	56	ECHO	70ECH	1697	961.5
13	413	HIGH ISLAND	228HI	5115	908.2
14	402	WEST END	87WED	71	878.1
15	2	CEDAR	698CE	21	869.8
16	47	NECHES	193NE	1436	852.5
17	53	ECHO	73ECH	784	837.1
18	6	STILSON	731SN	52	837
19	183	CHINA	92CHI	669	825.8
20	164	BROOKS CREEK	270BC	54	813.6
21	9	TAMINA	317TA	818	804.4
22	157	CORRIGAN BULK	239CR	496	800.3
23	24	HEIGHTS	363HT	1601	798.9
24	66	CORDREY	324CO	1647	781.7
25	89	Alden Bridge	771AL	2158	772.6
26	330	WEST END	82WED	488	760.1
27	99	DAISETTA	743DA	370	732.9
28	83	WARREN	506WR	1356	712.3
29	18	KICKAPOO	251KP	1355	706.9
30	86	BAYSHORE	213BA	1783	696.5
31	3	PORT ACRES SUB	67PTA	599	678.1
32	232	LOVELLS LAKE	141LV	730	677.5
33	13	CLEVELAND - TX	425CV	4247	674.7
34	267	STONEGATE	92STG	2023	673.8
35	10	TAMINA	598TA	886	668.9
36	100	LOEB	18LOB	554	658.9
37	51	CROCKETT	61CRK	99	655.3
38	302	DAISETTA	744DA	695	642
39	79	GEORGIA	670GE	989	640.9
40	75	TEMCO	628TE	411	629.8
41	136	DAYTON BULK	725DY	1578	626.6
42	213	SOUR LAKE	104SL	434	618.7
43	141	STOWELL	233ST	703	612.9
44	258	WINFREE	341WN	747	600.6
45	254	ECHO	71ECH	735	599.5
46	133	OILLA	345OI	1521	591.3
47	64	ELIZABETH	122EL	739	581.9

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
48	208	HANKAMER	207HA	777	570.3
49	19	MAGNOLIA AMES	711MG	814	566
50	206	RIVTRIN	268RV	2652	564.2
51	317	CORDREY	326CO	1217	561.6
52	20	JOHNSTOWN	544JT	3024	556.1
53	113	LACON	537LA	2266	553.6
54	58	CALVERT	6CAL	1668	549.7
55	50	JOHNSTOWN	345JT	2025	546.8
56	269	LOEB	17LOB	989	540.1
57	226	HANKAMER	206HA	698	538
58	38	HEIGHTS	365HT	664	531.4
59	194	GOSLIN	704GL	1680	530.1
60	346	CONROE BULK	504CN	238	516.9
61	107	LOVELLS LAKE	142LV	389	514.4
62	140	MERLIN	374MR	560	513.5
63	43	WARREN	592WR	2278	505.2
64	31	RAYWOOD	74RAY	1109	503.9
65	362	Alden Bridge	770AL	1924	496.5
66	90	PARKWAY	350PW	995	493.2
67	243	LACON	540LA	1414	488.7
68	174	HARDIN	35HDN	831	483
69	46	CRYSTAL	567CR	1321	481.5
70	151	LACON	538LA	1483	478.3
71	259	GRIMES	982GR	762	477.2
72	191	FRONT STREET	307FR	491	474.7
73	7	CORRIGAN BULK	238CR	611	472.8
74	252	BENTWATER	520BW	2349	471.5
75	374	TAMINA	316TA	1086	455.9
76	88	LINDBERGH	41LNB	1744	453.5
77	278	WOODVILLE - TX	594WD	1195	447.1
78	307	FORT WORTH	7FTW	1869	446.3
79	212	WALDEN	563WD	1975	444.3
80	283	STONEGATE	91STG	1387	424.1
81	219	ADAMS BAYOU	331AD	196	422.2
82	199	SHEAWILL	536SH	1413	422
83	156	DOUCETTE	570DC	1146	421.8
84	373	CONROE BULK	576CN	1698	419.2
85	61	WALDEN	564WD	2852	407.4
86	214	HANKS	23HKS	1394	406.9
87	87	APOLLO	320AP	2211	405.2
88	74	PEE DEE	808PD	948	404.6
89	186	HEIGHTS	364HT	2625	403.5
90	62	HUNTSVILLE	600HU	2312	402.3
91	332	SILSBEE	461SI	1098	400.7
92	32	YANKEE DOODLE	22YAN	2053	400.7
93	342	ORANGE	351ON	573	396.3
94	54	APOLLO	321AP	1949	390
95	325	SILSBEE	462SI	799	388.7
96	39	ELIZABETH	121EL	1463	379.1
97	393	METRO	716ME	33	372
98	203	ELIZABETH	120EL	1357	369.3

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
99	225	RAYWOOD	73RAY	463	367.6
100	266	NEW CANEY	334NC	6732	367.4
101	22	BEVIL	155BE	3960	366.4
102	224	EGYPT	551EP	2605	363.9
103	231	MAPLE	90MPL	334	357.6
104	201	METRO	719ME	1826	357.3
105	229	LINDBERGH	40LNB	1592	354.5
106	228	SPLENDORA	309SP	2328	351.8
107	123	SOUR LAKE	105SL	1268	345.4
108	246	WEST END	88WED	888	343.8
109	117	FOREST	750FO	660	343.3
110	171	GRIMES	883GR	903	342.8
111	298	TAMINA	599TA	460	341.8
112	357	LAKEVIEW	81LAV	1270	341.4
113	193	NEW CANEY	337NC	849	340.8
114	161	KOLBS	35KOL	1065	338.5
115	295	WALDEN	560WD	757	337.9
116	304	CROWDER	102CD	1767	333.7
117	339	KOUNTZE	453KT	725	331.7
118	49	HIGH ISLAND	226HI	106	331.7
119	291	METRO	722ME	1235	330.1
120	188	EASTGATE	781EG	1121	328.4
121	93	JOHNSTOWN	343JT	1554	327.8
122	216	MCDONALD	479MD	776	317.5
123	68	CLEVELAND - TX	405CV	832	309.5
124	234	NAVASOTA	905NA	2356	303.8
125	163	VIRGINIA	129VI	568	302.6
126	301	WALDEN	562WD	353	300.5
127	45	WEST END	86WED	504	299.3
128	245	RAYWOOD	75RAY	184	296.7
129	358	FOREST	759FO	441	296.3
130	129	CLEVELAND - TX	404CV	1880	292.2
131	57	DAYTON BULK	726DY	1573	291.5
132	153	KOLBS	37KOL	719	289.6
133	125	GRIMES	981GR	325	285.7
134	124	MCLEWIS	380MC	2429	285.2
135	159	MCDONALD	477MD	2056	283
136	239	PANORAMA	525PA	1439	280.3
137	55	PORT ACRES SUB	68PTA	1272	279.9
138	277	AMELIA BULK	181AM	2467	279.4
139	48	BRIDGE CITY	362BD	1201	277.3
140	257	MCLEWIS	381MC	1225	274
141	335	GOSLIN	706GL	1701	273.2
142	282	CORDREY	327CO	949	272.6
143	371	ADAMS BAYOU	332AD	532	272.4
144	N/A	NECHES	194NE	11	266.1
145	189	CONROE BULK	572CN	1438	260.4
146	207	WINFREE	340WN	483	260
147	352	LONGMIRE	581LM	2973	259.2
148	294	ORANGE	352ON	1225	259.1

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
149	395	TRAVIS	11TRV	26	258.6
150	155	VIRGINIA	132VI	591	255.9
151	27	PLANTATION - TX	545PL	1122	249.9
152	215	TANGLEWOOD	137TG	1506	249.3
153	29	CALVERT	4CAL	2188	248.1
154	103	PLANTATION - TX	546PL	866	243.5
155	160	PANSY	184PS	439	242.8
156	251	CONROE BULK	574CN	2370	239.9
157	248	BEVIL	154BE	2728	239.6
158	144	FOREST	753FO	1400	237.6
159	109	CONROE BULK	577CN	1956	237.2
160	180	BRIARCLIFF	30BRC	2408	236.7
161	380	HAMPTON	157HA	11	234.8
162	264	DOUCETTE	569DC	857	233.6
163	110	KOUNTZE BULK	432KT	898	233.5
164	134	BRIDGE CITY	360BD	1149	233.1
165	310	LILLARD	490LI	281	232.4
166	311	STOWELL	232ST	1165	232
167	111	ECHO	72ECH	498	231.3
168	280	NAVASOTA	969NA	1132	230.9
169	138	WYNTEX	634WT	1317	229
170	121	VIDOR	163VD	1685	228.9
171	350	PORT ACRES BULK	70PAS	764	227.4
172	165	CLEVELAND - TX	406CV	1826	226.3
173	119	VIDOR	161VD	577	224.6
174	96	OAK RIDGE - TX	743OK	1376	224.3
175	11	FORT WORTH	99FTW	713	223.7
176	146	TYRRELL	37TYR	496	223.1
177	142	DAYTON BULK	724DY	2257	222
178	391	Alden Bridge	765AL	722	221.9
179	247	EGYPT	552EP	2098	220.6
180	328	SPLENDORA	307SP	1715	217.5
181	148	APRIL	590AP	1597	217
182	16	HEARNE	26HRN	551	213.3
183	288	HANKS	25HKS	920	213.2
184	274	CROCKETT	65CRK	551	213.2
185	169	MCHALE	111MC	656	212.1
186	377	METRO	724ME	1194	210.3
187	329	WYNTEX	633WT	875	210.1
188	334	METRO	718ME	2058	210.1
189	285	OAK RIDGE - TX	744OK	3057	207.4
190	168	GOSLIN	709GL	3600	205.5
191	122	CHINA	93CHI	1300	204.8
192	364	GROVES-EGSI	63GRO	1313	204.6
193	175	CORDREY	325CO	1560	203.8
194	40	ROSEDALE - TX	153RS	767	203.6
195	341	STONEGATE	90STG	1041	203.5
196	97	BRIDGE CITY	361BD	1130	202.8
197	192	SPURLOCK	98SPU	729	202.5
198	185	ROSEDALE - TX	151RS	1279	202

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
199	21	BENTWATER	522BW	736	202
200	205	ROSEDALE - TX	152RS	748	195.9
201	272	LUMBERTON	441LU	4587	194.9
202	42	DOUCETTE	568DC	584	194.1
203	299	FLETCHER	456FL	834	194
204	154	BENTWATER	521BW	2102	190.8
205	105	NEW CANEY	335NC	2581	187.7
206	397	PORT NECHES	45PTN	1034	187.3
207	217	VIDOR	162VD	1859	182.7
208	279	BATSON	53BAT	918	182.1
209	33	CHEEK	159CH	548	181.1
210	263	DOBBIN	920DO	1970	178.5
211	211	HEIGHTS	360HT	287	176.1
212	115	NORTH END	21NOE	1867	175.7
213	196	VIRGINIA	130VI	1186	173.9
214	268	GOSLIN	702GL	1651	173.5
215	120	BEVIL	156BE	624	173.2
216	238	MEMORIAL	281ML	832	172.9
217	355	FRONT STREET	310FR	543	172.9
218	351	KOUNTZE	452KT	398	171.5
219	92	BAYSHORE	212BA	48	170.8
220	367	SOMERVILLE	126SO	846	169
221	400	CONAIR	515CN	831	167.5
222	348	CENTRAL	130CE	737	165.6
223	220	SILSBEE	463SI	777	165.4
224	172	PANSY	185PS	1333	164.9
225	177	Alden Bridge	763AL	1436	164.3
226	300	KOLBS	36KOL	1358	163.4
227	132	MERLIN	375MR	864	163.1
228	145	HANKS	22HKS	1113	161.5
229	297	CENTRAL	133CE	1611	160.5
230	67	MCHALE	112MC	818	159.4
231	230	WEST END	85WED	514	159.4
232	198	FORT WORTH	12FTW	1432	156.4
233	265	TANGLEWOOD	134TG	2237	156.2
234	363	CONAIR	516CN	308	155.6
235	149	OAK RIDGE - TX	740OK	1294	154.9
236	4	CRYSTAL	570CR	1193	153.3
237	204	CONAIR	512CN	1234	148
238	236	CROWDER	105CD	1262	147.9
239	227	NORTH SILSBEE	471NS	1120	147.4
240	184	NORTH SILSBEE	472NS	328	145.7
241	321	APRIL	591AP	1667	145.6
242	233	LACON	539LA	2157	145.3
243	200	BRIARCLIFF	31BRC	864	144.5
244	65	GROVES-EGSI	59GRO	1747	144.1
245	91	ELIZABETH	123EL	2621	143.6
246	368	MCHALE	113MC	618	143.2
247	318	CROWDER	103CD	1450	143.2
248	23	NECHES	197NE	139	141.3

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
249	195	BRIARCLIFF	32BRC	1289	140.9
250	41	CROCKETT	63CRK	610	137.1
251	260	WINSHIRE	241WS	1080	135.1
252	98	NEW CANEY	304NC	1864	132.7
253	347	METRO	721ME	692	131
254	30	DAYTON BULK	723DY	1090	130
255	82	OAK RIDGE - TX	741OK	829	128.6
256	331	BAYSHORE	211BA	1061	127.5
257	308	HUNTSVILLE	611HU	1533	126.5
258	411	FLATLAND	530CM	32	126.1
259	244	FLETCHER	457FL	1514	124.4
260	242	DOBBIN	519DO	2110	123
261	250	SARATOGA	761SA	434	120.8
262	104	MCHALE	110MC	1033	120.3
263	316	SOUTH LIBERTY	714SL	115	119.9
264	81	WESTSIDE	112WS	379	117.6
265	37	WINFREE	342WN	1209	115.1
266	178	CALDWELL INDUSTRIAL	138CI	741	112.6
267	336	MCDONALD	476MD	1114	106.9
268	338	NEW CANEY	338NC	1494	105.8
269	240	HANKS	24HKS	815	105.5
270	190	VIWAY	682VI	1702	104.7
271	315	HAMPTON	158HA	1126	104.7
272	306	JIROU	75JRU	60	104.4
273	17	ADAMS BAYOU	330AD	154	104
274	221	MANCHESTER	67MAN	973	103.8
275	256	CROWDER	104CD	1674	103.3
276	210	NEW CANEY	336NC	4915	102.5
277	127	HUNTSVILLE	607HU	3987	101.6
278	403	KOUNTZE BULK	435KT	50	101.6
279	261	HUNTSVILLE	608HU	3428	101.6
280	112	EGYPT	550EP	1102	99.5
281	319	DAYTON BULK	727DY	791	99.4
282	284	VIRGINIA	131VI	1364	97.3
283	404	JIROU	77JRU	601	96.8
284	162	WOODVILLE - TX	593WD	716	95.6
285	337	LINCOLN	16LCN	290	95.1
286	376	LAKEVIEW	80LAV	686	95.1
287	106	CONAIR	511CN	1631	91.9
288	401	Alden Bridge	764AL	1257	89.6
289	290	BRIDGE CITY	363BD	2201	89.4
290	235	LONGMIRE	582LM	1441	89.3
291	181	CONROE BULK	573CN	15	88.7
292	356	FOREST	752FO	357	88.7
293	187	CONROE BULK	507CN	2214	87.8
294	296	CONROE BULK	506CN	2161	85.5
295	167	TEMCO	627TE	934	83.6
296	340	CHEEK	165CH	120	83.1
297	320	NAVASOTA	904NA	1514	82.9
298	150	METRO	723ME	1245	82.5

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
299	275	AMELIA BULK	180AM	1422	81.7
300	70	PARKWAY	782PW	352	81.4
301	223	VIDOR	164VD	781	80.7
302	289	GOSLIN	705GL	1631	79.8
303	173	SOMERVILLE	127SO	492	78.4
304	322	BAYOU FANNETT	250BY	324	78.2
305	84	HUMPHREY - TX	107HM	868	76.9
306	312	WINSHIRE	240WS	959	76.8
307	249	GOSLIN	708GL	2226	76.5
308	128	WEST ORANGE	392WO	691	75.9
309	28	MCLEWIS	382MC	851	75.2
310	262	CLEVELAND - TX	403CV	1501	74.2
311	387	SHEAWILL	535SH	692	74.1
312	25	AMELIA BULK	182AM	1232	72.4
313	182	APRIL	592AP	1133	71.3
314	255	LINDBERGH	43LNB	781	71.2
315	309	TANGLEWOOD	135TG	675	71
316	209	CONROE BULK	505CN	1278	68.9
317	126	LONGMIRE	584LM	1416	66.7
318	349	GROVES-EGSI	62GRO	1562	66.1
319	292	GOSLIN	703GL	1647	65.9
320	139	CHEEK	160CH	712	65.6
321	14	STOWELL	231ST	1038	65
322	118	WYNTEX	632WT	889	64
323	80	GROVES-EGSI	61GRO	949	62.6
324	108	VIWAY	681VI	897	62.4
325	147	ORANGE	350ON	939	62.2
326	222	MANCHESTER	66MAN	2080	61.3
327	241	MEMORIAL	280ML	944	60.8
328	179	FEDERAL	801FE	262	59.7
329	407	TRAVIS	8TRV	23	59.2
330	197	WEST ORANGE	393WO	1066	58.3
331	271	GOSLIN	707GL	2989	54.6
332	293	JOHNSTOWN	342JT	736	54.5
333	385	FOREST	754FO	1488	53.9
334	218	ROSEDALE - TX	150RS	125	52.7
335	408	WEST END	80WED	269	52.4
336	273	NORTH END	28NOE	172	49.3
337	384	FOREST	751FO	3131	47.8
338	382	YANKEE DOODLE	25YAN	176	47.5
339	170	HUNTSVILLE	610HU	1793	46.7
340	36	PORT NECHES	46PTN	1300	46.5
341	114	KOLBS	34KOL	1064	44.3
342	396	HIGH ISLAND	227HI	220	44.1
343	324	MCDONALD	478MD	628	43.9
344	152	GOREE	682GR	1670	42
345	378	JIROU	76JRU	170	41.7
346	102	LONGMIRE	580LM	2397	41.6
347	77	CONAIR	513CN	1708	41.5
348	71	HUMPHREY - TX	106HM	1051	40.7

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
349	76	LONGMIRE	583LM	1806	39.9
350	135	HEARNE	28HRN	30	39.5
351	35	TANGLEWOOD	136TG	622	38.3
352	360	BRIARCLIFF	33BRC	301	36.3
353	398	NORTH END	29NOE	342	35.8
354	286	DAISETTA	741DA	253	34.9
355	345	Alden Bridge	769AL	1148	34.5
356	369	CONAIR	514CN	1217	32.5
357	60	PORT ACRES SUB	69PTA	724	32.5
358	137	Alden Bridge	762AL	5161	32
359	8	TRAVIS	14TRV	11	31.5
360	78	OAK RIDGE - TX	745OK	527	29.9
361	409	FLATLAND	528CM	30	29.7
362	85	METRO	720ME	549	28.4
363	333	CROCKETT	198CR	220	24.7
364	N/A	INDEPENDENCE - TX	945ID	10	24.5
365	237	LINDBERGH	42LNB	311	23.9
366	323	METRO	717ME	222	23.6
367	359	FRONT STREET	308FR	360	23.4
368	12	WESTSIDE	111WS	327	23.3
369	392	YANKEE DOODLE	24YAN	236	22.6
370	72	YANKEE DOODLE	23YAN	542	22.1
371	69	CROCKETT	64CRK	1011	20.9
372	130	CROCKETT	195CR	971	20.2
373	166	MAYHAW	673MA	1860	17.8
374	386	MAPLE	91MPL	204	17.6
375	381	TESCO	36TSC	80	17.5
376	375	Alden Bridge	766AL	1665	17.3
377	314	STONEGATE	93STG	2070	17.3
378	270	Alden Bridge	768AL	1531	17
379	281	Alden Bridge	767AL	2776	15.9
380	390	OAK RIDGE - TX	742OK	238	14.5
381	326	MANCHESTER	65MAN	58	13.5
382	383	HUMPHREY - TX	108HM	46	12.3
383	52	NEW CANEY	333NC	3908	10
384	202	FOREST	755FO	1375	9.9
385	370	SPURLOCK	99SPU	782	9.5
386	276	CENTRAL	132CE	1821	9.1
387	287	CENTRAL	131CE	979	9.1
388	361	LINCOLN	15LCN	293	8.8
389	394	CONROE BULK	575CN	894	8.8
390	366	SPLENDORA	308SP	4128	8.7
391	379	NORTH END	26NOE	301	8.5
392	313	JIROU	78JRU	300	8.4
393	344	PARKDALE	176PR	706	7.7
394	399	PARKWAY	351PW	586	7.5
395	365	FOREST	758FO	308	7.3
396	94	GOSLIN	701GL	876	6.7
397	101	TRAVIS	13TRV	39	6.6
398	116	WESTSIDE	113WS	273	5.9

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2022 SAIDI Ranking	2021 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2022 SAIDI Value
399	59	GOREE	681GR	656	5.5
400	354	GOSLIN	710GL	952	4.7
401	343	PARKDALE	171PR	694	1.7
402	353	CROCKETT	60CRK	205	1.5
403	389	NORTH END	27NOE	56	0
404	405	PARKDALE	172PR	24	0
405	406	TRAVIS	6TRV	26	0
406	131	TYRRELL	38TYR	50	0
407	410	FLATLAND	529CM	23	0
408	412	SPEEDWAY	917SW	50	0
409	303	FOREST	757FO	290	0
410	388	METRO	715ME	38	0

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

INTERRUPTION CAUSES

Provide the percentage of interruptions attributable to each cause.

2022 Reporting Year

Causes of Forced Interruptions	Percentage
Weather (Including Lightning)	13.90%
Vegetation	15.36%
Animals and Birds	1.90%
People (Including cars and farm equip)	9.48%
Utility-owned Equipment	32.32%
Other	21.07%
Unknown	5.97%

**ADDENDUM OF ENTERGY TEXAS, INC. TO ITS
SERVICE QUALITY REPORT FOR THE 2022 REPORTING YEAR**

In compliance with the Commission's January 25, 2022, Order in Docket No. 51966, *Agreed Notice of Violation and Settlement Agreement Relating to Entergy Texas, Inc.'s Violation of PURA § 38.005 and 16 TAC § 25.52, Concerning Reliability and Continuity of Service*, Entergy Texas, Inc. (ETI) files the following addendum:

I. Actions to Bring Feeders in Violation of System-Wide Standards into Compliance

Docket No. 51966 Order at Ordering Paragraph 5 provides:

Entergy must file a report regarding actions to bring feeders that are found to be in violation of any of its system-wide service quality standards for two or more consecutive years into compliance with the Commission's service quality standards, and this report must be filed as an addendum to Entergy's required annual service quality reports, as prescribed by 16 TAC § 25.81.

ETI Response:

ETI did not have any feeders found to be in violation of the system-wide service quality standards for two or more consecutive years as determined for reporting year 2019. On January 23, 2023, ETI received a Finding of Violation for reporting years 2020 and 2021 from the Commission's Division of Compliance and Enforcement ("DICE") and is currently working with DICE to finalize a settlement agreement. ETI will supplement this addendum as necessary.