



Control Number: 54565



Item Number: 997

TO: PUC DOCKET NO 54565


RECEIVED  
2023 FEB 21 AM 11:30

PUBLIC UTILITY COMMISSION  
CLERK

I WOULD LIKE TO SUBMIT ~~THESE~~ INVESTIGATION REPORTS DONE BY TCEQ SHOWING THAT CSWR OF TEXAS HAS SEVERAL VIOLATIONS THAT IS MY UNDERSTANDING, HAVE NOT BEEN COMPLETELY ADDRESS.

HOW CAN CSWR REQUEST A NEARLY 300% RATE INCREASE WHEN THEY MAY NOT BE IN TOTAL COMPLIANCE WITH THE STATE OF TEXAS REQUIREMENTS FOR A WATER COMPANY.

SINCERELY



2/16/23

ADDRESS

2919 CR 3990

WIKASBORO, TX 75484

PWS\_2500019\_CP\_20211101\_Investigation  
**Texas Commission on Environmental Quality**  
**Investigation Report**

The TCEQ is committed to accessibility. If you need assistance in accessing this document, please contact [oce@tceq.texas.gov](mailto:oce@tceq.texas.gov)

**Customer: CSWR-TEXAS UTILITY OPERATING COMPANY, LLC**  
**Customer Number: CN605844786**

---

**Regulated Entity Name: BIG WOOD SPRINGS WATER SYSTEM**

**Regulated Entity Number: RN101192847**

<b>Investigation</b>	# 1781829	<b>Incident Numbers</b>	371717
<b>Investigator:</b>	KEVIN GLANTON	<b>Site Classification</b>	GW 51-250 CONNECTION
<b>Conducted:</b>	10/14/2021 -- 11/01/2021	<b>NAIC Code:</b>	221310
<b>Program(s):</b>	PUBLIC WATER SYSTEM/SUPPLY	<b>SIC Code:</b>	4941
<b>Investigation Type:</b>	Compliance Investigation	<b>Location:</b>	LOCATED 13 MI E OF QUITMAN ON FM 2088 IN WOOD CO
<b>Additional ID(s):</b>	2500019		
<b>Address:</b>	1604 PR 8692, WINNSBORO, TX , 75494	<b>Local Unit:</b>	REGION 05 - TYLER
		<b>Activity Type(s):</b>	PWSCMPL - PWS Complaint PWSRECON - PWS Recon- Reconnaissance investigation for surface water and groundwater facilities.

**Principal(s):**

Role	Name
RESPONDENT	ESTATE OF PATETREEN PETTY
RESPONDENT	CSWR-TEXAS UTILITY OPERATING COMPANY LLC

**Contact(s):**

Role	Title	Name	Phone
REGULATED ENTITY MAIL CONTACT	CO-OWNER	MR DAVID PETTY	Cell (903) 217-2221 Work (903) 994-4200 Cell (903) 217-2221 Fax (903) 994-2747
REGULATED ENTITY MAIL CONTACT	PRESIDENT	MR JOSIAH COX	Work (314) 736-4672
PARTICIPATED IN	OPERATIONS MANAGER	MR ANDREW R MOORE	Work (903) 429-3008 Cell (903) 818-8412

**Other Staff Member(s):**

Role	Name
Supervisor	CARA FISHER
Investigator	BUFORD LESSLEY
QA Reviewer	CARA FISHER

---

**Associated Check List****Checklist Name**

PWS GENERIC VIOLATIONS

PWS COMPLAINT INVESTIGATION

**Unit Name**

GV

CPT

**Investigation Comments:****INTRODUCTION**

TCEQ Tyler Region Investigators, Mr. Kevin Glanton and Mr. Buford Lessley, conducted complaint and reconnaissance investigations at Big Wood Springs Water System (PWS ID No. 2500019) between 10/14/2021 and 11/01/2021. The water system is located 13 mi. E of Quitman on FM 2088 in Wood County, Texas. The water system was sold within one or two weeks prior to the investigation. The former Organization/Customer listed with TCEQ and PUC was the Estate of Patetreen Petty and the new purchaser is CSWR-Texas Utility Operating Company LLC (314-380-8533, 1650 Des Peres Rd, Ste 303, Des Peres, MO 63131-1853). CSWR contracts with Patterson Water Group, a water operations company (903-429-3008, 9963 Hwy 377, Collinsville, TX 76233). Mr. Andrew Moore, Operations Manager (903-818-8412) was the contact person with Patterson during the investigation.

**GENERAL FACILITY AND PROCESS INFORMATION**

According to Investigation No. 1664811, "Big Wood Springs water system is a ground water system that consists of one remote well with hypo chlorination, 0.022 MG high level ground storage tank, booster pumps, pressure tanks, housing, fencing and distribution. The water system serves approximately 75 connections. Of those connections, 3 are served by a booster pump and 86 gallon bladder pressure tank. Another 9 connections are served by a booster pump and (1) 86 gallon and (1) 81 gallon pressure tanks."

**BACKGROUND**

The TCEQ Tyler Region Office received a complaint on 10/12/2021, alleging that there was a water outage and there was difficulty contacting a representative with the water system. The water is supplied by a public water supply in Wood County.

**ADDITIONAL INFORMATION**

In response to the complaint, on 10/12/2021, Mr. Glanton called CSWR and was told a supervisor would call him back. On 10/13/2021, Mr. Fred Kriess, Regional Manager, CSWR (623-910-9074), called Mr. Glanton and they discussed the need to issue a boil water notice (BWN) due to the outage. Mr. Kriess said he would have a contract operator call Mr. Glanton to discuss the cause of the outage. On 10/13/2021, Mr. Glanton contacted Mr. Andrew Moore after getting his contact information from a complainant. Mr. Moore provided some background on the recent purchase of the water system and explained that the well had lost communication with the plant, which led to the storage tank being drained. Later in the day Mr. Moore said they had started running the well manually, but the tank was still not maintaining water. Therefore, he and Patterson operators were looked for closed valves or leaks. On the morning of 10/14/2021, Mr. Moore informed Mr. Glanton that had found a leak where it appeared that a compression coupling had come loose. After the repair, he said the tank was filling and the system was starting to repressurize. Later on 10/14/2021, Mr. Glanton and Mr. Lessley met Patterson staff at the Big Woods plant. They walked through the plant and the booster pump stations. They observed pressure readings of 35 PSI at one booster station adjacent to plant, 37 PSI at a flush valve off PR 8692 near the lake, 29 PSI on the suction side of the second booster station, 43 PSI on the boosted side of the second booster station, and 43 PSI on the flush valve on CR 3990. They measured the disinfectant residual as 1.56 mg/L of free chlorine at the flush valve on CR 3990. The minimum is 0.2 mg/L. Mr. Glanton and Mr. Lessley left pressure recorders on both of these flush valves for recording pressure readings once every minute until 11/01/2021. Meanwhile the BWN that was issued on 10/12/2021 remained effective until bacteriological samples passed.

On 11/01/2021, Mr. Glanton retrieved the two pressure recorders. Mr. Glanton had to reinstall the pressure recorder on CR 3990, because the one that was initially installed stopped recording on 10/14/2021. A separate investigation report is forthcoming. The recorder on the flush valve off PR 8692 near the lake showed pressure readings cycling between about 28 psi and 43 psi throughout each day that it was installed (a graph is attached). The minimum normal operating pressure is 35 PSI. This has been noted as a violation. This and the following other violations were noted during the investigations:

# BIG WOOD SPRINGS WATER SYSTEM - WINNSBORO

10/14/2021 to 11/1/2021 Inv. # - 1781829

Page 3 of 6

- 798871 inadequate distribution pressure
- 798872 inadequate line size
- 798873 unburied water main
- 798874 no automatic cut-off for booster pumps
- 798875 pressure tank not maintained

Responsible Official: Mr. Josiah Cox, President, CSWR-Texas Utility Operating Company LLC, (314) 736-4672, 1650 Des Peres Rd, Ste 303, Des Peres, MO 63131-1853.

<b>NOV Date</b>	01/10/2022	<b>Method</b>	WRITTEN
-----------------	------------	---------------	---------

## OUTSTANDING ALLEGED VIOLATION(S)

### ASSOCIATED TO A NOTICE OF VIOLATION

**Track Number:** 798871

**Compliance Due Date:** To Be Determined

**Violation Start Date:** 11/1/2021

**30 TAC Chapter 290.44(d)**

**30 TAC Chapter 290.46(r)**

#### Alleged Violation:

**Investigation:** 1781829

Comment Date: 12/18/2021

Failure to maintain normal operating pressure of at least 35 psi. 30 TAC 290.44(d) Minimum pressure requirement states, "The system must be designed to maintain a minimum pressure of 35 psi at all points within the distribution network at flow rates of at least 1.5 gallons per minute per connection. When the system is intended to provide fire-fighting capability, it must also be designed to maintain a minimum pressure of 20 psi under combined fire and drinking water flow conditions." 30 TAC 290.46(r) Minimum pressures states, "All public water systems shall be operated to provide a minimum pressure of 35 psi throughout the distribution system under normal operating conditions. The system shall also be operated to maintain a minimum pressure of 20 psi during emergencies such as firefighting. As soon as safe and practicable following the occurrence of a natural disaster, a public water system that is an affected utility shall maintain a minimum of 35 psi throughout the distribution system during an extended power outage."

During the investigation conducted between 10/14/2021 and 11/01/2021, the investigator installed a pressure recorder for recording pressure once every minute on a flush valve off PR 8692 near the lake. A graph is attached that shows pressure readings cycling between about 28 psi and 43 psi throughout each day that it was installed.

**Recommended Corrective Action:** Please submit a compliance plan by 02/09/2022. The plan should include the proposed actions to be taken to correct the alleged violation and a schedule for the completion of the corrections. If this violation has already been corrected, please submit compliance documentation, photographs, purchase orders, results of analyses, etc. demonstrating what actions were taken.

**Track Number:** 798872

**Compliance Due Date:** To Be Determined

**Violation Start Date:** 11/1/2021

**30 TAC Chapter 290.44(c)**

#### Alleged Violation:

**Investigation:** 1781829

Comment Date: 12/18/2021

Failure to provide minimum waterline sizes. The minimum waterline sizes are for domestic flows only and do

not consider fire flows. Larger pipe sizes shall be used when the licensed professional engineer deems it necessary. It should be noted that the required sizes are based strictly on the number of customers to be served and not on the distances between connections or differences in elevation or the type of pipe. No new waterline under two inches in diameter will be allowed to be installed in a public water system distribution system. These minimum line sizes do not apply to individual customer service lines. The maximum number of connections / minimum line size are as follows: 10 / 2", 25 / 2.5", 50 / 3", 100 / 4", 150 / 5", 250 / 6", >250 / 8" and larger.

During the investigation conducted between 10/14/2021 and 11/01/2021, the investigator documented that a one-inch line was serving about 13 connections. This was the line where a leaking compression fitting was repaired while trying to repressurize the distribution system after the water outage. The operators provided a photo of the one-inch line.

**Recommended Corrective Action:** Please submit a compliance plan by 02/09/2022. The plan should include the proposed actions to be taken to correct the alleged violation and a schedule for the completion of the corrections. If this violation has already been corrected, please submit compliance documentation, photographs, purchase orders, results of analyses, etc. demonstrating what actions were taken.

---

**Track Number:** 798873

**Compliance Due Date:** To Be Determined

**Violation Start Date:** 11/1/2021

**30 TAC Chapter 290.44(a)(4)**

**Alleged Violation:**

**Investigation:** 1781829

Comment Date: 12/18/2021

Failure to have all water mains buried at the minimum depth of least 24" below ground surface. 30 TAC 290.44(a)(4) states, "Water transmission and distribution lines must be installed in accordance with the manufacturer's instructions. However, the top of the waterline must be located below the frost line and in no case shall the top of the waterline be less than 24 inches below ground surface."

During the investigation conducted between 10/14/2021 and 11/01/2021, the investigator documented that the one-inch line that had been repaired while trying to repressurize the distribution system after the water outage was not buried at least 24" below ground surface. The operators indicated that it was exposed.

**Recommended Corrective Action:** Please submit a compliance plan by 02/09/2022. The plan should include the proposed actions to be taken to correct the alleged violation and a schedule for the completion of the corrections. If this violation has already been corrected, please submit compliance documentation, photographs, purchase orders, results of analyses, etc. demonstrating what actions were taken.

---

**Track Number:** 798874

**Compliance Due Date:** To Be Determined

**Violation Start Date:** 11/1/2021

**30 TAC Chapter 290.44(d)(2)**

**Alleged Violation:**

**Investigation:** 1781829

Comment Date: 12/18/2021

Failure to equip booster pumps with automatic pressure cut-off devices so that the pumping units become inoperative at a suction pressure of less than 20 psi. 30 TAC 290.44(d)(2) states, "When service is to be provided to more than one pressure plane or when distribution system conditions and demands are such that low pressures develop, the method of providing increased pressure shall be by means of booster pumps taking suction from storage tanks. If an exception to this requirement is desired, the designing engineer must furnish for the executive director's review all planning material for booster pumps taking suction from other than a

storage tank. The planning material must contain a full description of the supply to the point of suction, maximum demands on this part of the system, location of pressure recorders, safety controls, and other pertinent information. Where booster pumps are installed to take suction directly from the distribution system, a minimum residual pressure of 20 psi must be maintained on the suction line at all times. Such installations must be equipped with automatic pressure cut-off devices so that the pumping units become inoperative at a suction pressure of less than 20 psi. In addition, a continuous pressure recording device may be required at a predetermined suspected critical pressure point on the suction line in order to record the hydraulic conditions in the line at all times. If such a record indicates critical minimum pressures, less than 20 psi, adequate storage facilities must be installed with the booster pumps taking suction from the storage facility. Fire pumps used to maintain pressure on automatic sprinkler systems only for fire protection purposes are not considered as inline booster pumps."

During the investigation conducted between 10/14/2021 and 11/01/2021, the investigator observed that no cut-off devices were provided on either set of booster pumps.

**Recommended Corrective Action:** Please submit a compliance plan by 02/09/2022. The plan should include the proposed actions to be taken to correct the alleged violation and a schedule for the completion of the corrections. If this violation has already been corrected, please submit compliance documentation, photographs, purchase orders, results of analyses, etc. demonstrating what actions were taken.

**Track Number:** 798875

**Compliance Due Date:** To Be Determined

**Violation Start Date:** 11/1/2021

**30 TAC Chapter 290.46(m)**

**30 TAC Chapter 290.46(m)(1)(B)**

**Alleged Violation:**

**Investigation:** 1781829

**Comment Date:** 12/18/2021

Failure to maintain a pressure tank located at the main plant. The pressure tank was seriously corroded at a weld seam. 30 TAC 290.46(m) Maintenance and housekeeping states, "The maintenance and housekeeping practices used by a public water system shall ensure the good working condition and general appearance of the system's facilities and equipment." 30 TAC 290.46(m)(1)(B) states, "Pressure tank inspections must determine that the pressure release device and pressure gauge are working properly, the air-water ratio is being maintained at the proper level, the exterior coating systems are continuing to provide adequate protection to all metal surfaces, and the tank remains in watertight condition. Pressure tanks provided with an inspection port must have the interior surface inspected every five years."

During the investigation conducted between 10/14/2021 and 11/01/2021, the investigator observed that the pressure tank at the main plant was seriously corroded at a weld seam.

**Recommended Corrective Action:** Please submit a compliance plan by 02/09/2022. The plan should include the proposed actions to be taken to correct the alleged violation and a schedule for the completion of the corrections. If this violation has already been corrected, please submit compliance documentation, photographs, purchase orders, results of analyses, etc. demonstrating what actions were taken.

**Additional Issues**

**Description** Item 1

**Additional Comments**

Other items may be evaluated in a subsequent investigation, such as in-line booster pump plans and approvals and elevated storage capacity (based on elevations of highest customer and high-level ground storage tank).

**Description** Item 2

**BIG WOOD SPRINGS WATER SYSTEM - WINNSBORO**

10/14/2021 to 11/1/2021 Inv. # - 1781829

Page 6 of 6

**Additional Comments**

TCEQ had to reinstall the pressure recorder on CR 3990, because the one that was initially installed stopped recording on 10/14/2021. A separate investigation report is forthcoming.

Signed



Environmental Investigator

Date

12/20/21

Signed



Supervisor

Date

12/23/2021

**Attachments: (in order of final report submittal)**

\_\_\_ Enforcement Action Request (EAR)

\_\_\_ Letter to Facility (specify type) : \_\_\_\_\_

\_\_\_ Investigation Report

\_\_\_ Sample Analysis Results

\_\_\_ Manifests

\_\_\_ Notice of Registration

\_\_\_ Maps, Plans, Sketches

\_\_\_ Photographs

\_\_\_ Correspondence from the facility

\_\_\_ Other (specify) : \_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_



Jon Niermann, *Chairman*  
Emily Lindley, *Commissioner*  
Bobby Janecka, *Commissioner*  
Toby Baker, *Executive Director*



## TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

*Protecting Texas by Reducing and Preventing Pollution*

January 14, 2022

Mr. Bob Herrera  
12402 Trenton Dr.  
Dallas, TX 75243

Re: Investigation Request at:  
Big Wood Springs Water System,  
Complaint located on CR 3990, in (Wood County), Texas  
**Investigation No.: 372339**  
**Incident No.: 1782777**

Dear Mr. Herrera:

The Texas Commission on Environmental Quality (TCEQ) Tyler Regional Office has completed a final investigation in response to your concern regarding water quality at the above referenced facility. Enclosed is a copy of the investigation report.

For more information about our complaint process, you may access the publication GI-278: *Do You Want to Make an Environmental Complaint? Do You Have Information or Evidence?* on our website at [www.tceq.texas.gov](http://www.tceq.texas.gov).

We appreciate your concern in bringing this matter to our attention. If we can be of further assistance, please contact Mr. Kevin Glanton at the Tyler Regional Office at (903) 535-5133.

Sincerely,

A handwritten signature in black ink, appearing to read "Cara C. Fisher".

Ms. Cara C. Fisher  
Team Leader, Water Program  
Tyler Regional Office

CCF/RKG/dfy

Enclosures: TCEQ Investigation Report 1782777  
TCEQ Investigation Report 1781829

PWS\_2500019\_CP\_20211119\_Investigation  
**Texas Commission on Environmental Quality**  
**Investigation Report**

The TCEQ is committed to accessibility. If you need assistance in accessing this document, please contact oce@tceq.texas.gov

**Customer: CSWR-TEXAS UTILITY OPERATING COMPANY, LLC**  
**Customer Number: CN605844786**

---

**Regulated Entity Name: BIG WOOD SPRINGS WATER SYSTEM**

**Regulated Entity Number: RN101192847**

<b>Investigation #</b>	1782777	<b>Incident Numbers</b>	372339
<b>Investigator:</b>	KEVIN GLANTON	<b>Site Classification</b>	GW 51-250 CONNECTION
<b>Conducted:</b>	11/08/2021 -- 11/19/2021	<b>NAIC Code:</b>	221310
<b>Program(s):</b>	PUBLIC WATER SYSTEM/SUPPLY	<b>SIC Code:</b>	4941
<b>Investigation Type:</b>	Compliance Investigation	<b>Location:</b>	LOCATED 13 MI E OF QUITMAN ON FM 2088 IN WOOD CO
<b>Additional ID(s):</b>	2500019		
<b>Address:</b>	1604 PR 8692, WINNSBORO, TX , 75494	<b>Local Unit:</b>	REGION 05 - TYLER
		<b>Activity Type(s):</b>	PWSCMPL - PWS Complaint PWSRECON - PWS Recon- Reconnaissance investigation for surface water and groundwater facilities.

**Principal(s):**

Role	Name
RESPONDENT	ESTATE OF PATETREEN PETTY
RESPONDENT	CSWR-TEXAS UTILITY OPERATING COMPANY LLC


**Contact(s):**

Role	Title	Name	Phone
REGULATED ENTITY MAIL CONTACT	CO-OWNER	MR DAVID PETTY	Fax (903) 994-2747 Cell (903) 217-2221 Work (903) 994-4200 Cell (903) 217-2221
REGULATED ENTITY MAIL CONTACT	PRESIDENT	MR JOSIAH COX	Work (314) 736-4672
PARTICIPATED IN	OPERATIONS MANAGER	MR ANDREW R MOORE	Work (903) 429-3008 Cell (903) 818-8412

**Other Staff Member(s):**

Role	Name
QA Reviewer	CARA FISHER
Supervisor	CARA FISHER
Investigator	BUFORD LESSLEY

# Downloaded Data - Friday, November 19, 2021



**Associated Check List****Checklist Name**

PWS COMPLAINT INVESTIGATION

**Unit Name**

CPT

**Investigation Comments:****INTRODUCTION**

TCEQ Tyler Region Investigators, Mr. Kevin Glanton and Mr. Buford Lessley, conducted complaint and reconnaissance investigations at Big Wood Springs Water System (PWS ID No. 2500019) between 11/08/2021 and 11/19/2021. The water system is located 13 mi. E of Quitman on FM 2088 in Wood County, Texas. The water system was sold within one or two weeks prior to the investigation. The former Organization/Customer listed with TCEQ and PUC was the Estate of Patetreen Petty and the new purchaser is CSWR-Texas Utility Operating Company LLC (314-380-8533, 1650 Des Peres Rd, Ste 303, Des Peres, MO 63131-1853). CSWR contracts with Patterson Water Group, a water operations company (903-429-3008, 9963 Hwy 377, Collinsville, TX 76233). Mr. Andrew Moore, Operations Manager (903-818-8412) was the contact person with Patterson during the investigation.

**GENERAL FACILITY AND PROCESS INFORMATION**

According to Investigation No. 1664811, "Big Wood Springs water system is a ground water system that consists of one remote well with hypo chlorination, 0.022 MG high level ground storage tank, booster pumps, pressure tanks, housing, fencing and distribution. The water system serves approximately 75 connections. Of those connections, 3 are served by a booster pump and 86 gallon bladder pressure tank. Another 9 connections are served by a booster pump and (1) 86 gallon and (1) 81 gallon pressure tanks."

**BACKGROUND**

The TCEQ Tyler Region Office received a complaint on 10/12/2021, alleging that there was a water outage and there was difficulty contacting a representative with the water system. The water is supplied by a public water supply in Wood County.

**ADDITIONAL INFORMATION**

Investigation Report 1781829 provides the details of Mr. Glanton's and Mr. Lessley's initial responses to the complaint (the report is attached). That investigation was conducted between 10/14/2021 and 11/01/2021. On 11/01/2021, Mr. Glanton retrieved two pressure recorders, one which had been installed off PR 8692 near the lake. Mr. Glanton had to reinstall the pressure recorder that had been installed on CR 3990 at the same time as the other one, because the one that was initially installed on CR 3990 stopped recording on 10/14/2021. Therefore, a subsequent investigation was conducted separately from Investigation 1781829, and its findings are included in this report.

The recorder on the flush valve on CR 3990 (at the end of the water main) showed pressure readings cycling between about 28 psi and 50 psi throughout each day that it was installed (during the latter part of the time the pressure cycled higher than the first few days—a graph is attached). The minimum normal operating pressure is 35 PSI. This has been noted as a violation.

Responsible Official: Mr. Josiah Cox, President, CSWR-Texas Utility Operating Company LLC, (314) 736-4672, 1650 Des Peres Rd, Ste 303, Des Peres, MO 63131-1853.

<b><u>NOV Date</u></b>	01/14/2022	<b><u>Method</u></b>	WRITTEN
<b>OUTSTANDING ALLEGED VIOLATION(S)</b>			
<b>ASSOCIATED TO A NOTICE OF VIOLATION</b>			

**Track Number:** 799487**Compliance Due Date:** To Be Determined**Violation Start Date:** 11/19/2021

30 TAC Chapter 290.44(d)  
30 TAC Chapter 290.46(r)

**Alleged Violation:****Investigation: 1782777**


Comment Date: 01/04/2022

Failure to maintain normal operating pressure of at least 35 psi. 30 TAC 290.44(d) Minimum pressure requirement states, "The system must be designed to maintain a minimum pressure of 35 psi at all points within the distribution network at flow rates of at least 1.5 gallons per minute per connection. When the system is intended to provide fire-fighting capability, it must also be designed to maintain a minimum pressure of 20 psi under combined fire and drinking water flow conditions." 30 TAC 290.46(r) Minimum pressures states, "All public water systems shall be operated to provide a minimum pressure of 35 psi throughout the distribution system under normal operating conditions. The system shall also be operated to maintain a minimum pressure of 20 psi during emergencies such as firefighting. As soon as safe and practicable following the occurrence of a natural disaster, a public water system that is an affected utility shall maintain a minimum of 35 psi throughout the distribution system during an extended power outage."

During the investigation conducted between 11/08/2021 and 11/19/2021, the investigator installed a pressure recorder for recording pressure once every minute on a flush valve on CR 3990. A graph is attached that shows pressure readings cycling between about 28 psi and 43 psi throughout each day that it was installed (during the latter part of the time the pressure cycled higher than the first few days—a graph is attached).

**Recommended Corrective Action:** Please submit a compliance plan by 02/13/2022. The plan should include the proposed actions to be taken to correct the alleged violation and a schedule for the completion of the corrections. If this violation has already been corrected, please submit compliance documentation, photographs, purchase orders, results of analyses, etc. demonstrating what actions were taken.

Signed



Environmental Investigator

Date

1/4/22

Signed



Supervisor

Date

1/16/2022

**Attachments: (in order of final report submittal)**

\_\_\_ Enforcement Action Request (EAR)

\_\_\_ Maps, Plans, Sketches

\_\_\_ Letter to Facility (specify type) : \_\_\_\_\_

\_\_\_ Photographs

\_\_\_ Investigation Report

\_\_\_ Correspondence from the facility

\_\_\_ Sample Analysis Results

\_\_\_ Other (specify) : \_\_\_\_\_

\_\_\_ Manifests

\_\_\_ Notice of Registration