



Filing Receipt

Filing Date - 2023-08-14 02:43:28 PM

Control Number - 55361

Item Number - 2

DOCKET NO. 55361

APPLICATION OF CENTERPOINT	§	PUBLIC UTILITY COMMISSION
ENERGY HOUSTON ELECTRIC, LLC	§	
TO ADJUST ITS SYSTEM-WIDE	§	OF TEXAS
RELIABILITY STANDARDS	§	

ORDER NO. 1
REQUIRING COMMENTS AND RECOMMENDATIONS ON THE APPLICATION,
PROPOSED NOTICE, AND PROPOSED PROCEDURAL SCHEDULE

This Order addresses the August 11, 2023 application of CenterPoint Energy Houston Electric, LLC to adjust the system-wide reliability standards applicable to the company under 16 Texas Administrative Code (TAC) § 25.52(g)(1). Specifically, CenterPoint seeks approval to adjust its System Average Interruption Frequency Index, from 1.24000 to 0.97195, and its System Average Interruption Duration Index from 125.71666 to 101.47821, beginning calendar year January 1, 2024.

CenterPoint Energy proposes providing notice to parties in its most recent-base rate proceeding, Docket No. 49421.¹

By September 11, 2023, Commission Staff must file recommendations on the sufficiency of the application and the method and content of notice and propose a procedural schedule for processing.

Signed at Austin, Texas on the 14th day of August 2023.

PUBLIC UTILITY COMMISSION OF TEXAS



CHRISTINA DENMARK
ADMINISTRATIVE LAW JUDGE

Q:\CADM\Docket Management\Electric\MISCELLANEOUS\55xxx\55361-1.docx

¹ *Application of CenterPoint Energy Houston Electric, LLC for Authority to Change Rates*, Docket No. 49421, Order (Mar. 9, 2020).