



Filing Receipt

Filing Date - 2025-04-18 11:51:03 AM

Control Number - 55718

Item Number - 107

PUC PROJECT NO. 55718

RELIABILITY PLAN FOR THE § PUBLIC UTILITY COMMISSION
§
PERMIAN BASIN UNDER PURA §39.167 § OF TEXAS

The Texas Energy Buyers Alliance (TEBA) represents the collective voice of more than 260 companies, representing some of the state's largest employers and energy customers. In total, TEBA members represent more than \$20 trillion in market capitalization and hundreds of thousands of employees in Texas. Our organization is focused on helping to shape Texas' electricity market redesign in ways that propel Texas' economy forward, lower power bills for all energy customers, create jobs, spur innovation, strengthen the ERCOT grid, and extend Texas' energy leadership through the energy transition and for generations to come.

Many TEBA companies located their businesses in Texas in part because of its dependable business environment and open energy markets — including low-cost, increasingly clean, reliable power, and the ability to freely choose and procure it without unnecessary regulations or red tape. TEBA members believe reliable, clean, affordable energy is good for business, and that what's good for business is good for Texas.

TEBA, and one of its members investing in Texas, Google, sponsored this analysis from Siemens PTI. Please refer to this initial fact sheet in support of the study.

What the study did: Conduct a Cost Benefit Analysis of a 765-kV and 345-kV transmission system build-out.

Context: Based on building generation resources that are the fastest and cheapest to build, there is a geographic disconnect between where generation is expected to go and where demand is expected to locate, indicating an urgent need for new transmission infrastructure to move the power needed to meet demand growth.

Topline: *The study shows that a 765 kV system outperforms the 345 kV option, even with a conservative load forecast.*

- Both ERCOT and Siemens PTI analyses confirm that a 765-kV system outperforms the 345-kV option even with a conservative load forecast [109 GW system peak by 2034 and 115 GW by 2039].
- Siemens PTI's analysis shows even lower overall costs to consumers across all categories, further strengthening the case for 765-kV development (see table below).
- The 765 kV system avoids hundreds of millions in costs, both by 2034 and 2039.
- Even though the 765 kV system costs slightly more to construct, [\$4.27B vs \$4.1B], lower production costs, lower consumer energy costs, and dramatically reduced congestion rents, means **better cost to benefit ratios for 765-kV over 345-kV**, driven by the ability of 765 kV lines to deliver more low-cost energy into high-demand areas.
- The increased demand from the large load forecast is expected to be met from numerous generation types, including thousands of megawatts of new combustion turbines, batteries, solar, and wind.
- Critically, 765-kV provides a better means to manage the geographic disconnect between new generation and new load.

765-kV Outperforms 345-kV Across Key Metrics in Both ERCOT and Siemens PTI's Analyses

| | | ERCOT RTP Analysis | | | Siemens PTI Analysis | | |
|----------------------|------------|--------------------|--------|------------|----------------------|--------|------------|
| Attributes | Metric | 765-kV | 345-kV | Difference | 765-kV | 345-kV | Difference |
| Production Cost | 2034 (M\$) | 16,836 | 16,969 | 133 | 15,137 | 15,508 | 370 |
| | 2039 (M\$) | 19,059 | 19,088 | 28 | 15,982 | 16,471 | 941 |
| Consumer Energy Cost | 2034 (M\$) | 18,279 | 18,143 | -136 | 13,518 | 14,323 | 805 |
| | 2039 (M\$) | 21,914 | 22,143 | 229 | 15,434 | 16,375 | 941 |
| Congestion Rent | 2034 (M\$) | 1,444 | 1,539 | 94 | 469 | 1,386 | 917 |
| | 2039 (M\$) | 2,089 | 2,261 | 172 | 972 | 2,318 | 1,345 |

Additional conclusions:

- The 765-kV option demonstrates substantially greater improvement in West to East transfer capability compared to the 345-kV option (~1.46 GW higher).
- The 345 kV Transmission Scenario shows greater congestion, particularly affecting the South-Central Region, whereas the 765 kV Transmission Scenario largely addresses congestion affecting that region (by 2039).
- Total renewable energy curtailment drops to about half with 765-kV compared to 345-kV (from 2,990 MWh to 1,568 MWh), contributing to lower production costs and congestion cost savings, which enhances grid efficiency and helps stabilize customer costs.
- In the 2039 765-kV results, the West GTC is no longer expected to be as limiting as it is today.

Siemens PTI


Cost Benefit Analysis of 765-kV Transmission Facilities in ERCOT

Prepared for: Google & TEBA



Agenda



- Executive Summary
 - Background
 - Key Assumptions
 - Cost Benefit Analysis Results
- Appendix A - Assumptions
 - Load Scenarios
 - Generation
 - Natural Gas
 - Transmission Topology
- Appendix B - PV analysis
- Appendix C - ARR Calculation



Executive Summary

Background: Strategic Planning for a High-Growth Grid

- ERCOT is experiencing unprecedented load growth, with the 2030 summer peak demand projected to exceed 150 GW—driven by approximately 50 GW of large new loads, including:
 - Oil and gas electrification (especially in the Permian Basin)
 - Data centers, AI applications, and Crypto mining,
 - Hydrogen production and related industrial processes.
- In response, Google and the Texas Energy Buyers Alliance (TEBA) have engaged Siemens PTI to conduct a **cost-benefit analysis (CBA) of the potential 765-kV transmission buildout in ERCOT**.
- As part of this study, Siemens PTI is evaluating the benefits of the **765-kV Core Plan**, designed to enhance long-distance power delivery from generation-rich western regions.
- A 345-kV alternative scenario is used as the counterfactual, leveraging the 2024 ERCOT Regional Transmission Plan (RTP) as the basis for comparison.



Source: 2024 Regional Transmission Plan (RTP) 345-kV Plan and Texas 765-kV Strategic Transmission Expansion Plan Comparison.pdf

Study Assumptions



- This study aligns with ERCOT’s 2024 Long-Term System Assessment (LTSA) and reflects the following planning scenarios:
- **Current Trends Scenario:** Reflects ERCOT’s baseline outlook with moderate economic and demand growth, reflecting historical trends and expected economic expansion.
- **High Large Load Adoption Scenario:** Includes over 70 GW of new load from TSP forecasts, driven by cryptomining, hydrogen, and data centers.

Status: The current analysis focuses on the Current Trends Scenario. The High Large Load Adoption Scenario is under development and expected to be finalized within 3–5 days.

| Input | Scenario | Source | 2034 | 2039 |
|-----------------------|--------------------------|-------------------------------------|--|---|
| Load | Current Trends | LTSA | 109-GW | 115-GW |
| | High Large Load Adoption | LTSA Mapping: RPG (155-GW modeled) | 144-GW | 186-GW (31-GW unmapped: allocate ¼ to CNP, ¾ Oncor/AEP) |
| Capacity Additions | Current Trends | LTSA | 57.9-GW | 87.7-GW |
| | High Large Load Adoption | LTSA Mapping: RPG (246-GW modeled) | 197-GW | 285-GW (39-GW unmapped: allocate to strong 345-kV buses) |
| Natural Gas Price | All Scenarios | HH: EIA 2023 AEO Basis: Siemens PTI | \$3.67/MMBTU (2024) | \$4.15/MMBTU (2024) |
| Transmission Topology | All Scenarios | RTP Cases | 345-kV RTP (2038) 765-kV RTP STEP Case (2030) | 345-kV RTP (2038) 765-kV RTP STEP Case (2030) |

LTSA – Long-Term System Assessment (2024)
RTP – Regional Transmission Plan (2024)
RPG – Regional Planning Group

Regional Concentration of ERCOT Load and Growth




Key Insights:


- By 2039, ONCOR, CNP, and AEP collectively account for 67% of ERCOT's peak load.
- North Central (Dallas), South Central (Austin/San Antonio), and Coast (Houston) regions contribute **52% of the total peak load** in 2039.
- Between 2026 and 2034, **63% of peak load growth** occurs in these three regions, while the **Permian Basin (Far West/West)** accounts for approximately 13%.

Current Trends Capacity Additions by 2039 – Key Trends


Solar Additions by 2039 (MW)




Storage Additions by 2039 (MW)



Wind Additions by 2039 (MW)



NG Additions by 2039 (MW)




Key Insights:

- Over 70% of new capacity by 2039 will come from renewables, with solar leading the growth.
- Solar and wind are being developed where resource conditions are strongest — primarily in West and North Texas.
- Major load growth is occurring in the North Central (Dallas), South Central (Austin/San Antonio), and Coast (Houston) regions (63% of peak load growth).
- This geographic disconnect between generation and demand underscores the urgent need for new transmission infrastructure.

Steady-State Voltage Stability (PV Analysis): Enabling Low-Cost Power Transfer from West to East

- A Steady State Voltage Stability Analysis (PV analysis) was performed to analyze the WTE transfer capacity for all cases.
- For the study year 2034, results show an improvement of 2.8 GW (22.1%) in WTE GTC transfer capacity for 345-kV option and 4.3 GW (33.4%) for 765-kV core plan.
- The 765-kV option demonstrates substantially greater improvement in transfer capability compared to the 345-kV option (~1.46 GW higher).
- The results of year 2039 shows similar trends when using same topology but with higher load level modeled.



| Study Year | Transfer Capacity (MW) | | | Delta (%) Compared to Base | | Delta (MW) Compared to Base | |
|------------|------------------------|--------|--------|----------------------------|-------|-----------------------------|-------|
| | Base | 345kV | 765kV | 345kV | 765kV | 345kV | 765kV |
| 2034 | 12,854 | 15,692 | 17,151 | 22.1% | 33.4% | 2,838 | 4,297 |
| 2039 | 11,908 | 14,753 | 15,719 | 23.9% | 32.0% | 2,845 | 3,810 |

765-kV Transmission Reduces ERCOT's Wind Curtailment from 7.4% to 3.1% in 2039 and Solar Curtailment from 6.2% to 4.2%


- Total energy curtailment (Solar + Wind) drops to about half with 765-kV compared to 345-kV (from 2,990 MWh to 1,568 MWh).
- ERCOT South sees the most important improvement, followed by North, but benefits extend across all zones.
- Wind curtailment alone decreases by 63%, contributing to lower production and congestion costs.
- Reduced curtailment enhances grid efficiency, supports renewables integration, and helps stabilize customer costs.
- The 2034 results show identical trend.

| Current Trends - 2039 | | Wind | | Solar | |
|-----------------------|------------------------|--------|--------|--------|--------|
| Region | Metric | 765-kV | 345-kV | 765-kV | 345-kV |
| ERCOT-Houston | Curtailment (%) | 1.0% | 0.0% | 0.2% | 0.1% |
| ERCOT-North | Curtailment (%) | 1.4% | 1.9% | 1.1% | 3.7% |
| ERCOT-South | Curtailment (%) | 4.8% | 14.8% | 4.1% | 6.6% |
| ERCOT-West | Curtailment (%) | 3.0% | 6.0% | 8.2% | 9.2% |
| Total | Curtailment (%) | 3.1% | 7.4% | 4.2% | 6.2% |
| | Curtailed Energy (MWh) | 752 | 1,779 | 817 | 1,211 |

| Current Trends - 2034 | | Wind | | Solar | |
|-----------------------|------------------------|--------|--------|--------|--------|
| Region | Metric | 765-kV | 345-kV | 765-kV | 345-kV |
| ERCOT-Houston | Curtailment (%) | 1.9% | 0% | 0.8% | 0.1% |
| ERCOT-North | Curtailment (%) | 1.4% | 0.8% | 0.7% | 2.5% |
| ERCOT-South | Curtailment (%) | 3.9% | 13.7% | 4.00% | 6.9% |
| ERCOT-West | Curtailment (%) | 2.6% | 5.6% | 7.9% | 7.1% |
| Total | Curtailment (%) | 2.6% | 7.1% | 3.9% | 5.3% |
| | Curtailed Energy (MWh) | 579 | 1,552 | 665 | 901 |

The 345 kV Transmission Scenario shows important Congestion particularly affecting the South-Central Region (2039 results)

Marginal Avg Prices 2039 \$/MWh




- **South Central emerges as the congestion hotspot:** 4 of the 6 most congested lines in the 345-kV scenario affect this region.
- **The average LMPs also reflect this.** The lowest LMPs are in the south zone and facility #1 in the list (the most congested) and facility #3 constrain the transfer.
- The lower LMPs and associated generation the north and panhandle also limited to reach the load due to transmission constraints.
- The WT-GTC appears also to be binding

| 345-kV Top Congested Branches - Current Trends 2039 | | | | | |
|---|-------------------------|---------------------------|-----------|----------|-------------|
| | From Bus | To Bus | From Zone | To Zone | Congestion |
| 1 | 5400 [SPRUCE] 345kV | 5725 [PAWNEESW5] 345kV | SOUTH_CE | SOUTH_CE | \$ 546.28 |
| 2 | 3390 [JEWETT_S5] 345kV | 44645 [SNGLTN_B345] 345kV | EAST | EAST | \$ 171.27 |
| 3 | 7770 [L_BERGHE5] 345kV | 345/138 kV transformer | SOUTH_CE | SOUTH_CE | \$ 167.62 |
| 4 | 3687 [BELL_E_5] 345kV | 13429 [SAND_TXU_5] 345kV | NORTH_CE | SOUTH_CE | \$ 163.35 |
| 5 | 10049 [RANGER_5] 345kV | 11048 [TONKAWAW_5] 345kV | NORTH_CE | WEST | \$ 153.66 |
| 6 | 1685 [FARMVLSW_5] 345kV | 2461 [ROYSE_N5] 345kV | NORTH_CE | NORTH_CE | \$ 118.31 |
| 7 | 2432 [TRICRN1_5] 345kV | 2437 [FRNY1_5] 345kV | NORTH_CE | NORTH_CE | \$ 114.48 |
| Total Congestion top 20 facilities 345 kV Case | | | | | \$ 2,142.89 |

To and From buses do not indicate flow direction

The 765 kV Transmission Scenario largely addresses the congestion affecting the South-Central Region (2039 results)

Marginal Avg Prices 2039 \$/MWh



- The 765 kV option, diminishes system-wide congestion, especially in the South-Central Zone, mitigating the major transmission bottlenecks.
- **Again, the average LMPs also reflect this.** The LMPs are in a narrower range reflecting lower congestion.
- With 765 kV Option the Texas Panhandle shows similar levels of constraint as the south zone and the identified constraints reflect this.
- The WT-GTC appears be only weakly binding
- The 2034 results show the same trend

| 765 kV Top Congested Branches - Current Trends 2039 | | | | |
|---|---------------------------|-----------|----------|------------|
| From Bus | to Bus | From Zone | To Zone | Congestion |
| 2432 [TRICRN1_5] 345kV | 2437 [FRNY1_5] 345kV | NORTH_CE | NORTH_CE | \$ 146.02 |
| 3390 [JEWETT_S5] 345kV | 44645 [SNGLTN_B345] 345kV | EAST | EAST | \$ 120.47 |
| 5056 [CAGNON_5] 345kV | 5211 [HILLCTY_5] 345kV | SOUTH_CE | SOUTH_CE | \$ 117.88 |
| 42000 [P_H_R_B345] 345kV | 43030 [MEADOW_B345] 345kV | COAST | COAST | \$ 114.40 |
| 23924 [FARMLAND_5] 345kV | 888856 [HOLLY_POI] 345kV | FAR_WEST | SOUTH_CE | \$ 110.98 |
| 1430 [GRHAMSES1_] 345kV | 17002 [GARVEYRD_5] 345kV | NORTH_CE | NORTH | \$ 64.12 |
| 68010 [ROMNEY1_W] 345kV | 68020 [ROMNEY1_E] 345kV | NORTH_CE | NORTH_CE | \$ 57.73 |
| Total Congestion top 20 facilities 345 kV Case | | | | \$ 926.82 |

To and From buses do not indicate flow direction

CBA Highlights Strong Economic and System Value of 765-kV Transmission System

- **Affordability:** 765-kV infrastructure delivers lower production costs, lower consumer energy costs, and dramatically reduced congestion rents driven by the ability of 765 kV lines to deliver more low-cost energy into high-demand areas.
- **Sustainability:** Greater access to renewable energy under 765-kV reduces reliance on fossil fuels and curtailment, with potential for meaningful emissions reductions.
- **Reliability:** TBD

| | | | Current Trends | | |
|----------------|----------------------|---|----------------|--------|---------------------------------|
| | Attributes | Metric | 765-kV | 345-kV | CBA ($\Delta/\Delta ARR$)* |
| Affordability | Production Cost | 2034 (M\$) | 15,137 | 15,508 | 2.1 |
| | | 2039 (M\$) | 15,982 | 16,471 | 2.8 |
| | Consumer Energy Cost | 2034 (M\$) | 13,518 | 14,323 | 4.6 |
| | | 2039 (M\$) | 15,434 | 16,375 | 5.4 |
| | Congestion Rent | 2034 (M\$) | 469 | 1,386 | 5.0 |
| | | 2039 (M\$) | 972 | 2,318 | 7.7 |
| | Generator Revenue | 2034 (M\$) | 22,486 | 23,353 | 5.3 |
| | | 2039 (M\$) | 25,251 | 26,280 | 5.9 |
| Sustainability | Emissions | Total from 2034-2039 (millions tCO ₂) | 774 | 801 | NA |
| Reliability | Resource Adequacy | Expected Unserved Energy | TBD | TBD | NA |
| | Resilience | Low Probability High Impact Event | TBD | TBD | NA |

$$CBA_{\text{metric}} = \frac{\text{Value}_{345} - \text{Value}_{765}}{ARR_{765} - ARR_{345}}$$

*ARR: Annual Revenue Requirements or annualized cost for capital investments. More detail in Appendix C.

765-kV Outperforms 345-kV Across Key Metrics in Both ERCOT and Siemens PTI's Analyses

- Both ERCOT and Siemens PTI analyses confirm that a 765-kV system outperforms the 345-kV option even under the Current Trends Scenario, which represents a conservative load forecast.
- Siemens PTI's analysis shows even greater cost savings across all categories, further strengthening the case for 765-kV development.

| | | ERCOT RTP Analysis | | | Siemens PTI Analysis | | |
|----------------------|------------|--------------------|--------|------------|----------------------|--------|------------|
| Attributes | Metric | 765-kV | 345-kV | Difference | 765-kV | 345-kV | Difference |
| Production Cost | 2034 (M\$) | 16,836 | 16,969 | 133 | 15,137 | 15,508 | 370 |
| | 2039 (M\$) | 19,059 | 19,088 | 28 | 15,982 | 16,471 | 941 |
| Consumer Energy Cost | 2034 (M\$) | 18,279 | 18,143 | -136 | 13,518 | 14,323 | 805 |
| | 2039 (M\$) | 21,914 | 22,143 | 229 | 15,434 | 16,375 | 941 |
| Congestion Rent | 2034 (M\$) | 1,444 | 1,539 | 94 | 469 | 1,386 | 917 |
| | 2039 (M\$) | 2,089 | 2,261 | 172 | 972 | 2,318 | 1,345 |

Appendix A - Assumptions


Assumptions Summary

| Input | Scenario | Source | 2034 | 2039 |
|-----------------------|--------------------------|--|--|--|
| Load | Current Trends | LTSA | 109-GW | 115-GW |
| | High Large Load Adoption | LTSA Mapping: RPG (155-GW modeled) | 144-GW | 186-GW (31-GW unmapped: allocate ¼ to CNP, ¾ Oncor/AEP) |
| | Sensitivity Case | RTP Mapping: RPG (155-GW modeled) | 126-GW | 151-GW |
| Capacity Additions | Current Trends | LTSA | 57.9-GW | 87.7-GW |
| | High Large Load Adoption | LTSA Mapping: RPG (246-GW modeled) | 197-GW | 285-GW (39-GW unmapped: allocate to strong 345-kV buses) |
| | Sensitivity Case | Mapping: RPG (246-GW modeled) | TBD | TBD |
| Natural Gas Price | All Scenarios | HH: EIA 2023 AEO Basis: Siemens PTI | \$3.67/MMBTU (2024) | \$4.15/MMBTU (2024) |
| Transmission Topology | All Scenarios | RTP Cases | 345-kV RTP (2030) 765-kV RTP STEP Case (2030) | 345-kV RTP (2038) 765-kV RTP STEP Case (2030) |

LTSA – Long-Term System Assessment (2024)
RTP – Regional Transmission Plan (2024)
RPG – Regional Planning Group

Load Scenarios

- Load Scenarios:
 - **Current Trends:** Represents ERCOT’s moderate growth scenario from the LTSA, reflecting historical trends and expected economic expansion.
 - **High Large Load Adoption:** Assumes significant load growth beyond historical trends, incorporating TSP-submitted forecasts based on interconnection requests, industrial expansion, and economic growth. This scenario includes large flat demand (66 GW) and price-responsive load (4 GW LFL).
 - **Sensitivity Case:** A conservative alternative where only 50% of the projected load growth from TSPs is included in ERCOT’s planning studies. This approach balances uncertainty in load materialization and prevents overestimating infrastructure needs.





Load Distribution to the Nodal Level

Load Distribution:

- **Current Trends:** Detailed data at an hourly and nodal level allocations for 2034 and 2039 based on ERCOT's LTSA projections.
- **High Large Load Adoption:** Includes no detailed nodal allocation data, therefore we will use the RPG case to allocate to the nodal level, up to 155 GW.
 - Since CNP shows no growth in the Current Trends scenario, the necessary unmapped additional load in 2039 will be allocated as follows:
 - CNP: $\frac{1}{4}$ of the additional load
 - Oncor/AEP: $\frac{3}{4}$ of the additional load
- **Sensitivity Case:** Adjusts the 2034 and 2039 load distribution using the same allocation methodology as the High Large Load Adoption scenario.

Regional Concentration of ERCOT Load and Growth



Key Insights:

- By 2039, ONCOR, CNP, and AEP collectively account for 67% of ERCOT's peak load.
- North Central (Dallas), South Central (Austin/San Antonio), and Coast (Houston) regions contribute **52% of the total peak load** in 2039.
- Between 2026 and 2034, **63% of peak load growth** occurs in these three regions, while the **Permian Basin (Far West/West)** accounts for approximately 13%.

New Capacity Additions

Capacity Additions:

- New large load additions in the High Large Load Adoption scenario are expected to be primarily supplied by wind and solar, with solar additions projected to be 4x higher than in the Current Trends outlook.
- The largest capacity increase is expected from combustion turbines (CTs) to mitigate intermittency and support the 24/7 energy demands of large loads
- Mapping:
 - **Current Trends:** ERCOT provides capacity additions and mapping for Current Trends (2034 and 2039).
 - **High Large Load Adoption:** ERCOT's LTSA outlines total capacity additions, but Siemens PTI must perform mapping. As a starting point, Siemens will use the RPG case mappings (246 GW), which allocate capacity to strong 345-kV buses.
 - **Sensitivity Case:** TBD

| New Capacity by 2034 (MW) | | |
|---------------------------|----------------|-----------------|
| Technology | Current Trends | High Large Load |
| Battery | 9,748 | 23,095 |
| Combined Cycle | 9,747 | 17,328 |
| CT & IC | 6,162 | 52,140 |
| Solar | 19,951 | 84,056 |
| Wind | 12,300 | 20,400 |
| Total | 57,908 | 197,019 |


| New Capacity by 2039 (MW) | | |
|---------------------------|----------------|-----------------|
| Technology | Current Trends | High Large Load |
| Battery | 17,514 | 26,911 |
| Combined Cycle | 15,162 | 28,158 |
| CT & IC | 9,951 | 83,187 |
| Solar | 28,800 | 125,368 |
| Wind | 16,300 | 22,200 |
| Total | 87,727 | 285,824 |

New Capacity Additions Mapping


- Mapping:
 - **Current Trends:** ERCOT provides capacity additions and mapping for Current Trends (2034 and 2039).
 - **High Large Load Adoption:** ERCOT's LTSA outlines total capacity additions, but Siemens PTI must perform mapping. As a starting point, Siemens will use the RPG case mappings (246 GW), which allocate capacity to strong 345-kV buses.
 - **Sensitivity Case:** TBD

Current Trends Capacity Additions by 2039 – Key Trends


Solar Additions by 2039 (MW)




Storage Additions by 2039 (MW)



Wind Additions by 2039 (MW)



NG Additions by 2039 (MW)




Key Insights:

- Over 70% of new capacity by 2039 will come from renewables, with solar leading the growth.
- Solar and wind are being developed where resource conditions are strongest — primarily in West and North Texas.
- Major load growth is occurring in the Central and Coast.
- This geographic disconnect between generation and demand underscores the urgent need for new transmission infrastructure.



765-kV Topology

- Siemens PTI will use the 765-kV Core Plan based on 2030 Case as depicted in ERCOT's 2024 RTP.




345-kV Topology

- Alternative Solution: 345-kV transmission reinforcements depicted below and obtained from recent ERCOT analyses (Permian Basin Reliability Plan Study, from Jul 2024, and the 2024 Regional Transmission Plan, from Dec 2024).
- The 2034 Case will be based on RTP plan for 2030 and 2039 will be based on 2038 Case.



Natural Gas Forecast

- As reported in their 2024 LTSA, ERCOT utilized the gas price outlook from the latest EIA Annual Energy Outlook (AEO)*
- Due to the fast-changing nature of the electric industry right now, EIA has decided to skip the 2024 AEO to focus on incorporating large changes within their modeling (such as new emerging technologies, etc.)
- Due to this, the latest available AEO was released in March 2023.
- Siemens PTI produces and regularly updates our gas outlooks via a fundamentals-based industry standard model, GPCM. which also incorporates recent forwards as of October 2024.
- **After careful consideration, we have collectively decided to use the EIA 2023 AEO, despite its outdated nature, as it remains more conservative and aligns with ERCOT's RTP study.**




Natural Gas Basis

WAHA Hub Basis Insights

- WAHA hub often shows more volatility due to infrastructure constraints and pipeline bottlenecks in West Texas
- WAHA prices historically trade at a discount to Henry Hub due to transportation costs and regional supply imbalances.

Waha Future Expectations

- Anticipated to benefit from infrastructure upgrades, which are expected to reduce the differential with Henry Hub
- Various projects are expected to alleviate bottlenecks including:
 - Matternhorn Express Pipeline (operational as of late 2024)
 - Blackcomb Pipeline (expected 2026)
 - Hugh Brinson Pipeline (approved Q4 2024, operations expected 2026)



Note: Historical prices from Jan 2019 to September 2024. Reference case prices were developed using NYMEX forwards (Forwards are an average of 10/2/2024, 10/9/2024, and 10/16/2024). Forwards were used until March 2026 with hybrid of forwards and fundamentals until September 2027 and pure fundamentals thereafter.


Currently, less than 10% of the total gas capacity in ERCOT is utilizing the WAHA price point.

Appendix B – PV Analysis

PV Analysis Conclusions


Methodology:

- Cases were adjusted based on ERCOT 2030 RTP cases to have a reasonable west to east flow in the WTE GTC interface:
- ALL ERCOT coal and CT units were turned off
- Partial East/Coastal CC units were turned off/ dispatched down
- ERCOT loads were scaled down from 155 GW (in RTP cases) to 115 GW which aligns with 2039 current trend



Key Insights:

- For the study year 2039, results show an improvement of 2.8 GW (**23.9%**) in WTE GTC transfer capacity for 345-kV option and 3.8 GW (**32%**) for 765-kV core plan.
- The 765-kV option demonstrates substantially greater improvement in transfer capability compared to the 345-kV option (**~1GW** higher).
- The results of year 2034 shows similar trends when using same topology but with lower load level modeled.



Appendix C - Economic Results

Annual Revenue Requirements

- To evaluate the CBA of each transmission system (765-kV and 345-kV), we calculated the Annual Revenue Requirement (ARR) associated with each buildout.
- ARR provides a standardized annualized cost for capital investments,.
- We used the Capital Charge Rate (CCR) approach to annualize total capital costs.
- The CCR converts up-front capital costs into an equivalent annual cost.
- The total ARR includes:
 - Cost of capital (debt & equity)
 - Asset life (amortization schedule)
 - Depreciation schedule
 - Income taxes (federal & state)
 - Property taxes
 - Insurance
 - Fixed O&M

Annual Revenue Requirement

| | |
|------------|--------------|
| 765-kV ARR | 4.278 B/year |
| 365-kV ARR | 4.102 B/year |

Financial Assumptions

| | | |
|---------------------------|------|-------|
| Useful Life | 40 | years |
| Cost of Equity | 13.0 | % |
| Cost of Debt | 7.3 | % |
| Equity | 40 | % |
| Debt | 60 | % |
| Depreciation Annual Rate | 2.50 | % |
| WACC (Nominal After Tax) | 8.66 | % |
| Insurance and Admin | 0.70 | % |
| Tax Rate | 21.0 | % |
| Property Taxes | 0.7 | % |
| Capital Charge Rate (CCR) | 12.6 | % |

Economic Assumptions

| | | |
|---------------------|---------|-----------|
| CAPEX 765-kV | 33.9 | Billion |
| CAPEX 345-kV | 32.55 | Billion |
| 765-kV Miles | 2468 | Miles |
| 345-kV Miles | 2673 | Miles |
| Annual FOM (765-kV) | \$8,000 | Mile-year |
| Annual FOM (345-kV) | \$5,000 | Mile-year |

Contact

Nelson Bacalao

Principal

8850 Fallbrook Dr,
Houston, TX 77064, USA

Mobile

E-mail nelson.bacalao@siemens.com

Angelina Martinez

Consulting Director

8850 Fallbrook Dr,
Houston, TX 77064, USA

Mobile

E-mail Angelina.martinez@siemens.com

Chelsea Cupit

Project Manager

8850 Fallbrook Dr,
Houston, TX 77064, USA

Mobile


E-mail: chelsea.Laricci@siemens.com

For further information:

<https://www.siemens.com/us/en/products/energy/grid-software/pti-consulting.html>



Weather Zone by County



Study Assumptions Overview - Emphasizing High Load Outlook for Future Planning

- The assumptions of the study mimics the Current Trends and the High Large Load Adoption scenario from the 2024 LTSA
- Current Trends Scenario:** Reflects ERCOT's baseline outlook with moderate economic and demand growth, reflecting historical trends and expected economic expansion.
- High Large Load Adoption Scenario:** Includes over 70 GW of new load from TSP forecasts, driven by cryptomining, hydrogen, and data centers.

| Input | Scenario | Source | 2034 | 2039 |
|-----------------------|--------------------------|-------------------------------------|--|---|
| Load | Current Trends | LTSA | 109-GW | 115-GW |
| | High Large Load Adoption | LTSA Mapping: RPG (155-GW modeled) | 144-GW | 186-GW (31-GW unmapped: allocate ¼ to CNP, ¾ Oncor/AEP) |
| | Sensitivity Case | RTP Mapping: RPG (155-GW modeled) | 126-GW | 151-GW |
| Capacity Additions | Current Trends | LTSA | 57.9-GW | 87.7-GW |
| | High Large Load Adoption | LTSA Mapping: RPG (246-GW modeled) | 197-GW | 285-GW (39-GW unmapped: allocate to strong 345-kV buses) |
| | Sensitivity Case | Mapping: RPG (246-GW modeled) | TBD | TBD |
| Natural Gas Price | All Scenarios | HH: EIA 2023 AEO Basis: Siemens PTI | \$3.67/MMBTU (2024) | \$4.15/MMBTU (2024) |
| Transmission Topology | All Scenarios | RTP Cases | 345-kV RTP (2038) 765-kV RTP STEP Case (2030) | 345-kV RTP (2038) 765-kV RTP STEP Case (2030) |

LTSA – Long-Term System Assessment (2024)
RTP – Regional Transmission Plan (2024)
RPG – Regional Planning Group