



## **Filing Receipt**

**Filing Date - 2024-04-17 09:30:17 AM**

**Control Number - 55983**

**Item Number - 102**



## Public Utility Commission of Texas

### Annual Report

Required by 16 Texas Admin. Code § 25.97(f)

**PROJECT NO.** 55983

**AFFECTED ENTITY:** City of Austin dba Austin Energy

#### General Information

Pursuant to 16 Texas Admin. Code § 25.97(f)(1), not later than May 1 of each year, each affected entity must submit this report for the preceding calendar year. The first report must be submitted not later than May 1, 2020.

#### Instructions

Answer all questions, fill-in all blanks, and have the report notarized in the affidavit. If you check no in part 1.a, leave parts 1.b-d blank.

Violations resulting from, and incidents, fatalities, or injuries attributable to a violation resulting from, a natural disaster, weather event, or man-made act or force outside of an affected entity's control are not required to be reported.

#### Affidavit

A representative of the affected entity must swear to and affirm the truthfulness, correctness, and completeness of the information provided by attaching a signed and notarized copy of the Affidavit provided with this form.

#### Filing Instructions

Submit four copies (an original and three copies) of the completed form and signed and notarized Affidavit to:

Central Records Filing Clerk  
Public Utility Commission of Texas  
1701 N. Congress Avenue  
P.O. Box 13326  
Austin, Texas 78711-3326  
Telephone: (512) 936-7180

1. This part applies only to an affected entity that owns or operates overhead transmission facilities greater than 60 kilovolts.

a) Does this part 1 apply to you? Yes  No

b) Provide the number of identified occurrences of noncompliance with Public Utility Regulatory Act (PURA) § 38.004 regarding vertical clearance requirements of the National Electrical Safety Code (NESC) for overhead transmission facilities.

City of Austin dba Austin Energy has identified and confirmed two new occurrences during the reporting period. The first occurrence is a vertical clearance to ground. A modification to address the issue is currently in design. The second occurrence is due to an encroachment installed by a landowner. The landowner has been notified of the issue and requested to relocate their storage shed.

c) Do you have actual knowledge that any portion of your transmission system is not in compliance with PURA § 38.004 regarding vertical clearance requirements of the NESC for overhead transmission facilities?

The occurrences described in response 1b) are the only instances City of Austin dba Austin Energy is aware of.

d) Do you have actual knowledge of any violations of easement agreements with the United States Army Corps of Engineers relating to PURA § 38.004 regarding vertical clearance requirements of the NESC for overhead transmission facilities?

No

2. This part applies to an affected entity that owns or operates overhead transmission facilities greater than 60 kilovolts or distribution facilities greater than 1 kilovolt.
- a) Provide the number of fatalities or injuries of individuals other than employees, contractors, or other persons qualified to work in proximity to overhead high voltage lines involving transmission or distribution assets related to noncompliance with the requirements of PURA § 38.004.

Zero

b) Provide a description of corrective actions taken or planned to prevent the reoccurrence of fatalities or injuries described in subpart a), immediately above.

Not Applicable

**AFFIDAVIT**

I swear or affirm that I have personal knowledge of the facts stated in this report or am relying on people with personal knowledge, that I am competent to testify to them, and that I have the authority to submit this report on behalf of the affected entity. I further swear or affirm that all statements made in this report are true, correct, and complete.

Lisa J Martin

Signature

Lisa Martin

Printed Name


Deputy General Manager & Chief Operating Officer

Job Title

City of Austin dba Austin Energy

Name of Affected Entity

Sworn and subscribed before me this 15 day of April, 2024  
Month Year



S Budy

Notary Public in and For the State of Texas

My commission expires on 02-22-2026