

Filing Receipt

Filing Date - 2024-04-30 09:14:36 AM

Control Number - 55983

Item Number - 143



Public Utility Commission of Texas

Annual Report Required by 16 Texas Admin. Code § 25.97(f)

PROJECT NO. 55983

AFFECTED ENTITY: Fannin County Electric Cooperartive

General Information

Pursuant to 16 Texas Admin. Code § 25.97(f)(1), not later than May 1 of each year, each affected entity must submit this report for the preceding calendar year. The first report must be submitted not later than May 1, 2020.

Instructions

Answer all questions, fill-in all blanks, and have the report notarized in the affidavit. If you check no in part 1.a, leave parts 1.b-d blank.

Violations resulting from, and incidents, fatalities, or injuries attributable to a violation resulting from, a natural disaster, weather event, or man-made act or force outside of an affected entity's control are not required to be reported.

Affidavit

A representative of the affected entity must swear to and affirm the truthfulness, correctness, and completeness of the information provided by attaching a signed and notarized copy of the Affidavit provided with this form.

Filing Instructions

Submit four copies (an original and three copies) of the completed form and signed and notarized Affidavit to:

Central Records Filing Clerk Public Utility Commission of Texas 1701 N. Congress Avenue P.O. Box 13326 Austin, Texas 78711-3326 Telephone: (512) 936-7180

1. Thi faci	1. This part applies only to an affected entity that owns or operates overhead transmission facilities greater than 60 kilovolts.					
	a)	Does this part 1 apply to you? Yes No				
	b)	Provide the number of identified occurrences of noncompliance with Public Utility Regulatory Act (PURA) § 38.004 regarding vertical clearance requirements of the National Electrical Safety Code (NESC) for overhead transmission facilities.				
N/A						
:						

	c)	Do you have actual knowledge that any portion of your transmission system is not in compliance with PURA § 38.004 regarding vertical clearance requirements of the NESC for overhead transmission facilities?
N/A		
	d)	Do you have actual knowledge of any violations of easement agreements with the United States Army Corps of Engineers relating to PURA § 38.004 regarding vertical clearance requirements of the NESC for overhead transmission facilities?
N/A		
		•

- 2. This part applies to an affected entity that owns or operates overhead transmission facilities greater than 60 kilovolts or distribution facilities greater than 1 kilovolt.
 - a) Provide the number of fatalities or injuries of individuals other than employees, contractors, or other persons qualified to work in proximity to overhead high voltage lines involving transmission or distribution assets related to noncompliance with the requirements of PURA § 38.004.

Fannin County Electric requirements.	Cooperative has had n	o fatalities or injuries relate	d to noncomplicance
		•	

b) Provide a description of reoccurrence of fatalities of	Provide a description of corrective actions taken or planned to prevent the reoccurrence of fatalities or injuries described in subpart a), immediately above.					
N/A						
14771						
	•					
	•					
	•					
	•					
	•					
	•					
	•					

AFFIDAVIT

I swear or affirm that I have personal knowledge of the facts stated in this report or am relying on people with personal knowledge, that I am competent to testify to them, and that I have the authority to submit this report on behalf of the affected entity. I further swear or affirm that all statements made in this report are true, correct, and complete.

Signature

John Ed Shinpaugh

Printed Name

General Manager / CEO

Job Title

Fannin County Electric Cooperative

Name of Affected Entity

Sworn and subscribed before me this 30th day of A

Month

Vear

Notary Public in and For the State of 70

My commission expires on 6/31/3027

