



Filing Receipt

Filing Date - 2024-04-10 12:37:29 PM

Control Number - 55983

Item Number - 73



Public Utility Commission of Texas

Annual Report

Required by 16 Texas Admin. Code § 25.97(f)

PROJECT NO. 55983

AFFECTED ENTITY: Trinity Valley Electric Cooperative Inc.

General Information

Pursuant to 16 Texas Admin. Code § 25.97(f)(1), not later than May 1 of each year, each affected entity must submit this report for the preceding calendar year. The first report must be submitted not later than May 1, 2020.

Instructions

Answer all questions, fill-in all blanks, and have the report notarized in the affidavit. If you check no in part 1.a, leave parts 1.b-d blank.

Violations resulting from, and incidents, fatalities, or injuries attributable to a violation resulting from, a natural disaster, weather event, or man-made act or force outside of an affected entity's control are not required to be reported.

Affidavit

A representative of the affected entity must swear to and affirm the truthfulness, correctness, and completeness of the information provided by attaching a signed and notarized copy of the Affidavit provided with this form.

Filing Instructions

Submit four copies (an original and three copies) of the completed form and signed and notarized Affidavit to:

Central Records Filing Clerk
Public Utility Commission of Texas
1701 N. Congress Avenue
P.O. Box 13326
Austin, Texas 78711-3326
Telephone: (512) 936-7180

1. This part applies only to an affected entity that owns or operates overhead transmission facilities greater than 60 kilovolts.

a) Does this part 1 apply to you? Yes No

b) Provide the number of identified occurrences of noncompliance with Public Utility Regulatory Act (PURA) § 38.004 regarding vertical clearance requirements of the National Electrical Safety Code (NESC) for overhead transmission facilities.

Empty response area for question b)

c) Do you have actual knowledge that any portion of your transmission system is not in compliance with PURA § 38.004 regarding vertical clearance requirements of the NESC for overhead transmission facilities?

[Empty response box for question c)]

d) Do you have actual knowledge of any violations of easement agreements with the United States Army Corps of Engineers relating to PURA § 38.004 regarding vertical clearance requirements of the NESC for overhead transmission facilities?

[Empty response box for question d)]

2. This part applies to an affected entity that owns or operates overhead transmission facilities greater than 60 kilovolts or distribution facilities greater than 1 kilovolt.

- a) Provide the number of fatalities or injuries of individuals other than employees, contractors, or other persons qualified to work in proximity to overhead high voltage lines involving transmission or distribution assets related to noncompliance with the requirements of PURA § 38.004.

Trinity Valley Electric Cooperative Inc. experienced no fatalities or injuries of individuals on our electric distribution facilities in 2023 based on the above criteria.

b) Provide a description of corrective actions taken or planned to prevent the reoccurrence of fatalities or injuries described in subpart a), immediately above.

Trinity Valley Electric Cooperative Inc. experienced no incidents to mandate the need for corrective actions on our electric distribution facilities in 2023.

AFFIDAVIT

I swear or affirm that I have personal knowledge of the facts stated in this report or am relying on people with personal knowledge, that I am competent to testify to them, and that I have the authority to submit this report on behalf of the affected entity. I further swear or affirm that all statements made in this report are true, correct, and complete.

Chad Marshall

Signature

Chad Marshall

Printed Name

Manager of Safety and Loss Control

Job Title

Trinity Valley Electric Cooperative Inc.

Name of Affected Entity

Sworn and subscribed before me this 10 day of April, 2024
Month Year

Leah M. Bass

Notary Public in and For the State of Texas

My commission expires on 10/18/2027

