

Filing Receipt

Filing Date - 2024-10-22 03:35:25 PM

Control Number - 55999

Item Number - 73

PROJECT NO. 55845

REVIEW OF ANCILLARY SERVICES § PUBLIC UTILITY COMMISSION §
IN THE ERCOT MARKET § OF TEXAS

PROJECT NO. 55999

REPORTS OF THE ELECTRIC§PUBLIC UTILITY COMMISSION§88RELIABILITY COUNCIL OF TEXAS§0F TEXAS

ERCOT'S REQUEST FOR APPROVAL OF 2025 ERCOT METHODOLOGIES FOR DETERMINING MINIMUM ANCILLARY SERVICE REQUIREMENTS

Electric Reliability Council of Texas, Inc. (ERCOT) files with the Public Utility Commission of Texas (Commission) a request for approval of the 2025 ERCOT Methodologies for Determining Minimum Ancillary Service Requirements (hereinafter, the 2025 Ancillary Service Methodology). If approved, the 2025 Ancillary Service Methodology would be effective on January 1, 2025, and, beginning on that date would govern, throughout 2025, how ERCOT calculates the minimum amounts of each Ancillary Service procured.

I. Background

Ancillary Services are "services necessary to facilitate the transmission of electric energy including load following, standby power, backup power, reactive power, and any other services as the [C]ommission may determine by rule."¹ Ancillary Services are necessary to maintain the reliability of the ERCOT System; they are procured to 1) meet certain supply-and-demand-balancing-related reliability objectives defined in North American Electric Reliability Corporation (NERC) Reliability Standards and/or 2) reduce operational risks associated with the uncertainty and variability of both supply resources and customer demands on the grid. Ancillary Services are "ancillary" in that they provide supplemental operational capabilities that would not otherwise be provided solely by, or explicitly incented by, the energy market.

¹ Public Utility Regulatory Act, Tex. Util. Code Ann. § 35.004(e) (PURA).

The ERCOT Protocols define the Ancillary Services procured by ERCOT and charge ERCOT with determining a methodology to establish the minimum levels of Ancillary Services required for reliability (the Ancillary Service Methodology). Paragraph (2) of Protocol Section 3.16 requires ERCOT, at least annually, to determine this Ancillary Service Methodology. Paragraph (3) of Section 3.16 requires the Board to review and recommend approval of the Ancillary Service Methodology. This year, consistent with Commission guidance, the ERCOT Protocols were modified so that the Board recommendation now requires Commission approval before implementation.²

This filing is the first time the Ancillary Service Methodology is submitted for Commission review and approval. ERCOT seeks approval of the 2025 Ancillary Service Methodology to be effective on January 1, 2025. Below is a concise summary of the meetings in which ERCOT staff sought stakeholder feedback or a recommendation from the ERCOT Board of Directors (ERCOT Board) on the 2025 Ancillary Service Methodology. The dates provide hyperlinks to the presentations given at the respective meetings.

| Date | Group | Vote |
|-----------------|--|---|
| 07/23/24 | Wholesale Market Working Group (WMWG) | Not applicable (n/a) |
| 07/24/24 | Performance, Disturbance, Compliance Working Group (PDCWG) | n/a |
| <u>08/15/24</u> | Operations Working Group (OWG) | n/a |
| 08/21/24 | PDCWG | n/a |
| 08/30/24 | WMWG | n/a |
| 09/09/24 | Reliability and Operations Subcommittee (ROS) | Endorsed proposed changes to the Ancillary Service Methodology for 2025 as recommended by ERCOT staff: 26 votes in favor, none against, and 2 abstentions (1 Independent Generator representative (rep.), 1 Independent Power Marketer rep.), resulting in a weighted endorsement percentage of 100% |
| 09/11/24 | Wholesale Market Subcommittee (WMS) | Endorsed proposed changes to the Ancillary Service Methodology for 2025 as recommended by ERCOT staff: 20 votes in favor, none against, and 7 abstentions (1 Industrial Consumer rep., 4 Independent Generator reps., 1 Independent Power |

² ERCOT Nodal Protocols § 3.16.3.

| | | Marketer rep., 1 Independent REP rep.), resulting |
|-----------------|--------------------------|---|
| | | in a weighted endorsement percentage of 100% |
| 09/19/24 | Technical Advisory | Endorsed the 2025 Ancillary Service Methodology |
| | Committee (TAC) | as recommended by ERCOT staff: 26 votes in |
| | | favor, 1 vote against (1 Independent Generator |
| | | rep.), and 2 abstentions (1 Independent Generator |
| | | rep., 1 Independent Power Marketer rep.), resulting |
| | | in a weighted endorsement percentage of 96% |
| <u>10/09/24</u> | Reliability and Markets | Recommended the ERCOT Board recommend that |
| | Subcommittee of the | the PUC authorize and approve the proposed 2025 |
| | ERCOT Board of Directors | ERCOT Methodologies for Determining Minimum |
| | | Ancillary Service Requirements (2025 AS |
| | | Methodology) as recommended by ERCOT staff |
| | | and as endorsed by TAC, to be effective on January |
| | | 1, 2025: all votes in favor with no objections or |
| | | abstentions |
| 10/10/24 | ERCOT Board of Directors | Recommended approval of the proposed 2025 |
| | | ERCOT Methodologies for Determining Minimum |
| | | Ancillary Service Requirements (2025 AS |
| | | Methodology) as recommended by ERCOT staff, to |
| | | be effective January 1, 2025: all votes in favor with |
| | | no objections or abstentions |

Moreover, at the October 9, 2024 meeting of the ERCOT Board's Reliability and Markets Subcommittee, the Independent Market Monitor (IMM) confirmed it had no objections to the 2025 Ancillary Service Methodology.

ERCOT notes that other efforts regarding Ancillary Services, such as the pending development of a report providing an overview of ERCOT Ancillary Services and recommendations for future improvements, are underway and may affect how ERCOT determines amounts of Ancillary Services procured in years after 2025. PUC approval would be required before any such changes would go into effect through a process such as PUC consideration of revisions to the Ancillary Services Methodology for future years or to ERCOT Protocols, Guides, or Other Binding Documents.

II. Summary of Revisions

The primary changes for the 2025 Ancillary Services Methodology in comparison to the 2024 Ancillary Services Methodology are related to Regulation Service, ERCOT Contingency Reserve Service (ECRS), and Non-Spinning Reserve (Non-Spin) Service. No changes have been

proposed to the methodology used to compute Responsive Reserve Service. The changes are shown in red-line format in <u>Attachment A</u> to this filing and can be summarized as follows:

- Responsive Reserve Service (RRS) No Change
- Regulation Service
 - Change the computations to improve how historic error in forecasted net load used in Security-Constrained Economic Dispatch is accounted.
- ERCOT Contingency Reserve Service (ECRS)
 - Change the computations such that ECRS requirements are determined as the larger of capacity needed to recover frequency and capacity needed to support the net load forecast for the respective hour.
 - Adjust the frequency-recovery-related computations such that it covers 70% of historic net load and inertia conditions.
 - Remove the adjustment for risk to cover 90th percentile of historical intra-hour net load uncertainty which was previously applied during sunset hours.
- Non-Spin Reserve Service
 - Change the computations for Hour Ending 23 to Hour Ending 06 such that Non-Spin requirements for these hours are determined using 4-hour-ahead net load forecast error.

In addition to the changes proposed in the 2025 Ancillary Services Methodology outlined above, Attachment A updates the minimum level of RRS from Resources providing RRS using Primary Frequency Response to 1,365 MW due to a change in ERCOT's Interconnection Frequency Response Obligation (IFRO). The IFRO was changed in accordance with NERC Reliability Standard BAL-003, Frequency Response and Frequency Bias Setting. Lastly, the adjustment tables that are used by these Ancillary Services methodologies are being removed from the 2025 Ancillary Services Methodology and will be separately posted in the public reports that contain the minimum quantities.

III. <u>Request for Approval</u>

Attachment B to this filing provides the ERCOT Board resolution recommending that the Commission authorize and approve ERCOT's implementation of the 2025 Ancillary Services Methodology, as set forth in Attachment A, to be effective on January 1, 2025. ERCOT seeks the Commission's authorization and approval, consistent with the ERCOT Board's recommendation. If the Commission provides such authorization and approval, the 2025 Ancillary Services Methodology will be accessible in the market information posted on ERCOT's website at https://www.ercot.com/mktinfo/dam/index.html.

ERCOT appreciates the Commission's consideration of the 2025 Ancillary Services Methodology and will attend the Commission Open Meeting(s) at which this item is posted for discussion and possible action.

Respectfully submitted,

<u>/s/ Davida Dwyer</u> Chad V. Seely Senior Vice President and General Counsel Texas Bar No. 24037466 (512) 225-7035 (Phone) chad.seely@ercot.com

Nathan Bigbee Deputy General Counsel Texas Bar No. 24036224 512-225-7093 (Phone) nathan.bigbee@ercot.com

Davida Dwyer Senior Corporate Counsel Texas Bar No. 24052120 (512) 225-7182 (Phone) davida.dwyer@ercot.com ERCOT 8000 Metropolis Drive, Bldg. E, Suite 100 Austin, Texas 78744 (512) 225-7079 (Fax)

ATTORNEYS FOR ELECTRIC RELIABILITY COUNCIL OF TEXAS, INC.

ATTACHMENT A

2025 ERCOT Methodologies for Determining Minimum Ancillary Service Requirements -Redlined Version Showing Changes from the 2024 ERCOT Methodologies for Determining Minimum Ancillary Service Requirements

ERCOT Methodologies for Determining Minimum Ancillary Service Requirements

ERCOT Board <u>Recommended</u> approvaled on 12XX/19XX/2023XXXX

PUC Approved on XX/XX/XXXX

Effective Date of 1/1/20254

TABLE OF CONTENTS

| INTRODUCTION | 2 |
|---|----|
| REGULATION SERVICE REQUIREMENT DETAILS | 3 |
| NON-SPINNING RESERVE (NON-SPIN) REQUIREMENT DETAILS | 9 |
| RESPONSIVE RESERVE (RRS) REQUIREMENT DETAILS | .5 |
| ERCOT CONTINGENCY RESERVE SERVICE (ECRS) DETAILS | .6 |

Introduction

Paragraph (2) of Protocol Section 3.16, Standards for Determining Ancillary Service Quantities, requires that methodologies for determining the amounts of Ancillary Services to be required by ERCOT must be developed at least annually. Paragraph (3) of Protocol Section 3.16 requires approval review of this methodology by the ERCOT Board of Directors and approval by the Public Utility Commission of Texas (PUCT)Board of Directors.

This document discusses the various Ancillary Services for which requirements are to be developed. Further, detailed methodologies for determining those requirements are included as part of this document.

Specifically, methodologies are required for the determination of the quantities of Regulation Service, ERCOT Contingency Reserve Service (ECRS), Non-Spinning Reserve (Non-Spin) and Responsive Reserve (RRS) that are required to maintain system reliability. Those procedures are discussed below.

These procedures are intended for determining each of the Ancillary Service requirements for all months of the upcoming year. This procedure will be performed annually. The Ancillary Service requirements are determined annually and will be posted to the Market Information System (MIS) by December 20th for the upcoming year. If necessary, any additional incremental adjustment to the posted Ancillary Service requirements for a particular month will be made using this procedure and will be posted to the MIS prior to the 20th of each month for the upcoming month. If the Ancillary Service requirements identified through this process for a particular operating day are found to be insufficient based on the expected operating conditions for that day, ERCOT may make an updated Ancillary Service requirements posting for that day if the need for incremental adjustments is identified day-ahead and may use the Supplemental Ancillary Service Market (SASM) process for similar adjustments made closer to Real-Time. For any additional months for which ERCOT is required to provide an Ancillary Service requirement forecast, the forecasted requirement will be set to the historical requirement for the same month of the previous year.

Regulation Service Requirement Details

Introduction

Regulation Service consists of resources that can be deployed by ERCOT in response to changes in ERCOT System frequency to maintain the target ERCOT System frequency within predetermined limits according to the Operating Guides. ERCOT is required to evaluate normal requirements for Reg-Up Service and Reg-Down Service on an annual basis. It is ERCOT's practice to use historical rates of Regulation Service usage to perform evaluation and determine the required quantities for this service. Regulation Service is deployed in order to correct actual frequency to scheduled frequency and to ensure North American Electric Reliability Corporation (NERC) requirements are met.

Summary

The Regulation Service requirements are calculated with the expectation that sufficient Regulation Service will be available to cover the 95th percentile of deployed regulation or net load variability. An adjustment may also be made based on historic CPS1 performance.

Procedure

To evaluate Regulation Service requirements, ERCOT will collect historical Resource Registration information, CPS1 data, Regulation Service deployment data, aggregate output data, and ERCOT system load data. For determining the base Reg-Up requirements for a particular hour, ERCOT will <u>calculate take the largest of the 95th percentile of Reg Up deployments for the same month of the previous two years, and the 95th percentile of the positive net load (load – wind – solar) forecast error changes for the same month of the previous two years. For determining the base Reg-Down requirements, ERCOT will <u>calculate take the largest of the 95th percentile of the 95th percentile of Reg-Down deployments for the same month of the previous two years and the 95th percentile of the negative net load (load – wind – solar) forecast error changes for the same month of the previous two years and the 95th percentile of the negative net load (load – wind – solar) forecast error changes for the same month of the previous two years and the 95th percentile of the negative net load (load – wind – solar) forecast error changes for the same month of the previous two years. To better reflect balancing needs within the hours, the net load variability may be updated to account for accumulated Area Control Error (ACE).</u></u>

In order to consider the increased amount of wind and solar penetration, ERCOT will calculate the increase in installed wind and solar generation capacity, respectively. Then, depending on the month of the year and the hour of the day, ERCOT will add incremental MWs that are derived using the wind and solar <u>forecast error</u> adjustment tables and associated increase in wind and solar generation capacity, to the <u>maximum</u>-values determined above. The wind and solar <u>forecast error</u> adjustment tables for incremental MWs for Reg-Up and Reg-Down come from the study ERCOT performs annually, using similar techniques as the 2008 GE wind study, but using actual wind and solar data respectively. The increase in wind (or solar) generation capacity will be calculated by taking the total nameplate capacity of wind (or solar) resources in the ERCOT network model at the time of the procurement study and subtracting out the total nameplate capacity of wind (or solar) resources in the ERCOT metwork model at the end of the month being studied from the previous year.

ERCOT will post these monthly amounts for Regulation Service requirements for the upcoming year on the MIS.

If any incremental changes to the annually posted amounts are needed then the revised amounts for the following month will be posted to the MIS prior to the 20th of the current month. ERCOT

may include adjustments for hours in a month considering monthly average for CPS1 and 12month rolling average CPS1 scores. If it is determined that during the course of the year that the ERCOT monthly average for CPS1 score was less than 140% for a specific month, ERCOT will apply an extra 10% of both Reg-Up and Reg-Down for hours in which the CPS1 score was less than 140%. Additionally, if the ERCOT 12-month rolling average CPS1 score is less than 140%, for the next month ERCOT will procure an extra 10% of both Reg-Up and Reg-Down for hours in which the hourly CPS1 score was less than 140%. This value will increase to 20% if the CPS1 score falls below 100%.

| Increm Growtl | ental 1 | MW A | djustr | nent to |) Prio | -Year | Up-Re | egulati | on Va | lue, pe | r 1000 |) MW | of Inc | remen | tal Wi | nd Ge | neratio | on Ca j | oacity, | to Acc | count l | for Wi | nd Ca | pacity |
|------------------|------------------------|----------------|----------------|----------------|----------------|----------------|-------|----------------|------------------|----------------|-------------------|-------------------|-----------------|----------------|----------------|----------------|----------------|--------------------|----------------|-----------------|----------------|-----------------|-----------------|----------------|
| | | | | | | | | | | | Hou | Ir End | ing | | | | | | | | | | | |
| Month | 1 | Ŧ | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | # | 12 | 13 | 44 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 | 24 |
| dan. | 1.3 | 0.7 | 1.3 | +.+ | 2.1 | 1.3 | 1.2 | 1.3 | 4.1 | 3.8 | 1.0 | 0.9 | 1.5 | 1.9 | +.+ | 1.4 | 2.4 | 1.8 | -0.5 | -0.7 | -0.3 | 0.0 | 0.0 | 0.0 |
| Feb. | 0.7 | 0.8 | 1.4 | 0.7 | 1.0 | 1.4 | 1.1 | 1.9 | 3.5 | 3.3 | 2.2 | 1.7 | 2.0 | +:+ | 0.2 | 1.1 | 0.5 | 2.4 | 0.6 | -1.4 | -0.5 | -0.7 | -0.2 | 0.2 |
| Mar. | 13 | 0.6 | 1.0 | 0.6 | 0.6 | 1.3 | 1.4 | 1.4 | 5.1 | 4.0 | 1.4 | 2.4 | 3.0 | 1.1 | 1.3 | 1.3 | 1.7 | 3.1 | 2.7 | 2.9 | 0.9 | 0.1 | 0.3 | 0.5 |
| Apr. | -0.3 | 0.0 | 0.9 | 1.2 | +.+ | 0.9 | 1.3 | 2.1 | 3.3 | 0.5 | 2.2 | 3.0 | 4.3 | 2.9 | 2.5 | 1.0 | 0.9 | 1.2 | 1.3 | 2.6 | 0.7 | -0.1 | -0.1 | -0.3 |
| May | 0.2 | 0.8 | 0.6 | 1.7 | 1.6 | 3.2 | 1.4 | 3.7 | 3.9 | 1.8 | 3.3 | 3.7 | 2.6 | 2.6 | 0.3 | 4.0 | 0.1 | 0.3 | 0.4 | 4.0 | +.+ | -0.2 | 0.0 | 0.0 |
| dun. | 0.2 | 0.3 | 0.6 | 1.6 | 2.0 | 2.1 | 2.7 | 6.5 | 2.3 | 4.4 | 2.9 | 4.2 | 3.2 | 44 | 0.0 | 0.1 | -0.1 | -0.2 | -0.1 | 0.0 | 0.3 | -0.4 | 0.0 | 0.0 |
| dul. | 0.1 | 0.2 | 1.0 | 1.7 | 1.6 | 2.7 | 2.5 | 6.3 | 2.0 | 2.3 | 5.1 | 4.3 | 2.4 | 0.3 | -0.2 | -0.6 | -0.2 | -0.2 | -0.6 | -0.1 | 0.9 | -0.1 | 0.0 | 0.0 |
| Aug. | 0.7 | 0.8 | 1.0 | +.+ | 1.9 | 1.4 | 0.7 | 5.0 | 4.2 | 0.5 | 3.0 | 3.2 | 1.3 | 0.3 | -0.8 | -0.7 | 0.0 | -0.2 | -0.3 | 0.4 | 0.9 | -0.1 | 0.0 | 0.0 |
| Sep. | -0.1 | 0.5 | 0.9 | 1.5 | 1.5 | 2.1 | 1.3 | 2.3 | 6.4 | 2.3 | 1.5 | 1.8 | 1.1 | 0.4 | 0.8 | -0.9 | -0.2 | -0.5 | 0.3 | 0.1 | -0.8 | -0.4 | 0.0 | 0.0 |
| Qet. | -0.3 | 0.4 | 1.6 | 1.3 | 1.5 | 1.1 | 1.3 | 1.6 | 4.9 | 5.0 | 0.2 | 0.9 | 0.7 | 0.8 | 0,1 | -0.3 | 0.4 | 0.9 | 0.7 | -1.0 | -0.6 | -0.2 | -0.1 | 0.4 |
| Nov. | 0,5 | +.2 | 1.5 | 1.0 | 0.9 | 0.5 | 2.8 | 3.1 | 3.2 | 1.3 | 0.4 | 0,1 | 0, 4 | 0.5 | 0.6 | 1.2 | 1.6 | 0.7 | 0.4 | -0.2 | 0.4 | 0.1 | 0.2 | 0.3 |
| Dec. | 0.5 | 0.0 | 1.5 | 1.5 | +.+ | 1.0 | 0.8 | 1.2 | 2.7 | 2.2 | 0.5 | 0.7 | 0.3 | 0.8 | 0,9 | 0.8 | 2.3 | 1.1 | -0.8 | -0.2 | 0.0 | 0.4 | 0.1 | 0.4 |

I

| | | | | | | | | | | H | our Er | ding | | | | | | | | | | | | |
|-----------------|----------------|----------------|-----------------|------|----------------|----------------|----------------|-----------------|----------------|----------------|----------------|----------------|----------------|----------------|-----|-----|-----|---------------|-----|-----|----------------|----------------|-----------------|----------------|
| Month | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 45 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 | 24 |
| Jan. | 0.8 | 1.6 | 1.0 | 0.8 | 0.3 | -0.5 | -0.3 | -0,6 | -2.7 | -3.3 | 1.5 | 2.6 | 1.2 | 1.2 | 1.1 | 1.2 | 0.9 | 0.7 | 5.9 | 3.8 | 3.4 | 2.3 | 1.6 | 1.5 |
| Feb. | 0.7 | -0.5 | -0.3 | -0.3 | 0.1 | -0.2 | -0.2 | -0.4 | -4.8 | -2.8 | 0.3 | 1.4 | 1.5 | 0.6 | 0.3 | +.+ | 1.9 | 3.1 | 2.3 | 5.3 | 3,0 | 1.3 | 2.8 | 0.8 |
| Mar. | 0.1 | 0.3 | 1.1 | 1.1 | 0.5 | 0,1 | 0.0 | -0.9 | -3.9 | 0.3 | 3.0 | 1.0 | 2.2 | 0.5 | 1.5 | 1.7 | 1.9 | 1.3 | 2.3 | 4.4 | 5.9 | 4.3 | 3.3 | 3.4 |
| Apr. | 1.2 | 0.4 | -0.4 | 0,3 | -0.2 | -0.7 | -0,4 | -0.3 | 0.0 | 4.3 | 0.8 | 0.2 | -0.3 | 0.2 | 1.1 | 1.9 | 2.1 | 2.0 | 1.8 | 1.4 | 3.2 | 4.3 | 3,7 | 1.9 |
| May | 1.4 | 0.4 | -0.4 | -1.1 | -0.2 | -0.5 | -0.9 | -0.4 | 0.9 | 0,9 | -0.4 | -0.3 | 0,3 | 0.8 | 1.4 | 1.8 | 2.9 | 3,2 | 3.8 | 3.6 | 3,9 | 4.1 | 3.4 | 2.5 |
| Jun. | 1.1 | 0.1 | -1.3 | -2.1 | -1.3 | -1.4 | -1.6 | -1.0 | 0.7 | 0,1 | -0.1 | 0.0 | 0.2 | 0.7 | 1.2 | 1.8 | 2.6 | 2.7 | 2.7 | 2.3 | 2.5 | 5.4 | 4 .0 | 2.1 |
| Jul. | 1.0 | -0.8 | -1.3 | -1.5 | -1.6 | -2.5 | -1.7 | -1.4 | 0.6 | 0.0 | 0.0 | 0.0 | -0,1 | 0.6 | 2.1 | 2.9 | 3.5 | 4.4 | 3.6 | 3.2 | 1.9 | 6.8 | 4.7 | 2.0 |
| Aug. | 0.4 | -0.5 | -0.9 | -2.2 | -1.2 | -1.5 | -1.0 | -0.6 | 0.1 | 0.7 | -0.2 | -0.3 | 0.4 | 0.8 | 2.0 | 2.7 | 2.8 | 2.6 | 3.4 | 2.2 | 2.8 | 4.8 | 2.7 | 1.3 |
| Sep. | 0.1 | -1.4 | -0.6 | -1.2 | -1.6 | -1.0 | -0.6 | -0.8 | -0.8 | 0.0 | 0.1 | -0.1 | 0.1 | 0.1 | 1.0 | 1,1 | 1.9 | 2.2 | 2.3 | 2.8 | 6.4 | 5.1 | 3,4 | 1.5 |
| Oct. | 0.1 | -0.6 | -0.9 | -0.5 | -0.1 | -0.5 | -0.5 | 0.0 | -1.2 | -0.9 | 1.5 | 0.6 | 1.4 | 0.7 | 1.3 | 1.8 | 1.3 | 1.3 | 0,4 | 4.6 | 4.4 | 3.3 | 1.8 | 0.7 |
| Nov: | -0.1 | 0.0 | -0.4 | -0.7 | -0.2 | -0.4 | -0.4 | -1.0 | -1.0 | 0.3 | 2.3 | 1.4 | 1.4 | 1.3 | 0.9 | 1.3 | 0.9 | 1.0 | 3.5 | 3.9 | 1.9 | 1.9 | 1.2 | 0.1 |
| Dec. | -0.2 | -0.1 | -0.9 | 0.3 | 0.4 | 0.2 | 0.7 | 0.4 | -1.6 | -0.2 | 2.0 | 2.2 | 0.4 | -0.5 | 0.3 | 0.3 | 0.1 | 0.7 | 4.1 | 2.1 | 1.7 | 1.9 | 1.0 | 0.3 |

| Inerem Growtl | ental + | MW | / Adj | ustm | ent to | o Pri | ər-Ye a | ir Up- | Regula | ution V | Value, | per 10 | 00 MW | of Inc | rement | al Sola | r-Gener | ation C | apacity, | to Acco | unt fo | r Sola | r-Caj |)acity |
|------------------|-----------------------|-----|----------------|----------------|----------------|------------------|--------------------|-------------------|----------------|----------------|-------------------|-----------------|--------------------|----------------|----------------|----------------|------------------|-----------------|---------------------|----------------|-------------------|----------------|----------------|-------------------|
| ļ. | | | | | | | | | | | | He | ur En e | ling | | | | | | | | | | |
| Month | 4 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 44 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 | 24 |
| Jan. | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 2.6 | 4.2 | 5.3 | 5.9 | 7.2 | 7.6 | <u>9.9</u> | 18.0 | 15.1 | 1.4 | 0.1 | 0.0 | 0.0 | 0.0 | 0.0 |
| Feb. | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1.0 | 8.5 | 7,0 | 9.2 | 7.6 | 7.9 | 12,0 | 13,3 | 13,0 | 18.3 | 8.8 | 0,0 | 0.0 | 0.0 | 0.0 | 0.0 |
| Mar. | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0,0 | 0.0 | 8:6 | 8.6 | 10.6 | 12.3 | 13.4 | 13.2 | 15.9 | 15.5 | 17.2 | 16,6 | 11.7 | 0.1 | 0.0 | 0;0 | 0.0 |
| Apr. | 0,0 | 0.0 | 0,0 | 0,0 | 0,0 | 0.0 | 0,0 | 0.0 | +.+ | 7.1 | 9, 4 | 10,1 | 9,8 | 10.2 | 8,6 | 11,4 | 13.8 | 15.8 | 15,6 | 14,5 | 1,8 | 0.0 | 0,0 | 0,0 |
| May | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1.1 | 3.8 | 6.2 | 7.5 | 6.6 | 6.9 | 8.1 | 8.6 | -10.8 | 12.3 | 10.5 | 11.7 | 4.6 | 0.0 | 0.0 | 0.0 |
| Jun. | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 3.7 | 3.0 | 3.0 | 4.4 | 6.6 | 5.4 | 6.3 | 11.0 | 8.0 | 10.2 | 12.5 | 6.2 | 0.0 | 0.0 | 0.0 |
| dul. | 0.0 | 0,0 | 0.0 | 0.0 | 0.0 | 0,0 | 0.0 | 0.0 | 0,0 | 2.8 | 1.4 | 3.3 | 4.5 | 4.6 | 7.2 | 6,6 | 7.0 | 9,5 | 9.4 | 12.1 | 6.2 | 0.0 | 0.0 | 0.0 |
| Aug. | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 4.5 | 4.1 | 4.7 | 5.7 | 6.3 | 6.6 | 8.3 | 8.9 | 8.5 | 10.4 | 11.1 | 3.3 | 0,0 | 0.0 | 0.0 |
| Sep. | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0,0 | 0,0 | 0.0 | 0.8 | 3,9 | 4,1 | 5.2 | 6.0 | 7.4 | 6,9 | 7.2 | 9.5 | 13.9 | 8,0 | 0.0 | 0.0 | 0.0 | 0.0 |
| Qet. | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1.1 | 4.3 | 5.9 | 6.2 | 5.9 | 8.4 | 9.9 | 11.5 | 14.3 | 14.0 | 0.8 | 0.1 | 0.0 | 0.0 | 0.0 |
| Nov. | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1.4 | 4.7 | 5,6 | 8.5 | 8.9 | 8.0 | 9,4 | 11.0 | 14.3 | 8,8 | 5.6 | 0;0 | 0.0 | 0.0 | 0,0 | 0.0 |
| Dec. | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0,0 | 0.0 | 4.9 | 6.1 | 5.3 | 6.9 | 6.9 | 8.2 | 10.1 | 13,6 | 7.6 | 0.1 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

| | Hour Ending Month 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 | | | | | | | | | | | | | | | | | | | | | | | |
|-----------------|--|----------------|----------------|----------------|----------------|----------------|----------------|-----------------|-----------------|-----------------|----------------|-----------------|-----------------|----------------|----------------|-----------------|-----------------|-----------------|----------------|----------------|----------------|----------------|----------------|-----|
| Month | 4 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | # | +2 | 13 | 44 | 15 | 16 | 47 | 18 | 19 | 20 | 21 | 22 | 23 | 24 |
| Jan. | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 2.8 | 17.2 | 11.1 | 6.4 | 5.3 | 4.8 | 7,0 | 6.3 | 5.1 | 2.7 | 0.0 | 0,0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| Feb. | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 11.1 | 19.7 | 16.1 | 8.6 | 8.6 | 8.4 | 7.9 | 9,5 | 9.2 | 8.5 | 1.9 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| Mar. | 0.0 | 0,0 | 0.0 | 0.0 | 0:0 | 0.0 | 0,0 | 13,3 | 18.9 | 13.1 | 10,1 | 11.4 | 12.0 | 12.9 | 12.7 | 11.5 | 12.8 | 9.6 | 2.8 | 0.0 | 0:0 | 0.0 | 0.0 | 0.0 |
| Apr. | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 8.4 | 14.5 | 11.6 | 11.2 | 10.6 | 8.6 | 8.5 | +1.2 | 12,0 | 10.2 | 10.7 | 4.1 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| May | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 10.8 | 12.2 | 8.7 | 9,0 | 8.8 | 7.2 | 7.0 | 6.2 | 7.1 | 6.0 | 5.6 | 2.3 | 0,0 | 0.0 | 0,0 | 0.0 | 0.0 |
| Jun. | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 11.2 | 12.0 | 7.7 | 5.5 | 4.0 | 5.1 | 5.1 | 5.2 | 5.8 | 8.2 | 5.7 | 2.9 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| Jul. | 0.0 | 0,0 | 0.0 | 0.0 | 0.0 | 0.0 | 0,0 | 10.9 | 41.4 | 6.8 | 3.8 | 3.0 | 3.5 | 3.4 | 5.1 | 5.8 | 6.1 | 6,4 | 1.7 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| Aug. | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 8.4 | 11.9 | 6.8 | 5.2 | 4.3 | 4.0 | 5.3 | 5.2 | 5.8 | 5.6 | 4.5 | 1.8 | 0.0 | 0,0 | 0.0 | 0.0 | 0.0 |
| Sep. | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 6.4 | 15.5 | 8.5 | 5.9 | 3.6 | 4.0 | 4.6 | 4.6 | 5.0 | 5.6 | 3.3 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| Oet. | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 2.0 | 16.2 | 12.5 | 8.1 | 6.1 | 5.6 | 8,2 | 5.8 | 5,5 | 6.2 | 4.2 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| Nov. | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 8.8 | 12.4 | 10.5 | 8.3 | 9.1 | 8.7 | 7.0 | 7.3 | 8.9 | 3.7 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| Đee. | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 3.3 | 13.5 | 9.5 | 6.6 | 6.5 | 7.1 | 6.6 | 5.7 | 6.1 | 1.3 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

1 3 4337 4 12 000 3 533 . .

Non-Spinning Reserve (Non-Spin) Requirement Details

Introduction

Non-Spinning Reserve (Non-Spin) consists of Generation Resources capable of being ramped to a specified output level within 30 minutes or Controllable Load Resources that are capable of being interrupted within 30 minutes and that are capable of running (or being interrupted) at a specified output level for at least four consecutive hours. Non-Spin may also be provided by Load Resources that are not Controllable Load Resources and are capable of reducing consumption based on an ERCOT Extensible Markup Language (XML) instruction within 30 minutes and maintaining that deployment until recalled. Non-Spin may be deployed to replace loss of generating capacity, to compensate for Load forecast and/or forecast uncertainty on days in which large amounts of reserve are not available online, to address the risk of net load ramp, or when there is a limited amount of capacity available for Security-Constrained Economic Dispatch (SCED).

The periods when load is increasing and wind and/or solar are decreasing requires other generation resources to increase output or come online quickly to compensate for the sudden net load increases. As a result, net load ramp risk should be accounted for in the determination of Non-Spin requirements. While net load forecast analysis may cover reserves required for forecast uncertainty, it may not necessarily cover exposure to the loss of generation and net load ramp risk. Due to this risk, it may be necessary for ERCOT to have additional reserves available to protect against forecast uncertainty and Forced Outages of thermal Resources within an Operating Day.

Summary

I

Analysis for Non-Spin requirements are conducted using data from the same month of previous three years. For the purpose of determining the amount of Non-Spin to purchase for each hour of the day, hours will be placed into 4-hour blocks. The net load uncertainty for the analyzed days for all hours which are considered to be part of a 4-hour block will be calculated and a percentile will be assigned to this block of hours based on the risk of net load ramp. The same calculation will be done separately for each block. The Non-Spin requirement for the month for each block is calculated using the assigned percentile (based on risk of net load ramp) for the block minus the average Reg-Up requirement during the same block of hours ("Non-Spin block"). The Non-Spin requirement for each hour in the month is calculated by adding an adjustment that accounts for intra-day Forced Outage of thermal Resources to the previously calculated "Non-Spin block" quantity that the hour falls in.

ERCOT will post the monthly amounts for Non-Spin requirements for the upcoming year on the MIS. Following this posting, ERCOT will monitor the weather and net load forecast (i.e. load, wind and solar forecasts) near Real-Time and may procure up to an additional 1,000 MW of Non-Spin for Operating Hours that are (a) identified as having an increased potential of high forecast variability, (b) there is a risk that the actual net load during these Operating Hours could be higher than forecast (after making appropriate forecast model selection) and (c) the expected available capacity and expected reserves including the posted minimum Non-Spin requirements during these Operating Hours is not sufficient to cover the projected net load forecast uncertainty risk.

The minimum amount of Non-Spin procured from SCED dispatchable Resources in any hour shall not be less than ERCOT's Most Severe Single Contingency (MSSC) value.

Procedure

ERCOT will determine the Non-Spin requirement using the 75th to 95th percentile of hourly net load uncertainty from the same month of the previous three years. Net load is defined as the ERCOT load minus the estimated un-curtailed total output from Intermittent Renewable Resource (IRR), which includes both Wind-powered Generation Resources (WGRs) and Photo-Voltaic Generation Resources (PVGR) at a point in time. The forecast of net load is computed by subtracting the aggregate IRR High Sustained Limits (HSLs) in the Current Operating Plans (COPs) from the Mid-Term Load Forecast (MTLF). <u>The COPs and MTLF used for HE23, HE24, HE01 and HE02 are the updated values as of four hours prior to each Operating Hour. For remaining hours, Tthe COPs and MTLF used are the updated values as of six hours prior to each Operating Hour. The net load uncertainty is then defined as the difference between the average 5-minute net load within the hour and the forecasted net load.</u>

The risk of net load ramp is determined based on the change in net load over an hour divided by highest observed net load for the season. A fixed value of 68th percentile will be assigned to HE23, HE24, HE01 and HE02 to the net load forecast uncertainty calculated previously. Additionally, for these same hours a net load forecast uncertainty of four hours prior to the Operating Hour will be used for the calculations. Additionally, fin all seasons excluding Winter, in hours a fixed value of 68th percentile will also be assigned to HE03, HE04, HE05, HE06 a fixed value of 68th percentile will be assigned for the net load forecast uncertainty calculated previously. For the remaining hours, a fixed value of percentile ranging between 75th percentile and 95th percentile will be assigned to the net load forecast uncertainty calculated previously. For the remaining hours, a fixed value of percentile ranging between 75th percentile and 95th percentile will be assigned to the net load forecast uncertainty calculated previously. Periods where the risk of net load ramp is highest will use 95th percentile and 75th percentile for periods with lowest risks.

ERCOT has seen significant growth in installed wind and solar capacity from one year to the next; an increase in wind and solar capacity also tends to increase the MW quantity of error in their respective forecasts. Hence, ERCOT's reliance on historical wind and solar forecast errors alone creates a possibility of under-estimation of the Non-Spin requirement.

To address this, ERCOT will include the impact of increase in over-forecast error from the expected growth in wind and solar generation installed capacity into the future Non-Spin requirement. The net wind impact is calculated by a multiplication of the projected wind capacity growth between the same month of current year and the next year, and incremental MW adjustment to Non-Spin value per 1000 MW of incremental wind generation capacity. The incremental MW wind adjustment to the Non-Spin value per 1000 MW increase in wind installed capacity is calculated as the change in 50th percentile of the historical wind over-forecast error for 4-hour blocks of each month in the past 5 years, which is then normalized to per 1000 MW of installed wind capacity. The net solar impact is calculated by a multiplication of the projected solar capacity growth between the same month of current year and the next year, and incremental MW adjustment to Non-Spin value per 1000 MW of incremental solar generation capacity. The incremental MW solar adjustment to the Non-Spin value per 1000 MW increase in solar installed capacity is calculated as the change in 50th percentile of the historical solar over-forecast error for 4-hour blocks of each month in the past 3 years, which is then normalized to per 1000 MW of installed solar capacity. The tables below reflects the additional Non-Spin adjustments per 1000 MW of installed wind and solar capacity.

To account for increased capacity needs due to unplanned generation Outages that occur during an Operating Day, ERCOT will include an incremental adjustment in the Non-Spin requirements that accounts for intra-day Forced Outages of thermal Resources. This Forced Outage adjustment is calculated as the 75th percentile of the historical intra-day Forced Outages (accumulated since midnight) for six-hour blocks of each month in the past three years. The table below reflects additional Non-Spin adjustments to account for intra day Forced Outages of thermal Resources. ERCOT will purchase Non-Spin such that the combination of Non-Spin and Reg-Up Services cover the uncertainties of net load forecast errors depending on the net load ramp risk and intraday Forced Outages.

| Increment | tal MV | V Adju | istmen | t to N | on-Spi | nning | Reserv | ve Ser | vice, p | er 100 |) MW | of Inc | remen | tal Wi | nd Ge | nerati | on Ca | pacity | - | | | | | |
|-----------------|--------|--------|--------|--------|-------------------|-------|---------------|---------------|--------------------|-------------------|---------------|---------------|---------------|-------------------|------------------|-------------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|----|
| | | | | | | | | | | H | our En | ding | | | | | | | | | | | | |
| Month | + | 2 | 3 | 4 | 5 | six | 7 | 8 | 9 | 10 | # | 12 | 43 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 | 24 |
| Jan. | 27 | 27 | 27 | 27 | 27 | 27 | 29 | 29 | 29 | 29 | 22 | 22 | 22 | 22 | 23 | 23 | 23 | 23 | 28 | 28 | 28 | 28 | 27 | 27 |
| Feb. | 27 | 27 | 27 | 27 | 27 | 27 | 29 | 29 | 29 | 29 | 22 | 22 | 22 | 22 | 23 | 23 | 23 | 23 | 28 | 28 | 28 | 28 | 27 | 27 |
| Mar. | 29 | 29 | 31 | 31 | 31 | 31 | 30 | 30 | 30 | 30 | 25 | 25 | 25 | 25 | 26 | 26 | 26 | 26 | 29 | 29 | 29 | 29 | 29 | 29 |
| Apr. | 29 | 29 | 31 | 31 | 31 | 31 | 30 | 30 | 30 | 30 | 25 | 25 | 25 | 25 | 26 | 26 | 26 | 26 | 29 | 29 | 29 | 29 | 29 | 29 |
| May | 29 | 29 | 31 | 31 | 31 | 31 | 30 | 30 | 30 | 30 | 25 | 25 | 25 | 25 | 26 | 26 | 26 | 26 | 29 | 29 | 29 | 29 | 29 | 29 |
| Jun. | 27 | 27 | 26 | 26 | 26 | 26 | 26 | 26 | 26 | 26 | 19 | 19 | 19 | 19 | 21 | 21 | 21 | 21 | 28 | 28 | 28 | 28 | 27 | 27 |
| Jul. | 27 | 27 | 26 | 26 | 26 | 26 | 26 | 26 | 26 | 26 | 19 | 19 | 19 | 19 | 21 | 21 | 21 | 21 | 28 | 28 | 28 | 28 | 27 | 27 |
| Aug. | 27 | 27 | 26 | 26 | 26 | 26 | 26 | 26 | 26 | 26 | 19 | 19 | 19 | 19 | 21 | 21 | 21 | 21 | 28 | 28 | 28 | 28 | 27 | 27 |
| Sep. | 24 | 21 | 21 | 21 | 21 | 21 | 22 | 22 | 22 | 22 | 47 | 47 | 47 | 47 | 21 | 21 | 21 | 21 | 22 | 22 | 22 | 22 | 21 | 21 |
| Oct. | 21 | 21 | 21 | 21 | 21 | 21 | 22 | 22 | 22 | 22 | 17 | 17 | +7 | 17 | 21 | 21 | 21 | 21 | 22 | 22 | 22 | 22 | 21 | 21 |
| Nov. | 21 | 21 | 21 | 21 | 21 | 21 | 22 | 22 | 22 | 22 | 17 | 17 | 17 | 17 | 21 | 21 | 21 | 21 | 22 | 22 | 22 | 22 | 21 | 21 |
| Dec. | 27 | 27 | 27 | 27 | 27 | 27 | 29 | 29 | 29 | 29 | 22 | 22 | 22 | 22 | 23 | 23 | 23 | 23 | 28 | 28 | 28 | 28 | 27 | 27 |

| Incremen | tal MV | V Adj | ustme | n t to N | on Sp | inning | Reser | ve Ser | vice, j | per 10 0 | 0 MW | of Inc | remer | ntal So | lar Ge | nerati | ion Ca | pacity | ŧ | | | | | |
|-----------------|--------|------------------|-------|---------------------|-------|--------|-------|-------------------|--------------------|---------------------|-------------------|--------|---------------|---------|-------------------|--------|--------|---------------|---------------|---------------|----|----|----|----|
| | | | | | | | | | | H | our Er | nding | | | | | | | | | | | | |
| Month | + | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | ++ | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 | 24 |
| Jan. | 0 | θ | θ | θ | θ | θ | 3 | 3 | 3 | 3 | 37 | 37 | 37 | 37 | 31 | 31 | 31 | 31 | 0 | θ | θ | 0 | 0 | θ |
| Feb. | θ | θ | θ | θ | θ | θ | 3 | 3 | 3 | 3 | 37 | 37 | 37 | 37 | 31 | 31 | 31 | 31 | θ | θ | θ | θ | θ | θ |
| Mar. | θ | θ | θ | θ | θ | θ | 7 | 7 | 7 | 7 | 44 | -44 | 44 | 44 | 48 | 48 | 48 | 48 | 2 | 2 | 2 | 2 | θ | θ |
| Apr. | θ | θ | θ | θ | θ | θ | 7 | 7 | 7 | 7 | 44 | 44 | 44 | 44 | 48 | 48 | 48 | 48 | 2 | 2 | 2 | 2 | θ | θ |
| May | θ | θ | θ | θ | θ | θ | 7 | 7 | 7 | 7 | 44 | 44 | 44 | 44 | 48 | 48 | 48 | 48 | 2 | 2 | 2 | 2 | 0 | 0 |
| Jun. | θ | θ | θ | θ | θ | θ | ++ | ++ | ++ | ++ | 34 | 34 | 34 | 34 | 36 | 36 | 36 | 36 | 8 | 8 | 8 | 8 | 0 | θ |
| Jul. | 0 | θ | θ | θ | θ | θ | # | # | #1 | ++ | 34 | 34 | 34 | 34 | 36 | 36 | 36 | 36 | 8 | 8 | 8 | 8 | 0 | 0 |
| Aug. | θ | θ | θ | θ | θ | θ | ++ | ++ | ++ | ++ | 34 | 34 | 34 | 34 | 36 | 36 | 36 | 36 | 8 | 8 | 8 | 8 | θ | θ |
| Sep. | θ | θ | θ | θ | θ | θ | 4 | 4 | 4 | 4 | 26 | 26 | 26 | 26 | 23 | 23 | 23 | 23 | + | + | + | + | θ | θ |
| Oet. | θ | θ | θ | θ | θ | θ | 4 | 4 | 4 | 4 | 26 | 26 | 26 | 26 | 23 | 23 | 23 | 23 | 1 | + | + | + | θ | θ |
| Nov. | θ | θ | θ | θ | θ | θ | 4 | 4 | .4 | 4 | 26 | 26 | 26 | 26 | 23 | 23 | 23 | 23 | + | ÷. | Ŧ | + | θ | θ |
| Dec. | θ | θ | θ | θ | θ | θ | 3 | 3 | 3 | 3 | 37 | 37 | 37 | 37 | 34 | 31 | 31 | 31 | θ | θ | θ | θ | 0 | θ |

| | | | | | | | | | | 4 | Hour I | Ending | | | | | | | | | | | | |
|-----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|-----------------|-----------------|----------------|----------------|----------------|-----------------|-----------------|-----------------|----------------|-----------------|-----------------|-----------------|----------------|-----------------|----------------|----------------|----------------|
| Month | + | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | # | 12 | 13 | 14 | 15 | 16 | 47 | 18 | 19 | 20 | 21 | 22 | 23 | 24 |
| Jan. | 511 | 511 | 511 | 511 | 511 | 511 | 952 | 952 | 952 | 952 | 952 | 952 | 921 | 921 | 921 | 921 | 921 | 921 | 958 | 958 | 958 | 958 | 958 | 958 |
| Feb. | 432 | 432 | 432 | 432 | 432 | 432 | 805 | 805 | 805 | 805 | 805 | 805 | 1013 | 1013 | 1013 | 1013 | 1013 | 1013 | 70 4 | 704 | 704 | 704 | 704 | 704 |
| Mar. | 515 | 515 | 515 | 515 | 515 | 515 | 839 | 839 | 839 | 839 | 839 | 839 | 839 | 839 | 839 | 839 | 839 | 839 | 700 | 700 | 700 | 700 | 700 | 700 |
| Apr. | 621 | 621 | 621 | 621 | 621 | 621 | 869 | 869 | 869 | 869 | 869 | 869 | 815 | 815 | 815 | 815 | 815 | 815 | 759 | 759 | 759 | 759 | 759 | 759 |
| May | 786 | 786 | 786 | 786 | 786 | 786 | 881 | 881 | 881 | 881 | 881 | 881 | 1052 | 1052 | 1052 | 1052 | 1052 | 1052 | 984 | 984 | 98 4 | 984 | 984 | 984 |
| Jun. | 612 | 612 | 612 | 612 | 612 | 612 | 771 | 771 | 771 | 771 | 771 | 771 | 817 | 817 | 817 | 817 | 817 | 817 | 997 | 997 | 997 | 997 | 997 | 997 |
| Jul. | 635 | 635 | 635 | 635 | 635 | 635 | 763 | 763 | 763 | 763 | 763 | 763 | 525 | 525 | 525 | 525 | 525 | 525 | 723 | 723 | 723 | 723 | 723 | 723 |
| Aug. | 558 | 558 | 558 | 558 | 558 | 558 | 671 | 671 | 671 | 671 | 671 | 671 | 449 | 449 | 449 | 449 | 449 | 449 | 549 | 549 | 549 | 549 | 549 | 549 |
| Sep. | 435 | 435 | 435 | 435 | 435 | 435 | 777 | 777 | 777 | 777 | 777 | 777 | 533 | 533 | 533 | 533 | 533 | 533 | 510 | 510 | 510 | 510 | 510 | 510 |
| Oct. | 581 | 581 | 581 | 581 | 581 | 581 | 1016 | 1016 | 1016 | 1016 | 1016 | 1016 | 995 | 995 | 995 | 995 | 995 | 995 | 863 | 863 | 863 | 863 | 863 | 863 |
| Nev. | 639 | 639 | 639 | 639 | 639 | 639 | 835 | 835 | 835 | 835 | 835 | 835 | 97 4 | 97 4 | 97 4 | 974 | 97 4 | 97 4 | 1055 | 1055 | 1055 | 1055 | 1055 | 1055 |
| Dec. | 668 | 668 | 668 | 668 | 668 | 668 | 775 | 775 | 775 | 775 | 775 | 775 | 1018 | 1018 | 1018 | 1018 | 1018 | 1018 | 617 | 617 | 617 | 617 | 617 | 617 |

Responsive Reserve (RRS) Requirement Details

Nodal Operating Guide Section 2.3.1.1, Obligation, sets the minimum RRS requirement for all hours under normal conditions. ERCOT will procure amounts of RRS that vary by hour of the day and by month. These RRS amounts will be published by month in six separate blocks covering four-hour intervals. These amounts will be based on expected diurnal load, solar, and wind patterns for the month, will cover 70% of historic system inertia conditions for each block of hours for the month, and will use the equivalency ratio for RRS between Load Resources and Generation Resources to establish the conditions for each block of hours. The equivalency ratio will be used to establish the total reserves assuming the Day-Ahead Market (DAM) will use a one to one equivalency ratio. The minimum level of RRS procured from Resources providing RRS using Primary Frequency Response shall be determined for each month by ERCOT through the use of studies and shall not be less than 1,365185 MWs. The remaining capacity required for RRS will be procured from all Resources qualified to provide RRS including Load Resources. The maximum amount of RRS that can be provided by Resources providing Fast Frequency Response (FFR) is limited to 450 MW. DAM will limit the combined RRS procured from Load Resources controlled by high set under frequency relay and Resources providing FFR to 60% of the total ERCOT may increase the minimum capacity required from Resources RRS requirement. providing RRS using Primary Frequency Response if it believes that the current posted quantity will have a negative impact on reliability or if it would require additional Regulation Service to be deployed. ERCOT will procure additional 200 MW of RRS for each percent of Reserve Discount Factor (RDF) when ERCOT estimates RDF to be less than 1. This adjustment will only apply for those 4-hour blocks where the 85th percentile of weighted average temperate is greater than 95°F. RDFs are reviewed and adjusted based on the generators performance during an unannounced test. RRS amount will be published as a monthly requirement along with the equivalency ratio for each 4-hour block. Additionally, ERCOT will make incremental adjustments to account for Resources operating in synchronous condenser fast response mode providing RRS. This adjustment will only apply to those 4-hour blocks when system inertia is typically expected to be less than 250 GW*s. ERCOT will post these monthly amounts for the upcoming year on the MIS. These annually published amounts are the minimum quantity that will be procured in the DAM for each hour of the year.

Self-arranged RRS used to fulfill a Qualified Scheduling Entity's (QSE's) RRS requirement will be limited to 60% from Resources providing FFR and Load Resources excluding Controllable Load Resources.

If the percentage level for Resources providing FFR and Load Resources, excluding Controllable Load Resources, specified in the Protocols is changed, that change will be reflected in these requirements.

I

ERCOT Contingency Reserve Service (ECRS) Details

Introduction

ECRS is a service that is provided using capacity that is capable of being ramped to a specified output level within 10 minutes. ECRS may be provided by unloaded, On-Line Generation Resource capacity; Quick Start Generation Resources (QSGRs); Load Resources that may or may not be controlled by high-set, underfrequency relays; Controllable Load Resources; and Generation Resources operating in synchronous condenser fast-response mode as defined in the Operating Guides. ECRS may be deployed to restore frequency within 10 minutes of a significant frequency deviation to recover deployed Regulation Service, to compensate for intra-hour net load forecast uncertainty and variability on days in which large amounts of online thermal ramping capability is not available, or when there is a limited amount of capacity available for Security-Constrained Economic Dispatch (SCED).

Procedure

ERCOT will procure amounts of ECRS that vary by hour of the day and by month. ERCOT will determine the ECRS requirement as the <u>sum-maximum</u> of capacity needed to recover frequency following a large unit trip and capacity needed to cover for intra-hour net load forecast errors.

The frequency recovery related capacity for ECRS is computed for each hour in every month as capacity needed following a supply-side trip to recover frequency; will be based on expected diurnal load, solar, and wind patterns; -will cover <u>7060</u>% of historic system inertia conditions for each hour for the month and will include an adjustment to account for Regulation Up requirement in the hour.

Intra-hour net load forecast is utilized in establishing Base Points for SCED dispatchable Resources. ERCOT has observed larger intra-hour net load forecast errors during times when there are sudden net load ramps. Through including intra-hour net load forecast errors in calculating ECRS quantities, uncertainty in forecasting intra-hour net load (and hence intra-hour net load ramps) will be accounted for. Specifically, the intra-hour net load forecast error related capacity for ECRS is computed using the 85th to 95th percentile of intra-hour net load uncertainty from the same hour and same month in the previous two years. Net load is defined as the ERCOT load minus the estimated un-curtailed total output from Intermittent Renewable Resource (IRR), which includes both Wind-powered Generation Resources (WGRs) and Photo-Voltaic Generation Resources (PVGR). The forecast of net load is computed by subtracting the Intra-Hour Wind Power Forecast (IHWPF) and Intra-Hour Photo Voltaic Power Forecast (IHPPF) from the Intra-Hour Load Forecast (IHLF). The IHWPF, IHPPF and IHLF used are the updated values as of thirty minutes prior to each Security Constrained Economic Dispatch (SCED) interval. The net load uncertainty is then defined as the difference between the average net load within the SCED interval and the forecasted net load.

The risk of net load ramp is determined based on the change in net load over an hour divided by highest observed net load for the season. The fixed value of percentile ranging between 85th percentile and 95th percentile will be assigned to the net load forecast uncertainty calculated previously. Periods where the risk of net load ramp is highest will use 95th percentile and 85th percentile for periods with lowest risks. A value of at least 90th percentile will be assigned to the net load forecast uncertainty calculated to the net load forecast uncertainty calculated during sunset hours.

ERCOT has seen significant growth in installed solar capacity from one year to the next; an increase in solar capacity also tends to increase the MW quantity of error in their respective forecasts. Hence, ERCOT's reliance on historical solar forecast errors alone creates a possibility of under-estimation of the ECRS requirement. To address this, ERCOT will include the estimated impact of increase in over-forecast error from the expected growth in solar generation installed capacity into the future ECRS requirement. The net solar impact is calculated by a multiplication of the projected solar capacity growth between the same month of current year and the next year, and incremental MW adjustment to ECRS value per 1000 MW of incremental solar generation capacity. The incremental MW solar adjustment to the ECRS value per 1000 MW increase in solar installed capacity is calculated as the change in 50th percentile of the historical solar overforecast error for 4-hour blocks of each month in the past 2 years, which is then normalized to per 1000 MW of installed solar capacity. The tables below reflects the additional ECRS adjustments per 1000 MW of installed solar capacity.

| Incremental MW | Adj | ustr | nen | t to | ER | CO | F-C | onti | ngei | ncy Re | serve S | ervice | per 10 | 000 MV | V of In | eremer | ntal Sol | ar Gen | eratio | 1 Capa | eity | | | |
|-----------------|-----|------|-----|------|----|----|-----|------|------|---------------|---------------|--------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|--------|------|----|----|----|
| | | | | | | | | | | | | H | our Er | iding | | | | | | | | | | |
| Month | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 44 | 12 | 13 | 14 | 45 | 16 | 17 | 18 | 19 | 20 | 24 | 22 | 23 | 24 |
| Jan. | 0 | θ | 0 | θ | 0 | θ | θ | θ | θ | θ | 21 | 21 | 21 | 21 | 20 | 20 | 20 | 20 | θ | θ | θ | θ | 0 | θ |
| Feb. | θ | 0 | θ | θ | θ | θ | θ | θ | θ | θ | 33 | 33 | 33 | 33 | 20 | 20 | 20 | 20 | θ | θ | θ | θ | θ | θ |
| Mar. | 0 | θ | θ | θ | 0 | θ | 0 | 0 | θ | θ | 33 | 33 | 33 | 33 | 73 | 73 | 73 | 73 | θ | θ | θ | θ | θ | θ |
| Apr. | θ | θ | θ | θ | θ | θ | θ | 0 | θ | θ | 30 | 30 | 30 | 30 | 55 | 55 | 55 | 55 | θ | θ | θ | θ | θ | θ |
| May | 0 | 0 | θ | 0 | θ | 0 | θ | 0 | θ | θ | 59 | 59 | 59 | 59 | 96 | 96 | 96 | 96 | 26 | 26 | 26 | 26 | 0 | 0 |
| Jun. | 0 | θ | θ | θ | θ | θ | θ | θ | θ | θ | 17 | +7 | 17 | +7 | 41 | 41 | 41 | 41 | 37 | 37 | 37 | 37 | θ | θ |
| Jul. | θ | θ | θ | θ | θ | θ | θ | θ | θ | θ | 23 | 23 | 23 | 23 | 23 | 23 | 23 | 23 | 8 | 8 | 8 | 8 | θ | θ |
| Aug. | 0 | θ | θ | θ | θ | θ | θ | θ | θ | 0 | 45 | 45 | 45 | 45 | 53 | 53 | 53 | 53 | 4 | 4 | 4 | 4 | θ | θ |
| Sep. | 0 | θ | θ | θ | θ | θ | 0 | 0 | θ | θ | 64 | 64 | 64 | 64 | 56 | 56 | 56 | 56 | θ | 0 | θ | 0 | θ | θ |
| Oct. | 0 | θ | θ | θ | θ | θ | θ | θ | θ | θ | 26 | 26 | 26 | 26 | 37 | 37 | 37 | 37 | θ | θ | θ | 0 | θ | θ |
| Nov. | 0 | θ | 0 | θ | 0 | 0 | 0 | 0 | θ. | θ | + | Ŧ | + | 1 | 4 | 4 | 4 | 4 | θ | θ | θ | θ | θ | θ |
| Dec. | θ | θ | θ | θ | θ | θ | 0 | 0 | θ | θ | 3 | 3 | 3 | 3 | θ | θ | θ | θ | <u>0</u> | θ | θ | 0 | 0 | 0 |

ATTACHMENT B

Electric Reliability Council of Texas, Inc. Board of Directors Resolution Recommending Authorization and Approval to Implement 2025 ERCOT Methodologies for Determining Minimum

ercot \$

ELECTRIC RELIABILITY COUNCIL OF TEXAS, INC. BOARD OF DIRECTORS RESOLUTION

WHEREAS, Protocol Section 3.16 requires that the Board of Directors (Board) of Electric Reliability Council of Texas, Inc. (ERCOT) review and recommend approval of the ERCOT methodology for determining the minimum Ancillary Service requirements;

WHEREAS, Protocol Section 3.16 requires, prior to implementation, approval by the Public Utility Commission of Texas (PUCT) of any Board recommendation for determining the minimum Ancillary Service requirements;

WHEREAS, ERCOT staff has recommended that the Board recommend the PUCT authorize and approve ERCOT to implement the ERCOT Methodologies for Determining Minimum Ancillary Service Requirements, as set forth in <u>Attachment A</u>, effective on January 1, 2025;

WHEREAS, the Technical Advisory Committee (TAC) voted to endorse the 2025 Ancillary Service Methodology as presented by ERCOT;

WHEREAS, the Independent Market Monitor has raised no objection to the changes to the 2025 Ancillary Service Methodology proposed by ERCOT staff;

WHEREAS, the Reliability and Markets (R&M) Committee recommended that the Board recommend the PUCT authorize and approve ERCOT to implement the ERCOT Methodologies for Determining Minimum Ancillary Service Requirements, as recommended by ERCOT staff and as endorsed by TAC, to be effective on January 1, 2025.; and

WHEREAS, after due consideration of the alternatives, the Board deems it desirable and in the best interest of ERCOT to recommend the PUCT authorize and approve ERCOT to implement the ERCOT Methodologies for Determining Minimum Ancillary Service Requirements, as recommended by ERCOT staff, the R&M Committee, and as endorsed by TAC, to be effective on January 1, 2025;

THEREFORE, BE IT RESOLVED, that ERCOT hereby recommends the PUCT authorize and approve ERCOT to implement the ERCOT Methodologies for Determining Minimum Ancillary Service Requirements, as set forth in <u>Attachment A</u>, as recommended by ERCOT staff, the R&M Committee, and as endorsed by TAC, to be effective on January 1, 2025.

Item 9.3.1 ERCOT Public 1



CORPORATE SECRETARY'S CERTIFICATE

I, Chad V. Seely, Corporate Secretary of ERCOT, do hereby certify that, at its October 10, 2024, meeting, the Board passed a motion approving the above Resolution by unanimous vote with no abstentions.

IN WITNESS WHEREOF, I have hereunto set my hand this <u>22-day</u> of October 2024.

Chad V. Seely Corporate Secretary

ERCOT Methodologies for Determining Minimum Ancillary Service Requirements

ERCOT Board <u>Recommended approvaled</u> on <u>12XX/19XX/2023XXXX</u>

PUC Approved on XX/XX/XXXX

Effective Date of 1/1/20254

TABLE OF CONTENTS

| INTRODUCTION | 2 |
|---|---|
| REGULATION SERVICE REQUIREMENT DETAILS | 3 |
| NON-SPINNING RESERVE (NON-SPIN) REQUIREMENT DETAILS | 9 |
| RESPONSIVE RESERVE (RRS) REQUIREMENT DETAILS 1 | 5 |
| ERCOT CONTINGENCY RESERVE SERVICE (ECRS) DETAILS 1 | 6 |

Introduction

Paragraph (2) of Protocol Section 3.16, Standards for Determining Ancillary Service Quantities, requires that methodologies for determining the amounts of Ancillary Services to be required by ERCOT must be developed at least annually. Paragraph (3) of Protocol Section 3.16 requires approval-review of this methodology by the ERCOT Board of Directors and approval by the Public Utility Commission of Texas (PUCT)Board of Directors.

This document discusses the various Ancillary Services for which requirements are to be developed. Further, detailed methodologies for determining those requirements are included as part of this document.

Specifically, methodologies are required for the determination of the quantities of Regulation Service, ERCOT Contingency Reserve Service (ECRS), Non-Spinning Reserve (Non-Spin) and Responsive Reserve (RRS) that are required to maintain system reliability. Those procedures are discussed below.

These procedures are intended for determining each of the Ancillary Service requirements for all months of the upcoming year. This procedure will be performed annually. The Ancillary Service requirements are determined annually and will be posted to the Market Information System (MIS) by December 20th for the upcoming year. If necessary, any additional incremental adjustment to the posted Ancillary Service requirements for a particular month will be made using this procedure and will be posted to the MIS prior to the 20th of each month for the upcoming month. If the Ancillary Service requirements identified through this process for a particular operating day are found to be insufficient based on the expected operating conditions for that day, ERCOT may make an updated Ancillary Service requirements posting for that day if the need for incremental adjustments is identified day-ahead and may use the Supplemental Ancillary Service Market (SASM) process for similar adjustments made closer to Real-Time. For any additional months for which ERCOT is required to provide an Ancillary Service requirement forecast, the forecasted requirement will be set to the historical requirement for the same month of the previous year.

Regulation Service Requirement Details

Introduction

Regulation Service consists of resources that can be deployed by ERCOT in response to changes in ERCOT System frequency to maintain the target ERCOT System frequency within predetermined limits according to the Operating Guides. ERCOT is required to evaluate normal requirements for Reg-Up Service and Reg-Down Service on an annual basis. It is ERCOT's practice to use historical rates of Regulation Service usage to perform evaluation and determine the required quantities for this service. Regulation Service is deployed in order to correct actual frequency to scheduled frequency and to ensure North American Electric Reliability Corporation (NERC) requirements are met.

Summary

The Regulation Service requirements are calculated with the expectation that sufficient Regulation Service will be available to cover the 95th percentile of deployed regulation or net load variability. An adjustment may also be made based on historic CPS1 performance.

Procedure

To evaluate Regulation Service requirements, ERCOT will collect historical Resource Registration information, CPS1 data, Regulation Service deployment data, aggregate output data, and ERCOT system load data. For determining the base Reg-Up requirements for a particular hour, ERCOT will <u>calculate take the largest of the 95th percentile of Reg Up deployments for the same month of the previous two years, and the 95th percentile of the positive net load (load – wind – solar) forecast error ehanges for the same month of the previous two years. For determining the base Reg-Down requirements, ERCOT will <u>calculate take the largest of the 95th percentile of Reg 5th percentile of Reg-Down deployments for the same month of the previous two years. For determining the negative net load (load – wind – solar) forecast error ehanges for the same month of the previous two years and the 95th percentile of the base Reg-Down deployments for the same month of the previous two years and the 95th percentile of the negative net load (load – wind – solar) forecast error ehanges for the same month of the previous two years. To better reflect balancing needs within the hours, the net load variability may be updated to account for accumulated Area Control Error (ACE).</u></u>

In order to consider the increased amount of wind and solar penetration, ERCOT will calculate the increase in installed wind and solar generation capacity, respectively. Then, depending on the month of the year and the hour of the day, ERCOT will add incremental MWs that are derived using the wind and solar forecast error adjustment tables and associated increase in wind and solar generation capacity, to the maximum-values determined above. The wind and solar forecast error adjustment tables for incremental MWs for Reg-Up and Reg-Down come from the study ERCOT performs annually, using similar techniques as the 2008 GE wind study, but using actual wind and solar solar data respectively. The increase in wind (or solar) generation capacity will be calculated by taking the total nameplate capacity of wind (or solar) resources in the ERCOT network model at the time of the procurement study and subtracting out the total nameplate capacity of wind (or solar) resources in the ERCOT methods wind (or solar) resources in the ERCOT network model at the time of the procurement study and subtracting out the total nameplate capacity of wind (or solar) resources in the previous year.

ERCOT will post these monthly amounts for Regulation Service requirements for the upcoming year on the MIS.

If any incremental changes to the annually posted amounts are needed then the revised amounts for the following month will be posted to the MIS prior to the 20th of the current month. ERCOT

may include adjustments for hours in a month considering monthly average for CPS1 and 12month rolling average CPS1 scores. If it is determined that during the course of the year that the ERCOT monthly average for CPS1 score was less than 140% for a specific month, ERCOT will apply an extra 10% of both Reg-Up and Reg-Down for hours in which the CPS1 score was less than 140%. Additionally, if the ERCOT 12-month rolling average CPS1 score is less than 140%, for the next month ERCOT will procure an extra 10% of both Reg-Up and Reg-Down for hours in which the hourly CPS1 score was less than 140%. This value will increase to 20% if the CPS1 score falls below 100%.

.

| Ineren Growt | ental-l t | MW-A | djustn | nent te | Prior | -Year | Up-Re | gulati | on Va | lue, pe | r 1000 | MW- | of-Ine | remen | tal Wi | nd Gei | neratio | on-Caj | neity, | to Ae | count-i | or Wi | nd Ca | pacity |
|------------------|-----------------|----------------|----------------|----------------|----------------|----------------|-------|----------------|-------|--------------------|----------------|----------------|---------------|----------------|----------------|------------------|----------------|-----------------|------------------|----------------|------------------|-------------------|-----------------|-----------------|
| | | | | | | | | | | | Hou | r-Endi | ing | | | | | | | | | | | |
| Month | 4 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 44 | 12 | 13 | 44 | 15 | 16 | 1 7 | 18 | 19 | 20 | 21 | 22 | 23 | 24 |
| Jan . | 4.3 | 0.7 | 1.3 | +.+ | 2.1 | 4.3 | 1.2 | 1.3 | 4.1 | 3.8 | 1.0 | 0.9 | 1.5 | 1.9 | +.+ | 1.4 | 2.4 | 1.8 | -0.5 | -0.7 | -0.3 | 0.0 | 0.0 | 0.0 |
| Feb. | 0.7 | 0.8 | 1.4 | 0.7 | 1.0 | 1.4 | +.1 | 1.9 | 3.5 | 3.3 | 2.2 | 1.7 | 2.0 | +.+ | 0.2 | 1.1 | 0.5 | 2.4 | 0.6 | -4.4 | - 0.5 | -0.7 | -0.2 | 0.2 |
| Mar. | 1.3 | 0.6 | 1.0 | 0.6 | 0.6 | 1.3 | 1.4 | 1.4 | 5.1 | 4.0 | 1.4 | 2.4 | 3,0 | 1.1 | 1.3 | 1.3 | 1.7 | 3.1 | 2.7 | 2.9 | 0.9 | 0.1 | 0.3 | 0.5 |
| Apr. | -0.3 | 0.0 | 0.9 | +.2 | +.+ | 0.9 | +.3 | 2.1 | 3.3 | 0.5 | 2.2 | 3.0 | 4.3 | 2.9 | 2.5 | 1.0 | 0.9 | 1.2 | 1.3 | 2.6 | 0.7 | - 0.1 | -0.1 | -0.3 |
| May | 0.2 | 0.8 | 0.6 | 1.7 | 1.6 | 3.2 | 1.4 | 3.7 | 3.9 | 1.8 | 3.3 | 3.7 | 2.6 | 2.6 | 0.3 | 1.0 | 0,1 | 0.3 | 0.4 | 1.0 | 1.1 | -0.2 | 0.0 | 0.0 |
| dun. | 0.2 | 0.3 | 0.6 | 1.6 | 2.0 | 2.1 | 2.7 | 6.5 | 2.3 | 1.4 | 2.9 | 4.2 | 3.2 | 1.4 | 0.0 | 0.1 | -0.1 | -0.2 | - 0.1 | 0.0 | 0.3 | -0.4 | 0.0 | 0.0 |
| đul. | 0.1 | 0.2 | 1.0 | 1.7 | 1.6 | 2.7 | 2.5 | 6.3 | 2.0 | 2,3 | 5.1 | 4.3 | 2.4 | 0.3 | -0.2 | - 0.6 | -0.2 | -0.2 | - 0.6 | -0.1 | 0.9 | -0,1 | 0.0 | 0.0 |
| Aug. | 0.7 | 0.8 | 1.0 | +.+ | 1.9 | 1.4 | 0.7 | 5.0 | 4.2 | 0.5 | 3.0 | 3.2 | 1.3 | 0.3 | -0.8 | -0.7 | 0.0 | -0.2 | -0.3 | 0.4 | 0.9 | -0.1 | 0.0 | 0.0 |
| Sep. | -0.1 | 0.5 | 0.9 | 1.5 | 1.5 | 2.1 | 1.3 | 2.3 | 6.4 | 2.3 | 1.5 | 1.8 | 1.1 | 0.4 | 0.8 | -0.9 | -0.2 | -0.5 | 0.3 | 0.1 | -0.8 | - 0. 4 | 0.0 | 0.0 |
| øet. | -0.3 | 0.4 | 1.6 | 1.3 | 1.5 | +.1 | 1.3 | 1.6 | 4.9 | 5.0 | 0.2 | 0.9 | 0.7 | 0.8 | 0.1 | -0.3 | 0.4 | 0.9 | 0.7 | -1.0 | - 0.6 | -0.2 | -0.1 | 0.4 |
| Nov. | 0.5 | 1.2 | 1.5 | +.0 | 0.9 | 0.5 | 2.8 | 3,1 | 3.2 | 4.3 | 0.4 | 0.1 | 0.4 | 0.5 | 0.6 | 1.2 | +.6 | 0.7 | 0.4 | -0.2 | 0.4 | 0.1 | 0.2 | 0.3 |
| Dee. | 0.5 | 0.0 | 1.5 | 1.5 | +.1 | 1.0 | 0.8 | +.2 | 2.7 | 2.2 | 0.5 | 0.7 | 0.3 | 0.8 | 0.9 | 0.8 | 2.3 | 1.1 | -0.8 | -0.2 | 0.0 | 0. 4 | 0.1 | 0,4 |

1

| Incremental MW Adjustment to Prior-Year Dow | n-Regulation Value, per 1090 | MW of Incremental Win | d-Ceneration-C | apacity, to Account for | Wind |
|---|------------------------------|-----------------------|----------------|-------------------------|------|
| Capacity Growth | | | | | |

| | | | | | | | | | | H | our Er | ding | | | | | | | | | | | | |
|-----------------|----------------|----------------|-----------------|------------------|------------------|------------------|------------------|------------------|------------------|-----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|-----------------|-----------------|-----------------|
| Month | 4 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | ++ | 12 | 43 | 14 | 15 | 16 | 47 | 18 | 19 | 20 | 21 | 22 | 23 | 24 |
| Jan. | 0.8 | 1.6 | 1.0 | 0.8 | 0.3 | -0.5 | -0.3 | -0.6 | -2.7 | -3.3 | 1.5 | 2.6 | 1.2 | 1.2 | +.+ | 1.2 | 0.9 | 0.7 | 5.9 | 3.8 | 3.4 | 2.3 | 1.6 | 1.5 |
| Feb. | 0.7 | -0.5 | -0.3 | -0.3 | 0.1 | -0.2 | -0.2 | -0.4 | -4.8 | -2.8 | 0.3 | 1.4 | 1.5 | 0.6 | 0.3 | 1.1 | 1.9 | 3.1 | 2.3 | 5.3 | 3.0 | +.3 | 2.8 | 0.8 |
| Mor. | 0.1 | 0.3 | 1.1 | +.+ | 0.5 | 0.1 | 0.0 | -0.9 | -3.9 | 0.3 | 3.0 | 1.0 | 2.2 | 0.5 | 1.5 | 1.7 | 1.9 | 1.3 | 2.3 | 4.4 | 5.9 | 4.3 | 3.3 | 3. 4 |
| Apr. | 1.2 | 0.4 | -0.4 | 0.3 | -0.2 | -0.7 | -0.4 | -0.3 | 0.0 | 4.3 | 0.8 | 0.2 | -0.3 | 0.2 | +.+ | 1.9 | 2.1 | 2.0 | 1.8 | 1.4 | 3.2 | 4.3 | 3.7 | 1.9 |
| May | 1.4 | 0.4 | -0.4 | -1.1 | -0.2 | - 0.5 | - 0.9 | -0.4 | 0.9 | 0.9 | -0.4 | -0.3 | 0.3 | 0.8 | 1.4 | 1.8 | 2.9 | 3.2 | 3.8 | 3.6 | 3.9 | 4.1 | 3.4 | 2.5 |
| Jun. | +.+ | 0.1 | -1.3 | -2.1 | -1.3 | -1.4 | -1.6 | -1.0 | 0.7 | 0.1 | -0.1 | 0.0 | 0.2 | 0.7 | 1.2 | 1.8 | 2.6 | 2.7 | 2.7 | 2.3 | 2.5 | 5.4 | 4 .0 | 2.1 |
| Jul. | 1.0 | -0.8 | -1:3 | -1.5 | -1.6 | -2.5 | -1.7 | -1.4 | 0.6 | 0.0 | 0.0 | 0.0 | -0.1 | 0.6 | 2.1 | 2.9 | 3.5 | 4.4 | 3.6 | 3.2 | 1.9 | 6.8 | 4.7 | 2.0 |
| Aug. | 0.4 | -0.5 | -0.9 | -2.2 | -1.2 | -1.5 | -1.0 | - 0.6 | 0.1 | 0.7 | -0.2 | -0.3 | 0.4 | 0.8 | 2.0 | 2.7 | 2.8 | 2.6 | 3.4 | 2.2 | 2.8 | 4 .8 | 2.7 | 1.3 |
| Sep. | 0.1 | -1.4 | -0.6 | -1.2 | -1.6 | -1.0 | -0.6 | - 0.8 | - 0.8 | 0.0 | 0.1 | -0.1 | 0.1 | 0.1 | 1.0 | 1.1 | 1.9 | 2.2 | 2.3 | 2.8 | 6.4 | 5.1 | 3. 4 | 1.5 |
| Oet. | 0.1 | -0.6 | -0.9 | - 0.5 | - 0.1 | -0.5 | -0.5 | 0.0 | +.2 | -0.9 | 1.5 | 0.6 | 1.4 | 0.7 | 1.3 | 1.8 | 1.3 | 1.3 | 0.4 | 4.6 | 4.4 | 3.3 | 1.8 | 0.7 |
| Nov. | -0.1 | 0.0 | -0.4 | -0.7 | -0.2 | -0.4 | -0.4 | -1.0 | -1.0 | 0.3 | 2.3 | 1.4 | 1.4 | +.3 | 0.9 | 1.3 | 0.9 | 1.0 | 3.5 | 3.9 | 1.9 | 1.9 | 1.2 | 0.1 |
| Dee. | -0.2 | -0.1 | -0.9 | 0.3 | 0. 4 | 0.2 | 0.7 | 0.4 | -1.6 | -0.2 | 2.0 | 2.2 | 0.4 | -0.5 | 0.3 | 0.3 | 0.1 | 0.7 | 4.1 | 2.1 | 1.7 | 1.9 | 1.0 | 0.3 |

| Growt | enta: F | - 194 VI | - A 0j | ustm | ent to | 9 Fri | or-rea | ir-Up- | Regun | ation | value, | per 10 | 00 1/11 | - 01 ING | remen | iai soia | r Gener | ation C | араену, | 10-Acco | unt lo | 1-30ia | r-caj | заену |
|--------------------|----------------|----------------|-------------------|----------------|----------------|----------------|----------------|----------------|----------------|---------------|----------------|-----------------|----------------|---------------------|----------------|----------------|-----------------|-----------------|-----------------|----------------|----------------|----------------|----------------|----------------|
| | | | | | | | | | | | | H | our Ea | ling | | | | | | | | | | |
| Month | + | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | # | 12 | 13 | 14 | 15 | 16 | 1 7 | 18 | 19 | 20 | 21 | 22 | 23 | 24 |
| J <mark>an.</mark> | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 2.6 | 4,2 | 5.3 | 5.9 | 7.2 | 7.6 | 9,9 | 18.0 | 15.1 | 1.4 | 0.1 | 0.0 | 0.0 | 0.0 | 0.0 |
| Reb. | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1.0 | 8.5 | 7.0 | 9,2 | 7.6 | 7.9 | 12.0 | 13.3 | 13.0 | 18.3 | 8.8 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| Mar. | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 8.6 | 8.6 | 10.6 | 12.3 | 13.4 | 13.2 | 15.9 | 15.5 | 17.2 | 16.6 | 11.7 | 0.1 | 0.0 | 0.0 | 0.0 |
| Apr. | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1.1 | 7.1 | 9.4 | 10.1 | 9.8 | 10.2 | 8.6 | 11.4 | 13.8 | 15.8 | 15.6 | 14.5 | 1.8 | 0.0 | 0.0 | 0.0 |
| May | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1.1 | 3.8 | 6.2 | 7,5 | 6.6 | 6.9 | 8.1 | 8.6 | +0.8 | 12.3 | 10.5 | 11.7 | 4.6 | 0.0 | 0.0 | 0.0 |
| Jun, | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 3.7 | 3.0 | 3.0 | 4.4 | 6.6 | 5.4 | 6.3 | 11.0 | 8.0 | 10.2 | 12.5 | 6.2 | 0.0 | 0.0 | 0.0 |
| đul. | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 2.8 | 1.4 | 3,3 | 4.5 | 4.6 | 7.2 | 6.6 | 7.0 | 9.5 | 9. 4 | 12.1 | 6.2 | 0.0 | 0.0 | 0.0 |
| Aug. | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 4.5 | 4.1 | 4.7 | 5.7 | 6.3 | 6.6 | 8.3 | 8.9 | 8.5 | 10.4 | +1.1 | 3.3 | 0.0 | 0.0 | 0.0 |
| Sep | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.8 | 3.9 | 4.1 | 5.2 | 6.0 | 7.4 | 6.9 | 7.2 | 9.5 | 13.9 | 8.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| Get. | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1.1 | 4.3 | 5,9 | 6.2 | 5.9 | 8.4 | 9,9 | 11.5 | 14.3 | 14.0 | 0.8 | 0,1 | 0.0 | 0.0 | 0.0 |
| Nov. | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1.4 | 4.7 | 5.6 | 8.5 | 8.9 | 8.0 | 9.4 | 11.0 | 14.3 | 8.8 | 5.6 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| Dee. | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 4.9 | 6.1 | 5.3 | 6.9 | 6.9 | 8:2 | +0.1 | 13.6 | 7.6 | 0.1 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

× 1 1000 3 1000 **A 1** ~ -

Incremental MW Adjustment to Prior-Year Down Regulation Value, per 1000 MW of Incremental Solar Generation Capacity, to Account for Solar Capacity Growth

| | | | | | | | | | | H | our En | iding | | | | | | | | | | | | |
|-----------------|-----|----------------|----------------|----------------|----------------|----------------|----------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|----------------|-----------------|-----------------|----------------|----------------|----------------|----------------|----------------|----------------|
| Month | + | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | # | 12 | 13 | 1 4 | 15 | 16 | 1 7 | 18 | 1 9 | 20 | 24 | 22 | 23 | 24 |
| Jan. | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 2.8 | 17.2 | 11.1 | 6. 4 | 5.3 | 4.8 | 7.0 | 6.3 | 5.1 | 2.7 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| Feb. | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | ++.+ | 19.7 | 16.1 | 8.6 | 8.6 | 8. 4 | 7.9 | 9.5 | 9,2 | 8.5 | 1.9 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| Mar. | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | +3.3 | 18.9 | 13.1 | 10.1 | 11.4 | 12.0 | 12.9 | 12.7 | 11.5 | 12.8 | 9.6 | 2.8 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| Арт | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 8. 4 | 14.5 | 11.6 | 11.2 | 10.6 | 8.6 | 8.5 | 11.2 | 12.0 | 10.2 | 10.7 | 4.1 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| May | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 10.8 | 12,2 | 8.7 | 9,0 | 8.8 | 7.2 | 7.0 | 6.2 | 7.1 | 6.0 | 5.6 | 2.3 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| Jun. | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | +1.2 | 12.0 | 7.7 | 5.5 | 4.0 | 5.1 | 5.1 | 5.2 | 5.8 | 8.2 | 5.7 | 2.9 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| Jul. | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 10.9 | 11.4 | 6.8 | 3.8 | 3.0 | 3.5 | 3.4 | 5.1 | 5.8 | 6.1 | 6.4 | 1.7 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| Aug. | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 8.4 | 11.9 | 6.8 | 5.2 | 4.3 | 4 .0 | 5.3 | 5.2 | 5.8 | 5.6 | 4.5 | 1.8 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| Sep. | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 6.4 | 15.5 | 8.5 | 5.9 | 3.6 | 4.0 | 4 .6 | 4 .6 | 5.0 | 5.6 | 3.3 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| Oet. | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 2.0 | 16.2 | 12.5 | 8.1 | 6.1 | 5.6 | 8.2 | 5.8 | 5.5 | 6.2 | 4.2 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| Nov. | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 8.8 | 12.4 | 10.5 | 8.3 | 9.1 | 8.7 | 7.0 | 7.3 | 8.9 | 3.7 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| Dee. | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 3.3 | 13.5 | 9.5 | 6.6 | 6.5 | 7.1 | 6.6 | 5.7 | 6.1 | 1.3 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

Non-Spinning Reserve (Non-Spin) Requirement Details

Introduction

Non-Spinning Reserve (Non-Spin) consists of Generation Resources capable of being ramped to a specified output level within 30 minutes or Controllable Load Resources that are capable of being interrupted within 30 minutes and that are capable of running (or being interrupted) at a specified output level for at least four consecutive hours. Non-Spin may also be provided by Load Resources that are not Controllable Load Resources and are capable of reducing consumption based on an ERCOT Extensible Markup Language (XML) instruction within 30 minutes and maintaining that deployment until recalled. Non-Spin may be deployed to replace loss of generating capacity, to compensate for Load forecast and/or forecast uncertainty on days in which large amounts of reserve are not available online, to address the risk of net load ramp, or when there is a limited amount of capacity available for Security-Constrained Economic Dispatch (SCED).

The periods when load is increasing and wind and/or solar are decreasing requires other generation resources to increase output or come online quickly to compensate for the sudden net load increases. As a result, net load ramp risk should be accounted for in the determination of Non-Spin requirements. While net load forecast analysis may cover reserves required for forecast uncertainty, it may not necessarily cover exposure to the loss of generation and net load ramp risk. Due to this risk, it may be necessary for ERCOT to have additional reserves available to protect against forecast uncertainty and Forced Outages of thermal Resources within an Operating Day.

Summary

1

Analysis for Non-Spin requirements are conducted using data from the same month of previous three years. For the purpose of determining the amount of Non-Spin to purchase for each hour of the day, hours will be placed into 4-hour blocks. The net load uncertainty for the analyzed days for all hours which are considered to be part of a 4-hour block will be calculated and a percentile will be assigned to this block of hours based on the risk of net load ramp. The same calculation will be done separately for each block. The Non-Spin requirement for the month for each block is calculated using the assigned percentile (based on risk of net load ramp) for the block minus the average Reg-Up requirement during the same block of hours ("Non-Spin block"). The Non-Spin requirement for each hour in the month is calculated by adding an adjustment that accounts for intra-day Forced Outage of thermal Resources to the previously calculated "Non-Spin block" quantity that the hour falls in.

ERCOT will post the monthly amounts for Non-Spin requirements for the upcoming year on the MIS. Following this posting, ERCOT will monitor the weather and net load forecast (i.e. load, wind and solar forecasts) near Real-Time and may procure up to an additional 1,000 MW of Non-Spin for Operating Hours that are (a) identified as having an increased potential of high forecast variability, (b) there is a risk that the actual net load during these Operating Hours could be higher than forecast (after making appropriate forecast model selection) and (c) the expected available capacity and expected reserves including the posted minimum Non-Spin requirements during these Operating Hours is not sufficient to cover the projected net load forecast uncertainty risk.

The minimum amount of Non-Spin procured from SCED dispatchable Resources in any hour shall not be less than ERCOT's Most Severe Single Contingency (MSSC) value.

Procedure

ERCOT will determine the Non-Spin requirement using the 75th to 95th percentile of hourly net load uncertainty from the same month of the previous three years. Net load is defined as the ERCOT load minus the estimated un-curtailed total output from Intermittent Renewable Resource (IRR), which includes both Wind-powered Generation Resources (WGRs) and Photo-Voltaic Generation Resources (PVGR) at a point in time. The forecast of net load is computed by subtracting the aggregate IRR High Sustained Limits (HSLs) in the Current Operating Plans (COPs) from the Mid-Term Load Forecast (MTLF). <u>The COPs and MTLF used for HE23, HE24, HE01 and HE02 are the updated values as of four hours prior to each Operating Hour. For remaining hours, Fthe COPs and MTLF used are the updated values as of six hours prior to each Operating Hour. The net load uncertainty is then defined as the difference between the average 5-minute net load within the hour and the forecasted net load.</u>

The risk of net load ramp is determined based on the change in net load over an hour divided by highest observed net load for the season. A fixed value of 68th percentile will be assigned to HE23, HE24, HE01 and HE02 to the net load forecast uncertainty calculated previously. <u>Additionally</u> for these same hours a net-load forecast uncertainty of four hours prior to the Operating Hour will be used for the calculations. Additionally, Iin all seasons excluding Winter, in hours a fixed value of 68th percentile will also be assigned to HE03, HE04, HE05, HE06 a fixed value of 68th percentile will also be assigned to HE03, HE04, HE05, HE06 a fixed value of 68th percentile will be assigned forto the net load forecast uncertainty calculated previously. For the remaining hours, a fixed value of percentile ranging between 75th percentile and 95th percentile will be assigned to the net load forecast uncertainty calculated previously. Periods where the risk of net load ramp is highest will use 95th percentile and 75th percentile for periods with lowest risks.

ERCOT has seen significant growth in installed wind and solar capacity from one year to the next; an increase in wind and solar capacity also tends to increase the MW quantity of error in their respective forecasts. Hence, ERCOT's reliance on historical wind and solar forecast errors alone creates a possibility of under-estimation of the Non-Spin requirement.

To address this, ERCOT will include the impact of increase in over-forecast error from the expected growth in wind and solar generation installed capacity into the future Non-Spin requirement. The net wind impact is calculated by a multiplication of the projected wind capacity growth between the same month of current year and the next year, and incremental MW adjustment to Non-Spin value per 1000 MW of incremental wind generation capacity. The incremental MW wind adjustment to the Non-Spin value per 1000 MW increase in wind installed capacity is calculated as the change in 50th percentile of the historical wind over-forecast error for 4-hour blocks of each month in the past 5 years, which is then normalized to per 1000 MW of installed wind capacity. The net solar impact is calculated by a multiplication of the projected solar capacity growth between the same month of current year and the next year, and incremental MW adjustment to Non-Spin value per 1000 MW of incremental solar generation capacity. The incremental MW solar adjustment to the Non-Spin value per 1000 MW increase in solar installed capacity is calculated as the change in 50th percentile of the historical solar over-forecast error for 4-hour blocks of each month in the past 3 years, which is then normalized to per 1000 MW of installed solar capacity. The tables below reflects the additional Non-Spin adjustments per 1000 MW-of installed wind and solar capacity.

To account for increased capacity needs due to unplanned generation Outages that occur during an Operating Day, ERCOT will include an incremental adjustment in the Non-Spin requirements that accounts for intra-day Forced Outages of thermal Resources. This Forced Outage adjustment is calculated as the 75th percentile of the historical intra-day Forced Outages (accumulated since midnight) for six-hour blocks of each month in the past three years. The table below reflects additional Non-Spin adjustments to account for intra-day Forced Outages of thermal Resources. ERCOT will purchase Non-Spin such that the combination of Non-Spin and Reg-Up Services cover the uncertainties of net load forecast errors depending on the net load ramp risk and intraday Forced Outages.

| | - | | | | - | | | - | | | - P | | | | _ | _ | _ | | - | | | | | |
|-----------------|----|---------------|----|----|----|-----|---------------|---------------|---------------|---------------|---------------|---------------|----------------|---------------|----|---------------|----|---------------|---------------|---------------|---------------|---------------|---------------|----|
| | | | | | _ | | _ | | | -11- | our En | ding | | | | | | | | | | | | |
| Month | + | 2 | 3 | 4 | 5 | six | 7 | 8 | 9 | 10 | 44 | 12 | 1 3 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 24 | 22 | 23 | 24 |
| Jan. | 27 | 27 | 27 | 27 | 27 | 27 | 29 | 29 | 29 | 29 | 22 | 22 | 22 | 22 | 23 | 23 | 23 | 23 | 28 | 28 | 28 | 28 | 27 | 27 |
| Feb. | 27 | 27 | 27 | 27 | 27 | 27 | 29 | 29 | 29 | 29 | 22 | 22 | 22 | 22 | 23 | 23 | 23 | 23 | 28 | 28 | 28 | 28 | 27 | 27 |
| Mar. | 29 | 29 | 31 | 31 | 31 | 31 | 30 | 30 | 30 | 30 | 25 | 25 | 25 | 25 | 26 | 26 | 26 | 26 | 29 | 29 | 29 | 29 | 29 | 29 |
| Apr. | 29 | 29 | 31 | 31 | 31 | 31 | 30 | 30 | 30 | 30 | 25 | 25 | 25 | 25 | 26 | 26 | 26 | 26 | 29 | 29 | 29 | 29 | 29 | 29 |
| May | 29 | 29 | 31 | 31 | 34 | 31 | 30 | 30 | 30 | 30 | 25 | 25 | 25 | 25 | 26 | 26 | 26 | 26 | 29 | 29 | 29 | 29 | 29 | 29 |
| Jun. | 27 | 27 | 26 | 26 | 26 | 26 | 26 | 26 | 26 | 26 | 19 | 19 | 19 | 19 | 21 | 21 | 21 | 21 | 28 | 28 | 28 | 28 | 27 | 27 |
| Jul. | 27 | 27 | 26 | 26 | 26 | 26 | 26 | 26 | 26 | 26 | 19 | 19 | 19 | 19 | 21 | 21 | 21 | 21 | 28 | 28 | 28 | 28 | 27 | 27 |
| Aug. | 27 | 27 | 26 | 26 | 26 | 26 | 26 | 26 | 26 | 26 | 19 | 19 | 19 | 19 | 21 | 21 | 24 | 21 | 28 | 28 | 28 | 28 | 27 | 27 |
| Sep. | 21 | 21 | 24 | 21 | 21 | 21 | 22 | 22 | 22 | 22 | 17 | 17 | 47 | 17 | 21 | 21 | 21 | 21 | 22 | 22 | 22 | 22 | 21 | 21 |
| Oet. | 21 | 21 | 21 | 21 | 21 | 21 | 22 | 22 | 22 | 22 | 17 | 17 | 17 | 47 | 21 | 21 | 21 | 21 | 22 | 22 | 22 | 22 | 21 | 21 |
| Nov. | 21 | 21 | 21 | 21 | 21 | 21 | 22 | 22 | 22 | 22 | 17 | 17 | +7 | 17 | 21 | 21 | 21 | 21 | 22 | 22 | 22 | 22 | 21 | 21 |
| Dee. | 27 | 27 | 27 | 27 | 27 | 27 | 29 | 29 | 29 | 29 | 22 | 22 | 22 | 22 | 23 | 23 | 23 | 23 | 28 | 28 | 28 | 28 | 27 | 27 |

| -Incremen | tal MV | <mark>∦ Adj</mark> | ustmei | it to N | on Sp | inning | Reser | ve Ser | vice, j | per 100 | 0 MW | of Inc | remen | tal So | lar Ge | nerati | on Ca | pacity | t | | | | | |
|-----------------|--------|--------------------|--------|---------|-------|--------|-------|--------|---------|--------------------|---------------|---------------|---------------|---------------|--------|---------------|-------|---------------|---------------|----|----|----|----|----|
| | | | | | | | | | | H | our En | ding | | | | | | | | | | | | |
| Month | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 44 | 12 | 13 | 44 | 45 | 16 | 17 | 18 | 19 | 20 | 24 | 22 | 23 | 24 |
| Jan. | Ð | θ | θ | θ | θ | θ | 3 | 3 | 3 | 3 | 37 | 37 | 37 | 37 | 31 | 31 | 31 | 31 | θ | θ | θ | θ | θ | 0 |
| Feb. | θ | θ | θ | θ | θ | θ | 3 | 3 | 3 | 3 | 37 | 37 | 37 | 37 | 31 | 31 | 31 | 31 | θ | θ | θ | θ | θ | 0 |
| Mar. | θ | θ | θ | θ | θ | 0 | 7 | 7 | 7 | 7 | 44 | 44 | 44 | 44 | 48 | 48 | 48 | 48 | 2 | 2 | 2 | 2 | 0 | θ |
| Apr. | θ | θ | θ | θ | θ | θ | 7 | 7 | 7 | 7 | 44 | 44 | 44 | 44 | 48 | 48 | 48 | 48 | 2 | 2 | 2 | 2 | θ | 0 |
| May | θ | θ | θ | θ | θ | θ | 7 | 7 | 7 | 7 | 44 | 44 | 44 | 44 | 48 | 48 | 48 | 48 | 2 | 2 | 2 | 2 | θ | θ |
| Jun. | θ | θ | θ | θ | θ | θ | ++ | # | ++ | ++ | 34 | 34 | 34 | 34 | 36 | 36 | 36 | 36 | 8 | 8 | 8 | 8 | θ | θ |
| Jul. | θ | θ | θ | θ | θ | θ | +1 | # | ++ | -11 | 34 | 34 | 34 | 34 | 36 | 36 | 36 | 36 | 8 | 8 | 8 | 8 | θ | θ |
| Aug. | θ | θ | θ | θ | θ | θ | ++ | ++ | ++ | ++ | 34 | 34 | 34 | 34 | 36 | 36 | 36 | 36 | 8 | 8 | 8 | 8 | θ | θ |
| Sep. | 0 | θ | θ | θ | θ | θ | 4 | 4 | 4 | 4 | 26 | 26 | 26 | 26 | 23 | 23 | 23 | 23 | + | + | + | + | θ | θ |
| Oet. | θ | θ | θ | θ | θ | θ | 4 | 4 | 4 | 4 | 26 | 26 | 26 | 26 | 23 | 23 | 23 | 23 | + | + | + | + | θ | θ |
| Nov. | θ | θ | θ | θ | θ | θ | 4 | 4 | 4 | 4 | 26 | 26 | 26 | 26 | 23 | 23 | 23 | 23 | + | + | + | + | θ | 0 |
| Dee. | 0 | 0 | θ | θ | θ | θ | 3 | 3 | 3 | 3 | 37 | 37 | 37 | 37 | 31 | 31 | 31 | 31 | θ | θ | θ | θ | θ | θ |

| Increment | tal MV | V Adju | stmen | t to No | on-Spi | nning | Reserv | e Ser | ice to | accou | nt for | Intra | lay Fo | reed (| Jutage | s of th | ermal | resou | rees | | | | | |
|-----------|--------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|-----------------|-----------------|-----------------|-----------------|----------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|
| | | | | | | | | | | ł | lour F | Ending | | | | | | | | | | | | |
| Month | + | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | ++ | 42 | 43 | 14 | 1 5 | 16 | 17 | 18 | 19 | 20 | 24 | 22 | 23 | 24 |
| Jan. | 511 | 511 | 511 | 511 | 511 | 511 | 952 | 952 | 952 | 952 | 952 | 952 | 921 | 921 | 921 | 921 | 921 | 921 | 958 | 958 | 958 | 958 | 958 | 958 |
| Febr | 432 | 432 | 432 | 432 | 432 | 432 | 805 | 805 | 805 | 805 | 805 | 805 | 1013 | 1013 | 1013 | 1013 | 1013 | 1013 | 70 4 | 704 | 704 | 704 | 704 | 70 4 |
| Mar. | 515 | 515 | 515 | 515 | 515 | 515 | 839 | 839 | 839 | 839 | 839 | 839 | 839 | 839 | 839 | 839 | 839 | 839 | 700 | 700 | 700 | 700 | 700 | 700 |
| Apr. | 621 | 621 | 621 | 621 | 621 | 621 | 869 | 869 | 869 | 869 | 869 | 869 | 815 | 815 | 815 | 815 | 815 | 815 | 759 | 759 | 759 | 759 | 759 | 759 |
| May | 786 | 786 | 786 | 786 | 786 | 786 | 881 | 881 | 881 | 881 | 881 | 881 | 1052 | 1052 | 1052 | 1052 | 1052 | 1052 | 98 4 |
| Jun. | 612 | 612 | 612 | 612 | 612 | 612 | 771 | 771 | 771 | 771 | 771 | 771 | 817 | 817 | 817 | 817 | 817 | 817 | 997 | 997 | 997 | 997 | 997 | 997 |
| Jul. | 635 | 635 | 635 | 635 | 635 | 635 | 763 | 763 | 763 | 763 | 763 | 763 | 525 | 525 | 525 | 525 | 525 | 525 | 723 | 723 | 723 | 723 | 723 | 723 |
| Aug. | 558 | 558 | 558 | 558 | 558 | 558 | 671 | 671 | 671 | 671 | 671 | 671 | 449 | 449 | 449 | 449 | 449 | 449 | 5 49 | 549 | 549 | 549 | 549 | 549 |
| Sep. | 435 | 435 | 435 | 435 | 435 | 435 | 777 | 777 | 777 | 777 | 777 | 777 | 533 | 533 | 533 | 533 | 533 | 533 | 510 | 510 | 510 | 510 | 510 | 510 |
| Oet. | 581 | 581 | 581 | 581 | 581 | 581 | 1016 | 1016 | 1016 | 1016 | 1016 | 1016 | 995 | 995 | 995 | 995 | 995 | 995 | 863 | 863 | 863 | 863 | 863 | 863 |
| Nov. | 639 | 639 | 639 | 639 | 639 | 639 | 835 | 835 | 835 | 835 | 835 | 835 | 97 4 | 974 | 97 4 | 97 4 | 974 | 97 4 | 1055 | 1055 | 1055 | 1055 | 1055 | 1055 |
| Đee, | 668 | 668 | 668 | 668 | 668 | 668 | 775 | 775 | 775 | 775 | 775 | 775 | 1018 | 1018 | 1018 | 1018 | 1018 | 1018 | 617 | 617 | 617 | 617 | 617 | 617 |

Responsive Reserve (RRS) Requirement Details

Nodal Operating Guide Section 2.3.1.1, Obligation, sets the minimum RRS requirement for all hours under normal conditions. ERCOT will procure amounts of RRS that vary by hour of the day and by month. These RRS amounts will be published by month in six separate blocks covering four-hour intervals. These amounts will be based on expected diurnal load, solar, and wind patterns for the month, will cover 70% of historic system inertia conditions for each block of hours for the month, and will use the equivalency ratio for RRS between Load Resources and Generation Resources to establish the conditions for each block of hours. The equivalency ratio will be used to establish the total reserves assuming the Day-Ahead Market (DAM) will use a one to one equivalency ratio. The minimum level of RRS procured from Resources providing RRS using Primary Frequency Response shall be determined for each month by ERCOT through the use of studies and shall not be less than 1,365185 MWs. The remaining capacity required for RRS will be procured from all Resources qualified to provide RRS including Load Resources. The maximum amount of RRS that can be provided by Resources providing Fast Frequency Response (FFR) is limited to 450 MW. DAM will limit the combined RRS procured from Load Resources controlled by high set under frequency relay and Resources providing FFR to 60% of the total ERCOT may increase the minimum capacity required from Resources RRS requirement. providing RRS using Primary Frequency Response if it believes that the current posted quantity will have a negative impact on reliability or if it would require additional Regulation Service to be deployed. ERCOT will procure additional 200 MW of RRS for each percent of Reserve Discount Factor (RDF) when ERCOT estimates RDF to be less than 1. This adjustment will only apply for those 4-hour blocks where the 85th percentile of weighted average temperate is greater than 95°F. RDFs are reviewed and adjusted based on the generators performance during an unannounced test, RRS amount will be published as a monthly requirement along with the equivalency ratio for each 4-hour block. Additionally, ERCOT will make incremental adjustments to account for Resources operating in synchronous condenser fast response mode providing RRS. This adjustment will only apply to those 4-hour blocks when system inertia is typically expected to be less than 250 GW*s. ERCOT will post these monthly amounts for the upcoming year on the MIS. These annually published amounts are the minimum quantity that will be procured in the DAM for each hour of the year.

Self-arranged RRS used to fulfill a Qualified Scheduling Entity's (QSE's) RRS requirement will be limited to 60% from Resources providing FFR and Load Resources excluding Controllable Load Resources.

If the percentage level for Resources providing FFR and Load Resources, excluding Controllable Load Resources, specified in the Protocols is changed, that change will be reflected in these requirements.

ľ

ERCOT Contingency Reserve Service (ECRS) Details

Introduction

ECRS is a service that is provided using capacity that is capable of being ramped to a specified output level within 10 minutes. ECRS may be provided by unloaded, On-Line Generation Resource capacity; Quick Start Generation Resources (QSGRs); Load Resources that may or may not be controlled by high-set, underfrequency relays; Controllable Load Resources; and Generation Resources operating in synchronous condenser fast-response mode as defined in the Operating Guides. ECRS may be deployed to restore frequency within 10 minutes of a significant frequency deviation to recover deployed Regulation Service, to compensate for intra-hour net load forecast uncertainty and variability on days in which large amounts of online thermal ramping capability is not available, or when there is a limited amount of capacity available for Security-Constrained Economic Dispatch (SCED).

Procedure

ERCOT will procure amounts of ECRS that vary by hour of the day and by month. ERCOT will determine the ECRS requirement as the <u>sum-maximum</u> of capacity needed to recover frequency following a large unit trip and capacity needed to cover for intra-hour net load forecast errors.

The frequency recovery related capacity for ECRS is computed for each hour in every month as capacity needed following a supply-side trip to recover frequency; will be based on expected diurnal load, solar, and wind patterns; -will cover <u>7060</u>% of historic system inertia conditions for each hour for the month and will include an adjustment to account for Regulation Up requirement in the hour.

Intra-hour net load forecast is utilized in establishing Base Points for SCED dispatchable Resources. ERCOT has observed larger intra-hour net load forecast errors during times when there are sudden net load ramps. Through including intra-hour net load forecast errors in calculating ECRS quantities, uncertainty in forecasting intra-hour net load (and hence intra-hour net load ramps) will be accounted for. Specifically, the intra-hour net load forecast error related capacity for ECRS is computed using the 85th to 95th percentile of intra-hour net load uncertainty from the same hour and same month in the previous two years. Net load is defined as the ERCOT load minus the estimated un-curtailed total output from Intermittent Renewable Resource (IRR), which includes both Wind-powered Generation Resources (WGRs) and Photo-Voltaic Generation Resources (PVGR). The forecast of net load is computed by subtracting the Intra-Hour Wind Power Forecast (IHWPF) and Intra-Hour Photo Voltaic Power Forecast (IHPPF) from the Intra-Hour Load Forecast (IHLF). The IHWPF, IHPPF and IHLF used are the updated values as of thirty minutes prior to each Security Constrained Economic Dispatch (SCED) interval. The net load uncertainty is then defined as the difference between the average net load within the SCED interval and the forecasted net load.

The risk of net load ramp is determined based on the change in net load over an hour divided by highest observed net load for the season. The fixed value of percentile ranging between 85th percentile and 95th percentile will be assigned to the net load forecast uncertainty calculated previously. Periods where the risk of net load ramp is highest will use 95th percentile and 85th percentile for periods with lowest risks. A value of at least 90th percentile will be assigned to the net load forecast uncertainty calculated to the net load forecast uncertainty calculated during sunset hours.

ERCOT has seen significant growth in installed solar capacity from one year to the next; an increase in solar capacity also tends to increase the MW quantity of error in their respective forecasts. Hence, ERCOT's reliance on historical solar forecast errors alone creates a possibility of under-estimation of the ECRS requirement. To address this, ERCOT will include the estimated impact of increase in over-forecast error from the expected growth in solar generation installed capacity into the future ECRS requirement. The net solar impact is calculated by a multiplication of the projected solar capacity growth between the same month of current year and the next year, and incremental MW adjustment to ECRS value per 1000 MW of incremental solar generation capacity. The incremental MW solar adjustment to the ECRS value per 1000 MW increase in solar installed capacity is calculated as the change in 50th percentile of the historical solar overforecast error for 4-hour blocks of each month in the past 2 years, which is then normalized to per 1000 MW of installed solar capacity. The tables below reflects the additional ECRS-adjustments per 1000 MW-of installed solar capacity.

| | | | | | | | | | | | | H | our En | ding | | | | | | | | | | |
|-------|---|---|---|---|---|---|---|---|---|---------------|---------------|----|---------------|------|---------------|---------------|---------------|----------------|---------------|---------------|----|----|----|----|
| Month | + | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 1 8 | 19 | 20 | 21 | 22 | 23 | 24 |
| Jan. | θ | θ | θ | θ | θ | θ | θ | θ | θ | θ | 21 | 21 | 21 | 21 | 20 | 20 | 20 | 20 | θ | θ | θ | θ | 9 | θ |
| Feb. | θ | 0 | 0 | 0 | θ | θ | θ | θ | θ | θ | 33 | 33 | 33 | 33 | 20 | 20 | 20 | 20 | θ | θ | θ | θ | θ | θ |
| Mar. | θ | 0 | 0 | θ | θ | θ | θ | 0 | θ | 0 | 33 | 33 | 33 | 33 | 73 | 73 | 73 | 73 | θ | θ | θ | θ | θ | 0 |
| Apr, | θ | θ | θ | θ | θ | θ | θ | θ | θ | 0 | 30 | 30 | 30 | 30 | 55 | 55 | 55 | 55 | θ | θ | θ | θ | θ | θ |
| May | θ | θ | θ | θ | 0 | 0 | θ | θ | θ | 0 | 59 | 59 | 59 | 59 | 96 | 96 | 96 | 96 | 26 | 26 | 26 | 26 | θ | θ |
| Jun. | θ | θ | θ | θ | θ | 0 | 0 | θ | θ | θ | 17 | 47 | 17 | 47 | 41 | 41 | 41 | 41 | 37 | 37 | 37 | 37 | θ | 0 |
| Jul. | θ | θ | 0 | 0 | θ | θ | θ | θ | θ | 0 | 23 | 23 | 23 | 23 | 23 | 23 | 23 | 23 | 8 | 8 | 8 | 8 | 0 | 0 |
| Aug. | θ | θ | θ | θ | θ | θ | θ | θ | θ | 0 | 45 | 45 | 45 | 45 | 53 | 53 | 53 | 53 | 4 | 4 | 4 | 4 | θ | 0 |
| Sep. | θ | θ | θ | θ | θ | 0 | 0 | θ | θ | θ | 64 | 64 | 64 | 64 | 56 | 56 | 56 | 56 | θ | θ | θ | θ | 0 | 0 |
| Oet. | θ | θ | θ | θ | θ | 0 | θ | θ | θ | θ | 26 | 26 | 26 | 26 | 37 | 37 | 37 | 37 | θ | 0 | θ | θ | 0 | 0 |
| Nov. | θ | 0 | 0 | θ | 0 | θ | θ | θ | θ | θ | + | + | + | + | 4 | 4 | 4 | 4 | 0 | 0 | 0 | 0 | 0 | θ |
| Dee. | θ | θ | 0 | θ | θ | 0 | 0 | 0 | θ | θ | 3 | 3 | 3 | 3 | θ | 0 | 0 | θ | 0 | 0 | 0 | 0 | 0 | 0 |