



Filing Receipt

Filing Date - 2024-01-25 05:25:40 PM

Control Number - 55999

Item Number - 8

PROJECT NO. 55999

REPORTS OF THE ELECTRIC	§	PUBLIC UTILITY COMMISSION
RELIABILITY COUNCIL OF TEXAS	§	
	§	OF TEXAS

**ELECTRIC RELIABILITY COUNCIL OF TEXAS, INC.'S
NOTICE OF ENDORSEMENT OF A TIER 1 TRANSMISSION PROJECT**

Pursuant to Protocol Section 3.11.4.9(1), Electric Reliability Council of Texas, Inc. (ERCOT) files this Notice of ERCOT's endorsement of a Tier 1 transmission project submitted by Oncor Electric Delivery Company, LLC (Oncor), LCRA Transmission Services Company (LCRA TSC), and Wind Energy Transmission Texas, LLC (WETT) as reflected in Attachments A and B. Oncor, LCRA TSC and WETT are the ERCOT-registered Transmission Service Providers (TSPs) responsible for the transmission project. ERCOT is prepared to provide the Commission with any additional information it may request regarding this matter.

Dated: January 25, 2024

Respectfully Submitted,

/s/ Katherine Gross

Chad V. Seely
Senior Vice President and General Counsel
Texas Bar No. 24037466
(512) 225-7035 (Phone)
chad.seely@ercot.com

Brandon Gleason
Deputy General Counsel
Texas Bar No. 24038679
(512) 275-7442 (Phone)
brandon.gleason@ercot.com

Katherine Gross
Senior Corporate Counsel
Texas Bar No. 24065610
(512) 225-7184 (Phone)
katherine.gross@ercot.com

ERCOT
8000 Metropolis Drive, Bldg. E, Suite 100
Austin, Texas 78744
(512) 225-7079 (Fax)

ATTORNEYS FOR ELECTRIC
RELIABILITY COUNCIL OF TEXAS, INC.



Taylor
 2705 West Lake Drive
 Taylor, TX 76574
 T 512.248.3000
 F 512.225.7079

Austin
 8000 Montopolis Drive (Building E), Suite 100
 Austin, TX 78744
 T 512.225.7000
 F 512.225.7079

ercot.com

January 24, 2024

Mr. Eithar Nashawati
 Director, Asset Planning
 Oncor Electric Delivery
 2233-B Mountain Creek PKWY
 Dallas, TX 75211-6716

Mr. Sandeep Borkar
 Director, Transmission Planning
 LCRA TSC
 3505 Montopolis Drive (Building D)
 Austin, TX 78744

Mr. Yang Zhang
 Director, Transmission Planning
 Wind Energy Transmission Texas, LLC
 1901 Capital Parkway, Suite 200
 Austin, TX 78746

RE: WETT - Synchronous Condensers Project
 LCRA TSC - Bakersfield Dynamic Reactive Substation Upgrade Project
 Oncor - West Texas Synchronous Condenser Project

Dear Mr. Nashawati, Mr. Borkar and Mr. Zhang:

On December 19, 2023, the Electric Reliability Council of Texas (ERCOT) Board of Directors endorsed the following three Tier 1 transmission projects, collectively referred to as the "West Texas Synchronous Condenser Project," in accordance with ERCOT Protocol Section 3.11.4:

WETT - Synchronous Condensers Project:

- Construct two new 175 MVA synchronous condensers at Cottonwood 345-kV substation;
- Construct two new 175 MVA synchronous condensers at Bearkat 345-kV substation;
- Construct two new 175 MVA synchronous condensers at Long Draw 345-kV substation;

LCRA TSC - Bakersfield Dynamic Reactive Substation Upgrade Project:

- Construct two new 175 MVA synchronous condensers at Bakersfield 345-kV substation;

Oncor - West Texas Synchronous Condenser Project:

- Construct a new 350 MVA synchronous condenser capability at Tonkawa 345-kV substation;
- Construct a new 350 MVA synchronous condenser capability at Reiter 345-kV substation;

The synchronous condensers at each location meet the following engineering specifications:

- Approximately 350 MVA capacity per location;
- Approximately 3,600 Ampere (A) of three-phase fault current contribution to each 345-kV point of interconnection;
- A combined total inertia of 2,000 MW-s or above per location, incorporating synchronous condensers with flywheels; and
- Effective damping control to meet the damping criteria in ERCOT Planning Guide Section 4.1.1.6.

Should you have any questions please contact me at any time.

Sincerely,

A handwritten signature in black ink, reading "Kristi Hobbs". The signature is written in a cursive, flowing style.

Kristi Hobbs

Vice President, System Planning and Weatherization
Electric Reliability Council of Texas, Inc.

cc: Pablo Vegas, ERCOT
Woody Rickerson, ERCOT
Prabhu Gnanam, ERCOT
Robert Golen, ERCOT
Brandon Gleason, ERCOT



ERCOT Independent Review of West Texas Synchronous Condenser Project

Version 1.0

Document Revisions

Date	Version	Description	Author(s)
November 20, 2023	1.0	Final	Christian Danielson
		Reviewed by	Sun Wook Kang, Prabhu Gnanam

Executive Summary

Inverter-based resources (IBRs) in West Texas have experienced rapid and continued growth. The total capacity of IBRs in West Texas is projected to surpass approximately 42 GW¹ by the end of 2025. The performance of IBRs, such as solar, wind, and energy storage resources, relies heavily on power electronic controls and the strength of the system. In regions like West Texas, where the significant prevalence of IBRs coupled with the absence of conventional synchronous generation resources can result in relatively low levels of short circuit current and synchronizing torque (i.e. weak grid) and increase the likelihood of potential instability issues.

Recent Odessa events in 2021 and in 2022 highlighted this vulnerability as well as IBR performance failures, resulting in a substantial reduction in power output from IBRs triggered by the widespread low voltages during single-line-to-ground (SLG) fault conditions. As the penetration of these IBRs increases, the magnitude of the impact during such occurrences is likely to increase and pose a growing and significant reliability risk to the ERCOT system. Proactively addressing these concerns becomes essential to ensure a reliable and resilient system in West Texas.

To tackle these operational challenges and weak grid issues, ERCOT conducted a comprehensive study to strengthen the system in the West Texas region. In June 2023, ERCOT published the study report titled "[Assessment of Synchronous Condensers to Strengthen the West Texas System](#)," which included the assessment and recommendations for synchronous condenser installations at six 345-kV substations: Cottonwood, Bearkat, Tonkawa, Long Draw, Reiter, and Bakersfield. The study findings indicated that the implementation of synchronous condensers would effectively bolster the reliability of the West Texas system, enhance its resilience to unexpected events, and address the challenges that may arise in real-time operations.

As outlined in Appendix A of the ERCOT Assessment Report titled 'Assessment of Synchronous Condensers to Enhance the West Texas System,' ERCOT made recommendations for specific locations and engineering specifications for the installation of new synchronous condensers:

- Six locations: Cottonwood, Bearkat, Tonkawa, Long Draw, Reiter, and Bakersfield 345-kV substations
- Approximately 350 MVA_r capacity at each location
- Around 3,600 Ampere (A) of three-phase fault current contribution to the 345-kV point of interconnection (POI)
- A combined total inertia of 2,000 MW-seconds (MW-s) or above at each location, incorporating synchronous condenser with flywheel
- Effective damping control to meet the ERCOT damping criteria in the Planning Guide Section 4.1.1.6.

In September 2023, LCRA TSC, WETT, and Oncor submitted three Regional Planning Group (RPG) proposals for six synchronous condensers with the specifications and at the locations that were recommended in the ERCOT Assessment report. After reviewing the three separate RPG submissions (see Appendices B, C and D), ERCOT concluded that the proposed RPG projects align with the recommendations in the ERCOT Assessment Report (Appendix A). Because the study ERCOT conducted for the ERCOT Assessment Report satisfies the requirements of a study conducted for purposes of an ERCOT Independent Review of these RPG submissions under Section 3.11.4.7 of the ERCOT Protocols, ERCOT will utilize the study conducted for the ERCOT Assessment Report (Appendix A) in lieu of a separate study for this ERCOT Independent Review (EIR). Table E1

¹ West Texas IBRs in operation and meeting Planning Guide 6.9(1) by the end of 2025.

summarizes the expected in-service dates and estimated costs of the synchronous condensers proposed by TSPs. Figure E1 depicts the recommended locations for synchronous condensers in West Texas.

Table E1. Expected In-Service Date and Estimated Cost of Synchronous Condensers Proposed by TSPs

TSP	Substation Name	Expected In-Service Date	Estimated Total Cost (\$ Million)
LCRA TSC	Bakersfield 345-kV	May 2027	144.5
Oncor	Tonkawa 345-kV	May 2027	140.0
Oncor	Reiter 345-kV	May 2027	140.0
WETT	Bearkat 345-kV	October 2027	155.2
WETT	Cottonwood 345-kV	October 2027	155.6
WETT	Long Draw 345-kV	October 2027	156.9




Figure E1. Recommended Locations for Synchronous Condensers in West Texas

Table of Contents

Executive Summary	ii
1. Project Need	1
2. Conclusion and Recommendation.....	1
3. Appendix	3
3.1. Appendix A: ERCOT Assessment Report.....	3
3.2. Appendix B: LCRA TSC RPG Submittal	3
3.3. Appendix C: Oncor RPG Submittal	3
3.4. Appendix D: WETT RPG Submittal.....	3

1. Project Need

Over the past seven years, various interconnections across the United States have experienced several system disturbances related to Inverter-Based Resources (IBRs). Among these, three significant events occurred within ERCOT, with two of them taking place in the Odessa area within the West Texas region. These events, known as the Odessa Disturbance events, occurred in May 2021 and June 2022, resulting in substantial generation losses from solar farms. With the remarkable expansion of IBRs, particularly solar generation within ERCOT over the past few years, and the expectation of continued growth, there is a heightened potential for these events to amplify in magnitude, thereby posing significant reliability risks to the system.

In response to the 2021 and 2022 Odessa events, the North American Electric Reliability Corporation (NERC) issued a Level 2 alert in March 2023, identifying them as systemic performance issues that could lead to unexpected losses of Bulk Power System (BPS)-connected generation. NERC recommended addressing performance deficiencies in existing and future generation resources promptly to ensure the reliable operation of the power system.

Following the 2021 Odessa event, ERCOT has intensified efforts to analyze the causes of inverter tripping during such events and to identify corrective measures to enhance the resilience of IBRs and the overall power system. As part of the effort, ERCOT completed a study on June 27, 2023, to strengthen the West Texas region where IBRs are substantially present and conventional synchronous generation resources are lacking. More details of the study can be found in Appendix A.

For this Independent Review of the three combined RPG proposals, ERCOT thoroughly examined and confirmed the validity of the project need described in Section 3 of Appendix A. Additionally, the assumptions and methodology provided in Section 2 of Appendix A were carefully reviewed and found to be comprehensive.

2. Conclusion and Recommendation

The findings of the study in Appendix A indicated that new synchronous condensers at the six locations with a total of 2,100 MVA will improve the reliability and resilience of the West Texas system. The 345-kV substations at Cottonwood, Bearkat, Tonkawa, Long Draw, Reiter, and Bakersfield were identified as effective locations for the installation of a synchronous condenser.

The new synchronous condensers at these proposed substations exhibited a high relative ranking compared to other locations in terms of average weighted short-circuit MVA in the West Texas region. Additionally, these locations are strategically spaced apart, avoiding proximity to existing synchronous condensers, which ensures optimal distribution of reactive power support across the West Texas region. These locations provide support for a broad number of faults across the West Texas region and provide a significant improvement in system responses for critical faults even under stressed system conditions, as demonstrated by the results of the voltage dip and stability simulations. Moreover, these substations have a significant number of major transmission connections, indicating their importance as key hubs within the system. Lastly, the feasibility of installing synchronous condensers at each substation was evaluated and determined to have adequate space by the affected TSP(s). Both these improvements on the transmission system and continued focus on improving IBRs' capability and performance are needed to maintain the reliable operation of the ERCOT system.

Additional system improvements will be required to support the continued growth of IBRs in the ERCOT system.

ERCOT recommends the following locations and engineering specifications for the new synchronous condensers:

- Six locations: Cottonwood, Bearkat, Tonkawa, Long Draw, Reiter, and Bakersfield 345-kV substations
- Approximately 350 MVA capacity at each location
- Around 3,600 Ampere (A) of three-phase fault current contribution to the 345-kV point of interconnection (POI)
- A combined total inertia of 2,000 MW-seconds (MW-s) or above at each location, incorporating synchronous condenser with flywheel
- Effective damping control to meet the ERCOT damping criteria in the Planning Guide Section 4.1.1.6.

ERCOT recommends that the affected TSPs consult with ERCOT if different specifications of the synchronous condensers are considered for implementation.








Figure E1. Recommended Locations for Synchronous Condensers in West Texas

3. Appendix

3.1. Appendix A: ERCOT Assessment Report	 Assessment-of-Sync hronous-Condensei
3.2. Appendix B: LCRA TSC RPG Submittal	 Bakersfield Dynamic Reactive Substation
3.3. Appendix C: Oncor RPG Submittal	 RPG_Oncor_WestTe xas_Synchronous_Ct
3.4. Appendix D: WETT RPG Submittal	 WETT Synchronous Condenser RPG Proj



ERCOT Assessment of Synchronous Condensers to Strengthen the West Texas System

Version 1.0

Document Revisions


Date	Version	Description	Author(s)
June 27, 2023	1.0	Final	Christian Danielson
		Reviewed by	Sun Wook Kang, Prabhu Gnanam

Executive Summary

Inverter-based resources (IBRs) in West Texas have experienced rapid and continued growth. The total capacity of IBRs in West Texas is projected to surpass approximately 42 GW¹ by the end of 2025. The performance of IBRs, such as solar, wind, and energy storage resources, heavily relies on power electronic controls and the strength of the system. The intricate controls of IBRs exhibit rapid responsiveness to even minor system perturbations, which can lead to adverse effects on the system, especially in weak system conditions. In regions like West Texas, the significant prevalence of IBRs coupled with the absence of conventional synchronous generation resources can weaken the system and increase the likelihood of potential instability issues.

In fact, the West Texas region experienced notable disturbances in 2021 and 2022, specifically the Odessa events, which unexpectedly led to a substantial reduction in power output from IBRs triggered by the widespread propagation of low voltages during single-line-to-ground (SLG) fault conditions. In addition, certain IBRs impacted by these events were located relatively far away from the SLG fault location. This observation raises concerns about the potential weakening of the West Texas system. As the penetration of these IBRs increases, the magnitude of the impact during such occurrences is likely to increase and pose a growing and significant reliability risk to the ERCOT system. Proactively addressing these concerns becomes essential to ensure a reliable and resilient system in West Texas.

In addition to various ongoing efforts (e.g., model review and updates based on the event analysis and the approved PGRR085, enhancing operating requirements and model review processes) to minimize such unexpected issues, ERCOT performed a study to strengthen the system in the West Texas region and to address the operational challenges. As a result of the study, ERCOT identified the installation of new synchronous condensers at the Cottonwood, Bearkat, Tonkawa, Long Draw, Reiter, and Bakersfield 345-kV substations. The study results indicated that the implementation of synchronous condensers would effectively bolster the reliability of the West Texas system, make the system more resilient to unexpected events, and address the challenges that may arise in real-time operations. The recommended locations of the synchronous condensers are shown in the map below.



¹ West Texas IBRs in operation and meeting Planning Guide 6.9(1) by the end of 2025.

ERCOT recommends the following locations and engineering specifications for the new synchronous condensers:

- Six locations: Cottonwood, Bearkat, Tonkawa, Long Draw, Reiter, and Bakersfield 345-kV substations
- Approximately 350 MVar capacity at each location
- Around 3,600 Ampere (A) of three-phase fault current contribution to the 345-kV point of interconnection (POI)²
- A combined total inertia of 2,000 MW-seconds (MW-s) or above at each location, incorporating synchronous condenser with flywheel
- Effective damping control to meet the ERCOT damping criteria in the Planning Guide Section 4.1.1.6.

ERCOT recommends that the affected TSPs consult with ERCOT if different specifications of the synchronous condensers are considered for implementation.

ERCOT plans to use this study report and TSP's Regional Planning Group (RPG) project submittal(s) in lieu of an ERCOT Independent Review Report. Cost estimate(s) and anticipated in-service date(s) of the recommended synchronous condensers with flywheels will be provided by the TSPs as part of the RPG project submittal(s).

² To estimate short circuit contribution from each location, the System Protection Working Group (SPWG) case outlined in Section 2.1.1 was employed. Saturated impedance was used based on [ERCOT SPWG Short Circuit Case Building Procedure Manual](#).

Table of Contents

Executive Summary	ii
1. Introduction	5
2. Study Assumptions and Methodology	7
2.1 Assumptions	7
2.1.1 Reliability Study Cases	7
2.2 Methodology	9
2.2.1 System Strength Analysis	9
2.2.2 Voltage Dip Analysis	10
2.2.3 Dynamic Stability Analysis	10
2.2.4 Study Tools	10
3. Project Need	11
4. Project Option Evaluation	13
4.1 Results of System Strength Analysis	13
4.2 Results of Voltage Dip Analysis	14
4.3 Results of Dynamic Stability Analysis	15
5. Sub-Synchronous Oscillation (SSO) Assessment and Sensitivity Studies	17
5.1 SSO Assessment	17
5.2 Planning Guide Section 3.1.3(4) Sensitivity Studies	17
5.2.1 Generation Addition Sensitivity Analysis	17
5.2.2 Load Scaling Sensitivity Analysis	17
6. Other Considerations	18
6.1 West Texas and McCamey GTC Limit Impact Analysis	18
6.1.1 Impact on West Texas GTC	18
6.1.2 Impact on McCamey GTC	18
6.2 Impact on Stage 2 Transmission Upgrades	18
6.3 Impact on Long-Term West Texas Improvement Option	18
6.4 Impact of Additional Synchronous Condensers	19
6.5 Impact of Synchronous Condenser Functional Specifications	20
7. Conclusion and Recommendation	22

1. Introduction

Inverter-based resources (IBRs) in West Texas have experienced rapid and continued growth and are transforming the region's energy landscape, as shown below in Figure 1.1. The performance of IBRs, such as solar, wind, and energy storage resources, heavily relies on power electronics controls and the system strength. The controls associated with IBRs are very intricate and rapid, resulting in exceptionally sensitive responses. This sensitivity becomes particularly significant in weaker systems, such as the West Texas region, where IBRs are substantially present and conventional synchronous generation resources are lacking. As a consequence, the system becomes more vulnerable, posing a heightened risk of potential instability issues.

In fact, single-line-to-ground (SLG) fault events resulting in an unexpected significant power reduction of IBRs in the West Texas region were observed in the past two years, i.e., the 2021 and 2022 Odessa events. During these events, certain IBRs located at a considerable distance from the SLG fault location were impacted. ERCOT interprets this occurrence, along with the widespread propagation of low voltage, as a potential indication of the weakening of the West Texas system. As the penetration of IBRs continues to increase, the magnitude of their impact during such events is expected to escalate. Consequently, this poses a growing and significant reliability risk to the ERCOT system, and proactively addressing these concerns becomes essential to ensure a reliable and resilient system in West Texas.

In an effort to proactively address potential operational challenges, ERCOT conducted this study for adding potential synchronous condensers in the West Texas system. The primary objective of this study was to assess the benefit and feasibility of integrating synchronous condensers into the system and determine suitable locations and sizes for optimal effectiveness.

Figure 1.1 illustrates the trends of the cumulative operational and planned IBRs in the West Texas region up to the year 2025 based on the information obtained from the [May 2023 GIS Report](#) published in June 2023. Currently, there is approximately 4.9 GW of conventional synchronous generation in the West Texas region, some of the major conventional synchronous generators include Odessa Ector Combined Cycle (1,203 MW), Antelope Elk Energy Center (768 MW), and Graham Power Plant (624 MW). While there is no planned conventional synchronous generation that satisfied Planning Guide 6.9(1) as of June 2023, there has been a significant increase in IBRs in the West Texas region.




Figure 1.1 Cumulative Operational and Planned³ Generation Resources in West Texas

In conjunction with this synchronous condenser study, ERCOT is actively engaged in multiple endeavors aimed at improving system stability and enhancing system resilience. One notable initiative is the [Nodal Operation Guide Revision Request \(NOGRR\) 245](#) that is currently under the Stakeholder review process. NOGRR245 is expected to enhance the fault ride-through requirements associated with IBRs based on the IEEE2800-2022. Additionally, ERCOT and Stakeholders are making collaborative efforts to improve the model review process associated with IBRs, while conducting extensive model review of all existing generation resources based on the approved [Planning Guide Revision Request \(PGRR\) 085](#). Furthermore, ERCOT is investigating the events that occurred in the Odessa area to implement measures to prevent similar incidents in the future. Through these concurrent efforts, ERCOT is proactively addressing key challenges and implementing measures to minimize such unexpected reliability issues.

³ Planned Generation Resources includes all generation projects in West Texas under the generation interconnection process.

2. Study Assumptions and Methodology

This section provides an overview of the key assumptions and methodology that ERCOT employed to perform this assessment of the potential synchronous condensers.

2.1 Assumptions

The study region was defined as the ERCOT transmission system in the West Texas (WTX) region, as shown by the highlighted counties in Figure 2.1 below.




Figure 2.1 Study Region

2.1.1 Reliability Study Cases

The reliability study cases were developed based on the assumptions in the subsequent sections.

2.1.1.1. Base Case

- 2022 Dynamics Working Group (DWG) 2025 High Wind Low Load (HWLL) case
- 2022 System Protection Working Group (SPWG) 2025 Future Year (FY) case

2.1.1.2. Transmission Topology

Transmission system topology is consistent with the base case. In addition, the study region was further updated to incorporate major transmission upgrades identified in the 2022 ERCOT Regional Transmission Plan (RTP) that are scheduled for implementation in 2025 if they were not already modeled in the base case.

The placeholder reactive power support devices that were identified in the 2022 RTP were also modeled in the study case to address the potential steady-state voltage issues in the local areas of the Far West Texas (FWTX) region, as shown below in Table 2.1.1. The study case assumed a 350 MVar synchronous condenser at the Reiter 345-kV substation to meet the common reactive power support need between the 2022 RTP and [ERCOT Operations assessment](#). The selection of Reiter as the installation location was based on feedback received from Transmission Service Providers (TSPs), the identification of reactive power support devices in the 2022 RTP, and the proximity of Reiter to the Odessa location.

Table 2.1.1 Placeholder Reactive Power Support Upgrades Modeled in 2022 RTP

Weather Zone	MVar
Far West	2,238

The Delaware Basin Stage 2 upgrade (i.e., the Bearkat – North McCamey – Sand Lake 345-kV transmission line addition) endorsed in 2022 by the ERCOT Board of Directors is expected to be in-service in 2026. Therefore, this major transmission upgrade was not modeled in the study case. A sensitivity of adding this project is discussed in section 6.2.

2.1.1.3. Generation

The list of generators in Table 2.1.2 that met Planning Guide Section 6.9(1) and (2) for inclusion in the planning models at the time of the study were added to the study region based on the [January 2023 Generation Interconnection Status \(GIS\) report](#) published in February 2023.

Table 2.1.2 List of New Generation Based on GIS Published in February 2023

GINR	Project Name	Fuel Type	Projected COD	Capacity (MW)
20INR0120	Vortex Wind	Wind	2/23/2023	350
20INR0249	Appaloosa Run Wind	Wind	4/29/2023	175
20INR0268	Pyron BESS II	Battery	3/15/2023	30
20INR0269	Texas Solar Nova 2	Solar	12/29/2023	201
21INR0401	Young Wind	Wind	4/1/2023	499
21INR0473	Vortex BESS	Battery	3/14/2023	122
22INR0326	Inertia Wind	Wind	4/28/2023	301
22INR0328	Inertia BESS	Battery	10/31/2023	13
22INR0360	Jade Solar	Solar	6/30/2023	327
22INR0363	Hayhurst Texas Solar	Solar	11/1/2023	25
22INR0372	BRP Hydra BESS	Battery	8/1/2023	202
22INR0384	BRP Pavo BESS	Battery	8/1/2023	177
22INR0412	Andromeda Solar	Solar	6/30/2023	327
22INR0485	House Mountain	Battery	5/31/2023	63
23INR0371	Rodeo Ranch Energy Storage	Battery	7/17/2023	307

Generation in the study region was dispatched according to Table 2.1.3. All conventional synchronous generation in the WTX region was turned offline to represent stressed system conditions, i.e., high penetration of IBRs and no online conventional synchronous generation resources in the WTX region. The dispatch level of IBRs in the WTX region was determined based on the following dynamic stability analysis:

- Uniformly increase the power output from IBRs in the WTX study region to stress the WTX interface (power transfer from WTX to the rest of the system) until the system goes unstable under critical NERC P1 or P7 events associated with the WTX Generic Transmission Constraint (GTC) interface.
- The critical dispatch level (maximum stable dispatch) was modeled as the initial IBR dispatch level in the study case, as shown in Table 2.1.3.

Table 2.1.3 WTX Study Region Generation Dispatch

Fuel Type	Dispatch
Solar	70%
Wind	70%
Energy Storage	70%
Conventional	Offline

2.1.1.4. Loads

Large loads in the WTX study region were updated to be consistent with the 2022 RTP. Load updates were needed for the various ERCOT regions that make up the WTX study region, as shown below in Table 2.1.4.

Table 2.1.4 Large Loads Modeled in the WTX Study Region

Weather Zone	Load (MW)
Far West	2,529
North	2,400
West	200

2.2 Methodology

ERCOT utilized the study cases developed based on the assumptions in Section 2.1. These study cases were then utilized to conduct a range of analyses, primarily focusing on reviewing operational challenges and assessing the benefits associated with the potential integration of synchronous condensers. The analyses encompassed system strength analysis, voltage dip analysis, and dynamic stability analysis. The subsequent sections provide a detailed description of the methodologies employed in these analyses.

2.2.1 System Strength Analysis

A system strength analysis was performed with the goal of confirming the locations of the synchronous condensers identified in the ERCOT Operations assessment. System strength is usually measured by short-circuit current (or MVA). ERCOT's weighted short-circuit MVA (WSCMVA) is proposed in this study:

$$WSCMVA = \frac{\sum_{k=1}^n SCMVA_k * P_{GK}}{\sum_{k=1}^n P_{GK}}$$

where:

$SCMVA_k$: short-circuit MVA at the POI of the k-th IBR in WTX

P_{GK} : the capacity (MW) of the k-th IBR in WTX

The locations of the synchronous condensers were adjusted, as needed. The general steps for performing the system strength analysis were to:

1. Apply a three-phase (3PH) fault and record system strength at all individual WTX 345-kV buses in the DWG study case using the WSCMVA.
2. Add a synchronous condenser at each bus on all major WTX 345-kV buses and record system strength. Repeat this step for all individual 345-kV buses in the WTX study region.
3. Confirm and adjust the locations of synchronous condensers identified in the ERCOT Operations assessment.

2.2.2 Voltage Dip Analysis

A voltage dip analysis was performed using the latest System Protection Working Group (SPWG) case built for the year 2025 with the objective to confirm or adjust the locations of the synchronous condensers identified in the system strength analysis. The SPWG study case was used to assess voltage dip via short circuit fault analysis. The DWG study case was also used to assess voltage dip via dynamic stability analysis by applying a fault near the Odessa area. All conventional synchronous generators were turned offline. The synchronous condensers identified in the system strength study were modeled to perform the impact analysis. All IBRs in the WTX study region are assumed to provide negligible short circuit contributions. The general steps for performing the voltage dip analysis were to:

1. Apply a SLG fault on all major WTX 345-kV buses with and without the synchronous condensers modeled.
2. Review 345-kV and 138-kV bus voltages in the WTX study region.
3. Check for any bus voltages less than 0.85 p.u., as this is the assumed voltage ride-through mode trigger threshold.
4. Identify if adding more synchronous condensers would provide a significant benefit.
5. Perform a dynamic stability analysis by testing critical 345-kV SLG events near the Odessa area with and without synchronous condensers to further assess the benefit.

The voltage dip analysis evaluated the impact of fault conditions on the voltage levels at major 345-kV WTX buses, and IBR generation terminals in the WTX study region.

2.2.3 Dynamic Stability Analysis

Dynamic stability simulations were conducted using the DWG study case to further assess the reliability benefits of the synchronous condensers. NERC Category P1 and P7 contingencies associated with the WTX interface and contingencies near the synchronous condenser locations were evaluated.

2.2.4 Study Tools

ERCOT utilized the following software tools to perform the study:

- PSSE versions 33 and 35
- PowerWorld Simulator version 22

3. Project Need

Over the past seven years, several system disturbances related to Inverter-Based Resources (IBRs) have been observed in the United States. Among these disturbances, three have occurred within ERCOT, as depicted in Figure 3.1. Notably, two of these events took place in the Odessa area, which falls within the WTX region. These events, known as the Odessa Disturbance events, occurred in May 2021 and June 2022 within ERCOT. They were characterized by SLG system faults that resulted in a substantial loss of generation from multiple solar farms located in the WTX region. Table 3.1 summarized the reductions of the power output associated with the IBRs during the two events. With the remarkable expansion of IBRs, particularly solar generation within ERCOT over the past few years, and the expectation of continued growth, there is a heightened potential for these events to amplify in magnitude, thereby posing significant reliability risks to the system.




Figure 3.1. Historical IBR Disturbance Events (2016-2022)

Table 3.1 Reductions of MW Output by IBR Unit Type During the Odessa Events

Plant Type	MW Loss in 2021 Odessa Event	MW Loss in 2022 Odessa Event
Solar	1,112	1,711
Wind	36	-

Figure 3.2 depicts the generation interconnection projects by fuel type as of April 2023, showing a significant transition towards solar and energy storage resources (ESR). This shift highlights the evolving energy landscape in ERCOT, while also acknowledging the continued presence of wind projects in the generation interconnection pipeline.




Figure 3.2. Generation Interconnection Projects by Fuel Type (Source: [GIS Report May 2023](#))

The 2021 and 2022 Odessa events prompted NERC to issue a [Level 2 alert](#) on March 14, 2023, identifying them as systemic performance issues with the potential for unexpected losses of Bulk Power System (BPS)-connected generation. In light of these events, NERC recommended that any performance deficiencies in existing and future generation resources be promptly and effectively addressed to ensure the reliable operation of the power system in an efficient manner.

Following the 2021 Odessa event, ERCOT has also intensified its efforts to analyze the underlying causes of inverter tripping during such occurrences. The aim is to identify potential corrective measures that can enhance the ride-through performance of IBRs, strengthening the system's overall resilience. In February 2023, ERCOT Operations suggested integrating potential synchronous condensers at six locations in the WTX region to enhance system reliability and resilience. This initiative aimed to tackle operational challenges arising from unexpected generation or load loss during disturbances, while also strengthening the transmission system.

Based on the need drivers, ERCOT Planning conducted this study to assess operational challenges, evaluate the impact of synchronous condensers, and make recommendations to address these challenges effectively.

4. Project Option Evaluation

The high penetration of IBRs and the absence of conventional synchronous generation resources can weaken the system, increasing the risk of potential system instability and higher likelihood of triggering IBRs into ride-through mode during widespread voltage dips. The observed challenges during the Odessa events in the WTX region highlight the potential impact of system reliability and the need for mitigation.

Such system challenges in the WTX region can be improved through various options such as adding conventional synchronous generators, synchronous condensers, and other technologies (e.g., STATCOMs and grid-forming inverters). In this study, ERCOT considered adding synchronous condensers in the WTX region as the only transmission upgrade option because the installation of synchronous condensers can provide the necessary characteristics for supporting the reliable operation of a system with a high penetration of IBRs. The key characteristics of synchronous condensers include the following:

- Synchronous condensers' response to system disturbances is governed by the physical characteristics of the devices, which makes them more reliable and predictable than other device technologies that have a response based more on their control system programming. Inverter-based technology like grid-following inverters and STATCOMs are both based on power electronics control, which can be more susceptible to system conditions and unpredictable.
- Synchronous condensers are rotating machines, providing a strong system inertia which is important to keep the system frequency stable.
- Synchronous condensers provide dynamic reactive power support on the system by absorbing or generating reactive power as needed.
- Synchronous condensers improve system strength and increase fault current which is beneficial for the proper functioning of IBRs.
- Synchronous condensers are a mature technology with a long history of successful use.
- Synchronous condensers are being considered and implemented globally by the utility and system operators with a high penetration of IBRs. In addition, various countries in Europe (e.g., Germany, Latvia, Lithuania, UK, Ireland, Estonia, and Italy) are considering and have already implemented synchronous condensers augmented with flywheels in the last several years to improve the reliability of their systems.
- Flywheels, mechanically linked with synchronous condensers via couplings, provide additional inertia and are beneficial for frequency support. This addition is a valuable measure to prepare for uncertain system conditions that may arise in ERCOT.
- Two synchronous condensers were installed in 2018 in the ERCOT Panhandle region to provide the required voltage and system strength support. With the amount of existing and projected growth of IBRs, the need for the similar improvement has been identified for the broader WTX region.

4.1 Results of System Strength Analysis

ERCOT performed the system strength analysis based on the methodology outlined in Section 2.2.1 to evaluate the impact on the system strength by adding a synchronous condenser at each bus on all major WTX 345-kV buses. ERCOT repeated this step for all individual 345-kV buses in the WTX region and ranked those buses in terms of the WSCMVA.

According to the study results, there is an estimated average enhancement of 11% in the system strength within the WTX region. Based on the results of the system strength analysis, the 345-kV substations which ranked as the most suitable locations for the installation of new synchronous condensers were Cottonwood, Bearkat, Tonkawa, Long Draw, Reiter, and Bakersfield. These substations exhibited a higher average WSCMVA ranking compared to other substations in the WTX region.

4.2 Results of Voltage Dip Analysis

ERCOT performed a voltage dip analysis based on the methodology outlined in Section 2.2.2. A SLG fault was tested on all major WTX 345-kV buses with and without the synchronous condensers modeled to further assess the impact on the voltages at all WTX 345-kV buses and IBR terminals.

The results of the voltage dip analysis aligned with the findings of the system strength analysis, confirming the suitability of the 345-kV Cottonwood, Bearkat, Tonkawa, Long Draw, Reiter, and Bakersfield substations as effective locations for synchronous condensers. Synchronous condensers at these substations demonstrated their ability to mitigate voltage dips throughout the WTX region effectively, thereby minimizing the widespread voltage dips during fault events. This convergence of results from both analyses strengthens the case for selecting these substations as appropriate locations for synchronous condensers.

According to the study results, there is an estimated average reduction of 21% in the number of 345-kV and 138-kV buses and 22% in IBRs that encounter severe voltage dips (less than 0.85 p.u.) during major transmission faults in the WTX region. Figure 4.2.1 shows the voltage contour comparison illustrating a significant benefit of the synchronous condensers by mitigating the widespread voltage dip under a SLG fault in the Odessa area.




Figure 4.2.1 345-kV WTX Bus Voltage Profile Contour with a SLG Fault at Odessa-area 345-kV Bus

4.3 Results of Dynamic Stability Analysis

ERCOT tested SLG fault events at Odessa and other synchronous condenser locations with and without the potential synchronous condensers modeled in order to mimic the Odessa events and further assess any potential operational benefit. ERCOT also evaluated critical NERC P1 and P7 events with and without synchronous condensers to assess any potential reliability benefits.

The results of the stability analysis show no adverse impacts caused by the addition of the synchronous condensers and demonstrated improved stability, as depicted by the representative plots discussed below.

The plots in Figure 4.3.1 are representative of bus voltages for a critical NERC P1 contingency with a 3PH fault applied around a particular 345-kV substation in WTX. There is a notable reduction in voltage dip and voltage overshoot, and an improvement in voltage response during 3PH fault conditions, which can potentially lead to a reduction in unexpected generation tripping during critical events that occur under stressed system conditions.




Figure 4.3.1 345-kV Bus Voltage Comparison for P1 (3PH) at the WTX Interface

The additional plots below are representative of bus voltages for a P7 contingency with a SLG fault applied around a particular 345-kV substation in WTX. Similarly, the results reveal a reduction in voltage dip and voltage overshoot during SLG fault conditions, as shown below in Figure 4.3.2.




Figure 4.3.2 345-kV Bus Voltage Comparison for P7 (SLG) at the WTX Interface

5. Sub-Synchronous Oscillation (SSO) Assessment and Sensitivity Studies

For the potential synchronous condensers identified in this study, an SSO assessment was performed to identify any adverse impacts to the system in the study region. In addition, sensitivity studies were performed to identify the performance of the synchronous condensers under certain sensitivity scenarios.

5.1 SSO Assessment

Pursuant to Nodal Protocol Section 3.22.1.3, ERCOT conducted an SSO screening for the potential synchronous condensers. The results of the topology check indicated that all the synchronous condenser locations except at the Reiter 345-kV substation are considered to be potentially vulnerable to SSO. Therefore, a detailed SSO assessment is recommended, and the affected TSPs shall coordinate with ERCOT to perform and complete a detailed SSO assessment and provide any SSO Mitigation, if required, prior to energization of synchronous condensers.

5.2 Planning Guide Section 3.1.3(4) Sensitivity Studies

It is anticipated that the transmission upgrades (i.e., new synchronous condensers at six locations) is categorized as a Tier 1 project, pursuant to ERCOT Protocol 3.11.4.3. As required by Planning Guide Section 3.1.3 (4), ERCOT also performed generation and load sensitivity studies.

5.2.1 Generation Addition Sensitivity Analysis

Upon reviewing the [May 2023 GIS Report](#) published in June 2023, ERCOT concluded that conducting a generation sensitivity analysis is not required. This determination was made based on the fact that, apart from IBRs, there are no conventional synchronous generation resources that have a signed Standard Generation Interconnection Agreement (SGIA) that were excluded from the study cases.

5.2.2 Load Scaling Sensitivity Analysis

Planning Guide Section 3.1.3(4)(b) requires evaluation of the potential impact of load scaling on the criteria violations seen in this ERCOT independent review. ERCOT concluded that the load scaling would not have a material impact on the project need because of the following reason:

- The short circuit system strength and inertia primarily depend on the characteristics of the generation resources and the overall design of the power system. Load, on the other hand, is typically considered as a passive element in the system. While load plays a crucial role in determining the power flow and voltage levels within the system, it does not have a substantial influence on system strength and inertia.

6. Other Considerations

Further assessments were carried out to evaluate the potential effects of the new synchronous condensers on the existing GTCs and the conceptual long-term WTX improvement option⁴. ERCOT also conducted an analysis to evaluate the effectiveness of incorporating additional synchronous condensers or modifying their functional specifications. These analyses were undertaken to comprehensively understand the potential impacts and benefits of the new synchronous condensers.

6.1 West Texas and McCamey GTC Limit Impact Analysis

6.1.1 Impact on West Texas GTC

ERCOT performed dynamic stability studies utilizing the DWG study cases to assess the effect of the potential new synchronous condensers on the WTX GTC limit. The findings from the studies indicate that the WTX GTC limit was not significantly affected. Moving forward, the WTX GTC will undergo continuous review and updates in the future Quarterly Stability Assessments (QSAs) to ensure its accuracy and relevance.

6.1.2 Impact on McCamey GTC

ERCOT carried out dynamic stability studies using the most recent QSA case to analyze the influence of the potential new synchronous condensers on the existing McCamey GTC limit. The study findings indicate an anticipated average improvement of 15% in the McCamey GTC limit with the inclusion of the synchronous condensers. However, the extent of improvement may vary based on specific events and prior outage conditions. Moving forward, the McCamey GTC will undergo regular review and updates in future QSAs to ensure its accuracy and relevance.

6.2 Impact on the Delaware Basin Stage 2 Transmission Upgrades

ERCOT performed system strength and dynamic stability sensitivity analyses by modeling the Delaware Basin Stage 2 upgrade (i.e., the Bearkat – North McCamey – Sand Lake 345-kV Transmission Line Addition) in the DWG study case to evaluate the potential impacts on the locations of the new synchronous condensers. The Stage 2 upgrade was endorsed in 2022 by the ERCOT Board of Directors and is expected to be in-service in 2026.

The analysis revealed that none of the chosen locations were adversely affected by the transmission upgrades. However, it was observed that the 345-kV Bearkat location became even more advantageous due to the additional connections to the transmission system.

6.3 Impact on Long-Term West Texas Improvement Option

ERCOT utilized the previous 2030 HWLL study case from the ERCOT Long-term WTX Export study⁴, specifically focusing on modeling the Option 1 (4AC upgrades), to evaluate the impact of the new synchronous condensers by testing select critical NERC P7+P7 contingencies. The results of this study found no adverse impacts on the potential long-term WTX export option and only showed similar system improvements to those observed in the previously conducted analysis. As shown in Figure 6.3.1, the inclusion of the new synchronous condensers in the 2030 HWLL study case showed the benefits of enhanced system performance under fault conditions.

⁴ Long-Term West Texas Export Study Report: <https://www.ercot.com/gridinfo/planning>




Figure 6.3.1 Long-Term WTX Export Improvement Option and Effects of Synchronous Condensers

6.4 Impact of Additional Synchronous Condensers

Based on the results of the system strength and voltage dip analyses, it has been determined that installing new synchronous condensers at the six locations is adequate and the potential benefit of adding more would likely diminish. By strategically placing new synchronous condensers in WTX, the system can effectively manage fault conditions and mitigate voltage dips. However, beyond this threshold, the benefits of additional synchronous condensers may diminish due to factors such as diminishing marginal gains in voltage dip improvement, as observed in the plots below.




Figure 6.4.1 Diminishing # of Affected IBR Capacity with Additional Synchronous Condensers at Clear Crossing, Big Hill, Divide, and Dermott 345-kV substations




Figure 6.4.2 Diminishing # of Affected Transmission Buses with Additional Synchronous Condensers at Clear Crossing, Big Hill, Divide, and Dermott 345-kV substations

6.5 Impact of Synchronous Condenser Functional Specifications

The results of the system strength, voltage dip, and dynamic simulations support the selection of a 350 MVA size for the new synchronous condensers, favoring it over a smaller capacity of 175 MVA, as observed in the plots below. Considering these analyses, a synchronous condenser with a capacity of 350 MVA proves beneficial. Its larger capacity allows for enhanced system strength, voltage dip mitigation, and improved transient stability response. The higher capacity of the synchronous condensers provides a greater margin of reliability and flexibility, ensuring a robust and resilient system operation even under more stressed conditions.




Figure 6.5.1 System Strength Results (175 MVA vs 350 MVA)




Figure 6.5.2 Voltage Dip Results Measured as IBR Capacity (175 MVA vs 350 MVA)




Figure 6.5.3 Voltage Dip Results Measured as Affected Transmission Buses (175 MVA vs 350 MVA)





Figure 6.5.4 345-kV Bus Voltage Comparison for P1 (3PH) at the WTX Interface (175 MVA vs 350 MVA)

7. Conclusion and Recommendation

The findings of this study indicated that new synchronous condensers at the six locations with a total of 2,100 MVA will improve the reliability and resilience of the WTX system. The 345-kV substations at Cottonwood, Bearkat, Tonkawa, Long Draw, Reiter, and Bakersfield were identified as effective locations for the installation of a synchronous condenser. Firstly, the new synchronous condensers at these substations exhibited a high relative ranking compared to other locations in terms of average WSCMVA in the WTX region. Additionally, these locations are strategically spaced apart, avoiding proximity to existing synchronous condensers, which ensures optimal distribution of reactive power support across the WTX region. These locations provide support for a broad number of faults across the WTX region and provide a significant improvement in system responses for critical faults even under stressed system conditions, as demonstrated by the results of the voltage dip and stability simulations. Moreover, these substations have a significant number of major transmission connections, indicating their importance as key hubs within the system. Lastly, the feasibility of installing synchronous condensers at each substation was evaluated and determined to have adequate space by the affected TSP(s). Both these improvements on the transmission system and continued focus on improving IBRs' capability and performance are needed to maintain the reliable operation of the ERCOT system. Additional system improvements will be required to support the continued growth of IBRs in the ERCOT system.

ERCOT recommends the following locations and engineering specifications for the new synchronous condensers:

- Six locations: Cottonwood, Bearkat, Tonkawa, Long Draw, Reiter, and Bakersfield 345-kV substations
- Approximately 350 MVA capacity at each location
- Around 3,600 Ampere (A) of three-phase fault current contribution to the 345-kV point of interconnection (POI)²
- A combined total inertia of 2,000 MW-seconds (MW-s) or above at each location, incorporating synchronous condenser with flywheel
- Effective damping control to meet the ERCOT damping criteria in the Planning Guide Section 4.1.1.6.



ERCOT recommends that the affected TSPs consult with ERCOT if different specifications of the synchronous condensers are considered for implementation.

ERCOT plans to use this study report and TSP's RPG project submittal(s) in lieu of an ERCOT Independent Review Report. Cost estimate(s) and anticipated in-service date(s) of the recommended synchronous condensers with flywheels will be provided by the TSPs as part of the RPG project submittal(s).

Bakersfield Dynamic Reactive Substation Upgrade

ERCOT Regional Planning Group Submission

LCRA Transmission Services Corporation
September 1, 2023



TRANSMISSION PLANNING

Executive Summary

LCRA Transmission Services Corporation (LCRA TSC) is submitting the proposed Bakersfield Dynamic Reactive Substation Upgrade Project to the Regional Planning Group (RPG) for review and comment. Pursuant to ERCOT Nodal Protocols Section 3.11.4.6, this project is being submitted as a Tier 1 project. The approximate geographic location of the proposed project is shown in Figure 1.

In June 2023, ERCOT recommended, in its "Assessment of Synchronous Condensers to Strengthen the West Texas System"¹ study report, the addition of six 350 Mvar synchronous condensers at geographically and electrically diverse substations in West Texas. The study recommended that one of the six synchronous condensers be installed at Bakersfield Substation, a 345-kV substation owned and operated by LCRA TSC.



Figure 1: Bakersfield Substation

¹ <https://www.ercot.com/files/docs/2023/06/27/Assessment-of-Synchronous-Condensers-to-Strengthen-West-Texas-System.pdf>

In this project, LCRA TSC will install two 175 Mvar synchronous condensers capable of providing at least 3600 A of three-phase fault current contribution and 2,000 MW-seconds of total inertia at Bakersfield Substation by a planned in-service date of May 2027.

The cost estimate for the project is \$144.5 million. This cost estimate is subject to revision as the project proceeds through scoping, design, and construction.

Introduction

West Texas has experienced rapid and continued growth of inverter-based resources (IBRs) with few conventional synchronous generation resources in the region. This has resulted in a weaker system where single-line-to-ground fault events have resulted in unexpected significant power output reduction of IBRs in West Texas as well as conventional generation, as observed in the 2021 and 2022 Odessa events.

In June 2023, ERCOT published its “Assessment of Synchronous Condensers to Strengthen the West Teas System” study report. ERCOT presented the report at the June 2023 Regional Planning Group (RPG) meeting. The report recommended the installation of 350 Mvar synchronous condensers at six substations in the West Texas region, one of which was Bakersfield Substation.

Assessment of the Project Scope

This project will install two (2) 175 Mvar synchronous condenser (350 Mvar total capacity) at Bakersfield Substation. In LCRA TSC’s review of synchronous condenser design requirements and discussions with manufacturers, direct air-cooling technology is recommended for the design as it is safer to implement and operate, has a lower lifetime cost in comparison to other available technologies. To meet the prescribed short circuit requirements, two synchronous condensers will be required. Additionally, a step-up transformer for each synchronous condenser is recommended for resiliency, maintainability and operational flexibility of the synchronous condensers. To that extent, this project submission builds on the planning analysis presented in ERCOT’s report.

Evaluation of System Needs

Three system disturbances have occurred within ERCOT in recent years, “Odessa” in 2021, “Panhandle” in 2022, and “Odessa-2” in 2022. The Odessa 2021, the Panhandle 2022 and the Odessa 2022 events resulted in a power loss or reduction of 1,340 MW, 765 MW and 2,555 MW respectively. With the generation interconnection queue showing a continued growth of IBRs, 130 GW of Solar and 120 GW Energy Storage Resources, there will be increased potential for events like these in West Texas. These events and the growing IBR queue were the primary drivers for ERCOT to conduct the Assessment of Synchronous Condensers to Strengthen the West Teas System.

Bakersfield Substation is located on the key southernmost transmission corridor that connects West Texas to Central Texas. Bakersfield Substation is connected to four 345-kV circuits and will be connected to a fifth 345-kV circuit as part of the ongoing Bakersfield – Big Hill Second Circuit

Addition project². Bakersfield Substation also interconnects two 50 Mvar shunt reactors, as well as the 121 MW East Pecos (Bootleg) Solar, 202 MW Hydra BESS, 250 MW Redbarn Solar, and 182 MW Waymark Solar generation facilities.

System Strength and Voltage Dip Analysis

ERCOT identified six most suitable locations for an installation of a synchronous condenser. Bakersfield Substation was chosen as one of the six locations. Bakersfield Substation was identified via a system strength and a voltage dip analysis. Utilizing the Weighted Short Circuit MVA (WSCMVA) as measure of the system strength, Bakersfield was identified as having a higher WSCMVA compared to other substations in the West Texas region. Utilizing the System Protection Working Group (SPWG) 2025 Future Year (FY) case and the Dynamic Working Group (DWG) built for 2025 High Wind Low Load (HWLL), Bakersfield Substation was also found to help mitigate voltage dips throughout the West Texas region. The results of the system strength and voltage dip analysis confirmed Bakersfield Substation as an ideal location for a synchronous condenser.

Steady State Analysis

LCRA TSC performed steady state analysis of the 345-kV system surrounding Bakersfield Substation using the 2027 summer on-peak and 2027 high renewable minimum load power flow cases published by the ERCOT Steady State Working Group in June 2023. The steady state analysis conformed to the performance requirements in the NERC TPL-001-5.1 Reliability Standard, ERCOT Planning Guide, and LCRA TSC Transmission Planning Criteria. The analysis studied post-contingency performance for NERC Category P1, P2, P4, P5, and P7 contingency events and ERCOT Planning Guide Category 1. Selected NERC Category P3 and P6 contingency events and ERCOT Planning Guide Category 2 and 3 in the 345-kV surrounding system were also included in the analysis.

The steady state analysis did not find any adverse impact due to the addition of the synchronous condensers.

Dynamic Analysis

A dynamic analysis was performed by ERCOT by assessing critical NERC Category P1 and P7 contingency events and comparing the results with and without the synchronous condensers. The results of that analysis showed no adverse impacts caused by the addition of the synchronous condensers. Additionally, dynamic analysis of the McCamey GTC conducted by ERCOT revealed an average improvement of 15% to the McCamey GTC limit with the synchronous condenser. The Bakersfield Substation is located within the McCamey GTC boundary.

LCRA TSC performed an additional dynamic analysis of the 345-kV system surrounding Bakersfield Substation using the 2025 summer on-peak and 2026 high wind low load dynamic flat state cases posted by the ERCOT Dynamics Working Group in March of 2023. The dynamic analysis conformed to the performance requirements in the NERC TPL-001-5.1 Reliability Standard, ERCOT Planning Guide, and LCRA TSC Transmission Planning Criteria. The analysis studied post-contingency performance for NERC Category P1, P2, P4, P5, and P7 contingency

² ERCOT endorsed the Bakersfield to Big Hill 345-kV Second Circuit Addition Project in June 2021.

events and ERCOT Planning Guide Category 1. Selected NERC Category P3 and P6 contingency events and ERCOT Planning Guide Category 2 and 3 in the 345-kV surrounding system were also included in the analysis.

The LCRA TSC dynamic analysis did not find any adverse impact due to the addition of the synchronous condensers.

Short Circuit Analysis

LCRA TSC conducted a short circuit analysis to assess the impact of Bakersfield synchronous condensers using the SPWG Future Year 2025 case. Based on the results of this analysis, following addition of the synchronous condensers, the maximum fault duty experienced by Bakersfield and surrounding 345-kV substations will be 22.6 kA which is an increase of 3.6 kA compared to the base case. All existing LCRA TSC circuit breakers at the surrounding 345-kV substation are rated at 63 kA.

The LCRA TSC short circuit analysis confirmed that the short circuit increase requirement is met, and no adverse impacts were identified due to the addition of the synchronous condensers.

Sub-Synchronous Oscillation Assessment

A detailed SSO assessment will be conducted prior to energization of the synchronous condenser at Bakersfield Substation.

Project Scope

The schematic for the project can be found in Figure 2 and the cost of the project can be found in Table 1 below.

LCRA TSC, at Bakersfield Substation, will install:

- Two (2) synchronous condensers each with a step-up transformer and the following operating characteristics:
 - 175 Mvar capacity at each of the two machine terminals
 - A combined 3,600 A of three phase fault current contribution to the 345-kV Bakersfield Substation
 - A combined total inertia of 2,000 MW-seconds incorporating synchronous condenser with flywheel
 - Effective damping control to meet the ERCOT damping criteria in the Planning Guide Section 4.1.1.6
- Two (2) 345-kV transmission bays with four (4) 362-kV, 5000A, 63kAIC, circuit breakers connected in a double bus and double breaker configuration including 362-kV operating bus extensions, 362-kV switches and protective relaying connecting each synchronous condenser at Bakersfield Substation.




Figure 2: Bakersfield Synchronous Condenser Schematic

Table 1: Cost estimate³ for Bakersfield Dynamic Reactive Substation Upgrade Project

Scope	TSP(s)	Cost
Install two 175 MVar Synchronous Condensers and the necessary terminal equipment	LCRA TSC	\$144.5 M

Recommended Project Benefits

The recommended project will improve and enhance the reliability of the ERCOT System in the West Texas region in several ways. The project will:

- Improve system strength by providing inertia and increased fault current contribution in the area.
- Improve voltage stability by providing additional dynamic reactive support.
- Increase the McCamey GTC limit by approximately 15%.

Alternatives Evaluated

ERCOT considered and rejected addition of other technologies (e.g. STATCOMs) because the installation of synchronous condensers in the West Texas region are uniquely suited to provide

³ Latest available estimate prior to final issued design, and subject to revision as additional factors may be identified.

the necessary characteristics to support the inertia, dynamic reactive power support, and increased fault current needs of the region.

In addition to the six locations, ERCOT evaluated the benefits of adding additional synchronous condensers but opted to not recommend additional locations at this time based on the results of the system strength and voltage dip analyses.

Recommendation

In concurrence with the ERCOT Assessment of Synchronous Condensers to Strengthen West Texas System, LCRA TSC recommends the installation of two 175 Mvar synchronous condensers to meet ERCOT-specified requirements at the Bakersfield Substation with a planned in-service date of May 2027.

WEST TEXAS SYNCHRONOUS CONDENSER PROJECT

ERCOT RPG Submittal
September 15, 2023



Table of Contents

Executive Summary 3

Purpose and Necessity 3

 Steady-State Analysis 4

 Dynamic Analysis 5

 Subsynchronous Resonance (SSR) Screening 5

 Short-Circuit Study 5

Project Description 7

One-Line Diagram 7

Alternative Solution Considered 9

Project Cost 9

Recommendation 10

Executive Summary

Oncor Electric Delivery Company LLC (Oncor) proposes a Tier 1 project (Proposed RPG Project) which will consist of the following system upgrades:

1. Install 350 MVAR of Synchronous Condenser capacity at Reiter 345 kV Switch.
2. Install 350 MVAR of Synchronous Condenser capacity at Tonkawa 345 kV Switch.

Oncor has studied the additional synchronous support in West Texas proposed by ERCOT and believes this project will add synchronous support to West Texas, the need for which was previously identified by ERCOT

ERCOT's *Assessment of Synchronous Condensers to Strengthen the West Texas System* study identified solutions to address grid reliability issues related to Inverter Based Resources (IBRs) connected in West Texas. These IBR resources are sensitive to system fault disturbances which can result in regional instability. To address these concerns, ERCOT has proposed the addition of synchronous condensers at six 345 kV substations in West Texas: Cottonwood, Bearkat, Tonkawa, Long Draw, Reiter, and Bakersfield. The ERCOT study stipulates that the synchronous condensers at each site should meet the following specifications:

- Approximately 350 MVAR capacity at each location
- Around 3,600 Ampere (A) of three-phase fault current contribution to the 345 kV point of interconnection (POI)
- A combined total inertia of 2,000 MW-seconds (MW-s) or above at each location, provided by a flywheel incorporated into the synchronous condenser
- Effective damping control sufficient to meet the ERCOT damping criteria in the Planning Guide Section 4.1.1.6.

Oncor proposed to install synchronous condensers at Reiter and Tonkawa 345 kV stations to meet or exceed the ERCOT specification with a targeted in-service date of May 2027. The synchronous condensers will meet the ERCOT damping criteria in the Planning Guide Section 4.1.1.6. based on Oncor's study of ERCOT system conditions as reflected in the latest DWG cases. Based on information available from vendors at this time, a preliminary cost estimate for the synchronous condensers is \$280 M. This cost is subject to change based on actual bids on the machines after project commencement.

Purpose and Necessity

ERCOT has identified the need for additional synchronous support in West Texas. The May 9, 2021 Odessa area disturbance has shown that IBRs are sensitive to system events. ERCOT has identified synchronous condensers such as those in this proposed project as machines that will offer needed support to the system. Specifically, these machines will provide reactive support, short circuit contribution, and system inertia, with the short circuit and inertia attributes being unique to rotating machines like the proposed synchronous condensers. The ERCOT study provided recommended machine specifications and locations as follows:

- Six locations: Cottonwood, Bearkat, Tonkawa, Long Draw, Reiter, and Bakersfield 345 kV substations
- Approximately 350 MVar capacity at each location
- Around 3,600 Ampere (A) of three-phase fault current contribution to the 345 kV point of interconnection (POI)
- A combined total inertia of 2,000 MW-seconds (MW-s) or above at each location, incorporating synchronous condenser with flywheel
- Effective damping control to meet the ERCOT damping criteria in the Planning Guide Section 4.1.1.6

In support of this proposal, Oncor conducted steady-state, stability and short-circuit analyses of the system with the six proposed synchronous condensers to validate that there are no concerns introduced by this project, and that the six proposed synchronous condensers meet ERCOT's damping criteria as described in the Planning Guide Section 4.1.1.6. Oncor supports ERCOT's findings in the *Assessment of Synchronous Condensers to Strengthen the West Texas System* study, and the conclusion that the added synchronous condensers will enhance the system stability in West Texas. Two of the six proposed locations are at Oncor facilities: Reiter and Tonkawa. Oncor's proposed transmission facilities would be constructed to meet or exceed the specifications provided by ERCOT.

Steady-State Analysis

Oncor studied NERC P1 through P7 contingencies using the SSWG cases published on October 10, 2022. Study cases included 2025 SUM, 2026 SUM, 2026 HWLL and 2027 SUM. Each of these cases had two versions, one with all six added synchronous condensers and one without the added synchronous condensers to properly identify the effects of the new equipment

case by case. The steady-state analysis indicated that no new planning criteria violations were found.

Dynamic Analysis

In addition to ERCOT's dynamic analysis outlined in ERCOT's *Assessment of Synchronous Condensers to Strengthen the West Texas System* study, Oncor performed a dynamic analysis based on the NERC and ERCOT planning criteria with selected high-impact contingencies from P1 through P7. Oncor used the latest DWG cases SUM2025 and HWLL2026 published May 2023 with area topology converted to a node-breaker model arrangement to facilitate accurate contingency simulations. Oncor used a representative synchronous condenser model that meets ERCOT's specifications at the Reiter and Tonkawa locations. The proposed synchronous condensers from other TSPs located at Cottonwood, Bearkat, Long Draw, and Bakersfield 345 kV substations were added to the study cases as well. No instances of instability were observed resulting from the addition of this project, and the ERCOT damping criteria in the Planning Guide Section 4.1.1.6 was met.

Sub-synchronous Resonance (SSR) Screening

The proposed synchronous condenser at Tonkawa Switch was identified in ERCOT's screening for potential SSR. Oncor will be working with the equipment vendor to assess any SSR concerns and implement any necessary mitigations. The ERCOT study indicated that Reiter was not considered to be potentially vulnerable to SSO.

Short-Circuit Study

Oncor evaluated the short-circuit impacts of the Proposed RPG Project using the System Protection Working Group (SPWG) case "22_SPWG_2024_FY_06302022_FINAL". The SPWG case was modified to include changes associated with the Proposed RPG Project, as well as other Oncor system changes that occurred since the development of the SPWG case. The studies included a number of future projects addressing the transmission system upgrades in West Texas over the next 4-5 years. As a result of these system changes, Oncor identified several circuit breakers that will be over-dutied by 2027. The cost to upgrade these breakers is not factored into this submittal. The increase in the fault current will be the result of the sequential upgrades from projects in the area, including the synchronous condensers, and will

be handled according to the construction sequence of these projects. In addition, Oncor will address any additional necessary rating changes as they are identified in its annual short circuit assessment.

Project Description

ERCOT proposed adding synchronous condensers at six sites across West Texas in addition to the existing synchronous condensers at Alibates and Tule Canyon.




Figure 1: Synchronous Condensers Locations

Oncor is proposing to build 350 MVA synchronous condenser capacity at Reiter and Tonkawa. These machines will have the combined capacity to meet the needs identified by ERCOT's studies. Bays inside the existing 345 kV Tonkawa Switch and 345 kV Reiter Switch breaker-and-one-half stations will be utilized to connect the synchronous condensers.

Project Simplified One-Line Diagram




Figure 2. Reiter Switch Project Simplified One-line




Figure 3. Tonkawa Switch Project Simplified One-line

Alternative Solutions Considered

No alternative equipment solutions were considered for this RPG submittal as ERCOT has explicitly recommended synchronous condenser technology. Oncor has utilized ERCOT's recommended MVAR output, short circuit contribution, inertia contribution, and damping control for the proposed project.

Project Cost

Oncor has budgetary pricing for 350 MVAR synchronous condensers at Reiter and Tonkawa with an expected in-service date of May 2027. Oncor is evaluating multiple vendors to source the synchronous condensers and evaluating their ability to meet the given specifications. Table 1 below shows preliminary pricing. The equipment price listed is based upon budgetary pricing information from the vendors and is subject to change upon selecting a vendor.

Proposed RPG Project	
Component	Project Costs (Millions)
	Equipment Cost
Oncor Reiter 345 kV Switch, - 350 MVar Synchronous Condenser	\$140.0
Oncor Tonkawa 345 kV Switch, 350 MVar Synchronous Condenser	\$140.0
Total:	\$280.0

Table 1. Proposed RPG Project Cost Summary

Recommendation

Oncor recommends this RPG project to add synchronous support to West Texas, the need for which was previously identified by ERCOT. The equipment chosen will meet the specifications proposed by ERCOT.

Wind Energy Transmission Texas (WETT)
Synchronous Condensers
ERCOT Regional Planning Group Submittal

September 01, 2023

Wind Energy Transmission Texas (WETT)

WIND ENERGY TRANSMISSION TEXAS, LLC
WETT

1. Executive Summary

Wind Energy Transmission Texas, LLC (“WETT”) is submitting the proposed synchronous condenser addition project to the Regional Planning Group for review and comment. Pursuant to ERCOT Protocol 3.11.4.3 this project will be categorized as a Tier 1 Project.

Odessa low voltage disturbances in 2021 and 2022 caused by single line to ground events led to substantial reduction in output from inverter-based resources (IBRs) located far away from the fault locations. In response to these disturbances, ERCOT performed a study¹ (referred as “Study” hereafter) to evaluate the benefits of synchronous condensers to strengthen the system in the West Texas (WTX) region and address the operational challenges caused by high IBRs penetrations in weak systems. The Study concluded that new synchronous condensers at the six locations (Figure 1) with a total of 2,100 MVA will improve the reliability and resilience of the West Texas system. The 345 kV substations at Cottonwood, Bearkat, Tonkawa, Long Draw, Reiter, and Bakersfield were identified as effective locations for the installation of synchronous condensers. Three out of six 345 kV substations, i.e. Cottonwood, Bearkat, and Long Draw, are WETT’s facilities.




Figure 1: Recommended Locations for Synchronous Condensers in West Texas

WETT recommends adding synchronous condensers at the locations identified in the ERCOT study. Specifically, WETT will install synchronous condensers (350 MVA each) connected to

¹ <https://www.ercot.com/files/docs/2023/06/27/Assessment-of-Synchronous-Condensers-to-Strengthen-West-Texas-System.pdf>

Cottonwood, Bearkat, and Long Draw 345 kV substations (referred as “Project” hereafter) no later than October 2027. The in-service date may change based on several factors, including environmental assessments, licensing requests, regulatory approval, land acquisitions, supply chain constraints and/or construction process.

We request that this Project be designated as critical to the reliability of the ERCOT system, based on ERCOT’s study findings that installing synchronous condensers at identified locations will enhance the system reliability and resilience in the West Texas region, and minimize the unexpected IBRs generation losses like the 2021 and 2022 Odessa events.

The cost estimate for the Project is \$467.7M. Cost estimates provided within this submittal are subject to revision as additional information is revealed.

2. Introduction

The performance of IBRs heavily relies on power electronic controls and system strength. In West Texas, the high penetration of Inverter-based resources (IBRs) and absence of conventional synchronous generation resources weaken the system and increase the likelihood of potential instability issues. The West Texas region experienced notable disturbances in 2021 and 2022, specifically the Odessa events, which unexpectedly led to a substantial reduction in power output from IBRs triggered by the widespread propagation of low voltages during single-line-to-ground (SLG) fault conditions. The rapid and continued growth of IBRs in the West Texas system is likely to increase and pose a growing and significant reliability risk to the ERCOT system.

In 2023, ERCOT performed a Study to evaluate the benefits of synchronous condensers to strengthen the system in the West Texas region and address the operational challenges caused by high IBRs penetrations in weak systems. The Study concluded that new synchronous condensers at the six locations (Figure 1) with a total of 2,100 MVA will improve the reliability and resilience of the West Texas system. The 345 kV substations at Cottonwood, Bearkat, Tonkawa, Long Draw, Reiter, and Bakersfield were identified as effective locations for the installation of synchronous condensers. Three out of six 345 kV substations, i.e. Cottonwood, Bearkat, and Long Draw, are WETT’s facilities.

3. Project Scope, Cost and Schedule

Project Scope

The ERCOT Study identified six 345 kV substations in the West Texas region as effective locations for the installation of synchronous condensers to enhance system reliability and resilience. WETT owns three of them, i.e., Cottonwood, Bearkat, and Long Draw 345 kV substations. To meet the technical specifications for the condensers recommended in ERCOT Study, WETT will install two 175 MVA synchronous condensers at each of WETT’s Cottonwood, Bearkat, and Long Draw 345 kV substations, as shown in Figure 2.




Figure 2: New Synchronous Condensers at Cottonwood, Bearkat, and Long Draw

The synchronous condensers to be installed will meet the following specifications, per the Study and discussions between ERCOT and WETT:

- Approximately 350 MVar capacity (two 175 MVA condensers) at each location.
- Around 3,600 Ampere (A) of three-phase fault current contribution.
- A total inertia of 2,000 MW-seconds or above at each location, install flywheel if necessary.

All substation equipment at Cottonwood, Bearkat, and Long Draw 345 kV substations connected in series with the new synchronous condensers shall have a minimum continuous rating of 5,000 A and short circuit rating of 63 kA.

Project Cost and Schedule

The cost estimate for the Project is \$467.7M. WETT plans to put all three condensers in-service no later than October 2027. Please be aware that cost estimates provided within this submittal are subject to revision as additional information is revealed. The in-service date may change based on several factors, including environmental assessments, licensing requests, regulatory approval, land acquisitions, supply chain constraints and/or construction process. Table 1 summarizes the Project cost and schedule.

Table 1: Cost Estimates and Schedule for WETT Synchronous Condensers Addition

Scope	Cost	In-Service Date
Two 175 MVA Sync. Condensers at Long Draw	\$156.9M	October 2027
Two 175 MVA Sync. Condensers at Bearkat	\$155.2M	October 2027
Two 175 MVA Sync. Condensers at Cottonwood	\$155.6M	October 2027

4. System Impact Analysis

ERCOT performed a comprehensive and robust study to evaluate the impact of synchronous condensers on the ERCOT system, including system strength analysis, voltage dip analysis, and dynamic stability analysis. The ERCOT Study also concluded that there is no need to perform Generation Addition Sensitivity Analysis or Load Scaling Sensitivity Analysis. In addition to the analysis performed by ERCOT, the system impact analysis performed by WETT includes the following:

Power Flow Analysis

WETT conducted a power flow analysis to evaluate the impact of WETT Synchronous Condenser Addition Project using the ERCOT SSWG 2027 Summer Peak and HRML cases published in June 2023 on selected critical contingencies covering P1 through P7 and extreme events. The study results show that the Project has minimum impact on power flows and doesn't cause any new thermal violations.

Short Circuit Analysis

WETT conducted a Short Circuit Analysis to assess the impact of WETT Synchronous Condenser Addition Project using the ERCOT SPWG future year 2027 short circuit case. Based on the results of this analysis, the maximum fault duty experienced by the surrounding 345-kV substations will be 30 kA. All existing circuit breakers are rated at 63 kA, and no appreciable increase to the available fault duty will be realized by this project. Therefore, the synchronous condenser additions do not cause the need to upgrade any existing equipment for short circuit reasons.

Dynamic Stability Analysis

WETT conducted a dynamic stability analysis to evaluate the impact of WETT Synchronous Condenser Addition Project using the ERCOT DWG 2026 HWLL cases published in March 2023 on selected critical contingencies covering P1 through P7 and extreme events. Based on the results of this analysis, WETT Synchronous Condenser Addition Project is not expected to worsen system stability in this portion of the system and no new stability criteria violations were observed with the new system elements in place.

Sub-Synchronous Oscillation (SSO) Assessment

WETT will coordinate with ERCOT to perform and complete a detailed SSO assessment and provide any mitigation plan, if required, prior to the energization of the synchronous condensers.

5. Alternatives Evaluated

ERCOT considered adding synchronous condensers in the WTX region as the only transmission upgrade option because the installation of synchronous condensers can provide

the necessary characteristics for supporting the reliable operation of a system with a high penetration of IBRs.

ERCOT performed system strength analysis to determine the best location for the synchronous condensers, including all individual 345 kV buses in the West Texas region and concluded that the proposed locations exhibited a high relative ranking compared to other locations in terms of average WSCMVA in the WTX region. Synchronous condensers at the identified locations will provide a significant improvement in system responses for critical faults, even under stressed system conditions, as demonstrated by the results of the voltage dip and stability simulations included in ERCOT's Study.

WETT believes that the locations identified by ERCOT are effective locations for the installation of a synchronous condenser, as they are strategically placed to ensure optimal distribution of reactive power support across the WTX region. As a result, no other alternatives are being considered as this evaluation was robustly conducted as part of the ERCOT Study.

6. Conclusion

In concurrence with ERCOT's Assessment of Synchronous Condensers, WETT is proposing the installation of two 175 MVA synchronous condensers (a total of six 175 MVA synchronous condensers) at Cottonwood, Bearkat, and Long Draw 345 kV substations to improve and maintain reliable operation of the West Texas ERCOT system.