



Filing Receipt

Filing Date - 2024-02-08 11:53:58 AM

Control Number - 56005

Item Number - 2

Service Quality Report
To The
Public Utility Commission of Texas
In Accordance With
Substantive Rule §25.81
2023 Reporting Year

AEP Texas Inc.

Project 56005

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

System SAIFI	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced													
2023	1.242	0.086	0.053	0.163	0.131	0.153	0.137	0.073	0.111	0.095	0.102	0.058	0.080
Scheduled													
2023	0.109	0.010	0.010	0.018	0.011	0.012	0.007	0.009	0.008	0.006	0.005	0.006	0.006
Outside Causes													
2023	0.166	0.003	0.006	0.012	0.025	0.011	0.011	0.019	0.007	0.020	0.022	0.021	0.008
Major Events													
2023	0.361			0.026	0.230	0.052	0.016		0.038				

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

System SAIDI		Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced														
2023		147.14	8.03	6.44	20.72	17.91	21.82	15.35	7.16	11.70	13.24	10.10	6.47	8.20
Scheduled														
2023		10.87	1.17	1.30	1.33	1.00	1.06	0.91	0.61	0.83	0.65	0.52	0.59	0.89
Outside Causes														
2023		9.75	0.38	0.54	0.81	1.44	0.65	1.04	0.80	0.54	0.77	0.66	1.82	0.31
Major Events														
2023		193.55			4.36	158.06	15.79	8.30		7.05				

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

Total Number of Feeders

With 10 or more Customers

1313

Add or Delete Rows as Necessary

AEP Texas Inc.

2023 SAIFI Ranking	2022 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIFI Value
1	348	BEEVILLE	94CN300	1685	8.455
2	492	SA GRAPE CREEK	97SA4700	753	7.068
3	5	LULING - LCRA	94CN10	468	6.951
4	77	O_CONNER	94CN390	200	6.335
5	1066	KLEBERG	94CS280	1307	6.232
6	129	GANADO	94CN5795	487	5.776
7	244	HOLLY	94CS7620	2824	5.533
8	67	PLASTERCO (MWEC)	97AB2720	114	5.316
9	315	PLEASANTON	94LA120	1248	5.311
10	177	SOUTH SANTA ROSA	94SB1235	656	5.168
11	560	GOVERNMENT WELLS	94LA7240	232	5.159
12	50	HALL ACRES ROAD	94SB5585	1643	5.076
13	344	BROWNSVILLE	94SB4290	491	5.020
14	687	WEST MCALLEN	94SB4555	1632	5.007
15	801	CARANCAHUA	94CN1875	61	4.984
16	424	EDROY	94CS6980	196	4.934
17	202	FREER	94LA1500	207	4.792
18	590	EDROY	94CS6990	290	4.783
19	558	SARAGOSA	97SA14080	28	4.714
20	1131	NORTH MCALLEN	94SB4995	2477	4.631
21	275	PREMONT	94LA6610	838	4.601
22	103	GANADO	94CN5815	600	4.547
23	361	WOODSON OIL FIELD	97AB30	32	4.500
24	28	MOORE FIELD	94SB3120	156	4.494
25	475	SOUTHSIDE	94CS7905	1826	4.480
26	744	PHARAOH	94CS1185	1403	4.474
27	581	VALENTINE	97SA6325	585	4.436
28	343	GOODWIN	94SB4390	423	4.364
29	1270	AB MAPLE ST	97AB5755	1304	4.360
30	1112	NORTH MCALLEN	94SB9640	1533	4.296
31	514	THROCKMORTON	97AB3190	632	4.245
32	235	WEST OSO	94CS9085	936	4.241
33	1063	NORTH MCALLEN	94SB9660	2174	4.172
34	1110	BAIRD	97AB5120	558	4.170
35	852	PALMVIEW	94SB7595	3208	4.149
36	755	HOMEPORT	94CS4665	432	4.125
37	34	PORT ISABEL S.S.	94SB9295	1577	4.119
38	554	PHARR	94SB1645	1741	4.098
39	508	AB RAINEY CREEK	97AB4550	983	4.041
40	298	MCCAMEY	97SA2420	82	4.037
41	511	ROBSTOWN	94CS1650	353	4.011

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIFI Ranking	2022 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIFI Value
42	808	ASPR CONTINENTAL	97AB4800	32	4.000
43	188	MATTHEWS	94CN1740	160	3.988
44	131	CROSS PLAINS	97AB2915	786	3.985
45	395	CARRIZO SPRINGS	94LA750	607	3.954
46	741	HALL ACRES ROAD	94SB3670	1330	3.949
47	179	CLARKWOOD	94CS7230	623	3.939
48	731	PORTLAND	94CS6505	1843	3.887
49	565	POLK AVENUE	94SB4740	1707	3.858
50	260	LA PRYOR	94LA570	168	3.833
51	291	MALONE	94CN7560	59	3.831
52	326	CRESTONIO	94LA260	1767	3.825
53	426	PHARAOH	94CS5175	1277	3.817
54	501	PHARAOH	94CS5185	1231	3.813
55	418	FULTON	94CS9050	1624	3.804
56	379	MAVERICK	94LA9680	860	3.738
57	580	MCCOLL ROAD	94SB4910	337	3.700
58	430	KINGSVILLE	94CS1130	2226	3.699
59	385	TUSCOLA	97AB3730	1204	3.691
60	320	BLESSING	94CN1030	286	3.685
61	409	LYTLE	94LA2850	754	3.682
62	25	NORTH PADRE ISLAND	94CS720	1455	3.664
63	694	ARCADIA	94CS1400	443	3.609
64	264	COFFEE PORT	94SB1095	1087	3.587
65	286	EAST HARRISON	94SB3950	810	3.560
66	1065	SOUTH MCALLEN	94SB3850	1370	3.545
67	319	CONOCO-CHITTAM RANCH	94LA8580	26	3.538
68	416	LULING - LCRA	94CN20	272	3.537
69	1047	MESQUITE	94SB8340	836	3.467
70	877	MOORE FIELD	94SB3110	728	3.464
71	913	HOLCOMB	94LA2240	463	3.441
72	211	WADSWORTH	94CN8630	689	3.403
73	160	PORTLAND	94CS9290	1796	3.396
74	568	GRAYBACK	97AB3315	46	3.391
75	27	CHERRY CREEK TAP	97SA485	50	3.380
76	659	RANDADO	94LA8350	135	3.363
77	#N/A	GONZALES	97SA9650	271	3.358
78	68	MATHIS	94CS2870	876	3.349
79	37	CHARLOTTE	94LA2780	35	3.343
80	49	WEIL TRACT (138/12KV)	94CS5405	185	3.335
81	265	BRUNI	94LA1120	273	3.319
82	455	HEARN ROAD	94CS8980	1239	3.316
83	620	BLACK BAYOU	94CN1120	366	3.295
84	156	BEEVILLE	94CN8090	1400	3.280
85	1095	GOVERNMENT WELLS	94LA7250	570	3.267
86	73	CABANISS	94CS75	2251	3.247
87	100	HASKELL 12KV	97AB3495	807	3.245

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIFI Ranking	2022 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIFI Value
88	443	PLEASANTON	94LA9475	1378	3.239
89	1017	BUSH KNOB	97AB5200	309	3.233
90	207	PORTLAND	94CS9370	2108	3.184
91	935	POLK AVENUE	94SB4520	1072	3.180
92	523	ANSON 12KV	97AB6635	401	3.175
93	105	MORRIS STREET	94CS7625	496	3.171
94	65	PECOS VALLEY	97SA4080	228	3.171
95	214	HOLLY	94CS7740	2210	3.170
96	1252	MATADOR	97AB3090	315	3.156
97	615	AB ELM CREEK	97AB1820	100	3.150
98	449	PHARAOH	94CS1365	683	3.149
99	489	LANTANA	94CS7150	273	3.147
100	375	BROWNSVILLE	94SB4280	332	3.145
101	832	DARST	94CN1845	186	3.134
102	765	WESLACO UNIT	94SB8610	1188	3.126
103	614	PLEASANTON	94LA2080	1746	3.115
104	889	ELSA	94SB690	2439	3.114
105	779	GOVERNMENT WELLS	94LA6800	231	3.108
106	437	ELSA	94SB710	2463	3.108
107	325	CRYSTAL CITY	94LA8380	1340	3.104
108	538	MORRIS STREET	94CS7465	789	3.090
109	948	MILO	94LA3060	126	3.087
110	588	ANSON 12KV	97AB6630	717	3.086
111	439	HIGHWAY 9	94CS7200	645	3.073
112	7	RIO PECOS	97SA3835	98	3.071
113	215	AIRLINE	94CS7280	645	3.060
114	35	SOUTH PADRE ISLAND	94SB4695	1399	3.056
115	140	TATTON	94CS950	598	3.047
116	1303	ASPR CONTINENTAL	97AB3830	27	3.037
117	8	GREGORY	94CS5900	119	3.034
118	218	KEMPER EXXON HUMBLE	97SA72103	26	3.000
119	201	RAYMONDVILLE #1	94SB630	788	3.000
120	21	LOS FRESNOS	94SB4315	1340	2.993
121	432	THROCKMORTON	97AB2090	75	2.973
122	621	STAFFORD HILL	94CN1550	147	2.952
123	262	BEEVILLE	94CN1760	1845	2.932
124	185	RIO BRAVO	94LA5	733	2.891
125	146	PREMONT	94LA6570	822	2.881
126	696	REFUGIO	94CN1210	190	2.879
127	111	HIGHWAY 9	94CS7210	349	2.871
128	826	WEST MCALLEN	94SB4535	3065	2.858
129	75	LIVE OAK	94CS1080	2614	2.841
130	1088	GILA	94CS345	68	2.824
131	97	CLARKWOOD	94CS5525	629	2.819
132	232	PALACIOS	94CN8550	84	2.750
133	602	HAINE DRIVE	94SB8065	1402	2.748

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIFI Ranking	2022 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIFI Value
134	57	FT CHADBOURNE	97SA6515	90	2.744
135	269	PALMVIEW	94SB3930	1166	2.741
136	94	MATHIS	94CS340	1423	2.727
137	865	WESLACO UNIT	94SB9805	2299	2.718
138	155	HEARN ROAD	94CS8990	1428	2.697
139	404	WEST MCALLEN	94SB4505	1898	2.697
140	1122	VALADEZ	94CS2500	2578	2.688
141	402	GARCENO	94SB2130	1811	2.686
142	1041	SARAGOSA	97SA1552	778	2.680
143	367	UVALDE	94LA550	741	2.667
144	654	NORTH PADRE ISLAND	94CS1010	2409	2.664
145	512	SOUTH EAST EDINBURG	94SB5045	1831	2.640
146	717	MAGRUDER	94CN6690	750	2.620
147	997	SOUTH MCALLEN	94SB3790	1459	2.613
148	464	PALACIOS	94CN6840	1535	2.610
149	281	ASPHALT MINES	94LA500	43	2.605
150	1204	RAYMONDVILLE #2	94SB4160	326	2.601
151	1011	MORRIS STREET	94CS8840	735	2.570
152	928	EL CAMPO	94CN7260	531	2.561
153	294	GREENLAKE	94CN2740	382	2.555
154	3	BERCLAIR	94CN990	26	2.538
155	39	GREGORY	94CS8560	254	2.528
156	382	LAGUNA	94CS9065	2367	2.501
157	84	PARKER	94CN9010	22	2.500
158	688	CAMPWOOD	94LA3430	129	2.488
159	106	PALMHURST	94SB3890	1864	2.483
160	547	AB EAST 12KV	97AB4820	1118	2.480
161	193	FULTON	94CS2020	3614	2.478
162	653	CEDAR GAP (TEC)	97AB4115	974	2.467
163	625	DARST	94CN1610	68	2.456
164	1269	QUINTANA	94CNT001Y8	55	2.455
165	471	CASA BLANCA	94CS1300	285	2.449
166	123	SEAWALL	94CS9325	1595	2.444
167	650	EL GATO	94SB890	3102	2.437
168	490	BEEVILLE	94CN2200	719	2.426
169	1249	LA PRYOR	94LA1835	271	2.421
170	101	MALONE	94CN7550	234	2.415
171	807	CHARLOTTE	94LA1960	498	2.414
172	543	THREE RIVERS	94CN5100	76	2.408
173	167	MCKENZIE ROAD	94CS140	303	2.403
174	90	EL CAMPO	94CN2800	837	2.401
175	777	CRESTONIO	94LA6660	782	2.395
176	184	POLK AVENUE	94SB4190	1747	2.394
177	977	CLARKWOOD	94CS2170	808	2.394
178	1280	STERLING CITY	97SA11040	547	2.389
179	280	RISING STAR	97AB5080	615	2.380

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIFI Ranking	2022 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIFI Value
180	148	BEEVILLE	94CN8510	814	2.380
181	861	WAGGONER	97AB5900	27	2.370
182	23	POLK AVENUE	94SB4900	1919	2.369
183	974	ROMA	94SB3070	904	2.362
184	727	HAINE DRIVE	94SB270	1181	2.359
185	144	GARWOOD CITY	94CN2570	144	2.354
186	458	NAVAL BASE	94CS8540	1639	2.348
187	952	ESCONDIDO	94LA5730	2802	2.339
188	837	MORAN	97AB2108	306	2.337
189	335	PALACIOS	94CN6830	826	2.335
190	1254	BRONTE	97SA4160	224	2.335
191	633	KARNES CITY	94CN2315	1019	2.328
192	288	CITRUS CITY	94SB5070	1071	2.324
193	22	NORTH ALAMO	94SB4370	1664	2.324
194	63	HIGHWAY 9	94CS6770	940	2.321
195	282	SANTA ANNA	97SA3415	340	2.321
196	678	CRYSTAL CITY	94LA1425	1190	2.316
197	673	POLK AVENUE	94SB4180	1309	2.315
198	834	CLARKWOOD	94CS7610	103	2.311
199	307	BIG OAK	94CN420	344	2.308
200	410	EAST HARRISON	94SB3080	485	2.307
201	896	SOUTH PADRE ISLAND	94SB6440	2602	2.307
202	763	BRUNI	94LA1100	588	2.303
203	20	PLACEDO	94CN7980	415	2.270
204	460	CHRISTOVAL	97SA6620	647	2.264
205	172	PLEASANTON	94LA9505	1822	2.259
206	949	EDNA	94CN5775	503	2.249
207	1077	ROCKSPRINGS	94LA2600	354	2.223
208	509	BROOKHOLLOW	94CN8950	923	2.222
209	336	SAN YGNACIO	94LA16060	538	2.219
210	53	TATTON	94CN8490	291	2.216
211	1022	UVALDE	94LA9770	1132	2.214
212	238	GARWOOD CITY	94CN2560	198	2.212
213	1026	AB COUNTRY CLUB	97AB4855	938	2.205
214	18	RANDADO	94LA8360	168	2.202
215	665	RODD FIELD	94CS1730	2217	2.198
216	809	READING	94LA1275	78	2.192
217	709	AMISTAD DAM	94LA5450	786	2.182
218	791	ALPINE 12KV	97SA3155	1630	2.182
219	1123	MCCOLL ROAD	94SB2810	2311	2.180
220	198	LIVE OAK	94CS1070	2625	2.178
221	504	LIVE OAK	94CS1090	306	2.176
222	258	CLARKWOOD	94CS7220	929	2.175
223	960	SHARYLAND	94SB5635	2325	2.175
224	391	HARLINGEN SWITCH	94SB4230	1357	2.167
225	249	POLK AVENUE	94SB4170	1479	2.162

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIFI Ranking	2022 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIFI Value
226	209	BULLMOOSE	94CS4185	19	2.158
227	583	MAYBERRY	94SB1790	2662	2.158
228	356	FALFURRIAS	94LA2830	1532	2.155
229	26	WEST HARLINGEN	94SB3720	1314	2.145
230	1218	MORRIS STREET	94CS8850	396	2.144
231	314	WESMER	94SB1850	474	2.133
232	241	PHARR	94SB1640	1462	2.120
233	1125	LA GRULLA	94SB6150	1629	2.117
234	1264	SOUTH MCALLEN	94SB3640	196	2.112
235	338	BROOKHOLLOW	94CN7580	507	2.108
236	394	FLOMOT	97AB1852	76	2.105
237	24	NAVAL BASE	94CS7950	814	2.086
238	98	BANQUETTE	94CS9000	462	2.078
239	1139	QUANAH	97AB3530	333	2.075
240	102	HARLINGEN SWITCH	94SB320	1747	2.073
241	415	MORRIS STREET	94CS5655	314	2.070
242	10	PICACHO	94LA630	396	2.063
243	1175	AB MAPLE ST	97AB4070	1052	2.056
244	806	WINTERS	97SA3765	805	2.056
245	1183	SA AVENUE N	97SA1655	485	2.056
246	196	LOS FRESNOS	94SB2160	1944	2.053
247	697	AIRLINE	94CS8370	271	2.048
248	95	PALMVIEW	94SB6790	2648	2.040
249	1007	PORT ARANSAS	94CS3030	978	2.038
250	797	SHARYLAND	94SB5105	2073	2.037
251	117	LOS FRESNOS	94SB7270	2432	2.030
252	578	KLEBERG	94CS6410	252	2.024
253	113	NORTH WESLACO	94SB4810	1558	2.021
254	121	UNITEC	94LA3085	113	2.018
255	591	ELDORADO	97SA5310	188	2.016
256	390	VILLA CAVAZOS	94SB7615	1123	2.010
257	183	NORTH PADRE ISLAND	94CS5170	875	2.007
258	388	LOLITA	94CN6330	30	2.000
259	624	BULLMOOSE	94CS5875	66	2.000
260	0	RIO PECOS	97SA513	10	2.000
261	1160	RODD FIELD	94CS2190	98	2.000
262	138	CRESTONIO	94LA270	648	1.998
263	1090	ENCINAL	94LA2160	238	1.975
264	780	PORTLAND	94CS9270	1853	1.974
265	689	MESQUITE	94SB2900	950	1.973
266	442	WASHINGTON STREET	94LA6525	2736	1.970
267	407	PUEBLO	94LA9870	1774	1.967
268	82	RAYMONDVILLE #2	94SB3250	28	1.964
269	747	ALPINE 12KV	97SA6825	1557	1.961
270	810	NORTH VICTORIA	94CN7440	1660	1.949
271	400	ARANSAS PASS	94CS590	465	1.944

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIFI Ranking	2022 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIFI Value
272	137	MAYO	94CS625	205	1.941
273	526	LA GRULLA	94SB5005	1244	1.936
274	69	MESQUITE	94SB3360	1025	1.931
275	366	BRUNI	94LA5440	118	1.924
276	675	SOUTH MCALLEN	94SB5065	184	1.918
277	200	YORKTOWN	94CN8380	784	1.904
278	306	MAGNOLIA	94CN315	83	1.904
279	850	BLACK CAT	94CN4525	122	1.902
280	506	RIO GRANDE CITY	94SB3740	2397	1.902
281	499	NORTH EDINBURG	94SB560	2222	1.899
282	243	VILLA CAVAZOS	94SB1980	1851	1.898
283	180	EAGLE LAKE	94CN9455	615	1.888
284	715	MORRIS STREET	94CS8715	1569	1.885
285	676	ARANSAS PASS	94CS1250	668	1.880
286	62	HIGHWAY 9	94CS6760	1034	1.876
287	431	CONTINENTAL	94SB4880	72	1.875
288	29	ASHERTON	94LA4175	68	1.868
289	584	AB ELM CREEK	97AB1815	491	1.857
290	364	WEST OSO	94CS9090	1675	1.848
291	520	HOLCOMB	94LA3025	379	1.847
292	165	INDIAN MESA	97SA2695	90	1.844
293	771	PALMVIEW	94SB9685	2967	1.844
294	901	LAREDO PLANT	94LA8565	1458	1.844
295	134	UVALDE	94LA540	1962	1.841
296	9	MATHIS	94CS1410	468	1.840
297	71	CABANISS	94CS240	1401	1.839
298	1058	ROARING SPRINGS	97AB6155	30	1.833
299	874	MEDIO CREEK	94CN1380	800	1.833
300	1259	SA SOUTH	97SA3990	762	1.815
301	163	RIO RICO	94SB8290	335	1.812
302	327	PHARAOH	94CS1285	1779	1.811
303	695	BLESSING	94CN8790	771	1.804
304	980	YELLOW JACKET	97SA7935	796	1.802
305	173	ARCADIA	94CS1440	1659	1.791
306	986	ROARING SPRINGS	97AB2065	217	1.783
307	#N/A	MINES ROAD	94LA3680	316	1.772
308	406	BEEVILLE	94CN490	945	1.766
309	822	HIGHWAY 9	94CS6780	752	1.758
310	967	TANKERSLY (CVEC)	97SA5260	481	1.755
311	1037	SAN BENITO	94SB3860	255	1.741
312	725	PREMONT	94LA2720	761	1.728
313	452	CAUSEWAY	94SB4795	372	1.723
314	270	RIO GRANDE CITY	94SB3230	2699	1.720
315	868	KLEBERG	94CS6000	1381	1.718
316	363	DEVINE	94LA7100	1018	1.711
317	637	AB COUNTRY CLUB	97AB4725	236	1.703

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIFI Ranking	2022 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIFI Value
318	782	EAGLE LAKE	94CN320	623	1.690
319	617	CITRUS CITY	94SB3470	1809	1.682
320	1029	MAYO	94CS500	25	1.680
321	119	MCCAMEY	97SA2415	79	1.658
322	312	PROGRESO	94SB2545	89	1.652
323	239	BLACK CAT	94CN3175	502	1.637
324	17	BAY CITY	94CN6670	1624	1.635
325	19	INGLESIDE CITY	94CS8050	1287	1.632
326	830	RESACA	94SB7110	1738	1.625
327	943	KARNES CITY	94CN2325	668	1.624
328	990	KITTIE WEST	94CN3765	323	1.619
329	1304	ABILENE INDUSTRIAL PARK	97AB6600	13	1.615
330	488	SAN BENITO	94SB4030	1731	1.614
331	1008	PALMHURST	94SB2535	3204	1.610
332	60	BAY CITY	94CN2700	1064	1.608
333	318	WESMER	94SB7760	1447	1.607
334	277	SARAGOSA	97SA1590	43	1.605
335	354	SOUTHSIDE	94CS8055	853	1.604
336	159	EAGLE LAKE	94CN310	728	1.602
337	658	ALPINE 12KV	97SA3160	1094	1.594
338	786	MOCKINGBIRD	94CN400	1013	1.589
339	181	FASHING	94CN360	34	1.588
340	150	BAY CITY	94CN7480	375	1.587
341	289	OLMITO	94SB715	683	1.581
342	321	BLACK CAT	94CN2960	2190	1.579
343	674	HARLINGEN SWITCH	94SB4090	2332	1.576
344	481	CLOSNER	94SB4100	2138	1.568
345	849	NORTH VICTORIA	94CN2240	744	1.567
346	893	VERNON	97AB1750	253	1.561
347	774	ANNA STREET	94LA900	2813	1.558
348	836	BROOKHOLLOW	94CN8960	602	1.555
349	274	SHROPSHIRE	94CN1240	74	1.554
350	719	COFFEE PORT	94SB1090	1263	1.552
351	527	EDNA	94CN5785	1248	1.550
352	734	GREENLAKE	94CN2750	75	1.547
353	517	BROOKHOLLOW	94CN7190	280	1.546
354	381	SA NORTH	97SA3115	585	1.542
355	839	GRETA	94CN7890	239	1.536
356	362	MAGRUDER	94CN7870	1257	1.535
357	761	SAND CRAB	94CN6735	1324	1.532
358	43	ELSA	94SB3520	1029	1.529
359	414	DEVINE	94LA8100	1635	1.524
360	1035	AB VOGEL ST	97AB4650	802	1.522
361	197	PIRATE	94CS3490	377	1.520
362	433	EL GATO	94SB720	2575	1.515
363	1109	EDNA	94CN5765	1263	1.511

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIFI Ranking	2022 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIFI Value
364	643	MESA VIEW	97SA7045	96	1.510
365	1005	MILO	94LA3065	34	1.500
366	125	TAFT	94CS5230	837	1.498
367	76	NORTH MERCEDES	94SB3770	1913	1.498
368	920	TANKERSLY (CVEC)	97SA5265	373	1.493
369	372	TAFT	94CS1180	950	1.488
370	969	EL CAMPO	94CN6370	790	1.485
371	1003	WASHINGTON STREET	94LA2350	3033	1.480
372	204	MCELROY	97SA5165	94	1.479
373	261	NORTH MCALLEN	94SB3830	1404	1.479
374	83	SUNCHASE	94SB1150	1437	1.477
375	225	DEVINE	94LA7090	1083	1.477
376	166	VICTORIA POWER PLANT	94CN1390	1079	1.473
377	313	SPUDDER FLAT	97SA4175	32	1.469
378	805	SOUTHSIDE	94CS7955	1063	1.465
379	279	PORT ISABEL S.S.	94SB3760	800	1.464
380	162	MCCAMEY	97SA2830	96	1.458
381	1014	EAGLE PASS CITY	94LA2650	1390	1.458
382	988	PROGRESO	94SB2495	1711	1.456
383	723	KITTIE WEST	94CN3760	244	1.455
384	1116	MAYBERRY	94SB3010	342	1.453
385	157	PECAN BAYOU	97AB6815	1874	1.453
386	316	SAND ROAD	97AB5195	257	1.447
387	904	MARKHAM	94CN6440	471	1.446
388	189	GREGORY	94CS5920	870	1.445
389	789	BANDERA ELECTRIC (LEAKEY)	94LAL30	276	1.442
390	664	RUNGE	94CN3250	267	1.438
391	603	DIMMIT	94LA5545	573	1.435
392	359	SOUTHSIDE	94CS7925	1149	1.429
393	47	PHARR	94SB1620	1255	1.426
394	1101	CLYDE	97AB1755	132	1.424
395	465	SAN BENITO	94SB3920	1663	1.414
396	1236	HEINES	94CS3515	1308	1.403
397	1299	SANTA RITA	97SA1135	10	1.400
398	220	WESMER	94SB4480	1151	1.397
399	283	EOLA	97SA4950	207	1.396
400	1053	RAYMONDVILLE #1	94SB620	671	1.395
401	78	EAGLE PASS CITY	94LA2745	942	1.393
402	81	MORRIS STREET	94CS8820	1238	1.389
403	420	PICACHO	94LA590	408	1.387
404	1186	STEAMBOAT	97AB12515	68	1.382
405	510	DEL RIO CITY	94LA420	2054	1.381
406	902	BAY CITY	94CN1110	1243	1.380
407	843	BUENA VISTA	94LA9035	2101	1.376
408	919	CONTINENTAL	94SB4080	67	1.373
409	666	TWILIGHT TRAIL	97AB11500	1025	1.370

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIFI Ranking	2022 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIFI Value
410	733	RAYMONDVILLE #2	94SB3240	925	1.368
411	1241	FLOMOT	97AB81335	30	1.367
412	387	HALL ACRES ROAD	94SB5465	1434	1.362
413	72	JOURDANTON	94LA7880	595	1.361
414	728	GATEWAY	94LA390	2172	1.361
415	434	SAND CRAB	94CN6800	1150	1.360
416	925	SEAWALL	94CS9420	815	1.358
417	419	FREER	94LA5200	1011	1.355
418	1069	SONORA ATLANTIC (SWTEC)	97SA4415	31	1.355
419	154	DEL RIO CITY	94LA430	1775	1.346
420	528	CHILLICOTHE	97AB4530	487	1.343
421	487	INDIAN MESA	97SA2690	146	1.342
422	981	CISCO	97AB7400	839	1.342
423	840	CATARINA	94LA2380	199	1.337
424	845	REFUGIO	94CN5120	721	1.333
425	444	BLACK CAT	94CN3000	1656	1.332
426	389	PANTERA	94SB1765	931	1.331
427	854	HALL ACRES ROAD	94SB4895	883	1.331
428	516	SA LAKE DR	97SA5865	1063	1.327
429	768	HALL ACRES ROAD	94SB3460	3201	1.327
430	1039	QUANAH	97AB3975	212	1.325
431	403	KENEDY	94CN1970	564	1.324
432	1097	MIDWAY LANE	97SA3440	56	1.321
433	613	GATEWAY	94LA3595	1494	1.317
434	903	PUEBLO	94LA130	1789	1.316
435	846	NORTH EDINBURG	94SB4240	1168	1.312
436	276	SA MATHIS FIELD	97SA4790	196	1.311
437	297	SOUTH PADRE ISLAND	94SB5850	1379	1.311
438	1173	SOUTHSIDE	94CS5345	501	1.307
439	292	RODD FIELD	94CS205	2217	1.303
440	677	FREER	94LA2900	166	1.301
441	85	PAWNEE (STEC OWNED)	94CN22202	203	1.300
442	908	HALL ACRES ROAD	94SB9595	1571	1.300
443	856	LA GRULLA	94SB5110	1038	1.298
444	821	SUNCHASE	94SB1155	1448	1.295
445	670	BAY CITY	94CN5960	400	1.293
446	32	SAN BENITO	94SB4135	1398	1.292
447	815	REFUGIO	94CN1040	162	1.290
448	467	SHARYLAND	94SB6745	2349	1.286
449	266	STAMFORD PUMP	97AB3930	39	1.282
450	169	EL GATO	94SB910	2653	1.281
451	579	HOLLY	94CS9675	1633	1.276
452	1045	PRIMERA	94SB7020	1438	1.271
453	128	TYNAN	94CS1855	133	1.271
454	64	THREE RIVERS	94CN8430	194	1.268
455	1113	BALLINGER	97SA4395	528	1.267

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIFI Ranking	2022 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIFI Value
456	1104	LA GRULLA	94SB3045	1357	1.267
457	15	NORTH MERCEDES	94SB4860	1516	1.262
458	45	PREMONT	94LA2730	199	1.256
459	41	PUEBLO	94LA95	1152	1.252
460	1115	AB MAPLE ST	97AB5750	470	1.251
461	168	CALICOATTE	94CS8785	1198	1.250
462	1020	MARKHAM	94CN5550	20	1.250
463	655	HAROLD	97AB1495	24	1.250
464	551	MILO	94LA3070	2009	1.245
465	1275	COLLEGE HILLS	97SA5515	198	1.242
466	515	AFTON	97AB2310	250	1.240
467	300	ELDORADO	97SA2880	369	1.238
468	594	NORTH MCALLEN	94SB2750	3223	1.238
469	940	SKIDMORE	94CS600	371	1.237
470	194	STAFFORD HILL	94CN9955	73	1.233
471	1010	QUANAH	97AB1830	620	1.232
472	1126	BRONTE	97SA3590	194	1.232
473	110	LEARY LANE	94CN1430	1906	1.232
474	378	FT CHADBOURNE	97SA6520	558	1.231
475	337	EL GATO	94SB780	2183	1.229
476	1156	NORTH WESLACO	94SB4830	546	1.229
477	907	WEAVER ROAD	94CN1900	66	1.227
478	1100	HAMLIN	97AB3270	877	1.223
479	86	HIGHWAY 9	94CS6720	1285	1.216
480	1239	AB HARTFORD ST	97AB3820	867	1.212
481	895	HARLINGEN	94SB660	1269	1.212
482	871	OLMITO	94SB905	1666	1.207
483	199	AB SHELTON ST	97AB3660	632	1.204
484	842	MAGRUDER	94CN245	1246	1.201
485	453	SPUDDER FLAT	97SA4180	60	1.200
486	539	AB OVER STREET 12KV	97AB1635	532	1.199
487	226	SOUTH EAST EDINBURG	94SB4550	728	1.199
488	428	CHRISTOVAL	97SA6615	464	1.196
489	332	PECAN BAYOU	97AB6810	492	1.195
490	254	AB WALNUT ST	97AB3785	576	1.194
491	564	WESMER	94SB6900	103	1.194
492	1224	RANKIN	97SA7425	120	1.192
493	250	VICTORIA POWER PLANT	94CN8170	840	1.192
494	368	VICTORIA POWER PLANT	94CN7600	163	1.190
495	355	KINGSVILLE	94CS1660	1966	1.188
496	992	CLOSNER	94SB2945	1111	1.185
497	995	SANTA RITA	97SA1105	49	1.184
498	1073	STAMFORD	97AB6255	424	1.182
499	#N/A	SANTO NINO	94LAT000G8	882	1.180
500	818	EL CAMPO	94CN7710	1060	1.177
501	1084	SOUTH EAST EDINBURG	94SB4570	1920	1.177

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIFI Ranking	2022 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIFI Value
502	738	BUENA VISTA	94LA8965	928	1.173
503	136	HARLINGEN SWITCH	94SB4110	920	1.172
504	708	MATHIS	94CS1420	920	1.172
505	1036	SOUTH PADRE ISLAND	94SB4675	214	1.168
506	441	POWELL FIELD	97SA2529	12	1.167
507	616	HAMLIN SHELL	97AB6330	24	1.167
508	427	WEST OSO	94CS9095	1665	1.165
509	608	AB COUNTRY CLUB	97AB4730	542	1.164
510	866	LAREDO PLANT	94LA8505	1046	1.160
511	223	TURKEY	97AB3825	387	1.155
512	1024	KINGSVILLE	94CS1350	395	1.147
513	542	NORTH MCALLEN	94SB5055	3324	1.147
514	324	MORRIS STREET	94CS2515	1030	1.147
515	118	PAULANN	97SA6280	336	1.146
516	228	UVALDE	94LA5060	673	1.146
517	178	HAINE DRIVE	94SB9690	626	1.145
518	222	MCCOLL ROAD	94SB4790	2079	1.144
519	423	WYLIE	97AB2665	1065	1.143
520	953	AIRLINE	94CS6970	1410	1.143
521	224	COMSTOCK	94LA230	183	1.142
522	386	WESLACO UNIT	94SB7630	2697	1.141
523	474	THOMASTON	94CN9580	50	1.140
524	317	SABINAL	94LA485	501	1.140
525	6	RAYMONDVILLE #2	94SB3170	778	1.139
526	545	CARRIZO SPRINGS	94LA910	876	1.138
527	702	AIRLINE	94CS8260	1412	1.136
528	799	WEST MCALLEN	94SB4515	885	1.136
529	1242	ROCKSPRINGS	94LA8040	326	1.135
530	393	PALMHURST	94SB2820	1866	1.134
531	600	WOODSBORO	94CS8330	302	1.132
532	596	DARST	94CN1265	76	1.132
533	1244	AIRLINE	94CS7270	1035	1.126
534	1284	IRAAN	97SA4305	247	1.126
535	1276	MINES ROAD	94LA3745	2155	1.125
536	497	HAINE DRIVE	94SB3490	1192	1.124
537	1135	POLK AVENUE	94SB4600	162	1.123
538	347	HALL ACRES ROAD	94SB8870	2526	1.119
539	529	LAREDO PLANT	94LA9305	1075	1.117
540	559	WINTERS	97SA2113	792	1.116
541	862	WEAVER ROAD	94CN1910	27	1.111
542	1213	UNITEC	94LA5895	37	1.108
543	259	AB MCMURRY	97AB4355	986	1.108
544	962	SAN BENITO	94SB3910	677	1.106
545	712	MORRIS STREET	94CS8830	1486	1.106
546	619	AB WALNUT ST	97AB3445	57	1.105
547	1086	DEL MAR	94LA10	1760	1.105

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIFI Ranking	2022 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIFI Value
548	328	HIDALGO	94SB3400	880	1.102
549	754	PEARSALL	94LA7050	582	1.101
550	819	RUSSEK STREET	97SA11370	203	1.099
551	480	CLYDE	97AB3630	651	1.098
552	601	AB EAST 12KV	97AB5760	216	1.097
553	1243	HAMLIN	97AB3775	254	1.094
554	1033	TRADE ZONE	94SB2060	515	1.093
555	230	WEST HARLINGEN	94SB4870	1083	1.092
556	946	AB CANYON ROCK	97AB5035	836	1.092
557	936	MUNDAY REA (BKEC)	97AB2015	22	1.091
558	703	SOUTH SANTA ROSA	94SB1240	1723	1.089
559	634	HASKELL 12KV	97AB5240	642	1.086
560	573	AB MCMURRY	97AB4360	1081	1.083
561	255	POLK AVENUE	94SB4610	157	1.083
562	1232	AB ONYX REA	97AB3255	25	1.080
563	190	BEEVILLE	94CN2380	215	1.079
564	1096	SOUTH MISSION	94SB3940	862	1.079
565	661	MAYBERRY	94SB5770	950	1.078
566	1002	RODD FIELD	94CS3010	2065	1.077
567	1177	SA JACKSON ST	97SA4685	1451	1.076
568	587	AB OVER STREET 12KV	97AB3140	741	1.076
569	1189	BENTSEN	94SB5H215	56	1.071
570	61	VALENTINE	97SA5590	211	1.071
571	521	HOLLY	94CS5820	900	1.068
572	657	MCCAMEY	97SA2855	492	1.067
573	1141	AILEEN	97AB6435	850	1.065
574	1106	SHARYLAND	94SB2035	884	1.064
575	956	LEARY LANE	94CN6175	2472	1.064
576	525	MELVIN	97SA4955	84	1.060
577	531	CROSS PLAINS	97AB1795	446	1.058
578	1250	HAINE DRIVE	94SB9240	36	1.056
579	1082	RANKIN	97SA6400	58	1.052
580	912	NORTH MCALLEN	94SB5060	2655	1.049
581	329	PECOS VALLEY	97SA4075	21	1.048
582	1153	AB ELM CREEK	97AB4780	549	1.047
583	1294	WASHINGTON STREET	94LA2310	44	1.045
584	975	RANKIN	97SA5735	193	1.041
585	350	STAMFORD	97AB2815	700	1.041
586	114	GOODLETT	97AB12205	49	1.041
587	1146	DEL MAR	94LA220	1483	1.040
588	859	FALFURRIAS	94LA1070	924	1.040
589	586	YOUNG	94SB7145	2859	1.037
590	1149	HARLINGEN	94SB380	267	1.034
591	561	RANKIN	97SA6405	357	1.031
592	#N/A	MATADOR	97AB13495	504	1.030
593	187	HIDALGO	94SB4845	462	1.028

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIFI Ranking	2022 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIFI Value
594	1170	SA MATHIS FIELD	97SA5100	329	1.027
595	987	AB COUNTRY CLUB	97AB4735	120	1.025
596	399	HIGHWAY 9	94CS9830	139	1.022
597	380	FULTON	94CS3070	1584	1.013
598	927	SHARYLAND	94SB2150	895	1.011
599	1198	SIERRA VISTA	94LA8205	1343	1.010
600	1268	ESCONDIDO	94LA2035	462	1.009
601	898	DILLEY	94LA6400	864	1.008
602	303	WADSWORTH	94CN7660	1525	1.004
603	965	PALMHURST	94SB2525	2327	1.000
604	534	MAYBERRY	94SB5340	39	1.000
605	1297	WASHINGTON STREET	94LA2320	37	1.000
606	1288	WASHINGTON STREET	94LA2330	57	1.000
607	1293	WASHINGTON STREET	94LA6890	19	1.000
608	954	RACHAL	94LA6595	357	0.989
609	54	ALICE	94LA1770	1660	0.989
610	340	PICACHO	94LA1230	1064	0.982
611	456	RESACA	94SB8700	1126	0.980
612	108	RIO BRAVO	94LA1130	1055	0.971
613	996	LEARY LANE	94CN6005	1382	0.966
614	44	TUSCOLA	97AB3305	1090	0.961
615	575	PORT ARANSAS	94CS1000	1753	0.961
616	454	VALADEZ	94CS9890	1902	0.960
617	847	ARCADIA	94CS5030	1573	0.955
618	143	UVALDE	94LA6620	2177	0.952
619	1000	PALMHURST	94SB1300	2355	0.947
620	468	BOBCAT HILLS	97SA6655	70	0.943
621	293	SOUTHSIDE	94CS7995	1555	0.936
622	99	ALAZAN	94CS620	188	0.931
623	1118	SA CONCHO	97SA1705	925	0.922
624	891	CARRIZO SPRINGS	94LA370	546	0.921
625	690	PRIMERA	94SB6085	1494	0.919
626	1184	ALICE	94LA1790	451	0.918
627	349	LEARY LANE	94CN7530	3283	0.916
628	914	ALICE	94LA1780	516	0.905
629	1164	ZACATE CREEK	94LA2665	1732	0.905
630	36	CAMPWOOD	94LA2610	1027	0.904
631	970	ALICE	94LA2540	960	0.897
632	301	VERHALEN	97SA14765	28	0.893
633	334	CAUSEWAY	94SB4765	671	0.893
634	234	LAREDO PLANT	94LA8695	1606	0.877
635	208	LAGUNA	94CS9590	2372	0.875
636	938	QUANAH	97AB100	92	0.870
637	158	ZAPATA	94LA2710	1369	0.862
638	104	JOURDANTON	94LA250	780	0.862
639	985	LANTANA	94CS4095	194	0.845

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIFI Ranking	2022 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIFI Value
640	170	PUEBLO	94LA275	2945	0.845
641	339	SOUTH SANTA ROSA	94SB1225	867	0.843
642	716	STADIUM	94LA7800	688	0.840
643	192	FULTON	94CS440	2116	0.838
644	909	ANNA STREET	94LA850	1577	0.836
645	606	GOLIAD	94CN8220	1066	0.835
646	383	CROSS PLAINS	97AB2920	557	0.835
647	711	NORTH VICTORIA	94CN7430	1678	0.833
648	1059	TATTON	94CS8200	1269	0.828
649	612	HAINE DRIVE	94SB9700	1150	0.827
650	56	SAND CRAB	94CN9235	386	0.821
651	916	HEIGHTS	94LA2100	1988	0.820
652	405	CARANCAHUA	94CN5870	472	0.816
653	398	PARKER	94CN9260	129	0.814
654	770	FRIO	94LA2270	1142	0.798
655	1289	MINES ROAD	94LA8770	276	0.797
656	461	WEST HARLINGEN	94SB3800	1419	0.794
657	93	WEIL TRACT (138/12KV)	94CS1990	1344	0.794
658	171	DIMITT	94LA4120	1273	0.790
659	66	FREISS RANCH	97SA4870	100	0.790
660	813	SHEFFIELD	97SA6430	205	0.785
661	873	AB SHELTON ST	97AB3050	645	0.783
662	577	BONNIEVIEW	94CS8020	552	0.783
663	1196	PHARR	94SB1650	932	0.782
664	175	SOUTHSIDE	94CS8025	1148	0.778
665	310	ARCADIA	94CS8570	1448	0.777
666	271	PAULANN	97SA6285	66	0.773
667	205	EAGLE PASS CITY	94LA2770	2027	0.753
668	1048	HEIGHTS	94LA6810	2134	0.752
669	641	DEL MAR	94LA490	802	0.752
670	829	MILO	94LA6940	473	0.751
671	135	WEST HARLINGEN	94SB3700	2009	0.748
672	109	LOS FRESNOS	94SB5335	2752	0.746
673	1168	ALBANY	97AB3640	337	0.742
674	1155	PADUCAH CITY	97AB1935	286	0.734
675	373	YORKTOWN	94CN8420	652	0.729
676	322	ROUNDTOP	97AB4490	51	0.725
677	869	GARCENO	94SB2165	1980	0.720
678	296	CLARKWOOD	94CS9570	1236	0.715
679	681	COTULLA	94LA460	508	0.713
680	256	WESMER	94SB9705	960	0.706
681	227	LEARY LANE	94CN1540	792	0.699
682	790	VILLA CAVAZOS	94SB5680	2030	0.688
683	999	RAYMONDVILLE #1	94SB800	744	0.687
684	692	SOUTH MISSION	94SB3620	2129	0.683
685	115	PLACEDO	94CN7970	494	0.682

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIFI Ranking	2022 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIFI Value
686	491	SINTON	94CS6860	995	0.681
687	737	CHILDRESS 69	97AB1480	304	0.681
688	752	MAGRUDER	94CN7690	529	0.681
689	629	SABINAL	94LA200	444	0.680
690	729	SUN VALLEY	97SA4300	59	0.678
691	1199	GATEWAY	94LA5055	1711	0.678
692	1225	BRYANTS RANCH	97SA205	21	0.667
693	446	GREGORY	94CS420	475	0.665
694	857	AB ELM CREEK	97AB5045	386	0.661
695	721	LEARY LANE	94CN1890	1633	0.652
696	706	ARCADIA	94CS1460	2439	0.647
697	1070	FT DAVIS	97SA3345	540	0.646
698	89	ELSA	94SB3500	1333	0.641
699	284	ROBY	97AB3795	77	0.636
700	323	ARANSAS PASS	94CS8280	628	0.635
701	1107	MUNDAY	97AB3365	413	0.630
702	435	JOURDANTON	94LA5685	340	0.626
703	598	BROWNSVILLE	94SB3050	2026	0.624
704	941	AB OIL MILL	97AB3900	696	0.624
705	732	CABANISS	94CS80	102	0.618
706	369	NIXON	94CN3300	596	0.617
707	544	PUTNAM	97AB2129	193	0.617
708	161	FREER	94LA6320	169	0.615
709	1103	MCCOLL ROAD	94SB4400	1448	0.615
710	503	SHROPSHIRE	94CN3575	36	0.611
711	796	HOLLY	94CS1370	1884	0.610
712	886	WESLACO UNIT	94SB8195	1656	0.605
713	74	SOUTHSIDE	94CS5335	1614	0.604
714	55	WESMER	94SB4050	1946	0.604
715	930	CRYSTAL CITY	94LA2170	740	0.597
716	445	ANSON REA (SEC)	97AB5215	263	0.597
717	991	STADIUM	94LA6950	425	0.591
718	959	MAGRUDER	94CN6700	1365	0.589
719	582	HIDALGO	94SB3680	356	0.584
720	778	NIXON	94CN6630	645	0.581
721	794	ALBANY	97AB3540	628	0.580
722	377	ARCADIA	94CS1450	1645	0.578
723	1256	ROCHESTER	97AB3290	81	0.568
724	585	PANTERA	94SB1315	1947	0.566
725	691	MERTZON (CVEC)	97SA2905	594	0.566
726	884	MCKENZIE ROAD	94CS330	2409	0.565
727	671	SOUTHSIDE	94CS8035	1089	0.565
728	783	PORT ISABEL S.S.	94SB4070	264	0.561
729	408	SA GRAPE CREEK	97SA5220	715	0.551
730	1054	KLEIMANN	94CN425	612	0.549
731	38	ZAPATA	94LA8300	1611	0.547

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIFI Ranking	2022 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIFI Value
732	459	SHAFTER	97SA5110	46	0.543
733	91	CHARLOTTE	94LA2790	203	0.542
734	477	RISING STAR	97AB5075	680	0.541
735	58	SAN DIEGO	94LA2930	562	0.541
736	838	REFUGIO	94CN1170	858	0.538
737	421	JUNCTION	97SA10805	811	0.538
738	231	YORKTOWN	94CN3130	493	0.538
739	14	ELSA	94SB700	1543	0.536
740	831	EL CAMPO	94CN2860	1524	0.535
741	147	CABANISS	94CS615	309	0.534
742	880	AB RAINEY CREEK	97AB4220	223	0.534
743	1159	CISCO	97AB1020	491	0.532
744	707	STADIUM	94LA7810	1338	0.531
745	12	GEORGE WEST	94CN1320	690	0.529
746	1205	GARCENO	94SB5490	1476	0.528
747	642	TRENT	97AB2850	19	0.526
748	122	BEN FICKLIN	97SA14065	805	0.520
749	958	RIO GRANDE CITY	94SB3210	2009	0.520
750	812	SOUTHSIDE	94CS8005	744	0.516
751	448	NORDHEIM	94CN3380	177	0.514
752	305	PALMHURST	94SB2530	2198	0.514
753	820	EAST HARRISON	94SB4360	1784	0.512
754	683	POINT COMFORT	94CN6060	365	0.512
755	679	KLEBERG	94CS1560	1437	0.510
756	80	BLESSING	94CN8780	59	0.508
757	263	CHILLICOTHE	97AB4525	124	0.508
758	743	JUNCTION	97SA10795	802	0.507
759	1190	MARFA	97SA1900	807	0.506
760	59	PRAIRIE PUMP	94CN1940	95	0.505
761	756	SINTON	94CS1750	269	0.502
762	145	FALFURRIAS	94LA5210	1176	0.500
763	451	THREE RIVERS	94CN5190	465	0.499
764	1032	GOODWIN	94SB3530	340	0.497
765	153	GONZALES	97SA15390	1099	0.488
766	1278	ABILENE PLANT	97AB3175	119	0.487
767	1290	LAS CRUSES	94LA8530	76	0.487
768	302	LA PRYOR	94LA580	341	0.487
769	788	CASA BLANCA	94CS4170	1166	0.486
770	693	IRAAN	97SA2055	134	0.485
771	934	SA EMERSON ST	97SA4860	226	0.478
772	758	EAST HARRISON	94SB3030	680	0.476
773	855	AB DYESS 2	97AB6335	356	0.475
774	1200	SA WALNUT ST	97SA3915	711	0.474
775	308	NORTH MCALLEN	94SB2980	1911	0.473
776	883	BIG WELLS	94LA1570	426	0.472
777	663	CONTINENTAL	94SB3650	17	0.471

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIFI Ranking	2022 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIFI Value
778	627	YOUNG	94SB3310	1864	0.467
779	#N/A	SANTO NINO	94LAT000F5	1203	0.462
780	749	NIXON	94CN2025	535	0.462
781	466	AB MCMURRY	97AB3245	794	0.461
782	1092	SHARYLAND	94SB2020	1880	0.457
783	795	CRYSTAL CITY	94LA7425	449	0.457
784	735	PETTUS	94CN1020	467	0.454
785	736	EAST HARRISON	94SB3190	1474	0.444
786	447	MOORE FIELD	94SB3960	2175	0.442
787	268	PORT ISABEL S.S.	94SB3820	1159	0.442
788	242	NORTH ALAMO	94SB3580	1067	0.440
789	493	PROGRESO	94SB2515	210	0.438
790	767	LAS CRUSES	94LA7325	2764	0.432
791	776	JOURDANTON	94LA5695	327	0.431
792	330	PEARSALL	94LA9905	440	0.430
793	685	BANQUETTE	94CS130	235	0.426
794	1237	AB ELMDALE	97AB4520	290	0.424
795	203	ALICE	94LA2530	1491	0.423
796	1091	PEARSALL	94LA5580	856	0.421
797	164	CHARLOTTE	94LA8120	245	0.420
798	357	OLMITO	94SB4275	824	0.420
799	532	SA EMERSON ST	97SA4620	429	0.417
800	724	CITRUS CITY	94SB7985	1204	0.415
801	496	FALFURRIAS	94LA1080	464	0.414
802	730	GREENLAKE	94CN2760	1195	0.413
803	251	CAUSEWAY	94SB9880	1228	0.413
804	945	VALADEZ	94CS3140	2219	0.412
805	611	DEL MAR	94LA7930	2004	0.412
806	1012	SAN DIEGO	94LA1980	621	0.406
807	939	SOUTH MISSION	94SB3590	555	0.404
808	397	PORT ARANSAS	94CS6940	1648	0.403
809	#N/A	BENTSEN	94SB212	10	0.400
810	870	FULTON	94CS6070	1832	0.398
811	507	SOUTHSIDE	94CS8045	969	0.396
812	371	FT DAVIS	97SA4515	1027	0.395
813	142	DEL RIO CITY	94LA1930	1582	0.395
814	887	ARCADIA	94CS5020	1541	0.393
815	853	ANNA STREET	94LA2250	1536	0.391
816	700	ESCONDIDO	94LA3350	2305	0.390
817	87	INGLESIDE CITY	94CS6040	438	0.390
818	396	CHOKE CANYON	94CN9255	364	0.390
819	701	ALAZAN	94CS2740	36	0.389
820	152	WESLACO UNIT	94SB5970	1979	0.388
821	803	VERNON	97AB4275	589	0.385
822	844	CITRUS CITY	94SB9775	1596	0.383
823	910	MCCOLL ROAD	94SB1655	1522	0.382

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIFI Ranking	2022 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIFI Value
824	592	SA GRAPE CREEK	97SA5365	866	0.381
825	827	NORTH EDINBURG	94SB3570	1058	0.381
826	640	WEST MCALLEN	94SB4595	1206	0.380
827	182	MAYBERRY	94SB3160	555	0.378
828	1001	SOUTH MISSION	94SB5215	1284	0.378
829	1013	AB MCMURRY	97AB4510	812	0.376
830	139	HOLLY	94CS1480	1691	0.376
831	417	ABILENE PLANT	97AB1565	277	0.375
832	1151	SA CONCHO	97SA3325	293	0.375
833	835	STADIUM	94LA7490	1321	0.372
834	753	GATEWAY	94LA350	2040	0.372
835	411	PIRATE	94CS3220	740	0.370
836	2	MINES ROAD	94LA7235	46	0.370
837	374	EAGLE PASS CITY	94LA450	893	0.370
838	1137	PERKINS PROTHO	97SA3180	19	0.368
839	684	RAYMONDVILLE #1	94SB3130	313	0.367
840	151	RACHAL	94LA8145	381	0.365
841	#N/A	SANTO NINO	94LAT000G2	1490	0.364
842	33	CLYDE	97AB1760	471	0.363
843	892	SA WALNUT ST	97SA3920	913	0.363
844	176	SKIDMORE	94CS380	160	0.363
845	955	COLLEGE HILLS	97SA6145	979	0.362
846	841	BAY CITY	94CN2050	326	0.359
847	698	TYNAN	94CS4000	28	0.357
848	450	RULE	97AB3396	430	0.356
849	486	GOLIAD	94CN6540	1251	0.353
850	944	SAND ROAD	97AB5655	611	0.352
851	748	RUNGE	94CN4465	367	0.351
852	51	NORTH VICTORIA	94CN7770	818	0.350
853	593	SAND CRAB	94CN8390	537	0.348
854	440	YOUNG	94SB5135	1285	0.348
855	825	BUENA VISTA	94LA9385	896	0.347
856	483	MOCKINGBIRD	94CN370	49	0.347
857	894	CABANISS	94CS710	174	0.345
858	132	SAND CRAB	94CN8120	273	0.344
859	926	THREE RIVERS	94CN2580	120	0.342
860	751	RIO GRANDE CITY	94SB3220	1431	0.338
861	365	DILLEY	94LA510	556	0.338
862	757	JOURDANTON	94LA880	1158	0.338
863	718	NORTH VICTORIA	94CN1580	1008	0.336
864	745	ROCKPORT	94CS5130	571	0.336
865	879	SINTON	94CS360	337	0.335
866	1117	ROCKPORT	94CS5950	559	0.335
867	1302	SANTA RITA	97SA1140	39	0.333
868	833	AB VOGEL ST	97AB4410	769	0.333
869	333	MCCOLL ROAD	94SB4780	2009	0.330

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIFI Ranking	2022 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIFI Value
870	906	MOCKINGBIRD	94CN305	331	0.329
871	126	NORTH MERCEDES	94SB3840	722	0.328
872	1016	SAND ROAD	97AB5290	808	0.328
873	462	WYLIE	97AB6340	787	0.328
874	1138	EAST HARRISON	94SB4620	783	0.327
875	309	SOUTH SANTA ROSA	94SB1215	1738	0.327
876	864	AB ELMDALE	97AB4085	46	0.326
877	798	EAST HARRISON	94SB4310	1216	0.326
878	42	PIRATE	94CS3380	418	0.325
879	210	GOODWIN	94SB4380	1755	0.325
880	911	AB CANYON ROCK	97AB5030	698	0.325
881	233	KEPLER	94CS2665	37	0.324
882	550	CITRUS CITY	94SB6000	2386	0.324
883	785	SAN DIEGO	94LA2890	1020	0.324
884	229	ARCADIA	94CS6930	1497	0.322
885	760	DEL RIO CITY	94LA440	1107	0.322
886	1043	GOODWIN	94SB4625	2358	0.321
887	781	GEORGE WEST	94CN730	877	0.320
888	345	SOUTH EAST EDINBURG	94SB6580	948	0.319
889	484	AB SHELTON ST	97AB4640	679	0.318
890	1027	READING	94LA1385	1358	0.318
891	290	WESLACO UNIT	94SB7455	1230	0.318
892	1143	GOODWIN	94SB7380	2097	0.313
893	438	RIO BRAVO	94LA300	808	0.313
894	921	LAREDO PLANT	94LA8745	766	0.304
895	353	MERKEL	97AB1895	707	0.301
896	1193	CROWELL	97AB3980	475	0.297
897	566	HAROLD	97AB3055	27	0.296
898	498	EAGLE PASS CITY	94LA2510	713	0.295
899	96	HAWLEY	97AB4455	682	0.293
900	750	HARLINGEN	94SB370	1232	0.291
901	983	AB OIL MILL	97AB3895	117	0.291
902	1085	VERNON CITY PLANT	97AB5775	797	0.290
903	352	WEST MCALLEN	94SB4815	534	0.285
904	219	ODEM	94CS385	577	0.284
905	652	DEL MAR	94LA3440	1820	0.283
906	720	ARMSTRONG	94CS6050	85	0.282
907	890	RAYMONDVILLE #2	94SB1280	1018	0.282
908	772	FRIO	94LA1815	1062	0.281
909	1178	PALMVIEW	94SB9680	1053	0.279
910	823	STADIUM	94LA8540	1680	0.279
911	295	PORT ARANSAS	94CS990	2669	0.276
912	473	AB ELM CREEK	97AB4775	925	0.276
913	918	MARFA	97SA1905	1178	0.275
914	989	LA GRULLA	94SB4120	1571	0.274
915	636	MUSTANG ISLAND	94CS8510	534	0.268

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIFI Ranking	2022 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIFI Value
916	#N/A	HIDALGO	94SB3970	963	0.267
917	1015	AB MCMURRY	97AB3235	791	0.267
918	0	HOEFFS ROAD	97SA15680	15	0.267
919	804	DEL RIO CITY	94LA9790	2372	0.265
920	494	INGLESIDE CITY	94CS2495	273	0.264
921	932	EL CAMPO	94CN5745	951	0.263
922	1147	PADUCAH CITY	97AB1930	572	0.262
923	1105	POWELL FIELD	97SA2528	23	0.261
924	548	PUTNAM	97AB2131	124	0.258
925	1210	TRADE ZONE	94SB2220	66	0.258
926	1	RIO RICO	94SB8330	70	0.257
927	704	AB HARTFORD ST	97AB3815	1079	0.257
928	1121	KARNES CITY	94CN2340	785	0.256
929	740	HAMILTON ROAD	94LA9665	1575	0.255
930	680	SOUTH EAST EDINBURG	94SB4015	480	0.254
931	759	AIRLINE	94CS9605	707	0.253
932	195	MINES ROAD	94LA1600	908	0.252
933	552	ARANSAS PASS	94CS8270	417	0.252
934	422	ABILENE PLANT	97AB1570	961	0.251
935	656	JOSLIN POWER PLANT	94CN8720	24	0.250
936	457	DEL RIO CITY	94LA9850	1053	0.249
937	1060	GILA	94CS350	304	0.247
938	961	KINGSVILLE	94CS1140	1124	0.246
939	1234	AB HARTFORD ST	97AB3685	363	0.245
940	746	AIRLINE	94CS9030	405	0.244
941	978	ZAPATA	94LA7330	1356	0.244
942	773	ASHERTON	94LA5495	590	0.242
943	478	AB VOGEL ST	97AB4560	1453	0.242
944	1023	SA AVENUE N	97SA1730	830	0.242
945	828	ARCADIA	94CS1360	1545	0.242
946	341	KNIPPA	94LA6365	343	0.242
947	46	WEIL TRACT (138/12KV)	94CS2520	87	0.241
948	1127	KNOX CITY	97AB3300	466	0.240
949	304	HIGHWAY 9	94CS6730	559	0.240
950	557	ROTAN	97AB1860	676	0.240
951	860	SA WALNUT ST	97SA3925	889	0.240
952	917	YOUNG	94SB6140	2627	0.237
953	998	KENEDY	94CN6270	549	0.237
954	11	VERHALEN	97SA4460	81	0.235
955	206	BISHOP	94CS7180	917	0.233
956	648	SA COKE ST	97SA3905	657	0.233
957	311	SAN BENITO	94SB4945	1736	0.228
958	1046	TRENT	97AB4245	189	0.228
959	569	TURKEY	97AB2980	335	0.227
960	971	WASHINGTON STREET	94LA7015	1556	0.227
961	1098	AB VOGEL ST	97AB4405	605	0.226

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIFI Ranking	2022 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIFI Value
962	1067	ALBANY	97AB3655	627	0.225
963	867	SPUR	97AB5170	392	0.224
964	1216	ANNA STREET	94LA5780	653	0.224
965	668	BRACKETTVILLE	94LA8460	1196	0.222
966	1075	KLEBERG	94CS8140	652	0.222
967	16	ODEM	94CS375	639	0.222
968	863	WYLIE	97AB6495	369	0.222
969	669	WOOLRIDGE	94CS1170	437	0.222
970	888	DUNE FIELD (N CRANE)	97SA3885	68	0.221
971	878	CABANISS	94CS820	1327	0.219
972	1056	BIG WELLS	94LA2630	32	0.219
973	562	SA NORTH	97SA3125	1397	0.218
974	722	BRADY	97SA5015	199	0.216
975	626	HEIGHTS	94LA2390	1701	0.216
976	1142	ASPERMONT	97AB3380	391	0.215
977	213	BEN FICKLIN	97SA6175	592	0.215
978	245	SILVER	97SA4295	14	0.214
979	942	MORAN	97AB2107	207	0.213
980	70	RODD FIELD	94CS225	2973	0.212
981	112	OZONA	97SA3810	1152	0.211
982	1257	COLLEGE HILLS	97SA4835	499	0.210
983	570	ODEM	94CS2400	316	0.209
984	331	NAVAL BASE	94CS9720	2693	0.208
985	1130	SA SOUTHLAND HILLS	97SA5055	859	0.206
986	699	THREE RIVERS	94CN2010	316	0.206
987	1034	SA WALNUT ST	97SA4635	1551	0.205
988	649	PETTUS	94CN8210	349	0.203
989	1203	KENEDY S.S.	94CN6750	69	0.203
990	221	CASA BLANCA	94CS55	875	0.201
991	#N/A	GOODLETT	97AB11780	15	0.200
992	1274	ESCONDIDO	94LA3775	240	0.200
993	982	VERNON	97AB5000	251	0.199
994	130	BALLINGER	97SA4375	1133	0.198
995	1078	SPUR	97AB300	203	0.197
996	1166	AB ELM CREEK	97AB1810	818	0.196
997	899	MERKEL	97AB1890	578	0.196
998	766	KLEIMANN	94CN565	592	0.194
999	1207	SA SOUTH	97SA4795	1519	0.193
1000	429	CLYDE	97AB3635	453	0.192
1001	784	SAN DIEGO	94LA2880	1341	0.192
1002	257	MELVIN	97SA940	47	0.191
1003	1074	ROCKPORT	94CS5940	68	0.191
1004	929	ZACATE CREEK	94LA2675	1211	0.191
1005	1136	SA NORTH	97SA3120	1149	0.190
1006	412	HARLINGEN SWITCH	94SB5350	965	0.190
1007	124	BISHOP	94CS2690	640	0.189

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIFI Ranking	2022 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIFI Value
1008	541	RESACA	94SB9975	567	0.189
1009	360	HEIGHTS	94LA6820	1929	0.188
1010	186	FOSTER FIELD	94CN8880	297	0.185
1011	924	PANTERA	94SB1915	1164	0.185
1012	495	READING	94LA1445	532	0.182
1013	618	VERNON	97AB1520	727	0.182
1014	240	ELDORADO	97SA1845	514	0.181
1015	1233	HIGHLAND	97SA6375	323	0.180
1016	1080	BENJAMIN (BEPC)	97AB5680	162	0.179
1017	1197	AB EAST 12KV	97AB4830	1003	0.177
1018	811	CHOKE CANYON	94CN5390	412	0.177
1019	1120	SIERRA VISTA	94LA9900	2556	0.177
1020	964	YELLOW JACKET	97SA5505	539	0.176
1021	401	BALLINGER	97SA4370	778	0.175
1022	1004	ARANSAS PASS	94CS9130	454	0.174
1023	1025	CLOSNER	94SB6430	1032	0.173
1024	1061	ARANSAS PASS	94CS650	1219	0.173
1025	576	HASKELL 12KV	97AB3770	461	0.171
1026	1182	DEL MAR	94LA2120	1365	0.171
1027	1152	SA SOUTH	97SA3500	566	0.170
1028	236	ALBANY	97AB2029	242	0.169
1029	1181	ROBERT LEE	97SA4120	549	0.169
1030	191	NORTH VICTORIA	94CN7860	1493	0.169
1031	1140	ASPERMONT	97AB1070	332	0.169
1032	1215	MILES	97SA4670	392	0.168
1033	1018	MAGRUDER	94CN6680	703	0.168
1034	1076	CROWELL	97AB3490	173	0.168
1035	1134	ARANSAS PASS	94CS660	731	0.167
1036	1128	BARNHART	97SA590	18	0.167
1037	1068	SAND ROAD	97AB5295	614	0.166
1038	518	DONNA SKID	94SBTX_B	555	0.166
1039	482	NORTH VICTORIA	94CN6390	1509	0.166
1040	623	AB SHELTON ST	97AB3435	291	0.165
1041	470	AB ONYX REA	97AB3260	147	0.163
1042	972	WASHINGTON STREET	94LA6355	940	0.161
1043	1081	STAMFORD	97AB2835	106	0.160
1044	1094	SA AVENUE N	97SA1695	1533	0.159
1045	1145	SA NORTH	97SA3130	235	0.157
1046	1201	SA CONCHO	97SA1700	550	0.156
1047	546	AB OVER STREET 12KV	97AB1840	879	0.156
1048	1245	ROTAN	97AB1865	193	0.155
1049	1038	GILA	94CS7840	769	0.155
1050	858	NORTH VICTORIA	94CN1470	479	0.154
1051	1050	MUSTANG ISLAND	94CS9470	864	0.152
1052	1212	SHARYLAND	94SB2010	1150	0.151
1053	472	WESLACO UNIT	94SB2195	1113	0.151

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIFI Ranking	2022 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIFI Value
1054	116	OZONA	97SA3555	160	0.150
1055	40	FOSTER FIELD	94CN2550	67	0.149
1056	524	DUST DEVIL	94LA1495	2043	0.148
1057	1227	NEW BLUFFS	97SA7280	1600	0.148
1058	4	RIO RICO	94SB5050	285	0.147
1059	358	HEINES	94CS2185	1250	0.147
1060	682	SOUTH SANTA ROSA	94SB7485	1245	0.146
1061	392	ANNA STREET	94LA780	466	0.146
1062	533	VICTORIA POWER PLANT	94CN8070	599	0.145
1063	217	AB ELM CREEK	97AB4745	889	0.145
1064	519	SA SOUTHLAND HILLS	97SA5455	1429	0.145
1065	881	HARLINGEN	94SB360	2419	0.145
1066	273	VERNON CITY PLANT	97AB5770	90	0.144
1067	714	CHILDRESS 69	97AB1800	540	0.144
1068	436	BAIRD	97AB5125	501	0.144
1069	1108	PRIMERA	94SB5705	1274	0.144
1070	31	TAFT	94CS1260	200	0.140
1071	278	VERHALEN	97SA4465	36	0.139
1072	505	UVALDE	94LA480	579	0.138
1073	1209	AB EAST 12KV	97AB4825	413	0.138
1074	1028	ZAPATA	94LA8290	986	0.138
1075	1102	SOUTH MISSION	94SB3980	1967	0.137
1076	553	MUNDAY	97AB6715	241	0.137
1077	705	ROCKPORT	94CS5930	1017	0.137
1078	1165	CISCO	97AB6530	529	0.136
1079	1174	ESCONDIDO	94LA1510	742	0.135
1080	1093	KLEBERG	94CS9395	1240	0.133
1081	1162	BRONTE	97SA3560	229	0.131
1082	1195	HEIGHTS	94LA9080	693	0.130
1083	922	BAY CITY	94CN6450	162	0.130
1084	667	IRAAN	97SA2050	386	0.130
1085	885	HOLLY	94CS1950	833	0.128
1086	993	RODD FIELD	94CS245	709	0.128
1087	1148	SINTON	94CS180	235	0.128
1088	609	ROBY	97AB2276	329	0.128
1089	522	KINGSVILLE	94CS1670	424	0.127
1090	1267	COTULLA	94LA110	55	0.127
1091	968	SA COKE ST	97SA4910	1805	0.127
1092	52	INGLESIDE CITY	94CS8060	2711	0.127
1093	485	AB OVER STREET 12KV	97AB1645	796	0.126
1094	1228	MUNDAY	97AB2080	496	0.125
1095	851	TWILIGHT TRAIL	97AB3150	721	0.125
1096	556	QUANAH	97AB3100	545	0.125
1097	1042	STAMFORD	97AB4565	776	0.124
1098	13	SONORA 138 SUB	97SA4810	872	0.123
1099	574	SEAWALL	94CS9450	302	0.123

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIFI Ranking	2022 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIFI Value
1100	1019	AB OIL MILL	97AB2785	320	0.122
1101	1079	SA WALNUT ST	97SA3910	148	0.122
1102	1124	SA EMERSON ST	97SA4630	1255	0.121
1103	900	AB SHELTON ST	97AB3060	1540	0.120
1104	141	KNIPPA	94LA6535	25	0.120
1105	1009	MERTZON (CVEC)	97SA1530	338	0.118
1106	793	EAGLE PASS CITY	94LA7060	864	0.117
1107	30	HOLLY	94CS1220	3398	0.117
1108	976	TAYLOR	94SBSH111	719	0.117
1109	1150	SOUTH MCALLEN	94SB3935	508	0.116
1110	133	NORTH ALAMO	94SB3610	2019	0.116
1111	120	AB RAINEY CREEK	97AB4225	122	0.115
1112	1154	ABILENE PLANT	97AB1910	254	0.114
1113	1089	AB WALNUT ST	97AB3110	662	0.113
1114	710	AB OIL MILL	97AB2780	749	0.112
1115	267	CEDAR GAP (TEC)	97AB5445	518	0.112
1116	1083	WOOLRIDGE	94CS1120	1638	0.111
1117	1044	UNIVERSITY	94LA920	928	0.110
1118	1051	SOUTH MISSION	94SB4650	943	0.109
1119	413	SONORA 138 SUB	97SA4805	344	0.108
1120	127	PHARR	94SB1625	391	0.107
1121	897	GARCENO	94SB2135	1571	0.107
1122	1180	NORTH EDINBURG	94SB3810	1704	0.106
1123	1238	CHILDRESS 69	97AB2800	341	0.106
1124	1222	SPUR	97AB260	162	0.105
1125	#N/A	SANTO NINO	94LAT000F2	1889	0.103
1126	1226	AB REBECCA LANE	97AB5550	709	0.103
1127	742	YOUNG	94SB4435	851	0.102
1128	923	AIRLINE	94CS9390	1350	0.102
1129	963	CHILDRESS 20TH ST	97AB5725	668	0.102
1130	800	HEARN ROAD	94CS2220	1759	0.102
1131	686	MATADOR	97AB3030	217	0.101
1132	500	RULE	97AB3378	100	0.100
1133	937	SA LAKE DR	97SA5880	840	0.100
1134	1235	ABILENE PLANT	97AB1915	50	0.100
1135	1133	AB RAINEY CREEK	97AB4270	1623	0.100
1136	174	NORTH PADRE ISLAND	94CS7900	2372	0.099
1137	817	HEIGHTS	94LA2450	2032	0.099
1138	595	KNOX CITY	97AB3390	373	0.099
1139	984	SA SOUTH	97SA3995	787	0.098
1140	425	STERLING CITY	97SA1445	381	0.097
1141	536	RUSSEK STREET	97SA7705	650	0.097
1142	931	CARRIZO SPRINGS	94LA860	31	0.097
1143	572	BEN FICKLIN	97SA6185	758	0.095
1144	1072	WASHINGTON STREET	94LA2360	201	0.095
1145	651	AFTON	97AB2225	53	0.094

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIFI Ranking	2022 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIFI Value
1146	92	DILLEY	94LA3795	106	0.094
1147	792	AB MCMURRY	97AB3240	764	0.094
1148	1157	SA SOUTH	97SA4255	867	0.093
1149	950	SA JACKSON ST	97SA4265	806	0.093
1150	1300	GIRARD	97AB6260	43	0.093
1151	957	SA JACKSON ST	97SA4260	667	0.093
1152	299	CASA BLANCA	94CS5440	108	0.093
1153	463	HEARN ROAD	94CS9665	682	0.092
1154	764	VERNON	97AB3340	525	0.091
1155	346	SA SOUTHLAND HILLS	97SA5050	900	0.091
1156	1298	AB WALNUT ST	97AB3250	11	0.091
1157	88	ALPINE 12KV	97SA3875	669	0.090
1158	253	WEST MCALLEN	94SB6385	246	0.089
1159	79	PECOS VALLEY	97SA9615	56	0.089
1160	149	MILO	94LA8365	2143	0.087
1161	1176	KNOX CITY	97AB3985	23	0.087
1162	1192	SA JACKSON ST	97SA4690	1132	0.087
1163	535	SANTA ANNA	97SA3420	363	0.085
1164	1266	EAST HARRISON	94SB3000	548	0.084
1165	1031	AB REBECCA LANE	97AB5555	1240	0.084
1166	1163	JOSLIN POWER PLANT	94CN7915	12	0.083
1167	672	HEIGHTS	94LA9400	1485	0.083
1168	107	WEST MCALLEN	94SB4965	946	0.082
1169	513	NORTH MCCAMEY	97SA6555	801	0.082
1170	1208	SIERRA VISTA	94LA7170	1754	0.082
1171	951	CHILDRESS 69	97AB4865	782	0.081
1172	876	HEINES	94CS7875	2089	0.079
1173	1179	AB DYESS 1	97AB1775	931	0.077
1174	1087	DUST DEVIL	94LA1810	479	0.077
1175	1221	AB REBECCA LANE	97AB2710	262	0.076
1176	597	UNITEC	94LA4715	40	0.075
1177	246	AB MCMURRY	97AB4350	735	0.072
1178	1255	SA JACKSON ST	97SA4695	560	0.071
1179	1185	PAISANO	97SAPAISAN	172	0.070
1180	1217	CLOSNER	94SB7505	813	0.069
1181	947	HAMILTON ROAD	94LA9645	305	0.069
1182	#N/A	SANTO NINO	94LAT000E5	1609	0.068
1183	769	COTULLA	94LA610	720	0.068
1184	1030	VALADEZ	94CS8800	1803	0.068
1185	632	MINES ROAD	94LA4275	74	0.068
1186	1188	ROBERT LEE	97SA4125	270	0.067
1187	469	LA PRYOR	94LA1845	231	0.065
1188	1285	NEW BLUFFS	97SA3005	340	0.065
1189	966	COLLEGE HILLS	97SA4840	218	0.064
1190	1119	ROCHESTER	97AB3295	206	0.063
1191	1220	VALERA HUMBLE	97SA7015	80	0.063

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIFI Ranking	2022 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIFI Value
1192	1161	TWILIGHT TRAIL	97AB4285	1113	0.062
1193	1132	ROMA	94SB3060	1610	0.061
1194	237	TYNAN	94CS4010	49	0.061
1195	549	NORDHEIM	94CN4275	82	0.061
1196	563	BARNHART	97SA3725	135	0.059
1197	1230	SIERRA VISTA	94LA7360	1454	0.058
1198	604	JOURDANTON	94LA8725	35	0.057
1199	1296	KENEDY	94CN1960	70	0.057
1200	1206	EDEN	97SA3195	528	0.057
1201	1279	SIERRA VISTA	94LA3540	1240	0.056
1202	631	ROWENA	97SA4480	231	0.056
1203	1219	SA CONCHO	97SA1715	286	0.056
1204	212	ABILENE PLANT	97AB1575	608	0.056
1205	1272	UNIVERSITY	94LA305	825	0.056
1206	285	BEN FICKLIN	97SA6180	584	0.055
1207	713	HAMILTON ROAD	94LA9655	1332	0.052
1208	1052	CISCO	97AB9715	1011	0.049
1209	1171	EDITH HUMBLE	97SA6170	83	0.048
1210	287	TRADE ZONE	94SB1935	42	0.048
1211	476	LA PRYOR	94LA2440	190	0.047
1212	1064	TWILIGHT TRAIL	97AB4290	1169	0.046
1213	1260	WEINERT	97AB6490	131	0.046
1214	1055	HIGHLAND	97SA6385	1356	0.045
1215	384	SA LAKE DR	97SA6030	651	0.045
1216	1253	ALPINE 12KV	97SA6820	771	0.044
1217	1172	JAYTON	97AB6125	344	0.044
1218	1021	PAINT ROCK	97SA5235	138	0.043
1219	1231	SA SOUTHLAND HILLS	97SA5860	1197	0.043
1220	1265	HIGHLAND	97SA6380	463	0.043
1221	1040	UNIVERSITY	94LA465	960	0.043
1222	1114	WASHINGTON STREET	94LA2470	471	0.042
1223	540	WYLIE	97AB2675	833	0.041
1224	739	HIGHLAND	97SA6370	270	0.041
1225	537	AB SHELTON ST	97AB3045	553	0.040
1226	1282	MILES	97SA11330	176	0.040
1227	1247	TAYLOR	94SBSH112	990	0.039
1228	1071	COTULLA	94LA90	1054	0.039
1229	630	MCCOLL ROAD	94SB5485	1059	0.039
1230	933	SA EMERSON ST	97SA4625	414	0.039
1231	48	OZONA	97SA4185	729	0.038
1232	370	KEPLER	94CS1700	27	0.037
1233	994	LAREDO PLANT	94LA8705	174	0.034
1234	247	SWENSON	97AB136	30	0.033
1235	#N/A	STEAMBOAT	97AB12505	153	0.033
1236	775	KENEDY S.S.	94CN8340	309	0.032
1237	1246	TALPA ATLANTIC	97SA5180	62	0.032

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIFI Ranking	2022 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIFI Value
1238	905	ESPY WELLS	97SA50207	31	0.032
1239	216	WOOLRIDGE	94CS11110	1651	0.032
1240	1248	SONORA	97SAT000E2	504	0.032
1241	1251	CROCKETT HEIGHTS	97SA73703	65	0.031
1242	1271	PAINT ROCK	97SA11110	65	0.031
1243	610	AIRLINE	94CS8890	527	0.030
1244	875	PANTERA	94SB1105	626	0.030
1245	1158	AB SHELTON ST	97AB3145	997	0.029
1246	1144	KIRKLAND	97AB3545	36	0.028
1247	607	AB SHELTON ST	97AB3040	180	0.028
1248	555	TWILIGHT TRAIL	97AB5855	253	0.028
1249	802	CHILDRESS 20TH ST	97AB5720	182	0.027
1250	662	BENTSEN	94SBSH115	340	0.026
1251	1223	LAS CRUSES	94LA9865	505	0.026
1252	979	SONORA	97SA2045	203	0.025
1253	1129	AB HARTFORD ST	97AB3690	171	0.023
1254	376	UNIVERSITY	94LA950	1845	0.023
1255	342	SANTA RITA	97SA1100	130	0.023
1256	272	PAULANN	97SA6310	1118	0.022
1257	1167	AB REBECCA LANE	97AB6915	1002	0.022
1258	1258	RUSSEK STREET	97SA12295	283	0.021
1259	1187	HEINES	94CS8480	150	0.020
1260	872	SA SOUTH	97SA2595	1078	0.019
1261	1169	AB CANYON ROCK	97AB5025	58	0.017
1262	1099	AIRLINE	94CS7390	2454	0.016
1263	1211	AB ELM CREEK	97AB1825	218	0.014
1264	530	GREGORY	94CS2420	915	0.013
1265	1281	NEW BLUFFS	97SA9110	892	0.012
1266	1277	SA JACKSON ST	97SA4250	337	0.012
1267	1283	SA COKE ST	97SA4915	177	0.011
1268	1301	AILEEN	97AB4600	273	0.011
1269	1287	UNIVERSITY	94LA930	92	0.011
1270	351	ZACATE CREEK	94LA2635	978	0.010
1271	1261	SA AVENUE N	97SA1975	322	0.009
1272	824	MILO	94LA5020	120	0.008
1273	973	AILEEN	97AB4605	425	0.007
1274	502	GONZALES	97SA14685	1061	0.007
1275	605	RUSSEK STREET	97SA250	782	0.006
1276	#N/A	SANTO NINO	94LAT000G5	2351	0.006
1277	1062	COLLEGE HILLS	97SA4845	600	0.005
1278	1202	CAUSEWAY	94SB4775	1078	0.005
1279	882	COLLEGE HILLS	97SA5520	432	0.005
1280	1273	EDEN	97SA1780	233	0.004
1281	#N/A	GATEWAY	94LA4080	1997	0.004
1282	1263	TAYLOR	94SBSH114	624	0.003
1283	1286	BENTSEN	94SBSH211	374	0.003

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIFI Ranking	2022 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIFI Value
1284	248	AIRLINE	94CS5870	993	0.002
1285	#N/A	SANTO NINO	94LAT000H2	816	0.001
1286	639	KENEDY S.S.	94CN8320	142	
1287	1291	VICTORIA POWER PLANT	94CNNETVIC	88	
1288	647	VICTORIA POWER PLANT	94CNVBROWN	16	
1289	622	VICTORIA POWER PLANT	94CNVGREEN	29	
1290	646	VICTORIA POWER PLANT	94CNVRED	44	
1291	644	MCKENZIE ROAD	94CS150	24	
1292	848	ODEM	94CS5575	79	
1293	589	MORRIS STREET	94CSBLACK	82	
1294	660	MORRIS STREET	94CSBROWN	63	
1295	638	MORRIS STREET	94CSGREEN	230	
1296	1295	MORRIS STREET	94CSNET CC	317	
1297	635	MORRIS STREET	94CSRED	59	
1298	#N/A	HAISLEY	94CSTX_2_C	13	
1299	628	MORRIS STREET	94CSYELLOW	45	
1300	1057	DUST DEVIL	94LA1380	62	
1301	1292	WASHINGTON STREET	94LANETLAR	163	
1302	1006	RAYMONDVILLE #2	94SB5875	28	
1303	814	MAYBERRY	94SB6450	31	
1304	1191	ASHLAND	94SBSH301	12	
1305	1194	PEACOCK	97AB1375	43	
1306	599	ABILENE PLANT	97AB1735	85	
1307	1214	ABILENE PLANT	97AB1740	17	
1308	645	AFTON	97AB2355	45	
1309	762	TRUSCOTT	97AB3845	32	
1310	1240	SA CONCHO	97SA1725	29	
1311	915	PONDER KENNEDY	97SA50208	13	
1312	816	BRONTE AMBASSADOR	97SA6650	15	
1313	1111	TEX/NEW MEX PIPELINE	97SA9045	16	

Feeders from last year that are not in this year's list

2022 SAIFI Ranking	Substation Identification	Feeder ID	Reason not in 2023
252	HAISLEY	94CSTX_2_B	COUNT NOW UNDER 10
479	CHASE FIELD	94CN460	COUNT NOW UNDER 10
726	SANTO NINO	94LA515	RETIRED
567	PECAN BAYOU	97AB530	COUNT NOW UNDER 10
571	SANTO NINO	94LA75	RETIRED

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIFI Ranking	2022 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIFI Value
	787	SANTO NINO	94LA70	RETIRED	
	1049	SANTO NINO	94LA80	RETIRED	
	1229	SANTO NINO	94LA695	RETIRED	
	1262	SANTO NINO	94LA645	RETIRED	

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

Total Number of Feeders

With 10 or more Customers

1313

Add or Delete Rows as Necessary

AEP Texas Inc.

2023 SAIDI Ranking	2022 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIDI Value
1	86	GOVERNMENT WELLS	94LA7240	232	2,068.5
2	15	FREER	94LA1500	207	1,624.8
3	120	GARWOOD CITY	94CN2560	198	1,531.8
4	7	LULING - LCRA	94CN10	468	1,316.0
5	201	RANDADO	94LA8350	135	1,256.6
6	242	MCCAMEY	97SA2420	82	1,224.4
7	80	CONOCO-CHITTAM RANCH	94LA8580	26	1,184.3
8	52	BRUNI	94LA1120	273	1,165.4
9	70	WEST OSO	94CS9085	936	1,151.5
10	102	PLASTERCO (MWEC)	97AB2720	114	1,058.1
11	299	CRESTONIO	94LA260	1,767	1,033.9
12	556	GOVERNMENT WELLS	94LA6800	231	1,002.6
13	10	PECOS VALLEY	97SA4080	228	998.8
14	506	CHRISTOVAL	97SA6620	647	993.1
15	21	KEMPER EXXON HUMBLE	97SA72103	26	972.2
16	207	PALACIOS	94CN8550	84	940.7
17	312	MAVERICK	94LA9680	860	936.7
18	64	GANADO	94CN5795	487	932.0
19	409	CHRISTOVAL	97SA6615	464	890.6
20	792	CARANCAHUA	94CN1875	61	857.5
21	233	LOLITA	94CN6330	30	823.6
22	229	COFFEE PORT	94SB1095	1,087	804.6
23	998	GILA	94CS345	68	801.1
24	779	EDNA	94CN5785	1,248	779.0
25	89	LA PRYOR	94LA570	168	744.5
26	911	GOVERNMENT WELLS	94LA7250	570	744.2
27	481	BEEVILLE	94CN300	1,685	732.6
28	654	CLARKWOOD	94CS7610	103	722.0
29	1245	QUINTANA	94CNT001Y8	55	715.1
30	71	PORT ISABEL S.S.	94SB9295	1,577	711.6
31	533	ARCADIA	94CS1400	443	710.3
32	461	ROBSTOWN	94CS1650	353	697.3
33	119	MALONE	94CN7560	59	690.8
34	291	HOLCOMB	94LA3025	379	689.1
35	11	MALONE	94CN7550	234	678.3
36	474	CAMPWOOD	94LA3430	129	674.4
37	813	ASPR CONTINENTAL	97AB4800	32	657.8
38	230	WOODSON OIL FIELD	97AB30	32	647.4
39	1119	KLEBERG	94CS280	1,307	641.3
40	153	MATTHEWS	94CN1740	160	631.6
41	1032	ROMA	94SB3070	904	630.3
42	149	SOUTH PADRE ISLAND	94SB4695	1,399	627.2
43	626	WEST MCALLEN	94SB4555	1,632	627.1

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIDI Ranking	2022 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIDI Value
44	20	RIO PECOS	97SA3835	98	611.4
45	167	BULLMOOSE	94CS5875	66	610.2
46	602	LANTANA	94CS7150	273	608.2
47	97	RIO BRAVO	94LA5	733	606.9
48	480	MCCOLL ROAD	94SB4790	2,079	600.6
49	402	GRAYBACK	97AB3315	46	597.0
50	442	MESA VIEW	97SA7045	96	590.5
51	57	BULLMOOSE	94CS4185	19	582.9
52	600	COFFEE PORT	94SB1090	1,263	578.4
53	23	TATTON	94CS950	598	577.1
54	727	SUNCHASE	94SB1155	1,448	576.8
55	231	SUNCHASE	94SB1150	1,437	564.2
56	639	PHARAOH	94CS5175	1,277	558.6
57	25	PROGRESO	94SB2545	89	558.3
58	729	SOUTH PADRE ISLAND	94SB6440	2,602	547.5
59	886	SOUTH PADRE ISLAND	94SB4675	214	547.2
60	237	LULING - LCRA	94CN20	272	545.2
61	46	ASHERTON	94LA4175	68	544.2
62	862	PALMVIEW	94SB7595	3,208	540.5
63	177	EL CAMPO	94CN2800	837	535.1
64	550	NAVAL BASE	94CS8540	1,639	531.9
65	103	O_CONNER	94CN390	200	530.7
66	721	HOMEPORT	94CS4665	432	530.7
67	259	GANADO	94CN5815	600	527.7
68	1146	EDNA	94CN5765	1,263	523.7
69	0	RIO PECOS	97SA513	10	514.5
70	681	POLK AVENUE	94SB4740	1,707	513.4
71	19	SARAGOSA	97SA14080	28	508.3
72	528	KINGSVILLE	94CS1130	2,226	506.8
73	490	BLACK BAYOU	94CN1120	366	504.5
74	104	MOORE FIELD	94SB3120	156	494.6
75	1231	LA PRYOR	94LA1835	271	493.1
76	1170	BAIRD	97AB5120	558	492.0
77	484	PHARAOH	94CS5185	1,231	489.0
78	246	BRUNI	94LA1100	588	488.9
79	139	POWELL FIELD	97SA2529	12	488.8
80	214	CLARKWOOD	94CS7230	623	487.0
81	346	DARST	94CN1610	68	485.9
82	87	RAYMONDVILLE #2	94SB3250	28	485.4
83	355	CRYSTAL CITY	94LA1425	1,190	485.3
84	649	PHARAOH	94CS1365	683	483.3
85	232	VALENTINE	97SA6325	585	482.5
86	1182	HAMLIN	97AB3270	877	480.3
87	375	PLEASANTON	94LA9475	1,378	479.7
88	662	MOORE FIELD	94SB3110	728	478.9
89	55	PREMONT	94LA2730	199	477.4
90	245	SEAWALL	94CS9325	1,595	476.3
91	150	CONTINENTAL	94SB4880	72	467.3

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIDI Ranking	2022 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIDI Value
92	326	GOODWIN	94SB4390	423	466.5
93	253	SOUTH PADRE ISLAND	94SB5850	1,379	465.8
94	217	RAYMONDVILLE #1	94SB630	788	464.7
95	179	BANQUETTE	94CS9000	462	461.9
96	405	MCCOLL ROAD	94SB4910	337	460.2
97	1174	NORTH MCALLEN	94SB4995	2,477	445.8
98	762	ELDORADO	97SA5310	188	442.5
99	61	CLARKWOOD	94CS5525	629	439.5
100	977	CLARKWOOD	94CS2170	808	435.3
101	1239	HAMLIN	97AB3775	254	435.0
102	42	BRUNI	94LA5440	118	433.9
103	339	GREENLAKE	94CN2750	75	432.0
104	381	EAST HARRISON	94SB3950	810	430.9
105	123	BLESSING	94CN1030	286	430.3
106	9	RANDADO	94LA8360	168	429.6
107	411	POLK AVENUE	94SB4180	1,309	429.5
108	204	PREMONT	94LA6610	838	425.7
109	1028	LA GRULLA	94SB6150	1,629	422.3
110	38	CRESTONIO	94LA270	648	421.7
111	565	REFUGIO	94CN1210	190	420.4
112	496	KARNES CITY	94CN2315	1,019	416.7
113	285	SOUTH SANTA ROSA	94SB1235	656	415.9
114	369	PALMVIEW	94SB3930	1,166	414.4
115	1303	ASPR CONTINENTAL	97AB3830	27	413.4
116	740	CRESTONIO	94LA6660	782	412.6
117	324	NORTH PADRE ISLAND	94CS1010	2,409	411.9
118	563	SOUTHSIDE	94CS7905	1,826	410.5
119	393	WAGGONER	97AB5900	27	408.4
120	524	PORTLAND	94CS6505	1,843	408.0
121	24	TATTON	94CN8490	291	406.9
122	32	GREGORY	94CS5900	119	406.8
123	973	POLK AVENUE	94SB4520	1,072	406.7
124	408	BEEVILLE	94CN1760	1,845	404.4
125	830	MILO	94LA3060	126	401.7
126	548	KITTIE WEST	94CN3760	244	399.3
127	39	GREENLAKE	94CN2740	382	399.0
128	215	MAGNOLIA	94CN315	83	398.1
129	101	NORTH PADRE ISLAND	94CS5170	875	397.5
130	462	BROWNSVILLE	94SB4280	332	396.8
131	184	EDROY	94CS6990	290	395.0
132	183	LOS FRESNOS	94SB2160	1,944	392.8
133	595	RACHAL	94LA6595	357	387.3
134	403	BEEVILLE	94CN8090	1,400	385.5
135	643	PHARAOH	94CS1185	1,403	385.1
136	223	PALMHURST	94SB3890	1,864	384.5
137	445	CITRUS CITY	94SB3470	1,809	383.8
138	436	BROWNSVILLE	94SB4290	491	382.3
139	188	LOS FRESNOS	94SB4315	1,340	380.6
140	81	NORTH PADRE ISLAND	94CS720	1,455	379.2

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIDI Ranking	2022 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIDI Value
141	317	FREER	94LA2900	166	378.0
142	276	BLACK CAT	94CN3000	1,656	377.5
143	18	CHARLOTTE	94LA2780	35	377.0
144	58	WADSWORTH	94CN8630	689	374.8
145	387	PALACIOS	94CN6840	1,535	372.6
146	316	BIG OAK	94CN420	344	372.1
147	109	PARKER	94CN9010	22	371.5
148	775	SANTA RITA	97SA1105	49	370.6
149	687	MAYBERRY	94SB1790	2,662	369.4
150	1276	BRONTE	97SA4160	224	363.6
151	470	CRYSTAL CITY	94LA8380	1,340	360.6
152	106	SAN YGNACIO	94LA16060	538	358.8
153	222	ASPHALT MINES	94LA500	43	356.5
154	292	AB ELM CREEK	97AB1820	100	355.0
155	647	CASA BLANCA	94CS1300	285	354.9
156	271	RIO RICO	94SB8290	335	353.2
157	221	EDROY	94CS6980	196	351.9
158	803	MAGRUDER	94CN6690	750	350.1
159	84	UNITEC	94LA3085	113	349.0
160	443	BEEVILLE	94CN8510	814	348.2
161	1225	RODD FIELD	94CS2190	98	347.4
162	51	NAVAL BASE	94CS7950	814	344.6
163	3	BERCLAIR	94CN990	26	342.3
164	386	HAMLIN SHELL	97AB6330	24	341.9
165	856	ENCINAL	94LA2160	238	341.6
166	757	HOLCOMB	94LA2240	463	339.3
167	88	SHROPSHIRE	94CN1240	74	334.8
168	707	BLACK CAT	94CN4525	122	333.1
169	683	BROOKHOLLOW	94CN8950	923	330.0
170	288	FLOMOT	97AB1852	76	329.4
171	#N/A	MINES ROAD	94LA3680	316	329.4
172	113	FREISS RANCH	97SA4870	100	329.2
173	1133	NORTH MCALLEN	94SB9640	1,533	326.9
174	1064	NORTH MCALLEN	94SB9660	2,174	326.8
175	212	EOLA	97SA4950	207	323.4
176	502	AMISTAD DAM	94LA5450	786	322.6
177	916	MIDWAY LANE	97SA3440	56	318.9
178	667	LA GRULLA	94SB5005	1,244	318.3
179	1010	BRONTE	97SA3590	194	318.1
180	734	HIGHWAY 9	94CS6780	752	317.9
181	900	WEST MCALLEN	94SB4535	3,065	317.9
182	696	MORAN	97AB2108	306	317.8
183	374	VILLA CAVAZOS	94SB1980	1,851	316.2
184	835	KITTIE WEST	94CN3765	323	316.0
185	178	ELSA	94SB710	2,463	314.9
186	482	LAGUNA	94CS9065	2,367	313.1
187	343	PHARAOH	94CS1285	1,779	310.9
188	63	FT CHADBOURNE	97SA6515	90	309.8
189	860	SARAGOSA	97SA1552	778	308.6

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIDI Ranking	2022 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIDI Value
190	1088	QUANAH	97AB3975	212	307.8
191	125	PLACEDO	94CN7980	415	304.5
192	147	MATHIS	94CS2870	876	303.6
193	5	RAYMONDVILLE #2	94SB3170	778	303.0
194	894	MESQUITE	94SB2900	950	302.3
195	1081	STEAMBOAT	97AB12515	68	300.3
196	53	MATHIS	94CS340	1,423	298.6
197	476	DEVINE	94LA7100	1,018	297.6
198	1181	SA AVENUE N	97SA1655	485	296.9
199	1107	EDNA	94CN5775	503	295.1
200	334	BROOKHOLLOW	94CN7580	507	294.3
201	694	MEDIO CREEK	94CN1380	800	293.9
202	1073	SOUTH MCALLEN	94SB3850	1,370	293.7
203	219	PORTLAND	94CS9370	2,108	292.2
204	128	WEIL TRACT (138/12KV)	94CS5405	185	291.5
205	895	KLEBERG	94CS6000	1,381	291.0
206	100	THREE RIVERS	94CN5100	76	289.2
207	782	BEEVILLE	94CN490	945	288.2
208	138	PORTLAND	94CS9290	1,796	287.3
209	942	YELLOW JACKET	97SA7935	796	285.1
210	567	FULTON	94CS9050	1,624	281.7
211	514	BUENA VISTA	94LA9035	2,101	280.8
212	776	PREMONT	94LA2720	761	280.0
213	158	HALL ACRES ROAD	94SB5585	1,643	279.9
214	404	PAULANN	97SA6280	336	278.7
215	33	PREMONT	94LA6570	822	278.1
216	518	TUSCOLA	97AB3730	1,204	277.9
217	197	VILLA CAVAZOS	94SB7615	1,123	277.6
218	431	UVALDE	94LA540	1,962	277.3
219	1016	MAYO	94CS500	25	277.2
220	731	UVALDE	94LA550	741	277.0
221	279	LIVE OAK	94CS1090	306	276.9
222	927	TANKERSLY (CVEC)	97SA5260	481	276.1
223	819	EL CAMPO	94CN7260	531	274.0
224	527	EL GATO	94SB890	3,102	273.9
225	492	HAINE DRIVE	94SB8065	1,402	272.2
226	8	CHERRY CREEK TAP	97SA485	50	271.0
227	756	MILO	94LA3065	34	270.9
228	915	PALMHURST	94SB2525	2,327	270.7
229	417	PHARR	94SB1640	1,462	270.6
230	695	BROOKHOLLOW	94CN8960	602	270.3
231	390	VICTORIA POWER PLANT	94CN7600	163	270.0
232	746	STAFFORD HILL	94CN1550	147	269.7
233	187	PALACIOS	94CN6830	826	269.2
234	717	BEEVILLE	94CN2200	719	268.8
235	152	GREGORY	94CS8560	254	267.1
236	833	SAN BENITO	94SB3860	255	266.5
237	174	ARANSAS PASS	94CS590	465	266.3
238	980	SAN BENITO	94SB3910	677	265.8

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIDI Ranking	2022 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIDI Value
239	195	PALMVIEW	94SB6790	2,648	263.5
240	69	FASHING	94CN360	34	263.4
241	1042	SOUTH MCALLEN	94SB3790	1,459	263.2
242	682	YORKTOWN	94CN8380	784	263.1
243	1004	MARKHAM	94CN5550	20	262.1
244	220	CAUSEWAY	94SB4765	671	261.4
245	774	RIO GRANDE CITY	94SB3740	2,397	260.5
246	745	WESLACO UNIT	94SB8610	1,188	259.7
247	433	DEVINE	94LA7090	1,083	258.9
248	632	HALL ACRES ROAD	94SB3670	1,330	257.2
249	277	PIRATE	94CS3490	377	257.2
250	939	WESLACO UNIT	94SB9805	2,299	257.0
251	1008	AB COUNTRY CLUB	97AB4725	236	256.1
252	329	BLESSING	94CN8790	771	254.5
253	286	SOUTHSIDE	94CS8055	853	253.3
254	205	PORT ISABEL S.S.	94SB3760	800	252.9
255	117	POLK AVENUE	94SB4900	1,919	251.5
256	328	WEST OSO	94CS9090	1,675	251.3
257	684	WINTERS	97SA3765	805	251.2
258	360	HEARN ROAD	94CS8980	1,239	251.0
259	325	CITRUS CITY	94SB5070	1,071	251.0
260	473	DEVINE	94LA8100	1,635	250.9
261	1041	ROARING SPRINGS	97AB2065	217	249.4
262	796	DARST	94CN1845	186	248.8
263	134	MAYO	94CS625	205	248.6
264	884	EAGLE PASS CITY	94LA2650	1,390	248.3
265	621	SUN VALLEY	97SA4300	59	247.4
266	497	CAUSEWAY	94SB4795	372	246.9
267	459	WEST MCALLEN	94SB4505	1,898	246.8
268	37	NORTH ALAMO	94SB4370	1,664	245.5
269	739	PHARR	94SB1645	1,741	245.4
270	203	FALFURRIAS	94LA2830	1,532	243.6
271	186	LIVE OAK	94CS1080	2,614	243.1
272	234	PALMHURST	94SB2820	1,866	242.9
273	4	MATHIS	94CS1410	468	242.7
274	50	ALAZAN	94CS620	188	241.8
275	264	WOODSBORO	94CS8330	302	241.7
276	357	HOLLY	94CS7740	2,210	241.0
277	520	ANSON 12KV	97AB6635	401	239.3
278	655	CARRIZO SPRINGS	94LA750	607	239.3
279	820	OLMITO	94SB905	1,666	238.5
280	247	GARWOOD CITY	94CN2570	144	238.2
281	923	TANKERSLY (CVEC)	97SA5265	373	237.8
282	839	SA GRAPE CREEK	97SA4700	753	237.1
283	54	INGLESIDE CITY	94CS8050	1,287	236.8
284	161	MCKENZIE ROAD	94CS140	303	236.4
285	429	PLEASANTON	94LA120	1,248	236.1
286	115	MESQUITE	94SB3360	1,025	234.8
287	1012	SA LAKE DR	97SA5865	1,063	234.5

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIDI Ranking	2022 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIDI Value
288	1101	SIERRA VISTA	94LA8205	1,343	233.1
289	251	SOUTHSIDE	94CS7995	1,555	232.6
290	767	CEDAR GAP (TEC)	97AB4115	974	232.4
291	825	PALMVIEW	94SB9685	2,967	231.6
292	26	MCELROY	97SA5165	94	231.5
293	701	CATARINA	94LA2380	199	231.4
294	764	NORTH EDINBURG	94SB560	2,222	231.3
295	202	INDIAN MESA	97SA2695	90	230.8
296	448	LIVE OAK	94CS1070	2,625	229.0
297	1199	HEINES	94CS3515	1,308	228.9
298	424	POLK AVENUE	94SB4190	1,747	228.6
299	99	EAGLE LAKE	94CN9455	615	228.0
300	136	WADSWORTH	94CN7660	1,525	227.3
301	808	BAY CITY	94CN1110	1,243	227.3
302	254	INDIAN MESA	97SA2690	146	226.5
303	1266	HAINE DRIVE	94SB9240	36	224.4
304	1103	ROARING SPRINGS	97AB6155	30	223.8
305	869	ELSA	94SB690	2,439	223.7
306	66	PUEBLO	94LA95	1,152	223.4
307	151	PAWNEE (STEC OWNED)	94CN22202	203	223.0
308	1037	MESQUITE	94SB8340	836	222.7
309	948	BUSH KNOB	97AB5200	309	222.1
310	519	KINGSVILLE	94CS1660	1,966	221.6
311	885	ESCONDIDO	94LA5730	2,802	220.9
312	603	ARANSAS PASS	94CS1250	668	220.7
313	44	SAND ROAD	97AB5195	257	220.6
314	1018	PORT ARANSAS	94CS3030	978	217.5
315	114	ROUNDTOP	97AB4490	51	217.4
316	551	AFTON	97AB2310	250	217.0
317	758	SOUTH EAST EDINBURG	94SB5045	1,831	216.7
318	363	EAGLE LAKE	94CN310	728	216.6
319	871	SHARYLAND	94SB5105	2,073	215.3
320	457	HOLLY	94CS7620	2,824	215.1
321	858	MARKHAM	94CN6440	471	213.8
322	209	SOUTHSIDE	94CS7925	1,149	212.0
323	454	UVALDE	94LA6620	2,177	210.6
324	693	CLARKWOOD	94CS7220	929	210.2
325	182	PICACHO	94LA630	396	208.4
326	41	GOODLETT	97AB12205	49	207.3
327	638	GRETA	94CN7890	239	206.1
328	241	HIDALGO	94SB3400	880	205.8
329	947	SHARYLAND	94SB2150	895	205.6
330	988	QUANAH	97AB100	92	204.2
331	953	SHARYLAND	94SB5635	2,325	203.9
332	110	POLK AVENUE	94SB4170	1,479	203.9
333	594	SOUTHSIDE	94CS7955	1,063	203.8
334	31	MCCAMEY	97SA2415	79	203.6
335	964	ROCKSPRINGS	94LA2600	354	202.3
336	181	HAROLD	97AB1495	24	202.0

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIDI Ranking	2022 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIDI Value
337	907	HOLLY	94CS5820	900	201.9
338	370	CONTINENTAL	94SB4080	67	200.4
339	625	BROOKHOLLOW	94CN7190	280	198.9
340	494	JOURDANTON	94LA7880	595	198.8
341	1071	BALLINGER	97SA4395	528	197.9
342	608	GATEWAY	94LA390	2,172	197.7
343	168	LOS FRESNOS	94SB7270	2,432	196.5
344	1141	VALADEZ	94CS2500	2,578	195.8
345	478	AIRLINE	94CS7280	645	195.2
346	440	SAND CRAB	94CN6800	1,150	195.2
347	40	MCCAMEY	97SA2830	96	194.9
348	82	ALICE	94LA1770	1,660	194.2
349	738	HIGHWAY 9	94CS7200	645	194.2
350	786	CLOSNOR	94SB4100	2,138	194.0
351	1264	FLOMOT	97AB81335	30	192.1
352	93	STAFFORD HILL	94CN9955	73	192.0
353	275	MERTZON (CVEC)	97SA2905	594	191.1
354	441	LAGUNA	94CS9590	2,372	189.7
355	1059	DIMMIT	94LA5545	573	187.9
356	#N/A	MATADOR	97AB13495	504	187.1
357	703	BEEVILLE	94CN2380	215	186.6
358	857	ALPINE 12KV	97SA6825	1,557	185.5
359	228	PARKER	94CN9260	129	183.1
360	1248	MATADOR	97AB3090	315	183.0
361	971	AB RAINEY CREEK	97AB4550	983	181.9
362	627	HAINE DRIVE	94SB270	1,181	181.8
363	882	RANKIN	97SA5735	193	181.1
364	367	PLEASANTON	94LA2080	1,746	180.3
365	67	ARCADIA	94CS1440	1,659	179.9
366	406	HARLINGEN SWITCH	94SB4090	2,332	178.9
367	399	BONNIEVIEW	94CS8020	552	178.8
368	309	HASKELL 12KV	97AB3495	807	178.4
369	300	NORTH MERCEDES	94SB3770	1,913	176.8
370	91	SARAGOSA	97SA1590	43	176.5
371	1002	TATTON	94CS8200	1,269	176.5
372	540	CHARLOTTE	94LA1960	498	176.4
373	552	COTULLA	94LA460	508	175.4
374	295	DEL RIO CITY	94LA420	2,054	174.8
375	318	THOMASTON	94CN9580	50	174.7
376	747	SEAWALL	94CS9420	815	174.5
377	797	KLEBERG	94CS6410	252	173.3
378	65	SPUDDER FLAT	97SA4175	32	173.2
379	1083	BRYANTS RANCH	97SA205	21	173.0
380	425	RIO GRANDE CITY	94SB3230	2,699	172.2
381	376	HIGHWAY 9	94CS6720	1,285	171.0
382	171	NORTH MERCEDES	94SB4860	1,516	169.2
383	330	CARANCAHUA	94CN5870	472	169.0
384	1062	SOUTH EAST EDINBURG	94SB4570	1,920	168.8
385	1221	SOUTH MCALLEN	94SB3640	196	168.3

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIDI Ranking	2022 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIDI Value
386	345	FREER	94LA5200	1,011	168.3
387	661	MUNDAY REA (BKEC)	97AB2015	22	168.2
388	419	CABANISS	94CS240	1,401	168.0
389	1145	SA CONCHO	97SA1705	925	167.8
390	331	HARLINGEN SWITCH	94SB320	1,747	167.4
391	489	BAY CITY	94CN5960	400	167.4
392	165	BAY CITY	94CN7480	375	166.8
393	689	MOCKINGBIRD	94CN400	1,013	166.6
394	306	RISING STAR	97AB5080	615	166.5
395	1095	MCCOLL ROAD	94SB2810	2,311	165.8
396	263	OLMITO	94SB715	683	165.8
397	526	GARCENO	94SB2130	1,811	165.7
398	1048	SONORA ATLANTIC (SWTEC)	97SA4415	31	164.6
399	1187	PERKINS PROTHO	97SA3180	19	164.5
400	544	FT DAVIS	97SA4515	1,027	164.4
401	516	ARMSTRONG	94CS6050	85	163.9
402	314	EAST HARRISON	94SB3080	485	163.5
403	446	CROSS PLAINS	97AB2915	786	162.5
404	266	PLEASANTON	94LA9505	1,822	162.3
405	859	NORTH VICTORIA	94CN7440	1,660	162.2
406	450	SOUTH EAST EDINBURG	94SB4550	728	162.1
407	199	SANTA ANNA	97SA3415	340	162.0
408	236	PUEBLO	94LA9870	1,774	161.8
409	656	MORRIS STREET	94CS8830	1,486	161.8
410	466	LAREDO PLANT	94LA8695	1,606	161.1
411	395	SA MATHIS FIELD	97SA4790	196	161.1
412	304	LOS FRESNOS	94SB5335	2,752	159.6
413	959	QUANAH	97AB1830	620	158.8
414	750	WESMER	94SB7760	1,447	157.6
415	418	CROSS PLAINS	97AB1795	446	157.4
416	906	YOUNG	94SB7145	2,859	157.4
417	1045	TRADE ZONE	94SB2060	515	157.1
418	28	SAND CRAB	94CN9235	386	157.0
419	504	EL GATO	94SB720	2,575	156.7
420	458	PORT ARANSAS	94CS1000	1,753	156.4
421	49	BAY CITY	94CN6670	1,624	154.9
422	479	SAN BENITO	94SB4030	1,731	154.2
423	1054	SA MATHIS FIELD	97SA5100	329	153.7
424	121	ELSA	94SB3520	1,029	153.6
425	298	WESMER	94SB4480	1,151	153.5
426	1160	ALICE	94LA1790	451	153.2
427	398	GATEWAY	94LA3595	1,494	153.0
428	525	VILLA CAVAZOS	94SB5680	2,030	152.1
429	769	RESACA	94SB7110	1,738	151.0
430	847	AIRLINE	94CS6970	1,410	150.2
431	555	ANSON 12KV	97AB6630	717	150.1
432	589	TURKEY	97AB3825	387	149.5
433	216	LYTLE	94LA2850	754	149.0
434	137	FULTON	94CS2020	3,614	148.9

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIDI Ranking	2022 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIDI Value
435	83	ROBY	97AB3795	77	147.8
436	36	SPUDDER FLAT	97SA4180	60	147.7
437	1218	AIRLINE	94CS7270	1,035	146.6
438	73	HIGHWAY 9	94CS6760	1,034	146.4
439	290	CABANISS	94CS75	2,251	145.9
440	396	JOURDANTON	94LA250	780	145.6
441	#N/A	BENTSEN	94SBSH212	10	145.2
442	645	AIRLINE	94CS8370	271	145.2
443	799	LAREDO PLANT	94LA8565	1,458	144.7
444	1039	MAYBERRY	94SB3010	342	144.4
445	1289	MINES ROAD	94LA8770	276	144.4
446	85	RIO BRAVO	94LA1130	1,055	144.3
447	394	HARLINGEN SWITCH	94SB4230	1,357	143.9
448	787	RAYMONDVILLE #2	94SB3240	925	143.7
449	1253	SA SOUTH	97SA3990	762	143.1
450	711	PRIMERA	94SB6085	1,494	142.9
451	256	MELVIN	97SA4955	84	142.7
452	688	PECAN BAYOU	97AB6810	492	142.2
453	879	LAREDO PLANT	94LA9305	1,075	141.6
454	574	WEST OSO	94CS9095	1,665	141.4
455	1003	EL CAMPO	94CN6370	790	140.7
456	566	BANDERA ELECTRIC (LEAKEY)	94LAL30	276	140.5
457	351	EL GATO	94SB910	2,653	139.5
458	287	BLACK CAT	94CN2960	2,190	139.3
459	162	HEARN ROAD	94CS8990	1,428	138.7
460	986	HARLINGEN	94SB660	1,269	138.2
461	1005	PALMHURST	94SB1300	2,355	137.7
462	903	ANNA STREET	94LA850	1,577	137.5
463	305	WESMER	94SB1850	474	136.5
464	382	NORTH WESLACO	94SB4810	1,558	136.2
465	321	MAYBERRY	94SB5770	950	135.7
466	1260	AB MAPLE ST	97AB5755	1,304	135.3
467	282	SABINAL	94LA485	501	135.2
468	578	EAGLE LAKE	94CN320	623	133.9
469	815	WESMER	94SB6900	103	133.5
470	891	KLEIMANN	94CN425	612	133.5
471	1023	WASHINGTON STREET	94LA2350	3,033	132.9
472	508	HOLLY	94CS9675	1,633	131.8
473	651	PORTLAND	94CS9270	1,853	131.5
474	665	UVALDE	94LA5060	673	131.4
475	226	CROSS PLAINS	97AB2920	557	131.1
476	675	NORTH MCALLEN	94SB5055	3,324	130.7
477	353	NIXON	94CN3300	596	130.6
478	809	CARRIZO SPRINGS	94LA370	546	129.5
479	685	STAMFORD PUMP	97AB3930	39	129.4
480	249	ARCADIA	94CS1450	1,645	129.3
481	190	EAGLE PASS CITY	94LA2745	942	129.0
482	700	WASHINGTON STREET	94LA6525	2,736	128.5
483	613	REFUGIO	94CN1040	162	128.0

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIDI Ranking	2022 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIDI Value
484	410	CLARKWOOD	94CS9570	1,236	127.7
485	1029	SHARYLAND	94SB2035	884	127.4
486	342	PAULANN	97SA6285	66	127.3
487	16	BLESSING	94CN8780	59	127.3
488	715	ANNA STREET	94LA900	2,813	127.2
489	848	SAND CRAB	94CN6735	1,324	126.5
490	111	BLACK CAT	94CN3175	502	126.3
491	768	WEAVER ROAD	94CN1910	27	126.3
492	1013	STADIUM	94LA6950	425	125.1
493	401	MAYBERRY	94SB5340	39	125.0
494	1272	MINES ROAD	94LA3745	2,155	124.6
495	961	MORRIS STREET	94CS8840	735	124.0
496	861	SHARYLAND	94SB6745	2,349	123.8
497	30	SAN BENITO	94SB4135	1,398	123.2
498	1009	ALICE	94LA2540	960	122.7
499	539	BUENA VISTA	94LA8965	928	122.3
500	790	RUSSEK STREET	97SA11370	203	122.3
501	22	THREE RIVERS	94CN8430	194	122.0
502	1212	ROCKSPRINGS	94LA8040	326	120.9
503	510	PECAN BAYOU	97AB6815	1,874	120.9
504	160	WEST HARLINGEN	94SB3720	1,314	120.1
505	196	CHARLOTTE	94LA2790	203	119.8
506	347	EL GATO	94SB780	2,183	119.5
507	1056	LA GRULLA	94SB3045	1,357	119.2
508	297	MAGRUDER	94CN7870	1,257	118.8
509	1140	CLYDE	97AB1755	132	118.7
510	456	PICACHO	94LA1230	1,064	118.6
511	332	ARCADIA	94CS8570	1,448	117.7
512	732	NORTH MCALLEN	94SB2750	3,223	116.6
513	1238	RAYMONDVILLE #2	94SB4160	326	115.8
514	175	PHARR	94SB1620	1,255	115.1
515	17	TWILIGHT TRAIL	97AB11500	1,025	113.8
516	430	TAFT	94CS1180	950	113.8
517	789	WEST MCALLEN	94SB4515	885	113.7
518	658	PORT ISABEL S.S.	94SB4070	264	113.4
519	863	SHEFFIELD	97SA6430	205	113.1
520	897	PALMHURST	94SB2535	3,204	112.8
521	185	HIDALGO	94SB4845	462	112.4
522	301	CAUSEWAY	94SB9880	1,228	112.3
523	333	IRAAN	97SA2055	134	111.6
524	500	MORRIS STREET	94CS8715	1,569	111.3
525	169	DEL RIO CITY	94LA430	1,775	110.9
526	615	WEAVER ROAD	94CN1900	66	110.5
527	372	BIG WELLS	94LA1570	426	109.2
528	337	SAN BENITO	94SB3920	1,663	108.6
529	112	GREGORY	94CS5920	870	108.6
530	499	MAGRUDER	94CN7690	529	108.4
531	68	CHILLICOTHE	97AB4530	487	108.1
532	126	PRAIRIE PUMP	94CN1940	95	108.0

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIDI Ranking	2022 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIDI Value
533	1294	WASHINGTON STREET	94LA2310	44	107.7
534	849	CLYDE	97AB3630	651	107.6
535	#N/A	SANTO NINO	94LAT000G2	1,490	107.3
536	866	ALICE	94LA1780	516	106.9
537	349	SOUTHSIDE	94CS8025	1,148	106.9
538	1162	ALBANY	97AB3640	337	106.1
539	934	SOUTH EAST EDINBURG	94SB4015	480	106.0
540	1205	RANKIN	97SA7425	120	105.8
541	#N/A	GONZALES	97SA9650	271	105.3
542	449	THROCKMORTON	97AB2090	75	105.3
543	575	HAINE DRIVE	94SB3490	1,192	104.9
544	811	CASA BLANCA	94CS4170	1,166	104.6
545	45	TYNAN	94CS1855	133	104.1
546	635	READING	94LA1275	78	104.0
547	78	CAMPWOOD	94LA2610	1,027	104.0
548	777	ARCADIA	94CS5030	1,573	103.5
549	1297	WASHINGTON STREET	94LA2320	37	103.0
550	1288	WASHINGTON STREET	94LA2330	57	103.0
551	1293	WASHINGTON STREET	94LA6890	19	103.0
552	#N/A	SANTO NINO	94LAT000G8	882	102.0
553	553	MORRIS STREET	94CS7625	496	101.7
554	62	WEIL TRACT (138/12KV)	94CS1990	1,344	101.7
555	785	FALFURRIAS	94LA1070	924	101.6
556	122	FALFURRIAS	94LA5210	1,176	101.6
557	617	DEL MAR	94LA490	802	101.6
558	816	HALL ACRES ROAD	94SB3460	3,201	101.3
559	517	YORKTOWN	94CN8420	652	101.1
560	1124	AB MAPLE ST	97AB4070	1,052	101.1
561	1069	AB MAPLE ST	97AB5750	470	100.9
562	420	GOODWIN	94SB4380	1,755	100.3
563	577	HASKELL 12KV	97AB5240	642	100.2
564	670	RESACA	94SB8700	1,126	99.9
565	936	KARNES CITY	94CN2325	668	99.8
566	1211	ROCHESTER	97AB3290	81	99.8
567	609	SOUTH SANTA ROSA	94SB1240	1,723	99.3
568	924	VERHALEN	97SA14765	28	99.3
569	368	VALADEZ	94CS9890	1,902	99.3
570	554	SOUTH MISSION	94SB3620	2,129	99.2
571	521	MCCAMEY	97SA2855	492	99.0
572	13	TRENT	97AB2850	19	98.7
573	1265	ESCONDIDO	94LA2035	462	98.7
574	538	AB SHELTON ST	97AB3660	632	98.4
575	1050	LANTANA	94CS4095	194	98.3
576	488	RODD FIELD	94CS205	2,217	97.6
577	455	ALPINE 12KV	97SA3155	1,630	97.6
578	522	GOLIAD	94CN8220	1,066	97.5
579	200	ARANSAS PASS	94CS8280	628	96.8
580	875	PROGRESO	94SB2495	1,711	96.5
581	1049	POLK AVENUE	94SB4600	162	96.3

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIDI Ranking	2022 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIDI Value
582	240	HALL ACRES ROAD	94SB5465	1,434	95.8
583	501	DIMMIT	94LA4120	1,273	95.6
584	1026	DILLEY	94LA6400	864	95.2
585	60	KEPLER	94CS2665	37	95.1
586	979	NORTH VICTORIA	94CN2240	744	95.0
587	159	LEARY LANE	94CN1430	1,906	94.8
588	1130	SHARYLAND	94SB2020	1,880	94.7
589	143	STAMFORD	97AB2815	700	93.8
590	145	RACHAL	94LA8145	381	93.7
591	1151	SOUTHSIDE	94CS5345	501	93.7
592	90	PLACEDO	94CN7970	494	92.7
593	486	SOUTHSIDE	94CS8035	1,089	91.7
594	1027	RANKIN	97SA6400	58	91.3
595	156	FREER	94LA6320	169	91.3
596	79	INGLESIDE CITY	94CS6040	438	91.1
597	591	LEARY LANE	94CN7530	3,283	90.9
598	1227	MORRIS STREET	94CS8850	396	90.7
599	133	TAFT	94CS5230	837	90.6
600	1270	STERLING CITY	97SA11040	547	90.3
601	452	VICTORIA POWER PLANT	94CN8170	840	90.2
602	568	SOUTH MCALLEN	94SB5065	184	90.2
603	471	STADIUM	94LA7810	1,338	90.1
604	904	GARCENO	94SB2165	1,980	89.8
605	1036	WINTERS	97SA2113	792	89.7
606	660	NIXON	94CN6630	645	89.6
607	841	EL CAMPO	94CN2860	1,524	89.1
608	1131	AB COUNTRY CLUB	97AB4855	938	88.7
609	283	BOBCAT HILLS	97SA6655	70	88.6
610	850	CRYSTAL CITY	94LA2170	740	88.3
611	586	NIXON	94CN2025	535	88.2
612	864	MCKENZIE ROAD	94CS3330	2,409	88.1
613	335	PROGRESO	94SB2515	210	88.0
614	464	NORDHEIM	94CN3380	177	87.9
615	107	MAYBERRY	94SB3160	555	87.8
616	956	HALL ACRES ROAD	94SB4895	883	87.4
617	166	BAY CITY	94CN2700	1,064	87.2
618	844	HALL ACRES ROAD	94SB9595	1,571	87.0
619	993	RANKIN	97SA6405	357	86.6
620	890	PUEBLO	94LA130	1,789	86.5
621	315	HIDALGO	94SB3680	356	86.5
622	189	PUEBLO	94LA275	2,945	86.4
623	213	VICTORIA POWER PLANT	94CN1390	1,079	86.4
624	1136	ROCKPORT	94CS5950	559	85.9
625	379	HAINE DRIVE	94SB9700	1,150	85.9
626	1278	IRAAN	97SA4305	247	85.7
627	308	FULTON	94CS440	2,116	85.4
628	2	MINES ROAD	94LA7235	46	85.4
629	865	SKIDMORE	94CS600	371	84.9
630	570	BEN FICKLIN	97SA6175	592	84.8

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIDI Ranking	2022 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIDI Value
631	742	SA GRAPE CREEK	97SA5365	866	84.4
632	674	LEARY LANE	94CN1890	1,633	83.9
633	421	MORRIS STREET	94CS7465	789	83.4
634	783	PANTERA	94SB1765	931	82.7
635	131	PUTNAM	97AB2129	193	82.6
636	728	MAGRUDER	94CN245	1,246	82.5
637	704	EL CAMPO	94CN7710	1,060	81.9
638	822	BENTSEN	94SB5H215	56	81.8
639	384	PALMHURST	94SB2530	2,198	81.8
640	845	AB ELM CREEK	97AB5045	386	81.7
641	1085	CISCO	97AB7400	839	81.5
642	598	THROCKMORTON	97AB3190	632	81.5
643	579	ARCADIA	94CS1460	2,439	81.3
644	583	RODD FIELD	94CS1730	2,217	80.4
645	1139	AB VOGEL ST	97AB4650	802	80.3
646	194	ZAPATA	94LA2710	1,369	80.0
647	505	SA NORTH	97SA3115	585	79.9
648	361	NORTH MCALLEN	94SB3830	1,404	79.5
649	483	TYNAN	94CS4000	28	78.9
650	1100	MUNDAY	97AB3365	413	78.9
651	27	CHILLICOTHE	97AB4525	124	78.7
652	432	STADIUM	94LA7800	688	78.3
653	909	AB ELM CREEK	97AB1815	491	78.3
654	931	LAS CRUSES	94LA7325	2,764	78.3
655	657	JOURDANTON	94LA5685	340	77.9
656	426	GREENLAKE	94CN2760	1,195	77.7
657	293	WESLACO UNIT	94SB7630	2,697	77.4
658	239	DARST	94CN1265	76	77.3
659	154	HIGHWAY 9	94CS6770	940	77.2
660	584	WEST HARLINGEN	94SB3800	1,419	77.1
661	1077	DEL MAR	94LA10	1,760	77.1
662	0	HOEFFS ROAD	97SA15680	15	76.9
663	826	HOLLY	94CS1370	1,884	76.8
664	952	HEIGHTS	94LA2100	1,988	76.8
665	1304	ABILENE INDUSTRIAL PARK	97AB6600	13	76.7
666	130	SHROPSHIRE	94CN3575	36	76.6
667	127	PORT ARANSAS	94CS6940	1,648	76.4
668	451	FRIO	94LA2270	1,142	76.3
669	925	POWELL FIELD	97SA2528	23	76.3
670	821	AB RAINEY CREEK	97AB4220	223	76.1
671	385	MILO	94LA3070	2,009	75.8
672	155	ALICE	94LA2530	1,491	75.7
673	1109	PHARR	94SB1650	932	75.7
674	380	KNIPPA	94LA6365	343	75.7
675	823	NORTH EDINBURG	94SB3570	1,058	75.6
676	1167	GATEWAY	94LA5055	1,711	75.5
677	509	POINT COMFORT	94CN6060	365	75.5
678	289	FALFURRIAS	94LA1080	464	75.5
679	#N/A	HIDALGO	94SB3970	963	75.4

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIDI Ranking	2022 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIDI Value
680	710	MOORE FIELD	94SB3960	2,175	74.9
681	248	THREE RIVERS	94CN5190	465	74.9
682	1057	GOODWIN	94SB3530	340	74.7
683	943	SOUTH MISSION	94SB3590	555	74.5
684	338	CHOKE CANYON	94CN9255	364	74.0
685	206	EAGLE PASS CITY	94LA2770	2,027	73.6
686	1200	PALMVIEW	94SB9680	1,053	73.5
687	763	REFUGIO	94CN5120	721	73.2
688	1044	KINGSVILLE	94CS1350	395	73.2
689	47	PECOS VALLEY	97SA4075	21	73.0
690	437	HARLINGEN SWITCH	94SB4110	920	72.7
691	135	YORKTOWN	94CN3130	493	72.6
692	423	RISING STAR	97AB5075	680	72.4
693	881	COLLEGE HILLS	97SA6145	979	72.4
694	920	AB CANYON ROCK	97AB5035	836	72.2
695	1299	SANTA RITA	97SA1135	10	72.2
696	344	SHAFTER	97SA5110	46	71.9
697	146	ELSA	94SB3500	1,333	71.8
698	908	EAST HARRISON	94SB4360	1,784	71.4
699	831	AB MCMURRY	97AB4355	986	71.1
700	965	MAGRUDER	94CN6700	1,365	71.0
701	749	SAN DIEGO	94LA1980	621	70.7
702	468	CARRIZO SPRINGS	94LA910	876	70.6
703	870	CABANISS	94CS710	174	69.4
704	472	NORTH MCALLEN	94SB2980	1,911	69.4
705	503	HIGHWAY 9	94CS9830	139	69.3
706	412	ALPINE 12KV	97SA3160	1,094	69.2
707	43	SAN DIEGO	94LA2930	562	69.2
708	244	PORT ISABEL S.S.	94SB3820	1,159	69.1
709	636	ALBANY	97AB3540	628	69.1
710	990	REFUGIO	94CN1170	858	69.0
711	1206	GARCENO	94SB5490	1,476	69.0
712	225	LEARY LANE	94CN1540	792	68.9
713	1186	PADUCAH CITY	97AB1935	286	68.9
714	260	PICACHO	94LA590	408	68.8
715	691	ROCKPORT	94CS5130	571	68.7
716	930	AB ONYX REA	97AB3255	25	68.3
717	144	SINTON	94CS6860	995	68.1
718	243	PORT ARANSAS	94CS990	2,669	68.0
719	770	CITRUS CITY	94SB9775	1,596	67.0
720	840	AB COUNTRY CLUB	97AB4730	542	66.5
721	173	TUSCOLA	97AB3305	1,090	66.4
722	261	SKIDMORE	94CS380	160	66.1
723	1134	GOODWIN	94SB4625	2,358	65.9
724	708	CRYSTAL CITY	94LA7425	449	65.7
725	366	BROWNSVILLE	94SB3050	2,026	65.6
726	878	WESLACO UNIT	94SB8195	1,656	65.6
727	666	WYLIE	97AB2665	1,065	65.3
728	534	NORTH VICTORIA	94CN7430	1,678	65.0

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIDI Ranking	2022 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIDI Value
729	72	GEORGE WEST	94CN1320	690	65.0
730	512	PETTUS	94CN1020	467	64.9
731	976	JOURDANTON	94LA5695	327	64.7
732	1128	UNITEC	94LA5895	37	64.7
733	817	CABANISS	94CS80	102	64.3
734	561	KLEBERG	94CS1560	1,437	64.3
735	752	STADIUM	94LA7490	1,321	64.0
736	637	ALAZAN	94CS2740	36	64.0
737	960	ZAPATA	94LA7330	1,356	63.8
738	877	LEARY LANE	94CN6005	1,382	63.6
739	1214	ZACATE CREEK	94LA2665	1,732	63.6
740	302	DUNE FIELD (N CRANE)	97SA3885	68	63.6
741	469	MCCOLL ROAD	94SB4780	2,009	63.3
742	725	ARCADIA	94CS5020	1,541	63.3
743	267	BRACKETTVILLE	94LA8460	1,196	63.3
744	180	HIGHWAY 9	94CS7210	349	63.1
745	74	ELSA	94SB700	1,543	62.9
746	75	ZAPATA	94LA8300	1,611	62.6
747	1070	AB OIL MILL	97AB3895	117	62.4
748	917	NORTH MCALLEN	94SB5060	2,655	62.0
749	428	MORRIS STREET	94CS2515	1,030	61.9
750	901	FULTON	94CS6070	1,832	61.9
751	587	LAREDO PLANT	94LA8505	1,046	61.8
752	141	MELVIN	97SA940	47	61.5
753	371	WESMER	94SB9705	960	61.1
754	827	EAST HARRISON	94SB3030	680	61.0
755	1154	SA WALNUT ST	97SA4635	1,551	60.9
756	1147	GOODWIN	94SB7380	2,097	60.3
757	753	CITRUS CITY	94SB7985	1,204	60.3
758	427	FT CHADBOURNE	97SA6520	558	59.8
759	1105	GILA	94CS350	304	59.8
760	310	JOSLIN POWER PLANT	94CN8720	24	59.7
761	818	YOUNG	94SB3310	1,864	59.6
762	736	AB OVER STREET 12KV	97AB1635	532	59.6
763	1022	CLOSNER	94SB2945	1,111	59.1
764	164	SOUTHSIDE	94CS5335	1,614	59.0
765	669	AB COUNTRY CLUB	97AB4735	120	58.9
766	975	AB EAST 12KV	97AB5760	216	58.9
767	434	SOUTH SANTA ROSA	94SB1225	867	58.3
768	465	WESMER	94SB4050	1,946	58.1
769	365	HAWLEY	97AB4455	682	58.0
770	922	ANSON REA (SEC)	97AB5215	263	57.9
771	938	TRENT	97AB4245	189	57.6
772	389	DILLEY	94LA510	556	57.4
773	664	JUNCTION	97SA10795	802	57.1
774	1232	AB HARTFORD ST	97AB3820	867	57.1
775	828	MCCOLL ROAD	94SB1655	1,522	57.1
776	673	NORTH VICTORIA	94CN1580	1,008	57.0
777	949	RODD FIELD	94CS3010	2,065	56.5

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIDI Ranking	2022 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIDI Value
778	1252	COLLEGE HILLS	97SA5515	198	56.4
779	257	ARCADIA	94CS6930	1,497	56.2
780	1091	HEIGHTS	94LA6810	2,134	56.2
781	498	PANTERA	94SB1315	1,947	56.1
782	929	BAY CITY	94CN2050	326	56.0
783	56	SAND CRAB	94CN8120	273	55.9
784	814	LA GRULLA	94SB5110	1,038	55.9
785	893	AB SHELTON ST	97AB3050	645	55.7
786	596	RULE	97AB3396	430	55.7
787	836	AB CANYON ROCK	97AB5030	698	55.5
788	397	MERKEL	97AB1895	707	55.4
789	978	LEARY LANE	94CN6175	2,472	54.9
790	1000	DEL MAR	94LA2120	1,365	54.9
791	614	WEST HARLINGEN	94SB4870	1,083	54.8
792	378	HIGHWAY 9	94CS6730	559	54.5
793	98	WEIL TRACT (138/12KV)	94CS2520	87	54.1
794	1157	STAMFORD	97AB6255	424	54.0
795	485	HALL ACRES ROAD	94SB8870	2,526	53.8
796	193	WEST HARLINGEN	94SB3700	2,009	53.7
797	227	BRADY	97SA5015	199	53.3
798	928	AB DYESS 2	97AB6335	356	53.1
799	1115	KNOX CITY	97AB3300	466	53.0
800	766	SA EMERSON ST	97SA4620	429	52.9
801	1019	SOUTH MISSION	94SB5215	1,284	52.9
802	327	WESLACO UNIT	94SB5970	1,979	52.8
803	987	SA WALNUT ST	97SA3925	889	52.6
804	530	SA GRAPE CREEK	97SA5220	715	52.4
805	629	SAN DIEGO	94LA2890	1,020	52.4
806	294	MORRIS STREET	94CS5655	314	52.4
807	1040	SPUR	97AB300	203	52.4
808	634	WEST MCALLEN	94SB4595	1,206	52.4
809	932	NORTH EDINBURG	94SB4240	1,168	52.3
810	336	OLMITO	94SB4275	824	51.9
811	278	GOLIAD	94CN6540	1,251	51.8
812	984	VERNON	97AB1750	253	51.6
813	726	MORAN	97AB2107	207	51.4
814	800	SINTON	94CS360	337	51.3
815	1075	FT DAVIS	97SA3345	540	51.3
816	812	GATEWAY	94LA350	2,040	50.9
817	1240	ANNA STREET	94LA5780	653	50.5
818	698	CONTINENTAL	94SB3650	17	50.5
819	1090	SA AVENUE N	97SA1730	830	50.4
820	319	NORTH ALAMO	94SB3580	1,067	50.3
821	640	AB EAST 12KV	97AB4820	1,118	50.3
822	1031	PRIMERA	94SB7020	1,438	50.0
823	1153	SA SOUTHLAND HILLS	97SA5055	859	49.6
824	359	EAGLE PASS CITY	94LA2510	713	49.4
825	210	MATHIS	94CS1420	920	49.0
826	744	YELLOW JACKET	97SA5505	539	49.0

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIDI Ranking	2022 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIDI Value
827	944	EL CAMPO	94CN5745	951	48.9
828	954	AB WALNUT ST	97AB3785	576	48.9
829	994	RAYMONDVILLE #1	94SB800	744	48.7
830	605	SABINAL	94LA200	444	48.6
831	124	COMSTOCK	94LA230	183	48.5
832	1129	SA CONCHO	97SA3325	293	48.2
833	1096	DEL MAR	94LA220	1,483	48.0
834	163	HOLLY	94CS1480	1,691	47.8
835	663	ROTAN	97AB1860	676	47.4
836	59	CABANISS	94CS615	309	47.3
837	273	WOOLRIDGE	94CS1170	437	47.3
838	1164	CISCO	97AB1020	491	47.2
839	873	CHILDRESS 69	97AB1480	304	46.7
840	198	MORRIS STREET	94CS8820	1,238	46.5
841	1201	TRADE ZONE	94SB2220	66	46.2
842	720	SOUTH EAST EDINBURG	94SB6580	948	46.2
843	1092	UVALDE	94LA9770	1,132	46.0
844	905	MILO	94LA6940	473	45.9
845	1217	CROWELL	97AB3980	475	45.9
846	532	BANQUETTE	94CS130	235	45.6
847	284	BEN FICKLIN	97SA14065	805	45.3
848	802	SOUTHSIDE	94CS8005	744	44.9
849	997	AB ELMDALE	97AB4085	46	44.8
850	438	CLYDE	97AB1760	471	44.8
851	1171	SA JACKSON ST	97SA4685	1,451	44.8
852	620	ANNA STREET	94LA780	466	44.5
853	735	GEORGE WEST	94CN730	877	44.2
854	1198	SA WALNUT ST	97SA3915	711	43.9
855	383	THREE RIVERS	94CN2010	316	43.9
856	#N/A	SANTO NINO	94LAT000F5	1,203	43.8
857	1246	AB ELMDALE	97AB4520	290	43.7
858	968	GILA	94CS7840	769	43.7
859	899	SAND CRAB	94CN8390	537	43.6
860	350	VERNON	97AB4275	589	43.2
861	724	PEARSALL	94LA7050	582	43.1
862	778	STADIUM	94LA8540	1,680	42.8
863	630	AB SHELTON ST	97AB4640	679	42.7
864	970	WASHINGTON STREET	94LA7015	1,556	42.7
865	354	WEST MCALLEN	94SB4815	534	42.6
866	444	JUNCTION	97SA10805	811	42.5
867	211	PIRATE	94CS3380	418	42.4
868	1007	DEL MAR	94LA7930	2,004	42.3
869	348	RUNGE	94CN3250	267	42.3
870	157	DEL RIO CITY	94LA1930	1,582	41.8
871	1	RIO RICO	94SB8330	70	41.7
872	281	GONZALES	97SA15390	1,099	41.6
873	358	CHARLOTTE	94LA8120	245	41.5
874	1080	RAYMONDVILLE #1	94SB620	671	41.5
875	388	PUTNAM	97AB2131	124	41.4

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIDI Ranking	2022 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIDI Value
876	705	READING	94LA1445	532	41.3
877	377	AB SHELTON ST	97AB3435	291	41.2
878	616	JOURDANTON	94LA880	1,158	41.2
879	224	MINES ROAD	94LA1600	908	41.1
880	265	ELDORADO	97SA1845	514	41.0
881	1014	SOUTH MISSION	94SB3940	862	41.0
882	1015	AB MCMURRY	97AB3235	791	40.9
883	1302	SANTA RITA	97SA1140	39	40.9
884	340	POLK AVENUE	94SB4610	157	40.8
885	258	NAVAL BASE	94CS9720	2,693	40.7
886	1053	SA NORTH	97SA3130	235	40.6
887	623	UVALDE	94LA480	579	40.5
888	765	ODEM	94CS2400	316	40.3
889	1143	ALBANY	97AB3655	627	39.6
890	692	MOCKINGBIRD	94CN305	331	39.5
891	542	EAST HARRISON	94SB4310	1,216	39.3
892	320	SOUTHSIDE	94CS8045	969	39.3
893	653	PIRATE	94CS3220	740	39.2
894	1190	EAST HARRISON	94SB4620	783	39.2
895	1079	MCCOLL ROAD	94SB4400	1,448	39.2
896	1247	AB HARTFORD ST	97AB3685	363	39.0
897	515	FULTON	94CS3070	1,584	38.9
898	896	SPUR	97AB5170	392	38.7
899	313	MOCKINGBIRD	94CN370	49	38.6
900	1290	LAS CRUSES	94LA8530	76	38.4
901	487	SINTON	94CS1750	269	38.2
902	362	HAINE DRIVE	94SB9690	626	38.0
903	477	BAIRD	97AB5125	501	37.8
904	1195	MARFA	97SA1900	807	37.4
905	733	YOUNG	94SB5135	1,285	37.4
906	982	MERTZON (CVEC)	97SA1530	338	37.3
907	1223	SA SOUTH	97SA4795	1,519	37.2
908	644	RAYMONDVILLE #1	94SB3130	313	36.9
909	274	LA PRYOR	94LA580	341	36.9
910	94	NORTH MERCEDES	94SB3840	722	36.9
911	611	CITRUS CITY	94SB6000	2,386	36.8
912	677	SEAWALL	94CS9450	302	36.7
913	713	RUNGE	94CN4465	367	36.7
914	1116	AB ELM CREEK	97AB4780	549	36.3
915	601	ARANSAS PASS	94CS8270	417	36.3
916	832	SA WALNUT ST	97SA3920	913	36.3
917	1117	HARLINGEN	94SB380	267	36.3
918	558	KINGSVILLE	94CS1670	424	36.2
919	880	SA COKE ST	97SA3905	657	36.2
920	1150	NORTH WESLACO	94SB4830	546	36.2
921	795	CABANISS	94CS820	1,327	36.0
922	208	RODD FIELD	94CS225	2,973	35.7
923	680	ANNA STREET	94LA2250	1,536	35.7
924	958	LA GRULLA	94SB4120	1,571	35.6

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIDI Ranking	2022 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIDI Value
925	659	RIO GRANDE CITY	94SB3220	1,431	35.4
926	413	SA NORTH	97SA3125	1,397	35.3
927	96	CALLICOATTE	94CS8785	1,198	35.2
928	709	AB HARTFORD ST	97AB3815	1,079	35.1
929	400	ELDORADO	97SA2880	369	35.1
930	238	EAGLE PASS CITY	94LA450	893	35.1
931	618	EAST HARRISON	94SB3190	1,474	34.9
932	#N/A	GOODLETT	97AB11780	15	34.6
933	622	ESCONDIDO	94LA3350	2,305	34.5
934	699	AB WALNUT ST	97AB3445	57	34.3
935	619	PEARSALL	94LA9905	440	34.2
936	889	MERKEL	97AB1890	578	34.1
937	1165	SOUTH MCALLEN	94SB3935	508	33.9
938	545	ABILENE PLANT	97AB1570	961	33.8
939	599	DEL RIO CITY	94LA440	1,107	33.8
940	1282	ABILENE PLANT	97AB3175	119	33.7
941	447	MUSTANG ISLAND	94CS8510	534	33.7
942	963	YOUNG	94SB6140	2,627	33.5
943	535	ARANSAS PASS	94CS650	1,219	33.5
944	373	BISHOP	94CS7180	917	33.2
945	1020	HEIGHTS	94LA2390	1,701	32.8
946	780	HARLINGEN	94SB370	1,232	32.8
947	1244	AB REBECCA LANE	97AB5550	709	32.5
948	741	VERNON	97AB1520	727	32.4
949	463	SOUTH SANTA ROSA	94SB7485	1,245	32.3
950	341	SOUTH SANTA ROSA	94SB1215	1,738	32.0
951	641	ABILENE PLANT	97AB1565	277	31.8
952	12	VERHALEN	97SA4460	81	31.7
953	937	WYLIE	97AB6340	787	31.7
954	706	GARCENO	94SB2135	1,571	31.6
955	624	DEL MAR	94LA3440	1,820	31.5
956	582	BUENA VISTA	94LA9385	896	31.3
957	1132	SAND ROAD	97AB5290	808	31.3
958	1135	PEARSALL	94LA5580	856	31.0
959	751	TAYLOR	94SB5H111	719	30.8
960	422	WESLACO UNIT	94SB7455	1,230	30.8
961	991	MUSTANG ISLAND	94CS9470	864	30.7
962	92	ODEM	94CS385	577	30.6
963	262	NORTH ALAMO	94SB3610	2,019	30.6
964	1052	KINGSVILLE	94CS1140	1,124	30.2
965	761	SAN DIEGO	94LA2880	1,341	30.2
966	296	NORTH VICTORIA	94CN7860	1,493	30.2
967	1152	VERNON CITY PLANT	97AB5775	797	30.0
968	679	PETTUS	94CN8210	349	30.0
969	1257	COLLEGE HILLS	97SA4835	499	30.0
970	781	AB MCMURRY	97AB3245	794	30.0
971	1113	AB VOGEL ST	97AB4405	605	29.7
972	962	WASHINGTON STREET	94LA6355	940	29.5
973	322	FOSTER FIELD	94CN8880	297	29.5

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIDI Ranking	2022 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIDI Value
974	824	KENEDY	94CN1970	564	29.4
975	686	KLEIMANN	94CN565	592	29.4
976	919	VALADEZ	94CS3140	2,219	29.3
977	773	THREE RIVERS	94CN2580	120	29.2
978	1256	ESCONDIDO	94LA3775	240	28.9
979	1093	READING	94LA1385	1,358	28.7
980	280	CASA BLANCA	94CS55	875	28.5
981	453	PHARR	94SB1625	391	28.3
982	722	ARCADIA	94CS1360	1,545	28.3
983	843	HOLLY	94CS1950	833	28.3
984	1074	AB MCMURRY	97AB4510	812	28.1
985	1177	SA NORTH	97SA3120	1,149	28.1
986	853	GREGORY	94CS420	475	28.0
987	108	KNIPPA	94LA6535	25	27.9
988	989	AB VOGEL ST	97AB4560	1,453	27.6
989	1110	SA SOUTH	97SA4255	867	27.1
990	77	OZONA	97SA3810	1,152	27.1
991	759	AB MCMURRY	97AB4360	1,081	27.1
992	559	AIRLINE	94CS9605	707	27.1
993	837	PANTERA	94SB1915	1,164	27.1
994	1122	KARNES CITY	94CN2340	785	27.0
995	1084	AILEEN	97AB6435	850	26.8
996	1025	CLOSER	94SB6430	1,032	26.8
997	491	CLYDE	97AB3635	453	26.8
998	1065	SA EMERSON ST	97SA4860	226	26.7
999	628	ASHERTON	94LA5495	590	26.5
1000	1188	SA JACKSON ST	97SA4690	1,132	26.1
1001	140	ALBANY	97AB2029	242	26.1
1002	1224	MILES	97SA4670	392	26.0
1003	1021	BENJAMIN (BEPC)	97AB5680	162	25.9
1004	926	AB OIL MILL	97AB3900	696	25.8
1005	235	NORTH VICTORIA	94CN7770	818	25.8
1006	1189	QUANAH	97AB3530	333	25.6
1007	648	DONNA SKID	94SBTX_B	555	25.6
1008	702	KLEBERG	94CS8140	652	25.5
1009	883	STAMFORD	97AB2835	106	25.5
1010	172	ODEM	94CS375	639	25.5
1011	495	MUNDAY	97AB6715	241	25.4
1012	1094	SINTON	94CS180	235	25.3
1013	1118	ABILENE PLANT	97AB1910	254	25.0
1014	846	VERHALEN	97SA4465	36	25.0
1015	1111	ARANSAS PASS	94CS660	731	24.7
1016	14	TAFT	94CS1260	200	24.6
1017	794	FRIO	94LA1815	1,062	24.3
1018	536	AB ONYX REA	97AB3260	147	24.2
1019	1024	KENEDY	94CN6270	549	24.0
1020	1144	CROWELL	97AB3490	173	23.9
1021	714	AB VOGEL ST	97AB4410	769	23.9
1022	176	VALENTINE	97SA5590	211	23.6

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIDI Ranking	2022 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIDI Value
1023	1285	NEW BLUFFS	97SA3005	340	23.6
1024	1033	RIO GRANDE CITY	94SB3210	2,009	23.2
1025	1300	GIRARD	97AB6260	43	23.1
1026	1235	ROTAN	97AB1865	193	22.9
1027	435	BISHOP	94CS2690	640	22.8
1028	323	TURKEY	97AB2980	335	22.8
1029	132	HAROLD	97AB3055	27	22.7
1030	951	BIG WELLS	94LA2630	32	22.7
1031	1104	WASHINGTON STREET	94LA2470	471	22.7
1032	807	INGLESIDE CITY	94CS2495	273	22.7
1033	573	HEIGHTS	94LA6820	1,929	22.7
1034	218	INGLESIDE CITY	94CS8060	2,711	22.6
1035	1173	ASPERMONT	97AB3380	391	22.5
1036	1209	HEIGHTS	94LA9080	693	22.4
1037	95	FOSTER FIELD	94CN2550	67	22.3
1038	612	DEL RIO CITY	94LA9790	2,372	22.2
1039	571	AIRLINE	94CS8260	1,412	22.1
1040	557	UNITEC	94LA4715	40	22.1
1041	569	DEL RIO CITY	94LA9850	1,053	22.1
1042	142	SAN BENITO	94SB4945	1,736	22.0
1043	633	BALLINGER	97SA4375	1,133	21.5
1044	1148	SA AVENUE N	97SA1695	1,533	21.5
1045	838	BARNHART	97SA590	18	21.4
1046	1001	BAY CITY	94CN6450	162	21.4
1047	307	RESACA	94SB9975	567	21.3
1048	537	SA SOUTHLAND HILLS	97SA5455	1,429	21.3
1049	1191	PADUCAH CITY	97AB1930	572	21.2
1050	981	WYLIE	97AB6495	369	21.2
1051	1230	NEW BLUFFS	97SA7280	1,600	21.1
1052	1051	LAREDO PLANT	94LA8745	766	21.0
1053	255	VERNON CITY PLANT	97AB5770	90	20.8
1054	652	VICTORIA POWER PLANT	94CN8070	599	20.8
1055	588	AFTON	97AB2225	53	20.6
1056	1194	SA EMERSON ST	97SA4630	1,255	20.6
1057	607	NORTH VICTORIA	94CN6390	1,509	20.5
1058	1058	SIERRA VISTA	94LA9900	2,556	20.4
1059	1202	SA SOUTH	97SA3500	566	20.3
1060	1204	ROBERT LEE	97SA4120	549	19.9
1061	992	DUST DEVIL	94LA1495	2,043	19.9
1062	597	RULE	97AB3378	100	19.6
1063	531	ROCKPORT	94CS5930	1,017	19.6
1064	604	HEARN ROAD	94CS9665	682	19.4
1065	1203	AB EAST 12KV	97AB4830	1,003	19.3
1066	1123	AB OIL MILL	97AB2785	320	19.2
1067	719	AB OVER STREET 12KV	97AB3140	741	19.1
1068	912	AB SHELTON ST	97AB3060	1,540	18.9
1069	1030	SOUTH MISSION	94SB3980	1,967	18.8
1070	6	RIO RICO	94SB5050	285	18.7
1071	888	AB OIL MILL	97AB2780	749	18.5

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIDI Ranking	2022 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIDI Value
1072	303	NORTH PADRE ISLAND	94CS7900	2,372	18.4
1073	898	QUANAH	97AB3100	545	18.4
1074	439	SILVER	97SA4295	14	18.4
1075	1155	PRIMERA	94SB5705	1,274	18.2
1076	933	NORTH VICTORIA	94CN1470	479	18.2
1077	560	HASKELL 12KV	97AB3770	461	18.1
1078	1180	BRONTE	97SA3560	229	18.0
1079	606	AB ELM CREEK	97AB4775	925	17.9
1080	34	OZONA	97SA3555	160	17.7
1081	507	HEINES	94CS7875	2,089	17.7
1082	414	WEST MCALLEN	94SB6385	246	17.6
1083	590	HAMILTON ROAD	94LA9665	1,575	17.6
1084	572	HARLINGEN SWITCH	94SB5350	965	17.5
1085	1089	MARFA	97SA1905	1,178	17.3
1086	272	RIO BRAVO	94LA300	808	17.2
1087	1185	KIRKLAND	97AB3545	36	17.1
1088	1086	HIGHLAND	97SA6375	323	17.0
1089	1183	AB ELM CREEK	97AB1810	818	16.9
1090	1213	SHARYLAND	94SB2010	1,150	16.8
1091	851	ARANSAS PASS	94CS9130	454	16.8
1092	1076	SA COKE ST	97SA4910	1,805	16.6
1093	116	HOLLY	94CS1220	3,398	16.1
1094	829	CEDAR GAP (TEC)	97AB5445	518	16.1
1095	1068	SAND ROAD	97AB5655	611	15.9
1096	676	EAGLE PASS CITY	94LA7060	864	15.9
1097	1137	SIERRA VISTA	94LA7170	1,754	15.9
1098	#N/A	SANTO NINO	94LAT000F2	1,889	15.8
1099	801	RAYMONDVILLE #2	94SB1280	1,018	15.8
1100	1072	UNIVERSITY	94LA920	928	15.8
1101	941	MAGRUDER	94CN6680	703	15.7
1102	842	HEIGHTS	94LA2450	2,032	15.5
1103	867	AIRLINE	94CS9030	405	15.3
1104	737	HEINES	94CS2185	1,250	15.3
1105	523	AB ELM CREEK	97AB4745	889	15.2
1106	760	CHOKE CANYON	94CN5390	412	15.1
1107	1120	AB RAINEY CREEK	97AB4270	1,623	15.1
1108	562	MILO	94LA8365	2,143	15.0
1109	697	WEST MCALLEN	94SB4965	946	15.0
1110	995	HEIGHTS	94LA9400	1,485	14.9
1111	793	HEARN ROAD	94CS2220	1,759	14.9
1112	1061	SA JACKSON ST	97SA4260	667	14.8
1113	1114	ROBERT LEE	97SA4125	270	14.6
1114	1172	NORTH EDINBURG	94SB3810	1,704	14.6
1115	872	MINES ROAD	94LA4275	74	14.2
1116	910	HARLINGEN	94SB360	2,419	14.1
1117	1262	COTULLA	94LA110	55	14.0
1118	29	PECOS VALLEY	97SA9615	56	13.8
1119	754	AB OVER STREET 12KV	97AB1645	796	13.8
1120	1159	SAND ROAD	97AB5295	614	13.7

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIDI Ranking	2022 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIDI Value
1121	1063	ZAPATA	94LA8290	986	13.4
1122	718	IRAAN	97SA2050	386	13.4
1123	913	ROCKPORT	94CS5940	68	13.3
1124	1097	VERNON	97AB5000	251	13.2
1125	772	BEN FICKLIN	97SA6180	584	13.2
1126	475	SONORA 138 SUB	97SA4805	344	13.2
1127	1184	MUNDAY	97AB2080	496	13.1
1128	35	ALPINE 12KV	97SA3875	669	13.1
1129	788	AB MCMURRY	97AB3240	764	12.9
1130	1234	AB REBECCA LANE	97AB2710	262	12.6
1131	1017	ZACATE CREEK	94LA2675	1,211	12.5
1132	48	TYNAN	94CS4010	49	12.4
1133	631	WESLACO UNIT	94SB2195	1,113	12.4
1134	983	UNIVERSITY	94LA465	960	12.3
1135	1006	DUST DEVIL	94LA1810	479	12.3
1136	250	TRADE ZONE	94SB1935	42	12.0
1137	1082	SOUTH MISSION	94SB4650	943	11.9
1138	1060	SA LAKE DR	97SA5880	840	11.9
1139	1163	ROMA	94SB3060	1,610	11.7
1140	148	AB RAINEY CREEK	97AB4225	122	11.6
1141	1280	MILES	97SA11330	176	11.6
1142	1161	ASPERMONT	97AB1070	332	11.5
1143	1169	SPUR	97AB260	162	11.5
1144	1175	SA CONCHO	97SA1700	550	11.4
1145	1254	CROCKETT HEIGHTS	97SA73703	65	11.3
1146	1138	AB DYESS 1	97AB1775	931	11.2
1147	1210	PAISANO	97SAPAI SAN	172	11.1
1148	921	SA SOUTHLAND HILLS	97SA5050	900	11.1
1149	1067	TWILIGHT TRAIL	97AB4290	1,169	11.1
1150	712	AB OVER STREET 12KV	97AB1840	879	11.1
1151	887	BALLINGER	97SA4370	778	10.7
1152	270	BEN FICKLIN	97SA6185	758	10.7
1153	118	DILLEY	94LA3795	106	10.6
1154	1098	RODD FIELD	94CS245	709	10.5
1155	1197	KENEDY S.S.	94CN6750	69	10.5
1156	650	COTULLA	94LA610	720	10.4
1157	1112	AB WALNUT ST	97AB3110	662	10.4
1158	1106	STAMFORD	97AB4565	776	10.4
1159	1263	SA JACKSON ST	97SA4695	560	10.3
1160	511	RUSSEK STREET	97SA7705	650	10.3
1161	918	SA JACKSON ST	97SA4265	806	10.3
1162	352	HIGHLAND	97SA6370	270	10.1
1163	1099	ESCONDIDO	94LA1510	742	10.0
1164	1226	HIGHLAND	97SA6380	463	9.8
1165	1273	UNIVERSITY	94LA305	825	9.8
1166	999	TWILIGHT TRAIL	97AB3150	721	9.7
1167	1121	KLEBERG	94CS9395	1,240	9.6
1168	1046	VALADEZ	94CS8800	1,803	9.6
1169	129	ROBY	97AB2276	329	9.4

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIDI Ranking	2022 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIDI Value
1170	974	AIRLINE	94CS9390	1,350	9.3
1171	407	KNOX CITY	97AB3390	373	9.1
1172	1228	TWILIGHT TRAIL	97AB4285	1,113	9.0
1173	1261	TAYLOR	94SBSH112	990	8.9
1174	1156	SA WALNUT ST	97SA3910	148	8.9
1175	105	CASA BLANCA	94CS5440	108	8.9
1176	191	SONORA 138 SUB	97SA4810	872	8.9
1177	1249	CHILDRESS 69	97AB2800	341	8.7
1178	1216	CISCO	97AB6530	529	8.6
1179	902	SANTA ANNA	97SA3420	363	8.5
1180	311	WOOLRIDGE	94CS1110	1,651	8.4
1181	646	NORTH MCCAMEY	97SA6555	801	8.3
1182	940	VERNON	97AB3340	525	8.2
1183	416	STERLING CITY	97SA1445	381	8.2
1184	#N/A	SANTO NINO	94LAT000E5	1,609	8.1
1185	192	BARNHART	97SA3725	135	8.0
1186	967	CHILDRESS 69	97AB1800	540	7.8
1187	1158	WOOLRIDGE	94CS1120	1,638	7.5
1188	755	YOUNG	94SB4435	851	7.5
1189	549	LA PRYOR	94LA2440	190	7.4
1190	391	ABILENE PLANT	97AB1575	608	7.3
1191	834	MCCOLL ROAD	94SB5485	1,059	7.3
1192	170	LA PRYOR	94LA1845	231	7.3
1193	1108	AB EAST 12KV	97AB4825	413	7.3
1194	493	MATADOR	97AB3030	217	7.0
1195	874	AB REBECCA LANE	97AB5555	1,240	7.0
1196	806	JOURDANTON	94LA8725	35	6.9
1197	730	AB SHELTON ST	97AB3045	553	6.8
1198	950	WYLIE	97AB2675	833	6.6
1199	1250	VALERA HUMBLE	97SA7015	80	6.6
1200	1179	JOSLIN POWER PLANT	94CN7915	12	6.5
1201	1255	SA CONCHO	97SA1715	286	6.5
1202	1149	ROCHESTER	97AB3295	206	6.0
1203	610	SANTA RITA	97SA1100	130	6.0
1204	1127	HIGHLAND	97SA6385	1,356	6.0
1205	356	UNIVERSITY	94LA950	1,845	5.8
1206	852	AIRLINE	94CS8890	527	5.8
1207	1215	JAYTON	97AB6125	344	5.7
1208	716	ROWENA	97SA4480	231	5.7
1209	1208	SA SOUTHLAND HILLS	97SA5860	1,197	5.7
1210	668	HAMILTON ROAD	94LA9655	1,332	5.6
1211	#N/A	STEAMBOAT	97AB12505	153	5.5
1212	1043	SA SOUTH	97SA3995	787	5.5
1213	1034	HAMILTON ROAD	94LA9645	305	5.4
1214	1259	SONORA	97SAT000E2	504	5.4
1215	784	NORDHEIM	94CN4275	82	5.4
1216	690	AB SHELTON ST	97AB3040	180	5.3
1217	985	WASHINGTON STREET	94LA2360	201	5.3
1218	1166	EDEN	97SA3195	528	5.111742424

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIDI Ranking	2022 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIDI Value
1219	1192	CLOSNER	94SB7505	813	5.055350554
1220	1296	KENEDY	94CN1960	70	5.014285714
1221	1055	COTULLA	94LA90	1054	4.973434535
1222	1236	KNOX CITY	97AB3985	23	4.956521739
1223	892	SA SOUTH	97SA2595	1078	4.944341373
1224	914	CARRIZO SPRINGS	94LA860	31	4.935483871
1225	1237	SIERRA VISTA	94LA7360	1454	4.625171939
1226	743	LAREDO PLANT	94LA8705	174	4.586206897
1227	1269	EAST HARRISON	94SB3000	548	4.534671533
1228	76	OZONA	97SA4185	729	4.462277092
1229	1279	WEINERT	97AB6490	131	4.458015267
1230	1035	CHILDRESS 69	97AB4865	782	4.457800512
1231	723	AB MCMURRY	97AB4350	735	4.295238095
1232	1298	AB WALNUT ST	97AB3250	11	4.272727273
1233	1251	ALPINE 12KV	97SA6820	771	4.212710765
1234	585	PAULANN	97SA6310	1118	4.18783542
1235	1038	SA EMERSON ST	97SA4625	414	4.130434783
1236	1078	AB REBECCA LANE	97AB6915	1002	3.961077844
1237	269	SWENSON	97AB136	30	3.9
1238	1277	SIERRA VISTA	94LA3540	1240	3.878225806
1239	1268	TALPA ATLANTIC	97SA5180	62	3.870967742
1240	1125	CHILDRESS 20TH ST	97AB5725	668	3.851796407
1241	1102	COLLEGE HILLS	97SA4840	218	3.811926606
1242	996	EDITH HUMBLE	97SA6170	83	3.807228916
1243	415	BENTSEN	94SBSH115	340	3.605882353
1244	1233	AB CANYON ROCK	97AB5025	58	3.189655172
1245	1241	ABILENE PLANT	97AB1915	50	3.08
1246	935	ESPY WELLS	97SA50207	31	3.064516129
1247	1286	NEW BLUFFS	97SA9110	892	2.808295964
1248	547	KENEDY S.S.	94CN8340	309	2.779935275
1249	1142	CISCO	97AB9715	1011	2.601384768
1250	810	MILO	94LA5020	120	2.575
1251	564	SA LAKE DR	97SA6030	651	2.569892473
1252	1176	HEINES	94CS8480	150	2.513333333
1253	1281	SA JACKSON ST	97SA4250	337	2.412462908
1254	642	PANTERA	94SB1105	626	2.356230032
1255	1219	LAS CRUSES	94LA9865	505	2.342574257
1256	1087	AIRLINE	94CS7390	2454	2.103096985
1257	678	ZACATE CREEK	94LA2635	978	2.065439673
1258	1047	PAINT ROCK	97SA5235	138	2
1259	791	CHILDRESS 20TH ST	97AB5720	182	1.89010989
1260	1178	AB SHELTON ST	97AB3145	997	1.856569709
1261	945	TWILIGHT TRAIL	97AB5855	253	1.814229249
1262	268	KEPLER	94CS1700	27	1.740740741
1263	1283	SA COKE ST	97SA4915	177	1.666666667

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIDI Ranking	2022 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIDI Value
1264	1275	PAINT ROCK	97SA1110	65	1.646153846
1265	1242	AB ELM CREEK	97AB1825	218	1.325688073
1266	1301	AILEEN	97AB4600	273	1.274725275
1267	1287	UNIVERSITY	94LA930	92	1.217391304
1268	1274	SA AVENUE N	97SA1975	322	1.102484472
1269	1222	AB HARTFORD ST	97AB3690	171	1.005847953
1270	876	GREGORY	94CS2420	915	0.878688525
1271	#N/A	SANTO NINO	94LAT000G5	2351	0.770735857
1272	771	COLLEGE HILLS	97SA5520	432	0.756944444
1273	946	AILEEN	97AB4605	425	0.661176471
1274	1267	RUSSEK STREET	97SA12295	283	0.650176678
1275	1066	CAUSEWAY	94SB4775	1078	0.594619666
1276	798	GONZALES	97SA14685	1061	0.580584354
1277	1271	EDEN	97SA1780	233	0.454935622
1278	957	SONORA	97SA2045	203	0.443349754
1279	460	RUSSEK STREET	97SA250	782	0.420716113
1280	1168	COLLEGE HILLS	97SA4845	600	0.41
1281	#N/A	GATEWAY	94LA4080	1997	0.402603906
1282	1220	TAYLOR	94SBSH114	624	0.366987179
1283	1284	BENTSEN	94SBSH211	374	0.360962567
1284	581	AIRLINE	94CS5870	993	0.233635448
1285	#N/A	SANTO NINO	94LAT000H2	816	0.101715686
1286	1011	KENEDY S.S.	94CN8320	142	0
1287	1291	VICTORIA POWER PLANT	94CNNETVIC	88	0
1288	672	VICTORIA POWER PLANT	94CNVBROWN	16	0
1289	593	VICTORIA POWER PLANT	94CNVGREEN	29	0
1290	671	VICTORIA POWER PLANT	94CNVRED	44	0
1291	529	MCKENZIE ROAD	94CS150	24	0
1292	855	ODEM	94CS5575	79	0
1293	513	MORRIS STREET	94CSBLACK	82	0
1294	576	MORRIS STREET	94CSBROWN	63	0
1295	543	MORRIS STREET	94CSGREEN	230	0
1296	1295	MORRIS STREET	94CSNET CC	317	0
1297	546	MORRIS STREET	94CSRED	59	0
1298	#N/A	HAISLEY	94CSTX_2_C	13	0
1299	541	MORRIS STREET	94CSYELLOW	45	0
1300	972	DUST DEVIL	94LA1380	62	0
1301	1292	WASHINGTON STREET	94LANETLAR	163	0
1302	969	RAYMONDVILLE #2	94SB5875	28	0
1303	592	MAYBERRY	94SB6450	31	0
1304	966	ASHLAND	94SBSH301	12	0
1305	1193	PEACOCK	97AB1375	43	0
1306	804	ABILENE PLANT	97AB1735	85	0
1307	1229	ABILENE PLANT	97AB1740	17	0
1308	580	AFTON	97AB2355	45	0
1309	392	TRUSCOTT	97AB3845	32	0
1310	1196	SA CONCHO	97SA1725	29	0
1311	868	PONDER KENNEDY	97SA50208	13	0
1312	748	BRONTE AMBASSADOR	97SA6650	15	0

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

2023 SAIDI Ranking	2022 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2023 SAIDI Value
1313	1258	TEX/NEW MEX PIPELINE	97SA9045	16	0

Feeders from last year that are not in this year's list

2022 SAIDI Ranking	Substation Identification	Feeder ID	Reason not in 2023
252	HAISLEY	94CSTX_2_B	COUNT NOW UNDER 10
364	CHASE FIELD	94CN460	COUNT NOW UNDER 10
467	SANTO NINO	94LA515	RETIRED
805	PECAN BAYOU	97AB530	COUNT NOW UNDER 10
854	SANTO NINO	94LA75	RETIRED
955	SANTO NINO	94LA70	RETIRED
1126	SANTO NINO	94LA80	RETIRED
1207	SANTO NINO	94LA695	RETIRED
1243	SANTO NINO	94LA645	RETIRED

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Inc.

INTERRUPTION CAUSES

Provide the percentage of interruptions attributable to each cause.

2023 Reporting Year

Causes of Forced Interruptions	Percentage
Utility-Owned Equipment	45.93%
Weather (including lightning)	20.39%
Vegetation	14.58%
Unknown	11.33%
Animals and Birds	5.29%
People (including cars and farm eqpt)	2.47%
Other	0.01%

The following files are not convertible:

2024 AEP-TX SQR.xls

Please see the ZIP file for this Filing on the PUC Interchange in order to access these files.

Contact centralrecords@puc.texas.gov if you have any questions.