



Filing Receipt

Filing Date - 2024-10-15 12:17:51 PM

Control Number - 56822

Item Number - 195

PUC PROJECT NO. 56822

**INVESTIGATION OF EMERGENCY § PUBLIC UTILITY COMMISSION
PREPAREDNESS AND RESPONSE BY §
UTILITIES IN HOUSTON AND § OF TEXAS
SURROUNDING COMMUNITIES §**

October 15, 2024

**Contact: Peggy Sorum
CenterPoint Energy, Inc
1005 Congress Avenue, Suite 650
Austin, Texas 78701
Tel No: (512) 397-3077
Fax: (512) 397-3050
peggy.sorum@centerpointenergy.com**

TABLE OF CONTENTS

<u>Description</u>	<u>Page</u>
CenterPoint Energy Houston Electric, LLC’s Response to the Public Utility Commission of Texas First Requests for Information, PUC-RFI01-128S Supplemental.....	2
Certificate of Service	3

CENTERPOINT ENERGY HOUSTON ELECTRIC, LLC
PROJECT NO. 56822
INVESTIGATION OF EMERGENCY PREPAREDNESS AND RESPONSE

PUBLIC UTILITY COMMISSION OF TEXAS
REQUEST NO.: PUC-RF101-128S

QUESTION:

Mobile Generation

Please provide the following information on power restoration plans or procedures regarding critical infrastructure facilities.

- b. Did the TDU develop emergency preparedness plans in collaboration with critical infrastructure facilities in its service territory?

ANSWER:

Prior to and in anticipation of events in which TEEEF may be deployed, the Company coordinates with customers and stakeholders to determine any additional critical loads that should be considered, such as cooling or warming centers and health and public safety facilities, the information from which the Company used to perform engineering and operational evaluations such as voltage and phasing compatibility and the availability of physical access and space to determine TEEEF deployment feasibility.

The Company maintains a list of critical loads and utilizes the list in determining potential deployment locations if TEEEF may need to be deployed, along with its TEEEF priority matrix. Additionally, the Company has pre-identified critical infrastructure in the Company's service area such as medical facilities, water treatment facilities, and first responder facilities as potential locations for TEEEF deployment. Please refer to pages 37-38 of the Company's draft document titled "Mobile Generation Load Shed, Load Restoration, and Mutual Assistance Process" that was produced in response to RFI 1-129 for the list of pre-identified critical infrastructure.

SPONSOR:

Eric Easton

RESPONSIVE DOCUMENTS:

None

CERTIFICATE OF SERVICE

I hereby certify that on this 15th day of October 2024, a true and correct copy of the foregoing document was served upon all parties of record by email pursuant to Order Suspending Rules - PUC Docket No. 50664.


