



Filing Receipt

Filing Date - 2025-04-01 01:21:36 PM

Control Number - 57535

Item Number - 19



Public Utility Commission of Texas

Five-Year Report

Required by 16 Texas Admin. Code § 25.97(e)

PROJECT NO. 57535

AFFECTED ENTITY: City of College Station

General Information

Pursuant to 16 Texas Admin. Code § 25.97(e)(1), not later than May 1 every five years, each affected entity that owns or operates overhead transmission facilities greater than 60 kilovolts must submit this report. The first report must be submitted not later than May 1, 2020.

Instructions

Answer all questions, fill-in all blanks, and have the report notarized in the Affidavit.

Affidavit

A representative of the affected entity must swear to and affirm the truthfulness, correctness, and completeness of the information provided by attaching a signed and notarized copy of the Affidavit provided with this form.

Filing Instructions

Submit four copies (an original and three copies) of the completed form and signed and notarized Affidavit to:

Central Records Filing Clerk
Public Utility Commission of Texas
1701 N. Congress Avenue
P.O. Box 13326
Austin, Texas 78711-3326
Telephone: (512) 936-7180

1. Historical five-year reporting period: 2020 - 2024

What percentage of overhead transmission facilities greater than 60 kilovolts did you inspect for compliance with the National Electric Safety Code (NESC) relating to vertical clearance in the historical five-year reporting period?

In 2021, College Station completed tree clearing along College Station's 138 kV transmission right of way. This is completed on a three year cycle.

In 2024, College Station completed tree clearing along College Station's 138 kV transmission right of way. This is completed on a three year cycle.

In December of 2024, a visual inspection was completed by our crews on College Station's 138 kV transmission system which included looking for any encroachments into the right of way.

In the historical five-year reporting period, College Station has inspected 100% of it's overhead transmission facilities greater than 60 kilovolts.

2. Future five-year reporting period: 2025 - 2029

What percentage of overhead transmission facilities greater than 60 kilovolts do you anticipate you will inspect for compliance with the NESC relating to vertical clearance during the future five-year reporting period beginning on January 1 of the year in which this report is submitted?

100%

[Faint, illegible text, possibly a stamp or signature]

Affected Entity: City of College Station

PROJECT NO. 57535

AFFIDAVIT

I swear or affirm that I have personal knowledge of the facts stated in this report or am relying on people with personal knowledge, that I am competent to testify to them, and that I have the authority to submit this report on behalf of the affected entity. I further swear or affirm that all statements made in this report are true, correct, and complete.


Timothy R. Crabb, P.E.
Signature

Timothy R. Crabb, P.E.
Printed Name

Director of Electric Utility
Job Title

City of College Station
Name of Affected Entity

Sworn and subscribed before me this 1 day of April, 2025.
Month Year



Stacy Lee
Notary Public in and For the State of Texas

My commission expires on May 13, 2026