



Control Number: 57535



Item Number: 3



Public Utility Commission of Texas

Five-Year Report

Required by 16 Texas Admin. Code § 25.97(e)

PROJECT NO. 57535

PUBLIC UTILITY
COMMISSION OF TEXAS

JAN 28 2025

AFFECTED ENTITY: LAMB COUNTY ELEC COOP, INC.

General Information

Pursuant to 16 Texas Admin. Code § 25.97(e)(1), not later than May 1 every five years, each affected entity that owns or operates overhead transmission facilities greater than 60 kilovolts must submit this report. The first report must be submitted not later than May 1, 2020.

Instructions

Answer all questions, fill-in all blanks, and have the report notarized in the Affidavit.

Affidavit

A representative of the affected entity must swear to and affirm the truthfulness, correctness, and completeness of the information provided by attaching a signed and notarized copy of the Affidavit provided with this form.

Filing Instructions

Submit four copies (an original and three copies) of the completed form and signed and notarized Affidavit to:

Central Records Filing Clerk
Public Utility Commission of Texas
1701 N. Congress Avenue
P.O. Box 13326
Austin, Texas 78711-3326
Telephone: (512) 936-7180

1. Historical five-year reporting period: 2020-2024

What percentage of overhead transmission facilities greater than 60 kilovolts did you inspect for compliance with the National Electric Safety Code (NESC) relating to vertical clearance in the historical five-year reporting period?

Of the 39 miles of transmission facilities we have visually inspected 100%, 3 times a year, every year. We started measuring vertical clearance Sept. 1 of 2019. We have approximately 10 miles of 69kv inspected.

2. Future five-year reporting period: 2020-2024

What percentage of overhead transmission facilities greater than 60 kilovolts do you anticipate you will inspect for compliance with the NESC relating to vertical clearance during the future five-year reporting period beginning on January 1 of the year in which this report is submitted?

We plan on visually inspecting 100%, 3 times a year. Vertical clearance inspection will be completed by the end of 2020.

AFFIDAVIT

I swear or affirm that I have personal knowledge of the facts stated in this report or am relying on people with personal knowledge, that I am competent to testify to them, and that I have the authority to submit this report on behalf of the affected entity. I further swear or affirm that all statements made in this report are true, correct, and complete.

[Handwritten Signature]
Signature

Michael McDaniel
Printed Name

Manager of Operation Services
Job Title

LAMB COUNTY ELEC COOP, INC.
Name of Affected Entity

Sworn and subscribed before me this 24 day of January, 2015.
Month Year



Tracy Bowman
Notary Public in and For the State of Texas.
My commission expires on 01-11-2017.