



Filing Receipt

Filing Date - 2025-04-25 01:00:22 PM

Control Number - 57535

Item Number - 44



**Customer Driven.
Community Focused.™**

Public Utility Commission of Texas
Central Records
1701 N. Congress Ave.
Austin, Texas 78711

**Project No. 57535 – CY 2025 FIVE-YEAR REPORTS FOR LINE INSPECTION AND
SAFETY UNDER 16 TAC § 25.97 (E)**

Enclosed for filing is the City of Austin d/b/a Austin Energy's Five-Year Report, submitted in Project No. 57535, CY 2025 Five-Year Reports for Line Inspection and Safety Under 16 TAC § 25.97(E). Please contact undersigned counsel with any questions or concerns.

Respectfully submitted,

CITY OF AUSTIN D/B/A AUSTIN ENERGY

/s/ Ariane V. Arth

Ariane V. Arth
Assistant City Attorney
State Bar No. 24098553
ariane.arth@austintexas.gov
City of Austin Law Department
P.O. Box 1088
Austin, Texas 78767-1546
Telephone: (512) 974-3454
Facsimile: (512) 974-1311

Don Ballard
Division Chief, Utilities & Regulatory
State Bar No. 00790259
don.ballard@austintexas.gov
City of Austin Law Department
PO Box 1088
Austin, Texas 78767-1546
Telephone: (512) 974-1770
Facsimile: (512) 974-1311



Public Utility Commission of Texas

Five-Year Report

Required by 16 Texas Admin. Code § 25.97(e)

PROJECT NO. 57535

AFFECTED ENTITY: City of Austin dba Austin Energy

General Information

Pursuant to 16 Texas Admin. Code § 25.97(e)(1), not later than May 1 every five years, each affected entity that owns or operates overhead transmission facilities greater than 60 kilovolts must submit this report. The first report must be submitted not later than May 1, 2020.

Instructions

Answer all questions, fill-in all blanks, and have the report notarized in the Affidavit.

Affidavit

A representative of the affected entity must swear to and affirm the truthfulness, correctness, and completeness of the information provided by attaching a signed and notarized copy of the Affidavit provided with this form.

Filing Instructions

Submit four copies (an original and three copies) of the completed form and signed and notarized Affidavit to:

Central Records Filing Clerk
Public Utility Commission of Texas
1701 N. Congress Avenue
P.O. Box 13326
Austin, Texas 78711-3326
Telephone: (512) 936-7180

1. Historical five-year reporting period: Jan 2020 - Dec 2024

What percentage of overhead transmission facilities greater than 60 kilovolts did you inspect for compliance with the National Electric Safety Code (NESC) relating to vertical clearance in the historical five-year reporting period?

The City of Austin dba Austin Energy (Austin Energy) annually performed visual inspections on 100% of its transmission facilities (greater than 60 kV) during the reporting period. Visual inspections are conducted to identify potential safety and reliability issues, including inspecting for clearance compliance issues.

Austin Energy has collected Light Detection and Ranging (LiDAR) survey data on 100% of its transmission system. Austin Energy has modeled 100% of its transmission system and performed clearance checks using this data. Austin Energy has evaluated 100% of its system using this method during the reporting period.

2. Future five-year reporting period: Jan 2025- Dec 2029

What percentage of overhead transmission facilities greater than 60 kilovolts do you anticipate you will inspect for compliance with the NESC relating to vertical clearance during the future five-year reporting period beginning on January 1 of the year in which this report is submitted?



Austin Energy plans to continue 100% visual inspections annually, and to continue LIDAR verification of clearances for 100% of all new or modified facilities, and as identified for further analysis.

AFFIDAVIT

I swear or affirm that I have personal knowledge of the facts stated in this report or am relying on people with personal knowledge, that I am competent to testify to them, and that I have the authority to submit this report on behalf of the affected entity. I further swear or affirm that all statements made in this report are true, correct, and complete.


SignatureDavid Tomczyszyn
Printed NameVP, Electric System Engineering & Technical Services
Job TitleAustin Energy
Name of Affected Entity

Sworn and subscribed before me this 7 day of April, 25.
Month Year


Notary Public in and For the State of Texas
My commission expires on 6-3-2027